

500 Consumers Road  
North York, Ontario  
M2J 1P8  
PO Box 650  
Scarborough ON M1K 5E3

**Michael Brophy**  
Manager, DSM & Portfolio Strategy  
phone: (416) 495-5538  
fax: (416) 495-5331  
Email: michael.brophy@enbridge.com



Monday March 30, 2009

**VIA EMAIL and Courier**

Ms. Kirsten Walli  
Board Secretary  
Ontario Energy Board  
2300 Yonge Street, 27<sup>th</sup> Floor  
Toronto, Ontario  
M4P 1E4

Dear Ms. Walli:

**Re: Ontario Energy Board (the "Board")**  
**Enbridge Gas Distribution – 2009 DSM Assumptions and MT Revisions**

In accordance with Chapter 5 of the EB-2006-0021 Decision with Reasons, dated August 25, 2006, please find attached an updated package of DSM assumptions. This list is based on best available information and is intended for application to the 2009 program year. The attached list was jointly developed by Enbridge Gas Distribution Inc. ("EGDI" or the "Company") and Union Gas (jointly referred to as the "Utilities"), for the Board's consideration and approval.

In the submission of the 2008 Assumption Update (EB 2008-0384) Enbridge noted that it would be necessary to develop the updated assumption list for 2009 by the end of first quarter in order to provide clear direction for program management in 2009 from the earliest possible point. The Utilities have worked closely together to submit the 2009 Update list in a timely fashion. Early in February, the Board released the proposed assumptions for 2010. The Utilities then set aside consideration of 2009 assumptions and focused on responding jointly to the Board's 2010 proposal. Please refer to EGDI's submission dated March 13, 2009 for issues related to the 2010 Input Assumptions.

The work to submit best available information for the 2010 Assumptions (EB-2008-0346) has made it possible to finalize the submission on the 2009 Assumptions. With the exception of some 2009 specific modifications, the best available information remains the same. The Utilities have filed this submission as soon as possible after the filing of the 2010 response in order to allow the Board the greatest possible flexibility in addressing this 2009 Update. The Utilities have informed their respective Evaluation Audit Committees of this submission. Given that most 2009 measures are similar to the 2010 measures, the Utilities have also been able to consider all information submitted in



the EB-2008-0346 proceeding. However, based on the timing, circumstances did not afford the opportunity to solicit opinions from the EAC on the content of the 2009 submission prior to this filing. A full EAC consultation, in addition to a Board consultation process would have delayed the filing and approval of the 2009 Assumptions until it was too late in the year to base programs on a Board approved set of values. This also would significantly duplicate the Board process on the 2010 assumptions. Enbridge has offered to continue the dialogue with the Evaluation Audit Committee on DSM assumptions in general and to the extent practical, Enbridge would update the Board should a better assumption value become available in the immediate future.

The Utilities have prepared this submission jointly. In the 2010 submissions the Utilities reviewed the Board's proposal, any recently released research, utility experience, and previous approved assumptions, with a view to submitting assumptions based on best available information. For this 2009 Update, the Utilities took the 2010 submission as a starting point with the view that best available information for 2010 should also apply to 2009. Changes were made only where measures applied to one of the years but not both. These measures are listed below:

- high efficiency furnaces: apply only to 2009
- Energy Star for New Homes V3: applies only to 2009
- Tankless water heaters Residential sector: applies only to 2009
- In 2009 spillover is not included for aerators, showerheads, thermostats, pre-rinse valves and custom projects as it is in 2010.

There is one other significant change from the 2010 submission. In the 2010 submission the Utilities responded to the Board's proposal and indicated proposed amendments. Where no amendment was proposed, the Utilities made no comment. Thus, some measures on the Board's 2010 list are not currently offered by the Utilities. In the 2009 Update, only measures which the Utilities are currently offering or plan to offer in 2009 are included.

In addition to the 2009 Assumptions, this submission also includes an update to the Enbridge Market Transformation programs for 2009. In alignment with the Board's Decision in EB-2006-0021, Enbridge has gained experience in market transformation during the period of this current multi-year plan through the offering of a variety of programs. Based on this experience, Enbridge is submitting a revised Market Transformation plan for 2009.

EGDI has not resubmitted all the material from its EB-2008-0346 submission on 2010 Input Assumptions. However, since the process is the same to arrive at best available information for both years, the Board should note that the March 13, 2009 submission is supplementary to this submission.


This submission consists of four parts. The first is an Assumption Table showing all the 2009 Input Assumptions. The Assumption Table includes notes indicating which assumption was changed relative to the 2008 Board approved Assumptions. The



second document is a Table of Measure Life Assumptions for Custom Resource Acquisition Technologies. (A similar table was included with the 2008 Update.) The third document provides Substantiation Sheets for all the 2009 measures listed in the Assumption Table. The fourth document provides a description of the revised Enbridge Market Transformation programs for 2009.

At your earliest convenience, we ask that the Board consider and approve the 2009 Input Assumptions and the 2009 Market Transformation program revisions in order for Enbridge to incorporate it into our delivery.

Yours truly,

A handwritten signature in blue ink that reads "Samuel Jean Adams" with a small "for" written below it.

Michael Brophy  
Manager, DSM & Portfolio Strategy

Encl:

2009 DSM Input Assumptions - March 26, 2009											
Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Equipment Life	Customer Installed	Contractor Installed		
				m3	kWh	L	Years	(i)	(j)	(k)	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
	<b>RESIDENTIAL NEW CONSTRUCTION</b>										
1	Tankless Water Heater	Storage Tank Water	base	237	-	-	20	-	\$694	2%	As approved in EB 2008-0384 and 0385.
2a	Energy Star Home (version 3)	Home built to OBC 2006	weather	1,018	1,450	-	25	-	\$4,701	5%	As approved in EB 2008-0384 and 0385.
2b	Energy Star Home (version 4)	Home built to OBC 2006 as of Jan 1, 2009	weather	881	734	-	25	-	\$4,275	5%	As submitted with 2010 Assumptions.
	<b>RESIDENTIAL EXISTING HOMES</b>										
3a	Enhanced Furnace (ECM only)	Mid-Efficiency Furnace	weather	-65	730	-	18	-	\$550	15%	As per EB-2008-0384 and 0385
3b	Enhanced Furnace (Furnace only) & High Efficiency Furnace	Mid-Efficiency Furnace	weather	385	-	-	18	-	\$650	90%	As per EB 2008-0384 and 0385. Updated to reflect audit recommendation from Summit Blue Study (2007-65%, 2008 - 82%, 2009 - 90%)
4	Faucet Aerator (kitchen, distributed, 1.5 GPM)	Average existing stock, 2.5 GPM	base	38	-	7,797	10	\$1	-	Union 33% EGD 31%	As submitted with 2010 Assumptions. Navigant savings values and updated incremental cost based on EGD purchase costs. Measure life and FR as per EB 2008-0384 and 0385.
5	Faucet Aerator (bathroom, distributed, 1.5 GPM)	Average existing stock, 2.2 GPM	base	10	-	2,004	10	\$1	-	Union 33% EGD 31%	As submitted with 2010 Assumptions. Navigant savings values. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.
6	Low-Flow Showerhead (Per unit, distributed, 1.5 GPM)	Average existing stock, 2.2 GPM	base	33	-	6,334	10	\$4	-	10%	As submitted with 2010 Assumptions. Navigant savings values. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.
7	Low-Flow Showerhead (Per unit, distributed, 1.25 GPM)	Average existing stock, 2.2 GPM	base	60	-	10,570	10	\$4	-	10%	as above
	Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.0 GPM)	2.0 GPM showerhead	base	33	-	8,900	40	-	\$19	40%	no longer applicable
8a	Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.0-2.5 GPM)	2.0 -2.5 GPM showerhead (2.25 GPM)	base	66	-	10,886	10	-	\$19	10%	As submitted with 2010 Assumptions. Updated gas savings based on EGD load research and water savings as per Navigant. Incremental cost based on EGD purchase and installation. Measure life and FR as per EB 2008-0384 and 0385
8b	Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.6 + GPM)	2.6 + GPM showerhead (3.0 GPM)	base	116	-	17,168	10	-	\$19	10%	as above
9	Pipe Insulation	Water Heater w/o pipe insulation	base	25	-	-	10	\$1	\$4	4%	As submitted with 2010 Assumptions. Savings and measure life updated as per Navigant. Incremental costs and FR as per EB 2008-0384 and 0385
10	Programmable Thermostat	Standard Thermostat	weather	146	123	-	15	\$50		43%	As submitted with 2010 Assumptions. Updated using Navigant 2010 gas savings values. Navigant electricity savings adjusted to reflect market penetration of central air conditioning. Incremental cost, measure life and FR as per EB 2008-0384 and 0385.
11	Tankless Water Heater	Storage Tank Water Heater	base	237	-	-	20	-	\$694	2%	As approved in EB 2008-0384 and 0385
12	Reflector Panels	Radiant heat w/o reflector panels	weather	143	-	-	18	-	\$238	0%	As submitted with 2010 Assumptions. Updated incremental costs represent cost of panels + shipping. Savings, measure life and free ridership as per EB 2008-0384 and 0385.

Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Equipment Life	Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Customer Installed		Contractor Installed			
				m3	kWh	L						
	LOW INCOME											
13	Faucet Aerator (kitchen, distributed, 1.5 GPM)	Average existing stock, 2.5 GPM	base	38	-	7,797	10	\$1	-	1%	As submitted with 2010 Assumptions. Navigant savings values and updated incremental cost based on EGD purchase costs. Measure life and FR as per EB 2008-0384 and 0385.	
14	Faucet Aerator (bathroom, distributed, 1.5 GPM)	Average existing stock, 2.2 GPM	base	10	-	2,004	10	\$1	-	1%	As submitted with 2010 Assumptions. Navigant savings values. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.	
15	Low-Flow Showerhead (Per unit, distributed, 1.5 GPM)	Average existing stock, 2.2 GPM	base	33	-	6,334	10	\$4	-	Union: 1% EGD: 5%	As submitted with 2010 Assumptions. Navigant savings values. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.	
16	Low-Flow Showerhead (Per unit, distributed, 1.25 GPM)	Average existing stock, 2.2 GPM	base	60	-	10,570	10	\$4	-	Union: 1% EGD: 5%	as above	
	Low-Flow Showerhead (Per household, Installed, 1.25 GPM)	2.0 GPM showerhead	base	33	-	8,900	40	-	\$15	4%/5%	no longer applicable	
17a	Low-Flow Showerhead (Per household, Installed, 1.25 GPM)	2.0 -2.5 GPM showerhead	base	66	-	10,886	10	-	\$19	Union: 1% EGD: 5%	As submitted with 2010 Assumptions. Updated gas savings based on EGD load research and water savings as per Navigant. Incremental cost based on EGD purchase and installation. Measure life and FR as per EB 2008-0384 and 0385	
17b	Low-Flow Showerhead (Per household, Installed, 1.25 GPM)	2.6 + GPM showerhead	base	116	-	17,168	10	-	\$19	Union: 1% EGD: 5%	as above	
18	Pipe Insulation	Water Heater w/o pipe insulation	base	25	-	-	10	-	\$4	1%	As submitted with 2010 Assumptions. Savings and measure life updated as per Navigant. Incremental costs and FR as per EB 2008-0384 and 0385	
19	Programmable Thermostat	Standard Thermostat	weather	146	123	-	15	-	\$69	1%	As submitted with 2010 Assumptions. Updated using Navigant 2010 gas savings values. Navigant electricity savings adjusted to reflect market penetration of central air conditioning. Incremental cost updated to reflect utility purchase cost plus installation. Measure life and FR as per EB 2008-0384 and 0385.	
20	Weatherization	Existing home sample	weather	1,234	255	-	23	-	\$2,667	0%	As submitted with 2010 Assumptions. Savings and incremental costs updated based on 2 years of program data. Measure life and FR as per EB 2008-0384 and 0385	
	COMMERCIAL NEW BUILDING CONSTRUCTION											
21	Condensing Gas Water Heater	Storage Tank Water Heater	base	1,543	-	-	13	-	\$2,230	5%	As submitted with 2010 Assumptions. Savings, measure life and incremental cost as per Navigant. FR as per EB 2008-0384 and 0385.	
22	Rooftop Unit	Standard Rooftop Unit	weather	300	-	-	15	-	\$375	5%	As submitted with 2010 Assumptions. Updated savings. Measure life and incremental cost as per Navigant. FR as per EB 2008-0384 and 0385.	
23	Tankless Water Heater 50 - 150 USG/day, 84% thermal efficiency	Storage Tank Water Heater 91 gal tank, 80% efficiency	base	221	-	-	20	-	-\$1,570	2%	As submitted with 2010 Assumptions. Savings updated. Incremental cost as per Navigant. Measure life and FR as per EB-2008-0384 and 0385	

Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Equipment Life	Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Customer Installed		Contractor Installed			
24a	Infrared Heaters (0 - 49,999 BTUH)	Unit Heater	weather	m3	kWh	L	Years	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	As submitted with 2010 Assumptions. Electricity savings and incremental costs updated. Gas savings, measure life and FR as per EB-2008-0384 and 0385	
24b	Infrared Heaters (49,9099 - 164,999 BTUH)	Unit Heater	weather	0.0102 m3/BTUH	534	-	20	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	as above	
24c	Infrared Heaters (>165,000 BTUH)	Unit Heater	weather	0.0102 m3/BTUH	833	-	20	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	as above	
25a	Demand Control Kitchen Ventilation (0 - 4999 CFM)	Ventilation without DCKV	weather	3,972	7,190	-	15	-	\$5,000	5%	As submitted with 2010 Assumptions. Savings updated. Measure life as per Navigant. Incremental cost and FR as per E 2008-0384 and 0385.	
25b	Demand Control Kitchen Ventilation (5000 - 9999 CFM)	Ventilation without DCKV	weather	6,467	22,791	-	15	-	\$10,000	5%	as above	
25c	Demand Control Kitchen Ventilation (10000 - 15000 CFM)	Ventilation without DCKV	weather	11,838	40,217	-	15	-	\$15,000	5%	as above	
26	Energy Recovery Ventilators (ERV)	Ventilation without ERV	weather	3.75 m3/CFM	-	-	20	-	\$3.00/CFM	5%	As submitted with 2010 Assumptions. Savings, measure life and incremental costs as per Navigant. FR as per EB 2008-384 and 0385	
27	Heat Recovery Ventilator (HRV)	Ventilation without HRV	weather	3.49 / CFM	-	-	20	-	\$3.40/CFM	5%	As submitted with 2010 Assumptions. Savings and measure life as per Navigant. Incremental costs and FR as per EB 2008-0384 and 0385	
28	Condensing Boilers (90% estimated seasonal efficiency)	Non-condensing Boiler (76% estimated seasonal efficiency)	base	0.0119 m3/BTUH	-	-	25	-	\$12.00/10 <sup>3</sup> BTUH	5%	As submitted with 2010 Assumptions. Incremental cost updated as per Navigant. Savings, measure life and FR as per EB 2008-0384 and 0385	
29	Destratification Fans	No destratification fans	weather	7,020	(123)	-	15	-	\$7,021	10%	As submitted with 2010 Assumptions. Savings updated based on EGD research. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.	
30a	Programmable Thermostats (Warehouse, Recreation, Agriculture, Industrial)	Standard thermostat	weather	674	524	-	15	\$40	-	20%	As submitted with 2010 Assumptions. Savings updated based on 2 sub sectors. Incremental costs as per utility purchase price. Measure life and FR as per EB 2008-038 nd 0385.	
30b	Programmable Thermostats (Other, e.g., Retail, Office)	Standard thermostat	weather	191	246	-	15	\$40	-	20%	as above	
31	Energy Efficient Fryers	Standard fryer	base	916	-546	-	7	\$1,500	-		As submitted with 2010 Assumptions.	
	COMMERCIAL EXISTING BUILDINGS											
31	Condensing Gas Water Heater	Storage Tank Water Heater	base	1,543	-	-	13	-	\$2,230	5%	As submitted with 2010 Assumptions. Savings updated. Measure life and incremental cost as per Navigant. FR as per EB 2008-0384 and 0385	
	2a-Faucet Aerator-	Average Existing Stock	base	44	-	6,520	40	\$2	-	40%	No longer Applicable	
33a	Faucet Aerator (kitchen, installed, 1.5 GPM)	Average existing stock	base	26	-	5,377	10	\$2	-	10%	As submitted with 2010 Assumptions. Navigant savings values. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.	
33b	Faucet Aerator (kitchen, installed, 1.0 GPM)	Average existing stock	base	39	-	8,072	10	\$2	-	10%	As submitted with 2010 Assumptions. Navigant savings values adjusted for 1.0 GPM aerator. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.	



Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Equipment Life	Customer Installed	Contractor Installed		
				m3	kWh	L	Years				
34a	Faucet Aerator (bathroom, installed, 1.5 GPM)	Average existing stock	base	7	-	1,382	10	\$2	-	10%	As submitted with 2010 Assumptions. Navigant savings values. Incremental cost updated to reflect utility purchase. Measure life and FR as per EB 2008-0384 and 0385.
34b	Faucet Aerator (bathroom, installed, 1.0 GPM)	Average existing stock	base	11	-	2,371	10	\$1.50	-	10%	As submitted with 2010 Assumptions. Navigant savings values adjusted for 1.0 GPM aerator. Incremental cost updated to reflect utility purchase. Measure life and FR as per EB 2008-0384 and 0385.
35	High Efficiency Furnace	Mid-Efficiency Furnace	weather	5.1 per 1000 BTUH furnace capacity	-	-	18	-	\$650	17.50%	As per EB 2008-0384 and 0385. This is the last year for this measure due to a change in furnace standards.
	4-Low-Flow Showerhead (Contractor-installed per multi-res. Household)	Average Existing Stock	base	445	-	30,966	40	-	45	40%	No longer Applicable
36	Low-Flow Showerhead (Per unit, distributed, 1.5 GPM)	Average existing stock	base	30	-	5,345	10	\$4	-	10%	As submitted with 2010 Assumptions. Navigant savings updated to reflect percentage of showers taken with efficient units. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.
37	Low-Flow Showerhead (Per unit, distributed, 1.25 GPM)	Average existing stock	base	54	-	8,916	10	\$4	-	10%	as above
38a	Low-Flow Showerhead (Per household, Installed, 1.25 GPM)	2.0 -2.5 GPM showerhead (2.25 GPM)	base	53	-	9,078	10	\$17	-	10%	As submitted with 2010 Assumptions. Navigant savings updated to reflect percentage of showers taken with efficient units. Incremental cost updated to reflect utility purchase and installation costs. Measure life and FR as per EV 2008-0384 and 0385.
38b	Low-Flow Showerhead (Per household, Installed, 1.25 GPM)	2.6 + GPM showerhead and above (3.0GPM)	base	87	-	14,341	10	\$17	-	10%	as above
39a	Low-Flow Showerhead (Per household, Installed, 1.5 GPM)	2.0 -2.5 GPM showerhead (2.25 GPM)	base	28	-	5,197	10	\$17	-	10%	as above
39b	Low-Flow Showerhead (Per household, Installed, 1.5 GPM)	2.6 -3.0 GPM GPM showerhead (2.75 GPM)	base	55	-	9,490	10	\$17	-	10%	as above
39c	Low-Flow Showerhead (Per household, Installed, 1.5 GPM)	3.1 - 3.5 GPM showerhead (3.25 GPM)	base	79	-	13,250	10	\$17	-	10%	as above
39d	Low-Flow Showerhead (Per household, Installed, 1.5 GPM)	3.6 GPM and above (3.6 GPM)	base	91	-	15,114	10	\$17	-	10%	as above
40a	Low-Flow Showerhead (Per household, Installed, 2.0 GPM)	2.6 -3.0 GPM GPM showerhead (2.75 GPM)	base	4	-	1,727	10	\$17	-	10%	As submitted with 2010 Assumptions. Navigant savings updated to reflect 2.0 GPM replacement unit and percentage of showers taken with efficient units. Incremental cost updated to reflect utility purchase and installation costs. Measure life and FR as per EV 2008-0384 and 0385.
40b	Low-Flow Showerhead (Per household, Installed, 2.0 GPM)	3.1 o 3.5 GPM (3.25 GPM)	base	28	-	5,487	10	\$17	-	10%	as above
40c	Low-Flow Showerhead (Per household, Installed, 2.0 GPM)	3.6 GPM and above (3.6 GPM)	base	40	-	7,351	10	\$17	-	10%	as above
41a	Pre-Rinse Spray Nozzle (1.24 GPM) (Full Service)	standard pre-rinse spray nozzle (3.0 GPM)	base	931	-	182,000	5	\$100	-	12.4%	As submitted with 2010 Assumptions. Savings and free ridership adjusted as per Union Gas research with PA Consulting. Measure life and incremental cost as per EB 2008-0384 and 0385.
41b	Pre-Rinse Spray Nozzle (1.24 GPM) (Limited)	standard pre-rinse spray nozzle (3.0 GPM)	base	278	-	55,000	5	\$100	-	12.4%	as above
41c	Pre-Rinse Spray Nozzle (1.24 GPM) (Other)	standard pre-rinse spray nozzle (3.0 GPM)	base	272	-	53,000	5	\$100	-	12.4%	as above

Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Equipment Life	Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Customer Installed		Contractor Installed			
										m3		
42a	Pre-Rinse Spray Nozzle (0.64 GPM) (Full Service)	standard pre-rinse spray nozzle (3.0 GPM)	base	1,286	-	252,000	5	\$88	-	0%	As submitted with 2010 Assumptions. Savings and free ridership adjusted as per Union Gas research with PA Consulting. Incremental cost as per Union Gas purchase price. Measure life as per EB 2008-0384 and 0385.	
42b	Pre-Rinse Spray Nozzle (0.64 GPM) (Limited)	standard pre-rinse spray nozzle (3.0 GPM)	base	339	-	66,400	5	\$88	-	0%	as above	
42c	Pre-Rinse Spray Nozzle (0.64 GPM) (Other)	standard pre-rinse spray nozzle (3.0 GPM)	base	318	-	62,200	5	\$88	-	0%	as above	
43a	Programmable Thermostats (Warehouse, Recreation, Agriculture, Industrial)	Standard thermostat	weather	674	524	-	15	\$40	-	20%	As submitted with 2010 Assumptions. Savings updated based on 2 sub sectors. Incremental costs as per utility purchase price. Measure life and FR as per EB 2008-038 and 0385.	
43b	Programmable Thermostats (Other, e.g., Retail, Office)	Standard thermostat	weather	191	246	-	15	\$40	-	20%	as above	
44	Rooftop Unit	Standard Rooftop Unit	weather	300	-	-	15	-	\$375	5%	As submitted with 2010 Assumptions. Updated savings. Measure life and incremental cost as per Navigant. FR as per EB 2008-0384 and 0385.	
45	Tankless Water Heater 50 - 150 USG/day, 84% thermal efficiency	Storage Tank Water Heater 91 gal tank, 80% efficiency	base	221	-	-	20	-	-\$1,570	2%	As submitted with 2010 Assumptions. Savings updated. Incremental cost as per Navigant. Measure life and FR as per EB-2008-0384 and 0385.	
46a	Enhanced Furnace - up to 299 mbtu/h (ECM only)	Mid-Efficiency Furnace	weather	-0.87 per 1000 BTUH	9.7 per 1000 BTUH	-	18	-	\$550	10%	As per EB 2008-0384 and 0385. This is the last year for this measure due to a change in furnace standards.	
46b	Enhanced Furnace - up to 299 mbtu/h (furnace only)	Mid-Efficiency Furnace	weather	5.1 per 1000 BTUH furnace capacity	-	-	18	-	\$650	30%	as above	
47	Heat Recovery Ventilator (HRV)	Ventilation without HRV	weather	3.77 / CFM	-	-	20	-	\$3.40/CFM	5%	As submitted with 2010 Assumptions. Savings and measure life as per Navigant. Incremental costs and FR as per EB 2008-0384 and 0385.	
48	Energy Recovery Ventilators (ERV)	Ventilation without ERV	weather	3.95 m3/CFM	-	-	20	-	\$3.00/CFM	5%	As submitted with 2010 Assumptions. Savings, measure life and incremental costs as per Navigant. FR as per EB 2008-0384 and 0385.	
49	Condensing Boilers	Non-condensing Boiler (76% estimated seasonal efficiency)	base	0.0119 m3/BTUH	-	-	25	-	\$12.00/10 <sup>3</sup> BTUH	5%	As submitted with 2010 Assumptions. Incremental cost updated as per Navigant. Savings, measure life and FR as per EB 2008-0384 and 0385.	
50a	Infrared Heaters (0 - 49,999 BTUH)	Unit Heater	weather	0.0102 m3/BTUH	236	-	20	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	As submitted with 2010 Assumptions. Electricity savings and incremental costs updated. Gas savings, measure life and FR as per EB-2008-0384 and 0385.	
50b	Infrared Heaters (49,9099 - 164,999 BTUH)	Unit Heater	weather	0.0102 m3/BTUH	534	-	20	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	as above	
50c	Infrared Heaters (>165,000 BTUH)	Unit Heater	weather	0.0102 m3/BTUH	833	-	20	-	\$0.009/10 <sup>3</sup> BTUH/hr	33%	as above	



Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Equipment Life		Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Years	Customer Installed	Contractor Installed				
										m3	kWh		
51a	Demand Control Kitchen Ventilation (0 - 4999 CFM)	Ventilation without DCKV	weather	3,972	7,231	-	15	-	\$5,000	5%	As submitted with 2010 Assumptions. Savings updated. Measure life as per Navigant. Incremental cost and FR as per E 2008-0384 and 0385.		
51b	Demand Control Kitchen Ventilation (5000 - 9999 CFM)	Ventilation without DCKV	weather	10,347	23,051	-	15	-	\$10,000	5%	as above		
51c	Demand Control Kitchen Ventilation (10000 - 15000 CFM)	Ventilation without DCKV	weather	18,941	40,692	-	15	-	\$15,000	5%	as above		
52a	Air Curtains (Single Door)		weather	2,191	172	-	15	-	\$1,650	5%	As submitted with 2010 Assumptions. Gas savings updated as per Navigant. Electricity savings, measure life, incremental cost and FR as per EB 2008-0384 and 0385.		
52b	Air Curtains (Double Door)		weather	4,661	1,023	-	15		\$2,500	5%	as above		
53	Destratification Fans	No destratification fans	weather	7,020	(123)	-	15	-	\$7,021	10%	As submitted with 2010 Assumptions. Savings updated based on EGD research. Measure life, incremental cost and FR as per EB 2008-0384 and 0385.		
54	CEE Qualified Energy Efficient Washers	Conventional top loading washers.	base	222	296	80,000	11	-	\$600	10%	As submitted with 2010 Assumptions. Savings updated based on revised Navigant calculation. Measure life as per Navigant. Incremental cost based on EGD route operator data. FR as per EB 2008-0384 and 0385.		
55a	Prescriptive School Boilers (Elementary)	Space Heating, Hydronic Boiler with Comb. Eff. Of 80%-82%.	base	10,830	-	-	25	-	\$8,646	Union 27% EGD 12%	As submitted with 2010 Assumptions. Savings, measure life and incremental costs as per EB 2008-0384 and 0385. Free ridership as per Board Decision re: 2008 Update.		
55b	Prescriptive School Boilers (Secondary)	Space Heating, Hydronic Boiler with Comb. Eff. Of 80%-82%.	base	43,859	-	-	25	-	\$14,470	Union 27% EGD 12%	as above		
56	Energy Efficient Fryers	Standard fryer	base	916	-546	-	7	\$1,500	-		As submitted with 2010 Assumptions.		
57a	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 300 MBH 83-84% efficient	base	1,075	-	-	25	-	\$3,900	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
57b	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 600 MBH 83-84% efficient	base	1,777	-	-	25	-	\$5,800	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
57c	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1000 MBH 83-84% efficient	base	3,136	-	-	25	-	\$7,400	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
57d	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1500 MBH 83-84% efficient	base	4,317	-	-	25	-	\$5,900	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
58a	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 300 MBH 85-88% efficient	base	1,766	-	-	25	-	\$4,500	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
58b	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 600 MBH 85-88% efficient	base	2,290	-	-	25	-	\$6,000	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		
58c	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1000 MBH 85-88% efficient	base	5,155	-	-	25	-	\$10,300	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential		

Item	Efficient Equipment & Technologies	Base Equipment & Technologies	Load Type	Resource Savings Assumptions				Equipment Life	Incremental Cost		Free Ridership %	Reference
				Natural Gas	Electricity	Water	Customer Installed		Contractor Installed			
										m3		
58d	High Efficiency Boilers (DHW) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1500 MBH 85-88% efficient	base	7,095	-	-	25	-	\$7,400	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
59a	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 300 MBH 83-84% efficient	weather	2,105	-	-	25	-	\$3,900	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
59b	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 600 MBH 83-84% efficient	weather	3,994	-	-	25	-	\$5,800	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
59c	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1000 MBH 83-84% efficient	weather	7,310	-	-	25	-	\$7,400	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
59d	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1500 MBH 83-84% efficient	weather	11,554	-	-	25	-	\$5,900	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
59e	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 2000 MBH 83-84% efficient	weather	16,452	-	-	25	-	\$4,950	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
60a	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 300 MBH 85-88% efficient	weather	3,125	-	-	25	-	\$4,500	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
60b	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 600 MBH 85-88% efficient	weather	5,930	-	-	25	-	\$6,000	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
60c	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1000 MBH 85-88% efficient	weather	10,856	-	-	25	-	\$10,300	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
60d	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 1500 MBH 85-88% efficient	weather	17,157	-	-	25	-	\$7,400	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	
60e	High Efficiency Boilers (Space) Small Commercial, Large Commercial and Multi-residential	higher efficiency boilers 2000 MBH 85-88% efficient	weather	24,431	-	-	25	-	\$7,050	Enbridge: 10/12/20% Union: 10/59/42%	As submitted with 2010 Assumptions. FR for Small Commercial / Large Commercial / Multi-residential	



[illegible]

## Custom Resource Acquisition Technologies

### Measure Life Assumptions March, 2009

	Commercial	Industrial	Multi-residential
<b>Boiler Related</b>			
Boilers – DHW	25 <sup>1</sup>	n/a	25 <sup>1</sup>
Boilers - Industrial Process	n/a	20	n/a
Boilers – Space Heating	25 <sup>1</sup>	25 <sup>1</sup>	25 <sup>1</sup>
Combustion Tune-up	5	5	n/a
Controls	15	15	15
Steam pipe/tank insulation	n/a	15	n/a
Steam trap	13 <sup>3</sup>	13 <sup>3</sup>	n/a
<b>Building Related</b>			
Building envelope	25	25	25
Windows	25	25	25
Greenhouse curtains	na	10	na
Double Poly greenhouse	n/a	5	n/a
<b>HVAC Related</b>			
Dessicant cooling	15	n/a	n/a
Heat Recovery	15	15	n/a
Infra-red heaters	10	10	n/a
Make-up Air	15	15	15
Novitherm panels	15	n/a	15
Furnaces (gas-fired)	18 <sup>2</sup>	n/a	18 <sup>2</sup>
<b>Re-Commissioning</b>	<b>5<sup>4</sup></b>	n/a	<b>5<sup>4</sup></b>
<b>Process Related</b>			
Furnaces (gas-fired)	n/a	18 <sup>2</sup>	n/a

Source: RP-2002-0133 Settlement Proposal, Ex N1, Tab 1, Schedule 1, page 70.  
Board approved in EB-2006-0021.

<sup>1</sup>updated in RP-2006-0001 – Source: ASHRAE

<sup>2</sup>new item - Source: ASHRAE updated in EB-2006-0021

<sup>3</sup>Source: Measure Life of Steam Traps Research Study, Enbridge Gas Distribution, November, 2007.

<sup>4</sup>Source: Measure Life For Retro-Commissioning And Continuous Commissioning Projects, Finn Projects, December, 2008.



## **Appendix B:**

# **Substantiation Documents for 2009 Input Assumptions**

## TABLE OF CONTENTS

<b>RESIDENTIAL NEW CONSTRUCTION.....</b>	<b>4</b>
TANKLESS WATER HEATERS .....	5
ENERGY STAR FOR NEW HOMES (VERSION 3) .....	7
ENERGY STAR FOR NEW HOMES (VERSION 4) .....	8
<b>RESIDENTIAL EXISTING HOMES .....</b>	<b>11</b>
ENHANCED FURNACE.....	12
HIGH EFFICIENCY FURNACE.....	13
1.5 GAL/MIN FAUCET AERATOR (KITCHEN).....	14
1.5 GAL/MIN FAUCET AERATOR (BATHROOM).....	15
1.5 GAL/MIN LOW-FLOW SHOWERHEAD .....	16
1.25 GAL/MIN LOW-FLOW SHOWERHEAD .....	17
1.25 GAL/MIN LOW-FLOW SHOWERHEAD .....	18
PIPE WRAP (R-4).....	23
PROGRAMMABLE THERMOSTAT .....	25
TANKLESS WATER HEATERS .....	26
HEAT REFLECTOR PANELS.....	28
<b>LOW INCOME .....</b>	<b>29</b>
1.5 GAL/MIN FAUCET AERATOR (KITCHEN).....	30
1.5 GAL/MIN FAUCET AERATOR (BATHROOM).....	31
1.5 GAL/MIN LOW-FLOW SHOWERHEAD .....	32
1.25 GAL/MIN LOW-FLOW SHOWERHEAD .....	33
1.25 GAL/MIN LOW-FLOW SHOWERHEAD .....	34
PIPE WRAP (R-4).....	39
PROGRAMMABLE THERMOSTAT .....	41
WEATHERIZATION.....	42
<b>COMMERCIAL NEW BUILDING CONSTRUCTION .....</b>	<b>43</b>
CONDENSING GAS WATER HEATER.....	44
ROOFTOP UNIT .....	47
TANKLESS WATER HEATER .....	48
INFRARED HEATERS .....	50
DEMAND CONTROL KITCHEN VENTILATION (DCKV) .....	52
ENERGY RECOVERY VENTILATOR (ERV).....	54
HEAT RECOVERY VENTILATOR (HRV).....	57
CONDENSING BOILERS.....	60
DESTRATIFICATION FAN .....	61
PROGRAMMABLE THERMOSTAT .....	62
HIGH EFFICIENCY COMMERCIAL FRYER.....	65
<b>COMMERCIAL EXISTING BUILDINGS .....</b>	<b>68</b>
CONDENSING GAS WATER HEATER.....	69
1.5 GAL/MIN FAUCET AERATOR (KITCHEN).....	72
1.0 GAL/MIN FAUCET AERATOR (KITCHEN).....	73
1.5 GAL/MIN FAUCET AERATOR (BATHROOM).....	74
1.0 GAL/MIN FAUCET AERATOR (BATHROOM).....	75
HIGH EFFICIENCY FURNACE (UP TO 299 MBTU/H) .....	76
1.5 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE).....	77
1.25 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE).....	78



1.25 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE).....	79
1.5 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE).....	80
2.0 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE).....	81
PRE-RINSE SPRAY NOZZLE (1.24 GPM).....	82
PRE-RINSE SPRAY NOZZLE (0.64 GPM).....	84
PROGRAMMABLE THERMOSTAT .....	86
ROOFTOP UNIT .....	89
TANKLESS WATER HEATER .....	90
ENHANCED FURNACE (UP TO 299 MBTU/H) .....	92
HEAT RECOVERY VENTILATOR (HRV) .....	93
ENERGY RECOVERY VENTILATOR (ERV) .....	96
CONDENSING BOILERS .....	99
INFRARED HEATERS .....	100
DEMAND CONTROL KITCHEN VENTILATION (DCKV) .....	101
SINGLE AIR DOOR INSTALLATION .....	103
DOUBLE AIR DOOR INSTALLATION .....	104
DESTRATIFICATION FAN .....	105
CEE QUALIFIED CLOTHES WASHER .....	106
PRESCRIPTIVE SCHOOL BOILERS - ELEMENTARY .....	108
PRESCRIPTIVE SCHOOL BOILERS - SECONDARY .....	109
HIGH EFFICIENCY COMMERCIAL FRYER.....	110
HIGHER EFFICIENCY BOILERS – DOMESTIC WATER HEATING.....	113
PRESCRIPTIVE BOILERS –SPACE HEATING .....	115
<b>OTHER MEASURES .....</b>	<b>117</b>
CFL SCREW-IN (13W) .....	118
CFL SCREW-IN (23W) .....	119

## **RESIDENTIAL NEW CONSTRUCTION**

# TANKLESS WATER HEATERS

## Residential New Homes

Efficient Technology & Equipment Description
Tankless water heater (EF = 0.82)
Base Technology & Equipment Description
Storage tank water heater (EF = 0.58)

## Resource Savings Assumptions

Natural Gas	237 m <sup>3</sup>
<p>Natural gas savings claims are based on Exelon Services Report<sup>1</sup>. The consumption data was validated by Energy Technology based on the following:</p> <ol style="list-style-type: none"> <li>1. Hourly gas consumption data for Domestic Hot Water (DHW) from Load Research - 645 m<sup>3</sup>/year</li> <li>2. Calculated average efficiency of sample population using data from Natural Resources Canada (NRCAN) - 55% thermal efficiency</li> <li>3. Calculated average litres of DHW based upon average consumption and efficiencies - 179 L/day</li> <li>4. Used efficiency figures from the Okaloosa study** - 85.4% for tankless</li> <li>5. Adjusted energy requirement for colder city water than in Okaloosa - inlet temperature 8°C instead of 23.3°C</li> <li>6. Calculated gas consumption for tank and tankless water heaters based upon our average DHW usage - 415.9m<sup>3</sup>/year for tankless versus 645m<sup>3</sup>/year as provided by load research</li> </ol> <p>Assumptions:</p> <ol style="list-style-type: none"> <li>1. Load Research sample population is representative of Enbridge Gas Distribution (EGD) franchise</li> <li>2. NRCAN efficiency and market composition data for Ontario adequately approximates the EGD franchise</li> <li>3. Calculated efficiency is comparable or higher for colder inlet water so using the Okaloosa measured efficiencies for EGD city water temperatures is conservative</li> <li>4. The load profile for Okaloosa and EGD approximate each other adequately</li> </ol> <p>As approved in EB 2008-0384 &amp; 0385</p>	
Electricity	kWh
Water	N/A L

## Other Input Assumptions

Equipment Life	20 Years
<p>Tankless water heaters have an estimated service life of 20 years<sup>2</sup>. Approved in EB 2008-0384 &amp; 0385</p>	
Incremental Cost (Contractor Installation)	\$694
<p>To validate/update installation costs, research was conducted by the Channel Consultants and Market Development (with manufacturers), across our franchise area to obtain installed costs for both Power Vented 50-gallon tank-type water heaters and tankless water heaters in the residential sector. Twenty-two contractors/installers were contacted to provide installed costs for both types of natural gas water heating;</p>	

<sup>1</sup> Exelon Services Report, December 2002

<sup>2</sup> C. Aguilar, D.J. White, and David L. Ryan, "Domestic Water Heating and Water Heater Energy Consumption in Canada", CBEEDAC, April 2005

as well one retail outlet was visited to validate installation costs if the water heating equipment were purchased through a big box store.

### **RESULTS**

- This research provided average installed costs of:

Power Vented 50-gallon tank type	
average installed cost	\$1956
Tankless average installed cost	\$3273

- Assuming a purchase of a second conventional tank-type water heater will be required in 12 years\*\*\* at a cost in current dollars of approximately \$623 ( $= \$1956/[1.1^{12}]$ ), the incremental cost of a tankless water heater is  $\$3273 - \$1956 - \$623 = \$694$

As approved in EB 2008-0384 & 0385

### **Free Ridership**

**2 %**

Free ridership rate will remain as filed in EB 2008-0384 & 0385.



## **ENERGY STAR FOR NEW HOMES (VERSION 3)**

### *Residential, New Construction*

<b>Efficient Technology &amp; Equipment Description</b>
Energy Star for New Homes, version 3, qualified home
<b>Base Technology &amp; Equipment Description</b>
New Home built in Ontario, compliant to OBC-2006, prior to January 1, 2009.

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>1018 m<sup>3</sup></b>
Gas savings is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house <sup>3</sup> with London's climate, and another set in North Bay's climate. The sample houses are three houses which represent the mid-range of new homes built in UG Territory. The results were weighted 70% UG South and 30% UG North. The software used for analysis is HOT2000 version 9.34b. This is the same software that is currently in use for application of the EnerQuality Version 3.0 Energy Star Criteria, which is what's mandatory to evaluate homes for ESNH. A mix of 90% AFUE furnace (weighted 80%) and 80% AFUE combo heater (weighted 20%) was assumed as the base case heating system. The upgrade system was a 92% AFUE. A 3.57 ACH50 air leakage was used to describe the simply OBC-2006 houses (default present in HOT2000), which is representative of average new home construction <sup>4</sup>	
<b>Electricity</b>	<b>1450 kWh</b>
Electrical savings is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house <sup>3</sup> with London's climate, and another set in North Bay's climate. The sample houses are three houses which represent the mid-range of new homes built in UG Territory. <sup>3</sup> The results were weighted 70% UG South and 30% UG North. The software used for analysis is HOT2000 version 9.34b. This is the same software that is currently in use for application of the EnerQuality Version 3.0 Energy Star Criteria, which is what's mandatory to evaluate homes for ESNH. A 3.57 ACH50 air leakage was used to describe the simply OBC-2006 houses (default present in HOT2000), which is representative of average new home construction <sup>6</sup>	
<b>Water</b>	<b>n/a L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>25 years</b>
Energy Star homes have an estimated service life of 25 years (before major renovations are expected).	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$4,701</b>
Cost estimates for the upgrade measures were obtained from HVAC Trades and Builders who are actively building energy star homes. The upgrade costs based on a simple average of a new reference house, a 1 storey house, and a 2 storey house <sup>3</sup> .	
<b>Free Ridership</b>	<b>5 %</b>
As recommended by Summit Blue and approved in EB 2008-0384 & 0385	

<sup>3</sup> Based on *Comparison of EnergyStar vs. Ontario Building Code 2006 Energy Use*, spreadsheets, from July and August, 2008, by Bowser Technical Inc.

<sup>4</sup> Conversation with Jennifer Tausman, ESNH files coordinator, NRCAN OEE, July 21, 2008

# ENERGY STAR FOR NEW HOMES (VERSION 4)

## Residential, New Construction

Efficient Technology & Equipment Description
Energy Star for New Homes, version 4, qualified home
Base Technology & Equipment Description
New Home built in Ontario, compliant to OBC-2006 (as of January 1, 2009)

## Resource Savings Assumptions

Natural Gas	881 m <sup>3</sup>
<p>Gas savings is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house with London's climate, and another set in North Bay's climate. The sample houses are three houses which represent the mid-range of new homes built in UG Territory. The results were weighted 70% UG South and 30% UG North.<sup>5</sup> The software used for analysis is HOT2000 version 9.34c with weather file 9.10wthr. A mix of 90% AFUE furnace (weighted 80%) and 80% AFUE combo heater (weighted 20%) was assumed as the base case heating system. A 3.57 ACH50 air leakage was used to describe the simply OBC-2006 houses (default present in HOT2000), which is representative of average new home construction<sup>6</sup>.</p> <p>Most of the following specifications are based on the OBC 2009, specifically section 12.3: Some of the specifications are upgrades in excess of what is actually required in the code. These were established based on observations of what is representative of the market place for certain items. These items are marked with an asterisk.</p> <p><b>Walls</b> - 2x6 @ 16", R20 batt Insulation (Southern)          - 2x6 @ 16" R20 batt Insulation, R5 Code-board sheathing (Northern)          - ½" Gypsum interior          - 3/8" OSB Sheathing          - Brick Veneer</p> <p><b>Roof</b> - 2x4 Attic Truss w R40 Blown Insulation          - ½" Drywall interior on resilient channel</p> <p><b>Basement:</b> - Poured Concrete foundation          - R12 Insulation blanket to within 15" of floor slab</p> <p><b>Windows:</b> Double glazed, single low-E, air fill, metal spacer, vinyl frame</p> <p><b>Ventilation:</b> Exhaust fans (Kitchen &amp; bath) without heat recovery</p> <p><b>Heating:</b> a) Combination Heating System          - hot-water air-handler          - Induced draft fan water heater with spark ignition          (Steady State efficiency = 80%, e.g. Rheem PV75ce)          b) Conventional Heating System*          - 90% AFUE forced air furnace, PSC Blower          The model presumes that 20% of houses are equipped with Combination Heating Systems (code minimum) and the 80% are equipped with Conventional Heating Systems*</p> <p><b>Air Cond:</b> -SEER 13 entry level 410a split system*</p> <p><b>DHW:</b> a) Combination Heating System          - Induced Draft spark ignition 75 usg tank (Rheem PV75ce).          b) Conventional Heating System          - Induced Draft spark ignition 40 usg tank (GSW 5G40)</p> <p><b>Envelope:</b> 3.57 Air changes per hour @ 50 pa. ("Present" air-tightness default in HOT2000)</p> <ul style="list-style-type: none"> <li>General mode in HOT2000 was used. This allows overrides of default ventilation and occupancy</li> </ul>	

<sup>5</sup> Bowser Technical, Inc., Comparison of EnerQuality EnergyStar Version 3.0 & EnergyStar Version 4.0 Vs Ontario Building Code 2009 Energy use, March 10 2009

<sup>6</sup> Jennifer Tausman, ESNH files coordinator, NRCAN OEE, July 21, 2008

values

- The HOT 2000 Weather file “910wthr” was used. This is an older Canadian weather file that is consistent with Hot2000 version 9.34
- Occupancy was assumed to be 2 Adults and 1 child. This models the supposition that family size and average house hold size is less than the EnergyStar baseline of 2 adults and 2 children
- 50 cfm constant ventilation rate was assumed for all houses and for all ventilation systems. This models the supposition that occupants in general do not operate their ventilation systems as intended, rather they tend to under-use them
- 13 SEER air conditioning systems were considered to be installed in all homes. The London area homes were considered to operate with 20% open windows and the North Bay homes were considered to operate with 50% open windows

The following upgrades from the OBC 2009 specification were applied to the three sample homes

### Southern House<sup>7</sup>

**Walls** No upgrade

**Roof** No upgrade

**Basement:** No upgrade

**Windows:** Upgrade to Energy Star Zone C windows

**Ventilation:** Upgrade to simplified HRV (0.65/0.55 efficiency)

**Heating:** Upgrade to 92% AFUE ECM Blower EnergyStar furnace

Supply & return trunk ducts sealed

**Air Cond:** Upgrade to SEER 14 from SEER 13

**DHW:** Upgrade to Instantaneous Gas water heater (Noritz N0751DV, E.F. = 0.83)

**Envelope:** 2.0 Air changes per hour @ 50 pa.

**Electrical:** No Upgrade

### Northern House<sup>8</sup>

**Walls** No upgrade

**Roof** No upgrade

**Basement:** No upgrade

**Windows:** Upgrade to Energy Star Zone C windows

**Ventilation:** Upgrade to simplified HRV (0.65/0.55 efficiency)

**Heating:** Upgrade to 95% AFUE ECM Blower EnergyStar furnace

Supply & return trunk ducts sealed

**Air Cond:** Upgrade to SEER 14 from SEER 13

**DHW:** Upgrade to Instantaneous Gas water heater (Noritz N0751DV, E.F. = 0.83)

**Envelope:** 2.0 Air changes per hour @ 50 pa.

**Electrical:** No Upgrade

**Electricity**

**734 kWh**

<sup>7</sup> The upgrades are based on the EnerQuality Energy-Star for New Homes Technical Specifications Version 4.0 D, February '09 performance compliance method (section 5.1).

<sup>8</sup> The EnerQuality EnergyStar Version 4.0 Prescriptive options are not applicable to homes North of the Muskoka climate zone. Upgrades are based on the performance Compliance Method (section 5.1) as set out in the EnerQuality EnergyStar for New Homes Technical Specification Version 4.0, February '09..

Electrical saving were calculated from the same models as above.	
<b>Water</b>	<b>n/a L</b>

## Other Input Assumptions

<b>Equipment Life</b>	<b>25 years</b>												
Energy Star homes have an estimated life of 25 years (before major renovations are expected).													
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>4275 \$</b>												
<p>Cost estimates for the upgrade measures were obtained from HVAC Trades and Builders who are actively building energy star homes and based on a 70/30 UG South &amp; North. The upgrade cost is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house.</p> <p>The costs assigned to the particular upgrade follow:</p> <p><b>Walls:</b> \$0.0/ft<sup>2</sup> upgrade from R20 to R25 (add codeboard to 2x6 wall)  \$0.30/ft<sup>2</sup> upgrade from R25 to R27.5 (increase codeboard thickness)  s \$0.00/ft<sup>2</sup> upgrade to 2x6 @ 20" c.c. R20 (possible savings)</p> <p><b>Roof:</b> \$0.60/ft<sup>2</sup> upgrade from R40 to R50</p> <p><b>Basement:</b> \$0.20/ft<sup>2</sup> coverage upgrade to R20 full height insulation</p> <p><b>Windows:</b> \$1.00 per square foot of glazed surface upgrade to EnergyStar</p> <p><b>Ventilation:</b> \$1,500 upgrade to simple HRV  \$250 upgrade to 1.5 Sone Bath fan &amp; Interlock</p> <p><b>Heating:</b> \$871 upgrade to 92% afue Energy Star Furnace (ECM Blower)  \$871 upgrade to 95% afue Energy Star Furnace (ECM Blower)  \$250 duct sealing  \$166 saving for furnace size reduction 60 MBH to 50 MBH</p> <p><b>Air Cond.</b> \$61 saving for air conditioner size reduction 2.0 ton to 1.5 ton  \$275 saving for air conditioner size reduction 2.5 ton to 2.0 ton  \$194 upgrade to SEER 14 from SEER 13, 1.5 ton  \$168 upgrade to SEER 14 from SEER 13, 2.0 ton  \$80 upgrade to SEER 14 from SEER 13, 2.5 ton</p> <p><b>DHW:</b> \$218 upgrade to instantaneous gas water heater</p> <p><b>Envelope:</b> \$500 budget for increased air-tightness. This is highly variable from Builder to builder. Some builders will have no incremental costs.</p> <p><b>Electrical:</b> \$2.00 per Compact Fluorescent Bulb</p> <p><b>Consulting:</b> \$500 evaluation, testing, review and file processing.</p> <p><b>Fees:</b> \$125 home enrolment fees.</p> <p>Upgrade costs to ver 4.0</p> <table> <tr> <td><b>1 Storey Southern</b></td><td><b>\$4,324</b></td></tr> <tr> <td><b>1 Storey Northern</b></td><td><b>\$4,324</b></td></tr> <tr> <td><b>2 Storey Southern</b></td><td><b>\$4,292</b></td></tr> <tr> <td><b>2 Storey Northern</b></td><td><b>\$4,198</b></td></tr> <tr> <td><b>Reference House Southern</b></td><td><b>\$4,292</b></td></tr> <tr> <td><b>Reference House Northern</b></td><td><b>\$4,105</b></td></tr> </table>		<b>1 Storey Southern</b>	<b>\$4,324</b>	<b>1 Storey Northern</b>	<b>\$4,324</b>	<b>2 Storey Southern</b>	<b>\$4,292</b>	<b>2 Storey Northern</b>	<b>\$4,198</b>	<b>Reference House Southern</b>	<b>\$4,292</b>	<b>Reference House Northern</b>	<b>\$4,105</b>
<b>1 Storey Southern</b>	<b>\$4,324</b>												
<b>1 Storey Northern</b>	<b>\$4,324</b>												
<b>2 Storey Southern</b>	<b>\$4,292</b>												
<b>2 Storey Northern</b>	<b>\$4,198</b>												
<b>Reference House Southern</b>	<b>\$4,292</b>												
<b>Reference House Northern</b>	<b>\$4,105</b>												
<b>Free Ridership</b>	<b>5 %</b>												
Free Ridership based on EB-2008-0384 and 0385													



## **RESIDENTIAL EXISTING HOMES**

## ENHANCED FURNACE

### Residential Existing Homes

Efficient Technology & Equipment Description
High efficiency furnace with ECM.
Base Technology & Equipment Description
Mid efficiency furnace w/o PSC.

### Resource Savings Assumptions

<b>Natural Gas</b>	
ECM Only	- 65 m <sup>3</sup>
Furnace Only	385 m <sup>3</sup>
Impact on natural gas use from an ECM and the resulting decrease in savings from a high efficiency furnace are based on the Final Report on ECM Motors by the Canadian Centre for Housing Technology. Using the Enbridge high-efficiency furnace savings number of 385m3, the net gas savings are reduced to 320m3. <sup>1</sup>	
<b>Electricity</b>	
ECM Only	730 kWh
Furnace Only	0 kWh
Canadian Centre for Housing Technology – Final Report on the Effects of ECM Furnace Motors on Electricity and Gas Use: Results from the CCHT Research Facility and Projections. <sup>1</sup>	
<b>Water</b>	n/a L

### Other Input Assumptions

<b>Equipment Life</b>	18 years
Enhanced furnaces have an estimated service life of 18 years. <sup>1,2</sup>	
<b>Incremental Cost (Contractor Install)</b>	
ECM Only	\$550
Furnace Only	\$650
Enhanced furnaces have an estimated incremental cost of \$1200. <sup>1</sup>	
<b>Free Ridership (Updated)</b>	
ECM Only	15 %
Furnace Only	90 %
Free Ridership rate recommended by Summit Blue Consulting <sup>3</sup> , excluding spillover.	

<sup>1</sup> Approved in EB 2008-0384 & 0385

<sup>2</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3

<sup>3</sup> “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008

## ***HIGH EFFICIENCY FURNACE***

### *Residential Existing Homes*

<b>Efficient Technology &amp; Equipment Description</b>
High efficiency furnace
<b>Base Technology &amp; Equipment Description</b>
Mid-efficiency furnace

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>385 m<sup>3</sup></b>
Natural gas savings are based on Enbridge research that indicates the average consumption for a mid-efficiency furnace is 2,430 m <sup>3</sup> and 2,045 m <sup>3</sup> for a high efficiency furnace, suggesting annual savings of 385 m <sup>3</sup> as approved in the Decision for the Enbridge 2006 DSM Plan (EB2005-0001). <sup>1</sup>	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>18 years</b>
High efficiency furnaces have an estimated service life of 18 years. <sup>1, 2</sup>	
<b>Incremental Cost (Contractor Install)</b>	<b>\$650</b>
The incremental cost is based on a pricing survey of 15 contractors in the Union Gas franchise area. The single incremental cost number is weighted average of Union Gas South (70%) and Union Gas North (30%) average incremental costs. <sup>1</sup>	
<b>Free Ridership (Updated)</b>	<b>90 %</b>
Free Ridership rate recommended by Summit Blue Consulting <sup>3</sup> , excluding spillover.	

<sup>1</sup> Approved in EB 2008-0384 & 0385

<sup>2</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3

<sup>3</sup> “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008

## 1.5 GAL/MIN FAUCET AERATOR (KITCHEN)

### Residential Existing Homes

Efficient Technology & Equipment Description
Faucet Aerator (Kitchen) (1.5 GPM)
Base Technology & Equipment Description
Average existing stock (2.5 GPM)

### Resource Savings Assumptions

Natural Gas (Updated)	38 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water (Updated)	7,797 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 years
Faucet aerators have an estimated service life of 10 years. <sup>1, 2</sup> As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. Install) (UG/EGD)	\$1
As per utility program costs, bulk purchase of aerators.	
Free Ridership (Updated) (UG/EGD)	33/31 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>3</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-65-68, Feb. 6, 2009.

<sup>2</sup> U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

<sup>3</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.



## 1.5 GAL/MIN FAUCET AERATOR (BATHROOM)

### Residential Existing Homes

Efficient Technology & Equipment Description
Faucet Aerator (Bathroom) (1.5 GPM)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas (Updated)	10 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water (Updated)	2,004 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 Years
Faucet aerators have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385. <sup>1, 2</sup>	
Incremental Cost (Cust. Install) (UG/EGD)	\$1
As per utility program costs, bulk purchase of aerators.	
Free Ridership (Updated) (UG/EGD)	33/31 %
Free Ridership rate recommended by Summit Blue Consulting. As approved in EB 2008-0384 & 0385. <sup>3</sup>	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-61-64, Feb. 6, 2009.

<sup>2</sup> U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

<sup>3</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

## 1.5 GAL/MIN LOW-FLOW SHOWERHEAD

### Residential Existing Homes (Distribution)

Efficient Technology & Equipment Description
Low-flow showerhead (1.5 gal/min)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas	33 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water	6,334 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 Years
Low flow showerheads have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385. <sup>1</sup>	
Incremental Cost (Cust. Install)	\$4
As per utility program costs, bulk purchase of showerheads.	
Free Ridership	10 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>2</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-69-72, Feb. 6, 2009.

<sup>2</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD

*Residential Existing Homes (Distribution)*

Efficient Technology & Equipment Description
Low-flow showerhead (1.25 gal/min)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas	60 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water	10,570 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 Years
Low flow showerheads have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. Install)	\$4
As per utility program costs, bulk purchase of showerheads.	
Free Ridership	10 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>2</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-79-82, Feb. 6, 2009.

<sup>2</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD


### Residential Existing Homes

Efficient Technology & Equipment Description
Low-flow showerhead (1.25 gal/min)
Base Technology & Equipment Description
Average existing stock – see below for flow rates.

### Resource Savings Assumptions

Natural Gas (Updated)	See Below m <sup>3</sup>
<p>Gas savings as per results of EGD load research.</p> <p>Data was analyzed for 69 households pre and post installation of low-flow shower-heads. Data records began on August 31 2007 until December 31 2008 date. Showerheads were installed between 13 August 2008 and 18 October 2008. A simple paired t-test (before-after installation) was used to test for the magnitude and statistical significance of installation effect on consumption.</p> <p>Longitudinal mixed models were used to explore relationships between inputs and low flow showerhead installation on consumption.</p> <p><b>RESULTS</b></p> <p><b>Data Exploration</b></p> <p>A plot of seasonally adjusted consumption (SAC) by time shows that consumption is generally lower after low-flow showerhead installation (red) than before installation (blue). Surprisingly, immediately after installation (close to time 0) there appears to be an initial increase in consumption. But note the decreasing trend in consumption post-installation through time (red).</p>	





### ***Paired T-Tests***

Before-After Test on Seasonally Adjusted Data on 68 Households.

#### **ALL DATA**

#### **paired t-test**

Average hourly difference m <sup>3</sup> /hour	Average daily difference m <sup>3</sup> /day	Average annual difference m <sup>3</sup> /year
0.0102	0.245	89.35

#### **Lower 95% Confidence Bound**

0.0065	0.156	56.94
--------	-------	-------

#### **Upper 95% Confidence Bound**

0.0138	0.331	120.89
--------	-------	--------

### ***Longitudinal Mixed Model***

The T-Test results above do not control for household attributes or time since installation. The following shows predictions from two mixed models explained in the Final Report.

Predictions Derived by comparing low-flow to normal shower heads at the mean value of all other attributes, and the mean value of time pre and post installation.

INTERACTION MODEL						
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW - YES	0.0583	1.399	510.5	0.0533	0.0633	
LOW FLOW - NO	0.0478	1.147	418.8	0.0428	0.0528	
		Daily Savings	0.251			
		Annual Savings	91.7			

### ***Longitudinal Mixed Model: Accounting for Pre-Installation Flow***

We added information on pre-existing showerheads (AVGFLOW) to estimate savings due to low-flow installation by previous showerhead flow-rates.

Three buckets were originally proposed. However, the lowest flow bucket (2.0 gpm or less) had too few observations and are rare in the population of households. Further, Enbridge will not be installing low-flow shower heads in homes with existing low flow heads (less than 2.0 gpm). Therefore two buckets were used instead: 2.0 to 2.5 gpm heads (preflow=1) and greater than 2.5 gpm (preflow=0).

The FREQ Procedure

preflow	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	35	49.30	35	49.30
1	36	50.70	71	100.00

There were statistically significant effects of flow category of pre-existing showerheads on consumption.

The following prediction table shows that savings in consumption is greater for the 2.5 + gpm group of houses (0.316848 per day ) than in the 2.0-2.5 gpm group (0.179616 per day).

Predictions Derived by comparing low-flow to normal shower heads at the mean value of all other attributes, **for homes with pre-existing showerheads 2.0-2.5 gpm.**

**PREFLOW=LOW (2-2.5 SIMPLE MODEL**

Document

gpm)						
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW -NO	0.0517	1.240	452.5	0.0446	0.0587	
LOW FLOW -YES	0.0442	1.060	387.0	0.0370	0.0513	
			Daily Savings	0.180		
			Annual Savings	65.6		
Homes with pre-existing showerheads 2.0-2.5 gpm.						
PREFLOW=HIGH (> 2.5 gpm)		SIMPLE MODEL				
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW -NO	0.0660	1.583	577.8	0.0589	0.0730	
LOW FLOW -YES	0.0528	1.266	462.2	0.0456	0.0599	
			Daily Savings	0.317		
			Annual Savings	115.6		
Participants to be tracked, and gas savings assigned, as per the following table:						
Scenario	Flow Rate of 'OLD' showerhead (GPM)	Flow Rate of 'NEW' showerhead (GPM)	Gas Savings (m3)			
1	2.0-2.5	1.25	65.6			
2	2.6 +	1.25	115.6			
Electricity			n/a kWh			
Water (Updated)			See Below L			
Savings recommended by Navigant Consulting.						

Participants to be tracked, and water savings assigned, as per the following table:

Scenario	Flow Rate of 'OLD' showerhead (GPM)	Flow Rate of 'NEW' showerhead (GPM)	Water Savings (L)
2	2.0-2.5	1.25	10,886
3	2.6 +	1.25	17,168

### Other Input Assumptions

<b>Equipment Life</b>	<b>10 Years</b>
As recommended by Navigant and as approved in EB 2008-0384 & 0385.	
<b>Incremental Cost (Contr. Install)</b>	<b>\$19</b>
As per utility program costs, bulk purchase of showerheads plus cost of installation.	
<b>Free Ridership</b>	<b>10 %</b>
As approved in EB 2008-0384 & 0385.	

## PIPE WRAP (R-4)

### Existing Residential

Efficient Technology & Equipment Description
Insulated hot water pipe for conventional gas storage tank-type hot water heater (R-4).
Base Technology & Equipment Description
Conventional gas storage tank-type hot water heater without pipe wrap (R-1).

### Resource Savings Assumptions

Natural Gas	25 m <sup>3</sup>
<p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>Gas savings calculated using method set out in 2006 Massachusetts study<sup>1</sup> except where noted.</li> <li>Average water heater energy factor: 0.57<sup>2</sup></li> <li>Average household size: 3.1 persons<sup>3</sup></li> <li>Assumed diameter of pipe to be wrapped: 0.75 inches</li> <li>Length of pipe to be wrapped: 6 feet.</li> <li>Surface area of pipe to be wrapped: 1.18 square feet.</li> <li>Ambient temperature around pipes: 16 °C (60 °F)<sup>4</sup></li> <li>Average water heater set point temperature: 54 °C (130 °F)<sup>5</sup></li> <li>Hot water temperature in outlet pipe: 52 °C (125 °F)<sup>6</sup></li> </ul> <p>Annual gas savings calculated as follows:</p> $Savings = \left( \frac{1}{R_{base}} - \frac{1}{R_{eff}} \right) * Sa * (T_{pipe} - T_{amb}) * 24 * 365 * \frac{1}{EF} * 10^{-6} * 27.8$ <p>Where:</p> <p> <math>R_{base}</math> = R-value of base equipment  <math>R_{eff}</math> = R-value of efficient equipment  <math>Sa</math> = Surface area of outlet pipe (ft<sup>2</sup>)  <math>T_{pipe}</math> = Temperature of water in outlet pipe (°F)  <math>T_{amb}</math> = Ambient temperature around pipe (°F)  24 = Hours per day  365 = Days per year  EF = Water heater energy factor  10<sup>-6</sup> = Factor to convert Btu to MMBtu  27.8 = Factor to convert MMBtu to m<sup>3</sup> </p> <p>Gas savings were determined to be 75% over base measure</p> $Percent\ Savings = \frac{(G_{base} - G_{eff})}{G_{base}}$ <p>Where:</p> <p> <math>G_{eff}</math> = Annual natural gas use with efficient equipment, 8 m<sup>3</sup>  <math>G_{base}</math> = Annual natural gas use with base equipment, 33 m<sup>3</sup> </p>	

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>0 L</b>
Navigant has assumed that adopting the measure would not affect the quantity of water consumed.	

### Other Input Assumptions

<b>Equipment Life</b>	<b>10 years</b>
Based on the estimated measure lifetimes used in four other jurisdictions (Iowa - 15 years, Puget Sound Energy - 10 years, Efficiency Vermont – 10 years, and NYSEERDA7 – 10 years) Navigant recommends using an EUL of 10 years.	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$1 / \$4</b>
As per EB-2008-0384, EB-2008-0385, and as per utility bulk purchase price.	
<b>Free Ridership</b>	<b>4 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

<sup>1</sup> RLW Analytics, *Final Market Potential Report Of Massachusetts Owner Occupied 1-4 Unit Dwellings*, July 2006  
[http://www.cee1.org/eval/db\\_pdf/575.pdf](http://www.cee1.org/eval/db_pdf/575.pdf)

<sup>2</sup> Assumption of the Ministry of Energy of Ontario. See Table 4,  
<http://www.energy.gov.on.ca/index.cfm?fuseaction=conservation.guide13>

<sup>3</sup> Summit Blue, *Resource Savings Values in Selected Residential DSM Prescriptive Programs*, June 2008.

<sup>4</sup> RLW Analytics (2006). Given geographic proximity, Massachusetts temperatures used unchanged for Ontario.

<sup>5</sup> As suggested by NRCAN: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>6</sup> From source: "It is common to find a 5 - 10 F temperature drop from the water heater to the furthest fixtures in the house." Chinnery, G. *Policy recommendations for the HERS Community to consider regarding HERS scoring credit due to enhanced effective energy factors of water heaters resulting from volumetric hot water savings due to conservation devices/strategies*, EPA Energy Star for Homes, Sept 2006  
[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Volumetric\\_Hot\\_Water\\_Savings\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Volumetric_Hot_Water_Savings_Guidelines.pdf)



## PROGRAMMABLE THERMOSTAT

### Residential Existing Homes

Efficient Technology & Equipment Description
Programmable thermostat
Base Technology & Equipment Description
Standard thermostat

### Resource Savings Assumptions

Natural Gas (Updated)	146 m <sup>3</sup>
Savings adjustment recommended by Navigant Consulting. <sup>1</sup>	
Electricity (Updated)	123 kWh
Savings adjustment calculated by using a combination of Summit Blue and Navigant assumptions. <sup>1, 2</sup>	
<p>Navigant electricity savings are based on OPA 2009 assumptions of 100% market penetration of central air.<sup>1</sup> Summit Blue reports a penetration rate of 57% for CAC across the province based on information from EGD and NRCan.<sup>2</sup> Using 57% penetration the electricity savings are <math>(44 + (138 * .57) = 122.7 \text{ kWh}</math>.<sup>1,2</sup></p>	
Water	n/a L

### Other Input Assumptions

Equipment Life	15 Years
Equipment life recommended by Summit Blue Consulting and as approved in EB 2008-0384 & 0385. Also recommended by Navigant Consulting. <sup>1</sup>	
Incremental Cost (Contr. Install) (UG/EGD)	\$50
Based on average thermostat cost from Union survey of hardware chains.	
Free Ridership	43 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>3</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-50-53, Feb. 6, 2009.

<sup>2</sup> "Resource Savings Values in Selected DSM Prescriptive Programs", Summit Blue Consulting, pg. 28, June 2008.

<sup>3</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008

## TANKLESS WATER HEATERS

### Residential Existing Homes

Efficient Technology & Equipment Description
Tankless water heater (EF = 0.82)
Base Technology & Equipment Description
Storage tank water heater (EF = 0.58)

### Resource Savings Assumptions

Natural Gas	237 m <sup>3</sup>
<p>Natural gas savings claims are based on Exelon Services Report<sup>9</sup>. The consumption data was validated by Energy Technology based on the following:</p> <ol style="list-style-type: none"> <li>1. Hourly gas consumption data for Domestic Hot Water (DHW) from Load Research - 645 m<sup>3</sup>/year</li> <li>2. Calculated average efficiency of sample population using data from Natural Resources Canada (NRCAN) - 55% thermal efficiency</li> <li>3. Calculated average litres of DHW based upon average consumption and efficiencies - 179 L/day</li> <li>4. Used efficiency figures from the Okaloosa study** - 85.4% for tankless</li> <li>5. Adjusted energy requirement for colder city water than in Okaloosa - inlet temperature 8°C instead of 23.3°C</li> <li>6. Calculated gas consumption for tank and tankless water heaters based upon our average DHW usage - 415.9m<sup>3</sup>/year for tankless versus 645m<sup>3</sup>/year as provided by load research</li> </ol> <p>Assumptions:</p> <ol style="list-style-type: none"> <li>1. Load Research sample population is representative of Enbridge Gas Distribution (EGD) franchise</li> <li>2. NRCAN efficiency and market composition data for Ontario adequately approximates the EGD franchise</li> <li>3. Calculated efficiency is comparable or higher for colder inlet water so using the Okaloosa measured efficiencies for EGD city water temperatures is conservative</li> <li>4. The load profile for Okaloosa and EGD approximate each other adequately</li> </ol> <p>As approved in EB 2008-0384 &amp; 0385</p>	
Electricity	kWh
Water	N/A L

### Other Input Assumptions

Equipment Life	20 Years
<p>Tankless water heaters have an estimated service life of 20 years<sup>10</sup>. Approved in EB 2008-0384 &amp; 0385</p>	
Incremental Cost (Contractor Installation)	\$694
<p>To validate/update installation costs, research was conducted by the Channel Consultants and Market Development (with manufacturers), across our franchise area to obtain installed costs for both Power Vented 50-gallon tank-type water heaters and tankless water heaters in the residential sector. Twenty-two contractors/installers were contacted to provide installed costs for both types of natural gas water heating;</p>	

<sup>9</sup> Exelon Services Report, December 2002

<sup>10</sup> C. Aguilar, D.J. White, and David L. Ryan, "Domestic Water Heating and Water Heater Energy Consumption in Canada", CBEEDAC, April 2005

as well one retail outlet was visited to validate installation costs if the water heating equipment were purchased through a big box store.

### **RESULTS**

- This research provided average installed costs of:

Power Vented 50-gallon tank type	
average installed cost	\$1956
Tankless average installed cost	\$3273

- Assuming a purchase of a second conventional tank-type water heater will be required in 12 years\*\*\* at a cost in current dollars of approximately \$623 ( $= \$1956/[1.1^{12}]$ ), the incremental cost of a tankless water heater is  $\$3273 - \$1956 - \$623 = \$694$

As approved in EB 2008-0384 & 0385

### **Free Ridership**

**2 %**

Free ridership rate will remain as filed in EB 2008-0384 & 0385.

## HEAT REFLECTOR PANELS

### Residential Existing Homes

Efficient Technology & Equipment Description
A saw tooth panel made of clear PVC with a reflective surface placed behind a gas radiator reducing heat lost to poorly insulated exterior walls.
Base Technology & Equipment Description
Existing housing with radiant heat with no reflector panels.

### Resource Savings Assumptions

Natural Gas (Updated)	143 m <sup>3</sup>
As per EB 2008-0384 & 0385 and by Navigant Consulting. <sup>1</sup>	
Electricity	kWh
Water	L

### Other Input Assumptions

Equipment Life	18 Years
Based on average space heat measure life. <sup>1</sup> As approved in EB 2008-0384 & 0385.	
Incremental Cost (Customer Install)	\$238
As per utility program costs. (Cost of panels plus shipping)	
Free Ridership	0 %
Product not currently available to end-use consumers through typical retail channels. As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-39-41, Feb. 6, 2009.

## **LOW INCOME**

## 1.5 GAL/MIN FAUCET AERATOR (KITCHEN)

Low Income (Distributed)

Efficient Technology & Equipment Description
Faucet Aerator (Kitchen) (1.5 GPM)
Base Technology & Equipment Description
Average existing stock (2.5 GPM)

### Resource Savings Assumptions

<b>Natural Gas (Updated)</b>	<b>38 m<sup>3</sup></b>
Savings recommended by Navigant Consulting. <sup>1</sup>	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water (Updated)</b>	<b>7,797 L</b>
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

<b>Equipment Life</b>	<b>10 years</b>
Faucet aerators have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385. <sup>1,2</sup>	
<b>Incremental Cost Customer Install</b>	<b>\$1</b>
As per utility program costs, bulk purchase of aerators.	
<b>Free Ridership</b>	<b>1 %</b>
As per EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-112-115, Feb. 6, 2009.

<sup>2</sup> U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>



## 1.5 GAL/MIN FAUCET AERATOR (BATHROOM)

Low Income (Distributed)

Efficient Technology & Equipment Description
Faucet Aerator (Bathroom) ( 1.5 GPM)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas (Updated)	10 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water (Updated)	2,004 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 years
Faucet aerators have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385.	<sup>1, 2</sup>
Incremental Cost Customer Install	\$1
As per utility program costs, bulk purchase of aerators.	
Free Ridership	1 %
As per EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-108-111, Feb. 6, 2009.

<sup>2</sup> U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

## 1.5 GAL/MIN LOW-FLOW SHOWERHEAD

*Low Income (Distribution)*

Efficient Technology & Equipment Description
Low-flow showerhead (1.5 gal/min)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas	33 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water	6,334 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 Years
Low flow showerheads have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. Install)	\$4
As per utility program costs, bulk purchase of showerheads.	
Free Ridership (UG/EGD)	1/5 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>2</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-69-72, Feb. 6, 2009.

<sup>2</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD

*Low Income (Distribution)*

Efficient Technology & Equipment Description
Low-flow showerhead (1.25 gal/min)
Base Technology & Equipment Description
Average existing stock (2.2 GPM)

### Resource Savings Assumptions

Natural Gas	60 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity	n/a kWh
Water	10,570 L
Savings recommended by Navigant Consulting. <sup>1</sup>	

### Other Input Assumptions

Equipment Life	10 Years
Low flow showerheads have an estimated service life of 10 years. As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. Install)	\$4
As per utility program costs, bulk purchase of showerheads.	
Free Ridership (UG/EGD)	1/5 %
Free Ridership rate recommended by Summit Blue Consulting. <sup>2</sup> As approved in EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-79-82, Feb. 6, 2009.

<sup>2</sup> "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.


## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD

*Low Income (Installed per Household)*

Efficient Technology & Equipment Description
Low-flow showerhead (1.25 gal/min)
Base Technology & Equipment Description
Average existing stock – see below for flow rates.

### Resource Savings Assumptions

Natural Gas (Updated)	See Below m <sup>3</sup>
<p>Gas savings as per results of EGD load research.</p> <p>Data was analyzed for 69 households pre and post installation of low-flow shower-heads. Data records began on August 31 2007 until December 31 2008 date. Showerheads were installed between 13 August 2008 and 18 October 2008. A simple paired t-test (before-after installation) was used to test for the magnitude and statistical significance of installation effect on consumption.</p> <p>Longitudinal mixed models we used to explored relationships between inputs and low flow showerhead installation on consumption.</p> <p><b>RESULTS</b></p> <p><b>Data Exploration</b></p> <p>A plot of seasonally adjusted consumption (SAC) by time shows that consumption is generally lower after low-flow showerhead installation (red) than before installation (blue). Surprisingly, immediately after installation (close to time 0) there appears to be an initial increase in consumption. But note the decreasing trend in consumption post-installation through time (red).</p>	



### ***Paired T-Tests***

Before-After Test on Seasonally Adjusted Data on 68 Households.

#### **ALL DATA**

#### **paired t-test**

Average hourly difference m <sup>3</sup> /hour	Average daily difference m <sup>3</sup> /day	Average annual difference m <sup>3</sup> /year
0.0102	0.245	89.35

#### **Lower 95% Confidence Bound**

0.0065	0.156	56.94
--------	-------	-------

#### **Upper 95% Confidence Bound**

0.0138	0.331	120.89
--------	-------	--------

### ***Longitudinal Mixed Model***

The T-Test results above do not control for household attributes or time since installation. The following shows predictions from two mixed models explained in the Final Report.

Predictions Derived by comparing low-flow to normal shower heads at the mean value of all other attributes, and the mean value of time pre and post installation.

INTERACTION MODEL						
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW - YES	0.0583	1.399	510.5	0.0533	0.0633	
LOW FLOW - NO	0.0478	1.147	418.8	0.0428	0.0528	
		Daily Savings	0.251			
		Annual Savings	91.7			

### ***Longitudinal Mixed Model: Accounting for Pre-Installation Flow***

We added information on pre-existing showerheads (AVGFLOW) to estimate savings due to low-flow installation by previous showerhead flow-rates.

Three buckets were originally proposed. However, the lowest flow bucket (2.0 gpm or less) had too few observations and are rare in the population of households. Further, Enbridge will not be installing low-flow shower heads in homes with existing low flow heads (less than 2.0 gpm). Therefore two buckets were used instead: 2.0 to 2.5 gpm heads (preflow=1) and greater than 2.5 gpm (preflow=0).

The FREQ Procedure

preflow	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	35	49.30	35	49.30
1	36	50.70	71	100.00

There were statistically significant effects of flow category of pre-existing showerheads on consumption.

The following prediction table shows that savings in consumption is greater for the 2.5 + gpm group of houses (0.316848 per day ) than in the 2.0-2.5 gpm group (0.179616 per day).

Predictions Derived by comparing low-flow to normal shower heads at the mean value of all other attributes, **for homes with pre-existing showerheads 2.0-2.5 gpm.**

**PREFLOW=LOW (2-2.5 SIMPLE MODEL**

Document

gpm)						
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW -NO	0.0517	1.240	452.5	0.0446	0.0587	
LOW FLOW -YES	0.0442	1.060	387.0	0.0370	0.0513	
			Daily Savings	0.180		
			Annual Savings	65.6		
Homes with pre-existing showerheads 2.0-2.5 gpm.						
PREFLOW=HIGH (> 2.5 gpm)		SIMPLE MODEL				
MEAN	Average m <sup>3</sup> /hour	Average daily m <sup>3</sup> /day	Average annual m <sup>3</sup> /year	Lower CI m <sup>3</sup> /hour	Upper CI m <sup>3</sup> /hour	
LOW FLOW -NO	0.0660	1.583	577.8	0.0589	0.0730	
LOW FLOW -YES	0.0528	1.266	462.2	0.0456	0.0599	
			Daily Savings	0.317		
			Annual Savings	115.6		
Participants to be tracked, and gas savings assigned, as per the following table:						
Scenario	Flow Rate of 'OLD' showerhead (GPM)	Flow Rate of 'NEW' showerhead (GPM)	Gas Savings (m3)			
1	2.0-2.5	1.25	65.6			
2	2.6 +	1.25	115.6			
Electricity			n/a kWh			
Water (Updated)			See Below L			
Savings recommended by Navigant Consulting.						



Participants to be tracked, and water savings assigned, as per the following table:

Scenario	Flow Rate of 'OLD' showerhead (GPM)	Flow Rate of 'NEW' showerhead (GPM)	Water Savings (L)
2	2.0-2.5	1.25	10,886
3	2.6 +	1.25	17,168

### Other Input Assumptions

<b>Equipment Life</b>	<b>10 Years</b>
As recommended by Navigant and as approved in EB 2008-0384 & 0385.	
<b>Incremental Cost (Contr. Install)</b>	<b>\$19</b>
As per utility program costs, bulk purchase of showerheads plus cost of installation.	
<b>Free Ridership (Union/EGD)</b>	<b>1/5 %</b>
As approved in EB 2008-0384 & 0385.	

## PIPE WRAP (R-4)

### Low-Income Residential - Existing

Efficient Technology & Equipment Description
Insulated hot water pipe for conventional gas storage tank-type hot water heater (R-4).
Base Technology & Equipment Description
Conventional gas storage tank-type hot water heater without pipe wrap (R-1).

### Resource Savings Assumptions

Natural Gas	25 m <sup>3</sup>
<p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>Gas savings calculated using method set out in 2006 Massachusetts study<sup>1</sup> except where noted.</li> <li>Average water heater energy factor: 0.57<sup>2</sup></li> <li>Average household size: 3.1 persons<sup>3</sup></li> <li>Assumed diameter of pipe to be wrapped: 0.75 inches</li> <li>Length of pipe to be wrapped: 6 feet.</li> <li>Surface area of pipe to be wrapped: 1.18 square feet.</li> <li>Ambient temperature around pipes: 16 °C (60 °F)<sup>4</sup></li> <li>Average water heater set point temperature: 54 °C (130 °F)<sup>5</sup></li> <li>Hot water temperature in outlet pipe: 52 °C (125 °F)<sup>6</sup></li> </ul> <p>Annual gas savings calculated as follows:</p> $Savings = \left( \frac{1}{R_{base}} - \frac{1}{R_{eff}} \right) * Sa * (T_{pipe} - T_{amb}) * 24 * 365 * \frac{1}{EF} * 10^{-6} * 27.8$ <p>Where:</p> <p> <math>R_{base}</math> = R-value of base equipment  <math>R_{eff}</math> = R-value of efficient equipment  <math>Sa</math> = Surface area of outlet pipe (ft<sup>2</sup>)  <math>T_{pipe}</math> = Temperature of water in outlet pipe (°F)  <math>T_{amb}</math> = Ambient temperature around pipe (°F)  24 = Hours per day  365 = Days per year  EF = Water heater energy factor  10<sup>-6</sup> = Factor to convert Btu to MMBtu  27.8 = Factor to convert MMBtu to m<sup>3</sup> </p> <p>Gas savings were determined to be 75% over base measure</p> $Percent\ Savings = \frac{(G_{base} - G_{eff})}{G_{base}}$ <p>Where:</p> <p> <math>G_{eff}</math> = Annual natural gas use with efficient equipment, 8 m<sup>3</sup>  <math>G_{base}</math> = Annual natural gas use with base equipment, 33 m<sup>3</sup> </p>	

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>0 L</b>
Navigant has assumed that adopting the measure would not affect the quantity of water consumed.	

### Other Input Assumptions

<b>Equipment Life</b>	<b>10 years</b>
Based on the estimated measure lifetimes used in four other jurisdictions (Iowa - 15 years, Puget Sound Energy - 10 years, Efficiency Vermont – 10 years, and NYSEERDA7 – 10 years) Navigant recommends using an EUL of 10 years.	
<b>Incremental Cost (Contr. Install)</b>	<b>\$ 4</b>
Incremental cost as per utility bulk purchase price plus installation	
<b>Free Ridership</b>	<b>1 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

<sup>1</sup> RLW Analytics, *Final Market Potential Report Of Massachusetts Owner Occupied 1-4 Unit Dwellings*, July 2006  
[http://www.cee1.org/eval/db\\_pdf/575.pdf](http://www.cee1.org/eval/db_pdf/575.pdf)

<sup>2</sup> Assumption of the Ministry of Energy of Ontario. See Table 4,  
<http://www.energy.gov.on.ca/index.cfm?fuseaction=conservation.guide13>

<sup>3</sup> Summit Blue, *Resource Savings Values in Selected Residential DSM Prescriptive Programs*, June 2008.

<sup>4</sup> RLW Analytics (2006). Given geographic proximity, Massachusetts temperatures used unchanged for Ontario.

<sup>5</sup> As suggested by NRCan: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>6</sup> From source: "It is common to find a 5 - 10 F temperature drop from the water heater to the furthest fixtures in the house." Chinnery, G. *Policy recommendations for the HERS Community to consider regarding HERS scoring credit due to enhanced effective energy factors of water heaters resulting from volumetric hot water savings due to conservation devices/strategies*, EPA Energy Star for Homes, Sept 2006  
[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Volumetric\\_Hot\\_Water\\_Savings\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Volumetric_Hot_Water_Savings_Guidelines.pdf)

## PROGRAMMABLE THERMOSTAT

### Low Income

Efficient Technology & Equipment Description
Programmable thermostat
Base Technology & Equipment Description
Standard thermostat

### Resource Savings Assumptions

Natural Gas (Updated)	146 m <sup>3</sup>
Savings recommended by Navigant Consulting. <sup>1</sup>	
Electricity (Updated)	123 kWh
Savings adjustment calculated by using a combination of Summit Blue and Navigant assumptions. <sup>1,2</sup>	
<p>Navigant electricity savings are based on OPA 2009 assumptions of 100% market penetration of central air.<sup>1</sup> Summit Blue reports a penetration rate of 57% for CAC across the province based on information from EGD and NRCan.<sup>2</sup> Using 57% penetration the electricity savings are <math>(44 + (138 * .57) - 122.7 \text{ kWh})</math>.<sup>1,2</sup></p>	
Water	n/a L

### Other Input Assumptions

Equipment Life	15 years
Equipment life recommended by Summit Blue Consulting <sup>2</sup> and as approved in EB 2008-0384 & 0385. <sup>1</sup>	
Incremental Cost (Contr. Install) (UG/EGD)	\$69
As per utility program costs, bulk purchase of thermostats plus cost of installation.	
Free Ridership	1 %
As per EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-100-103, Feb. 6, 2009.

<sup>2</sup> "Resource Savings Values in Selected DSM Prescriptive Programs", Summit Blue Consulting, pg. 28, June 2008.

## WEATHERIZATION

### Low Income

Efficient Technology & Equipment Description
Energy audits to identify and implement the most cost-effective energy retrofit to improve building envelope efficiencies.
Base Technology & Equipment Description
No weatherization.

### Resource Savings Assumptions

Natural Gas (Updated)	1,234 M <sup>3</sup>
Based on the average actual results per participant from the 284 weatherized homes completed in 2007 & 2008.	
Electricity (Updated)	255 kWh
Based on the average actual results per participant from the 284 weatherized homes completed in 2007 & 2008.	
Water	N/A L

### Other Input Assumptions

Equipment Life (Updated)	23 Years
Based on average measure life of measures installed in 61 2007 program participant homes. (EB 2008-0384 & 0385) Measures included attic insulation, wall insulation, door <sup>1</sup> and weather stripping and caulking.	
Incremental Cost (Contr. Install) (Updated)	\$2,667
Based on the average actual results per participant from the 284 weatherized homes completed in 2007 & 2008.	
Free Ridership	0 %
As per Generic Hearing EB 2006-0021 & EB 2008-0384 & 0385.	

<sup>1</sup> Draft Report "Measures and Assumptions for Demand Side Management (DSM) Planning", Navigant Consulting Inc., Ontario Energy Board, Appendix C: Substantiation Sheets, pg. B-1104-106, Feb. 6, 2009.

## **COMMERCIAL NEW BUILDING CONSTRUCTION**

## CONDENSING GAS WATER HEATER

### New Commercial

Efficient Technology & Equipment Description
Condensing Gas Water Heater <sup>11</sup> (95% thermal efficiency), 50 gallons. Resource savings were calculated for 950 <sup>12</sup> USG/day hot water use <sup>13</sup> :
Base Technology & Equipment Description
Conventional storage tank gas water heater <sup>14</sup> (thermal efficiency <sup>15</sup> =80%), 91 gallons.

### Resource Savings Assumptions

Natural Gas	1543 m <sup>3</sup> /Btu/hr
<p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>• Daily hot water draw – 950 USG/day<sup>12</sup></li> <li>• Input rating for efficient and base equipment: 199,000 Btu.</li> <li>• Average water inlet temperature: 7.22 DegC (45 degF)<sup>16, 17</sup></li> <li>• Average water heater set point temperature: 54 degC (130 degF)<sup>18</sup></li> <li>• Stand-by loss of (condensing) Polaris PC 199-50 3NV: 244 Btu/hr.<sup>19</sup></li> <li>• Stand-by loss of (non-condensing) Rheem G91-200: 1,050 Btu/hr.<sup>20</sup></li> </ul> <p>Annual gas savings calculated as follows:</p>	

<sup>11</sup> Locally available commercial condensing gas water heater, trade name: Polaris, model #: PC 199-50  
[http://www.johnwoodwaterheaters.com/pdfs/GSW\\_PolarisSpecSheet.pdf](http://www.johnwoodwaterheaters.com/pdfs/GSW_PolarisSpecSheet.pdf)

<sup>12</sup> as per typical full service restaurant draw (EB-2006-0021, pg 31, Appendix B)

<sup>13</sup> One of the input assumptions required for calculating resource savings for this measure is the stand-by heat loss of storage tank water heaters. Hourly stand-by losses are treated as constant using values drawn from GAMA's *Consumer Directory* (see citation below). This means that marginal percentage gas savings will fall as hot water use rises.

<sup>14</sup> Locally available commercial conventional (non-condensing) gas water heater with the same input rating as the Polaris. Manufacturer: Rheem, model #: G91-200.

<sup>15</sup> Although the required minimum thermal efficiency to be in compliance with ASHRAE 90.1 is 78%, <http://www.energycodes.gov/comcheck/pdfs/404text.pdf>, only an very small percentage of commercial gas water heaters listed in the GAMA *Consumer's Directory of Certified Efficiency Ratings* had a thermal efficiency of less than 80%. [http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)



$$Savings = \left[ W * 8.33 * (T_{out} - T_{in}) * \left( \frac{1}{Eff_{base}} - \frac{1}{Eff_{eff}} \right) + (Stby_{base} - Stby_{eff}) * 24 * 365 \right] * 10^{-6} * 27.8$$

Where:

W = Annual hot water use (gallons)  
8.33 = Energy content of water (Btu/gallon/°F)  
T<sub>out</sub> = Water heater set point temperature (°F)  
T<sub>in</sub> = Water inlet temperature (°F)  
Eff<sub>base</sub> = Thermal efficiency of base equipment  
Eff<sub>eff</sub> = Thermal efficiency of efficient equipment  
10<sup>-6</sup> = Factor to convert Btu to MMBtu  
Stby<sub>base</sub> = Stand-by loss per hour for base equipment (Btu)  
Stby<sub>eff</sub> = Stand-by loss per hour for efficient equipment (Btu)  
24 = Hours per day  
365 = Days per year  
27.8 = Factor to convert MMBtu to m<sup>3</sup>

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>13 years</b>
Studies conducted in two different jurisdictions (Iowa <sup>21</sup> and Washington State <sup>22</sup> ) use an EUL of 13 years, whereas one conducted for Enbridge and Union in 2000 <sup>23</sup> uses an EUL of 15 years. Given that the two most recent studies both use 13 years, 13 years is deemed appropriate.	

<sup>16</sup> Navigant draft report, pg B-224 MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS - February 6, 2009

<sup>17</sup> Chinnery, Glen. Policy Recommendations for the HERS Community to Consider regarding HERS point credit for Waste Water Heat Recovery Devices, EPA, Energy Star for homes, March 2004  
[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Waste\\_Water\\_Heat\\_Recovery\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Waste_Water_Heat_Recovery_Guidelines.pdf)

<sup>18</sup> As suggested by NRCAN: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>19</sup> Consumer's Directory of Certified Efficiency Ratings  
[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf) In this case stand-by losses are constant. Recalculating gas savings using the WHAM algorithm, in which stand-by losses are a function of water draw, results in less than 3% variation over the figures presented above. Lutz, J.D., C.D. Whitehead, A.B. Lekov, G.J. Rosenquist, and D.W. Winiarski. 1999. WHAM: Simplified tool for calculating water heater energy use. ASHRAE Transactions 105 (1): 1005-1015.

<sup>20</sup> Consumer's Directory of Certified Efficiency Ratings  
[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)

<sup>21</sup> Iowa Utilities Board. Docket No. EEP-08-02 MidAmerican Energy Company. Volume IV, Appendix D, Part 1 of 2

<sup>22</sup> Quantec Comprehensive Assessment of Demand-Side Resource Potentials (2008-2027) Prepared for Puget Sound Energy

<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$ 2230</b>
Incremental cost determined from communication with local distributor <sup>24,25</sup>	
<b>Free Ridership</b>	<b>5 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

---

<sup>23</sup> Jacques Whitford Environment Ltd, Prescriptive Incentives for Select Natural Gas Technologies, Sept 2000

<sup>24</sup> Rheem G91-200: \$3,650; Polaris PC 199-50: \$5,880

<sup>25</sup> Navigant Consulting, Draft Report MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS, February 6, 2009, pg 225

## ROOFTOP UNIT

### Commercial New

Efficient Technology & Equipment Description
Two-stage rooftop unit, up to and including 5 tons of cooling (85% efficient)
Base Technology & Equipment Description
Single-stage rooftop unit (80% efficient)

### Resource Savings Assumptions

Natural Gas	300	m <sup>3</sup>
The natural gas savings are estimated from the difference in annual gas consumption from single-stage to two-stage operation. Assuming the base case efficiency of 80% and the gas use for 5 rooftop units is 25,500 M3 <sup>26</sup> , the actual space heating load is 25,500*0.8 = 20,400 M3/y. A system of 85% efficiency would then use 20,400/0.85 = 24,000 for a savings of 1,500 M3 for 5 – 5 ton units or 300 M3 per unit.		
Electricity	n/a	kWh
Water	n/a	L

### Other Input Assumptions

Equipment Life	15	years
As per Navigant Consulting <sup>27</sup> and ASHRAE Handbook, 2008		
Incremental Cost (Cust. / Contr. Install)	-	\$375
The incremental cost of two-stage rooftop units compared with single-stage units is \$250 per unit <sup>26</sup> . Local Canadian manufacturer disclosed an incremental cost of \$500 for 2-stage rooftop units compared to single stage rooftop units. Therefore, an average cost of \$375 is assumed ( (\$250 + \$500) / 2 = \$375). <sup>27</sup>		
Free Ridership	5	%
Free-ridership rate as per EB-2008-0384 and 0385		

<sup>26</sup> "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>27</sup> Navigant rooftop substantiation document, pg B-209 - EB-2008-0346 Ontario Energy Board DSM Assumptions, February 6, 2009

## TANKLESS WATER HEATER

### Commercial – New Build

Efficient Technology & Equipment Description
Tankless Water Heater (84% thermal efficiency (77% adjusted thermal efficiency <sup>30</sup> ), where approximately 50-150 USG/day will be used.
Base Technology & Equipment Description
Conventional storage tank gas water heater (thermal efficiency <sup>28</sup> =80%), 91 gallons <sup>30</sup> .

### Resource Savings Assumptions

Natural Gas	221 m <sup>3</sup>
<p>Resource savings were calculated for 100 USG/day hot water use<sup>29</sup>:</p> <p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>• Daily hot water draw – 100 USG/day</li> <li>• Input rating for efficient and base equipment: 199,000 Btu.</li> <li>• Average water inlet temperature: 7.22 DegC (45 degF)<sup>30 31</sup></li> <li>• Average water heater set point temperature: 54 degC (130 degF)<sup>32</sup></li> <li>• Stand-by loss of (non-condensing) Rheem G91-200: 1,050 Btu/hr.<sup>33</sup></li> </ul> <p>Annual gas savings calculated as follows<sup>30 34</sup>:</p> $Savings = \left[ W * 8.33 * (T_{out} - T_{in}) * \left( \frac{1}{Eff_{base}} - \frac{1}{Eff_{eff}} \right) + (Stby_{base} - Stby_{eff}) * 24 * 365 \right] * 10^{-6} * 27.8$ <p>Where:</p> <ul style="list-style-type: none"> <li>W = Annual hot water use (gallons)</li> <li>8.33 = Energy content of water (Btu/gallon/°F)</li> <li>T<sub>out</sub> = Water heater set point temperature (°F)</li> <li>T<sub>in</sub> = Water inlet temperature (°F)</li> <li>Eff<sub>base</sub> = Thermal efficiency of base equipment</li> <li>Eff<sub>eff</sub> = Thermal efficiency of efficient equipment</li> <li>10<sup>-6</sup> = Factor to convert Btu to MMBtu</li> <li>Stby<sub>base</sub> = Stand-by loss per hour for base equipment (Btu)</li> <li>Stby<sub>eff</sub> = Stand-by loss per hour for efficient equipment (Btu)</li> <li>24 = Hours per day</li> <li>365 = Days per year</li> <li>27.8 = Factor to convert MMBtu to m<sup>3</sup></li> </ul>	

<sup>28</sup> Although the required minimum thermal efficiency to be in compliance with ASHRAE 90.1 is 78%, <http://www.energycodes.gov/comcheck/pdfs/404text.pdf>, only an very small percentage of commercial gas water heaters listed in the GAMA *Consumer's Directory of Certified Efficiency Ratings* had a thermal efficiency of less than 80%. [http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)

<sup>29</sup> One of the input assumptions required for calculating resource savings for this measure is the stand-by heat loss of storage tank water heaters. Hourly stand-by losses are treated as constant using values drawn from GAMA's *Consumer Directory* (see citation below). This means that marginal percentage gas savings will fall as hot water use rises.

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
Equipment life is assumed to be 20 years based on manufacturer literature estimates of over 20 years <sup>35</sup> , Canadian Building Energy End-Use Data and Analysis Centre <sup>36</sup> , Energy Star's High Efficiency Water Heaters brochure <sup>37</sup> , and Energy Star's website <sup>38</sup> .	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>-\$1,570</b>
Commercial tankless water heaters are typically scaled up by unit - a commercial user would likely need several tankless water heaters to replace a single storage tank. The tankless model cited has a maximum flow rate of 4.7 – 7.4 GPM depending on temperature rise required. Any large commercial enterprise would likely require 2 – 3 tankless units to accommodate peak demand. <sup>39</sup> Costs for the two systems were determined to be: • WaiWela PH28CIFS tankless water heater and installation kit = \$2,080 <sup>30, 40</sup> • Rheem G91-200 storage tank water heater = \$3,650 <sup>41, 42, 30</sup>	
<b>Free Ridership</b>	<b>2 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

<sup>30</sup> Navigant draft report, pg B-237 MEASURES AND ASSUMPTIONS FOR DEMAND SIDE

MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS - February 6, 2009

<sup>31</sup> Chinnery, Glen. Policy Recommendations for the HERS Community to Consider regarding HERS point credit for Waste Water Heat Recovery Devices, EPA, Energy Star for homes, March 2004, pg 15

[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Waste\\_Water\\_Heat\\_Recovery\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Waste_Water_Heat_Recovery_Guidelines.pdf)

<sup>32</sup> As suggested by NRCan: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>33</sup> Consumer's Directory of Certified Efficiency Ratings

[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhtr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhtr.pdf)

<sup>34</sup> hot water heating - calculator - tankless comml - March 10 2009.xls

<sup>35</sup> "Introduction to Rinnai Water Heating Product – Course #101", page 7

<sup>36</sup> Canadian Building Energy End-Use Data and Analysis Centre - Domestic Water Heating and Water Heater Energy Consumption in Canada, C. Aguilar, D.J. White, and David L. Ryan, April 2005,

[http://www.ualberta.ca/~cbeedac/publications/documents/domwater\\_000.pdf](http://www.ualberta.ca/~cbeedac/publications/documents/domwater_000.pdf)

<sup>37</sup> Energy Star's High Efficiency Water Heaters brochure,

[http://www.energystar.gov/ia/new\\_homes/features/WaterHtrs\\_062906.pdf](http://www.energystar.gov/ia/new_homes/features/WaterHtrs_062906.pdf) pg 2, March 10, 2009

<sup>38</sup> Energy Star website, [http://www.energystar.gov/index.cfm?c=gas\\_tankless.pr\\_savings\\_benefits](http://www.energystar.gov/index.cfm?c=gas_tankless.pr_savings_benefits), March 10, 2009

<sup>39</sup> A study for Pacific Gas and Electric of a chain casual dining restaurant found peak water draws of up to 20 GPM. Wallace, C. and D. Fisher, Energy Efficiency Potential of Gas-Fired Commercial Hot Water Heating Systems in Restaurants. April 2007

<sup>40</sup> <http://www.tanklesswaterheaters.ca/waiwelaph28ci.html>

<sup>41</sup> From correspondence with local distributor by Navigant Consulting.

<sup>42</sup> Rheem G91-200: \$3,650

## INFRARED HEATERS

### New Building Construction

Efficient Technology & Equipment Description
Infrared Heater, Single Stage or High Intensity
Qualifier/Restriction
OBC 2006 requires infrared heaters for unenclosed spaces excluding loading docks with air curtains. Therefore, infrared heaters are not applicable to these conditions. (Caneta Research, Inc. August, 2008)
Base Technology & Equipment Description
Unit Heater

### Resource Savings Assumptions

Resource Savings Assumptions		
Natural Gas	0.0102 m <sup>3</sup> / Btu/hr	
The infrared heater gas savings were based on the analysis procedures previously created by Agviro Inc. for Union. The analysis was supplemented by adding a 20% over sizing factor on the equipment in the analysis. A generic rate of savings of 0.0102 m <sup>3</sup> / Btu/hr of capacity was determined from this analysis. The single savings number is the weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates.		
Electricity	236 kWh	0-49,999 Btu/hr
	534 kWh	50,000 – 164,999 Btu/hr
	833 kWh	> 165,000 Btu/hr

Electricity savings are determined from the difference in electricity consumption of the infrared heater and a comparable unit heater.

		Blower Motor	Infrared	Operating Hours <sup>43</sup>		Blower Motor	Infrared	Savings
Capacity (BTU/H)		kW	kW	Unit Heater (hrs/yr)	Infrared (hrs/yr)	kWh/yr	kWh/yr	kWh/yr
less than	50,000	0.125	0.031	2405	2044	299	64	236
less than	165,000	0.248	0.031	2405	2044	597	64	534
greater than	165000	0.373	0.031	2405	2044	897	64	833

Electricity based on 1/24 hp Solaronics Radiant Tube heaters.<sup>44</sup>

- Electricity savings = Unit heater capacity x operating hours – Infrared Capacity x operating hours, the savings are summarised above for three ranges of capacities.
- Electricity savings % = Electricity savings (kWh) / Baseline Consumption (kWh)

Water	n/a L
-------	-------

### Other Input Assumptions

Equipment Life	20 years
Infrared Heaters have an estimated service life of 20 years. <sup>45</sup>	
Incremental Cost	\$0.009 / 10 <sup>3</sup> Btu/hr
Local retailers reported an average of \$0.009 / Btu/hr incremental cost as per Navigant's survey of local retailers. <sup>46</sup>	

<sup>43</sup> from "Infrared Analysis (Agviro Replicated).xls", which included UG North & South climates as well as a 20% oversizing factor.

<sup>44</sup> [http://solaronics.thomasnet.com/Asset/SSTG-SSTU-GB\\_200010\\_Spec\\_Sheet.pdf](http://solaronics.thomasnet.com/Asset/SSTG-SSTU-GB_200010_Spec_Sheet.pdf)

<sup>45</sup> "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<b>Free Ridership</b>	<b>33 %</b>
Free Ridership based on EB-2008-0384 and 0385	

---

<sup>46</sup> Navigant Consulting, MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING  
APPENDIX C: SUBSTANTIATION SHEETS - Draft Report, Pg 207

## DEMAND CONTROL KITCHEN VENTILATION (DCKV)

### New Building Construction

Efficient Technology & Equipment Description
Ventilation with DCKV
Base Technology & Equipment Description
Ventilation without DCKV

### Resource Savings Assumptions

Natural Gas	3,972 m3	0 – 4999 CFM
	6,467 m3	5000-9999 CFM
	11,838 m3	10000-15000 CFM

The demand control kitchen ventilation savings were determined using the methodology described in the Detailed Energy Savings Report (www.melinkcorp.com). The savings were generated for three ranges of total range hood exhaust: 0 – 4999 CFM; 5000 – 9999 CFM; and 10,000 – 14,999 CFM. The midpoint of each exhaust range was used to generate the savings (both gas and electrical). The inputs for the savings calculations were supplied by MELINK as typical for each application range.

Assuming the DCKV system is operating 16 hours/day, 7 days/week, 52 weeks/year, at 80% heating efficiency, 2.5 hp motor, and 3.0 COP for cooling,

- Using design weather data from the Outdoor Airload Calculator, baseline net heating loads for exhaust volumes were determined for two locations: London (Union South) and North Bay (Union North)
- Weighted average natural gas savings is calculated by assigning 70% to Union Gas South consumption and 30% to Union Gas North consumption based on the customer population of Union Gas service territories.

These gas values were modified to take into account OBC-2006:

Modified so that 50% of the Makeup Air is conditioned to (i.e., 50% of the exhaust air is offset with unconditioned makeup air) for 5000-9999 CFM and 10000-15000 CFM savings assumptions. The 0-4999 CFM gas savings was unmodified<sup>47, 48</sup>.

		Savings				
			London	North Bay	70/30 blend	
New Building	up to 4999	Natural Gas	3,660	4,699	3,972	m3
		Electricity	7,229	7,098	7,190	kWh
	5000-9,999	Natural Gas	5,960	7,650	6,467	m3
		Electricity	22,855	22,643	22,791	kWh
	10,000-15,000	Natural Gas	10,910	14,004	11,838	m3
		Electricity	40,334	39,945	40,217	kWh

Electricity	7,190 kWh	0 – 4999 CFM
	22,791 kWh	5000-9999 CFM
	40,217 kWh	10000-15000 CFM

(see Natural Gas) All capacity categories were modified to reflect the OBC-2006 increase in minimum efficiency of the air conditioning COP from 3.0 to 3.81 (SEER = 13)<sup>48</sup>

Water	n/a L
-------	-------

<sup>47</sup> from Ontario Building Code (OBC) 2006 via ASHRAE 90.1-2004 clause 6.5.7.1

<sup>48</sup> Caneta Research Inc, Quasi-Tool Changes and Commentary, August, 2008



## Other Input Assumptions

Equipment Life	15 years	
Melink web site states “Each Optic Sensor enclosure has a purge fan that keeps the environment inside the enclosure under a positive air pressure. This prevents contaminated air from entering the sensor unit”. Melink Canada representative George McGrath estimates their system life at 15 years <sup>49</sup> .		
Incremental Cost	\$5,000	0 – 4999 CFM
	\$10,000	5000-9999 CFM
	\$15,000	10000-15000 CFM
Typical costing information was provided by MELINK.		
Free Ridership	5 %	
FR as per 2008-0384 and 0385		

<sup>49</sup> MELINK Canada, February, 2009

## ENERGY RECOVERY VENTILATOR (ERV)

### New Building Construction

Efficient Technology & Equipment Description		
Ventilation with ERV		
Qualifier/Restriction		
1) Restriction for New Building Construction: This measure is not applicable to systems $\geq 5,000$ CFM with $\geq 70\%$ OA ratio because energy recovery is required by Ontario Building Code 2006 2) Restriction for New Building Construction: This measure is not applicable to systems serving health care spaces indicated in <b>Table 1</b> because heat recovery is required by CSA Z317.2-01		
Table 1 - Health Care Spaces Not Eligible		
Anaesthetic gas scavenging	Cart and can washers	Areas using hazardous gases
Animal facilities	Chemical storage	Isolation rooms
Autopsy suite	Cooking facilities	Perchloric hoods
Biohazard and fume hoods	Ethylene oxide	Radioisotope hoods
Base Technology & Equipment Description		
Ventilation without ERV		

### Resource Savings Assumptions

Natural Gas

3.75 m<sup>3</sup> / CFM

- Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.
- For example, input assumptions for a typical Ontario retail store are:

Symbol s	Variable Names	Values	Sourc e
A	Supply air flow (cfm)	500	UG <sup>†</sup>
B	Exhaust air flow (cfm)	500	UG
C	Average indoor air temperature (°F)	70	UG
D	Average indoor relative humidity (%)	30	UG
E	Average outside air temperature (°F)	31.5	UG
F	Average outdoor relative humidity (%)	70	NCI <sup>Δ</sup>
G	Atmospheric pressure (psia)	14.3	UG
H	No. of hours in heating season (hrs)	4,800	UG
I1	Demand Controlled Ventilation	no	UG
I2	No. of hours of operation per week (hrs/wk)	108	UG
J	Make and Model of Heat Recovery Equipment	Eng A, HRW-2100	UG
K	Effectiveness of Heat Recovery Equipment (%)	60	NCI
L	Sensible Heat Recovery Only	no	UG
M	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET exhaust air	22.0	UG
N	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET supply air	10.4	UG
O	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of OUTLET supply air	17.3	UG
P	Average Temperature of OUTLET supply air (°F)	55	UG
Q	Average Hourly Moisture Addition (lb/hr)	2.6	UG
R	Defrost Control Derating Factor (%)	5	UG
S	Average Hourly Heat Recovery (MBH)	14.7	UG

U	Average annual gas reduction (m3)	1,571	UG
V	Incremental natural gas rate (\$/m3)	0.3	UG
W	Average annual gas savings (\$)	471.3	UG

<sup>†</sup>UG: Union Gas

<sup>Δ</sup>NCI: Navigant Consulting, Inc

**NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery /

(35.3 m<sup>3</sup>/MJ) / (Seasonal Efficiency / 100%) **(A)**

- 168 hour = 7 days/week x 24hours/day

Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor<sup>50</sup> %) **(B)**

- Operating hours for each sectors being considered are as the following

Building Occupancy	Typical Hrs of Operation per week
Hotel	168
Restaurant	108
Retail	108
Office	60
School	84
Health Care	168
Nursing Home	168
Warehouse	168

- New buildings and existing buildings mainly differ in the enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula (B).
- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated, and a simple average is taken to be the general savings.

Market Segment	ERV Capacity (CFM)	Existing Buildings	
		NG Savings (m3)	NG Savings per CFM (m3/CFM)
Hotel	500	2,444	4.89
Restaurant	500	1,571	3.14
Retail	500	1,571	3.14
Office	500	873	1.75
School	500	1,222	2.44
Health Care	500	2,444	4.89
Nursing Home	500	2,444	4.89
Warehouse	500	2,444	4.89
<b>Average (m3/CFM)</b>			<b>3.75</b>

**Electricity**

**n/a kWh**

<sup>50</sup> From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

<b>Water</b>	<b>n/a L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
ERVs originally had an estimated service life of 15 years based on Jacques Whitford study <sup>51</sup> . Questar Gas <sup>52</sup> and Puget Sound <sup>53</sup> which are newer studies both report 20 years as an ERV's effective useful life. Union Gas and Enbridge Gas Distribution estimate 20 years as an effective useful life for ERVs.	
<b>Incremental Cost</b>	<b>\$3 / CFM</b>
The incremental costs are based on communication with local contractors <sup>54</sup> .	
<b>Free Ridership</b>	<b>5 %</b>
Free ridership is based on EB-2008-0384 and 0385.	

<sup>51</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>52</sup> Questar Gas, DSM Market Characterization Report, by Nexant, August 9, 2006

<sup>53</sup> Quantec — Puget Sound Energy Demand-Side Management Resource Assessment

<sup>54</sup> Navigant Consulting Inc., Draft Report MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS, FEBRUARY 6, 2009

## HEAT RECOVERY VENTILATOR (HRV)

### New Building Construction

#### Efficient Technology & Equipment Description

Ventilation with HRV

- 1) Restriction for New Building Construction: This measure is not applicable to systems  $\geq 5,000$  CFM with  $\geq 70\%$  OA ratio because energy recovery is required by Ontario Building Code 2006
- 2) Restriction for New Building Construction: This measure is not applicable to systems serving health care spaces indicated in Table 1 because heat recovery is required by CSA Z317.2-01

**Table 1 - Health Care Spaces Not Eligible**

Anaesthetic gas scavenging	Cart and can washers	Areas using hazardous gases
Animal facilities	Chemical storage	Isolation rooms
Autopsy suite	Cooking facilities	Perchloric hoods
Biohazard and fume hoods	Ethylene oxide	Radioisotope hoods

#### Base Technology & Equipment Description

Ventilation without HRV

### Resource Savings Assumptions

Natural Gas

3.49 m<sup>3</sup> / CFM

- Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.
- For example, input assumptions for a typical Ontario retail store are:

Symbol s	Variable Names	Values	Source
A	Supply air flow (cfm)	500	UG <sup>†</sup>
B	Exhaust air flow (cfm)	500	UG
C	Average indoor air temperature (°F)	70	UG
D	Average indoor relative humidity (%)	30	UG
E	Average outside air temperature (°F)	31.5	UG
F	Average outdoor relative humidity (%)	70	NCI <sup>Δ</sup>
G	Atmospheric pressure (psia)	14.3	UG
H	No. of hours in heating season (hrs)	4,800	UG
I1	Demand Controlled Ventilation	no	UG
I2	No. of hours of operation per week (hrs/wk)	108	UG
J	Make and Model of Heat Recovery Equipment	Eng A, HRW-2100	UG
K	Effectiveness of Heat Recovery Equipment (%)	70	NCI
L	Sensible Heat Recovery Only	yes	UG
M	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET exhaust air	22.0	UG
N	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET supply air	10.4	UG
O	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of OUTLET supply air	16.9	UG
P	Average Temperature of OUTLET supply air (°F)	58	UG
Q	Average Hourly Moisture Addition (lb/hr)	0.0	UG
R	Defrost Control Derating Factor (%)	5	UG
S	Average Hourly Heat Recovery (MBH)	13.7	UG
T	Seasonal Efficiency of Gas-Fired Equipment (%)	82	UG

V	Incremental natural gas rate (\$/m <sup>3</sup> )	0.3	UG
W	Average annual gas savings (\$)	438.4	UG

<sup>†</sup>UG: Union Gas

<sup>Δ</sup>NCI: Navigant Consulting, Inc

- **NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m3/MJ) / (Seasonal Efficiency / 100%) **(A)**

- 168 hour = 7 days/week x 24hours/day

- Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor<sup>55</sup> %) **(B)**

- Operating hours for each sectors being considered are as the following

Building Occupancy	Typical Hrs of Operation per week
Hotel	168
Restaurant	108
Retail	108
Office	60
School	84
Health Care	168
Nursing Home	168
Warehouse	168

- New buildings and existing buildings mainly differ in enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula **(B)**.
- Based on the NG Savings formula **(A)** and input assumptions above, the natural gas savings for each of the commercial sectors are calculated, and a simple average is taken to be the general savings.

Market Segment	HRV Capacity (CFM)	New Buildings	
		NG Savings (m3)	NG Savings per CFM (m3/CFM)
Hotel	500	2,273	4.55
Restaurant	500	1,461	2.92
Retail	500	1,461	2.92
Office	500	812	1.62
School	500	1,137	2.27
Health Care	500	2,273	4.55
Nursing Home	500	2,273	4.55
Warehouse	500	2,273	4.55
<b>Average (m3/CFM)</b>			<b>3.49</b>

**Electricity**

**n/a kWh**

<sup>55</sup> From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

<b>Water</b>	<b>n/a L</b>

## Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
HRVs have an estimated service life of 15 years based on Jacques Whitford study <sup>56</sup> . Since Questar Gas <sup>57</sup> and Puget Sound <sup>58</sup> both report 20 years as its effective useful life, Union Gas and Enbridge Gas Distribution also estimate the EUL to be 20 years.	
<b>Incremental Cost</b>	<b>\$3.40 / CFM</b>
The incremental costs are based on relative scaling of incremental costs \$1,700 / 500 CFM <sup>59</sup> .	
<b>Free Ridership</b>	<b>5 %</b>
Free ridership is as per EB 2008-0384 and 0385	

<sup>56</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>57</sup> Questar Gas, DSM Market Characterization Report, by Nexant, August 9, 2006

<sup>58</sup> Quantec — Puget Sound Energy Demand-Side Management Resource Assessment

<sup>59</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

## CONDENSING BOILERS

### Commercial New Building Construction

Efficient Technology & Equipment Description
Condensing Boiler (90% estimated seasonal efficiency)
Base Technology & Equipment Description
Non-condensing Boiler (76% estimated seasonal efficiency)

### Resource Savings Assumptions

Natural Gas	0.0119 m <sup>3</sup> / Btu/hr
The natural gas savings are based on the reduction in space heating gas consumption from using a condensing boiler relative to a non-condensing boiler. The principle assumption in the calculation of the savings is that the condensing boiler is properly oversized by 20%. The heating load for the entire heating season can be determined from the installed capacity and boiler seasonal efficiency using degree day analysis. A generic rate of savings of 0.0119 m <sup>3</sup> / Btu/hr of capacity was determined from this analysis. The single savings number is the weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates.	
Electricity	n/a kWh
Water	n/a L

### Other Input Assumptions

Equipment Life	25 years
Condensing boilers have an estimated service life of 25 years. <sup>60</sup>	
Incremental Cost	\$12 / 10 <sup>3</sup> Btu/hr
A generic incremental cost of \$14,000 per million Btu / hr (adjusted for the US/CDN exchange by a factor of 1.10) was used based on information recently published in the ASHRAE Journal. <sup>61</sup> Local Canadian manufacturers reported \$9,800 for 230,000 Btu/hour condensing boilers <sup>62</sup> , which is \$43 / kBtu/hour. Baseline cost (conventional boilers) is \$31/kBtu/hr. Incremental cost is \$12 kBtu/hour.	
Free Ridership	5 %
Free Ridership as per 2008-0384 and 0385	

<sup>60</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3.

<sup>61</sup> "Boiler System Efficiency", Thomas H. Durkin, ASHRAE Journal - July 2006

<sup>62</sup> Veissmann Group, <http://www.viessmann.ca/en>



## DESTRATIFICATION FAN

### Commercial New Buildings

Efficient Technology & Equipment Description
Destratification Fan. (per fan) For fans with minimum diameter of 20' located in warehousing, manufacturing, industrial or retail buildings with forced air space heating, including unit heaters with ceiling heights 25ft and higher.
Base Technology & Equipment Description
No destratification fan.

### Resource Savings Assumptions

Natural Gas	7,020 m <sup>3</sup>
Based on Agviro's report "Prescriptive Destratification Fan Program - Prescriptive Savings Analysis", by Agviro Inc., February 2009, which was based largely on an analysis of energy savings due to destratification fans installed at the commercial manufacturing and warehousing facility of Hunter Douglas during the winter of 2008. The results of this evaluation are included in the report "Cold Weather Destratification; Hunter Douglas Monitoring Results, Final Report, May 2008". The analysis showed an area of destratification influence of approximately 100' diameter (7,850 ft <sup>2</sup> ). This would be considered as conservative energy savings versus the average installation since the fans were operated at a maximum 15 Hz instead of the typical 20 Hz. The energy savings is assumed to be an average for destratification fans installed in warehouses that have ceiling heights of 30'. Electrical savings are determined for reduced use of items that includes blower motors on space heating equipment. Savings were determined for a 1.5 hp destratification fan motor and the auxiliary electrical savings due to the heating energy savings.	
Electricity	(123) kWh
Based on Agviro's report and the same input parameters as above.	
Water	n/a L

### Other Input Assumptions

Equipment Life	15 years
The estimated equipment life for destratification fans is 15 years [SEED Program Guidelines. J-20. December. 2004]. This value is also supported by ASHRAE [ASHRAE Handbook, HVAC Applications SI Edition. Chapter 36 -Table 4. Pg. 36.3. 2007], which lists the service life for propeller fans as 15 years. As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. / Contr. Install)	\$ 7,021
Weighted average of 20' and 24' diameter fans based on market data and cost data <sup>63</sup> As approved in EB 2008-0384 & 0385.	
Free Ridership	10 %
Based on market & total sales data for Ontario <sup>64</sup> and building type data from UG's Customer database. As per EB 2008-0384 & 0385.	

<sup>63</sup> Targeted Market Study. HVLS fans on Wisconsin Dairy Farms. State of Wisconsin Department of Administration Division of Energy. June 12, 2006., RSMeans. Mechanical Cost Data - 29<sup>th</sup> Annual Edition. 2006, and communications with Manufacturers.

<sup>64</sup> Email from Joan Wood (EnviraNorth) to Victoria Falvo (UG), May 30, 2008

## PROGRAMMABLE THERMOSTAT

New Commercial (per thermostat)

### Efficient Technology & Equipment Description

Programmable thermostat

### Base Technology & Equipment Description

Standard manual thermostat

### Resource Savings Assumptions

Natural Gas				varies m <sup>3</sup>		
Energy use by market segment from space heating and cooling were based on NRCAN Energy intensity data <sup>65, 66</sup> . The percentage of gas savings are based on the assumption of 3% savings per degree F setback as applied in the Energy Star setback calculator and Honeywell commercial calculator, corrected for average outdoor heating season temperature to give a percentage savings of 2.4% per degree F for London, and 2.05% per degree F for North Bay <sup>67, 68</sup> . Setback duration was estimated for each market <sup>69</sup> . The actual setback temperatures used in each market were estimated based on best available information (72 degrees F to 64 degrees F for heating and 74 degrees F to 78 degrees F for cooling).						
NRCAN Market Segment	Space Heating Energy Intensity (m3/ft2/yr)	Gas Savings %	Space Cooling Energy Intensity (kWh/ft2/yr)	Electrical Savings %	Space Cooling Market Saturation	Setback/ Forward Duration
1. Wholesale Trade	2.6	6.5%	5.1	6%	85%	7hrs/night
2. Retail Trade	2.2	6.5%	4.4	6%	85%	7hrs/night
3. Transportation and Warehousing	2.5	10.4%	3.2	11%	10%	12hrs/M-Sat night + 24hrs Sunday
4. Information and Cultural Industries	2.4	12.1%	4.8	12%	75%	12hrs/weekday night + 24hrs Sat & Sun
5. Offices	1.8	12.1%	3.6	12%	86%	12hrs/weekday night + 24hrs Sat & Sun
6. Educational Services	2.4	12.1%	4.9	12%	45%	12hrs/weekday night + 24hrs Sat & Sun
7. Health Care and Social Assistance	2.7	0.0%	5.4	0%	75%	0
8. Arts, Entertainment and Recreation	3.7	6.5%	7.5	6%	87%	7hrs/night
9. Accommodation and Food Services	3.5	6.5%	7.0	6%	70%	7hrs/night
10. Other Services	2.2	10.4%	4.3	6%	69%	7hrs/night

<sup>65</sup> NEUD database space heating for 1990-2006 & HHV of natural gas (as of January 2009)

<sup>66</sup> NEUD database space cooling using for 1990-2006, (as of January 2009)

<sup>67</sup> "UG Thermostat\_calculator\_rv2 - JO.xls"

<sup>68</sup> This analysis includes a weighted average of UG North 30% and UG South 70%.

<sup>69</sup> As per UG's understanding of typical operating schedules

The market segments were converted from NRCAN to the UG market segments. In some cases a blend of up to 3 NRCAN market segments were used to describe the UG markets. The savings took into account typical heating/cooling zone areas covered by a thermostat for different market segments<sup>70, 71, 72</sup>. The institutional market varied so much that the floor areas were determined separately by its components<sup>73</sup>. Hospitals were not included, nor were Long Term Health Care Facilities, since many of the rooms are occupied 24/7 and would not benefit from temperature setback.

UG Market Segments	NRCAN Market Segment ID <sup>74</sup>	NRCAN Market Segment ID	NRCAN Market Segment ID	Thermostat Zone Area (SqFt)
1. Industrial	3	1	10	3,000
2. Warehouse	3			3,000
3. Multifamily	9			1,200
4. Office	4	5	6	650
5. Retail	1	2		600
6. Foodservice	9			1,175
7. Hotels/Motels	9			461
8. Institutional – (No Long Term Care), Schools, Universities, Colleges				
Information and Cultural Industries	4			650
Educational Services	6			986
9. Hospitals	7			NA
10. Recreation	8			2,500
11. Agriculture	10			3,000

The market segments were consolidated into segments below.

UG Market Segments	Gas Savings per Tstat (m3/yr/Tstat)
Warehouse, Recreation, Agriculture, Industrial	674
Office, Institutional (No Long Term Care), Multifamily, Foodservice, Hotels/Motels, Retail	191

**Electricity** varies **kWh**

The electricity savings is based on energy intensity from space cooling for different market segments<sup>75</sup> and the Energy Star/Honeywell Commercial calculator. Not all buildings have cooling, therefore the percentage of each segment that has cooling was included<sup>76</sup>. Otherwise, the electricity savings below were calculated in much the same way as the gas savings above.

<sup>70</sup> Kim Ellis, Sr. Salesperson at Engineered Air, London office, Feb 13, 2009

<sup>71</sup> Ian Dunbar, Feb 13, 2009 referring to a restaurant designed by Millennium Engineering, Burlington

<sup>72</sup> John Paleczny, March 6, 2009, from Yorkland Controls, London

<sup>73</sup> The "Institutional" market was assumed to comprise of "Information & Cultural Industries" and "Educational Services" for the purposes of this analysis.

<sup>74</sup> Refers to table above.

<sup>75</sup> National Energy Use Database, Commercial/Institutional Sectors, NRCAN, September 2008, covering 1990 to 2006.

<sup>76</sup> "Natural Gas Energy Efficiency Potential Commercial Sector –Draft Final Report", Dec 2, 2008, Marbek Resource Consultants

<b>UG Market Segments</b>		<b>Electrical Savings per Tstat (kWh/yr/Tstat)</b>
Warehouse, Recreation, Agriculture, Industrial		524
Office, Institutional (No Long Term Care), Multifamily, Foodservice, Hotels/Motels, Retail		246
<b>Water</b>	<b>n/a</b>	<b>L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>15</b>	<b>years</b>
Sanchez, M., Webber, C., Brown, R. and Homan, G. <i>2007 Status Report: Savings Estimates for the ENERGY STAR® Voluntary Labelling Program</i> , LBNL-56380, Lawrence Berkeley Lab., March 2007.		
<b>Incremental Cost</b>	<b>\$40</b>	
Incremental cost as per 2009 bulk purchase price.		
<b>Free Ridership</b>	<b>20</b>	<b>%</b>
Free Ridership as per EB-2008-0384 and 0385		

## HIGH EFFICIENCY COMMERCIAL FRYER

### New Commercial

Efficient Technology & Equipment Description
Energy Star commercial fryer (at least 50% cooking efficiency <sup>77</sup> ) or at least 50% efficiency and less than 9,000 BTU/H idle energy rate according to ASTM2144-07 <sup>78</sup> .
Base Technology & Equipment Description
Standard commercial fryer (35% cooking efficiency)

### Resource Savings Assumptions

Natural Gas		916 m <sup>3</sup>
The natural gas savings is based on the Energy Star calculator, by market research specific to UG Territory. Input parameters for the calculator can be found below, along with their sources.		
Category	Value	Data Source
<b>Power</b>		
<b>ENERGY STAR</b>		
<b>Qualified Unit</b>		
Initial Cost	\$3,740	Union Gas Contractors, Consortium for Energy Efficiency (NGTC 130908 report)
Cooking Energy Efficiency	50%	ENERGY STAR Specification Calculated - Cooking energy is fryer energy input while cooking, not energy absorbed by food
Cooking Energy Production	114,000 Btu/day	
Capacity	65 lb/hour	FSTC 2004
Idle Energy Rate	9,000 Btu/hour	ENERGY STAR Specification
Total Idle Time	9.26 hour/day	Calculated
Idle Energy	83,354 Btu/day	Calculated
Energy to Food	570 Btu/lb	FSTC 2004
Heavy Load	3 lb	FSTC 2004
Preheat Energy	15,500 Btu/day	FSTC 2004
Preheat Time	15 minutes	FSTC 2007
Total Energy	212,854 Btu/day	Calculated
Lifetime	7 years	Garland (Frymaster) estimate to Victoria Falvo, Union Gas, October 2008
<b>Conventional Unit</b>		
Initial Cost	\$2,240	Union Gas contractors
Cooking Energy Efficiency	35%	FSTC 2004 Calculated - Cooking energy is fryer energy input while cooking, not energy absorbed by food
Cooking Energy Production	162,857 Btu/day 60 lb/hour	FSTC 2007

<sup>77</sup> Cooking energy efficiency is defined as the quantity of energy input to the food products expressed as a percentage of the quantity of energy input to the appliance.

<sup>78</sup> NGTC, DEVELOPMENT OF MARKET INFORMATION AND DSM MEASURE FOR HIGH EFFICIENCY GAS FRYERS Final Report ver 1.2, October 30, 2008, Pg 36

<b>Capacity</b>			
Idle Energy Rate	14,000	Btu/hour	FSTC 2004
Total Idle Time	9.13	hour/day	Calculated
Idle Energy	127,867	Btu/day	Calculated
Energy to Food	570	Btu/lb	FSTC 2004
Heavy Load	3	lb	FSTC 2004
Preheat Energy	16,000	Btu/day	FSTC 2004
Preheat Time	15	minutes	FSTC 2007
Total Energy	306,724	Btu/day	Calculated
Lifetime	7	years	Garland (Frymaster) estimate to Victoria Falvo, Union Gas, October 2008
<b>Maintenance</b>			
Labor cost (per hour)	\$20		EPA 2004
Labor time (hours)	0		EPA 2004
<b>Usage</b>			
Average number of operating hours per day	11.05	hours/day	Restaurants on Union Gas' territory
Average number of operating hours per year	3,832	hours/year	Restaurants on Union Gas' territory
Number of Days of operation	346.75	days/year	Restaurants on Union Gas' territory
Number of Preheats per day	1	preheat/day	FSTC 2004
Pounds of Food Cooked per day	100	lb/day	Restaurants on Union Gas' territory
<p>The duty cycle of fryers was estimated by obtaining the operating hours of twenty restaurants on Union's territory.<sup>79</sup> The figure of 100 lbs/fryer/day correlates very well with FSTC 2007 estimate of 150 lbs/fryer/day used in the Energy Star calculator when one takes into account the reduced operating hours of Union Gas territory restaurants relative to US restaurants:</p> <p>150 lbs/dryer/day * 11.05 hours / 16 hours = 103.6 lbs/dryer/day.</p>			
<b>Electricity</b>			<b>-546 kWh</b>
<p>The difference in electricity usage, obtained separately from a simple calculation based on the manufacturer-specified power consumption, showed that high efficiency fryers use slightly more electricity than the base case fryer.<sup>78</sup></p>			
<b>Water</b>			<b>n/a L</b>

<sup>79</sup> NGTC, DEVELOPMENT OF MARKET INFORMATION AND DSM MEASURE FOR HIGH EFFICIENCY GAS FRYERS Final Report ver 1.2, October 30, 2008, Pg 33

## Other Input Assumptions

<b>Equipment Life</b>	<b>7 years</b>
Equipment life (7 yrs) was estimated by local distributor, Garland, October 8, 2008.	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>1500 \$</b>
The incremental installed costs were estimated by surveying five contractors in UG territory. <sup>78</sup> This figure disagrees with the value used in the Energy-Star calculator, \$6,206. We do not find it possible to substitute this hard field data by the number, almost three times as high, of the Energy-Star calculator. As noted before, fryer prices are heavily dependent on accessories, and it seems that the Energy-Star calculator chose a much better equipped base model than what is actually sold in the Union Gas market. <sup>79</sup>	
<b>Free Ridership</b>	<b>%</b>

## **COMMERCIAL EXISTING BUILDINGS**



## CONDENSING GAS WATER HEATER

### Existing Commercial

Efficient Technology & Equipment Description
Condensing Gas Water Heater <sup>80</sup> (95% thermal efficiency), 50 gallons. Resource savings were calculated for 950 <sup>81</sup> USG/day hot water use <sup>82</sup> :
Base Technology & Equipment Description
Conventional storage tank gas water heater <sup>83</sup> (thermal efficiency <sup>84</sup> =80%), 91 gallons.

### Resource Savings Assumptions

Natural Gas	1543 m <sup>3</sup> /Btu/hr
<p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>• Daily hot water draw – 950 USG/day<sup>12</sup></li> <li>• Input rating for efficient and base equipment: 199,000 Btu.</li> <li>• Average water inlet temperature: 7.22 DegC (45 degF)<sup>85 86</sup></li> <li>• Average water heater set point temperature: 54 degC (130 degF)<sup>87</sup></li> <li>• Stand-by loss of (condensing) Polaris PC 199-50 3NV: 244 Btu/hr.<sup>88</sup></li> <li>• Stand-by loss of (non-condensing) Rheem G91-200: 1,050 Btu/hr.<sup>89</sup></li> </ul> <p>Annual gas savings calculated as follows:</p>	

<sup>80</sup> Locally available commercial condensing gas water heater, trade name: Polaris, model #: PC 199-50  
[http://www.johnwoodwaterheaters.com/pdfs/GSW\\_PolarisSpecSheet.pdf](http://www.johnwoodwaterheaters.com/pdfs/GSW_PolarisSpecSheet.pdf)

<sup>81</sup> as per typical full service restaurant draw (EB-2006-0021, pg 31, Appendix B)

<sup>82</sup> One of the input assumptions required for calculating resource savings for this measure is the stand-by heat loss of storage tank water heaters. Hourly stand-by losses are treated as constant using values drawn from GAMA's *Consumer Directory* (see citation below). This means that marginal percentage gas savings will fall as hot water use rises.

<sup>83</sup> Locally available commercial conventional (non-condensing) gas water heater with the same input rating as the Polaris. Manufacturer: Rheem, model #: G91-200.

<sup>84</sup> Although the required minimum thermal efficiency to be in compliance with ASHRAE 90.1 is 78%, <http://www.energycodes.gov/comcheck/pdfs/404text.pdf>, only an very small percentage of commercial gas water heaters listed in the GAMA *Consumer's Directory of Certified Efficiency Ratings* had a thermal efficiency of less than 80%. [http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)

$$Savings = \left[ W * 8.33 * (T_{out} - T_{in}) * \left( \frac{1}{Eff_{base}} - \frac{1}{Eff_{eff}} \right) + (Stby_{base} - Stby_{eff}) * 24 * 365 \right] * 10^{-6} * 27.8$$

Where:

W = Annual hot water use (gallons)  
8.33 = Energy content of water (Btu/gallon/°F)  
T<sub>out</sub> = Water heater set point temperature (°F)  
T<sub>in</sub> = Water inlet temperature (°F)  
Eff<sub>base</sub> = Thermal efficiency of base equipment  
Eff<sub>eff</sub> = Thermal efficiency of efficient equipment  
10<sup>-6</sup> = Factor to convert Btu to MMBtu  
Stby<sub>base</sub> = Stand-by loss per hour for base equipment (Btu)  
Stby<sub>eff</sub> = Stand-by loss per hour for efficient equipment (Btu)  
24 = Hours per day  
365 = Days per year  
27.8 = Factor to convert MMBtu to m<sup>3</sup>

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>13 years</b>
Studies conducted in two different jurisdictions (Iowa <sup>90</sup> and Washington State <sup>91</sup> ) use an EUL of 13 years, whereas one conducted for Enbridge and Union in 2000 <sup>92</sup> uses an EUL of 15 years. Given that the two most recent studies both use 13 years, 13 years is deemed appropriate.	

<sup>85</sup> Navigant draft report, pg B-224 MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS - February 6, 2009

<sup>86</sup> Chinnery, Glen. Policy Recommendations for the HERS Community to Consider regarding HERS point credit for Waste Water Heat Recovery Devices, EPA, Energy Star for homes, March 2004  
[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Waste\\_Water\\_Heat\\_Recovery\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Waste_Water_Heat_Recovery_Guidelines.pdf)

<sup>87</sup> As suggested by NRCAN: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>88</sup> Consumer's Directory of Certified Efficiency Ratings  
[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf) In this case stand-by losses are constant. Recalculating gas savings using the WHAM algorithm, in which stand-by losses are a function of water draw, results in less than 3% variation over the figures presented above. Lutz, J.D., C.D. Whitehead, A.B. Lekov, G.J. Rosenquist., and D.W. Winiarski. 1999. WHAM: Simplified tool for calculating water heater energy use. ASHRAE Transactions 105 (1): 1005-1015.

<sup>89</sup> Consumer's Directory of Certified Efficiency Ratings  
[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)

<sup>90</sup> Iowa Utilities Board. Docket No. EEP-08-02 MidAmerican Energy Company. Volume IV, Appendix D, Part 1 of 2

<sup>91</sup> Quantec Comprehensive Assessment of Demand-Side Resource Potentials (2008-2027) Prepared for Puget Sound Energy

<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$ 2230</b>
Incremental cost determined from communication with local distributor <sup>93,94</sup>	
<b>Free Ridership</b>	<b>5 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

---

<sup>92</sup> Jacques Whitford Environment Ltd, Prescriptive Incentives for Select Natural Gas Technologies, Sept 2000

<sup>93</sup> Rheem G91-200: \$3,650; Polaris PC 199-50: \$5,880

<sup>94</sup> Navigant Consulting, Draft Report MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS, February 6, 2009, pg 225

## 1.5 GAL/MIN FAUCET AERATOR (KITCHEN)

*Commercial Building Retrofit (Installed) – Multi-Residential*

Efficient Technology & Equipment Description	
1.5 GPM Faucet Aerator	
Base Technology & Equipment Description	
Average existing stock / 2.5 GPM Faucet Aerator	

### Resource Savings Assumptions

Natural Gas (Updated)	26 m <sup>3</sup>
As recommended by Navigant.	
Electricity	n/a kWh
Water (Updated)	5,377 L
As recommended by Navigant.	

### Other Input Assumptions

Equipment Life	10 years
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
Incremental Cost (Contractor Install)	\$2
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
Free Ridership	10 %
EB 2008-0384 & 0385	

## **1.0 GAL/MIN FAUCET AERATOR (KITCHEN)**

*Commercial Building Retrofit (Installed) – Multi-Residential*

<b>Efficient Technology &amp; Equipment Description</b>	
1.0 GPM Faucet Aerator	
<b>Base Technology &amp; Equipment Description</b>	
Average existing stock / 2.5 GPM Faucet Aerator	

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>39 m<sup>3</sup></b>
Based on Navigant savings calculation adjusted for a 1.0 GPM unit.	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water (Updated)</b>	<b>8,072 L</b>
Based on Navigant savings calculation adjusted for a 1.0 GPM unit.	

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>10 years</b>
As recommended by Navigant.	
<b>Incremental Cost (Contractor Install)</b>	<b>\$2</b>
As per utility program costs.	
<b>Free Ridership (Updated)</b>	<b>10 %</b>
Free ridership – EB 2008-0384 & 0385	

## ***1.5 GAL/MIN FAUCET AERATOR (BATHROOM)***

*Commercial Building Retrofit (Installed) – Multi-Residential*

<b>Efficient Technology &amp; Equipment Description</b>	
1.5 GPM Faucet Aerator	
<b>Base Technology &amp; Equipment Description</b>	
Average existing stock / 2.2 GPM Faucet Aerator	

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>7 m<sup>3</sup></b>
As recommended by Navigant.	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water (Updated)</b>	<b>1,382 L</b>
As recommended by Navigant.	

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>10 years</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Incremental Cost (Contractor Install)</b>	<b>\$2</b>
As recommended by Navigant.	
<b>Free Ridership (Updated)</b>	<b>10 %</b>
EB 2008-0384 & 0385	

## ***1.0 GAL/MIN FAUCET AERATOR (BATHROOM)***

*Commercial Building Retrofit (Installed) - Multi-Residential*

<b>Efficient Technology &amp; Equipment Description</b>	
1.0 GPM Faucet Aerator	
<b>Base Technology &amp; Equipment Description</b>	
Average existing stock / 2.2 GPM Faucet Aerator	

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>11 m<sup>3</sup></b>
Based on Navigant savings calculation adjusted for a 1.0 GPM unit.	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water (Updated)</b>	<b>2,371 L</b>
Based on Navigant savings calculation adjusted for a 1.0 GPM unit.	

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>10 years</b>
As recommended by Navigant.	
<b>Incremental Cost (Contractor Install)</b>	<b>\$1.50</b>
As per utility program costs.	
<b>Free Ridership (Updated)</b>	<b>10 %</b>
Free ridership – EB 2008-0384 & 0385	

## **HIGH EFFICIENCY FURNACE (UP TO 299 MBTU/H)**

*Commercial - Existing Buildings*

<b>Efficient Technology &amp; Equipment Description</b>
High efficiency furnace
<b>Base Technology &amp; Equipment Description</b>
Mid-efficiency furnace

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>5.1 m<sup>3</sup>/ 1000 Btu/h</b>
Based on residential high-efficiency gas savings of 385 m <sup>3</sup> (see Existing Homes – High Efficiency Furnace) and a typical residential furnace input of 75,000 Btu/h furnace → 385/75 = 5 m <sup>3</sup> / 1000 Btu/h.	
<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>18 years</b>
High efficiency furnaces have an estimated service life of 18 years. <sup>95</sup>	
<b>Incremental Cost (Contractor Install)</b>	<b>650 \$</b>
The incremental cost is based on a pricing survey of 15 contractors in the Union Gas franchise area. The single incremental cost number is weighted average of Union Gas South (70%) and Union Gas North (30%) average incremental costs.	
<b>Free Ridership</b>	<b>17.5 %</b>
As per EB-2006-0021	

<sup>95</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3



## 1.5 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE)

Commercial Building Retrofit (Distributed) – Multi-Residential

Efficient Technology & Equipment Description
Low-flow showerhead 1.5 gal/min.
Base Technology & Equipment Description
Average existing stock. (2.2 gpm)

### Resource Savings Assumptions

Natural Gas	30 m3	2.2 GPM
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Water	5345 L	2.2 GPM
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Electricity	n/a kWh	

### Other Input Assumptions

Equipment Life	10 years
Low flow showerheads have an estimated service life of 10 years as recommended by Navigant and approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust Install)	\$4
As per utility program costs and approved in EB-2008-0384 & 0385.	
Free Ridership	10 %
As per EB 2008-00384 & 0385	

## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE)

Commercial Building Retrofit (Distributed) – Multi-Residential

Efficient Technology & Equipment Description
Low-flow showerhead 1.25 gal/min.
Base Technology & Equipment Description
Average existing stock. (2.2 GPM)

### Resource Savings Assumptions

Natural Gas		
	54 m3	2.2 GPM
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Water	8916	2.2 GPM
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Electricity	n/a	kWh

### Other Input Assumptions

Equipment Life	10 years
Low flow showerheads have an estimated service life of 10 years as recommended by Navigant and approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust Install)	\$4
As per utility program costs and approved in EB-2008-0384 & 0385.	
Free Ridership	10 %
As per EB 2008-00384 & 0385	

## 1.25 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE)

Commercial Building Retrofit (Installed) – Multi-Residential

Efficient Technology & Equipment Description
Low-flow showerhead 1.25 gal/min.
Base Technology & Equipment Description
Average existing stock (see below).

### Resource Savings Assumptions

Natural Gas		
	53 m3	2.0 - 2.5 GPM
	87 m3	2.6 +
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Water	9078	2.0 - 2.5 GPM
	14341	2.6 +
Based on Navigant savings calculation adjusted to account for percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Electricity	n/a kWh	

### Other Input Assumptions

Equipment Life	10 years
Low flow showerheads have an estimated service life of 10 years as recommended by Navigant and approved in EB 2008-0384 & 0385.	
Incremental Cost (Contractor Install)	\$17
As per utility program costs.	
Free Ridership	10 %
As per EB 2008-00384 & 0385	

## 1.5 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE)

Commercial Building Retrofit (Installed) – Multi-Residential

Efficient Technology & Equipment Description
Low-flow showerhead 1.5 gal/min.
Base Technology & Equipment Description
Average existing stock. (See below)

### Resource Savings Assumptions

Natural Gas		
	28 m3	2.0 - 2.5 GPM
	55 m3	2.6 - 3.0 GPM
	79 m3	3.1 – 3.5 GPM
	91 m3	3.6 + GPM
Based on Navigant savings calculation adjusted to account for 1.5 gpm replacement unit and percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008		
Water		
	5197 L	2.0 - 2.5 GPM
	9490 L	2.6 - 3.0 GPM
	13250 L	3.1 – 3.5 GPM
	15114 L	3.6 + GPM
Based on Navigant savings calculation adjusted to account for 1.5 gpm replacement and percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Electricity	n/a kWh	

### Other Input Assumptions

Equipment Life	10 Years
Low flow showerheads have an estimated service life of 10 years as recommended by Navigant and approved in EB 2008-0384 & 0385.	
Incremental Cost (Contractor Install)	\$17
As per utility program costs.	
Free Ridership	10 %
As per EB 2008-00384 & 0385	

## 2.0 GAL/MIN LOW-FLOW SHOWERHEAD (PER SUITE)

Commercial Building Retrofit (Installed) – Multi-Residential

Efficient Technology & Equipment Description
Low-flow showerhead 2.0 gal/min.
Base Technology & Equipment Description
Average existing stock (see below).

### Resource Savings Assumptions

Natural Gas	4 m3	2.6 – 3.0 GPM
	28 m3	3.1 – 3.5 GPM
	40 m3	3.6 + GPM
Based on Navigant savings calculation adjusted to account for 2.0 gpm replacement unit and percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008		
Water	1,727 L	2.6 – 3.0 GPM
	5,487 L	3.1 – 3.5 GPM
	7,351 L	3.6 + GPM
Based on Navigant savings calculation adjusted to account for 2.0 gpm replacement and percentage of showers taken with efficient unit in Multi- Residential setting (92%) compared to 76% in Low Rise residential as per Summit Blue, Resource Savings in selected Residential DSM Programs, June 2008.		
Electricity	n/a kWh	

### Other Input Assumptions

Equipment Life	10 years
Low flow showerheads have an estimated service life of 10 years. As per EB 2008 – 0384 & 0385	
Incremental Cost (Contractor Install)	\$17
As per utility program costs.	
Free Ridership	10 %
As per EB 2008 – 0384 & 0385	

## ***PRE-RINSE SPRAY NOZZLE (1.24 GPM)***

*Commercial, Existing*

<b>Efficient Technology &amp; Equipment Description</b>
Low-flow pre-rinse spray nozzle/valve (1.24 GPM)
<b>Base Technology &amp; Equipment Description</b>
Standard pre-rinse spray nozzle/valve (3.0 GPM)

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>See below m<sup>3</sup></b>								
<table border="1"> <thead> <tr> <th><b>Market Segment</b></th><th><b>Natural Gas (m<sup>3</sup>/yr)</b></th></tr> </thead> <tbody> <tr> <td>Full Dining Establishments</td><td>931</td></tr> <tr> <td>Limited Service Establishments</td><td>278</td></tr> <tr> <td>Other Establishments</td><td>272</td></tr> </tbody> </table> <p>A field study was undertaken at 37 sites across 4 regions in Union Gas territory. Measurements of water pressure, incoming and leaving (at both burner On and Off setpoints) water temperature at the water heater and supplied to the pre-rinse spray valve, details of the make, model and type of water heater, and type of food service establishment, were collected at each site.</p> <p>Flow rate vs. pressure curves for high-flow and nominal 1.6 USgpm (1.24 USgpm @ 60 psig) pre-rinse spray valves (PRSV) were developed from the Veritec studies in Waterloo<sup>96</sup> and Calgary<sup>97</sup>. An average flow rate vs pressure curve for high-flow PRSVs was developed from the Veritec Waterloo study.</p> <p>Water savings were evaluated for each region based on the difference between the flow rates of the high-flow and low-flow PRSV at the average measured water pressure, and the average usage of the PRSV for each of 3 food service establishment types from the Veritec studies in Waterloo and Calgary.</p> <p>Natural gas savings were determined using the US-DOE WHAM<sup>98</sup> model to establish water heater efficiency. Inputs to the model from site measurements included the average cold water and hot water setpoint temperatures for each region. Additional inputs to the model included water heater energy factor and rated water heater input (both average for the region), ambient air temperature (assumed at 70°F), and average daily volume of hot water. This last item was determined from a combination of research undertaken by FSTC<sup>99</sup>, and ASHRAE<sup>100</sup> recommendations, for each food service establishment type. The proportion of hot water delivered to the PRSV was determined from the average measured mixed water temperature for each region.</p>		<b>Market Segment</b>	<b>Natural Gas (m<sup>3</sup>/yr)</b>	Full Dining Establishments	931	Limited Service Establishments	278	Other Establishments	272
<b>Market Segment</b>	<b>Natural Gas (m<sup>3</sup>/yr)</b>								
Full Dining Establishments	931								
Limited Service Establishments	278								
Other Establishments	272								

<sup>96</sup> "Region of Waterloo – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., January 2005

<sup>97</sup> "City of Calgary" – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., December 2005.

<sup>98</sup> Appendix D-2. Water Heater Analysis Model. Water Heater Rulemaking Technical Support Documents.

<sup>99</sup> [http://www1.eere.energy.gov/buildings/appliance\\_standards/residential/waterheat\\_0300\\_r.html](http://www1.eere.energy.gov/buildings/appliance_standards/residential/waterheat_0300_r.html)

<sup>100</sup> Charles Wallace and Don Fisher Energy Efficiency Potential of Gas-Fired Commercial Hot Water Heating Systems in Restaurants. FSTC April 2007

<sup>100</sup> ASHRAE Handbook 2007HVAC Applications. Chapter 49

<b>Electricity</b>	<b>0 kWh</b>								
<b>Water</b>	<b>See below L</b>								
<table border="1"> <thead> <tr> <th>Market Segment</th><th>Water (L)</th></tr> </thead> <tbody> <tr> <td>Full Dining Establishments</td><td>182,000</td></tr> <tr> <td>Limited Service Establishments</td><td>55,000</td></tr> <tr> <td>Other Establishments</td><td>53,000</td></tr> </tbody> </table> <p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>Water savings were evaluated for 3 food service establishment types: Full Service Restaurants, Limited Service Restaurants, and Other</li> <li>The PRSV water usage was based on the 2 Veritec studies, and incorporated the measured differences in usage time for the high-flow and low-flow PRSVs.</li> </ul>		Market Segment	Water (L)	Full Dining Establishments	182,000	Limited Service Establishments	55,000	Other Establishments	53,000
Market Segment	Water (L)								
Full Dining Establishments	182,000								
Limited Service Establishments	55,000								
Other Establishments	53,000								

### Other Input Assumptions

<b>Equipment Life</b>	<b>5 years</b>
This is consistent with other studies <sup>101,102</sup>	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>100 \$</b>
The incremental cost is assumed to be \$100 – the cost of the spray nozzle and installation. This is comparable to the incremental cost of \$60 reported by the Region of Waterloo <sup>103</sup>	
<b>Free Ridership</b>	<b>12.4 %</b>
New information based on Free Ridership and Spillover for Low Flow Pre Rinse Spray Nozzles (Nov. 26, 2008, PA Consulting Group)	

<sup>101</sup> CEE Commercial Kitchens Initiative - Program Guidance on Pre-Rinse Spray Valves

<sup>102</sup> Enbridge market survey of average usage

<sup>103</sup> "Region of Waterloo – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., January 2005

## ***PRE-RINSE SPRAY NOZZLE (0.64 GPM)***

*Commercial, Existing*

<b>Efficient Technology &amp; Equipment Description</b>
Low-flow pre-rinse spray nozzle/valve (0.64 GPM)
<b>Base Technology &amp; Equipment Description</b>
Standard pre-rinse spray nozzle/valve (3.0 GPM)

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>See below m<sup>3</sup></b>								
<table border="1"> <thead> <tr> <th>Market Segment</th><th>Natural Gas (m<sup>3</sup>/yr)</th></tr> </thead> <tbody> <tr> <td>Full Dining Establishments</td><td>1,286</td></tr> <tr> <td>Limited Service Establishments</td><td>339</td></tr> <tr> <td>Other Establishments</td><td>318</td></tr> </tbody> </table> <p>A field study was undertaken at 37 sites across 4 regions in Union Gas territory. Measurements of water pressure, incoming and leaving (at both burner On and Off setpoints) water temperature at the water heater and supplied to the pre-rinse spray valve, details of the make, model and type of water heater, and type of food service establishment, were collected at each site.</p> <p>Flow rate vs. pressure curves for high-flow and nominal 0.64 USgpm pre-rinse spray valves (PRSV) were developed from the Veritec studies in Waterloo<sup>104</sup> and Calgary<sup>105</sup>. An average flow rate vs pressure curve for high-flow PRSVs was developed from the Veritec Waterloo study.</p> <p>Water savings were evaluated for each region based on the difference between the flow rates of the high-flow and low-flow PRSV at the average measured water pressure, and the average usage of the PRSV for each of 3 food service establishment types from the Veritec studies in Waterloo and Calgary.</p> <p>Natural gas savings were determined using the US-DOE WHAM<sup>106</sup> model to establish water heater efficiency. Inputs to the model from site measurements included the average cold water and hot water setpoint temperatures for each region. Additional inputs to the model included water heater energy factor and rated water heater input (both average for the region), ambient air temperature (assumed at 70°F), and average daily volume of hot water. This last item was determined from a combination of research undertaken by FSTC<sup>107</sup>, and ASHRAE<sup>108</sup> recommendations, for each food service establishment type. The proportion of hot water delivered to the PRSV was determined from the average measured mixed water temperature for each region. Operating times are not expected to be different between 1.24 &amp; 0.64 (Bricor model B064) USgpm models based on cleanability times of 20-21 seconds according to the FTSC<sup>109</sup>.</p>		Market Segment	Natural Gas (m <sup>3</sup> /yr)	Full Dining Establishments	1,286	Limited Service Establishments	339	Other Establishments	318
Market Segment	Natural Gas (m <sup>3</sup> /yr)								
Full Dining Establishments	1,286								
Limited Service Establishments	339								
Other Establishments	318								

<sup>104</sup> "Region of Waterloo – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., January 2005

<sup>105</sup> "City of Calgary" – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., December 2005.

<sup>106</sup> Appendix D-2. Water Heater Analysis Model. Water Heater Rulemaking Technical Support Documents.

[http://www1.eere.energy.gov/buildings/appliance\\_standards/residential/waterheat\\_0300\\_r.html](http://www1.eere.energy.gov/buildings/appliance_standards/residential/waterheat_0300_r.html)

<sup>107</sup> Charles Wallace and Don Fisher Energy Efficiency Potential of Gas-Fired Commercial Hot Water Heating Systems in Restaurants. FSTC April 2007

<sup>108</sup> ASHRAE Handbook 2007HVAC Applications. Chapter 49

<sup>109</sup> pg 32 & 37 "Deemed Savings for (Low Flow) Pre-Rinse Spray Nozzles" by Energy Profiles, January 30, 2009.



<b>Electricity</b>	<b>0 kWh</b>								
<b>Water</b>	<b>See below L</b>								
<table border="1"> <thead> <tr> <th>Market Segment</th><th>Water (L)<sup>109</sup></th></tr> </thead> <tbody> <tr> <td>Full Dining Establishments</td><td>252,000</td></tr> <tr> <td>Limited Service Establishments</td><td>66,400</td></tr> <tr> <td>Other Establishments</td><td>62,200</td></tr> </tbody> </table> <p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>Water savings were evaluated for 3 food service establishment types: Full Service Restaurants, Limited Service Restaurants, and Other</li> <li>The PRSV water usage was based on the 2 Veritec studies, and incorporated the measured differences in usage time for the high-flow and low-flow PRSVs.</li> </ul>		Market Segment	Water (L) <sup>109</sup>	Full Dining Establishments	252,000	Limited Service Establishments	66,400	Other Establishments	62,200
Market Segment	Water (L) <sup>109</sup>								
Full Dining Establishments	252,000								
Limited Service Establishments	66,400								
Other Establishments	62,200								

### Other Input Assumptions

<b>Equipment Life</b>	<b>5 years</b>
This is consistent with other studies <sup>110,111</sup>	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$88</b>
<p>\$88 = (\$50/pc* + \$1/pc* shipping USD) x 1.28901** exchange rate + \$22 installation***</p> <p>*estimated by Bricor, March 2, 2009</p> <p>**Exchange rate from March 2, 2009 - <a href="http://www.xe.com/ucc/convert.cgi">http://www.xe.com/ucc/convert.cgi</a></p> <p>***estimated installation from Seattle Utilities (\$21-23/pc), based on conversation with Bricor, March 2, 2009</p>	
<b>Free Ridership</b>	<b>0 %</b>
Relatively new product; currently only aware one manufacturer. Propose 0% free ridership.	

<sup>110</sup> CEE Commercial Kitchens Initiative - Program Guidance on Pre-Rinse Spray Valves

<sup>111</sup> Enbridge market survey of average usage

## PROGRAMMABLE THERMOSTAT

Existing Commercial (per thermostat)

### Efficient Technology & Equipment Description

Programmable thermostat

### Base Technology & Equipment Description

Standard manual thermostat

### Resource Savings Assumptions

Natural Gas				varies m <sup>3</sup>		
Energy use by market segment from space heating and cooling were based on NRCAN Energy intensity data <sup>112, 113</sup> . The percentage of gas savings are based on the assumption of 3% savings per degree F setback as applied in the Energy Star setback calculator and Honeywell commercial calculator, corrected for average outdoor heating season temperature to give a percentage savings of 2.4% per degree F for London, and 2.05% per degree F for North Bay <sup>114, 115</sup> . Setback duration was estimated for each market <sup>116</sup> . The actual setback temperatures used in each market were estimated based on best available information (72 degrees F to 64 degrees F for heating and 74 degrees F to 78 degrees F for cooling).						
NRCAN Market Segment	Space Heating Energy Intensity (m3/ft2/yr)	Gas Savings %	Space Cooling Energy Intensity (kWh/ft2/yr)	Electrical Savings %	Space Cooling Market Saturation	Setback/ Forward Duration
1. Wholesale Trade	2.6	6.5%	5.1	6%	85%	7hrs/night
2. Retail Trade	2.2	6.5%	4.4	6%	85%	7hrs/night
3. Transportation and Warehousing	2.5	10.4%	3.2	11%	10%	12hrs/M-Sat night + 24hrs Sunday
4. Information and Cultural Industries	2.4	12.1%	4.8	12%	75%	12hrs/weekday night + 24hrs Sat & Sun
5. Offices	1.8	12.1%	3.6	12%	86%	12hrs/weekday night + 24hrs Sat & Sun
6. Educational Services	2.4	12.1%	4.9	12%	45%	12hrs/weekday night + 24hrs Sat & Sun
7. Health Care and Social Assistance	2.7	0.0%	5.4	0%	75%	0
8. Arts, Entertainment and Recreation	3.7	6.5%	7.5	6%	87%	7hrs/night
9. Accommodation and Food Services	3.5	6.5%	7.0	6%	70%	7hrs/night
10. Other Services	2.2	10.4%	4.3	6%	69%	7hrs/night

<sup>112</sup> NEUD database space heating for 1990-2006 & HHV of natural gas (as of January 2009)

<sup>113</sup> NEUD database space cooling using for 1990-2006, (as of January 2009)

<sup>114</sup> "UG Thermostat\_calculator\_rv2 - JO.xls"

<sup>115</sup> This analysis includes a weighted average of UG North 30% and UG South 70%.

<sup>116</sup> As per UG's understanding of typical operating schedules

The market segments were converted from NRCAN to the UG market segments. In some cases a blend of up to 3 NRCAN market segments were used to describe the UG markets. The savings took into account typical heating/cooling zone areas covered by a thermostat for different market segments<sup>117, 118, 119</sup>. The institutional market varied so much that the floor areas were determined separately by its components<sup>120</sup>. Hospitals were not included, nor were Long Term Health Care Facilities, since many of the rooms are occupied 24/7 and would not benefit from temperature setback.

UG Market Segments	NRCAN Market Segment ID <sup>121</sup>	NRCAN Market Segment ID	NRCAN Market Segment ID	Thermostat Zone Area (SqFt)
1. Industrial	3	1	10	3,000
2. Warehouse	3			3,000
3. Multifamily	9			1,200
4. Office	4	5	6	650
5. Retail	1	2		600
6. Foodservice	9			1,175
7. Hotels/Motels	9			461
8. Institutional – (No Long Term Care), Schools, Universities, Colleges				
Information and Cultural Industries	4			650
Educational Services	6			986
9. Hospitals	7			NA
10. Recreation	8			2,500
11. Agriculture	10			3,000

The market segments were consolidated into segments below.

UG Market Segments	Gas Savings per Tstat (m3/yr/Tstat)
Warehouse, Recreation, Agriculture, Industrial	674
Office, Institutional (No Long Term Care), Multifamily, Foodservice, Hotels/Motels, Retail	191

Electricity	varies kWh
The electricity savings is based on energy intensity from space cooling for different market segments <sup>122</sup> and the Energy Star/Honeywell Commercial calculator. Not all buildings have cooling, therefore the percentage of each segment that has cooling was included <sup>123</sup> . Otherwise, the electricity savings below were calculated in much the same way as the gas savings above.	

<sup>117</sup> Kim Ellis, Sr. Salesperson at Engineered Air, London office, Feb 13, 2009

<sup>118</sup> Ian Dunbar, Feb 13, 2009 referring to a restaurant designed by Millennium Engineering, Burlington

<sup>119</sup> John Paleczny, March 6, 2009, from Yorkland Controls, London

<sup>120</sup> The "Institutional" market was assumed to comprise of "Information & Cultural Industries" and "Educational Services" for the purposes of this analysis.

<sup>121</sup> Refers to table above.

<sup>122</sup> National Energy Use Database, Commercial/Institutional Sectors, NRCAN, September 2008, covering 1990 to 2006.

<sup>123</sup> "Natural Gas Energy Efficiency Potential Commercial Sector –Draft Final Report", Dec 2, 2008, Marbek Resource Consultants

<b>UG Market Segments</b>		<b>Electrical Savings per Tstat (kWh/yr/Tstat)</b>
Warehouse, Recreation, Agriculture, Industrial		524
Office, Institutional (No Long Term Care), Multifamily, Foodservice, Hotels/Motels, Retail		246
<b>Water</b>	<b>n/a</b>	<b>L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>15</b>	<b>years</b>
Sanchez, M., Webber, C., Brown, R. and Homan, G. <i>2007 Status Report: Savings Estimates for the ENERGY STAR® Voluntary Labelling Program</i> , LBNL-56380, Lawrence Berkeley Lab., March 2007.		
<b>Incremental Cost</b>	<b>\$40</b>	
Incremental cost as per 2009 bulk purchase price.		
<b>Free Ridership</b>	<b>20</b>	<b>%</b>
Free Ridership as per EB-2008-0384 and 0385		

## ROOFTOP UNIT

### Commercial Existing

Efficient Technology & Equipment Description
Two-stage rooftop unit, up to and including 5 tons of cooling (85% efficient)
Base Technology & Equipment Description
Single-stage rooftop unit (80% efficient)

### Resource Savings Assumptions

Natural Gas	300	m <sup>3</sup>
The natural gas savings are estimated from the difference in annual gas consumption from single-stage to two-stage operation. Assuming the base case efficiency of 80% and the gas use for 5 rooftop units is 25,500 M3 <sup>124</sup> , the actual space heating load is $25,500 \times 0.8 = 20,400$ M3/y. A system of 85% efficiency would then use $20,400 / 0.85 = 24,000$ for a savings of 1,500 M3 for 5 – 5 ton units or 300 M3 per unit.		
Electricity	n/a	kWh
Water	n/a	L

### Other Input Assumptions

Equipment Life	15	years
As per Navigant Consulting <sup>125</sup> and ASHRAE Handbook, 2008		
Incremental Cost (Cust. / Contr. Install)	-	\$375
The incremental cost of two-stage rooftop units compared with single-stage units is \$250 per unit <sup>124</sup> . Local Canadian manufacturer disclosed an incremental cost of \$500 for 2-stage rooftop units compared to single stage rooftop units. Therefore, an average cost of \$375 is assumed ( $(\$250 + \$500) / 2 = \$375$ ). <sup>125</sup>		
Free Ridership	5	%
Free-ridership rate as per EB-2008-0384 and 0385		

<sup>124</sup> "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>125</sup> Navigant rooftop substantiation document, pg B-209 - EB-2008-0346 Ontario Energy Board DSM Assumptions, February 6, 2009

## TANKLESS WATER HEATER

Commercial - Existing

Efficient Technology & Equipment Description
Tankless Water Heater (84% thermal efficiency (77% adjusted thermal efficiency <sup>30</sup> ), where approximately 50-150 USG/day will be used.
Base Technology & Equipment Description
Conventional storage tank gas water heater (thermal efficiency <sup>126</sup> =80%), 91 gallons.

### Resource Savings Assumptions

Natural Gas	221 m <sup>3</sup>
<p>Resource savings were calculated for 100 USG/day hot water use<sup>127</sup>:</p> <p>Assumptions and inputs:</p> <ul style="list-style-type: none"> <li>• Daily hot water draw – 100 USG/day</li> <li>• Input rating for efficient and base equipment: 199,000 Btu.</li> <li>• Average water inlet temperature: 7.22 DegC (45 degF)<sup>128, 129</sup>,</li> <li>• Average water heater set point temperature: 54 degC (130 degF)<sup>130</sup></li> <li>• Stand-by loss of (non-condensing) Rheem G91-200: 1,050 Btu/hr.<sup>131</sup></li> </ul> <p>Annual gas savings calculated as follows<sup>30, 132</sup>:</p> $Savings = \left[ W * 8.33 * (T_{out} - T_{in}) * \left( \frac{1}{Eff_{base}} - \frac{1}{Eff_{eff}} \right) + (Stby_{base} - Stby_{eff}) * 24 * 365 \right] * 10^{-6} * 27.8$ <p>Where:</p> <ul style="list-style-type: none"> <li>W = Annual hot water use (gallons)</li> <li>8.33 = Energy content of water (Btu/gallon/°F)</li> <li>T<sub>out</sub> = Water heater set point temperature (°F)</li> <li>T<sub>in</sub> = Water inlet temperature (°F)</li> <li>Eff<sub>base</sub> = Thermal efficiency of base equipment</li> <li>Eff<sub>eff</sub> = Thermal efficiency of efficient equipment</li> <li>10<sup>-6</sup> = Factor to convert Btu to MMBtu</li> <li>Stby<sub>base</sub> = Stand-by loss per hour for base equipment (Btu)</li> <li>Stby<sub>eff</sub> = Stand-by loss per hour for efficient equipment (Btu)</li> <li>24 = Hours per day</li> <li>365 = Days per year</li> <li>27.8 = Factor to convert MMBtu to m<sup>3</sup></li> </ul>	

<sup>126</sup> Although the required minimum thermal efficiency to be in compliance with ASHRAE 90.1 is 78%, <http://www.energycodes.gov/comcheck/pdfs/404text.pdf>, only an very small percentage of commercial gas water heaters listed in the GAMA *Consumer's Directory of Certified Efficiency Ratings* had a thermal efficiency of less than 80%. [http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhr.pdf)

<sup>127</sup> One of the input assumptions required for calculating resource savings for this measure is the stand-by heat loss of storage tank water heaters. Hourly stand-by losses are treated as constant using values drawn from GAMA's *Consumer Directory* (see citation below). This means that marginal percentage gas savings will fall as hot water use rises.

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

### Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
Equipment life is assumed to be 20 years based on manufacturer literature estimates of over 20 years <sup>133</sup> , Canadian Building Energy End-Use Data and Analysis Centre <sup>134</sup> , Energy Star's High Efficiency Water Heaters brochure <sup>135</sup> , and Energy Star's website <sup>136</sup> .	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>-\$1,570</b>
Commercial tankless water heaters are typically scaled up by unit - a commercial user would likely need several tankless water heaters to replace a single storage tank. The tankless model cited has a maximum flow rate of 4.7 – 7.4 GPM depending on temperature rise required. Any large commercial enterprise would likely require 2 – 3 tankless units to accommodate peak demand. <sup>137</sup> Costs for the two systems were determined to be: • WaiWela PH28CIFS tankless water heater and installation kit = \$2,080 <sup>138</sup> • Rheem G91-200 storage tank water heater = \$3,650 <sup>139 140</sup>	
<b>Free Ridership</b>	<b>2 %</b>
Free-ridership rate as per EB-2008-0384 and 0385	

<sup>128</sup> Navigant draft report, pg B-237 MEASURES AND ASSUMPTIONS FOR DEMAND SIDE

MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS - February 6, 2009

<sup>129</sup> Chinnery, Glen. Policy Recommendations for the HERS Community to Consider regarding HERS point credit for Waste Water Heat Recovery Devices, EPA, Energy Star for homes, March 2004, pg 15

[http://www.energystar.gov/ia/partners/bldrs\\_lenders\\_raters/downloads/Waste\\_Water\\_Heat\\_Recovery\\_Guidelines.pdf](http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Waste_Water_Heat_Recovery_Guidelines.pdf)

<sup>130</sup> As suggested by NRCan: <http://oee.nrcan.gc.ca/residential/personal/new-homes/water-conservation.cfm?attr=4>

<sup>131</sup> Consumer's Directory of Certified Efficiency Ratings

[http://www.neo.ne.gov/neq\\_online/july2006/commgaswtrhtr.pdf](http://www.neo.ne.gov/neq_online/july2006/commgaswtrhtr.pdf)

<sup>132</sup> hot water heating - calculator - tankless comml - March 10 2009.xls

<sup>133</sup> "Introduction to Rinnai Water Heating Product – Course #101", page 7

<sup>134</sup> Canadian Building Energy End-Use Data and Analysis Centre - Domestic Water Heating and Water Heater Energy Consumption in Canada, C. Aguilar, D.J. White, and David L. Ryan, April 2005,

[http://www.ualberta.ca/~cbeedac/publications/documents/domwater\\_000.pdf](http://www.ualberta.ca/~cbeedac/publications/documents/domwater_000.pdf)

<sup>135</sup> Energy Star's High Efficiency Water Heaters brochure,

[http://www.energystar.gov/ia/new\\_homes/features/WaterHtrs\\_062906.pdf](http://www.energystar.gov/ia/new_homes/features/WaterHtrs_062906.pdf) pg 2, March 10, 2009

<sup>136</sup> Energy Star website, [http://www.energystar.gov/index.cfm?c=gas\\_tankless.pr\\_savings\\_benefits](http://www.energystar.gov/index.cfm?c=gas_tankless.pr_savings_benefits), March 10, 2009

<sup>137</sup> A study for Pacific Gas and Electric of a chain casual dining restaurant found peak water draws of up to 20 GPM. Wallace, C. and D. Fisher, Energy Efficiency Potential of Gas-Fired Commercial Hot Water Heating Systems in Restaurants. April 2007

<sup>138</sup> <http://www.tanklesswaterheaters.ca/waiwelaph28ci.html>

<sup>139</sup> From correspondence with local distributor by Navigant Consulting.

<sup>140</sup> Rheem G91-200: \$3,650

## **ENHANCED FURNACE (UP TO 299 MBTU/H)**

### **Commercial - Existing Buildings**

<b>Efficient Technology &amp; Equipment Description</b>
Two-stage furnace with ECM
<b>Base Technology &amp; Equipment Description</b>
Mid-efficiency furnace

### **Resource Savings Assumptions**

<b>Natural Gas</b> ( <i>Furnace / ECM</i> )	<b>5.1 / -0.87 m<sup>3</sup> / 1000 Btu/h</b>
Based on residential enhanced furnace gas savings of 385 m <sup>3</sup> and gas penalty of -65 m <sup>3</sup> (see Existing Homes – Enhanced Furnace) and a typical residential furnace input of 75,000 Btu/h furnace → $385/75 = 4.3$ m <sup>3</sup> / 1000 Btu/h and $-65/75 = -0.87$ m <sup>3</sup> / 1000 Btu/h.	
<b>Electricity</b> ( <i>Furnace / ECM</i> )	<b>0 / 9.7 kWh</b>
Based on residential enhanced furnace electricity savings of 730 m <sup>3</sup> (see Existing Homes – Enhanced Furnace) and a typical residential furnace input of 75,000 Btu/h furnace → $730/75 = 9.7$ kWh / 1000 Btu/h.	
<b>Water</b>	<b>n/a L</b>

### **Other Input Assumptions**

<b>Equipment Life</b> ( <i>Furnace / ECM</i> )	<b>18 years</b>
Two-stage, high efficiency furnaces have an estimated service life of 18 years. <sup>141</sup>	
<b>Incremental Cost</b> ( <i>Furnace / ECM</i> )	<b>\$650 / \$550</b>
The incremental cost is based on a pricing survey of 15 contractors in the Union Gas franchise area. The single incremental cost number is weighted average of Union Gas South (70%) and Union Gas North (30%) average incremental costs.	
<b>Free Ridership</b> ( <i>Furnace / ECM</i> )	<b>30% / 10%</b>
As per EB-2006-0021	

<sup>141</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3



## HEAT RECOVERY VENTILATOR (HRV)

### Existing Building Construction

Efficient Technology & Equipment Description
Ventilation with HRV
Base Technology & Equipment Description
Ventilation without HRV

### Resource Savings Assumptions

Natural Gas		3.77 m <sup>3</sup> / CFM	
<ul style="list-style-type: none"><li>Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.</li><li>For example, input assumptions for a typical Ontario retail store are:</li></ul>			
Symbols	Variable Names	Values	Source
A	Supply air flow (cfm)	500	UG <sup>†</sup>
B	Exhaust air flow (cfm)	500	UG
C	Average indoor air temperature (°F)	70	UG
D	Average indoor relative humidity (%)	30	UG
E	Average outside air temperature (°F)	31.5	UG
F	Average outdoor relative humidity (%)	70	NCI <sup>Δ</sup>
G	Atmospheric pressure (psia)	14.3	UG
H	No. of hours in heating season (hrs)	4,800	UG
I1	Demand Controlled Ventilation	no	UG
I2	No. of hours of operation per week (hrs/wk)	108	UG
J	Make and Model of Heat Recovery Equipment	Eng A, HRW-2100	UG
K	Effectiveness of Heat Recovery Equipment (%)	70	NCI
L	Sensible Heat Recovery Only	yes	UG
M	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET exhaust air	22.0	UG
N	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET supply air	10.4	UG
O	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of OUTLET supply air	16.9	UG
P	Average Temperature of OUTLET supply air (°F)	58	UG
Q	Average Hourly Moisture Addition (lb/hr)	0.0	UG
R	Defrost Control Derating Factor (%)	5	UG
S	Average Hourly Heat Recovery (MBH)	13.7	UG
T	Seasonal Efficiency of Gas-Fired Equipment (%)	82	UG
U	Average annual gas reduction (m <sup>3</sup> )	1,461	UG
V	Incremental natural gas rate (\$/m <sup>3</sup> )	0.3	UG
W	Average annual gas savings (\$)	438.4	UG
<sup>†</sup> UG: Union Gas			
<sup>Δ</sup> NCI: Navigant Consulting, Inc			

- **NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m<sup>3</sup>/MJ) / (Seasonal Efficiency / 100%) **(A)**  
 - 168 hour = 7 days/week x 24hours/day  
 - Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor<sup>142</sup> %) **(B)**
- Operating hours for each sectors being considered are as the following

Building Occupancy	Typical Hrs of Operation per week
Hotel	168
Restaurant	108
Retail	108
Office	60
School	84
Health Care	168
Nursing Home	168
Warehouse	168

- New buildings and existing buildings mainly differ in enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula **(B)**.
- Based on the NG Savings formula **(A)** and input assumptions above, the natural gas savings for each of the commercial sectors are calculated, and a simple average is taken to be the general savings.

Market Segment	HRV Capacity (CFM)	Existing Buildings	
		NG Savings (m3)	NG Savings per CFM (m3/CFM)
Hotel	500	2,452	4.9
Restaurant	500	1,576	3.15
Retail	500	1,576	3.15
Office	500	876	1.75
School	500	1,226	2.45
Health Care	500	2,452	4.9
Nursing Home	500	2,452	4.9
Warehouse	500	2,452	4.9
<b>Average (m3/CFM)</b>			<b>3.77</b>

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

<sup>142</sup> From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

## Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
HRVs have an estimated service life of 15 years based on Jacques Whitford study <sup>143</sup> . Since Questar Gas <sup>144</sup> and Puget Sound <sup>145</sup> both report 20 years as its effective useful life, Union Gas and Enbridge Gas Distribution also estimate the EUL to be 20 years.	
<b>Incremental Cost</b>	<b>\$3.40 / CFM</b>
The incremental costs are based on relative scaling of incremental costs \$1,700 / 500 CFM <sup>146</sup> .	
<b>Free Ridership</b>	<b>5 %</b>
Free ridership is as per EB 2008-0384 and 0385	

<sup>143</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>144</sup> Questar Gas, DSM Market Characterization Report, by Nexant, August 9, 2006

<sup>145</sup> Quantec — Puget Sound Energy Demand-Side Management Resource Assessment

<sup>146</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

## ENERGY RECOVERY VENTILATOR (ERV)

### Existing Building Construction

Efficient Technology & Equipment Description
Ventilation with ERV
Qualifier / Restriction
None
Base Technology & Equipment Description
Ventilation without ERV

### Resource Savings Assumptions

Natural Gas		3.95 m <sup>3</sup> / CFM	
<ul style="list-style-type: none"><li>Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.</li><li>For example, input assumptions for a typical Ontario retail store are:</li></ul>			
Symbol s	Variable Names	Values	Source
A	Supply air flow (cfm)	500	UG <sup>†</sup>
B	Exhaust air flow (cfm)	500	UG
C	Average indoor air temperature (°F)	70	UG
D	Average indoor relative humidity (%)	30	UG
E	Average outside air temperature (°F)	31.5	UG
F	Average outdoor relative humidity (%)	70	NCI <sup>Δ</sup>
G	Atmospheric pressure (psia)	14.3	UG
H	No. of hours in heating season (hrs)	4,800	UG
I1	Demand Controlled Ventilation	no	UG
I2	No. of hours of operation per week (hrs/wk)	108	UG
J	Make and Model of Heat Recovery Equipment	Eng A, HRW-2100	UG
K	Effectiveness of Heat Recovery Equipment (%)	60	NCI
L	Sensible Heat Recovery Only	no	UG
M	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET exhaust air	22.0	UG
N	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of INLET supply air	10.4	UG
O	Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) of OUTLET supply air	17.3	UG
P	Average Temperature of OUTLET supply air (°F)	55	UG
Q	Average Hourly Moisture Addition (lb/hr)	2.6	UG
R	Defrost Control Derating Factor (%)	5	UG
S	Average Hourly Heat Recovery (MBH)	14.7	UG
T	Seasonal Efficiency of Gas-Fired Equipment (%)	82	UG
U	Average annual gas reduction (m <sup>3</sup> )	1,571	UG
V	Incremental natural gas rate (\$/m <sup>3</sup> )	0.3	UG
W	Average annual gas savings (\$)	471.3	UG

<sup>†</sup>UG: Union Gas

<sup>Δ</sup>NCI: Navigant Consulting, Inc

**NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery /(35.3 m<sup>3</sup>/MJ) / (Seasonal Efficiency / 100%) **(A)**

- 168 hour = 7 days/week x 24hours/day

- Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply

air)/Specific  
Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor<sup>147</sup>%) (B)

- Operating hours for each sectors being considered are as the following

Building Occupancy	Typical Hrs of Operation per week
Hotel	168
Restaurant	108
Retail	108
Office	60
School	84
Health Care	168
Nursing Home	168
Warehouse	168

- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated, and a simple average is taken to be the general savings.

Market Segment	ERV Capacity (CFM)	Existing Buildings	
		NG Savings (m3)	NG Savings per CFM (m3/CFM)
Hotel	500	2,569	5.14
Restaurant	500	1,652	3.30
Retail	500	1,652	3.30
Office	500	918	1.84
School	500	1,285	2.57
Health Care	500	2,569	5.14
Nursing Home	500	2,569	5.14
Warehouse	500	2,569	5.14
<b>Average (m3/CFM)</b>			<b>3.95</b>

<b>Electricity</b>	<b>n/a kWh</b>
<b>Water</b>	<b>n/a L</b>

<sup>147</sup> From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

## Other Input Assumptions

<b>Equipment Life</b>	<b>20 years</b>
ERVs originally had an estimated service life of 15 years based on Jacques Whitford study <sup>148</sup> . Questar Gas <sup>149</sup> and Puget Sound <sup>150</sup> both are more recent studies and report 20 years as an ERV's effective useful life. Union Gas and Enbridge Gas Distribution estimate 20 years as an effective useful life for ERVs.	
<b>Incremental Cost</b>	<b>\$3 / CFM</b>
The incremental costs originally based on relative scaling of incremental costs \$2,500 / 1000 CFM <sup>5</sup> . This was updated based on communication with local contractors. The incremental costs are \$3/CFM <sup>151</sup> .	
<b>Free Ridership</b>	<b>5 %</b>
Free ridership is based on EB-2008-0384 and 0385.	

<sup>148</sup> "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>149</sup> Questar Gas, DSM Market Characterization Report, by Nexant, August 9, 2006

<sup>150</sup> Quantec — Puget Sound Energy Demand-Side Management Resource Assessment

<sup>151</sup> Navigant Consulting Inc., Draft Report MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS, FEBRUARY 6, 2009

## CONDENSING BOILERS

### Commercial Existing Buildings

Efficient Technology & Equipment Description
Condensing Boiler (90% estimated seasonal efficiency)
Base Technology & Equipment Description
Non-condensing Boiler (76% estimated seasonal efficiency)

### Resource Savings Assumptions

Natural Gas	0.0119 m <sup>3</sup> / Btu/hr
The natural gas savings are based on the reduction in space heating gas consumption from using a condensing boiler relative to a non-condensing boiler. The principle assumption in the calculation of the savings is that the condensing boiler is properly oversized by 20%. The heating load for the entire heating season can be determined from the installed capacity and boiler seasonal efficiency using degree day analysis. A generic rate of savings of 0.0119 m <sup>3</sup> / Btu/hr of capacity was determined from this analysis. The single savings number is the weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates.	
Electricity	n/a kWh
Water	n/a L

### Other Input Assumptions

Equipment Life	25 years
Condensing boilers have an estimated service life of 25 years. <sup>152</sup>	
Incremental Cost	\$12 / 10 <sup>3</sup> Btu/hr
A generic incremental cost of \$14,000 per million Btu / hr (adjusted for the US/CDN exchange by a factor of 1.10) was used based on information recently published in the ASHRAE Journal. <sup>153</sup> Local Canadian manufacturers reported \$9,800 for 230,000 Btu/hour condensing boilers <sup>154</sup> , which is \$43 / kBtu/hour. Baseline cost (conventional boilers) is \$31/kBtu/hr. Incremental cost is \$12 kBtu/hour.	
Free Ridership	5 %
Free Ridership as per 2008-0384 and 0385	

<sup>152</sup> ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3.

<sup>153</sup> "Boiler System Efficiency", Thomas H. Durkin, ASHRAE Journal - July 2006

<sup>154</sup> Veissmann Group, <http://www.viessmann.ca/en>

## INFRARED HEATERS

### Existing Building Construction

Efficient Technology & Equipment Description								
Infrared Heater, Single Stage or High Intensity								
Base Technology & Equipment Description								
Unit Heater								
Resource Savings Assumptions								
Natural Gas						0.0102 m <sup>3</sup> / Btu/hr		
The infrared heater gas savings were based on the analysis procedures previously created by Agviro Inc. for Union. The analysis was supplemented by adding a 20% over sizing factor on the equipment in the analysis. A generic rate of savings of 0.0102 m3 / Btu/hr of capacity was determined from this analysis. The single savings number is the weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates.								
Electricity						236 kWh	0-49,999 Btu/hr	
						534 kWh	50,000 – 164,999 Btu/hr	
						833 kWh	> 165,000 Btu/hr	
Electricity savings are determined from the difference in electricity consumption of the infrared heater and a comparable unit heater.								
		Blower Motor	Infrared	Operating Hours <sup>155</sup>		Blower Motor	Infrared	Savings
Capacity (BTU/H)		kW	kW	Unit Heater (hrs/yr)	Infrared (hrs/yr)	kWh/yr	kWh/yr	kWh/yr
less than	50,000	0.125	0.031	2405	2044	299	64	236
less than	165,000	0.248	0.031	2405	2044	597	64	534
greater than	165000	0.373	0.031	2405	2044	897	64	833
Electricity based on 1/24 hp Solaronics Radiant Tube heaters. <sup>156</sup>								
<ul style="list-style-type: none"><li>Electricity savings = Unit heater capacity x operating hours – Infrared Capacity x operating hours, the savings are summarised above for three ranges of capacities.</li><li>Electricity savings % = Electricity savings (kWh) / Baseline Consumption (kWh)</li></ul>								
Water						n/a L		
Other Input Assumptions								
Equipment Life						20 years		
Infrared Heaters have an estimated service life of 20 years. <sup>157</sup>								
Incremental Cost						\$0.009 / 10 <sup>3</sup> Btu/hr		
Local retailers reported an average of \$0.009 / Btu/hr incremental cost as per Navigant’s survey of local retailers. <sup>158</sup>								
Free Ridership						33 %		
Free Ridership based on EB-2008-0384 and 0385								

<sup>155</sup> from "Infrared Analysis (Agviro Replicated).xls", which included UG North & South climates as well as a 20% oversizing factor.

<sup>156</sup> [http://solaronics.thomasnet.com/Asset/SSTG-SSTU-GB\\_200010\\_Spec\\_Sheet.pdf](http://solaronics.thomasnet.com/Asset/SSTG-SSTU-GB_200010_Spec_Sheet.pdf)

<sup>157</sup> "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

<sup>158</sup> Navigant Consulting, MEASURES AND ASSUMPTIONS FOR DEMAND SIDE MANAGEMENT (DSM) PLANNING APPENDIX C: SUBSTANTIATION SHEETS - Draft Report, Pg 207



## DEMAND CONTROL KITCHEN VENTILATION (DCKV)

### Building Retrofit

Efficient Technology & Equipment Description
Ventilation with DCKV
Base Technology & Equipment Description
Ventilation without DCKV

### Resource Savings Assumptions

Natural Gas	3,972 m3	0 – 4999 CFM
	10,347 m3	5000-9999 CFM
	18,941 m3	10000-15000 CFM

The demand control kitchen ventilation savings were determined using the methodology described in the Detailed Energy Savings Report ([www.melinkcorp.com](http://www.melinkcorp.com)). The savings were generated for three ranges of total range hood exhaust: 0 – 4999 CFM; 5000 – 9999 CFM; and 10,000 – 14,999 CFM. The midpoint of each exhaust range was used to generate the savings (both gas and electrical). The inputs for the savings calculations were supplied by MELINK as typical for each application range.

Assuming the DCKV system is operating 16 hours/day, 7 days/week, 52 weeks/year, at 80% heating efficiency, 2.5 hp motor, and 3.0 COP for cooling,

- Using design weather data from the Outdoor Airload Calculator, baseline net heating loads for an exhaust volumes were determined for two locations: London (Union South) and North Bay (Union North)
- Weighted average natural gas savings is calculated by assigning 70% to Union Gas South consumption and 30% to Union Gas North consumption based on the customer population of Union Gas service territories.

		Savings				
			London	North Bay	70/30 blend	
Existing Building	up to 4999	Natural Gas	3,660	4,699	3,972	m3
		Electricity	7,281	7,115	7,231	kWh
	5000-9,999	Natural Gas	9,535	12,240	10,347	m3
		Electricity	23,180	22,748	23,051	kWh
	10,000-15,000	Natural Gas	17,455	22,406	18,941	m3
		Electricity	40,929	40,138	40,692	kWh

Electricity	7,231 kWh	0 – 4999 CFM
	23,051 kWh	5000-9999 CFM
	40,692 kWh	10000-15000 CFM

(see table above)

Water	n/a L
-------	-------

## Other Input Assumptions

Equipment Life	15 years	
Melink web site states “Each Optic Sensor enclosure has a purge fan that keeps the environment inside the enclosure under a positive air pressure. This prevents contaminated air from entering the sensor unit”. Melink Canada representative George McGrath estimates their system life at 15 years <sup>159</sup> .		
Incremental Cost	\$5,000	0 – 4999 CFM
	\$10,000	5000-9999 CFM
	\$15,000	10000-15000 CFM
Typical costing information was provided by MELINK.		
Free Ridership	5 %	
FR as per 2008-0384 and 0385		

<sup>159</sup> MELINK Canada, February, 2009

## ***SINGLE AIR DOOR INSTALLATION***

### *Commercial Existing Buildings*

<b>Efficient Technology and Equipment Description</b>	
Installing a single air barrier on an exterior entrance door in a retail facility to maintain indoor air temperature	
<b>Base Technology &amp; Equipment Description</b>	
Door without an air curtain.	

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>2,191 m<sup>3</sup></b>
As recommended by Navigant.	
<b>Electricity</b>	<b>172 kWh</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Water</b>	<b>N/A L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>15 years</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Incremental Cost (Contractor Installation)</b>	<b>\$1,650</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Free Ridership</b>	<b>5 %</b>
As per EB-2008-0384 / 0385.	

## ***DOUBLE AIR DOOR INSTALLATION***

### *Commercial Existing Buildings*

<b>Efficient Technology and Equipment Description</b>	
Installing a double air barrier on an exterior entrance door in a retail facility to maintain indoor air temperature.	
<b>Base Technology &amp; Equipment Description</b>	
Door without an air curtain.	

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>4,661 m<sup>3</sup></b>
As recommended by Navigant.	
<b>Electricity</b>	<b>1,023 kWh</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Water</b>	<b>N/A L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>15 years</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Incremental Cost (Contractor Installation)</b>	<b>\$2,500</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Free Ridership</b>	<b>5 %</b>
As per EB-2008-0384 / 0385.	

## DESTRATIFICATION FAN

### Commercial Existing Buildings

Efficient Technology & Equipment Description	
Destratification Fan. (per fan) For fans with minimum diameter of 20' located in warehousing, manufacturing, industrial or retail buildings with forced air space heating, including unit heaters with ceiling heights 25ft and higher.	
Base Technology & Equipment Description	
No destratification fan.	

### Resource Savings Assumptions

Natural Gas	7,020 m <sup>3</sup>
Based on Agviro's report "Prescriptive Destratification Fan Program - Prescriptive Savings Analysis", by Agviro Inc., February 2009, which was based largely on an analysis of energy savings due to destratification fans installed at the commercial manufacturing and warehousing facility of Hunter Douglas during the winter of 2008. The results of this evaluation are included in the report "Cold Weather Destratification; Hunter Douglas Monitoring Results, Final Report, May 2008". The analysis showed an area of destratification influence of approximately 100' diameter (7,850 ft <sup>2</sup> ). This would be considered as conservative energy savings versus the average installation since the fans were operated at a maximum 15 Hz instead of the typical 20 Hz. The energy savings is assumed to be an average for destratification fans installed in warehouses that have ceiling heights of 30'. Electrical savings are determined for reduced use of items that includes blower motors on space heating equipment. Savings were determined for a 1.5 hp destratification fan motor and the auxiliary electrical savings due to the heating energy savings.	
Electricity	(123) kWh
Based on Agviro's report and the same input parameters as above.	
Water	n/a L

### Other Input Assumptions

Equipment Life	15 years
The estimated equipment life for destratification fans is 15 years [SEED Program Guidelines. J-20. December. 2004]. This value is also supported by ASHRAE [ASHRAE Handbook, HVAC Applications SI Edition. Chapter 36 -Table 4. Pg. 36.3. 2007], which lists the service life for propeller fans as 15 years. As approved in EB 2008-0384 & 0385.	
Incremental Cost (Cust. / Contr. Install)	\$ 7,021
Weighted average of 20' and 24' diameter fans based on market data and cost data <sup>160</sup> As approved in EB 2008-0384 & 0385.	
Free Ridership	10 %
Based on market & total sales data for Ontario <sup>161</sup> and building type data from UG's Customer database. As per EB 2008-0384 & 0385.	

<sup>160</sup> Targeted Market Study. HVLS fans on Wisconsin Dairy Farms. State of Wisconsin Department of Administration Division of Energy. June 12, 2006., RSMeans. Mechanical Cost Data - 29<sup>th</sup> Annual Edition. 2006, and communications with Manufacturers.

<sup>161</sup> Email from Joan Wood (EnviraNorth) to Victoria Falvo (UG), May 30, 2008

## CEE QUALIFIED CLOTHES WASHER

Commercial Existing Buildings – Multi-Residential

Efficient Technology & Equipment Description
High Efficiency Front Load Washers for application in the Multi-residential sector. CEE qualified MEF = 2.20, WF = 5.33
Base Technology & Equipment Description
Conventional top loading vertical axis washers. MEF = 1.26, WF = 9.5

### Resource Savings Assumptions

Natural Gas	222 m <sup>3</sup>
<p><b>To utilize the Navigant annual gas savings calculation to reflect the conditions of the Enbridge Gas Distribution Front Load Washer Program the following are the suggested Inputs:</b></p> <ul style="list-style-type: none"> <li>• Average number of cycles (turns) per year 1,642 (4.5<sup>162</sup> cycles per day x 365)</li> <li>• Water use per cycle, base equipment: 29.26<sup>163</sup> US Gallons</li> <li>• Water use per cycle, CEE energy efficient washer : 16.39<sup>164</sup> US gallons</li> <li>• Percentage of water used by base equipment which is hot water: 18%<sup>164</sup></li> <li>• Percentage of water used by efficient equipment which is hot water: 10%<sup>165</sup></li> <li>• Average water inlet temperature: 7.22°C (45°F)</li> <li>• Average water heater set point temperature: 54°C (130°F)</li> <li>• Water heater thermal efficiency: 65%<sup>166</sup></li> <li>• Gas use per cycle for commercial gas dryer with base equipment: 0.138 m<sup>3</sup></li> <li>• Gas use per cycle for commercial gas dryer with CCE listed clothes washer: 0.096 m<sup>3</sup><sup>167</sup></li> <li>• Gas dryer penetration in Ontario Multi-family and Laundromat market: 60%<sup>168</sup></li> </ul> $Savings = \left[ (W_{base} * Hot_{base} - W_{eff} * Hot_{eff}) * 8.33 * \frac{1}{Eff} * (T_{out} - T_{in}) + (Dr_{base} - Dr_{eff}) * Pene \right] * 10^{-6} * 27.8$	
Electricity	296 kWh
$Savings = [(Wa_{base} - Wa_{eff}) + (Dr_{base} - Dr_{eff}) * (1 - Pene)] * Cyc$	
Water	80,000 L

<sup>162</sup> Average number of cycles per day based on "Multi-Residential High efficiency clothes washer pilot project", City of Toronto, April 2001. Average cycles per day from all sites in report except Louvain & Tyndall, pre-conversion 4.73 cyc/day, post 4.24 cyc/day average 4.49 round to 4.5.

<sup>163</sup> Water consumption in US Gallons for base case clothes washer, from US DOE Federal Energy Management Program, Life-Cycle and Cost spreadsheet, tab Energy and water use. The consumption calculated 26.6 gallons for base case and 14.9 for CEE average washer, both values adjusted by 10% to account for commercial usage, see Enbridge discussion document.

<sup>164</sup> Hot water consumption for both the base case and CEE case are adjusted for the total water consumption (ref 4) and the hot water is corrected based on original usage ratio then this value is increased by 10% to adjust for commercial clothes washer use, see Enbridge discussion document.

<sup>165</sup> Average all clothes washers listed in CEE to obtain average MEF and WF (MEF 2.2, WF 5.33), input into US DOE Life-Cycle and Cost and Payback Period spreadsheet. Increase water use and hot water consumption by 10%.

<sup>166</sup> See item Enbridge Discussion document item a. , Efficiency range for annual usage efficiency of water heaters estimated between 55% to 70%, 65% was selected as conservative estimate base on Enbridge experience. Further analysis is needed to quantify the efficiency of water heaters in commercial clothes washer facilities.

<sup>167</sup> Dryer energy usage is calculated using the US DOE Life-Cycle and Cost and Payback spreadsheet (0.9 kwh/cycle)

<sup>168</sup> 60% penetration for commercial clothes dryers "CEE Commercial, Family-Sized Washers: An Initiative Description of the Consortium for Energy Efficiency) 1998

$$Savings = (W_{base} - W_{eff}) * Cyc$$

### Other Input Assumptions

<b>Equipment Life</b>	<b>11 years</b>
As recommended by Navigant.	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>\$600</b>
Enbridge route operator data.	
<b>Free Ridership</b>	<b>10 %</b>
EB 2008-0384 & 0385	

## ***PRESCRIPTIVE SCHOOL BOILERS - ELEMENTARY***

### *Commercial Existing Buildings*

<b>Efficient Technology &amp; Equipment Description</b>	
Space Heating, Hydronic Boiler with Combustion Efficiency of 83% or higher	
<b>Base Technology &amp; Equipment Description</b>	
Space Heating, Hydronic Boiler with Combustion Efficiency of 80% to 82%.	

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>10,830 m<sup>3</sup></b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Electricity</b>	<b>N/A kWh</b>
<b>Water</b>	<b>N/A L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>25 years</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Incremental Cost (Contractor Install)</b>	<b>\$8,646</b>
Source: Elementary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. Incremental costs are based on the weighted average of boiler types as noted above. As approved in EB-2008-0384 & 0385.	
<b>Free Ridership (EGD/UG)</b>	<b>12% / 27%</b>
As recommended in Summit Blue and approved in EB 2008-0384 & 0385.	



## ***PRESCRIPTIVE SCHOOL BOILERS - SECONDARY***

### *Commercial Existing Buildings*

<b>Efficient Technology &amp; Equipment Description -</b>
Space Heating, Hydronic Boiler with Combustion Efficiency of 83% or higher
<b>Base Technology &amp; Equipment Description</b>
Space Heating, Hydronic Boiler with Combustion Efficiency of 80% to 82%.

### **Resource Savings Assumptions**

<b>Natural Gas</b>	<b>43,859 m<sup>3</sup></b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Electricity</b>	<b>N/A kWh</b>
<b>Water</b>	<b>N/A L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>25 years</b>
As recommended by Navigant and approved in EB-2008-0384 / 0385.	
<b>Incremental Cost (Contractor Install)</b>	<b>\$14,470</b>
Source: Secondary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. Incremental costs are based on the weighted average of boiler types as noted above. As approved in EB-2008-0384 & 0385	
<b>Free Ridership (EGD)</b>	<b>12% / 27%</b>
As recommended in Summit Blue and approved in EB 2008-0384 & 0385.	

## HIGH EFFICIENCY COMMERCIAL FRYER

### Existing Commercial

Efficient Technology & Equipment Description
Energy Star commercial fryer (at least 50% cooking efficiency <sup>169</sup> ) or at least 50% efficiency and less than 9,000 BTU/H idle energy rate according to ASTM2144-07 <sup>170</sup> .
Base Technology & Equipment Description
Standard commercial fryer (35% cooking efficiency)

### Resource Savings Assumptions

Natural Gas		916 m <sup>3</sup>
The natural gas savings is based on the Energy Star calculator, by market research specific to UG Territory. Input parameters for the calculator can be found below, along with their sources.		
Category	Value	Data Source
<b>Power</b>		
<b>ENERGY STAR</b>		
<b>Qualified Unit</b>		
Initial Cost	\$3,740	Union Gas Contractors, Consortium for Energy Efficiency (NGTC 130908 report)
Cooking Energy Efficiency	50%	ENERGY STAR Specification
Cooking Energy Production	114,000 Btu/day	Calculated - Cooking energy is fryer energy input while cooking, not energy absorbed by food
Capacity	65 lb/hour	FSTC 2004
Idle Energy Rate	9,000 Btu/hour	ENERGY STAR Specification
Total Idle Time	9.26 hour/day	Calculated
Idle Energy	83,354 Btu/day	Calculated
Energy to Food	570 Btu/lb	FSTC 2004
Heavy Load	3 lb	FSTC 2004
Preheat Energy	15,500 Btu/day	FSTC 2004
Preheat Time	15 minutes	FSTC 2007
Total Energy	212,854 Btu/day	Calculated
Lifetime	7 years	Garland (Frymaster) estimate to Victoria Falvo, Union Gas, October 2008
<b>Conventional Unit</b>		
Initial Cost	\$2,240	Union Gas contractors
Cooking Energy Efficiency	35%	FSTC 2004
Cooking Energy	162,857 Btu/day	Calculated - Cooking energy is fryer energy input

<sup>169</sup> Cooking energy efficiency is defined as the quantity of energy input to the food products expressed as a percentage of the quantity of energy input to the appliance.

<sup>170</sup> NGTC, DEVELOPMENT OF MARKET INFORMATION AND DSM MEASURE FOR HIGH EFFICIENCY GAS FRYERS Final Report ver 1.2, October 30, 2008, Pg 36

Production Capacity	60 lb/hour	while cooking, not energy absorbed by food
Idle Energy Rate		FSTC 2007
Total Idle Time	14,000 Btu/hour	FSTC 2004
Idle Energy	9.13 hour/day	Calculated
Energy to Food	127,867 Btu/day	Calculated
Heavy Load	570 Btu/lb	FSTC 2004
Preheat Energy	3 lb	FSTC 2004
Preheat Time	16,000 Btu/day	FSTC 2004
Total Energy	15 minutes	FSTC 2007
Lifetime	306,724 Btu/day	Calculated
	7 years	Garland (Frymaster) estimate to Victoria Falvo, Union Gas, October 2008
<b>Maintenance</b>		
Labor cost (per hour)	\$20	EPA 2004
Labor time (hours)	0	EPA 2004
<b>Usage</b>		
Average number of operating hours per day	11.05 hours/day	Restaurants on Union Gas' territory
Average number of operating hours per year	3,832 hours/year	Restaurants on Union Gas' territory
Number of Days of operation	346.75 days/year	Restaurants on Union Gas' territory
Number of Preheats per day	1 preheat/day	FSTC 2004
Pounds of Food Cooked per day	100 lb/day	Restaurants on Union Gas' territory
<p>The duty cycle of fryers was estimated by obtaining the operating hours of twenty restaurants on Union's territory.<sup>171</sup> The figure of 100 lbs/fryer/day correlates very well with FSTC 2007 estimate of 150 lbs/fryer/day used in the Energy Star calculator when one takes into account the reduced operating hours of Union Gas territory restaurants relative to US restaurants:</p> <p>150 lbs/dryer/day * 11.05 hours / 16 hours = 103.6 lbs/dryer/day.</p>		
<b>Electricity</b>		<b>-546 kWh</b>
<p>The difference in electricity usage, obtained separately from a simple calculation based on the manufacturer-specified power consumption, showed that high efficiency fryers use slightly more electricity than the base case fryer.<sup>172</sup></p>		
<b>Water</b>		<b>n/a L</b>

<sup>171</sup> NGTC, DEVELOPMENT OF MARKET INFORMATION AND DSM MEASURE FOR HIGH EFFICIENCY GAS FRYERS Final Report ver 1.2, October 30, 2008, Pg 33

<sup>172</sup> NGTC, DEVELOPMENT OF MARKET INFORMATION AND DSM MEASURE FOR HIGH EFFICIENCY GAS FRYERS Final Report ver 1.2, October 30, 2008, Pg 36

### Other Input Assumptions

<b>Equipment Life</b>	<b>7 years</b>
Equipment life (7 yrs) was estimated by local distributor, Garland, October 8, 2008.	
<b>Incremental Cost (Cust. / Contr. Install)</b>	<b>1500 \$</b>
The incremental installed costs were estimated by surveying five contractors in UG territory. <sup>172</sup> This figure disagrees with the value used in the Energy-Star calculator, \$6,206. We do not find it possible to substitute this hard field data by the number, almost three times as high, of the Energy-Star calculator. As noted before, fryer prices are heavily dependent on accessories, and it seems that the Energy-Star calculator chose a much better equipped base model than what is actually sold in the Union Gas market. <sup>171</sup>	
<b>Free Ridership</b>	<b>%</b>

## HIGHER EFFICIENCY BOILERS – DOMESTIC WATER HEATING

Existing and New Commercial and Multi- Residential

Efficient Technology & Equipment Description
Hydronic Boilers for water heating (Non Seasonal)
Base Technology & Equipment Description
80% Combustion Efficiency Domestic Water Heating Boiler

### Resource Savings Assumptions

Natural Gas (Updated)	Domestic Water Heating (Non Seasonal) M3 Savings by Combustion Efficiency	
	Boiler Size	83-84% 85-88%
	300 MBH	1,075 1,766
	600 MBH	1,777 2,290
	1,000 MBH	3,136 5,155
	1,500 MBH	4,317 7,095

Source: Prescriptive Commercial Boiler Program – Prescriptive Savings Analysis – Agviro Report Sept 10, 2008.

An iterative approach was used to determine the annual savings in the commercial sector. The following steps were taken:

- The Rate 6 accounts were subdivided into bins of annual gas use. This provided the annual average gas use, number of accounts, seasonal, non-seasonal and total gas use.
- The seasonal portion of the annual gas use was normalized to 30 year weather data. This normalized gas use was correlated to a seasonal boiler size required for gas consumption.
- Categories of boiler sizes were selected to provide a suitable range of boilers available within the sector.
- The Rate 6 accounts were subdivided using the normalized average seasonal gas use for the respective categories of boilers selected. This provided the annual average gas use, number of accounts, and total gas use per seasonal boiler size category.
- Seasonal annual gas use normalization of the boiler size category accounts was completed.
- Annual seasonal efficiency of the boiler size categories for each of the combustion efficiency ranges was determined.
- Boiler costs for the boiler size categories was compiled.
- A TRC analysis was completed for each of the boiler size categories.
- A similar approach was used for the non-seasonal gas use with the exception of normalizing the data.

Electricity (Updated)	kWh
Water	L

## Other Input Assumptions

<b>Equipment Life</b>	<b>25</b> <b>years</b>			
EB 2008-0384 & 0385				
<b>Incremental Cost (Contr. Install)</b>	<b>Domestic Water Heating (Non Seasonal) Incremental Cost by Combustion Efficiency</b>			
	<b><u>Boiler Size</u></b>	<b><u>83-84%</u></b>	<b><u>85-88%</u></b>	
	<b>300 MBH</b>	<b>\$3,900</b>	<b>\$ 4,500</b>	
	<b>600 MBH</b>	<b>\$5,800</b>	<b>\$ 6,000</b>	
	<b>1,000 MBH</b>	<b>\$7,400</b>	<b>\$10,300</b>	
	<b>1,500 MBH</b>	<b>\$5,900</b>	<b>\$ 7,400</b>	
Source: Prescriptive Commercial Boiler Program – Prescriptive Savings Analysis – Agviro Report Sept 10, 2008.				
<b>Free Ridership</b>	<b>Enbridge</b>		<b>Union</b>	
	<b>Small Commercial</b>	<b>10%</b>	<b>Small Commercial</b>	<b>10%</b>
	<b>Large Commercial</b>	<b>12%</b>	<b>Large Commercial</b>	<b>59%</b>
	<b>Multi-Family</b>	<b>20%</b>	<b>Multi-Family</b>	<b>42%</b>
EB 2008-0384 - 0385				

## ***PRESCRIPTIVE BOILERS –SPACE HEATING***

*Existing and New Commercial and Multi- Residential*

<b>Efficient Technology &amp; Equipment Description</b>
Hydronic Boilers for space (Seasonal)
<b>Base Technology &amp; Equipment Description</b>
80% Combustion Efficiency Space Heating Boiler

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>Space Heating (Seasonal) M3 Savings by Combustion Efficiency</b>	
	<b><u>Boiler Size</u></b>	<b><u>83-84%</u>   <u>85-88%</u></b>
	<b>300 MBH</b>	<b>2,105   3,125</b>
	<b>600 MBH</b>	<b>3,994   5,930</b>
	<b>1,000 MBH</b>	<b>7,310   10,856</b>
	<b>1,500 MBH</b>	<b>11,554   17,157</b>
	<b>2,000 MBH</b>	<b>16,452   24,431</b>

Source: Prescriptive Commercial Boiler Program – Prescriptive Savings Analysis – Agviro Report Sept 10, 2008.

An iterative approach was used to determine the annual savings in the commercial sector. The following steps were taken:

- The Rate 6 accounts were subdivided into bins of annual gas use. This provided the annual average gas use, number of accounts, seasonal, non-seasonal and total gas use.
- The seasonal portion of the annual gas use was normalized to 30 year weather data. This normalized gas use was correlated to a seasonal boiler size required for gas consumption.
- Categories of boiler sizes were selected to provide a suitable range of boilers available within the sector.
- The Rate 6 accounts were subdivided using the normalized average seasonal gas use for the respective categories of boilers selected. This provided the annual average gas use, number of accounts, and total gas use per seasonal boiler size category.
- Seasonal annual gas use normalization of the boiler size category accounts was completed.
- Annual seasonal efficiency of the boiler size categories for each of the combustion efficiency ranges was determined.
- Boiler costs for the boiler size categories was compiled.
- A TRC analysis was completed for each of the boiler size categories.
- A similar approach was used for the non-seasonal gas use with the exception of normalizing the data.

<b>Electricity (Updated)</b>	<b>kWh</b>
<b>Water</b>	<b>L</b>

## Other Input Assumptions

Equipment Life	25 years	
EB 2008-0384 & 0385		
Incremental Cost (Contr. Install)	Space Heating (Seasonal) Incremental Cost by Combustion Efficiency	
	Boiler Size	83-84% 85-88%
	300 MBH	\$3,900 \$ 4,500
	600 MBH	\$5,800 \$ 6,000
	1,000 MBH	\$7,400 \$10,300
	1,500 MBH	\$5,900 \$ 7,400
	2,000 MBH	\$4,950 \$ 7,050
Free Ridership	Enbridge	Union
	Small Commercial 10%	Small Commercial 10%
	Large Commercial 12%	Large Commercial 59%
	Multi-Family 20%	Multi-Family 42%
EB 2008-0384 - 0385		



## **OTHER MEASURES**

## ***CFL SCREW-IN (13W)***

*Existing/New developments in all sectors*

<b>Efficient Technology &amp; Equipment Description</b>
CFL screw-in 13W
<b>Base Technology &amp; Equipment Description</b>
60W Incandescent

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>0 m<sup>3</sup></b>
<b>Electricity</b>	<b>45 kWh</b>
Substantiation provided by the OPA, dated September 23, 2008 and approved in EB 2008-0384 & 0385.	
<b>Water (Updated)</b>	<b>0 L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>8 years</b>
Substantiation provided by the OPA, dated September 23, 2008 and approved in EB 2008-0384 & 0385.	
<b>Incremental Cost Contractor/Customer Install</b>	<b>0.00 \$</b>
<ul style="list-style-type: none"> <li>Average cost of 60 W incandescent bulb = \$0.75 / bulb based on Canadian Tire website (2007). OPA assumes each incandescent bulb has a one year life.</li> <li>Supplied cost of 13 W CFL = \$1.72 / bulb (based on 2009 distributor price to EGD) + \$0.50 (Contractor Delivery Charge) = \$2.22</li> </ul> <p>\$2.22 CFL cost – \$6.00 (8 incandescent bulbs x .75) = (\$3.78)</p>	
<b>Free Ridership</b>	<b>24 %</b>
Based on the results of an OPA program evaluation and as approved in EB 2008-0384 & 0385.	

## ***CFL SCREW-IN (23W)***

*Existing/New developments in all sectors*

<b>Efficient Technology &amp; Equipment Description</b>
CFL screw-in 23W
<b>Base Technology &amp; Equipment Description</b>
75W Incandescent

### **Resource Savings Assumptions**

<b>Natural Gas (Updated)</b>	<b>0 m<sup>3</sup></b>
<b>Electricity</b>	<b>49.7 kWh</b>
Substantiation provided by the OPA, dated October 17, 2008 and as approved in EB 2008-0384 & 0385.	
<b>Water (Updated)</b>	<b>0 L</b>

### **Other Input Assumptions**

<b>Equipment Life</b>	<b>8 years</b>
Substantiation provided by the OPA, dated October 17, 2008 and as approved in EB 2008-0384 & 0385 .	
<b>Incremental Cost Contractor/Customer Install</b>	<b>0.00 \$</b>
<ul style="list-style-type: none"> <li>Average cost of 75 W incandescent bulb = \$0.75 / bulb based on Canadian Tire website (2007). OPA assumes that each incandescent bulb has a one year life.</li> <li>Supplied cost of a 23 W CFL = \$2.05 (based on 2009 distributor cost to EGD) + \$0.50 (Contractor Delivery Charge) = \$2.55</li> </ul> <p>\$2.55 CFL cost - \$6.00 (8 incandescent bulbs x .75) = (\$3.45)</p>	
<b>Free Ridership</b>	<b>24 %</b>
Based on the results of an OPA program evaluation and as approved in EB 2008-0384 & 0385.	

## 2009 MARKET TRANSFORMATION PROGRAM UPDATE

The following submission provides updates and changes to the Enbridge DSM Market Transformation (“MT”) programs as filed in EB-2006-0021 (Exhibit A, Tab 6, Schedule 1, and Exhibit B, Tab 1, Schedule 1). These updates and changes result from actual MT program experience in 2007 and 2008.

The scorecard approach to measuring MT program results and calculating MT incentive amounts (as outlined in EB-2006-0021, Exhibit B, Tab 1, Schedule 1, pp 1-2) has not changed; however, some allocations of budget and incentive amounts to individual programs have changed. Table 1 below presents the updated budget and SSM amounts for each program. Amounts that have been revised from the EB-2006-0021 filing are highlighted in gray.

Program		2009	
		Budget	SSM
<b>Residential Market</b>			
	Fireplaces	\$120,000	\$125,000
	Home Performance Contractors	\$110,000	\$125,000
	Drain Water Heat Recovery	\$512,500	\$250,000
	Low Income	\$170,000	\$0
	Energy Star Washers (cancelled)	\$0	\$0
	subtotal	\$912,500	\$500,000
<b>Business Markets</b>			
	Boilers	\$0	\$0
	Business Partners	\$0	\$0
	subtotal	\$0	\$0
<b>Other</b>			
	Channel Market Support	\$90,000	\$0
	Developmental Activities	\$100,000	\$0
	subtotal	\$190,000	\$0
	<b>TOTAL</b>	<b>\$1,102,500</b>	<b>\$500,000</b>

## 1. EnerGuide for Natural Gas Fireplaces Market Transformation Program

The following changes have been made for the 2009 EnerGuide for Natural Gas Fireplaces MT program:

- a. Budget increase from \$80,000 to \$120,000
- b. SSM increase from \$100,000 to \$125,000
- c. A change to the metric levels for the two “Market Effects” metrics (awareness and influence of the Energuide label for fireplaces)
- d. A change to the program performance metric representing retail penetration from a percentage increase over the previous year to a target number of stores
- e. A new program performance metric representing maintenance of POP material in retail stores (i.e. material still on display at year end)
- f. Revised metric weightings to accommodate new program metric

### Rationale

During 2008, this program resulted in strong awareness and influence levels of the Energuide label for fireplaces. The previously-filed 100% target of a 10 percentage point increase in awareness and influence from an already-high awareness/influence level was deemed unrealistic, and these targets have been reduced by half across all three metric value levels. Previous activity has significantly increased the reference point for this metric and it will be a challenge to achieve the proposed targets. Based on feedback from our retail channel field staff, Enbridge has seen that our point-of-purchase messaging on the Energuide label is often the only source of energy-efficiency messaging on the retail floor where gas fireplaces are sold, and therefore this type of program is important to continue.

Enbridge has been successful in penetrating a large share of the fireplace retailer market with point-of-purchase communications in support of this program, but we recognize a need for a higher level of sales support to ensure this material

promoting the energy efficiency aspects of fireplaces stays visible, all year long, in an already-crowded retail environment. Enbridge Marketing and Sales staff will have to work harder (more retail visits, more frequent replacement of lost or damaged POP material, more retailer training and support, etc.) to achieve similar retail penetration numbers and impact for this program in 2009. The new metric related to maintenance of POP in retail stores will help drive this behaviour and ensure a constant presence of energy efficiency messaging in the retail market.

Updated Budget/SSM Summary and Scorecard Summary are as follows:

Budget / SSM Summary

	<u>2009</u>
Budget	\$120,000
Target SSM	\$125,000

Scorecard Summary

EnerGuide for Natural Gas Fireplaces		2009 Metric Value Levels			
Element	Metrics (weighting)	50%	100%	150%	Weight
ULTIMATE OUTCOMES	n/a	n/a	n/a	n/a	n/a
MARKET EFFECTS	a) Percentage point increase in customer awareness of the EnerGuide label	+0 percentage points/yr (maintain previous year's result)	+5 percentage points/yr	+10 percentage points /yr	/35
	b) Percentage point increase in influence of the EnerGuide label on purchase decision	+0 percentage points/yr (maintain previous year's result)	+5 percentage points /yr	+10 percentage points /yr	/35
PROGRAM PERFORMANCE	c) Number of stores with EnerGuide POP promotional material	100 stores	150 stores	175 stores	/15
	d) Share of stores which received the EnerGuide POP material which still have it visibly displayed at year end	80%	90%	100%	/15

## 2. Home Performance Contractor Market Transformation Program

The following changes have been made to the 2009 Home Performance Contractor MT program:

- a. Budget increase from \$90,000 to \$110,000
- b. SSM increase from \$100,000 to \$125,000
- c. A change in the measurement methodology for the ultimate outcome metric from “x increase in frequency of at least three weatherization measures” to “Average increase in frequency scores of all weatherization measures of x.”
- d. An increase in the target number of training workshops to be held from 3, 6 and 9 for the 3 metric value levels, to 5, 8, and 11.

### Rationale

In 2007 and 2008, the Home Performance Contractor workshops were very favourably received by attendees, and due to creative promotional strategies and word-of-mouth referrals, it is expected that interest in and demand for the workshops will increase in 2009. This will increase the need for budget dollars to support the additional workshops and measure the impacts.

In 2009 we will be targeting the ‘Influencers’ of the home performance air sealing measure by obtaining a listing from the Renovation Council and specifically offering this course to Owners and Sales staff.

The methodology for measuring the “increase in frequency of at least three weatherization measures” metric has been revised to eliminate a possible complication of measurement which could arise with the original methodology, that being the lack of a prescribed method for scoring when more than three measures experienced the reported increase in average score. In other words, the original methodology would have assigned the same score (100%) for a 1.0 increase in three weatherization measures, as it would for a 1.0 increase in eight weatherization measures, when clearly the second outcome is significantly

better. The new methodology assigns a score based on the average increase in frequency scores across all weatherization measures.

Updated Budget/SSM Summary, Scorecard Summary, and a scoring example are as follows:

Budget / SSM Summary

	<u>2009</u>
Budget	\$110,000
Target SSM	\$125,000

Scorecard Summary

Home Contractor Performance MT Program		2009 Metric Value Levels			
Element	Metrics	50%	100%	150%	Weight
ULTIMATE OUTCOMES	a) Average Increase in frequency scores of all weatherization measures	Average increase in frequency scores of all weatherization measures of 0.3	Average increase in frequency scores of all weatherization measures of 0.45	Average increase in frequency scores of all weatherization measures of 0.6	/60
MARKET EFFECTS	b) Contractor Engagement	30	60	90	/20
PROGRAM PERFORMANCE	c) Contractor Training Workshop	5	8	11	/20



## Scoring Example

The five-point scale to be used is as follows: 1=Never, 2=Sometimes, 3=Often, 4=Almost always, 5=Always.

<b>Sample Data</b>			
Measures (to be based on workshop curriculum)	Baseline Frequency (average score in 5-point scale from pre-course benchmarking study)	Post-Program Frequency (average score in 5-point scale from post-course benchmarking study)	Difference
1. Comprehensive air sealing of the attic floor with 2 component foam	2.0	2.7	0.7
2. Comprehensive air sealing of the attic floor with 1 part foam caulking	2.0	2.4	0.4
3. Some air sealing of the attic floor with 1 part foam and caulking	2.3	2.9	0.6
4. Air sealing baseboards, window & door trim, electrical outlets & switches	3.1	3.7	0.6
5. Air sealing basement sill plate and joint header area	3.1	3.8	0.7
6. Weather-stripping doors	2.9	3.5	0.6
7. Weather-stripping windows	2.7	2.9	0.2
8. Insulating garage ceilings, cantilevers, etc. with 2 component foam	2.2	2.3	0.1
		Average Result:	0.48

In the example above, the average increase in frequency scores was 0.48, achieving a metric score of 107% ( $0.48/0.45 \times 100$ ).

### 3. Drain Water Heat Recovery System (2009) Market Transformation Program

This is a new program to be offered by Enbridge in 2009 for the low-rise residential new construction market, complementing the current program that Union Gas is offering to builders in their franchise territory. Extensive consultation was held with Union Gas staff to ensure compatibility between the two utilities' programs, and consideration was given to simplify the builder's process and administration to streamline the program for builders that operate in both franchises. The key difference between the two utility programs is that Enbridge will be targeting its promotional activity to the key water heater rental service providers who will, in turn, promote the technology to the builder market, whereas Union Gas targets the builders directly.

Enbridge will be offering a builder incentive of \$400 per Drainwater Heat Recovery unit installed, the same offering that Union Gas has.

The scorecard below outlines the program elements and metrics proposed for this program. Metric descriptions are provided below the table.

Drainwater Heat Recovery		2009 Metric Value Levels			
Element	Metrics (weighting)	50%	100%	150%	Weight
ULTIMATE OUTCOMES	a) Builders Enrolled	6	12	16	/10
	b) Units Installed	325	650	975	/40
	c) Builder Knowledge	40%	50%	60%	/15
	d) Service Provider Promotion	60%	70%	80%	/20
PROGRAM PERFORMANCE	e) Builder Training Workshops	1	3	5	/5
	f) Contractor/Sub Workshops	1	3	5	/5
	g) Trade Show Promotion	1	3	5	5

- a) **Builders Enrolled:** The number of builders enrolled in the program will be tracked through the rental service providers. If a builder is enrolled, this does not necessarily mean that they are installing the technology in every home; however, it is an indicator of how widespread the awareness of the technology may be, and how many builders may be talking about the technology with potential homebuyers.
- b) **Units Installed:** This is the key “ultimate outcome” metric for the program, indicating the penetration of this technology in the residential new construction market, and therefore has the largest weighting of all the metrics.
- c) **Builder Knowledge:** Non-enrolled builders will be surveyed at the end of the year to establish their level of exposure and knowledge of the technology and Enbridge’s program. This metric will indicate how effective the service providers have been in promoting the program (regardless of uptake) and educating the market on the benefits of the technology. The baseline for this metric is assumed to be at, or close to, zero at the time of program launch.
- d) **Service Provider Promotion:** This metric will measure the extent to which participating service providers fulfill a series of prescribed promotional activities through the year to increase market awareness of the technology.
- e) **Builder Training Workshops:** The number of workshops delivered to builders with at least 10 builders in attendance.
- f) **Contractor/Sub Workshops:** The number of workshops delivered to contractors/sub-contractors with at least 10 contractors in attendance.

- g) Trade Shows/Builder Shows: The number of trade shows/builder shows with an Enbridge presence promoting Drainwater Heat Recovery.

#### 4. 2009 Market Transformation Program Cancellations

- a) ENERGY STAR™ WASHERS
- b) Boiler Market
- c) Business Partner Baseline

##### Rationale

##### ENERGY STAR™ WASHERS

Research conducted late in 2007 indicated that over 80% of clothes washers on display in a sample of retailers were already ENERGY STAR qualified. The remaining models, according to retailer feedback, were offered to fill the need for a lower-priced model for the more cost-conscious consumer. As a result of this research finding, this program was deemed unnecessary for 2008 and 2009, and therefore cancelled.

##### BOILERS

As a result of challenges encountered in the design of this program and its metrics, as identified in the 2007 DSM Audit (released in June 2008), Enbridge will be discontinuing this program for 2009. Acquisition of representative data on sales of these boilers in our franchise area, to fulfill the “ultimate outcomes” metrics, has proven to be particularly challenging, as manufacturers are not prepared to share competitive sales data on a regional level.

Enbridge continues to be committed to the promotion of high efficiency and condensing boilers, and plans to continue promotional activity in this area

through its existing custom incentive programs with commercial and industrial customers, and possibly through prescriptive boiler offerings.

## BUSINESS PARTNERS

As a result of challenges encountered in the design of this program and its metrics, as identified in the 2007 DSM Audit (released in June 2008), Enbridge will be discontinuing this program for 2009. Although the workshops provided by this program were very favourably received, the objective of introducing a large community of HVAC contractors and engineers to emerging technologies and influencing them to specify these technologies with increasing frequency is likely beyond the scope of this program's budget and timeline.

Enbridge will continue to communicate with its HVAC business partners on new and emerging technologies through case studies, workshops/training where appropriate and web-based communications.