

EXHIBITS

EB-2009-0149

Presented by Niagara-on-the-Lake Hydro Inc.

To the Issues Day Proceeding on Tuesday, July 7, 2009

Exhibit 1 Step-up Unit






Exhibit 2 Pole Line






Exhibit 3 Feeder Route






Exhibit 4A Rock Quarry






Exhibit 4B Down to Inaccessible Area






Exhibit 5 Inaccessible Area






Exhibit 6 Overview of Route





Exhibit 26 Stanley TS Load





Ontario Hydro letter, 1993






Exhibit 8 Re-Routed Feeder







Exhibit 8BGlendale Area





Ontario Hydro Notes - 1999 Meeting












Exhibit 11 NOTL Hydro Loads



YEARS				D	OTL Hydro	Load in m	/A / 9 of as	sumed)					
	JAN	FED	MAR	AP-K	MAY	JUN	JUL	ALIG	SEP	COT	NOV	DEC	
1971	3020	3043	2756	2403	2398	2398	2340	2403	2403	2353	2984	3148	
1972	3221	2864	2873	2673	2483	2730	2828	2851	2766	3000	3246	3500	
1973	3463	3363	3011	3016	2829	3328	3509	3323	2676	3132	3506	4132	
1974	3798	3702	3337	3209	3216	3303	BBBE	3519	3283	3363	3994	3903	
1975	3798	3701	3533	3580	3202	3708	3857	3970	3161	3446	3662	4370	
1976	4411	4407	3823	3613	3426	3938	3702	3797	3540	3473	4148	4384	
1977	4447	4181	3729	3404	3391	3876	4181	3938	4053	3242	4044	4389	
1978	4329	4092	3829	3587	3383	3863	4100	4173	3839	3406	4389	4411	
1979	4592	4511	4104	4179	3577	3986	4464	4132	4034	3500	4249	4707	
1980	5208	5479	4686	4327	4100	5027	5121	5177	4739	4441	4804	5619	
1981	5635	5570	5297	4098	4139	5244	5758	4980	5153	4427	5000	5443	
1982	6096	5664	5113	5011	4056	4412	5481	5011	5010	4018	4883	5374	
1983	20072	18009	17218	15946	14193	17946	10012	19440	19952	16314	18901	22127	
1984	21169	19197	19297	16114	15361	17937	19566	20660	17018	16598	19141	20313	
1985	23250	20950	20170	18130	15481	15302	20579	21088	21436	17704	20281	23300	
1986 1987	22192 23207	20831 22093	21859 20839	17537	17568	17848	21953	22044	18332	17747	21132	23017	
1955	25496	23531	20839	19496 18740	21247 21460	22143 24239	25831	26198	20424	19401	22522	23519	
1989	25582	25098	24924	21005		25345	28378	28522	22238	20612	22407	26191	
1990	24701	23477	23369	21581	20450 20189	25932	28807 29483	29568 31082	27147 25473	22232	25845 24820	30352 26283	
1991	25767	25817	22351	20857	25446	29557	30320	31916	28907	19818	23213	25909	
1992	25713	23357	24041	20879	18939	22236	23398	29293	25329	21832	23043	24113	
1993	23450	23757	22538	21189	17552	22702	27483	30320	23550	18894	20521	23548	
1994	26150	23591	20168	18916	18529	25219	28584	28179	25533	20662	23468	25411	
1995	24551	25237	21114	20797	18729	29396	31248	32928	25398	20686	22519	28635	
1996	24527	25153	22559	20230	20662	25854	28887	31400	28704	21155	23668	25416	
1997	25568	22214	22090	19499	18222	30329	32537	20233	24649	22366	24336	25616	
1998	23647	21926	21860	19077	25270	32761	34141	35382	29668	21476	23621	27588	
1999	27490	23490	23457	21041	25657	32566	37261	33383	32500	22243	25896	27999	
2000	27358	25348	22978	22347	25995	31309	34035	37314	36860	23687	27253	29450	
2001	27532	25822	24464	22550	25199	36582	41499	45152	38291	25538	26884	29231	
2002	27980	27901	27100	25934	27881	28229	43063	50171	4246D	31475	28702	31220	
2003	31251	32291	27852	26198	23826	88863	38708	41089	31799	26550	29073	30749	
2004	32322	28996	27667	25530	31026	37107	40167	40127	36420	28370	29418	33514	
2005	32523	29157	28049	28020	24792	43583	44593	45038	30179	31374	31834	32887	
2006	29702	29451	27360	25003	39887	38548	46410	48714	33028	27182	28337		
		8	F	lating of NO	TL DS exc	eeded 📕	R	ating of NC	OTL US and	l Stanley As	оке bangia	eeded (41.8	3 mVA)

Kraft Canada Letter



KRAFT Kraft Canada	
October 23, 2002	
	-
To Whom It May Camern: Kraft Poods operates a fruit processing plant and cold storage facility in the St. Davids area of Niagars-on-the-Lake. Our operation is primerily during the summer and early autumn months and our total connected local approachs 2 mW at the 27.6 kV level. Our electrical equipment is not of a particularly sensitive nature and consists mainly of compressors and conveyor drives.	
On several occasions this summer we experienced noticeable variations and reductions in our voltage supply fevel. Our local distribution company, Niagara-on-the Lake Hydro, was notified and informed us that the load flowed on their supply out of Niagara-Falls will be reduced to better regulate the supply voltage. On August 28, during a but affernoon, the supply loved again dropped as the lost increased and we contracted Niagara-on-the-Lake Fydro. Their crews advised us that the Niagara-Talls supply would be discomnected and they would return us to our normal supply out of Niagara-on-the-Lake. We have not experienced any further problems with voltage variations since the supply point was returned.	
Ningara-m-the-Lake Hydro has informed us that they are expected to otilize the Niagara halls supply on a regular basis. Kraff Poods is softonsly concerned with the integrity of this supply and asyports Neagara-on-the-Lake Hydro in their bid to remove their dependence on this supply.	
Yours mily, KRAFT CANADA INC.	
Kenr. Jones, Meintenence Superintenden;	II.
Krol, Camelalum. PO, Eu. 4, 120 Cock Rose' S. Davia, Ontari-139 SS - Tol-stems (2011) 583-4211 - Fasti da 2013 583-688	Exhibit 14
Areas commandation in the East Charle Rade in East Datable Officers (2007) and Commission Control of Control o	

Ontario Hydro Response



1/13/05 LRI 10:4P RVY 88P P81 458A	CCSTOMER SERVICE	ā 002	DB/13/02 FK1 14:47 FA4 985 981 1287	CUSTOMER SERVICE	Kr.
hydro G				2	
	В	NE NETWORKS INC. 1929 King Sand Infragen, Oreano Crist 1929 Oreland, Account Internative Contract States of Contract King Stat	the Magara on the Liste boundary, at a volfs (94%). This is consistent with the study fact the voltage of the boundary would be higher	of Stuniory TS voltage levels, the 10M2s feeds can delive ge that is within the acceptable limits of the Distribution was completed in conjunction with our work in 1999. Wi than 98% in all normal loading conditions.	System Code e calculate (fixe)
			concerns, Hydro One Networks would be ple	ased to work with you to resolve them.	a vonage
Mr. J. Huntingdon, General Managar, Niagara-on-the-Lake Fivdro.	Sopt	13, 2002	I trust you will find these communits to your s (905) 681-4281	atisfaction. If you have any additional questions please o	outact me at
P.O. Box 460, 8 Hernagan Rd., VIRGEL, ON L3K 5V7				RHA Ind	
Dear Mr Huntingdom				Robert Davidson Account Executive Customer Solutions	
	ninble from Stanley TS		ce. D. Fahra B. Singh C. Lee	Network Customer Rolations	
Thank-you for your letter dated Angust 22, 2002, In regarding the effectiveness of delivery of 10MVA of is supplied to the Niagara on the Lake boundary via	connective from Hodge Due Network is Stanley	sect concert; TS: This capacity			
In 1999, ofter discussions with Niagara on the Lake Sendey TS capacity to Niagara on the Lake Hydro. Natworks appraised the existing facilities and installs feeder to oursers adoquate empacity could be defivered	To mitugate exertending of Ningara on the Lat- ed new protections at Stanley TS, We upwerde	to DS Hadro One			
As a result of your record letter, Hydro One Network TS, specifically the 10M20 feedor	is has reviewed the configuration and the equip	proced at Similary			
Spot checks in August 2002, noted voltage levels bet regulator settings.	ween 14.1kV and 14.4kV. Passe are consisted	at with the			
		Da			
		수 기			
Race yes Time Sep. 3. 3:29PM		ν	Received Time Septis: 3:29	64	

Exhibit 17 NOTL Hydro Response





Niagara-on-the-Lake Hydro Inc.

September 26, 2002

Mr. Robert Devidson Hydro One Networks Inc. 1225 King Road Burlington, Ontario L7X 3X5

Dear Mr. Davidson;

Re: Capacity Available From Stanley T.S.

We are in receipt of your September 13, 2002 response to our capacity concerns at the Stanley T.S. supply point.

We will not dispute first voltage levels on the Stanley T.S. bus in August ranged between 14.1 and 14.4 kV. However, the supply voltage to Nitagora-on-tho-Lake is at the 27.8 kV level. The flydro One 13.8 to 27.6 kV step-up units have inherent lesses that reduce the voltage. The estimated 4 km distance to our boundary also results in further voltage loss. We challenge the Hydro One calculations of expected voltage levels at our boundary, based on our actual experience, and measured values.

On August 28, 2002, with an estimated 4 mW of load drawn from the Stanley station, we received numerous flow voltage calls. Hydro One operators confided that the auto tap change had moved down to 14.1 kV. A manual boost to 14.4 kV brought the secondary voltage just inside our boundary up to only 11.5 V directly of the 27.8 kV system. Our crews measured an average of 28,900 V at our boundary. This is not an acceptable voltage level. We will be circulating a copy of your September 13th letter to our customers that have been effected by the resulting low voltage. Perhaps the volte of outstoners such as Kraft Foods Fruit Processing Centro in St. David's may persuade Hydro One to reconsider their position.

At the maximum Stanloy bus voltage of 14.4 kV, the system struggles to supply 5 mVA and sustain sufficient voltage levels at our boundary. We have been informed that with the bus voltage positioned on the 14.4 kV setting, a high voltage scenario develops for Nilagara Falls Hydro customers.

8 HENEGAN ROAD, RO. 80X 460 • VIRGIL, ONTARIO • 1,05 1T0 PHONE: 985-106 4225 • PAX: 935-466-2861 Niagara-on-tho-I ake Hydro is prepared to take our physical evidence to the Organic Energy Board for a rulling, however, we welcome the apportunity to further exchange information and ciscuss a resolution to this issue at your seriest convenience.

Sincerely.

Jim Huntingdon General Manager

c Mr. Devinder Baara, Hydro One Networks Inc.

c Board of Directors, Niagara-on-the Lake Hydro Inc.

MTS#1 Connection Request



November 7, 2002 Mr. Jim Patterson Hydro One Networks Inc. 483 Bay Street, North Lower (TCT15) Tenanto, ON M5G 2P5 Re: Customer Connection Application Dear Mr. Patterson. Niagara-on-the-Lake Hydro Inc. formally requests connection to the Hydro One Networks 175 kV Q12S system for the addition of a 41 mVA transformer unit bereon described as NOTL MTS #1. Niagara-on the-Lake Hydro Inc. is an OUB ticeased distributor operating within the municipal boundaries of the town of Niugara-on-the-Lake. Our community is facing a serious shortage of treasformation capacity and has recently contracted Hydro One Network Services Inc. to design and construct a station to meet the short and long term needs of our community. Due to the urgency of this project, an aggressive in-service date of June 2003 is requested to meet our summer peak demand. Similar applications have been submidled to the PMO and the OEB. Attached, please find the required documentation per part 2 af the application. Please note that the submitted forecast load schedule is not "guaranteed", but is our best estimate of our community's load growth at this time, Should you require any additional information, please do not besitete to call. Sincerely, Jun Huntingdon General Manager C Robert Davidson HONI C.John Redding -HONSI

MTS#1 Connection Agreement




		Customer Project Agreement CP		
<u>s</u>	chedule 'B': Niagara-on-the-	Lake MTS #1		
Transformation Connection P	nol Work Estimate:			
N/A				
Line Connection Pool Work 10	dimuter			
8305,200 (For connection to 11)	kV Q12S carcuit)			
Non-pooled Work Estimate (r	ereverable):			
\$122,000 (excludes GST)	oto recubicy.			
Manner of payment of Non Po	al Works			
March 28, 2003 50%	or work.			
May 26, 2003 50%				
Capital Contribution (includin	v Non- Powled costs):			
\$122,000 (Pool & Non-Pool Wo	rk)			
Components of Pool and Non-Po	ed Works			
- \$0 (for Poul Work)				
- \$122,000 (for Non-Pool Work)			
Available Capacity:				
Current available capacity to Nin				
Niegara-en-the-Lake DS	31.8 MVA			
Niagara Stanley 1S Distribution feeder)	10.0 MVA (allocated to Niagara-	on-the-Lake Hydro, supplied by H	lydre One	
Note: Capacity available to other	customers from Niagara Smaley TS	is excluded from the above		
Buse Load Trigger Point:				
Base Load Trigger Point: 26.553 MW (Based on January	2000 to December 2002 actual lead	data provided by Ningara-condi-	⊳Take Hydro	
Base Lond Trigger Point: 26.553 MW (Based on January and existing available espacity at	2000 to December 2002 actual load Nisgara-on the Leke DS and Nisga	data provided by Ningara-condi-	-Take Hydro	
Base Load Trigger Point: 26.553 MW (Based on January and existing available capacity at Components of Base Load Trigge	2000 to December 2002 actual lead Niagara-on the Lake DS and Niaga tr Point are;	data provided by Ningara-condi-	∍Ī ske Hydro	
Base Load Trigger Point: 26.553 MW (Based on January) and existing available capacity at Components of Base Load Trigge Niagara-on-the Lake DS	2000 to December 2002 actual lead Niagara-on the Lake DS and Niaga tr Point are; 20,200 MW	data provided by Ningara-condi-	⊳Teke ijydro	
Base Load Trigger Point: 26.553 MW (Based on January and existing available capacity at Components of Base Load Friggs Niagara-on-the Lake DS Niagara Stanley TS	2000 to December 2002 actual lead Niagara-on the Lake DS and Niaga tr Point are;	data provided by Ningara-condi-	∍Tuke Hydro	
Base Lond Trigger Point: 26.553 MW (Based on January and existing available capacity at Components of Base Lond Trigge Niagara-on-the Lake DS Niagara Stanley TS	2000 to December 2002 actual lead Niagara-on the Lake DS and Niaga tr Point are; 20,200 MW	data provided by Ningara-condi-	>Take Hydro	
Base Lond Trigger Point: 26.553 MW (Based on January and evisting available capacity at Components of Base Lond Trigge • Niagara-on-the Lake DS • Niagara Stanley TS Guaranteed Revenue Date:	2000 to December 2002 actual lead Niagara-uo file Leke DS and Niaga at Point and 20,200 MW 6,353 MW	data provided by Ningara-condi-	>Teke IIydro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing available capacity at Components of Base Lived Trigger Niagura-on-the Lake DS Niagura-Stanley TS Guarauted Revenue Date: Line Connection Prof Work:	2000 to December 2002 actual lead Nilagara-un fine Leke DS and Nilaga re Point and 20,200 M/W 6,353 M/W	data provided by Ningara-condi-	-Teke Hydro	
Base Lond Trigger Point: 26.553 MW (Based on January and evisting available capacity at Components of Base Lond Trigge • Niagara-on-the Lake DS • Niagara Stanley TS Guaranteed Revenue Date:	2000 to December 2002 actual lead Nilagara-un fine Leke DS and Nilaga re Point and 20,200 M/W 6,353 M/W	data provided by Ningara-condi-	≈Take ilydro	
Reso Lond Trigger Point: 26.513 MW (Bosed on January) and existing suitable capacity at Components of Base Lond Trigge Nagana on the Lake DS Nagana Sandre VTS Guaranteed Resource Date: Line Connection Faul Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	rTeke Hvdro	
Reso Lond Trigger Point: 26.513 MW (Bosed on January) and existing suitable capacity at Components of Base Lond Trigge Nagana on the Lake DS Nagana Sandre VTS Guaranteed Resource Date: Line Connection Faul Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	-Teke Hydro	
Reso Lond Trigger Point: 26.513 MW (Bosed on January) and existing suitable capacity at Components of Base Lond Trigge Nagana on the Lake DS Nagana Sandre VTS Guaranteed Resource Date: Line Connection Faul Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	≈Take ilydro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing resultable capacity at Components of Base Lond Triggs Components of Base Lond Triggs Nagara Garden Triggs Nagara Sander TS Guaranteed Revenue Date: Line Connection Fuel Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	≻Feke Hvdro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing resultable capacity at Components of Base Lond Triggs Components of Base Lond Triggs Nagara Garden Triggs Nagara Sander TS Guaranteed Revenue Date: Line Connection Fuel Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	-Take Hydro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing resultable capacity at Components of Base Lond Triggs Components of Base Lond Triggs Nagara Garden Triggs Nagara Sander TS Guaranteed Revenue Date: Line Connection Fuel Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	∍Take ilydro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing resultable capacity at Components of Base Lond Triggs Components of Base Lond Triggs Nagara Garden Triggs Nagara Sander TS Guaranteed Revenue Date: Line Connection Fuel Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	⊳Teke iivdro	
Base Lond Trigger Point: 26.513 MW (Based on January) and existing resultable capacity at Components of Base Lond Triggs Components of Base Lond Triggs Nagara Garden Triggs Nagara Sander TS Guaranteed Revenue Date: Line Connection Fuel Work: Transformation Pool Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-		
Base Lord Trigger Point: 26.513 MW (Bosed on January) and existing svaliable capacity at Components of Base Lived Trigger Niagara-condite Lake DS Niagara-Stanley TS Guaranteed Revenue Date: Line Connection Poul Work:	2000 to December 2002 actual lead Nikgara-un lite Leke DS and Nikga R Point-ane 20,200 MW 6.353 MW	data provided by Ningara-condi-	FT eke livdro	

Customer Project Agreement CPA V2 (4-2002) Niugara-on-the-Lake W18 #1 gara-on-the-Lake Hydro inc. (the "Cassuro-t") has requested and Hydro One Networks Inc. ("Notworkst") has ted to coment their new 115-27,6 kV 2544 MVA transformed station "Niggora-on the Lake MTS #1" (the eed to consist their flow 115 220 XY 2991 XVV intentational states that the property of the second to the second t icel Summary rryjew and purpose of the project gora-on-the-Lake Hydro has advised Networks that it would need now repactly to supply its 27.5 kV loads in the gggra-m-tho-Lake supply area. The leads in the Nisquar-ou-fiel-lake area have already exceeded the available again-m-tho-Lake supply area. The leads in the Nisquar-ou-fiel-lake area have already exceeded the available acity. Ningara-on-tho-Lake Hydro plans to build a customer owned new 115-27.6 kv 75/41 MVA transformer ion Niagara-on-the-Lake MTS #1 in the Town of Niagara-ca-the-Lake. trastitution has requested that Notworks connect the new Miagara-on-the-Lutte MYS #1 to Networks 115 kV uit Q128. The cost of connecting the Ningara-on-the-Leke MTS #1 to Eyem One Networks System is described are One recommended an entirely pool funded option to connect Niegara-or-the-Lake MTS#, to two cartains 15 and Q128 is, it provides improved restoration is no for supply and avoids long duration amages to the MTS, agars on-the-Lake Hydro has declined this option and has decided to connect the MTS in a single circuit Q128. gara-on-the-Lake Hydro fully recognizes that this single circuit connection to the MTS will have increased oration time for sustained and planned outages). ody for Service date May 26, 2003 arial Circumstuners e Project schedule is subject to: the Customer executing and returning this Agreement to Networks by no later than Fahreary 28, 2003, and all accessary approvals being obtained as onlined under Special Communications. is Agreement constitutes the entire agreement between the parties with respect to the subject matter of this B Agreement constituence and effective agreement and the presence and agreement and appear to the subject homeometric and agreement and appearation all the presence and agreement and appearation and the presence and agreement. Schodules A'' and "U", line Standard Terris and Conditions (TRC V 2 ISST 15-25 55-2007) and a shadood Automotion (4) with Schodules Terris and Conditions (TRC V 1-8H t 12-20 2-20-20), thingthe favorable 24. 3) attached horoto are to be read with and from part of this Agreement. WITNESS WHEREOF, the pensies hereto have traised this Agreement to be executed by the signatures of their per officers, as of the day and year first written above. DRO ONE NETWORKS INC. progra all Contemper Contracts & Business Relations ave the authority to bind the Corporation. oeral Manager - Ningara-on-the-Leke Hydro (no ave the authority to bind the Corporation.


Amendment






Request to H1 for Dispute Resolution






Request for OEB Intervention





Requested By-Pass Compensation





OEB Transmission System Code



PHASE I POLICY DECISION WITH REASONS

customer should not be allowed to transfer existing load from the transmitters' facilities). A customer may waive the right to construct its own connection facilities to serve new load as part of a contractual negotiation. In order to be effective and enforceable, such a notiver must be in writing, and should include a rejerence to the Section of the Code bestoving the right, and should stipulate that the Customer has waived the right voluntarily, and without undue influence or duress.

Where contracts entered into prior to the adoption of this provision contain restrictions on the customer's right to build its own facilities to serve new load, such restrictions shall be unenforceable.

4.8.1 Analysis and Findings

Hydro One agreed that customers should have the right to arrange for their own connection facility requirements if Available Capacity will not meet their new load requirements. The determination of whether Available Capacity is adequate should be: (1) based on both local and system wide considerations; and (2) made jointly between the transmitter and customer, with disagreements subject to a timely dispute resolution process. Hydro One further submitted that a customer's new load must not be incremental load airendy included in the initial load forecast that led to the construction of the transmitter's Connection factive in the first place. If load in the initial load forecast is transferred to a customer's own connection facilities, this would constitute hypass of the transminer's Connection facilities and would have an unacceptable negative impact on other

APPeO submitted that it is unworkable and unrealistic from an economic point of view to expect that a customer would split new load from old. Such a requirement would lead to uneconomic duplication of connection facilities. In its view, this issue needs to be resolved in conjunction with proposition 5.3 of the Transmission System Bypass section. Sithe supported APPrO's position.

Hydro One - "Available Capacity"



2.0 Ratings and Loading Criteria of existing facilities for the purposes of CCR

The standard practice to calculate available capacity will be based upon the following loading criteria or as established by Hydro One Networks Inc.:

Ratings and Loading Criteria of Existing Facilities

Transformer Stations	Line Connections	Low Voltage Feeders		
The Ten Day Limited Time	The lesser of the capacity of the	44.00kV Feeder 25.00 MVA		
Rating (10 Day LTR) of a fransformation station as	Transmission Line Connection -Or-	27.60kV Feeder 16.70 MVA		
established by Hydro One Networks Inc.	The Transformation Facility based on Ten Day Limited Time Rating (10 Day LTR) of that facility as established by Hydro One Networks Inc.	13.80kV Foeder 8.00 MVA As established by Hydro One Networks Inc.		

For shared facilities, there shall be a determination of the proportion of the shared facility that should be allocated to the customer. Hydro One Networks Inc. at it sole discretion, may provide exceptions to the above practice if there are satisfactory operating arrangements and agreements in place with a customer.

3.0 Available Capacity

Available Capacity is that portion of the existing capacity, which can "effectively & economically" with Hydro One Networks Inc.'s agreement, supply the customer's peak load. This applies to Hydro One Networks Inc. owned facility, shared facilities and customer owned facilities. The following rules shall apply in the determination of Available Capacity:

- (a) Any part of the existing capacity that cannot "effectively & economically" be utilized to serve the new load shall be excluded from the Available Capacity. The determination of effective and economic capacity shall be based upon the least capital cost option to supply the "end user."
- (b) When the customer's forecasted incremental load (step load) is such that it can not be supplied in entirety from the existing Available Capacity, the romaining Available Capacity will be excluded for the purposes of CCR. However, it the actual

Exhibit 30

OEB Transmission System Code



PHASE I POLICY DECISION WITH REASONS

This principle guided the Board primarily in a number of findings under Contestability.

 Partie careable to effect efficiencies in their use of electricity without juring promitive measures or distinctainess where a mountifier may impose a minimum payment obligation to cover present loads in Arabable Capacity on existing Connection facilities.

This prenciple guided the Board in findings 5.1.1, 5.2.1, 5.4.1, 5.6.1 and 8.9.1.

4. New generation is not discouraged.

This principle guided the Board in findings 5.1.1 and 5.4.1.

5. Unnecessary transmission asset diplication is avoided.

The Board approach recognized that "Transformation Connection" is currently a contestable area in Ontario, and thus should be managed in a different way than is the case for the Line Connection and Network poulse. Transformation Connection assets can be displicated, subject to the Board-approved approach to compensate for bypass. This issue was canvassed in Board Proceeding RP-1999-0644. Durphantion, reinforcement or reconfiguration of Transmission Network assets and Line Connection assets are subject to much more stringent control, and is pertainted only in certain circumstances. This principle guided the Board in Endings 4.8.1 and 5.3.1.

 Transmission assets are considered to histranded assets only to the extent that their value has not been captared in the revenue requirement established for the purpose PHASE I POLICY DECISION WITH REASONS

of rate sorting. Assets which have been fully depreciated are not consultered to be strended by hypotes, and assets which have been partially depreciated shall be considered to be stranded only to the extent that their value has not been fully considered to be stranded only to the extent that their value has not been fully considered to the strands of the considered to the consider

This principle guided the Board in finding 4.8.1.

Economic evaluations should include appropriate costs and revenues that are
associated with transmission connection to the extent that these accommodate new
load. Economic evaluations should exclude sunk costs and historic revenues.

The sampe of this principle was expanded from its initial version to include the concept that the evaluation should be limited only to costs associated with new load. This principle guided the Board in findings 8.1.1 and 8.8.1.

- Load customers are held responsible for their load forecasts subject to a true-up mechanism. There we two proposed exceptions in this principle;
 - embedded generation units of 1MW or less; and
 - measures for energy conservation, energy efficiency, load nanagement and the use of renewable energy resources.

In these cases load customers experiencing shortfalls in projected load should receive relief through periodic true-ups and load forecast wifustment.

The scope of this principle was narrowed somewhat from the initial version by replacing "cleaner energy sources" with "renewable energy resources". This principle guided the Beard in finding 8.9.1.

Exhibit Bloods

1

2001 Planning Document




		NOTE Loan' F	Projections		* 0.00				
Actual kW/ Billing Pea	dos.	NOTE Eddi: P	vojecions		April 4/01				
YEAR	JAN FEB	MAR AI	'R MAY	JUN JUL	AUG	SEP	OCT NOV	DEC AVG	XAM
109 5 1997		635 20303 993 10881	18207 18596 17549 16400		18 25250		19043 21:		
1998	21282 19	733 19874	17549 16400 17169 22743		310 25410 727 31844		20129 219 19328 213	102 23054 221 258 24829 237	
1999 2000		141 21111 814 20680	18937 29091		535 30046	29250	20019 233		
2001		814 20680 066	20352 23396	28179 30	938 83588	33174	21318 24	528 26505 256	33583
Conversion to kVA.									
.9% pf YEAR	JAN FEB	MAR AP	m 1985						
				JUN JUL	AUG	SEP (DOT NOV	DEC AVG	MAX
1995		153 22559 214 22090	20230 20662 19499 16222	25654 281 30329 321	887 31400	28704		968 25416 248	
1993		926 21860	19077 25270	32761 341		24649 29668	22366 243 21476 230	336 25818 248 321 27588 263	
1929 2020		490 23457	21041 25657	32596 37		32500		396 27999 277	
2001		349 22978 629	2294/ 25996	31309 34	142 37314	3686D	28687 272	%3 29450 287	712 3/314
Projected Peak KW L	.og <u>ds</u> SUMMER WINT			0150701-00-1-0					
YEAR	PEAK PEA			CUSTOMER ADD	SITIONS	DIVERSIFIE	ED LOAD W	IN-SERVICE DAT	E
2001 2002		393		Leon's Furniture V			300	Sept/01	1
2003	40925 32: 41484 32:			Henry Shain Area		ticals	400	Sept/01	
2004	42049 333			McDonaki's Resta Jackson Triggs w			150 250	Aug/01 Jale/01	
2005	42820 338	569		Peller Estates win	ory		300	Oct/01	
Projected Pask KVA	Loads *using	II Street		Royal Niegera Go	ficluthouse/m	igation	200	Jun/01	
	SUMMER WINT			VOA Wine District Holiday Inn 90 uni		ir.	150 500	Apr/02 Jul/02	
YEAR	PEAK PEA			Maidenfield Green	houses		200	Jul/01	
2001 2002	40042 348 45472 359			White Oaks Additi			250	Jul/01	
2008	48084 364			Pallisk Estates our	nimencial/reside	antial	150 150	May/02	
2004	46721 368	110					150	May/03 May/04	
2005	47595 374	10		Base Load Growth	niloffiii		150	May/05	
				Dase Livii: 15101/1	en min		1%		

Exhibit 12B

"Imbedded"



Exhibit 12B ткаххитавіни сомоля MINUTES OF MEETING March 10, 1999 Niagara-on-the-Lake HEC Planning Meeting WHUTES PREPARED: April 14, 1999 David Robertsen NOTE HEC Bir Huntinge on Cettario Lydro Ontano Hydro Robert Davidson LO Stanley TS Auto Transformer Supply Option Ontain: Hydro is proposing to milize from 5 to 10MW of the 20MW of capacity available at the Stemes TS note-facusfications to supply MCCH III.C when the NOTL PS capacity is close in its LTR, around 32 to 34 MW. This proposal fits in with the utility's contingency planning where Stanley TS would be used to pick up about 2 to 3 MW of load at the St David's community. Outstid Hydro [PNAM] will append the M20, which is 336 ACS2, with some pote regracement and installation of a neural. The M19 will not be appended but will be left to give. The unity covine that the line going somes the ± 0.5 belonged to Octano Eyelin; the mility circuit begins on the next pole which have switch rescalled. Short team capacity at Stanley TN is limited as a dow loss leading From three to five years is expected. Water this load is gone, capacity should not be an issue, depending of course or whitever other load may have developed in the meantion. The new Marketing Design Committee coles would then be in offers but impact on future planning is made in H was noted that key new capacity invalled at this man, such as the Strudey TS supply to NOTE 1000, would be considered to be "imbedded" under MDC rules. MOT: HTC advised Outside Hydro that it accepts this rapply option, Based on the acceptance Outside Fyriro is proceeding with the process and will obtain management's approval. A mid July 1999 in corvice date is targetext. Action: D Bahra There are no place at this firm to remove any of the four an ottors form Startley TS. 2.0 Stanley TS Auto Transformer Protortion Issues Existing prosecution will be adequate to protect usual of Controls Hydro's existing equipment TCT, 321 relays will be installed to protect the transformers from both distance and internal fault-





Supplementary Exhibits



Supplementary - Exhibit 13

Ningara-on-the-Lake "South" TS: Build a 118-27.6kV Transformer Station

Budgetary Costs for TS


Option	Ball Park
	Cost. *
Option 1a.	\$3.76M
1x25/41.7MVA 115-27.6 Ky Transformer	
2 feeder positions with 27.6kV, 600A Rectosers	
(including Land +EA)	ı
Option Ib.	\$2,73M
tx15/25MVA 115-27.6 Ky Transformer	
2 feeder positions with 27.6kV, 600A Rectosors	
(including Land +FA)	:
This said ma (11)	
Option 2.	\$4.73M
UX35/11.7MVA 115-27.6 Ky Transformer	\$4.75KI
2 feeder positions with 27.6kV \$200A Circuit Breakers	
(including Lind (BA)	!
*These half park costs are for budgefary purpose to show the	relative ranking of
the options described above. These costs include bullpark cos	t of land and EA
NM overhead and interest.	

Line Tap budgetary Costs - Common to all options (not included in TS Costs above)

215 KV tap from Q12S to new TS	\$125,000
	 !



Supplementary - Exhibit 23





Supplementary - Exhibit 24

Hydro One is currently reviewing these OEB decisions including those referencing the CCRA policies. Should we determine there is any impact regarding the York TS CCRA we will contact you to review the issue(s) noted.

Hope you find the above to your satisfaction.

Please call me if you wish to discuss further.

Robert

----Original Message---From: Jim Huntingdon [mailte:jhuntingdon@notlhydro.com]
Sent: Wednesday, June 09, 2004 12:19 PM
To: Robert Davidson
Subject: York TS Pool and Non-Pool Charges

Hi Rob

As discussed yesterday, in accordance with the Bydro One / NOTL Bydro CCRA agreement section 20.1 and our requirement to provide station accounting to the OBS annually, we need to meet "one year after the end of the month following the in service date of the new station" to calculate tarrifs. I will be on vacation the first two weeks of July but am available after the 14th to meet.

The standard terms and conditions for transmission customer connection, projects agreement indicates that Oydro One should have provided NOTL Dydro with actual costs accounting for both the "pooled" line connection costs 15305,200 revenue guarantee) within 180 days and "con-pooled" costs 18132,000) within 60 days of the in-service date May 26, 2003 (sections 12 and 14). I realize that the new actual "pooled" cost will need to be re-run in the capital contribution model along with updated loss days or York TS. As a matter of trust, we have always provided our customers with actual line extrastor cost data and as required, updated the CCSA model accordingly and provided this data. We trust that this data and updated model information will be offered to us for the York project.

Please advise us of potential dates to meet.

thanks

Jin Huntingdon President Niagara-on-the-Lake Hydro Inc. 905 468-4235 X55 905 468-3861 fax

Supplementary - Exhibit 32 Neighbouring LDC



