

December 8, 2009

VIA RESS, COURIER AND EMAIL

Ontario Energy Board
P.O. Box 2319
2300 Yonge Street, 27th Floor
Toronto ON M4P 1E4


Attention: Ms. K. Walli, Board Secretary

Dear Ms. Walli:

Re: Canadian Niagara Power Inc. - Application for Leave to Construct and Reinforce Transmission Facilities in the Fort Erie / Niagara Falls Area - Submissions-in-Chief (Board File No. EB-2009-0283)

We are counsel to Canadian Niagara Power Inc. (the "Applicant"). Enclosed are two copies of the Applicant's Supplemented and Restated Submissions-in-Chief, which have been filed electronically on RESS.

Yours truly,



Charles Keizer

CK*dh

Tel 416.865.7512
Fax 416.865.7380
ckeizer@torys.com

c.c. Robert Caputo, Ontario Energy Board
Michael Millar, Ontario Energy Board
Intervenors
Angus Orford, CNP
Douglas Bradbury, CNP
Jonathan Myers, Torys LLP

ONTARIO ENERGY BOARD

IN THE MATTER OF the *Ontario Energy Board Act, 1998*, S.O. 1998, c.15 (Sched. B);

AND IN THE MATTER OF an application by Canadian Niagara Power Inc. for an Order or Orders pursuant to section 92 of the *Ontario Energy Board Act, 1998* (as amended) granting leave to construct and reinforce transmission facilities in and around Fort Erie, Ontario.

APPLICANT'S SUPPLEMENTED AND RESTATED SUBMISSIONS-IN-CHIEF

December 8, 2009

1 **APPLICANT'S SUPPLEMENTED AND RESTATED SUBMISSIONS-IN-CHIEF**

2 **1. Introduction**

3 These are the supplemented and restated submissions of Canadian Niagara Power Inc. ("CNP")
4 in the matter of its application for leave to construct and reinforce transmission facilities in the
5 Fort Erie and Niagara areas (EB-2009-0283). The Applicant's Submissions dated November 6,
6 2009 are subsumed and restated, in part, in these submissions and these submissions should be
7 taken as the complete submissions-in-chief of the Applicant. Below, CNP will set out its case in
8 brief. Each of the key elements of its position will be expanded upon to establish that, pursuant
9 to section 96(2) of the *Ontario Energy Board Act*, 1998 (as amended), the Project is in the public
10 interest with respect to prices and the reliability and quality of electricity service, as well as
11 consistent with the policies of the Government of Ontario with respect to the use of renewable
12 energy sources.

13 CNP has proposed a project that will develop a synchronous connection between the CNP
14 transmission system, the IESO-controlled grid and the NYISO-controlled grid to provide the
15 ability for instantaneous restoration of service on the CNP transmission system upon the loss of a
16 single element (the "Project"). The Project has two purposes: (i) improving reliability on the
17 CNP transmission system in accordance with Good Utility Practice; and (ii) providing inertia
18 benefits to Ontario.

1 **2. Case in Brief**

2 From a reliability perspective, the current configuration of CNP’s transmission system is
3 deficient in a fundamental way. The system only has one normal source of supply. CNP’s
4 transmission system is exposed to the risk of its entire system “going dark” for extended periods
5 if any one of several circumstances occur (Exhibit B, Tab 3, Schedule 1, p. 3). Because of the
6 current configuration, these *system-wide* outages affect over 15,000 end-users (IR Response
7 1.0(iv)), including residential, commercial, institutional and industrial end-users and
8 approximately 30,000 Ontario residents (Exhibit B, Tab 1, Schedule 1). It is also a disincentive
9 for future growth.

10 Based on benchmarking, CNP’s transmission system’s reliability performance exceeds the
11 average outage frequency and duration benchmarks established by the Canadian Electricity
12 Association and Hydro One Networks Inc. (“Hydro One”) (Exhibit B, Tab 3, Schedule 1 at p.
13 11-12). Historically, CNP’s performance under the Independent Electricity System Operator’s
14 (“IESO”) Local Area Performance benchmark have been inconsistent ranging from “Red”,
15 below threshold, to “Green”, which is the threshold (Exhibit B, Tab 3, Schedule 1, p. 10). Given
16 the configuration of the system and the natural risks associated with it, recent “near misses”
17 could have easily, and once again, driven CNP’s performance below the Local Area benchmark
18 (Response to Interrogatory 1.0(x)). Recent good fortune leading to better performance is no
19 guarantee that the trend will continue because the underlying reliability problem has not been
20 remedied.

1 Good planning dictates that a transmitter should learn from the past and implement solutions to
2 resolve reliability concerns in the present so as to avoid a future with the same consequences for
3 end-users. Focusing only on good performance over a very short term period (such as 3 years) is
4 “selective planning” and unreasonably ignores the problems that gave rise to the true indicators
5 of performance over a longer timeframe.

6 The implications of reliability are real for end-users, as evidenced by letters from customers (see
7 CNP response to Board Staff SI-3 and Appendix “B” thereto). In addition, CNP provided
8 evidence in Section 2 of Exhibit B, Tab 4, Schedule 1, of the impact on end-users showing costs
9 of \$11.5 million. This cost validated CNP’s calculation of value of lost load (“VoLL”) in the
10 range of \$16.1 million. Furthermore, as described in CNP’s response to Board Staff SI-1, the
11 reliability of the CNP transmission system also has significant issues for prospective renewable
12 energy generators seeking to connect projects developed under the OPA’s Feed-in Tariff
13 Program.

14 There has been some discussion in the proceeding as to the standard to apply with respect to
15 CNP’s obligations under the Transmission System Code (“TSC”). Notwithstanding that CNP
16 has acknowledged that the NERC standard does not apply (General Response to Supplemental
17 Interrogatories SI-1, -2 and -3), CNP has presented evidence and has consistently maintained
18 that, based on the facts unique to CNP, the Project is needed as part of Good Utility Practice and
19 that there are sufficient quantitative and qualitative benefits to justify the Project in the public
20 interest. As noted in Section 4 below, the TSC’s definition of Good Utility Practice permits its
21 application to specific facts and actions.

1 CNP submits that the Project, which enables the system to withstand the loss of a single element,
2 is the only solution to the reliability concerns. CNP considered a number of project variations
3 and alternatives and each was either not viable or of questionable viability (Exhibit B, Tab 6,
4 Schedule 1). Standing still is not an option as the emergency tie currently in place between
5 CNP's transmission system and U.S. National Grid's ("USNG") transmission system in New
6 York has limited capacity relative to CNP's peak load (Exhibit B, Tab 3, Schedule 1, p. 8) and
7 takes significant time to bring into service (Response to Supplemental Interrogatory SI-4). The
8 Project provides the only solution.

9 If the Project is brought into service, CNP's transmission system will be able to withstand the
10 loss of its primary source of supply and to deliver uninterrupted supply to its end-users in such
11 circumstances. If this is the case, the concerns expressed by end-users will be eliminated, the
12 VoLL will be an avoided cost and renewable generation resources will be facilitated.

13 The Project will develop a synchronous connection between the CNP transmission system, the
14 IESO-controlled grid and the NYISO-controlled grid, thereby providing significant system-wide
15 benefits to Ontario due to the resulting increase in inertia capacity. The Project is rated to
16 provide 150 MW of inertia capacity in both directions at the Niagara/New York interface, with
17 an additional 100 MW in certain circumstances. As indicated in the response to Interrogatory
18 1.0(v), the IESO confirms that the Project would enhance the overall Ontario import/export
19 capability and, therefore, provide:

- 20
- increased market activity and efficiency;

- 1 • flexibility to address situations of surplus baseload and/or renewable generation;
2 and
- 3 • flexibility to import during periods of supply shortages (Board Staff Interrogatory
4 1.0(v)).

5 CNP quantified the intertie benefits at \$39.9 million, being the total of the present value of \$36.6
6 million arising from avoided generation capacity costs and \$3.4 million arising from relieving
7 constraints during generation maintenance outages (Exhibit B, Tab 4, Schedule 1, p. 10). The
8 OPA confirmed that, subject to an adjustment, CNP's calculation of \$36.6 million of intertie
9 benefits is reasonable (See Appendix "D" of Supplemental Interrogatory Responses). In
10 particular, in its correspondence, the OPA stated that "the use of avoided costs for demand
11 response for this case is not entirely accurate because the value of demand response takes into
12 account the value of reduced reserve margin requirements and losses. The value of demand
13 reduction is expected to be about 20% higher than the value of additional supply" (See Appendix
14 "D" of Supplemental Interrogatory Responses). Accordingly, CNP recalculated the avoided
15 generation capacity benefit associated with the Project so as to take into account this variable.
16 This recalculation determined the value of the avoided generation capacity benefit to be nearly
17 \$30.5 million (See response to Board Staff SI-7).

18 According to its pre-filed evidence, CNP's calculation of the Project's net present value ("NPV")
19 is \$10.4 million, being net of costs and the present value of both local benefits and Ontario
20 system-wide benefits (Exhibit B, Tab 5, Schedule 1, Figure 5.2). Even when factoring into the
21 NPV calculation the above-noted recalculation of intertie capacity benefits, the NPV remains
22 positive at \$4.27 million (Response to Supplemental Interrogatory SI-7). Furthermore, it is

1 important to note that this NPV calculation does not include the significant qualitative benefits
2 described further in Section 5(a) below and set out in Exhibit B, Tab 4, Schedule 1 at pp. 15-21.
3 Clearly, based on the foregoing, the Project is in the public interest and satisfies the requirements
4 of Section 96(2) of the OEB Act.

5 In the submissions that follow, the following is addressed:

- 6 • Reliability concerns, including:
 - 7 • Problems with the configuration of CNP's transmission system,
 - 8 • Reliability benchmarks,
 - 9 • Resolution of the reliability threat, and
 - 10 • the IESO's Ontario Resource and Assessment Criteria;
- 11 • Good Utility Practice and the Project as the Only Viable Solution;
- 12 • System-Wide Benefits for Ontario
- 13 • Qualitative Local and System-Wide Benefits
- 14 • Positive Net Present Value and Cost Recovery

15 **3. Reliability Concerns**

16 (a) **The Current Configuration Does Not Work**

17 The current configuration of the CNP transmission system does not allow for the system to
18 provide uninterrupted supply upon the loss of its primary source. As explained in Exhibit B, Tab
19 2, Schedule 1, loss of the primary supply may result from:

- 1 • a fault on the Hydro One transmission system,
- 2 • a fault on line A37 between Hydro One's Murray TS and CNP's Station #11,
- 3 • a failure at Station #11, which is the sole supply point to line L2, or
- 4 • a fault on line L2, between Station #11 and Station #18.

5 An interruption to CNP's primary supply results in the entire CNP transmission system going
6 dark.

7 While the CNP transmission system has some limited backup capability from USNG through the
8 use of the Emergency Tie Line¹, this backup capability is deficient. As described in Exhibit B,
9 Tab 3, Schedule 1 at p. 8, the Emergency Tie Line is no longer capable of meeting average
10 monthly peak load levels on the CNP system. Moreover, as described in Exhibit B, Tab 3,
11 Schedule 1 at pp. 5-8, the Emergency Tie Line cannot be engaged without there first being a
12 significant interruption to supply. This is because it takes a minimum of 4 hours to complete the
13 co-ordination and switching over to this alternate supply source, in a manner that does not cause
14 adverse impacts on systems in New York and in Ontario, in the event of a forced outage.² As
15 explained in CNP's response to Board Staff SI-4, this timeframe is needed:

- 16 • To allow for CNP to carry out its initial response, which involves identifying the
17 problem and its location, assessing the damage, determining the approximate

¹ The Emergency Tie Line is described at Exhibit B, Tab 1, Schedule 1.

² For a planned outage, such as for purposes of carrying out maintenance on the CNP system, CNP can undertake some of the co-ordination activities in advance but the process of switching over to the Emergency Tie Line still requires an outage of approximately 30 minutes in duration. During such a planned outage, with few exceptions, the entire CNP system necessarily goes dark and all end-users are affected. Moreover, in order to switch back from the Emergency Tie Line to the primary supply source following either a planned or forced outage, CNP's system experiences an additional 30 minute outage during which the entire system goes dark and all end-users are once again affected.

1 repair time and making a decision on whether or not the outage warrants the use
2 of the Emergency Tie Line. Where the outage is on HONI's system that supplies
3 CNP, CNP must await the outcome of HONI's initial response before a decision
4 can be made;

- 5 • To allow CNP's System Operator to communicate the relevant information to the
6 IESO, HONI and USNG;
- 7 • To allow USNG, upon receiving the communication from CNP's System
8 Operator, to initiate and complete its own process of preparing its system to
9 supply the Fort Erie load, including ensuring sufficient generation capacity is
10 available; and
- 11 • Upon USNG notifying CNP that it is ready and able to provide emergency supply,
12 CNP must then follow a 31-step switching procedure to effect the transfer of its
13 load to USNG through the Emergency Tie Line.

14 For the duration of this process, the entire CNP transmission system remains dark and all end-
15 users are affected.

16 (b) **Outages to the CNP Transmission System are System-Wide Outages**

17 With the exception of only a few minor circumstances,³ the CNP system's configuration results
18 in outages that are *system-wide* outages and which affect over 15,000 end-users in the service
19 territory, which has a population of approximately 30,000 people. The CNP service territory is
20 primarily urban and includes a diverse group of end-users. These include residential,
21 commercial, institutional and industrial end-users who depend on a reliable source of supply
22 (Exhibit B, Tab 4, Schedule 1, pp 6-7). As explained in Exhibit B, Tab 3, Schedule 1 on p. 14, in
23 addition to unplanned or forced outages, due to the system's configuration some planned
24 maintenance activities on CNP's transmission system require outages to the entire system. Two

³ The minor exceptions are those instances where planned outages are needed for maintenance purposes on certain parts of the system where isolation of that outage is possible.

1 such outages have taken place in recent years. Outages adversely impact individuals, businesses
2 and institutions, as well as the economic well-being of the region served by CNP's transmission
3 system. CNP filed as evidence, in its response to Board Staff SI-3, letters from end-users
4 expressing concerns relating to the need for reliability. This series of correspondence from end-
5 users stresses the importance and need for improved reliability on the CNP transmission system.
6 Examples of comments from the letters include the following:

- 7
- 8 • Aero-Safe Processing Inc., which operates an anodizing, electroplating and metal
9 finishing facility that supplies the military and aerospace industries, explains that "*a large
10 power interruption would impact our customers ability to assemble completed product
11 and meet the very stringent time lines dictated by their prime customers resulting in loss
12 of revenue and large financial penalties . . . Improving the reliability of electrical power
13 to this facility would enhance our ability to meet our customer's timelines, maintain our
14 environmental obligations and employee safety requirements.*"

 - 15 • AmericanColor, which operates a large printing facility for newspaper and mail inserts
16 and which serves major retailers and large food chains in Canada and the United States,
17 explains that "*a major power interruption would have a large impact on (client) sales, as
18 their flyers would not be printed and distributed in the allowed timeframe. The key
19 impact to the food chains would be the loss of perishable goods that would not be
20 advertised and therefore not sold.*"

 - 21 • The Town of Fort Erie, through the Office of the Mayor, explains that "*Fort Erie has had
22 its share of power interruptions . . . CNP has proposed an elegant solution . . . This will
23 establish a level of reliability of supply for the Town of Fort Erie that other communities
24 are receiving, a very important economic development benefit . . . As Mayor I wish to
25 offer my support for this CNP project as part of the overall pool of transmission
26 resources and bring the same level of reliability to our border community as other towns
27 and cities across Ontario now enjoy.*"

 - 28 • Buffalo and Fort Erie Public Bridge Authority explains that "*the Peace Bridge is . . . the
29 busiest border crossing for cars and the third busiest truck crossing (between Canada
30 and the United States) . . . Many sectors of the local, regional, provincial and national
31 economy rely on a free-flowing border with no interruptions. Many factories rely on
32 just-in-time inventory control which would be disrupted if the border is closed. Tourist
33 operators, particularly in the Niagara Region rely heavily on cross border traffic. A long
34 term power outage would have a significant negative impact on border traffic movements*"

1 *and the overall economy. It is imperative that the reliability of the power supply be*
2 *enhanced to ensure that the border continues to operate uninterrupted. It is crucial that*
3 *an alternative or a redundant power supply be achieved as quickly as possible.”*

4 Among the end-users is the Buffalo and Fort Erie Public Bridge Authority, which operates the
5 Peace Bridge – one of the busiest and most economically significant border crossings between
6 Canada and the United States (Exhibit B, Tab 4, Schedule 1, p. 15). This is a critical
7 infrastructure link and among the busiest border crossings between Canada and the United
8 States. The Peace Bridge is important for trade and houses vital security and immigration-
9 related facilities. Power outages result in significant delays, most notably to truck traffic. The
10 economic impacts of such delays cannot be measured precisely, but it is estimated that on
11 average trade across the Peace Bridge is valued at US\$3.4 million *per hour*. In addition, there
12 are impacts on truck drivers, transport companies and on all of the parties who rely upon the
13 timely delivery of goods (See Exhibit B, Tab 4, Schedule 1 at pp. 15-17). A letter from the
14 Buffalo and Fort Erie Public Bridge Authority is included in Appendix “B” of the Supplemental
15 Interrogatory Responses.

16 As noted in section 2, above, and as described in Exhibit B, Tab 4, Schedule 1 at pages 2-9, CNP
17 has provided evidence of the local economic implications of CNP’s reliability problems on its
18 system end-users. In particular, CNP considered the value of lost load (“VoLL”) as the basis for
19 quantifying the benefit, from the Project, of avoiding outages. This approach, conservatively
20 applied, determined that the value of avoiding outages has a net present value of \$16.1 million.
21 The validity of this finding was supported in the evidence through the use of “bottom-up”
22 calculations using data on a narrow range of local costs associated with service interruptions.

1 This approach identified \$11.5 million of avoided costs, which validates the finding through the
2 VoLL approach. CNP therefore concluded that the net present value of avoiding outages would
3 be \$16.1 million.

4 In addition, electricity generators require reliable transmission both as a source of supply for
5 their generation facilities and as a means for delivering their generation output. This includes
6 renewable energy generators proposing to connect either directly to the transmission system or to
7 the distribution system that is served by CNP's transmission system. CNP, through its
8 distribution system that serves Fort Erie, has received several queries and expressions of interest
9 from prospective renewable energy generators. Reliability history has been an important part of
10 these queries. As discussed in CNP's response to Board Staff SI-1, prospective renewable
11 energy generators may be reluctant to connect to the existing CNP transmission system or the
12 distribution system that it serves for reasons that include the following:

- 13 • Given the 20-year timeframe of a contract under the OPA's Feed-in Tariff
14 Program, a renewable generator would be interested in longer-term reliability
15 performance, which, based on data since 2002, would show that CNP has, on
16 average, experienced lower than average reliability;
- 17 • There is not much more that CNP can do to improve the reliability of its
18 transmission system unless it undertakes the Project, because the Project is the
19 only means of resolving the fundamental reliability problem associated with the
20 CNP system;
- 21 • Despite CNP's improved reliability performance over the last three years, the
22 number of near-miss events, the nature of the reliability problem associated with
23 the system, and the fact that there were no material changes made to the system or
24 its manner of operation which caused the improved reliability performance during
25 this timeframe, indicates that the system remains highly vulnerable to frequent
26 outages of significant scope and duration; and

- 1 • Under the FIT Contract for renewable energy generators, such a generator would
2 be at risk of not receiving payments for electricity in any period in which it is able
3 to generate but for an outage on the transmission system to which it is directly or
4 indirectly connected.

5 (c) **Reliability Benchmarks**

6 Typical measures of reliability include frequency, duration, loss of load probability, energy
7 unsupplied and customer impacts. With respect to the frequency and duration of outages under
8 the current configuration, CNP considered its historical performance against the findings of the
9 Canadian Electricity Association's *Study on Forced Outages of Transmission System Equipment,*
10 *115-149 kV* (Exhibit B, Tab 3, Schedule 1, p. 11). This analysis generally indicates that the
11 performance of the CNP transmission system has been below average. For the period 2002-2006
12 (being the period of the CEA report), the outage frequency on the CNP transmission system is
13 8.75 outages per 100 km-year, far greater (730% higher) than the CEA average frequency of
14 1.0534 outages per 100 km-year.

15 With respect to the comparison against the Hydro One Customer Delivery Point Performance
16 Standards, CNP's transmission system performance from 2002 to 2008 fell below both the
17 minimum and average performance standards for both frequency and duration of outages.
18 Specifically, as set out in Exhibit B, Tab 3, Schedule 1 at p. 12, this comparison shows that the
19 average of the three-year rolling averages for the frequency of interruptions on the CNP
20 Transmission System has been 2.9 outages per year, with a maximum of 4.3 outages per year.
21 This is compared to Hydro One's average benchmark of 1.1 outages per year and its minimum
22 standard of performance of 3.5 outages per year (See Figure 3.3(b)). With respect to outage

1 duration over the same period, the analysis indicates that the CNP Transmission System
2 experienced an average of 184 minutes of outages per year based on the average of three-year
3 rolling averages, as indicated by Figure 3.3(a), which is far greater than the average standard of
4 22 minutes of outages per year under Hydro One's CDPPS and greater than the minimum
5 standard of performance of 140 minutes per year.

6 In contingency planning, it is pertinent to consider the potential exposure of the system to risk.
7 Of particular note for CNP are the significant portions of the transmission system which consist
8 of lines strung on wooden poles located along road allowances where there is a risk that
9 vehicular accidents can cause service disruptions. These wooden poles are also subject to the
10 possibility of burning due to insulator tracking. In addition to the vehicle accidents and burning
11 pole incidents described in Exhibit B, Tab 3, Schedule 1, Figure 3.2 of the pre-filed evidence,
12 which lists events that resulted in actual system outages, in recent years there have also been a
13 number of similar events on these portions of the system that gave rise to significant risks of
14 lengthy, forced outages, but which did not actually result in service disruption. As described in
15 CNP's response to Interrogatory 1.0(x):

- 16 1) A vehicle accident occurred in 2005 that resulted in a broken transmission pole;
- 17 2) A transmission pole burned in 2006 due to insulator tracking;
- 18 3) A vehicle accident occurred in 2009 that resulted in a broken transmission pole;
19 and
- 20 4) A transmission pole burned in 2009 due to insulator failure on a 34.5 kV
21 underbuild circuit.

1 While each of these incidents could very well have given rise to lengthy outages to CNP's entire
2 transmission system, CNP and the end-users of the system were very fortunate that none of the
3 above-noted incidents actually caused forced outages. Nevertheless, these incidents demonstrate
4 the types of risks faced by CNP, any one of which poses a significant risk of causing a forced
5 outage.

6 In 2007 and 2008, favourable weather conditions were experienced and there were no vehicular
7 accidents affecting CNP's transmission system (Interrogatory Response 1.0(xi)). As part of its
8 ongoing maintenance programs, CNP carried out activities that included the removal of trees that
9 posed potential risks to transmission lines and the replacement of some older insulators. Prior to
10 2007, CNP also implemented more systematic line inspection and vegetation management
11 programs. While these activities may have reduced some risk, there is no way to quantify their
12 relative contributions, if any, to CNP's reliability performance in 2007 and 2008 (Interrogatory
13 Response 1.0(xi)).

14 Under the IESO's Local Area Performance benchmarks, the performance of a transmission
15 system is rated as "Red", "Yellow" or "Green" based on system performance in relation to
16 performance in recent years. Red indicates poorer performance than threshold and Green
17 indicates threshold performance. Since 2002, the rating of the CNP Transmission System has
18 gone from Yellow (2002) to Red (2003 and 2004) to yellow (2005 and 2006) to Green (2007 and
19 2008). The inconsistency in the performance record for the CNP Transmission System is
20 indicative of the fact that in some years CNP is fortunate that no major equipment failures or

1 supply outages occur but in other years, despite its good management, CNP is exposed to
2 potentially serious reliability concerns (Exhibit B, Tab 3, Schedule 1, p. 10).

3 As discussed in CNP's response to Board Staff SI-1, while CNP's local area performance based
4 on the IESO's process and criteria for assessment has been categorized as "Green" in 2007 and
5 2008, achieving this "Green" classification has been largely a function of the classification
6 methodology, which compares unsupplied energy levels in recent years against a 10-year
7 average level of unsupplied energy. For the "Green" years of 2007 and 2008, CNP performance
8 was measured against the 10-year average level of unsupplied energy on the CNP transmission
9 system between 1993 and 2002. Based on this, just a 30 minute outage in a period of average
10 load in one of those years would have caused CNP's classification to fall to "Yellow" and if an
11 outage of such duration were to have occurred in consecutive years, CNP's classification would
12 have fallen to "Red". However, the threshold for achieving the "Green" classification has been
13 reset for 2009 to 2014 based on the 10-year average level of unsupplied energy between 1999
14 and 2008. As such, for the next 5 years it will take an outage of approximately 150 minutes or
15 more for CNP's classification to fall to "Yellow" and two consecutive years with an outage of
16 such duration for CNP's classification to fall to "Red". Putting this measure into context,
17 declining performance over time lowers this threshold and better performance raises the
18 threshold. The underlying assumption is that a transmitter strives to improve. However, as in
19 CNP's case, when all improvements have been made, the change in the benchmark to signify
20 "Green" merely represents the shifts in CNP's good fortune and the inherent uncertainties
21 associated with the reliability of the system.

1 Despite this moving target, any one of the near-miss events noted in CNP's response to Board
2 Staff Interrogatory 1.0(x) would be expected to have given rise to an outage of approximately 4
3 hours. As such, CNP's classification under the IESO's process and criteria for assessing local
4 area performance can change at any time, as a result of just a single event. There is no certainty
5 that CNP will stay "Green" and there is nothing inherent in CNP's system that would enable
6 CNP to avoid falling to "Yellow" or "Red" under this performance indicator. Consequently,
7 CNP cannot provide assurance to end-users or prospective generators that it can consistently stay
8 within the "Green" classification. For these reasons, there should be little weight given to CNP's
9 recent classifications under this performance indicator.

10 (d) **Resolution of Reliability Threat**

11 Notwithstanding CNP's good management, a change in CNP's good fortune could return CNP to
12 "Yellow" or "Red" status and result in even poorer performance relative to the CEA or CDPPS
13 standards. If the Project is implemented, none of the incidents from 2002-2006 or the near-
14 misses in the past 3 years would have caused a transmission line outage resulting in system-wide
15 outages to end-users (Exhibit B, Tab 4, Schedule 1, p. 2).

16 Implementation of the Project will enable CNP to consistently achieve and improve with respect
17 to benchmarks. The threat to CNP's reliability, particularly by way of the total loss of supply
18 due to the loss of a single element, would be eliminated and the impact on and costs to end-users
19 would be avoided.

1 (e) **Resource and Transmission Assessment Criteria**

2 In response to Board Staff interrogatory SI-16, the IESO referenced the *Ontario Resource and*
3 *Transmission Assessment Criteria* (the “RTAC”) relating to load security and restoration.⁴ In its
4 response in SI-16, the IESO states that transmission systems such as CNP’s must be planned
5 such that all loads must be restored with approximately 8 hours.

6 CNP submits that the IESO has not fully stated what the criterion is or how it should be applied,
7 and has not adequately set out the context in which it should be applied. It is not a bright line
8 test that establishes a benchmark for reliability from an operator’s perspective.

9 As such, the Board should not give full weight to the IESO’s statement as it is written in the
10 IESO’s response to SI-16 and should take into account the following:

- 11 • The RTAC is to be used to evaluate long-term system adequacy and connection
12 assessments, not for identifying “operating” criteria (RTAC, p.1). CNP seeks to
13 implement the Project from an operational perspective to improve system
14 reliability and to implement a technical remedy to avoid the threat to reliability
15 that impacts all of the end-users in the CNP system. The approval of the Project
16 is about operation and the real life impacts associated with operation and not
17 about operating the system to a generally applied design standard of
18 approximately 8 hours.

- 19 • The study parameters must be applied on the basis of good utility practice and
20 judgment, taking into account the particular circumstances and characteristics of
21 the part of the IESO-controlled grid that is being studied (RTAC, p.3). As stated
22 in these submissions and in the general response to Board Staff SI-1, -2 and -3,
23 CNP has maintained that good utility practice should be applied based on the
24 circumstances on a case by case basis. It is reasonable to state that no utility in
25 Ontario would believe that it is good utility practice for a utility to take up to 8

⁴ The RTAC is available on the IESO’s website at:
http://www.ieso.ca/imoweb/pubs/marketAdmin/IMO_REQ_0041_TransmissionAssessmentCriteria.pdf

1 hours to restore power to 56 MW of load. Moreover, this load represents the total
2 demand of the CNP system and represents an urban area with diverse end-users
3 and an important international border crossing. Consideration should be given to
4 the fact that the contingency impacts 100% of the CNP load and that the Project
5 would help in improving the supply reliability. This is consistent with the IESO's
6 *Supply Deliverability Guidelines*,⁵ which state the following at page 3:

7 *The planned deliverability to be provided to a load should take into*
8 *account contingencies, past performance, probability of failure, the size of*
9 *the load involved, the cost of interruptions to the customers, and the cost*
10 *of remedial measures.*

- 11 • The 8 hour restoration time is part of a transmission system planning design
12 criteria that affected loads be restored within the following times.
- 13 a. All loads within approximately 8 hours;
- 14 b. Loads in excess of 150 MW within approximately 4 hours; and
- 15 c. Loads in excess of 250 MW within 30 minutes (RTAC, p.30).

16 Each case can be considered separately, taking into account the probability of the
17 contingency, frequency of occurrence, length of repair time, the extent of hardship
18 caused and cost (RTAC. p. 30).

19 Higher or lower levels of reliability may be applied for technical, economic,
20 safety and environmental reasons (RTAC, p.30). The criteria set out above are
21 planning parameters. One can only view these as basic minimums and not
22 standards to assess reliability from an operational sense. These criteria are not
23 determinative of good utility practice which is factually driven.

- 24 • It is important for the Board to understand the origins of the 8 hour time frame.
25 The 8 hour time frame evolved from the IESO's *Supply Deliverability Guidelines*,
26 which in turn were based on Ontario Hydro's "Guide to Planning Regional
27 Supply Facilities" (also known as the "E2" Guide). The IESO modified the E2
28 Guide as part of the *Supply Deliverability Guidelines*. Both provide for the
29 restoration of loads less than 75 MW within 8 hours. However it is important to
30 note the following:

⁵ The Supply Deliverability Guidelines are available on the IESO website at:
http://www.ieso.ca/imoweb/pubs/marketAdmin/IMO_GDL_0021_IMOSupplyAvailabilityGuidelines.pdf

1 *(The) E2 guide tried to capture the cost of interruptions by relating*
2 *transmission facilities to load size. However, the guide did not directly*
3 *specify the level of reliability to be provided in terms of typical measures*
4 *such as frequency, duration, loss of load probability, energy unsupplied ...*
5 *or customer impacts . . . Ontario Hydro made decisions on new facilities*
6 *or enhancements on a case-by-case basis. They were not made solely on*
7 *the provision of the E2 Guide. For example, higher levels of customer*
8 *reliability may have been provided for technical, economic, safety and*
9 *environmental reasons (IESO Supply Deliverability Guidelines, p.1).*

10 As such, the 8 hour time frame is not a bright line test, but only a planning parameter that is not
11 reflective of true operating conditions that must be taken into account as part of good utility
12 practice.

13 **4. Good Utility Practice and the Only Viable Solution**

14 CNP is relying on that part of the definition of “good utility practice” set out in section 2.0.33 of
15 the Transmission System Code which provides that "good utility practice" means:

16 *any of the practices, methods and acts which, in the exercise of reasonable*
17 *judgment in light of the facts known at the time the decision was made, could have*
18 *been expected to accomplish the desired result at a reasonable cost consistent*
19 *with good business practices, reliability, safety and expedition.*

20 While this aspect of the definition is worded so as to be applied with hindsight to projects that
21 have already been carried out, if CNP could have carried out this project without leave and then
22 sought recovery for costs at a later date, then this would be the applicable measure of whether it
23 was good utility practice to do the Project. As such, there is no reason why this portion of the
24 definition does not apply to a leave to construct proceeding. There are not two standards, i.e. one
25 for actions taken with leave and one for actions taken without leave. Using this portion of the
26 definition is therefore appropriate to employ on a case by case basis.

1 For the CNP transmission system, providing the ability to withstand the loss of a single
2 contingency is the only viable solution to providing improved reliability that, in the
3 circumstance, is consistent with fundamental principles of good utility practice. For a system of
4 the size and nature of CNP's transmission system, serving end-users with the diversity and
5 economic significance of those served by CNP's system, good utility practice requires CNP to
6 strive to improve reliability and to lessen the threat to reliability. The only solution that achieves
7 this is the Project, which permits the system to have the ability to withstand the loss of one
8 element. CNP would have a readily available secondary supply available to provide
9 uninterrupted service in the event of the unplanned loss of the system's primary supply. In
10 addition, good utility practice suggests that CNP should have the ability to carry out planned
11 outages for purposes of carrying out maintenance activities without incurring lengthy system-
12 wide outages in the course of switching to and from an emergency supply source (See Exhibit B,
13 Tab 3, Schedule 1, p. 14).

14 While CNP carries out a wide range of activities and is always considering improvements that
15 may enhance system performance, no such activities or improvements would address the basic
16 reliability problem of the system not being able to withstand the loss of its primary supply
17 source. As indicated in CNP's responses to Board Staff interrogatories:

- 18 • With respect to the two circuits on the limiting Queen St. Tower to High Tower
19 section, where only one of the circuits is currently energized, even if the second
20 circuit was upgraded to 60-cycle, re-insulated and energized, the basic reliability
21 problem of not having N-1 contingency would not be mitigated (See responses to
22 1.0(vi) and 2.0(ii)(b));

- 1 • An upgrade to the limiting transmission line section between Queen St. Tower
2 and High Tower would improve line capacity by a small margin and would
3 therefore increase the capacity of the Emergency Tie Line by a small margin, but
4 the Emergency Tie Line would still provide inadequate emergency backup supply
5 and would still take at least 4 hours to engage. Such an upgrade would not
6 address the basic reliability problem of not being able to withstand the loss of a
7 single element (See response to 2.0(ii)(a));

- 8 • The minimum 4-hour long procedure for engaging the Emergency Tie Line in the
9 event of a forced outage, along with the similar process for switching back to the
10 primary supply cannot be condensed or shortened. As discussed above in 3(a)
11 above, this amount of time is needed in order for CNP to carry out its initial
12 response activities (or await the completion of HONI's initial response for an
13 outage on HONI's system), as well as for necessary communications and
14 coordination, for USNG to perform the necessary operations to prepare its system
15 to supply Fort Erie load, and for CNP to complete its 31-step switching
16 procedure. These processes are needed to ensure the safe and effective
17 connection with the USNG system, as well as to prevent adverse consequences to
18 the USNG system that would otherwise result from use of the Emergency Tie
19 Line. In any event, even if the process could be shortened, this would not address
20 the basic reliability problem of not being able to withstand the loss of a single
21 element (See response to 2.0(ii)(c); and

- 22 • CNP has in recent years carried out work for purposes of enhancing system
23 performance and minimizing risk, including the removal of trees posing risks to
24 the transmission lines, the replacement of some older insulators, as well as the
25 implementation of more systematic line inspection and vegetation management
26 programs. CNP also has a range of planned system improvements of a normal or
27 ongoing nature, such as procedural improvements and capital and maintenance
28 expenditures to enhance system robustness. While these activities may reduce
29 some risk and improve system performance, none of this work addresses the basic
30 reliability problem of not having N-1 contingency (see responses to 1.0(xi) and
31 2.0(ii)(d)).

32 As indicated, the only solution to the fundamental reliability problem of the system not being
33 able to withstand the loss of its primary supply is to equip the system with this ability to provide
34 uninterrupted supply in the event of such loss. Furthermore, the Project is the only viable means
35 of doing so. To arrive at this conclusion, CNP considered two alternative projects as well as
36 three different variations of the Project. These are discussed in Exhibit B, Tab 6, Schedule 1.

1 As explained in Section 3 of Exhibit B, Tab 6, Schedule 1, each of the two options considered
2 would have involved development of a new transmission line along existing rights-of-way in
3 order to connect the CNP system to the IESO-controlled grid at a second location. One option
4 would have been to connect at Station #11 in Niagara (the “Niagara Project Alternative”) and the
5 other option would have been to connect at Crowland TS in Port Colborne (the “Port Colborne
6 Project Alternative”). Each of these alternatives would be expected to provide the same local
7 reliability benefits as would be expected from the Project.

8 However, as neither of the alternatives would provide additional intertie capacity, they would not
9 provide any of the associated system-wide benefits that are expected from the Project (Exhibit B,
10 Tab 6, Schedule 1, p. 8). Because of this, the project alternatives were both found to have
11 negative net present values (See Exhibit B, Tab 6, Schedule 1, pp. 16-17). Moreover, as these
12 alternatives would require the construction of lengthy, new lines through a region that includes
13 highly populated areas in some places, along with numerous areas that are recognized as being
14 environmentally sensitive, the permitting and stakeholdering risks would be significant (See
15 Exhibit B, Tab 6, Schedule 1, pp. 13-16). The viability of the Niagara Project Alternative and
16 the Port Colborne Project Alternative was therefore found to be highly uncertain. By contrast, as
17 explained in Exhibit B, Tab 4, Schedule 1 at page 20, the Project maximizes the use of existing
18 infrastructure. In particular, it is not expected that the Project will require any new transmission
19 poles or towers or any additional lands. In addition to avoiding land acquisition costs through
20 the use of existing infrastructure, impacts on the community are minimized. This results in
21 advantages from a regulatory and permitting perspective for the Project.

1 CNP also considered several different variations of the Project. These variations, discussed in
2 Section 2 of Exhibit B, Tab 6, Schedule 1, involved the development of a synchronous
3 connection with USNG using phase shifters at different sizes - 60 MVA, 80 MVA and 150
4 MVA. The conclusion of this analysis demonstrated that, due to the need to overcome system
5 limitations for each alternative, the incremental cost of using a 150 MVA phase shifter is
6 minimal. As such, the use of a 150 MVA phase shifter was found to be, by far, the most prudent
7 approach to developing a synchronous connection with New York. Generally, to make full use
8 of the smaller sized phase shifters, most of the system upgrades needed for the Project would still
9 be required. Therefore, for a very small incremental cost associated with the higher capacity
10 phase shifter, significant incremental benefits would be realized (See Exhibit B, Tab 6, Schedule
11 1, pp. 2-7). The Project, therefore, was found to be the only viable option.

12 **5. The Project Offers Significant System-Wide Benefits to Ontario**

13 CNP has demonstrated three broad classes of benefits that will be derived from the Project: (1)
14 local reliability benefits that have been quantified (see section 4, above), (2) intertie capacity
15 benefits to Ontario that have been quantified, and (3) qualitative local and system-wide benefits.
16 It should be noted that, in all aspects of the analysis, CNP has taken a highly conservative
17 approach to quantifying the reliability and intertie capacity benefits anticipated from the Project.
18 With respect to intertie capacity benefits, CNP identified two types of benefits that were able to
19 be quantified: (a) reduced capacity requirements for Ontario, and (b) insurance against

1 generation maintenance outages. These are discussed in Exhibit B, Tab 4, Schedule 1 starting at
2 p. 10.

3 To quantify the value of the Project in reducing capacity requirements for Ontario, CNP
4 considered the cost of building equivalent new generating capacity. To support this
5 methodology, CNP used the Board's *Guidelines for Electricity Distributor Conservation and*
6 *Demand Management*, which provide a forecast of avoided costs for generation capacity to the
7 year 2025. Based on the Guidelines, the net present value of the avoided generation cost for 150
8 MW of generation capacity over the life of the Project was determined to be approximately \$365
9 million. Consistent with CNP's highly conservative approach to quantifying the benefits of the
10 Project, this amount was reduced by a factor of 90% to arrive at an estimate of \$36.5 million for
11 the net present value of the avoided generation cost provided by the Project (See Exhibit B, Tab
12 4, Schedule 1 at pp. 12-13). An additional \$3.4 million in benefits was identified in respect of
13 the fact that the Project would help relieve constraints during shoulder seasons when generation
14 may not be available due to maintenance activities (See Exhibit B, Tab 4, Schedule 1 at p. 14).
15 Together, CNP has therefore quantified \$39.9 million in benefits associated with the increased
16 intertie capacity provided by the Project.

17 As noted in its correspondence of December 3, 2009, which is provided in Appendix "D" of
18 CNP's responses to the Supplemental Interrogatories, the OPA has endorsed CNP's approach to
19 quantifying the present value of avoided generation costs as being reasonable, with one
20 adjustment. In particular, the OPA stated that "the use of avoided costs for demand response for
21 this case is not entirely accurate because the value of demand response takes into account the

1 value of reduced reserve margin requirements and losses. The value of demand reduction is
2 expected to be about 20% higher than the value of additional supply." Accordingly, CNP
3 recalculated the avoided generation capacity benefit associated with the Project so as to take into
4 account this variable. This recalculation determined the value of the avoided generation capacity
5 benefit to be nearly \$30.5 million (See response to Board Staff SI-7).

6 According to its pre-filed evidence at Figure 5.2 of Exhibit B, Tab 5, Schedule 1, CNP's
7 calculation of the Project's net present value ("NPV") is \$10.4 million, being net of costs and the
8 present value of both local benefits and Ontario system-wide benefits. When factoring into the
9 NPV calculation the above-noted recalculation of intertie capacity benefits, the NPV remains
10 positive at \$4.27 million (Supplemental Interrogatory Response SI-7). Furthermore, this NPV
11 calculation does not include the significant qualitative benefits described below. Based on the
12 foregoing, the Project is in the public interest and satisfies the requirements of Section 96(2) of
13 the OEB Act.

14 (a) **Qualitative Local and System-Wide Benefits**

15 CNP has identified numerous qualitative benefits that can be expected from the Project. These
16 are described in Section 4 of Exhibit B, Tab 4, Schedule 1. As indicated in 5.3.2 of the Board's
17 Filing Requirements, qualitative benefits are an important consideration in evaluating the Project
18 and alternatives to the Project.

1 These qualitative benefits include significant benefits to the Fort Erie Public Bridge Authority
2 which operates the Peace Bridge connecting Fort Erie, Ontario with Buffalo, New York (Exhibit
3 B, Tab 4, Schedule 1, p. 15).

4 Other qualitative benefits, discussed in Exhibit B, Tab 4, Schedule 1 at pp. 17-21, include the
5 following:

- 6 • Short-term Supply Shortage — as a result of the increased intertie capacity
7 provided by the Project, the Project will offer some protection against short-term
8 supply shortages which can result from unexpected reductions in Ontario-based
9 supply due to growing dependence on intermittent sources;
- 10 • Surplus Baseload — as a result of the increased intertie capacity provided by the
11 Project, during periods of low Ontario demand, the Project would provide the
12 IESO with greater flexibility by allowing for greater exports of surplus baseload
13 generation to New York;
- 14 • Increased Opportunities for Trade — as a result of the increased intertie capacity
15 provided by the Project, in normal operating circumstances the intertie would
16 provide benefits associated with the possibility of increased trade with New York;
- 17 • Use of Existing Infrastructure — the Project offers the practical, economically
18 efficient and social benefit of maximizing the use of existing infrastructure and
19 not requiring the use of additional lands; and
- 20 • Fewer Regulatory Risks — related to the above-noted benefit regarding the use of
21 existing infrastructure and the need for no additional lands, the Project presents
22 few regulatory risks as compared to the alternatives considered and the Project
23 offers significant benefits without adversely affecting people, communities or the
24 natural environment.

25 As indicated in the response to Board Staff interrogatory 1.0(v), the IESO confirms and
26 emphasizes several of the above-noted benefits, particularly those related to the increased intertie
27 capacity that would result from the Project. Specifically, the IESO confirmed and emphasizes

1 the potential for the Project to enhance the overall Ontario import/export capability and,
2 therefore, to provide:

- 3 • increased market activity and efficiency,
- 4 • flexibility to address situations of surplus baseload and/or renewable generation,
5 and
- 6 • flexibility to import during periods of supply shortages.

7 Moreover, in the IESO's response to Supplemental Interrogatory SI-13, it is stated that "in the
8 IESO's view, should CNP choose to meet the N-1 planning criteria, it will enable itself to
9 maintain a higher degree of load security, especially given the noted diversity and economic
10 significance of its customer base."

11 **6. Net Present Value and Cost Recovery**

12 The Project carries an estimated cost of \$30.9 million (See Figure 5.1 of Exhibit B, Tab 5,
13 Schedule 1). As indicated in CNP's response to Board Staff interrogatory 3.0(i), when an
14 allowance for funds used during construction (AFUDC) is included, the cost estimate rises to
15 \$33.2 million. As indicated in Exhibit B, Tab 5, Schedule 1, the Project has a positive net
16 present value of over \$10 million. This calculation takes into account the project cost including
17 AFUDC. When also factoring into the calculation the adjustment identified in the December 3,
18 2009 correspondence from the OPA, the Project is found to have a positive Net Present Value of
19 \$4.27 million (Supplemental Interrogatory Response SI-7), as well as the many important
20 qualitative benefits described above.

1 CNP proposes that the Project costs, which include the capital contribution that CNP will have to
2 make to USNG to cover the costs of work to be carried out on the USNG system in support of
3 the Project, be added to CNP's rate base upon the Project coming into service. These costs
4 would then be recovered through the Uniform Transmission Rates. This is appropriate for the
5 following reasons:

- 6 • the Project is required in accordance with good utility practice which, as
7 indicated, in the present circumstances requires CNP to provide a reliability
8 solution;
- 9 • the Project is part of good system planning and provides significant local benefits;
- 10 • the Project will, as discussed, provide a wide range of significant, system-wide
11 benefits to Ontario, such benefits having been confirmed and emphasized by the
12 IESO; and
- 13 • the Project will provide the level of reliability that is needed to support economic
14 growth in the Niagara and Fort Erie region, as well as to support the potential
15 future connection of new generation, including renewable energy generation
16 facilities, to the CNP transmission system and/or the distribution system that it
17 serves, all in support of provincial government policy objectives.

18 As described in Exhibit B, Tab 5, Schedule 1, it is expected that rates would increase by an
19 average of 1.2 cents per kilowatt, per month, over the life of the Project. On this basis, the
20 expected impact of the Project on a typical residential customer would be 2.7 cents per month or
21 an increase of 0.024%.

1 **7. Conclusions**

2 For all of the foregoing reasons, we hereby submit that leave should be granted in accordance
3 with CNP's Application, pursuant to Section 92 of the *Ontario Energy Board Act*, for an order or
4 orders granting:

5 (a) leave to reinforce 2.0 km of line (being CNP's lines A36 and A37) to
6 accommodate the maximum capability of an upgraded interconnection between
7 CNP's transmission system in Fort Erie, Ontario and US National Grid's
8 ("USNG") transmission system in Buffalo, New York;

9 (b) leave to construct and reinforce 0.5 km of Conductor from the Bertie Hill Tower
10 to Queen Street Tower in Fort Erie with 795 MCM conductor to provide capacity
11 of at least 150 MW; and

12 (c) leave to construct and reinforce 0.66 km of Conductor from the Queen Street
13 Tower in Fort Erie, Ontario, across the Niagara River, to the High Tower forming
14 part of the USNG transmission system in Buffalo, New York.

15 And including the following, which are fundamental and integral to the completion of the
16 forgoing:

17 (a) installation of an additional 115 kV breaker adjacent to the Murray taps on A36N
18 and A37N;

- 1 (b) installation of two additional breakers at Station #17 in Stevensville for enhanced
2 sectionalizing and zone control;
- 3 (c) installation of a 150 MVA phase shifting transformer and voltage regulator at
4 Station #18 in Fort Erie;
- 5 (d) construction of a 115 kV three-breaker ring station located at switch SW 998 in
6 Buffalo, New York, that will tie L46, L47 and USNG's Canada Bus; and
- 7 (e) removal and replacement of approximately 10 km of conductor from the Huntley
8 Station to a new 115 kV Paradise Station being planned by USNG in Buffalo,
9 with a new 115 kV three-phase transmission circuit.

10 All of which is respectfully submitted by:

11 _____
12
13 Charles Keizer, Counsel for the Applicant

14 _____
15
16 Jonathan Myers, Counsel for the Applicant