

# Composite Conductor Field Trial Summary Report:

## ORNL ACCR 477 Kcmil

*Installation Date* July 25, 2002  
*Field trial Location* Oak Ridge, Tennessee, USA

### Line Characteristics

*Organization* Oak Ridge National Laboratory  
*Point of Contact* John Stovall, ORNL  
*Installation Date:* July 25, 2002  
*Conductor Installed* ACCR 477  
*Length of line:* 1,200 feet (365.7 meters)- 4 spans  
*Conductor diameter* 0.858 inch, (21.8 mm)  
*Voltage* 400 VDC  
*Ruling span length* 600 feet, (183 meters)  
*Structure Type* Steel Poles  
*Instrumentation:*

- (1) Load cell
- (2) Current, voltage
- (3) Weather station
- (4) Sag
- (5) Thermocouples in conductor and accessories

### Hardware

*Suspension Hardware* Preformed Line Product, THERMOLIGN<sup>R</sup> Suspensions TLS-0101-SE  
*Termination hardware* PLP THERMOLIGN<sup>R</sup> Dead End TLDE-0104  
Alcoa Compression dead end B9085-A  
PLP THERMOLIGN<sup>R</sup> Splice TLSP-0104  
Alcoa compression splice B9095-A  
Alcoa terminal connector B9102-A  
*Dampers* Alcoa Stockbridge dampers 1704-7  
*Insulator type* Polymer

### Results and

### Measurements

*Full range of temperature tests from 30°F – 412°F (0°C – 240°C) with currents ranging from 0 to 1,400 amps*

- Conductor temperature (surface and core)
- Sag temperature from 0°C – 240°C
- Accessory temperature profile during thermal cycling
- Conductor and accessory strength after thermal cycling
- Measured vs predicted thermal rating

### Acknowledgement:

This material is based upon work supported by the U.S. Department of Energy under Award No. DE-FC02-02CH11111. Any opinions, findings or recommendations expressed in this material are those of the authors and do not necessarily reflect the views of the U.S. Department of Energy.

3M Copyright, 2004

# Table of Contents

|   |    |
|---|----|
| Acknowledgement:  | 1  |
| Abstract:   | 3  |
| 1- Background   | 4  |
| 2- Installation and Conductor Stringing                                 | 6  |
| 2-1 Overview  | 6  |
| 2-2 Installation details:   | 6  |
| 2- 4 Conductor and Accessories Temperature Measurements:                | 10 |
| 2-5 Controls  | 10 |
| 2-6 Accessories:  | 11 |
| 3- Thermal Cycles and High Temperature Exposure:                        | 12 |
| 5- Accessories Response at High Temperature:                            | 18 |
| 5-1 PLP Accessories:  | 19 |
| 5-2 AFL Telecommunications (Formerly Alcoa) Accessories:                | 22 |
| 8- Post ORNL Conductor and Accessories Evaluation                       | 25 |
| 8-1 Conductor tensile tests:  | 25 |
| 8-2 Conductor Stress-strain:  | 26 |
| 8-3 Conductor resistance test:  | 28 |
| 8-4 Connector tensile tests:  | 29 |
| 8-4-2 Alcoa (AFL Telecommunications) Connector Microscopic Examination: | 29 |
| 8-5 PLP Accessories:  | 30 |
| 9- Summary  | 31 |
| 10- Appendix  | 32 |
| 10-1 Conductor Specs  | 32 |
| 10-2 Conductor Resistance Data:   | 32 |
| 10-4 Emissivity Measurements:   | 33 |

## ***Abstract:***

Under DOE funding Agreement No. DE-FC02-02CH11111, ORNL jointly with The Tennessee Valley Group, TVA, successfully installed the ACCR 477 conductor on a high temperature test line at ORNL in July 2002. The test line consists of two 600 foot spans; two on the road side and two on the tree side between a steel suspension pole and two guyed, dual steel pole dead-end poles. The test conductor forms a loop connected to a DC power supply located at one end of the line, therefore a total of 2400 feet of conductor was tested.

The conductor was installed with commercial hardware developed for ACCR conductors. The line was fully instrumented with (1) thermocouples in the conductor and accessories, (2) a CAT-1 system to measure tension and (3) a full weather station.

Oak Ridge National Laboratory subjected the line to severe thermal cycling and extended high temperature load using 400 V DC and about 1200 amps depending on weather conditions. The conductor was thermally cycled from May 2003 to October 2003 between ambient and over 200<sup>0</sup> C for 200 hours. The conductor experienced over 100 cycles to elevated temperature. During the course of the cycling, conductor tension and temperature were monitored. The measured conductor tension - temperature response agreed with predictive models.

Predicted conductor current, using IEEE thermal rating ampacity method, agrees well with measured values. Conductor's emissivity of 0.347 was measured using IR method and used in the IEEE conductor- rating model.

Conductor and accessories were taken down from the line after thermal cycling and tested. The results showed that mechanical and electrical properties of the conductor and accessories were unchanged.

## **1- Background**


Reliable high temperature performance is one of the key requirements for implementing new high temperature-low sag conductors. It is imperative to demonstrate in the field that the conductor and accessories can operate as predicted at high-temperature, under thermal cycling and without degradation. It is also important to demonstrate that the sag-temperature-current characteristics can be predicted after repeated thermal cycles. High-temperature exposure and thermal cycling of the conductor and accessories can be achieved on a test line that operates at low voltage with a controlled current. Such a test line is able to simulate lifetime field conditions in three months by applying dozens of emergency cycles where the conductor temperature exceeds the normal operating temperature of  $210^{\circ}\text{C}$ , ( $410^{\circ}\text{F}$ ) and where the line is exposed to a range of wind speeds, directions, and tension.

ORNL built a fully instrumented low-voltage test line to evaluate the high-temperature operation of ACCR conductors. The instrumentation includes mechanical tension, full weather station with anemometer, voltage, current, laser sensor to measure sag, and temperature thermocouples in multiple locations in the conductor and in all accessories, Figure 1.

This report summarizes the ACCR 477 conductor installation, testing and analysis at ORNL as well as post thermal cycling evaluation.



Aerial view of the line



Conductor cross section



Towers

Figure 1- View of the ORNL test line and conductor cross-section

## ***2- Installation and Conductor Stringing***

### ***2-1 Overview***

A four span test line was constructed on the grounds of the Oak Ridge National Laboratory in Oak Ridge, Tennessee, as a part of a Department of Energy program. Oak Ridge National Laboratory subcontracted the line engineering and construction to the Tennessee Valley Authority, (TVA). The test line (Figure 2) consists of 2, 600 feet (183 meters) spans between a steel suspension pole and two guyed dual steel dead end poles. The test conductor forms a loop over two spans connected to a DC power supply located at one end of the line. Thermocouples were installed along the test conductor and on the dead ends, suspensions and splices to measure the temperature of these components during and after periods of high temperature operation.




Figure 2- Line layout and CAT-1 system

### ***2-2 Installation details:***

The installation of the 477 ACCR follows the IEEE 524 installation guideline for overhead transmission conductors. The only conductor stringing method recommended is the tension method. It is important that bending of the composite conductor during installation be carefully planned to avoid damaging the composite core. The combination

of bending and tension could damage the conductor if it exceeds the allowable core strength. Therefore stringing blocks and bull wheels were selected to keep the stringing loads below the conductor core strength. The crew used 28" diameter stringing blocks and 36" diameter bull wheels diameter to meet such criteria; Table 2. Lined blocks are recommended for use with ACCR. Cable spools around which the conductor is wrapped must have 40" diameter to avoid core damage. Other installation procedure and hardware used were very similar to that used for ACSR. PLP DG- Grips were used to pull the conductor to sag and to install full tension splices.

Sagging procedures of ACCR conductor are very similar to that of ACSR. During installations of this type of conductor, a dynamometer was used to verify the final sag tensions of the conductor. By using a chain hoist and a dynamometer between a temporary conductor grip and the tower structure, the final sag tension was set. Sufficient length of conductor was provided to install the permanent Alcoa dead end. The conductor grip was placed on the conductor at least 12 to 15 feet from the connection point to the insulator string. After the final sag tension was set, the dead ends were installed onto the ACCR. With the initial placement of the conductor grip at 12 to 15 feet, this allowed enough slack in the conductor to maneuver it and apply the dead end assembly.

Table 1- Installation Equipment and Procedure

| Installation Equipment | ACSR | ACCR                   |
|------------------------|------|------------------------|
| Stringing blocks       | Yes  | Yes ( 28")             |
| Bull wheels            | Yes  | Yes ( 54")             |
| Drum Puller            | Yes  | Yes                    |
| Socket splice          | Yes  | Yes                    |
| Conductor grip         | Any  | Distribution grips, DG |
| Cable spool            | Yes  | Yes (48" drums)        |
| Cable cutter           | Yes  | Yes                    |
| Reel stands            | Yes  | Yes                    |
| Grounding clamps       | Yes  | Yes                    |
| Running ground         | Yes  | Yes                    |

| Installation Procedure | ACSR           | ACCR                          |
|------------------------|----------------|-------------------------------|
| Cable stringing        | Tension/ slack | Tension                       |
| Sag tensioning         | Any            | Line of sight-<br>Dynamometer |
| Dead ending            | Any            | DG grips with chain hoist     |
| Clipping               | Any            | Any                           |

The following images and those under the next section are typical examples of the installation details



Figure 3- Conductor stringing



Figure 4- Sagging with chain hoist and dynamometer



### 2-3- CAT-1 Instrumentation:

A CAT-1 system with weather station was installed on one of the dead end structures to monitor the conductor tension and weather conditions (temperature, wind speed, and direction) at one-minute intervals. Conductor tension was measured by the CAT-1 load cells, see Figure 5. The CAT-1 system includes an anemometer to measure wind speed and direction and a net radiation sensor to measure ambient temperature and solar radiation. Data acquisition was done at 1minute rate for all channels.

The CAT-1 main unit is in a NEMA-enclosed, solar powered, data acquisition and processing unit. Net Radiation Temperature, (NRT), was measured by the net radiation sensor, (NRS).



5-a Load cell to monitor tension



5-c Net radiation sensor, Measures no - load conductor temperature and solar radiation



5-b CAT1 system

Figure 5 CAT 1 System hardware

## *2- 4 Conductor and Accessories Temperature Measurements:*

Temperature was measured using thermocouples mounted at various locations along the span, including ones directly touching the composite core and the conductor surface.

Additional thermocouples were mounted on all accessories.



Figure 6- Thermocouple enclosure

A separate data acquisition system was used to collect the information from the thermocouples. To accommodate the multiplicity of points along the conductor and withstand the accumulated voltage drop, many fiber-connected, isolated measurement nodes were used. A thermocouple measurement node is fabricated using a multiplexer (ICPCON I-7018) and a RS-485-to-fiber modem (B&B FOSTCDR). Up to eight thermocouples are monitored per node. The node requires 120 VAC power and is data connected through a duplex fiber optic network. The multiplexer, fiber modem, and a power supply are housed in a Preformed Line Product COYOTE<sup>R</sup> RUN T enclosure.

## *2-5 Controls*

The line was operated under constant either current and / or constant conductor temperature with thermal cycles lasting from less than one hour to several days. The circuitry needed for controlling the 2MW power supply via software and analog to digital modules was built and installed. Also, a lower panel was added to permit remote control

(in the instrumentation trailer) of the power supply's reset, contactor, and DC circuit. Previously, these were manually controlled at the power supply trailer only. The power supply has a dual rating of 400 Vdc and 5000 amps or 600 Vdc and 3750 amps. The input voltage to the power supply is 4160 V, 3-phase. A dry-type ABB transformer is used to step down the voltage from a 13.8 KV distribution line.

#### *2-6 Accessories:*

Two types of full tension connectors were installed; a compression type made by Alcoa and a formed wire type made by Preformed Line Products, see Figures 7 to 9. The following is a list of all the accessories:

- Two ALCOA compression dead ends; part # B9085-A; those dead ends consist of both direct core gripping parts and conductor gripping sleeve.
- One ALCOA full tension splice part# B9095-A; it has the same design as the dead end for direct core gripping..
- Two THERMOLIGN<sup>R</sup> PLP Suspensions, part # TLS-0101-SE
- Two PLP THERMOLIGN<sup>R</sup> Dead Ends, part# TLDE-0104.
- One PLP THERMOLIGN<sup>R</sup> Splice, Part #TLSP-0104.
- Six Alcoa all aluminum terminal connectors; Part# B9102-A
- Four Alcoa Stockbridge dampers; part # 1704-7.



Figure 7- THERMOLIGN<sup>R</sup> Suspension



Figure 8- Installation of Alcoa compression splice.



Figure 9- Installed PLP THERMOLIGN<sup>R</sup> Splice

### 3- Thermal Cycles and High Temperature Exposure:

The 477 conductor was thermally cycled from May 2003 to October 2003 between ambient and over 200<sup>0</sup> C for more than 200 hours under a wide range of weather and load conditions, Table 2. Figure 10 shows the composite conductor core temperature during a typical thermal cycle in temperature control. The temperature is maintained at 210-240 C by controlling the current from 1000 amps to 1200 amps while the wind fluctuates between 0 fpm and 15 fpm.




Figure 10- shows an example of thermal cycling in one day at ORNL test line

Table 2- Summary of Thermal Cycling of ACCR 477 at High Temperature

| Date       | #Cycles | Total  | Hours          | Total Run | Nature of cycle        | Maximum      |
|------------|---------|--------|----------------|-----------|------------------------|--------------|
|            | Per day | Cycles | Per day        | Hours     |                        | Current, amp |
| 5/1/2003   | 1       | 1      | 10             | 10        | Current controlled     | 1295         |
| 5/2/2003   | 1       | 2      | 7              | 17        | Current controlled     | 992          |
| 6/2/2003   | 1       | 3      | 12.5           | 29.5      | Current controlled     | 1177         |
| 6/4/2003   | 0       | 3      | 11             | 40.5      | Current controlled     | 1060         |
| 6/5/2003   | 0       | 3      | 3              | 43.5      | Current controlled     | 1053         |
| 6/9/2003   | 0       | 3      | 12             | 55.5      | Current controlled     | 1057         |
| 6/10/2003  | 0       | 3      | 11.5           | 67        | Current controlled     | 1031         |
| 8/27/2003  | 1       | 4      | 2.5            | 69.5      | Current controlled     | 975          |
| 9/8/2003   | 5       | 9      | 5              | 74.5      | Current controlled     | 1033         |
| 9/11/2003  | 5       | 14     | 10             | 79.5      | Current controlled     | 1057         |
| 9/16/2003  | 4       | 18     | 14             | 83.5      | Current controlled     | 1052         |
| 9/17/2003  | 7       | 25     | 21             | 90.5      | Current controlled     | 1102         |
| 9/18/2003  | 5       | 30     | 26             | 95.5      | Current controlled     | 1153         |
| 9/19/2003  | 8       | 38     | 34             | 103.5     | Current controlled     | 1126         |
| 9/23/2003  | 8       | 46     | 42             | 111.5     | Current controlled     | 1152         |
| 9/24/2003  | 7       | 53     | 49             | 118.5     | Current controlled     | 1153         |
| 9/25/2003  | 8       | 61     | 57             | 126.5     | Current controlled     | 1201         |
| 9/26/2003  | 8       | 69     | 65             | 134.5     | Current controlled     | 1191         |
| 9/29/2003  | 8       | 77     | 73             | 142.5     | Current controlled     | 1292         |
| 9/30/2003  | 7       | 84     | 80             | 149.5     | Current controlled     | 1290         |
| 10/1/2003  | 4       | 88     | 84             | 153.5     | Current controlled     | 1275         |
| 10/2/2003  | 8       | 96     | 92             | 161.5     | Current controlled     | 1291         |
| 10/3/2003  | 8       | 104    | 100            | 169.5     | Current controlled     | 1401         |
| 10/7/2003  | 1       | 105    | (7hours/100 C) | 176.5     | Current controlled     | 861          |
| 10/13/2003 | 1       | 106    | 10             | 10        | Temperature controlled | 1172         |
| 10/14/2003 | 1       | 107    | 5              | 15        | Temperature controlled | 1370         |
| 10/15/2003 | 1       | 108    | 10             | 25        | Temperature controlled | 1236         |
| 10/16/2003 | 1       | 109    | 10             | 35        | Temperature controlled | 1256         |
| 10/17/2003 | 1       | 110    | 10             | 45        | Temperature controlled | 1114         |
| 10/18/2003 | 1       | 111    | 10             | 55        | Temperature controlled | 1225         |
| 10/21/2003 | 1       | 112    | 8              | 63        | Temperature controlled | 1311         |
| 10/22/2003 | 1       | 113    | 9              | 72        | Temperature controlled | 1288         |
| 10/23/2003 | 1       | 114    | 6              | 78        | Temperature controlled | 1201         |
| 10/24/2003 | 1       | 115    | 10             | 88        | Temperature controlled | 1213         |
| 10/27/2003 | 1       | 116    | 6              | 94        | Temperature controlled | 1225         |
| 10/28/2003 | 1       | 117    | 6              | 100       | Temperature controlled | 1214         |

Thermocouples were installed along the length of the conductor in two different spans and at different radial positions going from the conductor surface to contacting the composite core, Figure 11. The thermocouples indicated that there were significant temperature differences along the axial location and moderate gradients along the radial position.




Figure 11- Thermocouples were positioned along the length and in different radial positions.

The radial gradient, when the conductor was above 200°C, was measured to fluctuate between 2°C and 15°C. In average, the radial gradient was about 8°C when the conductor was at 200°C, Figure 12a. Variation in wind speed and direction affected the magnitude of the radial gradient with greater wind speeds causing a larger gradient.




Figure 12- a- Temperature difference between conductor surface and core at mid span

Temperature fluctuation along the length of the conductor varied between 5°C to 50°C depending on wind conditions. Span 2 was more sheltered by trees than span 1 and consistently experienced higher temperatures. The difference between span 1 and 2 was in average about 20°C when the conductor was above 200°C, Figure 12b. In some cycles the difference between span 2 and 1 was as high as 50°C for a short period of time. As a result the maximum temperature in span 2 reached as high as 270°C when the average temperature was at about 230°C.




Figure 12- b An example of temperature difference along the conductor length.

#### 4- Measured and Predicted Line Tension and Sag:

Sag was computed using the Strain Summation Method (which accounts for the full loading history) and the Graphic Method (Alcoa SAG-10). The main events, which cause permanent- elongation, were included (creep, low temperatures).

The calculated and measured tension and sag values are plotted in Figures 13 to 16 as a function of both conductor core and surface temperatures. The knee-point measured at

about 80° C matches the prediction. It confirms the validity of the stress-strain, creep properties and thermo-elastic behavior of the conductor.

Figure 13 shows good agreement between measured and predicted tension in the range of 0° C and 250° C. The measured line tension lies in between values predicted using either the strain summation method or the graphic one. The predictions assumed a compressive stress of -1.45 Ksi in the aluminum after the knee point. The “October 28<sup>th</sup>” cycle was the last of over 100 cycles after the conductor experienced over 200 hours of high temperature exposure. It shows that the tension response remained predictable and stable after long thermal exposure and numerous cycles.

There is a small hysteresis observed between the heating and cooling cycles mostly due to variation in conductor temperature along the length of the line, and wire settling when passing through the knee point.




Figure 13- Good agreement between calculated and measured tension for the last cycle on October 28,2003. The Strain Summation method was used with a 1.45 ksi compressive stress.






Figure 14- Initial and final tensions calculated using the SAG- 10<sup>TM</sup> with 10 MPa (1.45 Ksi) compressive stress agree well with CAT-1 measured values.

Figure 13 shows the last high temperature cycle and Figure 14 shows both the first and last cycle. The measured conductor response was accurately predicted with the models using a –1.45 Ksi stress after the knee point.




Figure 15- Measured vs. calculated tension, using the Strain Summation method, as a function of conductor temperature.

Figure 16 shows the tree-side line sag vs. conductor core temperature. The sag was directly measured at the mid- span with a laser monitor. The sag measurements agree with those calculated from tension within 0.2 feet.




Figure 16- Measured Sags Compared with Those Calculated from Tension.

Summary:

Predicted sag agrees well with measured values in the range of 0<sup>0</sup> C to 250<sup>0</sup> C. The sag remained predictable after thermal cycling and long exposure to high temperature. There has been virtually no creep.

### ***5- Accessories Response at High Temperature:***

The accessories performed well during conductor thermal cycling and high temperature exposure; overall their maximum temperature was less than 120<sup>0</sup> C.

### 5-1 PLP Accessories:

Figure 17 shows that the inner reinforcing rods in the Thermolign<sup>R</sup> Suspension had the highest temperature rise while the external housing had the lowest temperature rise, the neoprene insert did not see temperature higher than 100<sup>0</sup> C.




Figure 17- a shows the PLP THERMOLIGN<sup>R</sup> suspension running at temperature < 100<sup>0</sup> C when conductor was thermal cycled to above 200<sup>0</sup> C




Figure 17-b PLP THERMOLIGN<sup>R</sup> Suspension System thermocouples location (3 locations, TC1, 2 and 3) during current cycling.

The PLP THERMOLIGN<sup>R</sup> dead end temperature profile along its length (6 locations-marked in red circles in Figure 18 shows a much lower temperature than that of the conductor, Figure 19. The inner rods maximum temperature was about 90<sup>0</sup> C while the outer rods never exceeded 75<sup>0</sup> C, Figure 20.




Figure 18-a- Location of thermocouples in red, TC's, on PLP THERMOLIGN<sup>R</sup> dead end

PLP Thermolign<sup>R</sup> Dead End ran very cool during high temperature exposure of conductor




Figure 18-b An example of PLP THERMOLIGN<sup>R</sup> Dead End temperature profile thermal cycling of conductor to 200<sup>0</sup> C.

The PLP THERMOLIGN<sup>R</sup> Splice temperature was monitored at 4 locations on both the inner stiffening rod and the outer one (Figure 19). The inner rod temperatures (PS1, 2) were slightly higher than those measured on the outer one- rod (PS3) and the inner center of the splice (PS4) where conductor segments come together (because of its proximity to the conductor); both splice rods ran cool (Figure 19).




Figure 19- a- Thermocouple locations for temperature measurement of splice inner and outer rods.

PLP THERMOLIGN<sup>R</sup> splice shows temperature gradient between inner and outer rods as shown in figure 19-b; two thermocouples were mounted on each rod.. Both rods ran much cooler than conductor, well below 100<sup>0</sup> C.

PLP THERMOLIGN<sup>R</sup> splice temperature profile during one cycle exposure of conductor




Figure 19-b An example of a single thermal cycle showing the PLP THERMOLIGN<sup>R</sup> splice running very cool, temperature < 100<sup>0</sup> C when conductor was around 200<sup>0</sup> C.

To summarize all PLP accessories (dead end, splice and suspension) behaved normally during high temperature exposure of the ACCR 477 conductor, their maximum surface temperature was at or below 100<sup>0</sup> C.

## 5-2 AFL Telecommunications (Formerly Alcoa) Accessories:

Both AFL splices, dead end and terminal connector ran well below  $100^{\circ}\text{C}$  when conductor temperature was above  $200^{\circ}\text{C}$  as recorded by numerous thermocouples (five on dead ends, two on terminal connector and five on splice). Accessories temperature near the tapered mouth close to conductor was higher than at other locations but below  $100^{\circ}\text{C}$  (see Figures 20 to 22).




Figure 20- AFL compression dead ends temperature was below  $70^{\circ}\text{C}$  when conductor temperature was greater than  $200^{\circ}\text{C}$





Figure 21 AFL Splice temperature during conductor cycling at around  $200^{\circ}\text{C}$ - Splice remained cool never exceeded  $80^{\circ}\text{C}$




Figure 22- AFL compression terminal connector temperature less than 50 C when conductor temperature was greater than 200 °C

## 7- Ampacity and Thermal Rating of Conductor

The steady state version of the IEEE STD 738-1993 “Standard for Calculating the Current Temperature Relationship of Bare Overhead Conductors” was used to predict conductor current during thermal cycling. The model balances resistive losses, solar heating, convective and radiative heat losses. The data for current, wind speed and direction was used in the model; wind speed and direction were averaged over 60 minutes interval. Conductor emissivity  $\varepsilon = 0.347$  was measured by ORNL using IR method. Both Figure 23 and table 3 show measured and predicted current. Table 4 lists values of parameters used in the model

Table 3 - Ampacity Rating Conditions and Data

| Conductor temperature, C | Ambient Temperature, C | Wind speed, f/s | Wind angle, degrees | Measured Current, Amp | Computed current, amp |
|--------------------------|------------------------|-----------------|---------------------|-----------------------|-----------------------|
| 196                      | 14                     | 5               | 3                   | 1004                  | 1011                  |
| 145                      | 16                     | 7               | 9                   | 981                   | 1011                  |
| 119                      | 18                     | 8               | 9                   | 994                   | 978                   |
| 162                      | 20                     | 9               | 9                   | 1098                  | 1120                  |
| 223                      | 25                     | 4               | 19                  | 1135                  | 1160                  |
| 162                      | 26                     | 4               | 20                  | 986                   | 1015                  |
| 203                      | 17                     | 4               | 13                  | 1050                  | 1065                  |
| 164                      | 20                     | 6               | 15                  | 1050                  | 1078                  |
| 169                      | 27                     | 5               | 22                  | 1047                  | 1076                  |
| 233                      | 15                     | 0               | 27                  | 1049                  | 1063                  |
| 174                      | 26                     | 4               | 24                  | 1050                  | 1075                  |
| 222                      | 19                     | 0               | 23                  | 1025                  | 1029                  |
| 186                      | 25                     | 3               | 18                  | 1025                  | 1008                  |
| 235                      | 19                     | 0               | 9                   | 1024                  | 1057                  |
| 157                      | 30                     | 8               | 10                  | 999                   | 1032                  |

Conductor temperature was used as input to the model along with other variables of Table 4. The agreement between model and measurements is good.




Figure 23- Predicted vs. Measured Steady State conductor current / rating

|                          |                    |        |
|--------------------------|--------------------|--------|
| Emissivity               |                    | 0.35   |
| Solar Absorbtion         |                    | 0.50   |
| Conductor Elevation      | ft above sea level | 800.00 |
| latitude                 | degrees            | 30.00  |
| Zc                       |                    | 180.00 |
| Sun Altitude             | degrees            | 54.00  |
| Theta                    | radians            | 1.57   |
| density air              | lb/ft^3            | 0.0765 |
| Absolute Viscosity Air   | lb/h-ft            | 0.0433 |
| Thermal Conductivity Air | W/ft.degreeC       | 0.01   |

In summary the IEEE model predicted conductor current agrees reasonably well with that measured during thermal cycling at ORNL test line. The ACCR 477 conductor was rated at 1169 amps for continuous operation at 210<sup>0</sup> C and 1266 amps for emergency at 240<sup>0</sup> C using the model and 40<sup>0</sup> C ambient temperature, 2 f/s wind speed, emissivity & solar absorption of 0.5 at Sea Level. Thermal cycling history



reported in Table 2 shows that the conductor was exposed to a maximum current in excess of 1350 amps without any degradation or damage, see Section 8 for details.

## **8- Post ORNL Conductor and Accessories Evaluation**

The following tests & measurements were carried out on the conductor and accessories after thermal cycling at ORNL:

### **8-1 Conductor tensile tests:**

Three samples from the “free-span” conductor were terminated using cast-resin terminations. Clamps were used to preserve the as-received position of the conductor layers until the resin cured. The sample preparation method ensures that the laboratory tensile test loads each conductor strand in the same manner as a field overloads, and thereby measures the in-service conductor strength. Free conductor between the end fittings is 20 feet (6 meters).

The 1999 Aluminum Association guide for conductor stress-strain testing was followed with the exception of special values for the elastic properties of the metal matrix composite (MMC) core were used instead of values for steel core used in ACSR conductors. The core strand from another sample is used to measure core stress-strain, and determine the elastic properties of the composite conductor.

The results show that the conductor maintained its strength after thermal cycling at above 200C. The average of five measurements is 109 % RBS as shown in Table 3.

Table 5- Conductor test data

| Sample  | Breaking<br>load,<br>Lbs | % RBS | Failure Mode                               |
|---------|--------------------------|-------|--|
| 04114T1 | 20,710                   | 106   | All strands fractured in the gage section  |
| 04114T2 | 19,860                   | 102   | All strands fractured in the resin fitting |
| 04114T3 | 20,800                   | 107   | All strands fractured at the resin fitting |

|                              |        |     |                                    |
|------------------------------|--------|-----|------------------------------------|
| Stress- Strain-<br>conductor | 20,350 | 104 | Mid span break, all strands failed |
| Stress Strain-<br>Core       | 12,910 | 111 | Mid span break, all strands failed |

## 8-2 Conductor Stress-strain:

Stress-strain results are similar to results from the same conductor prior to the field test. The principal difference is that creep during the 30% load hold phase is less on the field sample, apparently because the field loads caused the initial creep to be removed from the conductor as shown in Figures 24 to 26.




Figure 24- Plot of raw core stress-strain data recorded during conductor stress-strain test (blue),




Figure 25- Core stress-strain shows essentially no change due to field test




Figure 26- Combined stress- strain plot

### 8-3 Conductor resistance test:

Welded equalizers were installed at each end of a 19-foot long sample from the free-span section. A second set of voltage equalizers in the form of tightly wrapped solid copper strands are applied nominally 20 feet apart in the test section. The sample is placed on a flat surface, and pulled with sufficient tension to remove any residual curvature in the conductor. Tension was about 200 – 300 lb. A digital low-resistance Ohmmeter was used to make a 4-wire resistance measurement for the conductor section between the two voltage equalizers. A digital multi meter was used to verify the sample was electrically isolated (see Figure 27).



Figure 27- Resistance measuring set up and sample

Resistance of a 19 ft test section was measured. Readings were repeated later in the day as noted below. The average of all readings is 0.1834  $\Omega$ /mile at 20° C. The published value is 0.1832  $\Omega$ /mile at 20° C, very close to the measured value.

#### 8-4 Connector tensile tests:

##### 8-4-1 Alcoa compression accessories

Two dead-ends were provided with cast resin fittings at free ends. The procedure preserves the “as received” position of the conductor components, and thereby assures that the breaking strength is the same as existed when the samples were in service on the test span. Dead ends maintained their load carrying capability of 100% RBS or more (see Table 6 and Figure 28).

Table 6- Connector tensile tests

| Sample   | Breaking Load, Lbs | % RBS | Failure Mode                               |
|----------|--------------------|-------|--|
| 04114DE1 | 20,380             | 105   | All strands fractured ~ 5” inside dead end |
| 04114DE2 | 19,550             | 100   | All strands fractured ~ 5” inside dead end |




Figure 28 Connector tensile test plots

##### 8-4-2 Alcoa (AFL Telecommunications) Connector Microscopic Examination:

Connector dissection (one dead): A milling machine was used to split the aluminum sleeve and reveal the internal components. Correct installation is verified by observing proper placement of the core grip, proper conductor preparation, and proper injection of inhibitor compound prior to compression

The dissections and inspections showed good workmanship for core and aluminum insertion depth, component placement, and the crimping operation. The center cavity was full of oxide inhibitor, and the distribution pattern shows that the injection was done correctly prior to the start of crimping. One discrepancy was noted: There is no evidence that the conductor was wire-brushed prior to splice installation. AFL instructions require wire brushing of the conductor OD only in cases where the connector is installed on weathered conductor. However, most field and lab experience is that failure to wire-brush new conductor can cause premature connector failure.

#### *8-5 PLP Accessories:*

The suspension taken down from the ORNL test line after thermal cycling was disassembled and conductor inside the suspension was tested for residual strength. It failed at 19,437 Lbs (100% RBS). The conductor failed 21” from center of suspension. Conductor samples and both the THERMOLIGN™ Splice and Dead End were pulled in tension. Splice/ conductor combination failed at 19428 Lbs (100% RBS) in the conductor within the splice region. Two dead end samples with conductor were pulled to failure; they gave 19,157 Lbs (98% RBS) and 19,817 (102% RBS) Lbs respectively.

## ***9- Summary***

ACCR 477 conductor was installed successfully on the ORNL- PCAT line using commercial hardware and normal installation procedures. The conductor and accessories were thermally cycled from ambient to over 200<sup>0</sup>C for several hundred hours, using DC power supply and as high current as 1200 amps. The measured sag matched the SAG-10 prediction. Data analysis shows that the measured conductor current agrees well with the IEEE thermal rating model predicted values. After de-installation the conductor and accessories were tested for residual strength and degradation. Residual strength exceeded 100% RBS and neither conductor nor accessories showed any signs of damage. Conductor resistance after cycling is equivalent to that of conductor not exposed to thermal cycling

## 10- Appendix

### 10-1 Conductor Specs

#### Conductor Physical Properties

|                           |                 |         |
|---------------------------|-----------------|---------|
| <b>Designation</b>        |                 | 477-T16 |
| <b>Stranding</b>          |                 | 26/7    |
| <b>kcmils</b>             | kcmil           | 477     |
| <b>Diameter</b>           |                 |         |
| <b>indiv Core</b>         | in              | 0.105   |
| <b>indiv Al</b>           | in              | 0.135   |
| <b>Core</b>               | in              | 0.32    |
| <b>Total Diameter</b>     | in              | 0.86    |
| <b>Area</b>               |                 |         |
| <b>Al</b>                 | in <sup>2</sup> | 0.374   |
| <b>Total Area</b>         | in <sup>2</sup> | 0.435   |
| <b>Weight</b>             | lbs/linear ft   | 0.539   |
| <b>Breaking Strength</b>  |                 |         |
| <b>Core</b>               | lbs             | 11,632  |
| <b>Aluminum</b>           | lbs             | 7,844   |
| <b>Complete Cable</b>     | 000's lbs       | 19,476  |
| <b>Modulus</b>            |                 |         |
| <b>Core</b>               | msi             | 31.4    |
| <b>Aluminum</b>           | msi             | 8.0     |
| <b>Complete Cable</b>     | msi             | 11.2    |
| <b>Thermal Elongation</b> |                 |         |
| <b>Core</b>               |                 | 6       |
| <b>Aluminum</b>           |                 | 23      |
| <b>Complete Cable</b>     |                 | 16      |
| <b>Heat Capacity</b>      |                 |         |
| <b>Core</b>               | W-sec/ft-C      | 13      |
| <b>Aluminum</b>           | W-sec/ft-C      | 194     |

#### Conductor Electrical Properties

|                   |           |        |
|-------------------|-----------|--------|
| <b>Resistance</b> |           |        |
| <b>DC @ 20C</b>   | ohms/mile | 0.1832 |
| <b>AC @ 25C</b>   | ohms/mile | 0.1875 |
| <b>AC @ 50C</b>   | ohms/mile | 0.2061 |
| <b>AC @ 75C</b>   | ohms/mile | 0.2247 |

### 10-2 Conductor Resistance Data:



| Conductor Resistance   |                   |                |                    |
|--|-------------------|----------------|--------------------|
| NEETRAC Project No.  | 04-114            |                | = Data Input Cells |
| AVO (Biddle) DLRO, Calibration Control #   | CQ1097            |                | = Calculated Value |
| Temperature Indicator (Instrument)   | CN3022            |                |                    |
| Temperature coefficient for resistance:  | 0.0036            |                |                    |
| Resistance measurement on a 477 ACCR sample from the ORNL test line. Bolted end fitting for equalizer (see photos), pulled to ~200 lbs tension w/a come-a-long |                   |                |                    |
| These readings taken manually @ 10/25/04 @ 10:19 AM  |                   |                |                    |
| Conductor Temperature:   | 21.8 deg C        |                |                    |
| Test Section:  | 19.000 ft         |                |                    |
| Resistance Reading 1   | 665.1 uOhms       | At 21.8 deg C  |                    |
| Resistance Reading 2   | 665.1 uOhms       | At 21.8 deg C  |                    |
| Resistance Reading 3   | 664.9 uOhms       | At 21.8 deg C  |                    |
| Average of 3 Readings  | 665.03 uOhms      | At 21.8 deg C  |                    |
| Ohms/ft:   | 3.5002E-05 Ohm/ft | At 21.8 deg C  |                    |
| Ohms/ft:   | 3.4775E-05        | At 20.0 deg C  |                    |
| Ohms/mi  | 0.184809 Ohm/mi   | At 21.8 deg C  |                    |
| Ohms/mi @ 20C:   | 0.183612          | At 20.0 deg C  |                    |
| These readings taken manually @ 10/25/04 @ 1:24 pm   |                   |                |                    |
| Conductor Temperature:   | 21.3 deg C        |                |                    |
| Test Section:  | 19.000 ft         |                |                    |
| Resistance Reading 1   | 663.5 uOhms       | At 21.30 deg C |                    |
| Resistance Reading 2   | 663.5 uOhms       | At 21.30 deg C |                    |
| Resistance Reading 3   | 663.5 uOhms       | At 21.30 deg C |                    |
| Average of 3 Readings  | 663.50 uOhms      | At 21.30 deg C |                    |
| Ohms/ft:   | 3.4921E-05 Ohm/ft | At 21.30 deg C |                    |
| Ohms/ft:   | 3.4695E-05        | At 20.00 deg C |                    |
| Ohms/mi  | 0.184383 Ohm/mi   | At 21.30 deg C |                    |
| Ohms/mi @ 20C:   | 0.183188          | At 20.00 deg C |                    |
| Average  |                   |                |                    |
| Ohms/mi @ 20C:   | 0.18340           | At 20.0 deg C  |                    |
| 3M nominal   | 0.18317 Ohm/mi    | At 20.0 deg C  |                    |

#### 10-4 Emissivity Measurements:

Oak Ridge National Laboratory measured various 3M composite conductor emissivity using IR Imaging. A calibrated IR Camera and Mikron M305 Blackbody calibration source were used. Figures 29 shows the used hardware; the calibrated black body target was multiplied by various emissivity values until a good fit occurs with the conductor received signal (see Figure 30). Such fit yielded an average emissivity value of 0.345 within +- 2% (see Figure 31).




Figure 29- Calibrated IR Camera and Mikron M305 Blackbody calibration source used for measuring emissivity




Figure 30- Conductor emissivity of 0.348 was determined using a black body signal matching




Figure 31- Signal error is < 1% in the temperature range 120 to 200 C with an emissivity value of 0.346