



To: Colin McCullough
3M Company

**KINECTRICS NORTH AMERICA INC. TEST REPORT FOR 3M COMPANY
ELEVATED TEMPERATURE SUSTAINED LOAD TEST ON 795 KCMIL ACCR
COMPRESSION DEAD-ENDS**

**Kinectrics North America Report: 9513-004-RC-0004-R00
February 2003**

C.J. Pon, M.J. Kastelein, M. Colbert
Transmission and Distribution Technologies Department

A tensile load test was performed for 3M Company on their 795 kcmil ACCR conductor. The test was performed by Kinectrics North America Inc. personnel at 800 Kipling Avenue, Toronto, Ontario, M8Z 6C4, Canada.

OBJECTIVE

The objective of the test was to determine if the tensile strength of the conductor/dead-end clamp system was adversely affected after being subjected to sustained elevated temperature at a constant tensile load.

Test Conductor

3M prepared the cable sample with a pre-installed compression dead-end at one end and a spelter type fitting at the other end. The sample length was 40 feet.

Test Apparatus

The conductor sample was installed in a hydraulically-activated horizontal test machine. Several inches of fibreglass insulation was wrapped around the conductor to minimize convection cooling.

For the elevated temperature test, an electrical ac power supply was connected to each end of the cable. This supply was cycled on and off to maintain a constant temperature.

The tests were carried out in a temperature-controlled laboratory at $20^{\circ}\text{C} \pm 2^{\circ}\text{C}$.

PRIVATE INFORMATION

**Contents of this report shall not be disclosed without authority of the client.
Kinectrics North America Inc., 800 Kipling Avenue, Toronto, Ontario M8Z 6C4.**

Instrumentation and Data Acquisition

The conductor tension as measured by the load cell and the temperature as measured by thermocouples were monitored continuously using a digital data logging system. The thermocouples were located between two adjacent aluminum alloy strands on the outside layer.

The measuring instruments and equipment used in this test are listed in Appendix C.

TEST PROCEDURE

The conductor was tensioned to 4,670 lbf or 15% of the cable RTS (31,134 lbf) and heated to 240°C. This condition was maintained for 168 hours (7 days). At the end of the 168 hours, the cable was unloaded, allowed to cool naturally to room temperature and then tensioned to failure.

TEST RESULTS

The breaking load is shown in Table 1. The conductor had a clean break at about midspan. Figure 3 shows the conductor after breaking.

Table 1: Breaking Load Result

| Cable Designation | Breaking Load (lbf) | Percent of RTS |
|--------------------------|--------------------------------|-----------------------|
| Elevated Temperature | 32,228 | 103.5 % |



Figure 3 – “Elevated Temperature” sample after breaking

ACKNOWLEDGEMENTS

The assistance of Mr. G. Gouliaras is greatly appreciated.

Prepared by:

C.J. Pon
Principal Engineer
Transmission and Distribution Technologies Department

M. J. Kastelein
Technologist
Transmission and Distribution Technologies Department

M. Colbert
Technologist
Transmission and Distribution Technologies Department

Approved by:

J. Kuffel
Manager
Transmission and Distribution Technologies Department

CJP:MJK:MC:JC

DISCLAIMER

Kinectrics North America Inc. has prepared this report in accordance with, and subject to, the terms and conditions of the contract between Kinectrics North America Inc. and 3M Company, dated August 15, 2002.

ISO-9001
Form: QF11-1
Rev 0, 97-10

APPENDIX C INSTRUMENT SHEET 3M Company (Reference: 795 kcmil ACCR Conductor)

Test Description: Breaking Load Tests
Project Number: 9513-004-2003

Test Start Date: January 23, 2003
Test Finish Date: February 3, 2003

| TEST DESCRIPTION | EQUIPMENT DESCRIPTION | MAKE | MODEL | ASSET # or SERIAL # | ACCURACY CLAIMED | CALIBRATION DATE | CALIBRATION DUE DATE | TEST USE |
|--|-----------------------|----------------------|-----------|---------------------|------------------|--------------------|----------------------|------------------|
| Breaking Load And Elevated Temperature Test | A/D Board | National Instruments | PCI-6034E | CA1C1A | ±0.1% of reading | September 14, 2002 | September 14, 2003 | Data Acquisition |
| | Load Cell (MTS) | Lebow | 3156 | 17356-0 | | | | |
| | Load Cell Conditioner | MTS | 493.01DC | 10000686-0 | ±1% of reading | February 13, 2002 | February 13, 2003 | Breaking Load |
| | Data Logger | Campbell Scientific | 21X | 11119-0 | ±0.1% of F.S. | January 28, 2003 | January 28, 2004 | Data Acquisition |

DISTRIBUTION

Dr. Colin McCullough (2)

3M Company
Composite Conductor Program
2465 Lexington Ave. South
Mendota Heights, MN
55120
USA

Mr. C. Pon

Transmission and Distribution Technologies, KB104