



**EB-2007-0006**

**IN THE MATTER OF** the *Ontario Energy Board Act, 1998*,  
S. O. 1998, c.15, Schedule B;

**AND IN THE MATTER OF** an application by Kruger  
Energy Port Alma Limited Partnership for an Order  
granting leave to construct transmission facilities near the  
Town of Merlin in the Municipality of Chatham-Kent.

**BEFORE:** Cynthia Chaplin  
Presiding Member

Pamela Nowina  
Member and Vice Chair

Bill Rupert  
Member

**ORDER AMENDING DECISION AND ORDER OF MAY 29, 2007**

The Ontario Energy Board (the “Board”) issued a Decision and Order in the matter of the above proceeding on May 29, 2007 (the “Decision”), under section 92 of the *Ontario Energy Board Act, 1998*, S.O. 1998, c.15, Schedule B (the “Act”). In the Decision the Board stated at page 3: “The IESO has imposed an output restriction (limiting aggregate output to 98 MW, down from the initial 101 MW), a modification of the generator transformer step-up ratio, and the addition of static compensation to the collector bus.”

The IESO System Impact Assessment (the “SIA”), which is part of the pre-filed evidence in this proceeding, states at item 2, page 2, that the restriction would apply only in circumstances where the IESO control room so directs. The SIA indicates that the restriction could be required because the Var (reactive power) capability of the machines used may not meet the usual IESO requirements at the extremes of the required voltage operating range (SIA, page 16).

Given the above, a correction to the Decision is required.

**THE BOARD ORDERS THAT:**

1. The Decision and Order dated May 29, 2007 is amended as follows:

The sentence at page 3 which states: "The IESO has imposed an output restriction (limiting aggregate output to 98 MW, down from the initial 101 MW), a modification of the generator transformer step-up ratio, and the addition of static compensation to the collector bus." is to be replaced with the following:

The IESO requires that the output of each generator must be limited to 2.23 MW (98.12 MW in aggregate) when directed by the IESO control room.

**ISSUED** at Toronto on June 22, 2007

**ONTARIO ENERGY BOARD**

Peter H. O'Dell  
Assistant Board Secretary

**APPENDIX A**

**TO DECISION AND ORDER**

**DATED May 29, 2007**

**BOARD FILE NO. EB-2007-0006**

**DATED June 22, 2007**

