Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 1 Schedule 042 Page 1 of 4

Board Staff Interrogatory #042

3 **Ref:** Ex. F1-T1-S1, pages 18-22

5 **Issue Number: 6.2**

6 **Issue:** Is the benchmarking methodology reasonable? Are the benchmarking results and targets flowing from those results for OPG's regulated hydroelectric facilities reasonable?

8 9

1

2

Interrogatory

10

11 The results of the Navigant Consulting OM&A unit energy cost benchmarking are 12 summarized in Chart 4 on page 18. The application provides several reasons why the unit 13 cost for SAB PGS is much higher than the other hydroelectric facilities. For example, the 14 application notes on page 22 "In addition to its role in pumping water for use during peak 15 periods (which is typical for PGS's), Sir Adam Beck PGS is used to: 1) control the cross-over 16 elevation of the Sir Adam Beck canals, 2) assist in automatic generation control, and 3) 17 provide for flexibility and optimization of operations at the Sir Adam Beck complex." 18 However, between 2006 and 2008, the unit cost almost doubled (increased from 47.1 to 81.2 19 cents/kWh) and is consistently in the 4th quartile (ranging from 22.1 to 81.1 cents) amongst 20 the other PGS comparators. Board staff considered that the rising unit cost may be due to 21 addressing the issue of increased SBG but staff understands from the May 2009 IESO 18-22 month Outlook report that SBG events became a prominent issue following the 23 benchmarking period, in early 2009.

- 24 25
- a) Please explain why the unit cost almost doubled between 2006 and 2008.
- b) The application appears to suggest that none of the other 15 PGS comparators in the
 Navigant results provide functions beyond pumping water for use during peak periods,
 with references to the SAB PGS being "unique". For example, do none of the other
 PGS units provide other functions such as Automatic Generation Control?
- 30 c) Is OPG able to provide a listing of those 15 PGS comparators (with or without their respective unit costs)? If so, please provide the list.
- d) On page 16 it notes that, since March 2009, the "operational performance has been excellent" in relation to SAB PGS. What has the unit cost been since March 2009?
- 34 35

36

37

<u>Response</u>

a) The Sir Adam Beck Pump Generating Station ("SAB PGS") unit energy costs increased
 by 72 per cent between 2006 and 2008, rising from \$47.1/MWh to \$81.2/MWh.

The primary reason for this significant increase was the unusually large volume of maintenance and repair work required in 2008 relative to 2006. There was more than twice the number of outage days in 2008 as compared to 2006. The majority of these outage days were for troubleshooting and base maintenance related to the SAB PGS-6 runner failure. The increased staff required to support these outages and the materials Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 1 Schedule 042 Page 2 of 4

4

5

6

7

8 9

10

11 12

13

14

15

16

17

18 19

20

21

22

23

and equipment required to carry out temporary repairs resulted in the significant cost
 increases.

The SAB PGS unit energy costs were also negatively affected by changes in exchange rates. Navigant Consulting applies exchange rates to OPG's Canadian dollar costs. From 2006 – 2008, the Canadian dollar appreciated by approximately 10.3 per cent versus the U.S. dollar.

In general terms (i.e., not necessarily with respect to 2006 versus 2008), the SAB PGS costs are high compared to other pump-generating plants for the following reasons:

- With a capacity of 174 MW and a head of only 24.4 metres, SAB PGS is the smallest of all 15 peer group plants. The average plant size and head, excluding SAB PGS, is 942 MW and 243 metres, respectively. As such, the SAB PGS does not have the economies of scale associated with these comparators. SAB PGS is included in the benchmarking with these larger plants because there is not enough similarly-sized pump-generating plant data to form a more representative peer group.
 - SAB PGS has an inherently low generation-to-pump cycle efficiency of about 50 per cent, as further detailed in the next bullet. Some peer group plants operate as high as 70 80 per cent cycle efficiency. The higher efficiencies of the peer group increase their generation output, thus lowering their unit energy costs.
- 24 • While SAB PGS is primarily used for peaking generation, it also supports the control 25 of the water supply to the Sir Adam Beck complex (diversion control), and provides: 26 voltage support (reactive power), operating reserve, and Automatic Generation 27 Control ("AGC"). Diversion control is accomplished through the SAB PGS by either 28 generating or pumping in order to maintain the crossover elevation upstream of the 29 Sir Adam Beck I and II Generating Station forebays. Maintaining the crossover 30 elevation is critical to controlling and optimizing the diversion of water to these 31 stations. The units at the SAB PGS can be required to make several quick changes in 32 input/output flow per minute in order to maintain the correct crossover elevation. This 33 type of constantly changing operation means that the SAB PGS units are very seldom 34 operated at or near efficiency. The provision of ancillary services (i.e., operating 35 reserve and AGC), while valuable to the power system, reduces the energy 36 generated and increases the unit energy cost for this station. 37
- b) OPG does not have specific information from Navigant Consulting detailing the provision of ancillary services by the peer group plants. However, from discussions with other pump-generation station owners, OPG is aware of no other plant in North America that is subject to the frequency and depth of manoeuvring that is experienced at SAB PGS. For example, Raccoon Mountain (Tennessee Valley Authority) is a 1,650 MW plant that provides very limited AGC and no reactive support service. Carters (Army Corps of Engineers) is a 591 MW plant which does not provide AGC or reactive support service.
 - Witness Panel: Hydroelectric

- c) The pumped-generating station comparators that were included in the 2009 (2008 data)
 Navigant Benchmarking study are listed in Table 1. Unit energy costs for SAB PGS and
 the 14 peer group plants selected by Navigant are shown in Table 2. Due to legal and
 confidentiality requirements, the information is presented in a coded format. Study
 participants are required to avoid linking the unit energy costs with the specific stations.
 Furthermore, it should be noted that most of the cost and energy information for the other
 stations in the study date back to prior years and have been adjusted and escalated to
 2008 dollars. Therefore, they may no longer reflect their most current unit energy costs.
- 9
- 10

11 12

Table 1:Pump-Generating Stations in 2009 Navigant Benchmarking

Company	Station Group Name		
California Dept. of Water Resources	Gianelli GS		
Exelon Power	Muddy Run		
Guangzhou Pumped Storage Power Station	Guangzhou Pumped Storage		
Iberdrola	La Muela		
Iberdrola	Villarino		
Los Angeles Dept. of Water & Power	Castaio Pump		
New York Power Authority	Blenheim-Gilboa		
New York Power Authority	Lewiston		
Ontario Power Generation	Sir Adam Beck PGS		
Scottish Power	Cruachan		
Southern California Edison	Big Creek Pumped Storage		
Tennessee Valley Authority	Raccoon Mountain		
U.S. Army Corps of Engineers (ASE – Mobile)	Carters		
U.S. Bureau of Reclamation	Grand Coulee (Pump Storage)		
Virginia Power	Bath City		

13 14 1 2

3

Plant Code	Data (Year)	Plant Size (MW)	Head (m)	OM&A Cost (2008 USD/MWh)
04UF	2004	2,400	535.0	5.3
95DP	1995	2,100	330.0	5.0
08QV	2008	1,653	317.0	3.7
96SI	1996	1,272	304.8	14.0
01RE	2001	550	105.2	14.3
08PE	2008	1,072	137.0	6.1
02MB	2002	1,040	334.9	19.2
93ZD	1993	810	N/A	8.0
93OY	1993	621	N/A	14.7
93GI	1993	420	N/A	18.4
04SZ	2004	402	88.4	26.6
02DK	2002	336	22.9	26.3
08OA	2008	314	105.5	39.4
94KE	1994	207	396.0	4.5
SAB PGS	2008	174	24.4	81.1

Table 2:Pump-Generating Station Data in Navigant Benchmaking

4

d) The statement in the evidence on page 16 (lines 14-15) was made with reference to SAB
 PGS Unit 6's environmental and operational performance since it returned to service in
 March 2009. OPG does not track unit energy costs for individual hydroelectric units and
 thus cannot provide costs specific to Unit 6.

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 1 Schedule 043 Page 1 of 2

Board Staff Interrogatory #043

3
4 Ref: Ex. F1-T1-S1, page 16, and Attachment 1, pages 10 and 34

5

1

2

6 **Issue Number: 6.2**

7 **Issue:** Is the benchmarking methodology reasonable? Are the benchmarking results and targets flowing from those results for OPG's regulated hydroelectric facilities reasonable?

9

10 Interrogatory

11

12 As noted in the application and referenced in the interrogatory above, the Navigant 13 benchmarking results show the unit cost of the SAB PGS almost doubled and the SAB PGS 14 provides many important functions in the Ontario electricity market. The summary report 15 prepared by Elenchus, in relation to OPG's stakeholder consultation meetings (in November 16 2007) prior to the previous payments application, notes that the SAB PGS is over half a 17 century old and is relatively inefficient, with about a 50% efficiency loss when water is 18 pumped (i.e., for each MWh used to pump water, 0.5 MWh is generated) and that efficiency 19 loss is attributable to the age of the equipment. The application also notes on page 16 that 20 the unit had to be "dismantled and shipped to the manufacturer's facility in Montreal" and the 21 repairs "took over ten months". In Attachment 1 (p. 34), which is page 13 of the Business 22 Plan, it further identifies "• SAB PGS Unit rehabilitation on G2-5 planned for 2011-2014. PGS 23 Unit transformers also scheduled for replacement 2009-11. Unit breakers and governors 24 planned for replacement 2011-13." Attachment 1 (p.10) further notes OPG has conducted a 25 "preliminary review of expansion of the existing Sir Adam Beck PGS reservoir".

- 26
- a) Given all of the above, please explain if OPG has investigated a full replacement of the
 PGS equipment. If not, please explain why. If so, what is the estimated cost of a full
 replacement?
- b) Please identify the total estimated cost of all of the recent and planned material
 investments in relation to the SAB PGS (i.e., dismantling and shipping to the
 manufacturer's facility, rehabilitation, transformer replacements, breaker and governor
 replacements, etc.).
- 36 c) What efficiency improvement could likely be achieved with state-of-the-art equipment?
- 3738 d) Please also elaborate on the results of the preliminary review of SAB PGS expansion.
- 39 40

41 <u>Response</u>42

43 a) At this time, OPG has not performed a complete investigation nor prepared a detailed
 44 cost estimate for replacing the six units at Sir Adam Beck Pump Generating Station
 45 ("SAB PGS"). OPG has initiated a Plant Condition Assessment ("PCA") study for the

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 1 Schedule 043 Page 2 of 2

8

9

10

13

14

15

16

PGS. The PCA study is expected to be completed by December 2010. The PCA study
 will be followed by a Life Cycle Plan to be completed by December 2011. Estimates for
 the replacement of PGS equipment will be developed as part of the Life Cycle Plan study.

- b) PGS investments (i.e. capital and OM&A projects) over the 2010 2014 approved
 business planning ("BP") period total \$31.4 M. The major projects are:
 PGS Unit overhauls (OM&A: \$9.1 M of \$15.0 M total guoted in F1-3-1 Table 1 is
 - PGS Unit overhauls (OM&A: \$9.1 M of \$15.0 M total quoted in F1-3-1 Table 1 is within the BP period)
 - Transformer Replacements (Capital: \$6.9 M of \$7.2 M Total quoted in D1-1-2 Table 2 is within the BP period)
- 13.8kV Breaker Replacement (Capital: \$5.9 M as quoted in D1-1-2 Table 2 is in the BP period)
 - Governor Replacements (Capital: \$5.6 M as quoted in D1-1-2 Table 2 is in the BP period)
 - The balance of \$3.9 M is composed of small projects under \$5 M.
- c) OPG estimates that it would likely be able to achieve up to a 5 per cent increase in cycle efficiency (combining both pumping and generation operation efficiencies) with state of the art pumping and generating equipment at SAB PGS. As explained in L-01-042, the unique operating circumstances of the SAB PGS limit the opportunities for efficiency improvements generally and, in particular, would make it very difficult to justify the installation of new pump-turbines.
- d) The preliminary review referenced in the Business Plan Presentation considered the
 following options: expanding the footprint of the reservoir, deepening the reservoir, and
 increasing the dyke elevation. While the reservoir volume increases under the individual
 options can be as high as 27 per cent, a combination of options could result in volume
 increases of over 40 per cent.

king results and 9?
king results and ∋?
calculated.
· of days lost by
ent) that a unit is that require a
ng a given year
example would nt.
IW unit that can time is added to an operating unit
it derating). This ge hours (in the
se of a derating s while available both the forced
nts n Antiant ge sister

45 simple example of EFOR.

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 14 Schedule 010 Page 2 of 2

- 1 2 3 4 5 The EFOR calculation methodology is defined in the Generating Availability Data System Reporting Instructions issued by the North American Reliability Council ("NERC").
- b) Confirmed.

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 14 Schedule 011 Page 1 of 1

VECC Interrogatory #011

2 3 **Ref:** Ex. F1-T1-S1, pages 5, 10, and 11

5 **Issue Number: 6.2**

6 **Issue:** Is the benchmarking methodology reasonable? Are the benchmarking results and targets flowing from those results for OPG's hydroelectric facilities reasonable?

8 9

1

4

Interrogatory

10

Please provide specific details regarding the construction of the environmental performanceindex.

- 13
- 14

15 <u>Response</u>16

17 The Environmental Performance Index ("EPI") is described in Ex. F1-T1-S1, pages 5, 10, 18 and 11. The EPI is normally produced annually at the plant group level. The components of 19 the EPI target are shown in the sample calculation below, which is representative of the 20 components in an actual index.

- 21
- 22 23

2010 Environmental Performance Index (EPI) – Sample Calculation

Category	Performance Measure	Threshold (0.5)	Target (1.0)	Max. (1.5)	Weighting (%)	Actual	Score
Spills	Category A Spill	0	0	0	Meet	0	Meet
	Category B Spill	0	0	0	Meet	0	Meet
	Category C Spill	2	1	0	25%	1	25%
Regulatory Compliance	Major Regulatory Infractions	0	0	0	Meet	0	Meet
	Moderate Regulatory Infractions	2	1	0	35%	0	53%
Internal Energy Efficiency (IEE)	Energy Efficiency Projects Completed	1 runner upgrade	1 runner upgrade; 1 transformer replacement	2 runner upgrades; 1 transformer replacement	40%	1 runner upgrade	20%
TOTAL					100%		98%

24

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 14 Schedule 012 Page 1 of 2

VECC Interrogatory #012

Ref: Ex. F1-T1-S1, pages 6 and 7, and Chart 1

Issue Number: 6.2

Issue: Is the benchmarking methodology reasonable? Are the benchmarking results and targets flowing from those results for OPG's hydroelectric facilities reasonable?

Interrogatory

11 Regarding the EFOR targets and actual as shown on Chart 1, please provide the 12 comparable CEA and EUCG average and median results for 2007, 2008, and 2009. Also, 13 please explain how the targets for future years are set.

14

1 2 3

4 5

6

7

8 9

10

15

16 <u>Response</u> 17

18 The comparable results are presented in the tables below. The 2009 data from Canadian 19 Electrical Association ("CEA") and Electric Utility Cost Group ("EUCG") is not currently 20 available.

- 21
- 22

Table 1 Average Equivalent Forced Outage Rate (%)

Name of Station/Grouping	2007	2008	2009
CEA Excluding OPG	3.25	N/A	N/A
EUCG Excluding OPG	5.77	6.17	N/A
OPG	1.80	1.50	1.00

23 24

Table 2 Median Equivalent Forced Outage Rate (%)

median Equivalent i erecu outage nate (70)						
Name of Station/Grouping	2007	2008	2009			
	Not Available					
CEA Excluding OPG	(CEA may make it available in 2011)					
EUCG Excluding OPG (median by plant,						
~210 plants)	0.61	0.85	N/A			
OPG (median by unit, 5 regulated plants						
$= 49 \text{ units})^1$	0.03	0.02	0.01			

25 26

¹ The sample of OPG five regulated plants is statistically insufficiently representative to calculate the median by plant.

Filed: 2010-08-12 EB-2010-0008 Issue 6.2 Exhibit L Tab 14 Schedule 012 Page 2 of 2

In general, Equivalent Forced Outage Rate ("EFOR") targets are set based on plant historical performance. An average EFOR is calculated for the last ten years after rejecting the two most extreme numbers (i.e., minimum and maximum years) leaving eight data points. Continuous improvement or other factors may be added to the targets subject to the discretion of the Executive Management Team. However, since recent EFOR targets have been at historical lows, they have received little or no adjustment.