

**Hydro One Networks Inc.**

8<sup>th</sup> Floor, South Tower  
483 Bay Street  
Toronto, Ontario M5G 2P5  
www.HydroOne.com

Tel: (416) 345-5700  
Fax: (416) 345-5870  
Cell: (416) 258-9383  
Susan.E.Frank@HydroOne.com



**Susan Frank**

Vice President and Chief Regulatory Officer  
Regulatory Affairs

BY COURIER

October 7, 2010

Ms. Kirsten Walli  
Secretary  
Ontario Energy Board  
Suite 2700, 2300 Yonge Street  
P.O. Box 2319  
Toronto, ON.  
M4P 1E4

Dear Ms. Walli:

**EB-2010-0229 – Hydro One Networks Request for Exemption from Certain Sections of the Distribution System Code– Response to Undertakings J1.3 and J1.4**

I am attaching two (2) copies of the responses to undertakings J1.3 and J1.4.

An electronic copy of the undertakings have been filed using the Board's Regulatory Electronic Submission System.

Sincerely,

ORIGINAL SIGNED BY SUSAN FRANK

Susan Frank

Attach.

c. EB-2010-0229 Intervenors (electronic)

**UNDERTAKING**

**Undertaking**

PLEASE PROVIDE AN UPDATE TO TABLE 1 IN EXHIBIT B, TAB 1, SCHEDULE 2, PAGE 4 TO SHOW HOW MANY OF THE PROJECTS AFFECTED BY DISTANCE LIMITATION HAVE NOW BEEN CONNECTED.

**Response**

The following is the updated Table 1, as requested.

There have been no further connections of generators within this list since the date that this Application was originally filed (June 30, 2010). The dates noted in bold font indicate that the in-service dates for a number of projects have been changed (a few have advanced their dates slightly and the remainder have been delayed by one to about ten months).

<b>Table 1. Projects Affected by Distance Limitation (Voltage Fluctuations)</b>			
<b>Project ID</b>	<b>Size (MW)</b>	<b>Technology</b>	<b>In-Service Date</b>
835	6.7	Hydraulic	Connected
69	6.6	Wind	Connected
1084	9.9	Wind	Connected
1096	9.9	Wind	Connected
1097	9.9	Wind	Connected
1099	9.9	Wind	Connected
281	9.9	Wind	Connected
282	9.9	Wind	Connected
49	10.0	Wind	Connected
76	10.0	Wind	Connected
8	10.0	Wind	<b>Oct. 8, 2010</b>
645	1.3	Hydraulic	<b>Oct. 8, 2010</b>
89	10.0	Wind	<b>Dec. 2, 2010</b>
251	15.0	Hydraulic	<b>Oct. 18, 2010</b>
964	10.0	Solar	<b>Sept. 1, 2011</b>
965	10.0	Solar	<b>Sept. 2, 2011</b>
11bi	6.5	Wind	Nov. 30, 2010
274	9.9	Wind	<b>March 13, 2011</b>
252	9.5	Hydraulic	<b>Oct. 26, 2010</b>
487	8.5	Solar	<b>Dec. 1, 2010</b>
1014	10.0	Wind	<b>March 31, 2011</b>
689	10.0	Solar	<b>May 16, 2011</b>

1 **UNDERTAKING**

2  
3 **Undertaking**

4  
5 HOW MANY OF THE NINE PROJECTS AFFECTED BY THE DELTA-Y STEP UP  
6 TRANSFORMER ISSUE (THE GROUNDING TRANSFORMER ISSUE) HAVE  
7 ALREADY BEEN CONNECTED?

8  
9 **Response**

10  
11 Eight of the nine projects have been connected.