

Hydro One Networks Inc.

8th Floor, South Tower
483 Bay Street
Toronto, Ontario M5G 2P5
www.HydroOne.com

Tel: (416) 345-5700
Fax: (416) 345-5870
Cell: (416) 258-9383
Susan.E.Frank@HydroOne.com

Susan Frank

Vice President and Chief Regulatory Officer
Regulatory Affairs



BY COURIER

October 7, 2010

Ms. Kirsten Walli
Secretary
Ontario Energy Board
Suite 2700, 2300 Yonge Street
P.O. Box 2319
Toronto, ON.
M4P 1E4

Dear Ms. Walli:

EB-2010-0229 – Hydro One Networks Request for Exemption from Certain Sections of the Distribution System Code– Response to Undertakings J1.3 and J1.4

I am attaching two (2) copies of the responses to undertakings J1.3 and J1.4.

An electronic copy of the undertakings have been filed using the Board's Regulatory Electronic Submission System.

Sincerely,

ORIGINAL SIGNED BY SUSAN FRANK

Susan Frank

Attach.

c. EB-2010-0229 Intervenor (electronic)

UNDERTAKING

Undertaking

PLEASE PROVIDE AN UPDATE TO TABLE 1 IN EXHIBIT B, TAB 1, SCHEDULE 2, PAGE 4 TO SHOW HOW MANY OF THE PROJECTS AFFECTED BY DISTANCE LIMITATION HAVE NOW BEEN CONNECTED.

Response

The following is the updated Table 1, as requested.

There have been no further connections of generators within this list since the date that this Application was originally filed (June 30, 2010). The dates noted in bold font indicate that the in-service dates for a number of projects have been changed (a few have advanced their dates slightly and the remainder have been delayed by one to about ten months).

Table 1. Projects Affected by Distance Limitation (Voltage Fluctuations)			
Project ID	Size (MW)	Technology	In-Service Date
835	6.7	Hydraulic	Connected
69	6.6	Wind	Connected
1084	9.9	Wind	Connected
1096	9.9	Wind	Connected
1097	9.9	Wind	Connected
1099	9.9	Wind	Connected
281	9.9	Wind	Connected
282	9.9	Wind	Connected
49	10.0	Wind	Connected
76	10.0	Wind	Connected
8	10.0	Wind	Oct. 8, 2010
645	1.3	Hydraulic	Oct. 8, 2010
89	10.0	Wind	Dec. 2, 2010
251	15.0	Hydraulic	Oct. 18, 2010
964	10.0	Solar	Sept. 1, 2011
965	10.0	Solar	Sept. 2, 2011
11bi	6.5	Wind	Nov. 30, 2010
274	9.9	Wind	March 13, 2011
252	9.5	Hydraulic	Oct. 26, 2010
487	8.5	Solar	Dec. 1, 2010
1014	10.0	Wind	March 31, 2011
689	10.0	Solar	May 16, 2011

UNDERTAKING

Undertaking

HOW MANY OF THE NINE PROJECTS AFFECTED BY THE DELTA-Y STEP UP
TRANSFORMER ISSUE (THE GROUNDING TRANSFORMER ISSUE) HAVE
ALREADY BEEN CONNECTED?

Response

Eight of the nine projects have been connected.