



# TILTRAN SERVICES INC.

## *Electrical Power System Specialists*

July 5, 2010

Erie Thames Power  
280 Elm Street  
Aylmer, ON  
N5C 3G3

**Attention:** *Mr. Chris White, Chief Operating Officer*

**Re: Maintenance Inspection Report -- Our Ref. No. 23404LSP**  
**Site: West Perth Mitchell - MS#2 - Wellington Street**

Dear Chris,

Please find attached the report for the inspections completed May 22, 2010.

Tiltran Services cleaned, serviced and tested as required the main power system. All testing results were satisfactory with no faults found. A summary of the site findings is listed below for your review.

### ***Findings/ Repairs:***

- Minor oil leak found on bottom tank sample valve – monitoring required



- Silica gel was replaced



All other equipment that we tested appears in satisfactory condition, suitable for continued service.

If you have any questions/concerns please do not hesitate to contact us. We look forward to being of continued service to West Perth Power.

Sincerely,  
TILTRAN SERVICES INC.



Doug Charron  
Master Electrician, Technician  
Maintenance and Technical Services  
Phone: (519) 842-6458 Ext 227  
Fax: (519) 842-2496  
Cell: (519) 521-2600