



TILTRAN SERVICES INC.

Electrical Power System Specialists

September 20, 2010

Erie Thames Power
280 Elm Street
Aylmer, ON
N5C 3G3

Attention: *Mr. Chris White, Chief Operating Officer*

Re: Maintenance Inspection Report -- Our Ref. No. 23404LSP
Site: West Perth Mitchell - MS#2 - Wellington Street

Dear Chris,

Please find attached the report for the inspections completed September 9, 2010 at the West Perth MS2 site.

Tiltran Services cleaned, serviced and tested as required the main power system. All testing results were satisfactory with no faults found. A summary of the site findings is listed below for your review.

Recommendations:


- It is recommended that the gate fabric to be bonded during the next maintenance inspection



All other equipment that we tested appears in satisfactory condition, suitable for continued service.

If you have any questions/concerns please do not hesitate to contact us. We look forward to being of continued service to West Perth Power.

Sincerely,
TILTRAN SERVICES INC.



Doug Charron
Master Electrician, Technician
Maintenance and Technical Services
Phone: (519) 842-6458 Ext 227
Fax: (519) 842-2496
Cell: (519) 521-2600