

UNDERTAKING J6.3

Undertaking

To provide the average number of days of uncertainty reserve for each year from 2009 to 2012 per outage.

Response

Each station's planned outage schedule includes an allowance for uncertainty in the outage duration for potential discovery work (Ex. E2-T1-S1, page 9, line 16). The table below provides, by station, the number of days provided as an allowance for potential discovery work for the period 2009 - 2012.

	2009 Actual (days)	2010 Budget (days)	2011 Plan (days)	2012 Plan (days)
Pickering A	2.5	6.5	7.5	6.5
Pickering B	12.0	12.0	12.0	12.0
Darlington	24.0	8.8	8.8	3.8
OPG Nuclear	38.5	27.3	28.3	22.3