

March 14, 2011

Ontario Energy Board
2300 Yonge Street, Suite 2700
Toronto, Ontario
M4P 1E4

ATTN: Ms. Kirsten Walli, Board Secretary

**RE: EB-2009-0166 – Union Gas Limited – 2010 Demand Side Management Plan
Revised 2010 DSM Measure - Post the Audit of Union's 2009 DSM Annual Report**

Dear Ms. Walli:

Union requests the Ontario Energy Board's (the "Board") approval for certain 2010 revised DSM measures for its 2010 program year.

On August 25, 2006 the Board issued its EB-2006-0021 Decision which outlined a process allowing for updates to the DSM input assumptions (page 57). Union followed the approved process to establish the 2010 DSM input assumptions. Union consulted with the 2010 Evaluation and Audit Committee ("EAC") on all the measures and achieved complete consensus on all the input assumptions. On June 22, 2010, the Board issued its EB-2010-0182 Decision approving the 2010 DSM input assumptions.

Attachment A contains revised 2010 DSM input assumptions in response to the Audit of Union's 2009 DSM Annual Report. Specifically, changes were made to the following technology substantiation documents: Energy Recovery Ventilators (ERVs), Heat Recovery Ventilators (HRVs), Infrared Heaters and Low-Flow Showerheads for both the Residential and Low-Income Markets.

Attachment B reflects the updates for 2010 SSM calculations. In addition, Union's updated Custom Program Free Rider rates are included on the last page.

Union followed the Board's process established in EB-2006-0021 and achieved consensus from its EAC for all of the enclosed revised 2010 measures. Union requests the Board's approval of the revised 2010 DSM measures.

If you have any questions, please contact me at 519-436-4521.

Sincerely,

[original signed by]

Marian Redford
Manager, Regulatory Initiatives

Cc: Crawford Smith (Torys)
EB-2009-0166 Intervenors

Revised 2010 DSM Measures – Post Audit of Union’s 2009 DSM Annual Report

Energy Recovery Ventilator (ERV)

Heat Recovery Ventilator (HRV)

Infrared Heaters

Low Flow Showerheads

36. Energy Recovery Ventilator (ERV) – Existing Commercial

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|--------------------|
| | | September 16, 2010 |

Efficient Equipment and Technologies Description

Ventilation with an Energy Recovery Ventilator (ERV)

Base Equipment and Technologies Description

Ventilation without an Energy Recovery Ventilator (ERV)

| Decision Type | Target Market(s) | End Use |
|---------------|---------------------|---------------|
| Replacement | Existing Commercial | Space Heating |

Codes, Standards, and Regulations

N/A

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$/CFM) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------|--|--|
| | Natural Gas (m ³ /CFM) | Electricity (kWh) | Water (L) | | |
| 1 | 2.17 – 6.12 | 0 | 0 | 3.18 | 0 |
| 2 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 3 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 4 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 5 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 6 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 7 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 8 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 9 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 10 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 11 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 12 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 13 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| 14 | 2.17 – 6.12 | 0 | 0 | 0 | 0 |
| TOTALS | 30.4 – 85.7 | 0 | 0 | 3.18 | 0 |

Resource Savings Assumptions

| | |
|-----------------------------------|--------------------------------------|
| Annual Natural Gas Savings | 2.17 – 6.12 m³/CFM |
|-----------------------------------|--------------------------------------|

- Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.

| Symbols | Variable Names | Values | Source |
|---------|--|--------------------------|--------|
| A | Supply air flow (cfm) | ERV Capacity | UG |
| B | Exhaust air flow (cfm) | ERV Capacity | UG |
| C | Average Indoor Air Temperature (°F) | 70 | UG |
| D | Average Indoor Relative Humidity (%) | 30 | UG |
| E | Average Outside Air Temperature (°F) | Adjust Based On District | N |
| F | Average Outdoor Relative Humidity (%) | 75 | N |
| G | Atmospheric Pressure (psia) | 14.25 | UG |
| H | No. Of Hours in Heating Season (hrs) | Adjust Based On District | N |
| I2 | No. Of Hours Of Operation Per Week | See Table Below | N |
| K | Effectiveness Of Heat Recovery Equipment (%) | 67 | N |
| L | Sensible Heat Recovery Only | no | UG |
| M | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Exhaust Air | Calculated | UG |
| N | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Supply Air | Calculated | UG |
| O | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of OUTLET supply Air | Calculated | UG |
| P | Average Temperature of OUTLET Supply Air (°F) | Calculated | UG |
| Q | Average Hourly Moisture Addition (lb/hr) | Calculated | UG |
| R | Defrost Control Derating Factor (%) | 5 | UG |
| S | Average Hourly Heat Recovery (MBH) | Calculated | UG |
| T | Season Efficiency of Gas-Fired Equipment (%) | 82 | UG |
| U | Average Annual Gas Reduction (m ³) | Calculated | UG |
| V | Incremental Natural Gas Reduction (\$/m ³) | 0.3 | UG |
| W | Average Annual Gas Savings (\$) | Calculated | UG |

UG - Union Gas

N - Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010

- NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m³/MJ) / (Seasonal Efficiency / 100%) **(A)**
 - 168 hour = 7 days/week x 24hours/day
 - Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor¹ %) **(B)**

¹ From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

- Operating hours for each sectors being considered are as the following

| Segment | Hours of Operation per Week |
|--------------|-----------------------------|
| Multi-Family | 168 |
| Health Care | 168 |
| Nursing Home | 168 |
| Hotel | 120 |
| Restaurant | 87 |
| Retail | 73 |
| Office | 64 |
| Warehouse | 61 |
| School | 54 |

- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated. Gas savings for each district were combined using a 70/30 South/North split. Markets with similar gas savings were combined to reduce administration costs and to simplify the program.

Example below:

| Grouping | Segment | ERV Capacity (CFM) | Existing Buildings | |
|------------|--------------|--------------------|-------------------------------|---|
| | | | Gas Savings (m ³) | Gas Savings per CFM (m ³ /CFM) |
| High Use | Multi-Family | 500 | 3058 | 6.12 |
| | Health Care | | | |
| | Nursing Home | | | |
| Medium Use | Hotel | 500 | 1699 | 3.40 |
| | Restaurant | | | |
| | Retail | | | |
| Low Use | Office | 500 | 1086 | 2.17 |
| | Warehouse | | | |
| | School | | | |

| | |
|-----------------------------------|----------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | 0 L/CFM |
| N/A | |

Other Input Assumptions

| | |
|--|-------------------|
| Effective Useful Life (EUL) | 14 Years |
| The 14 year life recommended by DEER is based on KEMA-XENERGY's <i>Retention Study of PG&Es 1996-1997 Energy Incentive Program</i> (50). This study tracked installed equipment over 6 years and used statistical analysis to calculate EUL. ² | |
| Incremental Costs | \$3.18/CFM |
| The incremental costs are based on relative scaling of incremental costs \$2,500 / 1000 CFM ³ . Based on communication with local contractors, the incremental costs are \$3/CFM. Nexant recommends increasing the incremental cost by inflation, to \$3.18/CFM. ⁴ | |

² Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-32

³ "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁴ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-34

37. Energy Recovery Ventilator (ERV) – New Commercial

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|--------------------|
| | | September 16, 2010 |

Efficient Equipment and Technologies Description

Ventilation with ERV

Base Equipment and Technologies Description

Ventilation without ERV

| Decision Type | Target Market(s) | End Use |
|---------------|------------------|---------------|
| New | New Commercial | Space Heating |

Codes, Standards, and Regulations

- 1) Restriction for new building construction: This measure is not applicable to system $\geq 5,000$ CFM with $\geq 70\%$ OA ratio because energy recovery is required by Ontario Building Code 2006.
- 2) Restriction for new building construction: This measure is not applicable to systems serving health care spaces indicated in **Table 1** because heat recovery is required by CSA Z317.2-01

Table 1 - Health Care Spaces Not Eligible

| | | |
|----------------------------|----------------------|-----------------------------|
| Anaesthetic gas scavenging | Cart and can washers | Areas using hazardous gases |
| Animal facilities | Chemical storage | Isolation rooms |
| Autopsy suite | Cooking facilities | Perchloric hoods |
| Biohazard and fume hoods | Ethylene oxide | Radioisotope hoods |

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$/CFM) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------|--|--|
| | Natural Gas (m ³ /CFM) | Electricity (kWh) | Water (L) | | |
| 1 | 2.05 – 5.77 | 0 | 0 | 3.18 | 0 |
| 2 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 3 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 4 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 5 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 6 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 7 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 8 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 9 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 10 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 11 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 12 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 13 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| 14 | 2.05 – 5.77 | 0 | 0 | 0 | 0 |
| TOTALS | 28.7 – 80.8 | 0 | 0 | 3.18 | 0 |

Resource Savings Assumptions

Annual Natural Gas Savings

2.05 – 5.77 m³/CFM

- ERV gas savings in new buildings is determined in the same way as in the ERV gas savings in existing buildings except the balance point temperature of a building. The balance point temperature of a building is selected based on building's thermal characteristics (internal & solar heat gains, infiltration rates and indoor temperature settings). Generally, older buildings (pre-1970's) or buildings with low internal heat gains (residences, motels, supermarkets, warehouses) should consider using a base HDD65°F or HDD60°F value. New buildings built to current OBC standards or buildings with high internal heat gains (retail, restaurants, offices) should consider using base HDD55°F, HDD50°F or even lower balance point temperature.
- Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.

| Symbols | Variable Names | Values | Source |
|---------|--|--------------------------|--------|
| A | Supply air flow (cfm) | ERV Capacity | UG |
| B | Exhaust air flow (cfm) | ERV Capacity | UG |
| C | Average Indoor Air Temperature (°F) | 70 | UG |
| D | Average Indoor Relative Humidity (%) | 30 | UG |
| E | Average Outside Air Temperature (°F) | Adjust Based On District | N |
| F | Average Outdoor Relative Humidity (%) | 75 | N |
| G | Atmospheric Pressure (psia) | 14.25 | UG |
| H | No. Of Hours in Heating Season (hrs) | Adjust Based On District | N |
| I2 | No. Of Hours Of Operation Per Week | See Table Below | N |
| K | Effectiveness Of Heat Recovery Equipment (%) | 67 | N |
| L | Sensible Heat Recovery Only | no | UG |
| M | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Exhaust Air | Calculated | UG |
| N | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Supply Air | Calculated | UG |
| O | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of OUTLET supply Air | Calculated | UG |
| P | Average Temperature of OUTLET Supply Air (°F) | Calculated | UG |
| Q | Average Hourly Moisture Addition (lb/hr) | Calculated | UG |
| R | Defrost Control Derating Factor (%) | 5 | UG |
| S | Average Hourly Heat Recovery (MBH) | Calculated | UG |
| T | Season Efficiency of Gas-Fired Equipment (%) | 82 | UG |
| U | Average Annual Gas Reduction (m ³) | Calculated | UG |
| V | Incremental Natural Gas Reduction (\$/m ³) | 0.3 | UG |
| W | Average Annual Gas Savings (\$) | Calculated | UG |

UG - Union Gas

N - Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010

NG Savings = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m³/MJ) / (Seasonal Efficiency / 100%) **(A)**

- 168 hour = 7 days/week x 24hours/day

Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor¹ %) **(B)**

¹ From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

- Operating hours for each sectors being considered are as the following

| Segment | Hours of Operation per Week |
|--------------|-----------------------------|
| Multi-Family | 168 |
| Health Care | 168 |
| Nursing Home | 168 |
| Hotel | 120 |
| Restaurant | 87 |
| Retail | 73 |
| Office | 64 |
| Warehouse | 61 |
| School | 54 |

- New buildings and existing buildings mainly differ in the enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula **(B)**.
- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated. Gas savings for each district were combined using a 70/30 South/North split. Markets with similar gas savings were combined to reduce administration costs and to simplify the program.

| Grouping | Segment | ERV Capacity (CFM) | New Buildings | |
|------------|--------------|--------------------|-------------------------------|---|
| | | | Gas Savings (m ³) | Gas Savings per CFM (m ³ /CFM) |
| High Use | Multi-Family | 500 | 2885 | 5.77 |
| | Health Care | | | |
| | Nursing Home | | | |
| Medium Use | Hotel | 500 | 1603 | 3.21 |
| | Restaurant | | | |
| | Retail | | | |
| Low Use | Office | 500 | 1025 | 2.05 |
| | Warehouse | | | |
| | School | | | |

| | |
|-----------------------------------|--------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | 0 L |
| N/A | |

Other Input Assumptions

| | |
|--|---------------------|
| Effective Useful Life (EUL) | 14 Years |
| The 14 year life recommended by DEER is based on KEMA-XENERGY's <i>Retention Study of PG&Es 1996-1997 Energy Incentive Program</i> (50). This study tracked installed equipment over 6 years and used statistical analysis to calculate EUL. ² | |
| Incremental Costs | \$3.18 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$2,500 / 1000 CFM ³ . Based on communication with local contractors, the incremental costs are \$3/CFM. Nexant recommends increasing the incremental cost by inflation, to \$3.18/CFM. ⁴ | |

² Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-32

³ "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁴ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-34

40. Heat Recovery Ventilator (HRV) – Existing Commercial

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|--------------------|
| | | September 16, 2010 |

Efficient Equipment and Technologies Description

Ventilation with HRV

Base Equipment and Technologies Description

Ventilation without HRV

| Decision Type | Target Market(s) | End Use |
|---------------|---------------------|---------------|
| Retrofit | Existing Commercial | Space Heating |

Codes, Standards, and Regulations

N/A

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$/CFM) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------|--|--|
| | Natural Gas (m ³ /CFM) | Electricity (kWh) | Water (L) | | |
| 1 | 1.67 – 4.70 | 0 | 0 | 3.61 | 0 |
| 2 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 3 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 4 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 5 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 6 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 7 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 8 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 9 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 10 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 11 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 12 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 13 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| 14 | 1.67 – 4.70 | 0 | 0 | 0 | 0 |
| TOTALS | 23.4 – 65.8 | 0 | 0 | 3.61 | 0 |

Resource Savings Assumptions

| Annual Natural Gas Savings | | | 1.67 – 4.70 m ³ / CFM |
|--|--|--------------------------|----------------------------------|
| <ul style="list-style-type: none"> Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity. | | | |
| Symbols | Variable Names | Values | Source |
| A | Supply air flow (cfm) | HRV Capacity | UG |
| B | Exhaust air flow (cfm) | HRV Capacity | UG |
| C | Average Indoor Air Temperature (°F) | 70 | UG |
| D | Average Indoor Relative Humidity (%) | 30 | UG |
| E | Average Outside Air Temperature (°F) | Adjust Based On District | N |
| F | Average Outdoor Relative Humidity (%) | 75 | N |
| G | Atmospheric Pressure (psia) | 14.25 | UG |
| H | No. Of Hours in Heating Season (hrs) | Adjust Based On District | N |
| I2 | No. Of Hours Of Operation Per Week | See Table Below | N |
| K | Effectiveness Of Heat Recovery Equipment (%) | 61 | N |
| L | Sensible Heat Recovery Only | no | UG |
| M | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Exhaust Air | Calculated | UG |
| N | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Supply Air | Calculated | UG |
| O | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of OUTLET supply Air | Calculated | UG |
| P | Average Temperature of OUTLET Supply Air (°F) | Calculated | UG |
| Q | Average Hourly Moisture Addition (lb/hr) | Calculated | UG |
| R | Defrost Control Derating Factor (%) | 5 | UG |
| S | Average Hourly Heat Recovery (MBH) | Calculated | UG |
| T | Season Efficiency of Gas-Fired Equipment (%) | 82 | UG |
| U | Average Annual Gas Reduction (m ³) | Calculated | UG |
| V | Incremental Natural Gas Reduction (\$/m ³) | 0.3 | UG |
| W | Average Annual Gas Savings (\$) | Calculated | UG |

UG - Union Gas

N - Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010

- NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m³/MJ) / (Seasonal Efficiency / 100%) **(A)**
 - 168 hour = 7 days/week x 24hours/day
 - Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor⁵ %) **(B)**

⁵ From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

- Operating hours for each sectors being considered are as the following

| Segment | Hours of Operation per Week |
|--------------|-----------------------------|
| Multi-Family | 168 |
| Health Care | 168 |
| Nursing Home | 168 |
| Hotel | 120 |
| Restaurant | 87 |
| Retail | 73 |
| Office | 64 |
| Warehouse | 61 |
| School | 54 |

- New buildings and existing buildings mainly differ in enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula **(B)**.
- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated. Gas savings for each district were combined using a 70/30 South/North split. Markets with similar gas savings were combined to reduce administration costs and to simplify the program.

Example below:

| Grouping | Segment | ERV Capacity (CFM) | Existing Buildings | |
|------------|--------------|--------------------|-------------------------------|---|
| | | | Gas Savings (m ³) | Gas Savings per CFM (m ³ /CFM) |
| High Use | Multi-Family | 500 | 2352 | 4.70 |
| | Health Care | | | |
| | Nursing Home | | | |
| Medium Use | Hotel | 500 | 1307 | 2.61 |
| | Restaurant | | | |
| | Retail | | | |
| Low Use | Office | 500 | 835 | 1.67 |
| | Warehouse | | | |
| | School | | | |

| | |
|-----------------------------------|------------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | 0 L / CFM |
| N/A | |

Other Input Assumptions

| | |
|---|---------------------|
| Effective Useful Life (EUL) | 14 Years |
| The 14 year life recommended by DEER is based on KEMA-XENERGY's <i>Retention Study of PG&Es 1996-1997 Energy Incentive Program</i> (50). This study tracked installed equipment over 6 years and used statistical analysis to calculate EUL. ⁶ | |
| Incremental Costs | \$3.61 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$1,700 / 500 CFM ⁷ . Nexant recommends increasing the incremental cost by inflation, to \$3.61/CFM. ⁸ | |

⁶ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-32)

⁷ "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁸ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-34

41. Heat Recovery Ventilator (HRV) – New Commercial

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|--------------|
| | | |

Efficient Equipment and Technologies Description

Ventilation with HRV

Base Equipment and Technologies Description

Ventilation without HRV

| Decision Type | Target Market(s) | End Use |
|---------------|------------------|---------------|
| New | Commercial | Space Heating |

Codes, Standards, and Regulations

- Restriction for New Building Construction: This measure is not applicable to system $\geq 5,000$ CFM in an application requiring $\geq 70\%$ OA ratio according to Ontario Building Code 2006, because energy recovery is required.
- Restriction for New Building Construction: This measure is not applicable to systems serving health care spaces indicated in **Table 1** because heat recovery is required by CSA Z317.2-01

Table 1 - Health Care Spaces Not Eligible

| | | |
|----------------------------|----------------------|-----------------------------|
| Anaesthetic gas scavenging | Cart and can washers | Areas using hazardous gases |
| Animal facilities | Chemical storage | Isolation rooms |
| Autopsy suite | Cooking facilities | Perchloric hoods |
| Biohazard and fume hoods | Ethylene oxide | Radioisotope hoods |

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$/CFM) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------|--|--|
| | Natural Gas (m ³ /CFM) | Electricity (kWh) | Water (L) | | |
| 1 | 1.52 – 4.28 | 0 | 0 | 3.61 | 0 |
| 2 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 3 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 4 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 5 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 6 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 7 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 8 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 9 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 10 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 11 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 12 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 13 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| 14 | 1.52 – 4.28 | 0 | 0 | 0 | 0 |
| TOTALS | 21.3 – 59.9 | 0 | 0 | 3.61 | 0 |

Resource Savings Assumptions

| | |
|-----------------------------------|--------------------------------------|
| Annual Natural Gas Savings | 1.52 – 4.28 m³/CFM |
|-----------------------------------|--------------------------------------|

- HRV gas savings in new buildings is determined in the same way as in the HRV gas savings in existing buildings except the balance point temperature of a building. The balance point temperature of a building is selected based on building's thermal characteristics (internal & solar heat gains, infiltration rates and indoor temperature settings). Generally, older buildings (pre-1970's) or buildings with low internal heat gains (residences, motels, supermarkets, warehouses) should consider using a base HDD65oF or HDD60oF value. New buildings built to current OBC standards or buildings with high internal heat gains (retail, restaurants, offices) should consider using base HDD55oF, HDD50oF or even lower balance point temperature. The balance point values listed represent climate data for the London area.
- Natural gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity.

| Symbols | Variable Names | Values | Source |
|---------|--|--------------------------|--------|
| A | Supply air flow (cfm) | HRV Capacity | UG |
| B | Exhaust air flow (cfm) | HRV Capacity | UG |
| C | Average Indoor Air Temperature (°F) | 70 | UG |
| D | Average Indoor Relative Humidity (%) | 30 | UG |
| E | Average Outside Air Temperature (°F) | Adjust Based On District | N |
| F | Average Outdoor Relative Humidity (%) | 75 | N |
| G | Atmospheric Pressure (psia) | 14.25 | UG |
| H | No. Of Hours in Heating Season (hrs) | Adjust Based On District | N |
| I2 | No. Of Hours Of Operation Per Week | See Table Below | N |
| K | Effectiveness Of Heat Recovery Equipment (%) | 61 | N |
| L | Sensible Heat Recovery Only | no | UG |
| M | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Exhaust Air | Calculated | UG |
| N | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of INLET Supply Air | Calculated | UG |
| O | Enthalpy (Btu/lba) & Humidity Ratio (lbw/lba) Of OUTLET supply Air | Calculated | UG |
| P | Average Temperature of OUTLET Supply Air (°F) | Calculated | UG |
| Q | Average Hourly Moisture Addition (lb/hr) | Calculated | UG |
| R | Defrost Control Derating Factor (%) | 5 | UG |
| S | Average Hourly Heat Recovery (MBH) | Calculated | UG |
| T | Season Efficiency of Gas-Fired Equipment (%) | 82 | UG |
| U | Average Annual Gas Reduction (m ³) | Calculated | UG |
| V | Incremental Natural Gas Reduction (\$/m ³) | 0.3 | UG |
| W | Average Annual Gas Savings (\$) | Calculated | UG |

UG - Union Gas

N - Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010

- **NG Savings** = # of Hours in Heating Season x (operating hours/168) x Average Hourly Heat Recovery / (35.3 m³/MJ) / (Seasonal Efficiency / 100%) **(A)**
 - 168 hour = 7 days/week x 24hours/day
 - Average Hourly Heat Recovery = Supply air flow x 60 x (Supply air flow – Inlet supply air)/Specific Supply Air Conditions Volume x (1 – Defrost Control De-rating Factor¹³ %) **(B)**
- Operating hours for each sectors being considered are as the following

| Segment | Hours of Operation per Week |
|--------------|-----------------------------|
| Multi-Family | 168 |
| Health Care | 168 |
| Nursing Home | 168 |
| Hotel | 120 |
| Restaurant | 87 |
| Retail | 73 |
| Office | 64 |
| Warehouse | 61 |
| School | 54 |

- New buildings and existing buildings mainly differ in enthalpy (BTU/LBa) that is used to calculate the Specific Supply Air Conditions Volume in formula **(B)**.
- Based on the NG Savings formula (A) and input assumptions above, the natural gas savings for each of the commercial sectors are calculated. Gas savings for each district were combined using a 70/30 South/North split. Markets with similar gas savings were combined to reduce administration costs and to simplify the program.

| Grouping | Segment | ERV Capacity (CFM) | New Buildings | |
|------------|--------------|--------------------|-------------------------------|---|
| | | | Gas Savings (m ³) | Gas Savings per CFM (m ³ /CFM) |
| High Use | Multi-Family | 500 | 2142 | 4.28 |
| | Health Care | | | |
| | Nursing Home | | | |
| Medium Use | Hotel | 500 | 1190 | 2.38 |
| | Restaurant | | | |
| | Retail | | | |
| Low Use | Office | 500 | 761 | 1.52 |
| | Warehouse | | | |
| | School | | | |

| | |
|-----------------------------------|----------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | 0 L/CFM |
| N/A | |

¹³ From Union Gas, all air-to-air heat recovery equipment requires frost control in colder climates to prevent freeze-up of exhaust air condensate on heat exchange components. Depending on the defrost control system, annual heat recovery estimates should be reduced by 5 to 15 %. Equipment manufacturers and suppliers can provide an estimated defrost derating factor given the operating conditions of the equipment.

Other Input Assumptions

| | |
|--|---------------------|
| Effective Useful Life (EUL) | 14 Years |
| The 14 year life recommended by DEER is based on KEMA-XENERGY's <i>Retention Study of PG&Es 1996-1997 Energy Incentive Program</i> (50). This study tracked installed equipment over 6 years and used statistical analysis to calculate EUL. ¹⁴ | |
| Incremental Costs | \$3.61 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$1,700 / 500 CFM ¹⁵ . Nexant recommends increasing the incremental cost by inflation, to \$3.61/CFM. ¹⁶ | |

¹⁴ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-32

¹⁵ "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., by Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

¹⁶ Nexant, Evaluation of Natural Gas DSM Measures: ERVs & HRVs, March 12 2010, page 6-34

43. Infrared Heaters

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|--------------|
| | | |

Efficient Equipment and Technologies Description

Infrared heater (up to 255,000 Btu/hour)

Base Equipment and Technologies Description

Regular unit heater

| Decision Type | Target Market(s) | End Use |
|---------------|-----------------------------------|---------------|
| New/Retrofit | New/Existing Commercial buildings | Space Heating |

Codes, Standards, and Regulations

The old code CAN 1-2.16-M81 (R1996) has been withdrawn.

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$/Btu/hour) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|---|----------------------|--------------|---|--|
| | Natural Gas (m ³ /Btu/hour) | Electricity (kWh) | Water (L) | | |
| 1 | 0.015 | 16 - 873 | 0 | 0.0122 | 0 |
| 2 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 3 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 4 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 5 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 6 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 7 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 8 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 9 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 10 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 11 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 12 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 13 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 14 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 15 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 16 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 17 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 18 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 19 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| 20 | 0.015 | 16 - 873 | 0 | 0 | 0 |
| TOTALS | 0.3 | 326 - 17,469 | 0 | 0.0122 | 0 |

Resource Savings Assumptions

Annual Natural Gas Savings

0.015 m³ / Btu/ h

The infrared heater gas savings were based on the analysis procedures previously created by Agviro Inc. for Union Gas¹.

Savings in the Agviro report are provided in three bins, corresponding to the input rating (Btu/hour) of the 0% over-sized conventional draft hood unit heater to be replaced. Agviro explicitly notes that over-sizing was not taken into account in the calculation of savings.

Agviro also notes that the efficient technology, the infrared heater “has been downsized by the infrared adjustment factor” and that “[when/if] the conventional system is 75,000 btu/h input... the infrared heater is [approximately] 64,000 Btu/h input....”

Put another way, an IR heater replacing a 0% over-sized conventional draft hood heater will have an input in btu/h that is 85% (the IR adjustment factor) that of the conventional unit.

Rather than using input range bins for the conventional draft hood heater, Navigant recommends using the corresponding input range bins for the efficient technology. This is for two reasons:

1. It will likely be much simpler to determine the input (btu/h) of the replacement/efficient technology than of the old conventional heater to be replaced.
2. The savings will not be overstated regardless of whether or not the conventional unit is over-sized, so long as the IR heater is appropriately sized for the heating load to be served. If in fact the conventional unit is over-sized the savings estimated will likely be understated given that an oversized draft hood heater operating at partial capacity is likely to consume more gas for a given heating load than a 0% oversized draft hood heater operating at optimal capacity.

In summary: the input heater range bins (and the attendant savings) shown below correspond to the input of *the efficient measure*.

| Location | Heater Range (Btu/h) | Annual Gas Savings (m ³ /year) | | |
|----------|----------------------|---|---------|----------------|
| | | Single Stage | 2-Stage | High Intensity |
| London | 0 – 63,750 | 898 | 1,508 | 898 |
| | 64,600 – 127,500 | 1,786 | 3,017 | 1,786 |
| | 128,350 - 255,000 | 3,591 | 6,033 | 3,591 |
| Sudbury | 0 – 63,750 | 971 | 1,631 | 971 |
| | 64,600 – 127,500 | 1,942 | 3,262 | 1,942 |
| | 128,350 - 255,000 | 3,883 | 6,524 | 3,883 |

Annual gas savings were determined by taking the difference in the annual natural gas consumption of a conventional system and the annual natural gas consumption of the efficient technology as in equation (1) below.

$$\Delta GasUse = \left(\frac{AnnualHeatLoss_{Conv}}{Eff_{Conv}} - \frac{AnnualHeatLoss_{EE}}{Eff_{EE}} \right) \times \frac{1}{35,300} \quad (1)$$

¹ Assessment of Average Infrared Heater Savings, Agviro, December 1, 2004

Where:

AnnualHeatLoss = Annual heat loss of conventional heater and EE infrared heater (as defined by subscript).

Eff = The combustion efficiency of the heater (%).

35,300 = The energy value of natural gas (Btu/m³)

The annual heat loss is calculated by Agviro as the sum of unit heat losses in a variety of outdoor temperature bins each of which is multiplied by the number of hours in which the temperature, on average falls into a given bin².

An average rate of savings of 0.015 m³/Btu/hour was determined by taking a weighted average of the savings from both locations: 70% of Union Gas South (London) and 30% of Union Gas North (Sudbury) based on customer population distribution in Union Gas service territories. Navigant, in determining the average rate of savings from the information in the Agviro report has conservatively assumed that the Btu/h is the highest possible for a given range. For example, a single-stage infrared heater saves on average 920 m³ of natural gas per year (see table directly below) for heaters in the 0 – 75,000 Btu/h range – the weighted average between Union's two territories. Assuming that the average Btu/h within this range is in fact the highest possible value in this range (in this case 75,000 Btu/h) this results in savings of 0.0123 m³/Btu/hr/year as shown in the bottom half of the table directly below.

| Weighted Average | | | | |
|----------------------|--|---------------------------------------|--|--------------------------------------|
| Heater Range (Btu/h) | Single Stage (m ³ /year) | 2-Stage (m ³ /year) | High Intensity (m ³ /year) | Average (m ³ /year) |
| 0 – 63,750 | 920 | 1,545 | 920 | 1,128 |
| 64,600 – 127,500 | 1,833 | 3,091 | 1,833 | 2,252 |
| 128,350 - 250,000 | 3,679 | 6,180 | 3,679 | 4,513 |
| Heater Range (Btu/h) | Single Stage (m ³ /Btu/hr/year) | 2-Stage (m ³ /Btu/hr/year) | High Intensity (m ³ /Btu/hr/year) | Average (m ³ /Btu/h/year) |
| 0 – 63,750 | 0.0123 | 0.0206 | 0.0123 | 0.015 |
| 64,600 – 127,500 | 0.0122 | 0.0206 | 0.0122 | 0.015 |
| 128,350 - 250,000 | 0.0123 | 0.0206 | 0.0123 | 0.015 |

As noted above, the average savings, 0.015 m³/Btu/h/year, should be applied to the input btu/h of the efficient, not the base, technology.

Baseline estimates of natural gas consumption³:

| Heater Range (Btu/h) | Annual Gas Use (m ³ /year) |
|----------------------|---------------------------------------|
| 0 – 63,750 | 6,131 |
| 64,600 – 127,500 | 12,262 |
| 128,350 - 250,000 | 24,525 |

² Ibid.

³ Ibid.

Percentage of natural gas savings = Average Savings / Baseline Gas Consumption = 18.4%

Annual Electricity Savings

16 - 873 kWh

Both infrared heaters and conventional draft-hood unit heaters require an electrically powered circulating fan. Infrared heaters typically use a fan of a much lower horse-power than those used by a conventional draft-hood heater.

Navigant has estimated the base measure's fan load by converting the average fan horse-power of a representative sample of conventional draft-hood heaters⁴ into kilowatts. Fan loads for infrared heaters were obtained by Navigant by contacting several manufacturers by and requesting the horse-power of the fan/blower on the most popular units in a given btu/hr input range⁵.

As with the natural gas savings shown above, the electricity savings correspond to the input range bin in which the input (btu/h) of the efficient technology falls, not the base technology.

| Heater Range (Btu/h) | Fan load (kW) | | Operating Hours per Year | | Electricity Savings |
|----------------------|--------------------------------|-----------------|--------------------------------|-----------------|---------------------|
| | Conventional draft-hood heater | Infrared Heater | Conventional draft-hood heater | Infrared Heater | |
| < 50,000 | 0.02 | 0.02 | 2509 | 2133 | 16 |
| 50,000 - 165,000 | 0.19 | 0.04 | 2509 | 2133 | 409 |
| > 165,000 | 0.43 | 0.09 | 2509 | 2133 | 873 |

Annual Water Savings

0 L

N/A

Other Input Assumptions

Effective Useful Life (EUL)

20 Years

Infrared heaters have an estimated service life of 20 years⁶.

Base & Incremental Conservation Measure Equipment and O&M Costs

\$ 0.0122 / Btu / h

An incremental cost of \$350 was used based on past input assumptions filed by Union⁷. Local retailers reported an average of \$0.009 / Btu/hr incremental cost. Navigant Consulting therefore is estimating an average of \$0.0122 / Btu/hour.

Measure Assumptions Used by Other Jurisdictions

| Source | Annual Natural Gas Savings | Effective Useful Life | Incremental Cost (\$) | Penetration/Market Share |
|--------|----------------------------|-----------------------|-----------------------|--------------------------|
|--------|----------------------------|-----------------------|-----------------------|--------------------------|

⁴ Horse-powers are drawn from Trane's specifications sheet for that company's line of conventional draft-hood heaters: <http://www.trane.com/Commercial/Uploads/Pdf/1024/uh-ts-1.pdf>

⁵ Navigant contacted Spaceray (www.spaceray.com), Schwank (www.schwankgroup.com) and Calcana (www.Calcana.com) and also consulted the online specifications published by Solaronics (http://solaronics.thomasnet.com/Asset/SSTG-SSTU-GB_200010_Spec_Sheet.pdf). The infrared heaters produced by Solaronics, Schwank and Spaceray all use the same horse-power fan, regardless of btu/hr input, whereas the Calcana heater fan horse-power varies by input range. Navigant has conservatively assumed that the fan load of the 0 – 75,000 btu/hr range will be the average of all those reported to Navigant, whereas the fan-load for the other two buckets will be those reported by Calcana.

⁶ "Prescriptive Incentives for Selected Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁷ EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

Low-Flow Showerhead (1.25 GPM, Residential, Distributed, per Household)

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|------------------|
| | | October 28, 2010 |

Efficient Equipment and Technologies Description

Low-flow Showerhead (1.25 GPM) – distributed to participants under Union Gas' ESK program. One showerhead distributed per ESK Kit.

Base Equipment and Technologies Description

Average existing stock (2.21 GPM)¹.

| Decision Type | Target Market(s) | End Use |
|---------------|------------------|---------------|
| New/Retrofit | Residential | Water heating |

Codes, Standards, and Regulations

Ontario Building Code (2006)² requires shower heads to have a maximum flow of 2.5 GPM (9.5 L/min)

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|----------------|---|--|
| | Natural Gas (m ³) | Electricity (kWh) | Water (L) | | |
| 1 | 44 | 0 | 13,885 | 3.69 | 0 |
| 2 | 44 | 0 | 13,885 | 0 | 0 |
| 3 | 44 | 0 | 13,885 | 0 | 0 |
| 4 | 44 | 0 | 13,885 | 0 | 0 |
| 5 | 44 | 0 | 13,885 | 0 | 0 |
| 6 | 44 | 0 | 13,885 | 0 | 0 |
| 7 | 44 | 0 | 13,885 | 0 | 0 |
| 8 | 44 | 0 | 13,885 | 0 | 0 |
| 9 | 44 | 0 | 13,885 | 0 | 0 |
| 10 | 44 | 0 | 13,885 | 0 | 0 |
| TOTALS | 440 | 0 | 138,850 | 3.69 | 0 |

Resource Savings Assumptions

| Annual Natural Gas Savings | 44 m ³ |
|--|-------------------|
| <p>Enbridge Gas commissioned a study by the SAS Institute (Canada)³ to estimate natural gas savings for low-flow showerheads in Enbridge territory. Data was collected August 31, 2007 until August 31, 2009 for both treatment and control groups. Low flow showerheads were installed in treatment households between August 13, 2008 and October 30, 2008. There were 54 households with low-flow showerheads and 124 households without low-flow showerheads.</p> | |

¹ Shower-heads distributed under Union Gas's ESK program are installed by homeowners rather than Union contractors. No observation is made of the base equipment's GPM. It is therefore assumed to be the full-on flow rate corresponding to the as-used flow from York Region monitoring study calculated using the equation cited below. Resource Management Strategies, Inc., Regional Municipality of York Water Efficiency Master Plan Update, April 2007. Cited by: Summit Blue, *Resource Savings Values in Selected Residential DSM Prescriptive Programs*, June 2008.

² Ontario Regulations 350/06, 2006 Building Code

³ Rothman, Lorne, SAS® PHASE II Analysis for Enbridge Gas Distribution Inc.: Estimating the Impact of Low-Flow Showerhead Installation; April 5, 2010

To calculate the gas savings, three different models were used to analyze the gas consumption data

- 1) a comparison made during the same time frame (post-installation) between a control set of households⁴ and households that had them installed
- 2) a Pre & Post installation analysis on the same households, and
- 3) a complex time trend model analysis that factored in many household characteristics over the whole Pre & Post time period.

All three analyses agreed well with each other.⁵

Three buckets for pre-existing showerheads were originally proposed. However, the lowest flow bucket (2.0 GPM or less) had too few observations and are rare in the population of households. The natural gas savings for the other two buckets are estimated to be as follows:

| Baseline Flow rate (GPM) | Energy Efficient Flow Rate (GPM) | Change in GPM | Annual Natural Gas Savings (m ³) | Annual Natural Gas Savings (m ³ per GPM) |
|--------------------------|----------------------------------|---------------|--|---|
| 2.25 ⁶ | 1.25 | 1.0 | 46 | 46 |
| 3 ⁷ | 1.25 | 1.75 | 88 | 50 |

For base flow/efficient flow showerhead types not explicitly tested in the SAS study, gas savings have been extrapolated in the following manner:

1. The results of the SAS institute study indicate that gas savings increase at an increasing rate as the difference between efficient and base GPM increases.
2. Fitting a polynomial function with no intercept (no change in GPM = no gas savings) delivers the following function (where $\Delta\text{GPM} = \text{Base GPM} - \text{Efficient GPM}$):

$$\begin{aligned}\text{Annual Gas Savings (m}^3\text{)} &= 40.29 \cdot \Delta\text{GPM} + 5.71 \cdot \Delta\text{GPM}^2 \\ &= 40.29 \cdot (2.21 - 1.25) + 5.71 \cdot (2.21 - 1.25)^2 \\ &= 44\end{aligned}$$

These savings values assume that 100% of household showering is reduced to 1.25 gpm. A survey determining the percentage of showering affected by the program should be used to adjust the year end program results.

| | |
|-----------------------------------|-----------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | 13,885 L |

Since the SAS report did not look at water savings, Navigant Consulting proposes the following method for calculating resulting water savings:

Assumptions and inputs:

- As-used flow rate with base equipment: 1.89 GPM⁸
- Average household size: 3.1 persons⁹
- Showers per capita per day: 0.75¹⁰
- Average showering time per capita per day with base equipment: 7.32 minutes
- Average showering time per capita per day with new technology: 7.61 minutes¹¹

⁴ where no low-flow showerheads were ever installed

⁵ Model 1 – a blended rate of 71.3 m3/yr (only models II and II provided bucketed savings estimates)

Model 2 – a blended rate of 67.4 m3/yr (45.4 m3/yr for 2 to 2.5 GPM bucket and 87.8 m3/yr for over 2.5 GPM), and

Model 3 – a blended rate of 77.2 m3/yr (46.4 m3/yr for 2 to 2.5 GPM bucket and 87.9 m3/yr for over 2.5 GPM).

⁶ Average of 2.0 GPM and 2.5 GPM

⁷ Assumed average low flow showerhead which is greater than 2.5 GPM.

⁸ As-used flow is calculated as a function of “full-on” or label flow: as-used flow = min{ 0.691+0.542*full-on flow, full-on flow}. Proctor, J. Gavelis, B. and Miller, B. *Savings and Showers: It's All in the Head*, (PGE) Home Energy Magazine, July/Aug 1994. Cited in Summit Blue (2008).

⁹ Summit Blue (2008).

¹⁰ Ibid, based on data from: Resource Management Strategies, Inc., Regional Municipality of York Water Efficiency Master Plan Update, April 2007

¹¹ Relationship modeled as: Average shower length = 8.17 – 0.448 * as-used GPM. From Energy Center of Wisconsin Analysis of data from Resource Management Strategies, Inc., *Regional Municipality of York Water Efficiency Master Plan Update*, April 2007. Cited in Summit Blue (2008)

Annual water savings calculated as follows:

$$Savings = Ppl * Sh * 365 * (T_{base} * Fl_{base} - T_{eff} * Fl_{eff})$$

Where:

Ppl = Number of people per household

Sh = Showers per capita per day

365 = Days per year

T_{base} = Showering time with base equipment (minutes)

T_{eff} = Showering time with efficient equipment (minutes)

Fl_{base} = As-used flow rate with base equipment (GPM)

Fl_{eff} = As-used flow rate with efficient equipment (GPM)

Savings = 3,668 gallons or 13,885 litres

Other Input Assumptions

| | |
|--|-----------------|
| Effective Useful Life (EUL) | 10 Years |
| Summit Blue (2008) suggests an EUL of 10 years based on a survey of five studies of showerheads in other jurisdictions (California – two studies, New England, Vermont, Arkansas). | |
| Incremental Costs | \$3.69 |
| As per utility program costs, bulk purchase of showerheads. | |
| Free-Ridership | 10% |
| Free Ridership rate recommended by Summit Blue Consulting. ¹² | |

¹² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

Low-Flow Showerhead (1.25 GPM, Residential, Installed, per Household)

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|------------------|
| | | October 28, 2010 |

Efficient Equipment and Technologies Description

One Low-flow Showerhead (1.25 GPM) – Installed by Union-designated contractors.

Base Equipment and Technologies Description

Average existing stock within one of three ranges.

Range mid-points used as point estimates:

- Scenario A – 2.25 GPM
- Scenario B – 3.0 GPM

When new showerheads are installed contractors use a bag-test to determine base equipment flow-rate.

| Decision Type | Target Market(s) | End Use |
|---------------|------------------------|---------------|
| Retrofit | Residential (Existing) | Water heating |

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------------------|---|--|
| | Natural Gas (m ³) | Electricity (kWh) | Water (L) | | |
| 1 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 3.69 | 0 |
| 2 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 3 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 4 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 5 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 6 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 7 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 8 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 9 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 10 | A:46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| TOTALS | A: 460 B: 880 | 0 | A: 142,940 B: 225,800 | 3.69 | 0 |

Resource Savings Assumptions

| Annual Natural Gas Savings | A: 46 m ³ B: 88 m ³ |
|----------------------------|--|
|----------------------------|--|

Enbridge Gas commissioned a study by the SAS Institute (Canada)¹³ to estimate natural gas savings for low-flow showerheads in Enbridge territory. Data was collected August 31, 2007 until August 31, 2009 for both treatment and control groups. Low flow showerheads were installed in treatment households between August 13, 2008 and October 30, 2008. There were 54 households with low-flow showerheads and 124

¹³ Rothman, Lorne, SAS® PHASE II Analysis for Enbridge Gas Distribution Inc.: Estimating the Impact of Low-Flow Showerhead Installation; April 5, 2010

households without low-flow showerheads.

To calculate the gas savings, three different models were used to analyze the gas consumption data

- 1) a comparison made during the same time frame (post-installation) between a control set of households¹⁴ and households that had them installed
- 2) a Pre & Post installation analysis on the same households, and
- 3) a complex time trend model analysis that factored in many household characteristics over the whole Pre & Post time period.

All three analyses agreed well with each other.¹⁵

Three buckets for pre-existing showerheads were originally proposed. However, the lowest flow bucket (2.0 GPM or less) had too few observations and are rare in the population of households. The natural gas savings for the other two buckets are estimated to be as follows:

| Baseline Flow rate (GPM) | Energy Efficient Flow Rate (GPM) | Change in GPM | Annual Natural Gas Savings (m ³) | Annual Natural Gas Savings (m ³ per GPM) |
|--------------------------|----------------------------------|---------------|--|---|
| 2.25 ¹⁶ | 1.25 | 1.0 | 46 | 46 |
| 3 ¹⁷ | 1.25 | 1.75 | 88 | 50 |

For base flow/efficient flow showerhead types not explicitly tested in the SAS study, gas savings have been extrapolated in the following manner:

1. The results of the SAS institute study indicate that gas savings increase at an increasing rate as the difference between efficient and base GPM increases.
2. Fitting a polynomial function with no intercept (no change in GPM = no gas savings) delivers the following function (where $\Delta\text{GPM} = \text{Base GPM} - \text{Efficient GPM}$):

$$\begin{aligned}
 \text{Annual Gas Savings (m}^3\text{)} &= 40.29 * \Delta\text{GPM} + 5.71 * \Delta\text{GPM}^2 \\
 &= 40.29 * (2.25 - 1.25) + 5.71 * (2.25 - 1.25)^2 \\
 &= 46
 \end{aligned}$$

$$\begin{aligned}
 \text{Annual Gas Savings (m}^3\text{)} &= 40.29 * \Delta\text{GPM} + 5.71 * \Delta\text{GPM}^2 \\
 &= 40.29 * (3.0 - 1.25) + 5.71 * (3.0 - 1.25)^2 \\
 &= 88
 \end{aligned}$$

These savings values assume that 100% of household showering is reduced to 1.25 gpm. A survey determining the percentage of showering affected by the program should be used to adjust the year end program results.

| | |
|-----------------------------------|------------------------------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | A: 14,294 L B: 22,580 L |

Since the SAS report did not look at water savings, Navigant Consulting proposes the following method for calculating resulting water savings:

¹⁴ where no low-flow showerheads were ever installed

¹⁵ Model 1 – a blended rate of 71.3 m3/yr (only models I and II provided bucketed savings estimates)

Model 2 – a blended rate of 67.4 m3/yr (45.4 m3/yr for 2 to 2.5 GPM bucket and 87.8 m3/yr for over 2.5 GPM), and Model 3 – a blended rate of 77.2 m3/yr (46.4 m3/yr for 2 to 2.5 GPM bucket and 87.9 m3/yr for over 2.5 GPM).

¹⁶ Average of 2.0 GPM and 2.5 GPM

¹⁷ Assumed average low flow showerhead which is greater than 2.5 GPM.

Assumptions and inputs:

- As-used flow rate with base equipment¹⁸:
Scenario **A**: 1.91 GPM
Scenario **B**: 2.32 GPM
- Average household size: 3.1 persons¹⁹
- Showers per capita per day: 0.75²⁰
- Average showering time per capita per day with base equipment:
Scenario **A**: 7.31 minutes
Scenario **B**: 7.13 minutes
- Average showering time per capita per day with new technology: 7.61 minutes²¹

Annual water savings calculated as follows:

$$Savings = Ppl * Sh * 365 * (T_{base} * Fl_{base} - T_{eff} * Fl_{eff})$$

Where:

Ppl = Number of people per household.

Sh = Showers per capita per day.

365 = Days per year.

T_{base} = Showering time with base equipment (minutes)

T_{eff} = Showering time with efficient equipment (minutes).

Fl_{base} = As-used flow rate with base equipment (GPM)

Fl_{eff} = As-used flow rate with efficient equipment (GPM)

Scenario **A**: Savings = 3,776 gallons or 14,294 litres

Scenario **B**: Savings = 5,965 gallons or 22,580 litres

Other Input Assumptions

| Effective Useful Life (EUL) | 10 Years |
|--|----------|
| Summit Blue (2008) suggests an EUL of 10 years based on a survey of five studies of showerheads in other jurisdictions (California – two studies, New England, Vermont, Arkansas). | |
| Incremental Costs | \$3.69 |
| As per utility program costs, bulk purchase of showerheads. | |
| Free-Ridership | 10% |
| Free Ridership rate recommended by Summit Blue Consulting. ²² | |

¹⁸ As-used flow is calculated as a function of “full-on” or label flow: as-used flow = min{ 0.691+0.542*full-on flow, full-on flow}. Proctor, J. Gavelis, B. and Miller, B. *Savings and Showers: It's All in the Head*, (PGE) Home Energy Magazine, July/Aug 1994. Cited in Summit Blue (2008)..

¹⁹ Summit Blue (2008).

²⁰ Ibid, based on data from: Resource Management Strategies, Inc., Regional Municipality of York Water Efficiency Master Plan Update, April 2007

²¹ Relationship modeled as: Average shower length = 8.17 – 0.448 * as-used GPM. From Energy Center of Wisconsin Analysis of data from Resource Management Strategies, Inc., *Regional Municipality of York Water Efficiency Master Plan Update*, April 2007. Cited in Summit Blue (2008)

²² “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008.

Low-Flow Showerhead (1.25 Gpm, Low Income, Installed, per Household)

| Revision # | Description/Comment | Date Revised |
|------------|---------------------|------------------|
| | | October 28, 2010 |

Efficient Equipment and Technologies Description

Low-flow Showerhead (1.25 Gpm) – One or more showerheads are installed by Union-designated contractors.

Base Equipment and Technologies Description

Average existing stock within one of three ranges.

Range mid-points used as point estimates:

- Scenario A – 2.25 GPM
- Scenario B – 3.0 GPM

When new showerheads are installed contractors use a bag-test to determine base equipment flow-rate.

| Decision Type | Target Market(s) | End Use |
|---------------|-----------------------------------|---------------|
| Retrofit | Low Income Residential (Existing) | Water heating |

Resource Savings Table

| Year (EUL=) | Electricity and Other Resource Savings | | | Equipment & O&M Costs of Conservation Measure (\$) | Equipment & O&M Costs of Base Measure (\$) |
|-----------------|--|----------------------|--------------------------|---|--|
| | Natural Gas (m ³) | Electricity (kWh) | Water (L) | | |
| 1 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 3.69 | 0 |
| 2 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 3 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 4 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 5 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 6 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 7 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 8 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 9 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| 10 | A: 46 B: 88 | 0 | A: 14,294 B: 22,580 | 0 | 0 |
| TOTALS | A: 460 B: 880 | 0 | A: 142,940 B: 225,800 | 3.69 | 0 |

Resource Savings Assumptions

Annual Natural Gas Savings

A: 46 m³
B: 88 m³

Enbridge Gas commissioned a study by the SAS Institute (Canada)²³ to estimate natural gas savings for low-flow showerheads in Enbridge territory. Data was collected August 31, 2007 until August 31, 2009 for both treatment and control groups. Low flow showerheads were installed in treatment households between

²³ Rothman, Lorne, SAS® PHASE II Analysis for Enbridge Gas Distribution Inc.: Estimating the Impact of Low-Flow Showerhead Installation; April 5, 2010

August 13, 2008 and October 30, 2008. There were 54 households with low-flow showerheads and 124 households without low-flow showerheads.

To calculate the gas savings, three different models were used to analyze the gas consumption data

- 1) a comparison made during the same time frame (post-installation) between a control set of households²⁴ and households that had them installed
- 2) a Pre & Post installation analysis on the same households, and
- 3) a complex time trend model analysis that factored in many household characteristics over the whole Pre & Post time period.

All three analyses agreed well with each other.²⁵

Three buckets for pre-existing showerheads were originally proposed. However, the lowest flow bucket (2.0 GPM or less) had too few observations and are rare in the population of households. The natural gas savings for the other two buckets are estimated to be as follows:

| Baseline Flow rate (GPM) | Energy Efficient Flow Rate (GPM) | Change in GPM | Annual Natural Gas Savings (m ³) | Annual Natural Gas Savings (m ³ per GPM) |
|--------------------------|----------------------------------|---------------|--|---|
| 2.25 ²⁶ | 1.25 | 1.0 | 46 | 46 |
| 3 ²⁷ | 1.25 | 1.75 | 88 | 50 |

For base flow/efficient flow showerhead types not explicitly tested in the SAS study, gas savings have been extrapolated in the following manner:

1. The results of the SAS institute study indicate that gas savings increase at an increasing rate as the difference between efficient and base GPM increases.
2. Fitting a polynomial function with no intercept (no change in GPM = no gas savings) delivers the following function (where $\Delta\text{GPM} = \text{Base GPM} - \text{Efficient GPM}$):

$$\begin{aligned}\text{Annual Gas Savings (m}^3\text{)} &= 40.29 * \Delta\text{GPM} + 5.71 * \Delta\text{GPM}^2 \\ &= 40.29 * (2.25 - 1.25) + 5.71 * (2.25 - 1.25)^2 \\ &= 46\end{aligned}$$

$$\begin{aligned}\text{Annual Gas Savings (m}^3\text{)} &= 40.29 * \Delta\text{GPM} + 5.71 * \Delta\text{GPM}^2 \\ &= 40.29 * (3.0 - 1.25) + 5.71 * (3.0 - 1.25)^2 \\ &= 88\end{aligned}$$

These savings values assume that 100% of household showering is reduced to 1.25 gpm. A survey determining the percentage of showering affected by the program should be used to adjust the year end program results.

| | |
|-----------------------------------|------------------------------------|
| Annual Electricity Savings | 0 kWh |
| N/A | |
| Annual Water Savings | A: 14,294 L B: 22,580 L |

Since the SAS report did not look at water savings, Navigant Consulting proposes the following method for calculating resulting water savings:

²⁴ where no low-flow showerheads were ever installed

²⁵ Model 1 – a blended rate of 71.3 m3/yr (only models II and II provided bucketed savings estimates)

Model 2 – a blended rate of 67.4 m3/yr (45.4 m3/yr for 2 to 2.5 GPM bucket and 87.8 m3/yr for over 2.5 GPM), and

Model 3 – a blended rate of 77.2 m3/yr (46.4 m3/yr for 2 to 2.5 GPM bucket and 87.9 m3/yr for over 2.5 GPM).

²⁶ Average of 2.0 GPM and 2.5 GPM

²⁷ Assumed average low flow showerhead which is greater than 2.5 GPM.

Assumptions and inputs:

- As-used flow rate with base equipment²⁸:
 Scenario **A**: 1.91 GPM
 Scenario **B**: 2.32 GPM
- Average household size: 3.1 persons²⁹
- Showers per capita per day: 0.75³⁰
- Average showering time per capita per day with base equipment:
 Scenario **A**: 7.31 minutes
 Scenario **B**: 7.13 minutes
- Average showering time per capita per day with new technology: 7.61 minutes³¹

Annual water savings calculated as follows:

$$Savings = Ppl * Sh * 365 * (Fl_{base} * T_{base} - T_{eff} * Fl_{eff})$$

Where:

Ppl = Number of people per household.

Sh = Showers per capita per day.

365 = Days per year.

T_{base} = Showering time with base equipment (minutes)

T_{eff} = Showering time with efficient equipment (minutes).

Fl_{base} = As-used flow rate with base equipment (GPM)

Fl_{eff} = As-used flow rate with efficient equipment (GPM)

Scenario **A**: Savings = 3,776 gallons or 14,294 litres

Scenario **B**: Savings = 5,965 gallons or 22,580 litres

Other Input Assumptions

| Effective Useful Life (EUL) | 10 Years |
|--|----------|
| Summit Blue (2008) suggests an EUL of 10 years based on a survey of five studies of showerheads in other jurisdictions (California – two studies, New England, Vermont, Arkansas). | |
| Incremental Costs | \$3.69 |
| As per utility program costs, bulk purchase of showerheads. | |
| Free-Ridership | 1% |
| Free Ridership rate recommended by Summit Blue Consulting. ³² | |

²⁸ As-used flow is calculated as a function of “full-on” or label flow: as-used flow = min{ 0.691+0.542*full-on flow, full-on flow}. Proctor, J. Gavelis, B. and Miller, B. *Savings and Showers: It's All in the Head*, (PGE) Home Energy Magazine, July/Aug 1994. Cited in Summit Blue (2008).

²⁹ Summit Blue (2008).

³⁰ Ibid, based on data from: Resource Management Strategies, Inc., Regional Municipality of York Water Efficiency Master Plan Update, April 2007

³¹ Relationship modeled as: Average shower length = 8.17 – 0.448 * as-used GPM. From Energy Center of Wisconsin Analysis of data from Resource Management Strategies, Inc., *Regional Municipality of York Water Efficiency Master Plan Update*, April 2007. Cited in Summit Blue (2008)

³² “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008.

| | (m3) | (Years) | | |
|--|-------|---------|-------|-----|
| Questar Gas ⁸ | 32.64 | 17 | 1,391 | N/A |
| Comments Specifications for infrared heaters are not provided in the report or the baseline assumptions. | | | | |

⁸ Questar Gas, DSM Market Characterization Report, by Nexant, August 9, 2006

Revised 2010 SSM Calculations and Updated Program Free Rider Rates

| | |
|--|-------------------------------------|
| | As per EB-2010-0055 |
| | Indicates changes from EB-2010-0055 |

| Target Market | | Equipment Details | | | | Annual Resource Savings | | | Other | | | |
|----------------------------------|--------------|--|---|------------------------------------|-------------------------------------|-------------------------|-------------------|-----------|-------|-----------------------|----------------|--|
| Sector | New/Existing | Efficient Equipment | Details of efficient equipment | Base Equipment | Details of base equipment | Natural Gas (m3) | Electricity (kWh) | Water (L) | EUL | Incremental Cost (\$) | Free Rider (%) | Reference |
| Residential Space Heating | | | | | | | | | | | | |
| Residential | Existing | Reflector Panels | | No reflector panels | | 143 | 0 | 0 | 18 | \$229 | 0% | |
| Residential | Existing | Programmable Thermostat | | Standard Thermostat | | 53 | 54 | 0 | 15 | \$25 | 43% | |
| Residential | New | Programmable Thermostat | | Standard Thermostat | | 53 | 54 | 0 | 15 | \$25 | 10% | Substantiation document provided in Appendix B. |
| Residential | New/Existing | High efficiency fireplace with intermittent ignition | EnerGuide efficiency rating 5% above base equipment efficiency* | Natural gas fireplace with a pilot | EnerGuide median efficiency rating* | 108 - 122* | (-) 31 | 0 | 20 | \$135 | 17% | Substantiation document provided in Appendix B. |
| Residential | Existing | Fireplace intermittent ignition control retrofit | | Natural gas fireplace with a pilot | | 104 | (-) 31 | 0 | 8 | \$150 | 1% | Substantiation document provided in Appendix B. |
| Residential Water Heating | | | | | | | | | | | | |
| Residential | New/Existing | Faucet Aerator | Bathroom, 1.5 GPM | Average existing stock | 2.2 GPM | 6 | 0 | 2,004 | 10 | \$0.55 | 33% | Costs as per utility program costs, bulk purchase. |
| Residential | New | Faucet Aerator | Kitchen, 1.5 GPM | Ontario Building Code 2006 | 2.2 GPM | 19 | 0 | 6,201 | 10 | \$1.39 | 33% | Base case adjusted to Ontario Building Code (2006). Costs as per utility program costs, bulk purchase. Substantiation document provided in Appendix B. |
| Residential | Existing | Faucet Aerator | Kitchen, 1.5 GPM | Average existing stock | 2.5 GPM | 23 | 0 | 7,797 | 10 | \$1.39 | 33% | Costs as per utility program costs, bulk purchase. |
| Residential | New | Faucet Aerator | Bathroom, 1.0 GPM | Ontario Building Code 2006 | 2.2 GPM | 10 | 0 | 3,435 | 10 | \$0.55 | 33% | Substantiation document provided in Appendix B. |
| Residential | Existing | Faucet Aerator | Bathroom, 1.0 GPM | Average existing stock | 2.2 GPM | 10 | 0 | 3,435 | 10 | \$0.55 | 33% | Substantiation document provided in Appendix B. |
| Residential | New | Faucet Aerator | Kitchen, 1.0 GPM | Ontario Building Code 2006 | 2.2 GPM | 32 | 0 | 10,631 | 10 | \$1.59 | 33% | Substantiation document provided in Appendix B. |
| Residential | Existing | Faucet Aerator | Kitchen, 1.0 GPM | Average existing stock | 2.5 GPM | 35 | 0 | 11,694 | 10 | \$1.59 | 33% | Substantiation document provided in Appendix B. |
| Residential | Existing | Low flow showerhead (Distributed) | 1.5 GPM | Average existing stock | 2.2 GPM | 46 | 0 | 6,334 | 10 | \$6 | 10% | |
| Residential | New/Existing | Low-flow showerhead (Distributed) | 1.25 GPM | Average existing stock | 2.2 GPM | 44 | 0 | 13,885 | 10 | \$3.69 | 10% | Substantiation document provided in Appendix B. |
| Residential | Existing | Low-flow showerhead (Contractor Installed) | 1.25 GPM | Average existing stock | 2.25 GPM | 46 | 0 | 14,294 | 10 | \$3.69 | 10% | Substantiation document provided in Appendix B. |
| Residential | Existing | Low-flow showerhead (Contractor Installed) | 1.25 GPM | Average existing stock | 3.0 GPM | 88 | 0 | 22,580 | 10 | \$3.69 | 10% | Substantiation document provided in Appendix B. |
| Residential | Existing | Pipe Wrap (R-4) | Insulation for DWH outlet pipe | Uninsulated DHW outlet pipes | R-1 | 18 | 0 | 0 | 10 | \$0.98 | 4% | Costs as per utility program costs, bulk purchase. |
| Residential | Existing | Solar Pool Heaters | | Natural gas pool heater | | 1,116 | 57 | 0 | 20 | \$1,450 | 10% | Substantiation document provided in Appendix B. |
| Low-Income Space Heating | | | | | | | | | | | | |
| Low-Income | Existing | Programmable Thermostat | | Standard manual thermostat | | 53 | 54 | 0 | 15 | \$26.95 | 1% | Costs as per utility program costs, bulk purchase. |
| Low Income Water Heating | | | | | | | | | | | | |
| Low-Income | Existing | Faucet Aerator | Bathroom, 1.5 GPM | Average existing stock | 2.2 GPM | 6 | 0 | 2,004 | 10 | \$0.55 | 1% | Costs as per utility program costs, bulk purchase. |
| Low-Income | Existing | Faucet Aerator | Kitchen, 1.5 GPM | Average existing stock | 2.5 GPM | 23 | 0 | 7,797 | 10 | \$1.39 | 1% | Costs as per utility program costs, bulk purchase. |
| Low-Income | Existing | Faucet Aerator | Bathroom, 1.0 GPM | Average existing stock | 2.2 GPM | 10 | 0 | 3,435 | 10 | \$0.55 | 1% | Costs as per utility program costs, bulk purchase. |
| Low-Income | Existing | Faucet Aerator | Kitchen, 1.0 GPM | Average existing stock | 2.5 GPM | 35 | 0 | 11,694 | 10 | \$1.59 | 1% | Costs as per utility program costs, bulk purchase. |
| Low-Income | Existing | Low-flow showerhead (Distributed) | 1.5 GPM | Average existing stock | 2.2 GPM | 46 | 0 | 6,334 | 10 | \$6 | 1% | |
| Low-Income | Existing | Low-flow showerhead (Distributed) | 1.25 GPM | Average existing stock | 2.2 GPM | 63 | 0 | 10,570 | 10 | \$3.69 | 1% | Costs as per utility program costs, bulk purchase. |
| Low-Income | Existing | Low-flow showerhead (Contractor installed) | 1.25 GPM | Average existing stock | 2.5 GPM | 46 | 0 | 14,294 | 10 | \$3.69 | 1% | Substantiation document provided in Appendix B. |
| Low-Income | Existing | Low-flow showerhead (Contractor installed) | 1.25 GPM | Average existing stock | 3.0 GPM | 88 | 0 | 22,580 | 10 | \$3.69 | 1% | Substantiation document provided in Appendix B. |
| Low-Income | Existing | Pipe insulation for DHW outlet pipe | R-4 insulation | Uninsulated DHW outlet pipes (R-1) | R-1 | 18 | 0 | 0 | 10 | \$0.98 | 1% | Costs as per utility program costs, bulk purchase. |
| Commercial Cooking | | | | | | | | | | | | |
| Commercial | New/Existing | Energy Star Fryer | 50% cooking efficiency | Standard fryer | 35% cooking efficiency | 913 | 0 | 0 | 12 | \$2,648 | 30% | |
| Commercial Space Heating | | | | | | | | | | | | |
| Commercial | Existing | Air Curtains | Single door | Non-air curtain doors | | 667 | 172 | 0 | 15 | \$1,650 | 5% | |
| Commercial | Existing | Air Curtains | Double door | Non-air curtain doors | | 1,529 | 1,023 | 0 | 15 | \$2,500 | 5% | |
| Commercial | Existing | Condensing Boilers | 88% seasonal efficiency (est.) | Non-condensing boiler | 76% estimated seasonal efficiency | 0.0104 / Btu/hr | 0 | 0 | 25 | \$12/Kbtu/hr | 5% | |
| Commercial | New/Existing | Demand Control Kitchen Ventilation | 0 - 4,999 CFM | Kitchen ventilation without DCKV | | 4,801 | 13,521 | 0 | 15 | \$10,000 | 5% | |

| | |
|--|-------------------------------------|
| | As per EB-2010-0055 |
| | Indicates changes from EB-2010-0055 |

| Target Market | | Equipment Details | | | | Annual Resource Savings | | | Other | | | |
|-----------------------------------|--------------|---|---|--|---|-------------------------|----------------------------|--------------------|-------|-----------------------|----------------|--|
| Sector | New/Existing | Efficient Equipment | Details of efficient equipment | Base Equipment | Details of base equipment | Natural Gas (m3) | Electricity (kWh) | Water (L) | EUL | Incremental Cost (\$) | Free Rider (%) | Reference |
| Commercial | New/Existing | Demand Control Kitchen Ventilation | 5,000 - 9,999 CFM | Kitchen ventilation without DCKV | | 11,486 | 30,901 | 0 | 15 | \$15,000 | 5% | |
| Commercial | New/Existing | Demand Control Kitchen Ventilation | 10,000 - 15,000 CFM | Kitchen ventilation without DCKV | | 18,924 | 49,102 | 0 | 15 | \$20,000 | 5% | |
| Commercial | New/Existing | Destratification Fans | | No destratification fans | | 0.5/ft ² | (-)0.0034 /ft ² | 0 | 15 | \$7,021 | 10% | |
| Commercial | Existing | Energy Recovery Ventilator | Ventilation with ERV | Ventilation without ERV | | 2.17 - 6.12/CFM** | 0 | 0 | 14 | \$3.18/CFM | 5% | Substantiation document provided in Appendix B. |
| Commercial | New | Energy Recovery Ventilator | Ventilation with ERV | Ventilation without ERV | | 2.05 - 5.77/CFM** | 0 | 0 | 14 | \$3.18/CFM | 5% | Substantiation document provided in Appendix B. |
| Commercial | Existing | Heat Recovery Ventilation | Ventilation with HRV | Ventilation without HRV | | 1.67 - 4.70/CFM** | 0 | 0 | 14 | \$3.61/CFM | 5% | Substantiation document provided in Appendix B. |
| Commercial | New | Heat Recovery Ventilation | Ventilation with HRV | Ventilation without HRV | | 1.52 - 4.28/CFM** | 0 | 0 | 14 | \$3.61/CFM | 5% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Infrared Heaters | 0 - 49,999 BTU/hr | Regular Unit Heater | | 0.015 /Btu/hr | 16 | 0 | 20 | \$0.0122/Btu/hr | 33% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Infrared Heaters | 50,000 - 164,999 BTU/hr | Regular Unit Heater | | 0.015 /Btu/hr | 409 | 0 | 20 | \$0.0122/Btu/hr | 33% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Infrared Heaters | 165,000 - 300,000 BTU/hr | Regular Unit Heater | | 0.015 /Btu/hr | 873 | 0 | 20 | \$0.0122/Btu/hr | 33% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Rooftop Unit | Two-stage rooftop unit | Single stage rooftop unit | | 255 | 0 | 0 | 15 | \$375 | 5% | |
| Commercial | Existing | Programmable Thermostat | | Standard thermostat | | 82 - 538** | 63 - 266** | 0 | 15 | \$40 | 20% | Costs as per utility program costs, bulk purchase. |
| Commercial | Existing | Prescriptive Schools - Elementary | hydronic boiler with 83%+ efficiency | hydronic boiler with 80%-82% efficiency | | 10,830 | 0 | 0 | 25 | \$8,646 | 27% | |
| Commercial | Existing | Prescriptive Schools - Secondary | hydronic boiler with 83%+ efficiency | hydronic boiler with 80%-82% efficiency | | 43,859 | 0 | 0 | 25 | \$14,470 | 27% | |
| Commercial | New/Existing | Condensing Unit Heater | | % Sales Weighted Average model | Equivalent in efficiency to a power vented or separated combustion unit heater (78% Annually Efficient) | 0.00631 /Btu/hr | (-)0.00186 /Btu/hr | 0 | 18 | \$0.0129 /Btu/hr | 0% | Substantiation document provided in Appendix B. |
| Commercial Water Heating | | | | | | | | | | | | |
| Commercial | New/Existing | Condensing Gas Water Heater (100gal/day) | 95% thermal efficiency | Conventional water heater | 80% efficiency, 91 gal. tank. | 332 | 0 | 0 | 13 | \$2,230 | 5% | |
| Commercial | New/Existing | Condensing Gas Water Heater (500gal/day) | 95% thermal efficiency | Conventional water heater | 80% efficiency, 91 gal. tank. | 873 | 0 | 0 | 13 | \$2,230 | 5% | |
| Commercial | New/Existing | Condensing Gas Water Heater (1,000gal/day) | 95% thermal efficiency | Conventional water heater | 80% efficiency, 91 gal. tank. | 1,551 | 0 | 0 | 13 | \$2,230 | 5% | |
| Commercial | Existing | Pre-Rinse Spray Nozzle | 1.24 GPM | Standard pre-rinse spray nozzle | 3.0 GPM | 190 - 886** | 0 | 36,484 - 170,326** | 5 | \$60 | 12.4% | |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Full Service) | 0.64 GPM | Pre-rinse spray nozzle | 1.6 GPM | 457 | 0 | 97,292 | 5 | \$150 | 0% | Substantiation document provided in Appendix B. |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Limited) | 0.64 GPM | Pre-rinse spray nozzle | 1.6 GPM | 90 | 0 | 19,197 | 5 | \$150 | 0% | Substantiation document provided in Appendix B. |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Other) | 0.64 GPM | Pre-rinse spray nozzle | 1.6 GPM | 109 | 0 | 23,166 | 5 | \$150 | 0% | Substantiation document provided in Appendix B. |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Full Service) | 0.64 GPM | Standard pre-rinse spray nozzle | 3.0 GPM | 1,286 | 0 | 252,000 | 5 | \$150 | 0% | Costs as per utility program costs, bulk purchase. |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Limited) | 0.64 GPM | Standard pre-rinse spray nozzle | 3.0 GPM | 339 | 0 | 66,400 | 5 | \$150 | 0% | Costs as per utility program costs, bulk purchase. |
| Commercial | Existing | Pre-Rinse Spray Nozzle (Other) | 0.64 GPM | Standard pre-rinse spray nozzle | 3.0 GPM | 318 | 0 | 62,200 | 5 | \$150 | 0% | Costs as per utility program costs, bulk purchase. |
| Commercial | New/Existing | Energy Star Dishwasher | Undercounter - High Temperature | Non-Energy Star Dishwasher | | 801 | 3,754 | 112,795 | 10 | (-) \$13 | 40% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Energy Star Dishwasher | Undercounter - Low Temperature | Non-Energy Star Dishwasher | | 326 | 559 | 45,891 | 10 | (-) \$13 | 40% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Energy Star Dishwasher | Stationary Rack, (Door type, or Single rack) - High Temperature | Non-Energy Star Dishwasher | | 619 | 3,553 | 87,119 | 15 | (-) \$350 | 20% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Energy Star Dishwasher | Stationary Rack, (Door type, or Single rack) - Low Temperature | Non-Energy Star Dishwasher | | 841 | 855 | 118,369 | 15 | (-) \$350 | 20% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Energy Star Dishwasher | Rack Conveyor, Single (Tank) - High Temperature | Non-Energy Star Dishwasher | | 2,203 | 9,811 | 310,271 | 20 | \$2,375 | 27% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Energy Star Dishwasher | Rack Conveyor, Multi (Tank) - High Temperature | Non-Energy Star Dishwasher | | 3,708 | 15,822 | 522,192 | 20 | \$288 | 27% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Commercial Laundry Washing Equipment with Ozone | Washer extractor - 60 lbs | Commercial Laundry Washing Equipment without Ozone | | 0.0328 /lbs/yr | 0.00219 /lbs/yr | 2.01 /lbs/yr | 15 | \$10,970 | 8% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Commercial Laundry Washing Equipment with Ozone | Washer extractor - 500 lbs | Commercial Laundry Washing Equipment without Ozone | | 0.0328 /lbs/yr | 0.00219 /lbs/yr | 2.01 L/lbs/yr | 15 | \$30,270 | 8% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Commercial Laundry Washing Equipment with Ozone | Tunnel Washer - 120 lbs | Commercial Laundry Washing Equipment without Ozone | | 0.0240 /lbs/yr | 0.00152 /lbs/yr | 1.22 /lbs/yr | 15 | \$49,667 | 8% | Substantiation document provided in Appendix B. |
| Commercial | New/Existing | Commercial Laundry Washing Equipment with Ozone | Tunnel Washer - 500 lbs | Commercial Laundry Washing Equipment without Ozone | | 0.0240 /lbs/yr | 0.00152 /lbs/yr | 1.22 /lbs/yr | 15 | \$160,065 | 8% | Substantiation document provided in Appendix B. |
| Multi-Family Water Heating | | | | | | | | | | | | |
| Multi-Family | New/Existing | CBE Tier 2 Front-Loading Clothes Washer | MEF=2.20, WF=5.1 | Conventional top-loading, vertical axis clothes washer | MEF=1.26, WF=9.5 | 117 | 396 | 58,121 | 11 | \$600 | 10% | |

| | |
|--|-------------------------------------|
| | As per EB-2010-0055 |
| | Indicates changes from EB-2010-0055 |

| Target Market | | Equipment Details | | | | Annual Resource Savings | | | Other | | | |
|---|--------------|--|--------------------------------|--|---------------------------|-------------------------|-------------------|-----------|-------|-----------------------|----------------|--|
| Sector | New/Existing | Efficient Equipment | Details of efficient equipment | Base Equipment | Details of base equipment | Natural Gas (m3) | Electricity (kWh) | Water (L) | EUL | Incremental Cost (\$) | Free Rider (%) | Reference |
| Multi-Family | New/Existing | Energy Star Front-Loading Clothes Washer | MEF=1.72, WF=8.0 | Conventional top loading vertical axis washers | MEF = 1.26, WF=9.5 | 76 | 201 | 19,814 | 11 | \$150 | 48% | Substantiation document provided in Appendix B. |
| Multi-Family | New | Faucet Aerator | Bathroom, 1.5 GPM | Ontario Building Code 2006 | 2.2 GPM | 4 | 0 | 1,382 | 10 | \$0.55 | 10% | Substantiation document provided in Appendix B. |
| Multi-Family | Existing | Faucet Aerator | Bathroom, 1.5 GPM | Average existing stock | 2.2 GPM | 4 | 0 | 1,382 | 10 | \$0.55 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | New | Faucet Aerator | Kitchen 1.5 GPM | Ontario Building Code 2006 | 2.2 GPM | 13 | 0 | 4,280 | 10 | \$1.39 | 10% | Substantiation document provided in Appendix B. |
| Multi-Family | Existing | Faucet Aerator | Kitchen, 1.5 GPM | Average existing stock | 2.5 GPM | 16 | 0 | 5,377 | 10 | \$1.39 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | New | Faucet Aerator | Bathroom, 1.0 GPM | Ontario Building Code 2006 | 2.2 GPM | 7 | 0 | 2,371 | 10 | \$0.55 | 10% | Substantiation document provided in Appendix B. |
| Multi-Family | Existing | Faucet Aerator | Bathroom, 1.0 GPM | Average existing stock | 2.2 GPM | 7 | 0 | 2,371 | 10 | \$0.55 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | New | Faucet Aerator | Kitchen, 1.0 GPM | Ontario Building Code 2006 | 2.2 GPM | 22 | | 7,337 | 10 | \$1.59 | 10% | Substantiation document provided in Appendix B. |
| Multi-Family | Existing | Faucet Aerator | Kitchen, 1.0 GPM | Average existing stock | 2.5 GPM | 24 | 0 | 8,072 | 10 | \$1.59 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | New | Low-flow showerhead (Distributed) | 1.5 GPM | | 2.2 GPM | 33 | 0 | 5,228 | 10 | \$6 | 10% | Substantiation document provided in Appendix B. |
| Multi-Family | Existing | Low-flow showerhead (Distributed) | 1.5 GPM | Average existing stock | 2.2 GPM | 33 | 0 | 5,228 | 10 | \$6 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | New | Low-flow showerhead (Distributed) | 1.25 GPM | Average existing stock | 2.2 GPM | 45 | 0 | 8824 | 10 | \$3.69 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | Existing | Low-flow showerhead (Distributed) | 1.25 GPM | Average existing stock | 2.2 GPM | 45 | 0 | 8824 | 10 | \$3.69 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | Existing | Low-flow showerhead (Contractor Installed) | 1.25 GPM | Average stock | 2.25 GPM | 48 | 0 | 9,088 | 10 | \$3.69 | 10% | Costs as per utility program costs, bulk purchase. |
| Multi-Family | Existing | Low-flow showerhead (Contractor Installed) | 1.25 GPM | Average stock | 3.0 GPM | 84 | 0 | 14,333 | 10 | \$3.69 | 10% | Costs as per utility program costs, bulk purchase. |
| * Efficiency ratings and natural gas savings will vary by fireplace type. Please see substantiation sheet for type specific efficiency ratings and savings. | | | | | | | | | | | | |
| ** Savings will vary for different segments. Please see substantiation sheet for segment specific savings. | | | | | | | | | | | | |

| Union Gas Custom Projects | | |
|-----------------------------|----------------|----------------------|
| Sector | Free Rider (%) | Measure Life (Years) |
| Agriculture | 54% | |
| Industrial | 54% | |
| Commercial | 54% | |
| Multi-Residential | 54% | |
| New Construction | 54% | |
| Low-Income - Weatherization | 0% | 23 |