

DISCLAIMER

TERMS OF USE: This document is being provided by Hydro One Networks Inc. ("Hydro One") to the party to whom it is being provided ("the Requestor") because the Requestor asked Hydro One to do so. The Requestor's acceptance of this document is the Requestor's acknowledgment and agreement that: (a) Hydro One makes no representations or warranties (express, implied, statutory or otherwise) as to this document or its contents, including, without limitation, the accuracy or completeness of the information therein; (b) the Requestor's employees, directors and agents (the "Representatives") shall be responsible for their respective use of the document and any conclusions derived from its contents; (c) Hydro One will not be liable for any damages resulting from or in any way related to the reliance on, acceptance or use of the document or its contents by the Requestor or its Representatives; and (d) neither the Requestor nor its Representatives will provide this document or any of its contents to any third party.

All costing information contained in this document are preliminary and were prepared for option assessment purposes only.

Number / Duration of Circuit Outages for East-West Tie

From 2002 to 2011

Forced Sustained Outages:

Year	W21M	W22M	M23L	M24L
2011	1	1	1	0
2010	2	1	0	4
2009	2	2	1	9
2008	1	0	1	1
2007	2	3	1	2
2006	2	0	2	0
2005	1	1	3	1
2004	4	4	5	5
2003	1	1	0	0
2002	4	2	3	3
Sum	20	15	17	25
Duration (hr)	164	65	513	1040
Ave. Dur (hr/outage)	8.2	4.4	30.2	41.6

Ice storm outaged M23L/M24L for 16 days

Forced Momentary Outages:

Year	W21M	W22M	M23L	M24L
2011	0	0	5	0
2010	3	3	2	10
2009	3	0	1	5
2008	1	1	2	4
2007	1	2	2	4
2006	4	2	2	4
2005	1	1	3	3
2004	3	2	1	1
2003	3	2	1	1
2002	2	2	1	2
Sum	21	15	20	34

Planned Outages:

Year	W21M	W22M	M23L	M24L
2011	0	0	2	1
2010	0	0	2	3
2009	1	2	25	7
2008	2	2	2	3
2007	2	1	1	2
2006	4	1	0	0
2005	0	3	2	0
2004	1	2	2	2
2003	0	0	2	0
2002	0	0	3	4
Sum	10	11	41	22
Duration (hr)	457	436	1123	865
Ave. Dur (hr/outage)	45.7	39.6	27.4	39.3