Enersource Hydro Mississauga Inc. EB-2012-0033 Filed: September 12, 2012 Response to Undertaking J3.4 Page 1 of 1

## **Undertaking No. J3.4**

To calculate the correlation between population and the total system load, to see if it is negative or positive, p.129.

## Response:

The total system load and population have a positive correlation of 68.9%.

It's important to note that since 2004, Enersource's forecast modelling has produced energy consumption forecasts within 1.7% to weather-corrected energy purchases.