

Hydro One Networks Inc.

8th Floor, South Tower
483 Bay Street
Toronto, Ontario M5G 2P5
www.HydroOne.com

Tel: (416) 345-5707
Fax: (416) 345-5866
Andrew.skalski@HydroOne.com

Andrew Skalski

Director – Major Projects and Partnerships
Regulatory Affairs



BY COURIER

January 23, 2013

Ms. Kirsten Walli
Secretary
Ontario Energy Board
Suite 2601, 2300 Yonge Street
P.O. Box 2319
Toronto, Ontario
M4P 1E4

Dear Ms. Walli:

**EB-2012-0047 – Horizon Utilities Corporation – Application for Service Area Amendment –
Hydro One Networks Interrogatory Question**

I am attaching two (2) copies of Hydro One Networks (“Hydro One”) interrogatory question of Hamilton-Wentworth Catholic School Board evidence which is being directed to the School Energy Coalition.

A copy of this cover letter and the attached interrogatory question has been filed in text-searchable electronic form through the Ontario Energy Board's Regulatory Electronic Submission System and the confirmation slip is also enclosed.

Sincerely,

ORIGINAL SIGNED BY ANDREW SKALSKI

Andrew Skalski

Attach.

c. EB-2012-0047 Intervenors (electronic only)

**Horizon Utilities Corporation (“HUC”)
Service Area Amendment Application EB-2012-0047**

**Hydro One Networks Inc. Interrogatories to Hamilton-Wentworth Catholic
School Board**

1. Hydro One, in developing its Offer to Connect in relation to Bishop Ryan School, which is included in Hydro One’s evidence at Appendix C, relied upon the attached Load forecast provided for the school by the Hamilton-Wentworth Catholic School Board. This forecast is materially different from the load forecast included by Horizon in its response to Hydro One’s Interrogatory #8, Attachment 1, Page 3. Please indicate which load forecast is correct.

NEW CUSTOMER CONNECTION INFORMATION

SECTION 1 - Customer Section – please complete the following providing all information requested in yellow highlight												
Customer Name: Bishop Ryan Catholic S S	Customer Phone#: 905 525-2930	Civic Address: 1824 Rymal Road East										
Township: Hamilton, Ontario	Concession:	Lot:										
Contractor/Consultant: NRG Consultants	Contractor/Consultant Phone#: 905 304-0294	Fax#: 905 304-0275										
Desired Connection Date: April, 2013	Peak Load - Existing: N/A kW Proposed: 1000 kW											
Requested Service Voltage Rating: 347/600	Service Ampere Rating - Existing: N/A Amps Proposed: 1500 Amps											
Loading Profile												
Note: If load is greater then 50 kW Customer is to complete DEMAND SECTION only. If the load is less than 50 kW Customer is to complete ENERGY SECTION only.												
	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec
Demand Section												
Existing Service Demand (kW)	0	0	0	0	0	0	0	0	0	0	0	0
New Service Demand (kW)												
1 st year	0	0	0	300	300	300	400	400	800	900	1000	1100
2 nd year	1200	1200	1100	1100	1100	1000	900	800	1200	1100	1100	1100
3 rd year	1200	1200	1100	1100	1100	1000	900	800	1200	1100	1100	1100
4 th year	1200	1200	1100	1100	1100	1000	900	800	1300	1200	1200	1200
5 th year	1200	1200	1100	1100	1100	1000	900	800	1300	1200	1200	1200
Energy Section												
Existing Service Demand (kWh)	0	0	0	0	0	0	0	0	0	0	0	0
New Service Energy (kWh)												
1 st year												
2 nd year												
3 rd year												
4 th year												
5 th year												
Motor Information												
Type of Motor:						Rated Horse Power:						
Type of Operation:						Full Load Current in Amps:						
Starting Current Amps:						In Rush KVA:						
Frequency of Starts:						NEMA Std:						
Limitations may apply see Conditions of Service: Section 2.3.3, Electrical Disturbances "Customer Responsibilities"												
Welding Machines												
KVA Rating:						Details:						
Rated Welder Primary Voltage:						Maximum Primary Current in Amps:						
Power Factor:						Number of Welders Operated Simultaneously:						
Frequency of Operations of Each Machine (weld/min)						Duration of Welds for Each Machine:						