

AIRD & BERLIS LLP

Barristers and Solicitors

Scott Stoll
Direct: 416.865.4703
E-mail: sstoll@airdberlis.com

June 18, 2014

BY COURIER, EMAIL AND RESS

Mr. John Pickernell
Applications Administration
Ontario Energy Board
P.O. Box 2319, 27th Floor
2300 Yonge Street
Toronto, ON M4P 1E4

Dear Mr. Pickernell:

**Re: Rainy River Resources Ltd. ("RRR")
Application for Leave to Construct Transmission Facilities
Board File No.: EB-2014-0014**

Pursuant to your letter dated June 9, 2014, please find enclosed a copy of correspondence from Hydro One Networks Inc. dated June 17, 2014.

If there are any questions, please contact the undersigned.

Yours very truly,

AIRD & BERLIS LLP



Scott Stoll
SS/bm

cc: All parties

Encl.

18472180.1

Hydro One Networks Inc.

483 Bay Street, 6th Floor
Toronto, Ontario, M5G 2P5
www.HydroOne.com

Tel: (416) 345-5878

John Walewski, P.Eng.

Manager, Network Connections
Network Connections and Development



June 17, 2014

Mr. Darcy Cowan
Infrastructure Lead
New Gold Inc.,
Rainy River Project Office
Suite 201, 2275 Upper Middle Road
Oakville, Ontario, L6H 0C3

Dear Mr. Cowan:


Re: Rainy River Gold Project, CAA ID Number: 2013-502

Thank you for advising Hydro One, about change of secondary voltage at your Rainy River Gold Project from 27.6 kV to 13.8 kV. We have reviewed your change and determined that this change will have no material impact on your 230 kV connection to Hydro One transmission line K24F. Therefore, a revised CIA is not required.

Rainy River Gold project should complete the Transmission Connection agreement and request a Cover before in-service of the project as required by the Hydro One Customer Connections process.

If you have any questions or require further information, please contact me or Raj Ghai (416-345-5302).

Yours Truly,


John Walewski, P.Eng
Manager – Network Connections
E-mail: john.walewski@hydroone.com

Cc: Raj Ghai, John Blackburn