

**UNDERTAKING J4.4**

**Undertaking**

To provide Surplus Baseload Generation (SBG) for the Newly Regulated hydro facilities for 2011 and 2012 in Terawatt-hours.

**Response**

The estimated quantity of foregone production due to SBG conditions at OPG's newly regulated facilities is 0.2TWh in 2011 and 0.3TWh in 2012.