Filed: 2014-06-23 EB-2013-0321 J7.9 Page 1 of 1

| 1 | <u>UNDERTAKING J7.9</u> |
|----|---|
| 2 | |
| 3 | <u>Undertaking</u> |
| 4 | |
| 5 | TO CONFIRM WHETHER HYDRO-QUEBEC'S NUCLEAR FACILITY IS A BOILING- |
| 6 | WATER OR PRESSURIZED-WATER SYSTEM |
| 7 | |
| 8 | |
| 9 | <u>Response</u> |
| 10 | |
| 11 | Hydro Quebec's nuclear facility, Gentilly-2, is a Candu 6 series, pressurized heavy water |
| 12 | reactor. |
| 13 | |
| 14 | |
| 15 | |