

**Ontario Energy
Board**
P.O. Box 2319
27th Floor
2300 Yonge Street
Toronto ON M4P 1E4
Telephone: 416- 481-1967
Facsimile: 416- 440-7656
Toll free: 1-888-632-6273

**Commission de l'énergie
de l'Ontario**
C.P. 2319
27e étage
2300, rue Yonge
Toronto ON M4P 1E4
Téléphone; 416- 481-1967
Télécopieur: 416- 440-7656
Numéro sans frais: 1-888-632-6273



BY EMAIL

November 4, 2014

Kirsten Walli
Board Secretary
Ontario Energy Board
2300 Yonge Street, 27th Floor
Toronto ON M4P 1E4

Dear Ms. Walli:

**Re: Board Staff Interrogatories
London Hydro Inc.
Application for an Exemption from Section 5.1.3 of the
Distribution System Code EB-2014-0292**

In accordance with the Notice of Application and Written Hearing, please find enclosed Board Staff Interrogatories filed in the above mentioned proceeding.

Yours truly,

Original signed by

Irina Kuznetsova
Case Manager

Attachment

Board Staff Interrogatories

**Application for Licence Amendment for
Temporary Exemption from Section 5.1.3 a) of
the Distribution System Code (the “DSC”)**

London Hydro Inc. (“London Hydro”)

EB-2014-0292

November 4, 2014

1. Section 5.1.3 a) of the DSC requires distributors, starting August 21, 2014, to install a MIST (interval) meter on any new installation that is forecast by the distributor to have a monthly average peak demand during a calendar year of over 50 kW. London Hydro applies for a temporary exemption from this DSC requirement with respect to the customers with monthly average peak demand greater than 50 kW but less than 200 kW.
 - a. Please provide historical annual number of customers with monthly average peak demand greater than 50 kW but less than 200 kW connected to the London Hydro's distribution system in the past five years.
 - b. Please identify a number of connection requests received by London Hydro from this group of customers after August 21, 2014.
 - c. Please provide all costs incurred for the interim solution after August 21, 2014.
2. In its application, London Hydro provided an estimated cost of \$100,000 that will be incurred if London Hydro required to comply with section 5.1.3 a) of the DSC starting August 21, 2014.
 - a. Please provide the incremental cost of meeting requirement of section 5.1.3 a) of the DSC.
3. Please identify when London Hydro will be able to replace the legacy pulse meters installed between August 21, 2014 and December 31, 2015 with MIST (interval) meters and provide estimated replacement cost.