Ontario Energy Board P.O. Box 2319 27th Floor 2300 Yonge Street Toronto ON M4P 1E4 Telephone: 416-481-1967 Facsimile: 416-440-7656

Toll free: 1-888-632-6273

Commission de l'énergie de l'Ontario C.P. 2319 27e étage 2300, rue Yonge Toronto ON M4P 1E4 Téléphone: 416-481-1967 Télécopieur: 416-440-7656 Numéro sans frais: 1-888-632-6273



BY E-MAIL ONLY

January 30, 2015

Jesse Long wpd White Pines Wind Inc. 2233 Argentia Road Suite 102 Mississauga ON L5N 2X7

Dear Mr. Long:

Re: wpd White Pines Wind Incorporated ("wpd White Pines")
Application for Leave to Construct Transmission Facilities
Board File No. EB-2013-0339

The Board has determined that some additional information pertaining to the Customer Impact Assessment ("CIA"), as described below, is required in order to complete the record.

Page 1 of the System Impact Assessment ("SIA") Addendum dated July 21, 2014 lists five changes that were made to the original proposal on which the SIA Addendum was based. The December 1, 2014 letter from Hydro One Networks Inc. ("HONI") lists only four of the five changes on which their conclusion that there is no significant impact is based.

The change that is listed in the SIA Addendum but not the HONI letter is as follows:

Install a 10 MVAr @ 115 kV inductor at LV side of 230/69 kV transformer.

Due to the apparent discrepancy, the Board requires the following information:

- (1) Proof from wpd White Pines and/or the IESO that the information regarding the above-noted inductor was provided to HONI before HONI's last decision point on the CIA.
- (2) If the information in (1) was not provided to HONI before HONI's last decision point on the CIA, please provide an official response from HONI, confirming that a revised CIA will or will not be required, based on the latest information including the above-noted inductor.

Please provide the requested information by February 9, 2015.

Yours truly,

Original Signed By

Kirsten Walli Board Secretary

cc: Patrick G. Duffy, Stikeman Elliott LLP Ingrid A. Minott, Stikeman Elliott LLP All intervenors in EB-2013-0339