

700 University Avenue, Toronto, ON M5G 1X6

**Tel:** 416-592-6846 **Fax:** 416-592-8519  
greg.towstego@opg.com

April 7, 2015

**VIA EMAIL**

Ms. Kirsten Walli  
Board Secretary  
Ontario Energy Board  
P.O. Box 2319  
2300 Yonge Street, 27<sup>th</sup> Floor  
Toronto, ON  
M4P 1E4

Dear Ms. Walli:

**Re: Ontario Power Generation ("OPG")  
Section 92 Application for Leave to Construct Transmission  
Line, New Post Creek Generating Station (EB-2014-0194)  
- Final System Impact Assessment and Customer Impact  
Assessment Addendums**

This is a follow-up to OPG's February 2, 2015 reply to a Board letter dated January 21, 2015, where the Board requested information to complete the record in OPG's application for an order or orders granting leave to construct a 115 kV transmission line for New Post Creek Generating Station. In the February 2, 2015 reply OPG indicated that the final System Impact Assessment (SIA) Addendum and final Customer Impact Assessment (CIA) Addendum would be provided when they become available.

These assessments have now been issued by the IESO (SIA) and Hydro One (CIA) and are attached.

The SIA addendum, dated February 10, 2015, concludes that the proposed project is expected to have no material adverse impact on the reliability of the integrated power system. The CIA addendum, dated March 31, 2015, indicates that the proposed project does not adversely impact existing Hydro One customers.

As indicated in the EB-2014-0194 Application, Ex. H1-1 and Ex. I1-1, OPG/CRP will satisfy the requirements, recommendations and any other conditions imposed by the IESO as described in the SIA, and any other conditions imposed by Hydro One as described in the CIA.

Please direct any comments or questions in this matter to the undersigned.

Yours truly,

*[Original Signed by]*

Greg Towstego

Attach

cc: Fred Cass, Aird & Berlis LLP  
Carlton Mathias, OPG  
Maia Chase, IESO