

June 23, 2015

Ontario Energy Board P.O Box 2319 2300 Yong Street, 27<sup>th</sup> Floor Toronto, Ontario M4P 1E4 **RECEIVED**JUN 2 4 2015

ONTARIO ENERGY BOARD

Dear: Board Secretary

RE: Markham District Energy Inc. Generation Licence# EG-2000-0420

We are requesting an amendment to our generation licence to have two additional generator units added to Schedule 1, which are described below.

• Two 2,500 kW generators (5 MW total) installed at the Bur Oak Energy Centre Plant, 3211 Bur Oak Avenue, Markham.

EB-2015-0209

These two generator units are primarily for emergency back-up power, but are able to synchronize with the distribution grid and back-feed power to the LDC for testing purposes and for demand response. Further details on the above are provided in the attached schedule.

We wish to have the proceeding disposed of without a hearing in reference to the test set out in section 21 (4)(b) of the Ontario Energy Board Act, 1988. No other person will be adversely affected in a material way by the outcome of the proceeding. The generators have Environmental Compliance Approval (ECA) from the Ministry of Environment and Climate Change (MOECC) and approval from the LDC (PowerStream) for their operation.

Regards,

Peter Ronson Vice President 905-513-2758 **Generation Facility** 

Licence#

EG-2000-0420

**Sch 1 Amendment** 

New generation facility

Bur Oak Energy Centre
3211 Bur Oak Avenue, Markham, Ontario
5.000 MW
Diesel
2
Markham District Energy Inc.
Markham District Energy Inc.
01-Jul-15
1.9M
N/A