

UNDERTAKING JT1.2

UNDERTAKING

Technical Conference TR, page 8

Enbridge to advise what percentage of low income multi-residential buildings in Enbridge service territory have the air duct system versus the water heating system.

RESPONSE

Most of the low income multi-residential buildings in the Company's franchise area were built before 1985 (also referred to as post-war or mid-century buildings). Buildings of this vintage predominantly use hydronic heating systems. Though the Company is not aware of any specific research on this matter, Enbridge estimates that approximately 90% of these buildings use hot water (hydronic) heating systems.

Witnesses: M. Lister
E. Lontoc