

1 UNDERTAKING NO. J3.3: TO ADVISE HOW THE REAR LOT REMEDIATION PROGRAM CMI
2 SAVINGS WERE VALUED.

3

4 **RESPONSE:**

5 CMI calculations and value conversion for a specific 2016 project is listed below:

6

7 Project ID 150039 Rear Lot Supply Remediation – Royal Orchard – East – Phase 2

8

9 Frequency of Failure (FAIL) is: 2 failures per year

10

- 11 • Estimated number of customers affected by 1 failure is: 157 customers + 100 customers
12 outside of the Rear Lot area. Total = 157 + 100 = 257 (assuming 255 residential and 2
13 commercial)
- 14 • Estimated number of customers affected by 2 failures is: 257 x 2 = 514 customers
- 15 • Peak load lost = 255x 3kW+ 2x 1000 kW= 2765kW
- 16 • Redundancy Lost in case of failure = 20 hours
- 17 • Frequency of interruption is: 2 failures per year
- 18 • Duration of interruption is: for 157 customers inside of Rear Lot area is 4 hours; for 100
19 customers outside of Rear Lot area is 1 hour. Weighted average is 2.8 hours per
20 customer per interruption.
- 21 • No of Customers (NCUS) affected per failure is: 255 residential + 2 commercial = 257
- 22 • CMI per 1 failure is: 257 x 2.8 hour x 60 min = 43,176 CMI
- 23 • CMI per 2 failures is: 43,176 x 2 = 86,352 CMI
- 24 • Customer Interruption Costs (frequency and Duration) at PowerStream for Mixed
25 Residential and Commercial Customers is valued at \$ 20/Kw and \$20/kWh

26

27 The total Duration is calculated as follows:

28 Duration = DUR+DURR*0.05 = 2.8+1 = 3.8 hours

29

30 DUR represents the duration of the outage that is experienced by customers, where DURR
31 represents the duration for which redundancy will be lost. Running without redundancy is clearly

1 not as significant as actual customer outage, but during that period of time it is possible that a
2 second failure will occur and then customers will experience lengthy outages. Computing the
3 likelihood of a secondary failure is complex and varies from situation to situation, so 5% has
4 been chosen as a reasonable average expectation. This 5% value has been used by
5 Copperleaf at other utilities.

6

7 The total Reliability Value is calculated as follows:

- 8 • Reliability Cost = CMI Cost*0.89 + (Frequency Cost + Duration Cost)*0.11
- 9 • CMI Cost (\$) = FAIL*Duration*60*NCUS*\$1/minute = 2*60*257*3.8*1= 117,192
- 10 • Frequency Cost (\$) = FAIL*PEAK*frequency cost per kW= 2x2765*20= 110,600
- 11 • Duration Cost (\$) = FAIL*PEAK*Duration*duration cost per kWh= 2*2765*3.8*20=420, 280
- 12 • Reliability Cost (\$) = 117,192*.89+ (110,600+420,280)*.11= 162697.68/1000=162,697.68
- 13 • Each value units is represented by 1000\$ and hence the total value is =162.70