EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Table of Contents Page 1 of 5 Delivered: February 24, 2015



# Chapter 5

## Consolidated

### **Distribution System Plan**

Delivered: February 24, 2015

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Table of Contents Page 2 of 5 Delivered: February 24, 2015

### **TABLE OF CONTENTS**

	Table of Contents	1 to 5
5.0	Introduction	1 to 6
	Structure of this DS Plan	
	Overview	
5.1.4	Planning in Consultation with Third Parties	1 to 2
	Regional Planning and Consultations	
	Renewable Energy Generator Investments	
5.2.1	Distribution System Plan Overview	1 to 5
	Key Elements of the Plan	
	Source of Cost Savings due to the Plan	
	Period Covered by the Plan	
	Data Used for Investment Decisions	
	Changes to the Plan since the Last Plan	
	Contingent Events included in the Plan	
	Third Party Reviews	
5.2.2	Coordinated Planning with Third Parties	1 to 14
	Overview	
	Planning Process	
	Municipal Energy Plans	

... 1 to 61

5.2.3	Performance Measurement for Continuous Improvement	1 to 19
	Performance Methodology and Metrics	
	Corporate Continuous Improvements	
	Asset Investment Planning Improvements	
	2013 and 2014 Extreme Weather Events	
	Methods and Measures used for Distribution System Planning Process Perf	ormance
	Summary of Performance and Performance Trends	
	Effects of Performance on the DS Plan	
5.3.1	Asset Management Process Overview	1 to 28
	PowerStream's Asset Management Planning Process	

- 5.3.2 <u>Overview of Assets Managed</u> PowerStream's Service Territory System Configuration Asset Inventory Asset Utilization Capital Investment Key Drivers
- 5.3.3 <u>Asset Lifecycle Optimization Policies and Procedures and Risk Management</u>...1 to 38 Asset Replacement and Refurbishment (Remediation) Programs & Policies Optimized, Prioritized Spending Procedures & Risk Management Maintenance Planning Criteria and Assumptions Impact of System Renewal on Routine O&M and Emergency/Reactive Repairs Impact of System Renewal on Reliability

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Table of Contents Page 4 of 5 Delivered: February 24, 2015

5.4.1	Capital Expenditure Plan Summary	1 to 11
	Capability of PowerStream to Connect New Load	
	Total Annual Capital Expenditures by Investment Category	
	Outputs of the Plan	
	Material Capital Expenditures	
	Regional Planning	
	Customer Engagement Activities	
	Five Year System Development	
	Special Activities	
5.4.2	Capital Expenditure Planning Process Overview	1 to 13
	Capital Expenditure Planning Objectives	
	Identification, Selection and Prioritization of Projects	
	Customer Engagement - General	
	Customer Engagement – DS Plan	
5.4.3	System Capability Assessment for Renewable Energy Generation	1 to 14
	Applications for Renewable Generators over 10kW	
	Number and Capacity (MW) of Renewable Connections Anticipated	
	PowerStream Capacity (MW) for Connection per Station	
	System Constraints	
	Customer Constraints	
5.4.4	Capital Expenditure Summary	1 to 14
	Explanatory Notes on Variances in Capital Expenditure Summary	

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Table of Contents Page 5 of 5 Delivered: February 24, 2015

#### 5.4.5 Justifying Capital Expenditures

... 1 to 36

Overall Plan Comparative Expenditures by Category Forecast Impact on System Operating & Maintenance Costs a) System Access

- b) System Renewal
- c) System Service
- d) General Plant

Material Investments

#### **APPENDICES**

- <u>Appendix A:</u> Project Investment Summaries Material Projects
- Appendix B: OPA Letters
- Appendix C: Distribution System Plan Review Primer Residential
- <u>Appendix D:</u> Distribution System Plan Review Primer General Service over 50
- <u>Appendix E</u>: PowerStream Work Book
- <u>Appendix F</u>: Customer Consultation Report

#### 1 5.0 INTRODUCTION

On March 28, 2013, the Ontario Energy Board ("OEB" or the "Board") issued Chapter 5 of the
Board's Filing Requirements for Electricity Transmission and Distribution Applications, entitled *Consolidated Distribution System Plan Filing Requirements (the "Chapter 5 Requirements").*The Chapter 5 Requirements provide a standard approach to a distributor's filing of asset
management and capital expenditure plan information in support of a rate application and its
Distribution System Plan.

8

9 PowerStream has compiled its consolidated Distribution System Plan (DS Plan) in accordance
10 with the filing requirements for Chapter 5 for Electricity Transmission and Distribution
11 applications.

12

#### 13 Structure of this DS Plan

In accordance with Section 5.2 of the Chapter 5 Filing Requirements, this DS Plan has been organized to provide the required information using the section headings indicated. For clarity, the relevant section of Chapter 5 will commence each section, and is provided in 10 point italics font.

18

Section 5.0 and 5.2 of the Chapter 5 Filing Requirements states the format andexpectations for structuring the DS Plan.

- 21
- 22 <u>5.0</u>

These filing requirements set out the information required by the Board under the renewed regulatory framework for electricity to assess distributor applications involving planned expenditures on distribution system and other infrastructure.<sup>1</sup> For the purposes of these filing requirements, a Distribution System Plan ("DS Plan") consolidates documentation of a distributor's asset management process and capital expenditure plan, where:

an Asset Management Process is the systematic approach a distributor uses to collect, tabulate
 and assess information on physical assets, current and future system operating conditions and
 the distributor's business and customer service goals and objectives to plan, prioritize and

- optimize expenditures on system-related modifications, renewal and operations and maintenance, and on general plant facilities, systems and apparatus; and
- a Capital Expenditure Plan sets out and robustly justifies according to the Board's standard
   requirements for evaluation a distributor's proposed expenditures on its distribution system and
   (non-system) general plant over a five-year planning period, including investment and asset related maintenance expenditures.
- 7

1 2

8 <u>5.2</u>

9 Distributors are encouraged to organize the required information using the section headings indicated. If a 10 distributor's application uses alternative section headings and/or arranges the information in a different 11 order, the distributor shall demonstrate that these requirements are met by providing a table that clearly 12 cross-references the headings/subheadings used in the application as filed to the section 13 headings/subheadings indicated below.

14

This DS plan has been formatted and organized to provide the information using the sectionheadings indicated in the filing requirements.

17

#### 18 Overview

19 The DS Plan reflects PowerStream's integrated approach to planning, prioritizing, managing 20 assets and includes regional planning, local stakeholder consultations, renewable generation 21 connections and smart grid considerations.

PowerStream has completed this DS Plan with a focus on customer preferences and
 operational effectiveness while achieving optimal value for capital spending.

24

25 Section 5.1.1 of the Chapter 5 Filing Requirements directs distributors to group each 26 investment project and activity for filing purposes into one of four investment categories:

- System Access;
- System Renewal;
- System Service; and
- 30 General Plant.
- 31

1 PowerStream has followed these four categories, specifically:

System Access: Investments that are modifications to PowerStream's system in which
 there exists an obligation to perform customer connections and comply with mandated
 service obligations.

5

6

• System Renewal: Investments that involve replacing or refurbishing system assets which extend the service life of the assets.

7 8

System Service: Investments that are modifications to PowerStream's distribution system
 to ensure that operational objectives are met and future customer requirements can be
 addressed.

12

•General Plant: Investments that are modifications, replacements or additions to
 PowerStream's assets where these assets are not part of the electrical distribution system
 (land, trucks, computers etc.).

The summary totals of investments within these four categories for the bridge year (2015) and
subsequent years (2016-2020) proposed in this DS Plan are provided below in Table 1.

18

	2015	2016	2017	2018	2019	2020	
	Proposed	Proposed	Proposed	Proposed	Proposed	Proposed	Total
General Plant	\$24,544,709	\$17,631,419	\$19,557,978	\$13,966,910	\$16,840,554	\$18,205,522	\$110,747,091
System Access	\$24,145,118	\$28,232,154	\$28,469,723	\$29,560,667	\$28,726,052	\$31,866,709	\$171,000,423
System Renewal	\$42,388,194	\$48,714,625	\$51,500,169	\$52,051,933	\$52,970,854	\$52,405,780	\$300,031,555
System Service	\$27,321,977	\$38,321,819	\$32,071,882	\$29,920,325	\$26,963,080	\$23,022,061	\$177,621,144
Grand Total	\$118,399,998	\$132,900,017	\$131,599,752	\$125,499,835	\$125,500,540	\$125,500,071	\$759,400,213

19

	2015	2016	2017	2018	2019	2020	Overall
	Proposed	Proposed	Proposed	Proposed	Proposed	Proposed	Total
General Plant	21%	13%	15%	11%	13%	15%	15%
System Access	20%	21%	22%	24%	23%	25%	23%
System Renewal	36%	37%	39%	41%	42%	42%	40%
System Service	23%	29%	24%	24%	21%	18%	23%
Grand Total	100%	100%	100%	100%	100%	100%	100%

20 21

Table 1: Annual Dollar Spending and Annual Percentage Spending by OEB Category

1	For compliar	nce with Section 5.0, this DS Plan has been arranged in two parts:
2	1. The A	sset Management Plan; and
3	2. The C	Capital Expenditure Plan.
4		
5	Within the As	sset Management Plan, the sections are:
6	• 5.0	Introduction (this section)
7		
8	• 5.1.4	Planning in Consultation with Third Parties
9	0	Regional planning and consultations, renewable energy generation
10		investments.
11		
12	• 5.2.1	Distribution System Plan Overview
13	0	Key elements of the plan, source of costs savings due to the plan, changes
14		since the last DS Plan, contingent events included in the plan.
15		
16	• 5.2.2	Coordinated Planning with Third Parties
17	C	Consultation process with 3 <sup>rd</sup> parties, external stakeholders, agencies and
18		customers.
19		
20	• 5.2.3	Performance Measurement for Continuous Improvement:
21	0	Corporate continuous improvement, asset investment planning improvements,
22		results from the 2013 Ice storm and 2014 Wind storm, performance metrics and
23		measures utilized to monitor the planning and implementation effectiveness of
24		the DS Plan in efforts towards continuous improvement, effects of performance
25		on the DS Plan.
26		
27	• 5.3.1	Asset Management Process Overview
28	0	Asset management planning process, asset capacity/utilization/constraint
29		assessment, worst performing feeder assessment.
30		

1	• 5.3.2	Overview of Assets Managed
2	0	PowerStream's service territory, system configuration, asset utilization, assets
3		managed.
4		
5	• 5.3.3	Asset Lifecycle Optimization Policies and Procedures
6	0	Asset replacement and refurbishment policies, optimized, prioritized spending,
7		impact of system renewal on routine OM&A and emergency/reactive repairs.
8		
9	• 5.4.3	System Capability Assessment for Renewable Energy Generation
10	0	Applications from renewable generators over 10kW, number and capacity of
11		renewable connections anticipated, PowerStream capacity for connection per
12		station, system constraints,
13		
14	Within the Ca	pital Expenditure Plan, the sections are:
15		
16	• 5.4.1	Capital Expenditure Plan Summary
17	0	Capability of PowerStream to connect new load, total annual capital expenditures
18		by investment category, outputs of the plan, material capital expenditures,
19		regional planning, customer engagement activities, five year system
20		development, special activities.
21		
22	• 5.4.2	Capital Expenditure Planning Process Overview
23	0	Capital Expenditure Planning Objectives, identification, selection and
24		prioritization of projects, customer engagement.
25		
26	• 5.4.4	Capital Expenditure Summary
27	0	Explanatory Notes on Variances in Capital Expenditure Summary, capital
28		expenditure summary.
29		
30		
31 22		
32		

1	• 5.4.5	Justifying Capital Expenditures
2	0	Investment summary reports for projects above the materiality threshold.
3		
4		S
5	Appendix A:	Project Investment Summaries – Material Projects
6	Appendix B:	OPA Letters
7	Appendix C:	Distribution System Plan Review Primer – Residential
8	Appendix D:	Distribution System Plan Review Primer – General Service over 50
9	Appendix E:	PowerStream Work Book
10	Appendix F:	Customer Consultation Report
11		
12		

1	5.1.4 PL	ANNING IN CONSULTATION WITH THIRD PARTIES
2	5.1.4.1	Regional planning and consultations
3		
4		illing a DS Plan and at a time and in a manner to be determined in consultation with the
5	participa	nts in a Regional Planning Process, a distributor must:
6 7	4 6	Dravida regionally intergence and distributors (including best and/or embedded where
7 8		Provide regionally interconnected distributors (including host and/or embedded where
9		icable), the transmitter to which the distributor is connected and the OPA (where applicable) information on:
10	VVILII	
11	•	forecast load at existing (and proposed, if any) points of interconnection;
12	•	forecast renewable generation connections and any planned network investments to
13		accommodate the connections;
14	•	investments involving smart grid equipment and/or systems that could have an impact on the
15		operation of assets serving the regionally interconnected utilities; and
16	•	the results of projects or activities involving the study or demonstration of innovative
17		processes, services, business models, or technologies; and on the projects or activities of
18		this nature planned by the distributor over the forecast period.
19		
20	2. (	Consult with regionally interconnected distributors (including host and embedded where
21	appl	icable) and transmitter(s) to which the distributor is connected in preparing their DS Plan.
22		
23	5.1.4.2	Renewable energy generation investments
24		
25	Prior to f	iling a DS Plan, a distributor must:
26		
27	1.	Not less than 60 days (where REG investments are contemplated; 30 days otherwise) in
28		advance of the date the distributor needs to receive the OPA letter for inclusion in an
29		application, a distributor must submit information to the OPA in relation to the REG investments
30		identified in their DS Plan and request in writing that the OPA provide a letter commenting on
31		the information by a date that conforms to the distributor's filing timetable.
32	2. 7	The Board expects that the OPA comment letter will include:

1	• the applications it has received from renewable generators through the FIT program for
2	connection in the distributor's service area;
3	• whether the distributor has consulted with the OPA, or participated in planning meetings
4	with the OPA;
5	• the potential need for co-ordination with other distributors and/or transmitters or others on
6	implementing elements of the REG investments; and
7	<ul> <li>whether the REG investments proposed in the DS Plan are consistent with any Regional</li> </ul>
8	Infrastructure Plan.
9	
10	The Board may postpone processing an application where a comment letter from the OPA has not
11	been filed in accordance with this requirement.
12	
13	5.1.4.1 Regional Planning and Consultations
14	The Ontario Energy Board's Report of the Board – A Renewed Regulatory Framework for
15	Electricity Distributors: A Performance Based Approach (the "RRFE Board Report") requires a
16	consultation process aimed at promoting the cost-effective development of electricity
17	infrastructure through coordinated planning on a regional basis between licensed distributors
18	and transmitters
19	
20	PowerStream has participated in all levels of regional planning required to develop long-term
21	electricity plans. This is described fully in Exhibit G, Tab 2, Section 5.2.2.
22	
23	
24	5.1.4.2 Renewable Energy Generation Investments
25	All information related to Renewable generation is included in Exhibit G, Tab 2, Section 5.4.3.
26	

#### 1 5.2.1 DISTRIBUTION SYSTEM PLAN OVERVIEW

#### 2 5.2.1 Distribution System Plan overview

This section provides the Board and stakeholders with a high level overview of the information filed in the
DS Plan, including but not limited to

- 5 a) key elements of the DS Plan that affect its rates proposal, especially prospective business 6 conditions driving the size and mix of capital investments needed to achieve planning objectives
- 7 b) the sources of cost savings expected to be achieved over the forecast period through good planning
- 8 and DS Plan execution
- 9 c) the period covered by the DS Plan (historical and forecast years);
- 10 d) an indication of the vintage of the information on investment 'drivers' used to justify investments
- 11 *identified in the application (i.e. the information should be considered "current" as of what date?);*
- 12 e) where applicable, an indication of important changes to the distributor's asset management process
- (e.g. enhanced asset data quality or scope; improved analytic tools; process refinements; etc.) since
   the last DS Plan filing; and
- 15 f) aspects of the DS Plan that relate to or are contingent upon the outcome of ongoing activities or
- 16 future events, the nature of the activity (e.g. Regional Planning Process) or event (Board decision on
- 17 LTLT) and the expected dates by which such outcomes are expected or will be known.
- 18
- Prior to filing, care should be taken to ensure that summary information is consistent with the detailedinformation filed in the following sections and elsewhere in the application.
- 21


#### 22 Key Elements of the Plan

- This Distribution System Plan (DS Plan) presents the summary of the processes, drivers,
  outcomes and justifications of the proposed capital investments, from 2015 to 2020, for
  PowerStream to achieve its corporate and planning objectives.
- 26

PowerStream's corporate strategic objectives are shown in Figure 1. These corporate objectives
influence the DS Plan. They are used within the optimization scoring process to link value to
the strategy map and they are tied to business cases. This is further described in Exhibit G, Tab

30 2, Section 5.3.3, pages 19 and 20.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.1 Distribution System Plan Overview Page 2 of 5 Delivered: February 24, 2015



1 2

3

#### Figure1: PowerStream Corporate Strategic Objectives

The capital expenditure plan provided in this DS Plan is the product of PowerStream's Asset
Management Planning and Budget Process. This is documented in Exhibit G, Tab 2, Section
5.3.1, and includes the following key elements:

7

8

9

 a) <u>Contributing Influences</u> - includes corporate strategic initiatives, customers, efficiencies and policies & procedures and their impact on the process;

1 b) Asset Knowledge – Identifies, records and manages the condition of both distribution 2 system and general plant assets, performs asset condition assessments, reviews asset 3 capacity and constraints as well as the inspection and maintenance practices; 4 5 c) Asset Strategy and Planning - applies asset planning criteria, reviews capacity 6 requirements, construction and materials standards, reliability performance, worst 7 performing feeders and interdepartmental committees; and 8 9 d) Asset Management and Decision Making - includes the process for optimization, 10 business cases and ongoing management of the capital portfolio. 11 12 The process for gathering data, analysing data, and forming strategic actions, acquiring 13 customer feedback and seeking efficiencies are all key elements of the plan. 14 15 Source of Cost Savings due to the Plan 16 The cost savings associated with this DS Plan can be referenced in Exhibit F, Tab 1. 17 18 Period Covered by this DS Plan 19 This DS Plan covers 2010 to 2014 for historical years, the 2015 Bridge Year, and the years 20 2016 to 2020. 21 22 Data Used for Investment Drivers 23 All asset information used for the Asset Condition Assessment was as of December 31, 2014. 24 Reliability metrics and analysis presented in this DS Plan include all outage information to 25 December 31, 2014. 26 27 Changes to the Plan since the last DS Plan 28 PowerStream has not previously filed a DS Plan. Since the last cost of service submission, 29 PowerStream has filed an Incremental Capital Module (ICM). 30

1	Contingent Events included in this DS Plan
2	The execution of distribution system capital investment programs often involves co-ordination
3	with, and dependency on, external organizations. PowerStream's co-ordination with third
4	parties has identified a number of projects where either the scope, timing or need for the project
5	has external dependencies. These projects include:
6	
7	<u>Municipal Road Relocation / Upgrade Projects</u> – System Access investments required to
8	facilitate road relocation projects may be dependent upon the eleven municipalities
9	served by PowerStream;
10	
11	Regional Road Relocation / Upgrade Projects – System Access investments required to
12	facilitate road relocation projects may be dependent upon the Region and County served
13	by PowerStream;
14	
15	• Ministry of Transportation Road Relocation Projects - System Access investments
16	required to facilitate road relocation projects may be dependent upon the provincial
17	agency;
18	
19	• Regional Planning Projects - PowerStream is actively participating in four Regional
20	Infrastructure Planning Processes ("RIP") with Hydro One. One RIP is in the early stages
21	of development and projects identified to date have not required PowerStream to plan
22	any capital investments. PowerStream continues to participate and support both the
23	IRRP the RIP processes and will make the required investments into projects arising
24	from the plans as identified; and
25	
26	<ul> <li><u>Customer Connections</u> – System Access investments in the expansion of</li> </ul>
27	PowerStream's distribution system may be required. The timing of these investments is
28	dependent on the location and service requirements of new customers.
29	
30	

#### 1 Third Party Reviews

2 PowerStream has prepared the DS Plan without the direct use of external consultants as

3 authors. PowerStream has, however, engaged third parties for their expertise in several key

4 areas of the business that are included in the plan. These are noted in Table 1.

5

Category	Consultant	Section Reference	Driver
Asset Condition Assessment	Kinectrics	5.3.3	Initial report and base models
Storm Hardening	CIMA	5.2.3	review weather patterns & other utilty experence, review Powerstream practices and make recommendations.
Asset Management	UMS	5.3.3	review current practices against PASS 55
Customer Engagement	Innovative Solutions	5.4.2	fulfill requirements of Chapter 5 filing
<b>Optimization &amp; Prioritization</b>	Copperleaf	5.3.3	develop benefit and risk mitigation value questions
Cyber Security	White Hat	5.4.5	perform cyber security audit and make recommendations
DS Plan	Paul Vlahos	all	review document and provide commentary

Table 1: External Consultants and the DS Plan

6 7

8

#### 1 5.2.2 COORDINATED PLANNING WITH THIRD PARTIES

To demonstrate that a distributor has met the Board's expectations in relation to coordinating
infrastructure planning with customers, the transmitter, other distributors and/or the OPA or other third
parties where appropriate, a distributor must provide:
a) a description of the consultation(s), including:

- the purpose of the consultation (e.g. Regional Planning Process);
- whether the distributor initiated the consultation or was invited to participate in it;
- the other participants in the consultation process (e.g. customers; transmitter; OPA);
- 9 the nature and prospective timing of the final deliverables (if any) that are expected to result from
  10 or otherwise be informed by the consultation(s) (e.g. Regional Infrastructure Plan; Integrated
  11 Regional Resource Plan); and
- an indication of whether the consultation(s) have or are expected to affect the distributor's DS
   Plan as filed and if so, a brief explanation as to how.
- b) where a final deliverable of the Regional Planning Process is available, the final deliverable; where
  a final deliverable is expected but not available at the time of filing, information indicating:
  - the role of the distributor in the consultation;
- 17 the status of the consultation process; and
- 18 where applicable the expected date(s) on which final deliverables are expected to be issued.
- c) the comment letter provided by the OPA in relation to REG investments included in the
   distributor's DS Plan (see 5.2.4.2), along with any written response to the letter from the distributor,
   if applicable.
- 22

16

23

#### 24 Overview

On October 18, 2012, the Ontario Energy Board (the "Board") issued its *Report of the Board – A Renewed Regulatory Framework for Electricity Distributors: A Performance Based Approach*(the "RRFE Board Report"). The RRFE Board Report concluded a consultation process aimed
at promoting the cost-effective development of electricity infrastructure through coordinated
planning on a regional basis between licensed distributors and transmitters.

30

The objective of the regional planning process is to develop long-term electricity plans that thoughtfully integrate all relevant resource options such as conservation and demand 1 management, distributed generation, large-scale generation transmission and distribution or2 other energy solutions.

3

#### 4 Planning Process

In 2013, the Regional Planning Process was formally introduced by the Board. This process
outlined the requirements for LDCs, Transmitters and Provincial Entities with respect to
integrated electricity planning. An overview of the requirements is shown in Figure 1.


- 8
- 9 Integrated Regional **Resource Planning** Long-term Energy (IRRP) Plan/Integrated Power **Distribution Planning** System Plan (Bulk System Planning) **Regional Infrastructure** Planning (RIP or "wires" planning) **Bulk System Planning Regional Planning Distribution Network Planning**  500 kV & 230 kV transmission 230 kV & 115 kV transmission Transformer stations to connect to the Interconnections 115/230 kV autotransformers and transmission system Inter-area network transfer capability associated switchyard facilities Distribution network planning (e.g. new System reliability (security and adequacy) Customer connections & modified Dx facilities) to meet NERC, NPCC, ORTAC Load supply stations · Distribution system reliability (capacity Congestion and system efficiency Regional reliability (security and & security) System supply and demand forecasts adequacy) to meet NERC, NPCC & ORTAC Distribution connected generation & Incorporation of large generation ORTAC local area reliability criteria CDM resources Typically medium- and long-term focused Regional/local area generation & CDM LDC demand forecasts resources Near- & medium-term focused Typically near- & medium-term focused 10 11 Figure 1: The Regional Planning Process 12 Under the Regional Planning requirements, transmitters are required to: 13
- Identify the need for regional planning for local areas;
  Lead the RIP process;
  Identify potential transmission solution(s); and
  Provide information required to facilitate the RIP and IRRP process
- 18

- Under the Regional Planning requirements, Local Distribution Companies are required to:
   Provide information required to facilitate the RIP and IRRP process;
   Identify potential distribution solution (s) and provide input on investments that may have a direct impact on the distributors; and
   Incorporate regional planning considerations as part of their rate application submission.
- 7

10

11

- 8 The Ontario Power Authority developed a 24 month cycle, and it includes the preparation of
- 9 required reports. Refer to Figure 2.



On May 13, 2013, the Planning Process Working Group (PPWG), a group of industry representatives convened by the Board, posted a **final** version of its *Report to the Board: The Process for Regional Infrastructure Planning in Ontario.* This report outlined the requirements for LDCs, Transmitters and Provincial Entities with respect to integrated electricity planning. The final PPWG report prescribes 21 regions within the Province. Within those 21 regions, PowerStream is included in four regions, namely:

- 7
- <u>GTA North</u>, part of Group 1 (underway in 2014) for 5 Hydro One owned stations and 9
   PowerStream owned stations;
- <u>Metro Toronto</u>, part of Group 1 (underway in 2014) for 4 Hydro One owned stations;
- <u>GTA North</u>, Western Sub-Region, part of Group 1 for 2 Hydro One owned stations and 1
   PowerStream owned station; and
- <u>South Georgian</u>, part of Group 2 (commences in 2015) for 5 Hydro One owned stations.
- 14

#### 15 GTA North (part of Group 1)

PowerStream is part of the existing Regional Plan for York Region. In 2005, an integrated planning study for Northern York Region (NYR) considered transmission, distribution, generation, and CDM solutions, and was developed with input from local stakeholders. The plan identified several key activities. These activities and their current status are:

- 20
- Add capacitor banks at Armitage TS. <u>Completed</u>.
- Install emergency load transfer capability. <u>Completed</u>.
- Contract conservation resources 20 MW of DR, in addition to provincial conservation
   efforts. <u>Completed</u>.
- Construct new Holland TS. <u>Completed</u>. (in-service June 2009; 230 kV switching to be provided)
- Procure gas-fired generation. *This was placed in-service spring 2012.*
- Build a third transformer station (Aurora TS) <u>not needed yet, therefore not implemented</u>
- The 2005 study concluded that completion of these activities (with exceptions noted) wouldprovide a reliable and adequate supply to Northern York Region.

1	Since the 2005 plan was adopted, the following system developments have occurred in York
2	Region:
3	
4	The launch of the Feed-in-Tariff (FIT) program, and expression of significant interest
5	in development of renewable energy generation in York Region and surrounding
6	areas through FIT applications;
7	Continued load growth in Northern York Region (albeit at a slower pace than initially
8	forecasted due to economic changes);
9	<ul> <li>Load growth in Southern York Region has caused the 230 kV circuits along the</li> </ul>
10	Parkway Belt to reach their limit to supply new transformation facilities without
11	transmission reinforcement;
12	<ul> <li>Forecast load growth throughout York Region is expected to outstrip transformation</li> </ul>
13	supply in the medium term; and
14	<ul> <li>In November 2010, PowerStream indicated to the OPA the need for additional</li> </ul>
15	capacity in the PowerStream south supply area (Vaughan, Richmond Hill and
16	Markham) and in the Aurora area.
17	
18	These developments called for a new regional plan to be developed that would incorporate
19	recent system developments and system assumptions, update demand forecasts to reflect
20	current economic conditions, and include current planning criteria.
21	
22	In the fall of 2010, PowerStream requested that the OPA initiate a regional planning study for
23	York Region. In early 2011, a working group was established to assess the reliability of supply
24	in York Region over a 20-year period. The engagement partners for the 2011 study included
25	PowerStream, Newmarket-Tay Power, the Ontario Power Authority, Hydro One and the IESO.
26	
27	The study had the following objectives:
28	<ul> <li>Identify needs in the near term (0-5 years), medium term (5-10 years) and long term (10-</li> </ul>
29	20 years);
30	<ul> <li>Identify actions to address near- and medium-term needs;</li> </ul>
31	<ul> <li>Provide direction for the long term; and</li> </ul>

- Prepare an integrated planning study, considering CDM, local generation, transmission
   and distribution as potential solutions.
- 3

The working group methodology provided the initial framework for exploring the new regional planning process proposed by the OPA and adopted by the Regulator, the basis for fostering two-way communication with stakeholders about local growth and electricity needs, developing various alternatives for meeting regional needs and their associated benefits/trade-offs, gaining better understanding of local conditions and opportunities and how to refine evaluation criteria to reflect local priorities.

10

In November of 2012, the *York Region Study, Summary of Needs and Options* was completed,
outlining near term needs (next 3 years), medium term needs (4-7 years) and long term needs
8-18 years). Refer to Figure 3.

14 15 Near Term Medium Long Term 16 17 Northern York **Reduce Impact of Potential** 18 Supply Capacity to New TS Supply Interruptions Region 19 20 Vaughan/Richmond Hill **Reduce Impact of Potential** Supply Capacity to New TS Supply Capacity to New TS Supply Interruptions (Vaughan #4) (Vaughan #5) Area 21 22 Markham/ Reduce Impact of Potential Supply Capacity to New TS 23 (Markham#5) Supply Interruptions **Buttonville Area** 24 25 Figure 3: High Level Study Results 26 27 On December 14, 2012, the OPA provided PowerStream with a letter to support the Working

27 On December 14, 2012, the OPA provided PowerStream with a letter to support the Working
28 Group's choice of the option to connect PowerStream's next transformer station in Vaughan to
29 the Claireville to Minden line.

1 For the medium term, the Ontario Power Authority, on December 14, 2012, issued a letter to 2 support the connection of Vaughan #4 MTS to the Claireville-Minden line in 2017, and on June 3 14, 2013, issued a directive to the affected parties, providing instructions to Hydro One to initiate 4 a Regional Infrastructure Planning (RIP) Process to develop and implement the near-term 5 transmission component of the integrated plan to meet the near and medium-term reliability 6 needs of York Region. The directive also handed off, from the OPA, the lead responsibility for 7 the planning process associated with the near-term transmission component of the York Region 8 Integrated Regional Resource Planning (IRRP) process to Hydro One to initiate the RIP 9 process. Specifically, the projects identified were:

- 10
- 11

 $\circ$   $\;$  The installation of switches/breakers at Holland TS (existing H1 property);

12

• The installation of switching station(s) on the Parkway Belt (Hwy 407 corridor).

13

A copy of these OPA letters are included in Appendix B. These upgrades maximize the use of the existing system, and provide for adequate supply until the early 2020's. In the long term (in the early 2020's), three additional stations will likely be needed to supply load growth in northern York Region, Markham and Vaughan, as the system is reaching its capacity. In addition, new infrastructure is required to supply these stations. Potential sources are from Parkway, Claireville/Kleinburg, local generation, conservation and demand management/response, storage or other initiatives.

21


In October 2013, the Technical Working group and the Communications Working group
 commenced, establishing a timeline for stakeholder engagement. In November of 2013, the
 near term projects (Holland TS and Vaughan TS#4) commenced their requisite communications
 and approval protocols.

26

In September of 2014, the Working Group met with the Directors of Planning for the municipalities in York Region to provide greater clarity on local planning initiatives. In December of 2014, the Working Group met with the CAOs for the municipalities in York Region to provide a similar presentation. The links between the various local planning activities is detailed in Figure 4.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.2 Coordinated Planning with 3<sup>rd</sup> Parties Page 8 of 14 Delivered: February 24, 2015

#### **Links Between Various Local Planning Activities**



2 3

1

4 The outcomes of the refreshed York Region regional plan has resulted in capital expenditure 5 requirements by PowerStream for the construction of a new transformer station (VTS#4) and its 6 associated feeder integration within this DS Plan timeframe, specifically in spending between 2015 and 2017 for the station and 2016 to 2019 for feeder integration. At the time of this writing, 7 8 it is assumed that any costs associated with the two Hydro One projects (Parkway Belt Switches 9 and Holland TS Switches) are to be pool funded. 10 11 The planning process for the integrated regional resource plan is moving to the next phase, 12 involving community engagement on long-term needs and alternatives. 13

- 10
- 14
- 15

#### 1 <u>Metro Toronto (part of Group 1)</u>

For this zone, regional planning from PowerStream's perspective primarily focuses on interactions with Hydro One, as PowerStream has feeders that are supplied from Hydro One owned transformer stations. Of the four Hydro One owned transformer stations, one is exclusive for PowerStream (Buttonville TS), while the other three are shared between Hydro One and Toronto Hydro.

7

8 A summary of activities is as follows:

- PowerStream has participated in the Regional Infrastructure Planning Needs Screening
   (NS) Process for the Metro Toronto Northern Sub-Region, and has supplied all requisite
   load forecasting information.
- The facilities in this sub-region which supply PowerStream include Hydro One
   transformer stations connected to the Richview TS to Cherrywood TS 230 kV
   transmission circuits.
- The study period for this Needs Screening is 2014 through 2023.
- The study phase of the NS process was initiated on April 14, 2014 and the report
   completed on June 11, 2014.
- Study results relevant to PowerStream are as follows:
- The loading on the 27.6 kV windings of Leslie TS T1/T2 is forecast to reach
   normal supply capacity within the first five years of the study period when based
   on the gross demand forecast;
- When net demand forecast is considered, the normal supply capacity of this
   facility is not expected to be exceeded during the 10-year study period;
- At this time, no action is required for Leslie TS and the capacity needs for this
   facility will be reviewed in the next planning cycle;
- No significant reliability and operating issues were identified for this sub-region,
   however, under certain contingency conditions, certain Ontario Resource and
   Transmission Assessment Criteria (ORTAC) restoration criteria may not be met;
   and
- 30 o Further assessment regarding restoration capability and requirements is required
  31 by the transmitter.

1	Study recommendations are as follows:
2	• At this time, the potential needs identified in this NS study do not require further
3	regional coordination and can be adequately and more efficiently addressed by
4	Hydro One and the relevant Local Distribution Companies.
5	
6	GTA North, Western Sub-Region (part of Group 1)
7	For this zone, regional planning from PowerStream's perspective primarily focuses on
8	interactions with Hydro One, as PowerStream has feeders that are supplied from Hydro One
9	owned transformer stations, which are shared with Brampton and Enersource. A summary of
10	activities is as follows:
11	PowerStream has participated in the Regional Infrastructure Planning Needs Screening
12	(NS) Process for the GTA North, Western Sub-Region which includes the Claireville TS
13	to Kleinburg TS 230 kV transmission circuits and the three connected transformer
14	stations in York Region, namely Vaughan MTS#3, Kleinburg TS and Woodbridge TS.
15	PowerStream has supplied all requisite load forecasting information;
16	• The study phase of the NS process was initiated on April 28, 2014 and the report was
17	completed on June 27, 2014;
18	<ul> <li>The study period for this NS is 2014 through 2023;</li> </ul>
19	<ul> <li>Study results relevant to PowerStream are as follows:</li> </ul>
20	o Transformer stations in this sub-region have sufficient capacity to accommodate
21	forecast loading requirements during the study period;
22	<ul> <li>Peak load at Vaughan MTS#3 is at its normal supply capacity;</li> </ul>
23	<ul> <li>Vaughan MTS#4, which is planned for in service in 2017, will provide capacity</li> </ul>
24	relief for Vaughan MTS#3;
25	$\circ$ The other two transformer stations supplied from these circuits, namely
26	Woodbridge TS and Kleinburg TS, have sufficient capacity to meet the
27	forecasted demand during the study period;
28	$\circ$ No major equipment in this sub-region is expected to reach the end of its useful
29	life during the study period; and

1	<ul> <li>No significant reliability and operating issues were identified for this sub-region,</li> </ul>
2	however, under certain contingency conditions, certain Ontario Resource and
3	Transmission Assessment Criteria (ORTAC) restoration criteria may not be met.
4	
5	Study recommendations are as follows:
6	$\circ$ The Ontario Power Authority (OPA) will include the affected LDCs in the
7	Integrated Regional Resource Plan (IRRP) process for the GTA West, Northern
8	Sub-Region with respect to load restoration needs in this sub-region;
9	$_{\odot}$ The sub-region's needs will be revisited in the next planning cycle which is
10	expected to be within the next five years.
11	
12	South Georgian Region (part of Group 2)
13	The planning studies for this region will commence in 2015, and includes Hydro One
14	Distribution, Innisfil Hydro, Orangeville Hydro, Veridian, and Newmarket-Tay Hydro
15	
16	Municipal Energy Plans
17	Although the Chapter 5 requirements do not explicitly require commentary on Municipal Energy
18	Plans, PowerStream is actively involved in these within its southern service territory.
19	
20	In July of 2013, the provincial government announced its continuing support for local energy
21	planning and conservation through the Municipal Energy Plan (MEP). The MEP program
22	supports municipalities' efforts to better understand their local energy needs, identify
23	opportunities for energy efficiency and clean energy, and develop plans to meet their goals.
24	
25	MEPs will help municipalities assess their community's energy use and greenhouse gas (GHG)
26	emissions; identify opportunities to conserve, improve energy efficiency and reduce GHG
27	emissions; consider the impact of future growth, and options for local clean energy generation;
28	and support local economic development.
29	
30	Successful municipalities from the first round of applications within PowerStream's service
31	territory are the City of Markham and the City of Vaughan

31 territory are the City of Markham and the City of Vaughan.

1	In November, 2013, PowerStream provided a letter confirming PowerStream Inc.'s participation
2	in the stakeholder engagement consultations, as well as providing electricity consumption data,
3	towards the development of Vaughan's Municipal Energy Plan (MEP), and that PowerStream
4	will also participate in the stakeholder engagement process.
5	
6	In January of 2014, PowerStream provided a letter confirming PowerStream Inc.'s participation
7	in the stakeholder engagement consultations, as well as providing electricity consumption data,
8	towards the development of Markham's MEP, and that PowerStream will also participate in the
9	stakeholder engagement process.
10	
11	In August of 2014, after both Municipalities received the requisite funding, both Municipalities
12	convened their own Municipal Energy Plan Stakeholder Working Groups with PowerStream as
13	a stakeholder.
14	
15	Markham MEP
16	There are three phases in the two year development of the Markham's Municipal Energy Plan.
17	These phases include:
18	<ul> <li>Phase 1: Stakeholder Engagement (August 2014 – January 2015);</li> </ul>
19	<ul> <li>Phase 2: Energy Mapping &amp; Study (February 2015 – July 2015); and</li> </ul>
20	<ul> <li>Phase 3: Energy Plan Development (August 2015 – August 2016).</li> </ul>
21	
22	Markham's Municipal Energy Plan will meet the following objectives upon completion:
23	• Identify energy and water efficiency and local energy generation and water reuse
24	opportunities throughout Markham in order to achieve net zero energy, water, waste
25	and emissions by 2050;
26	• Recommend actions, strategies and short to medium term targets and long term
27	milestones to achieve net zero by 2050;
28	• Set out monitoring and reporting processes and frequency in order to guide
29	implementation;

1	Integrate Communication & Engagement and Implementation Plans in the MEP to
2	meet the recommendations set forth;
3	<ul> <li>Implement a MEP framework for Secondary Plans to meet the requirements for the</li> </ul>
4	community energy plan component;
5	• Guide other Markham strategies, plans, policies and actions by the City to increase
6	energy efficiency, resilience and overall sustainability, including active transportation;
7	Seek 2016 and future capital project funding and/or partnerships to kick start
8	implementation; and
9	<ul> <li>Continue engagement with stakeholders to steward MEP implementation.</li> </ul>
10	
11	The MEP will be a living document to be updated on a regular basis to reflect the outcomes of
12	the monitoring and reporting process, as well as incorporating updates.
13	
14	PowerStream will continue to support the electricity component of the MEP.
15	
16	Vaughan MEP

17 Vaughan's goals are detailed in Figure 5.

> Goal 1: To significantly reduce our use of natural resources and the amount of waste we generate

Goal 2: To ensure sustainable development and redevelopment

Goal 3: To ensure that Vaughan is a city that is easy to get around with a low environmental impact

Goal 4: To create a vibrant community where citizens, business and visitors thrive

Goal 5: To be leaders in advocacy and education on sustainability issues

Goal 6: To ensure a supportive system for the implementation of the Community Sustainability and Environmental Master Plan

18 19

Figure 5: Vaughan Municipal energy Plan Goals

1	Vaugh	an's Municipal Energy Plan will meet the following objectives upon completion:
2	•	Identify key geographic areas for action, type of action, allocation of resources;
3	•	Empowering the right people and creating policies that work;
4	•	More clarity and public education;
5	•	Good coordination with other local policy and planning objectives;
6	•	Have a "menu" with options due to "one size does not fit all" challenge;
7	•	Mix of uses, options, broader objectives;
8	•	Based on user base – residential, commercial, mixed use;
9	•	Consider new developments vs. existing areas that are experience intensification; and
10	•	Have flexibility for both situations.
11		
12	Power	Stream will continue to support the electricity component of the MEP.
13		

#### 1 5.2.3 PERFORMANCE MEASUREMENT FOR CONTINUOUS IMPROVEMENT

As mentioned in section 5.0, good distributor planning is an essential element of the Board's performance-based rate-setting approaches. The Board understands that distributors often use certain qualitative assessments and/or quantitative metrics to monitor the quality of their planning process, the efficiency with which their plans are implemented, and/or the extent to which their planning objectives are met. The Board expects that this information is used to improve continuously a distributor's asset management and capital expenditure planning processes.

- a) identify and define the methods and measures (metrics) used to monitor distribution system
  planning process performance, providing for each a brief description of its purpose, form
  (e.g. formula if quantitative metric) and motivation (e.g. consumer, legislative, regulatory,
  corporate). These measures and metrics are expected to address, but need not be limited to:
  customer oriented performance (e.g. consumer bill impacts; reliability; power quality);
- cost efficiency and effectiveness with respect to planning quality and DS Plan
   implementation (e.g. physical and financial progress vs. plan; actual vs. planned cost of
   work completed); and
  - asset and/or system operations performance.
- b) provide a summary of performance and performance trends over the historical period using the
   methods and measures (metrics/targets) identified and described above. This summary must
   include historical period data on:
  - 1) all interruptions; and
- 2) all interruptions excluding loss of supply' for a) the distribution system average interruption
   frequency index; b) system average interruption duration index; and c) customer average
   interruption duration index.<sup>15</sup>
- Where performance assessments indicate marked adverse deviations from trend or targets
  (including any established in a previously filed DS Plan), provide a brief explanation and refer
  to these instances individually when responding to provision 'c)' below.
- c) explain how this information has affected the DS Plan (e.g. objectives; investment priorities;
   expected outcomes) and has been used to continuously improve the asset management and
   capital expenditure planning process.
- 30

16

- 31
- 32

#### **1** Performance Methodology and Metrics

This section of the filing requirements requests that distributors identify and define the methods and measures that will be used to monitor the quality of their planning process, the efficiency with which their plans are implemented, and/or the extent to which their planning objectives are met.

6

PowerStream has developed a set of measures to monitor quality and drive continuous improvement in its distribution system planning and implementation work over the 2015-2020 planning horizon. The measures cover several distinct dimensions of PowerStream's capital planning and implementation processes and/or address directly the outcomes of such processes, motivated by customer needs, regulatory compliance obligations, or efficiency objectives. Figure 1 outlines the DS Plan ongoing performance metrics.

13

1 System Average Interruption Duration Index (SAIDI)	SAIDI =		tes of Interruption Customers Served
2 System Average Interruption Frequency Index (SAIFI)	$SAIFI = \frac{\sum Total N}{Total N}$	Tumber of C	Customers Interrupted
3 Customer Average Interruption Duration Index (CAIDI)	CAIDI =		s of Interruption
4 Momentary Average Interruption Frequency Index (MAIFI)	$MAIFI = \frac{\sum Total}{}$		Customer Momentary Interruptions
5 DS Plan Spending Progress Report	<u>\$ spent in a year</u> budget in a year	plus	<pre>\$ spent cumulative over n years (n=1 to 5) \$ cumulative budget over n years (n=1 to 5)</pre>
6 Work Order Closing Variances	percentage of WC	s that clc	ose within prescribed policy limits
7 Cable Failure Rates	comparison pre-re	emediatio	n vs post remediation for cable projects

14 15

Figure 1: Performance Metrics

#### 1 Reliability Indices: SAIDI, SAIFI, CAIDI, MAIFI

2 SAIDI – System Average Interruption Duration Index

3 SAIDI is an indicator of system reliability that expresses the average length of sustained 4 interruptions that each customer experiences in a year. All planned and unplanned sustained 5 interruptions are used to calculate this index. Loss of supply and major event days are 6 excluded.

7

#### 8 SAIFI – System Average Interruption Frequency Index

9 SAIFI is an indicator of system reliability that expresses the average number of sustained
10 interruptions that each customer experiences in a year. All planned and unplanned sustained
11 interruptions are used to calculate this index. Loss of supply and major event days are
12 excluded.

13

#### 14 CAIDI – Customer Average Interruption Duration Index

15 CAIDI is an indicator of the speed at which power is restored. All planned and unplanned
16 sustained interruptions are used to calculate this index. Loss of supply and major event days
17 are excluded.

18

#### 19 MAIFI – Momentary Average Interruption Frequency Index

20 MAIFI is an indicator of system reliability that expresses the average number of momentary 21 interruptions that each customer experiences in a year. All unplanned momentary 22 interruptions are used to calculate this index. Loss of supply and major event days are 23 excluded.

24

PowerStream will continue to conform with the expectations reliability performance (SAIDI,
SAIFI, CAIDI) by remaining, as a minimum, within the range of its historical previous 3 year
average performance.

- 29 Refer to Figure 1 to Figure 6 on pages 13 and 14 for historical information.
- 30

3 Plan. 4 On an annual basis, PowerStream's will calculate for that year, and on a cumulative basis for 6 the five years of the DS Plan, its actual capital spending compared to the approved capital 7 budget. 8 9 As this is the first DS Plan filing, there are no historical statistics. 10 11 Work Order Closing Variances 12 PowerStream will be monitoring its execution of the projects and programs included in the DS 13 Plan. Variances, which are defined as a comparison of the actual dollars spent compared to the 14 approved budget estimate, are reviewed are categorized within prescribed limits. 15 16 On an annual basis, PowerStream's will calculate for that year, how successful the variances on 17 individual work orders were. PowerStream will review the variance reports and determine if 18 incremental improvements have transpired, and based on the results, take corrective actions as 19 are deemed necessary. 20 21 Figure 2 details the overall percentage of work orders for 2014 that were closed where the 22 variances were within the prescribed limits. 23 24

PowerStream will be monitoring its execution of the projects and programs included in the DS

1

2

DS Plan Spending Progress Report

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.3 Performance Measurement for Continuous Improvement Page 5 of 19 Delivered: February 24, 2015

Vork Order Review	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	2014
		<u>.</u>	# of	Reviews I	ssued Req	uiring M	anageme	ent Appro	val	۵			
Capital	0	53	19	0	20	8	10	11	12	6	20	8	167
ICI	0	3	3	0	6	3	9	7	11	5	9	2	58
Subdivision	0	2	3	0	5	2	4	4	3	2	5	2	32
Non Paper Trail	2	12	33	0	0	5	1	0	0	6	1	1	61
TOTAL	2	70	58	0	31	18	24	22	26	19	35	13	318
			# o	f Reviews	Not Requ	iring Ma	nagemen	t Approv	al				
Capital	5	18	12	0	2	25	16	6	3	1	5	3	96
ICI	8	6	3	0	10	10	9	5	3	7	10	4	75
Subdivision	4	2	0	0	0	1	5	2	0	2	3	3	22
Non Paper Trail	0	15	20	0	0	2	1	1	0	2	1	0	42
TOTAL	17	41	35	0	12	38	31	14	6	12	19	10	235
	Per	cent of W	ork Orders	Complet	ed Within	Variance	(Not Re	auiring N	lanageme	nt Approv	val)		
%	89	37	38	0	28	68	56	39	19	39	35	43	42

## 1 2

## Figure 2: 2014 Work Order Closing Results

# 3

# 4 Cable Failure Rates

PowerStream's system renewal, as detailed in Exhibit G, Tab 2, Section 5.3.3 page 7, contains
several programs. Cable remediation is the only program where failure rate analysis can be
readily measured.

8

9 As an area is remediated (large areas will be done in phases) and upon the completion of a
10 rehabilitated underground area, PowerStream will review the failure rates within that area and
11 compare the previous 5 years to the five years following project completion to assess the
12 reduction in failures. These figures will be available at the conclusion of each year within the DS
13 Plan horizon.

14

For the areas that were completed under the cable remediation program over the past three years (2012-2014), there were 86 cable and splice failures in the areas that were slated for injection. Post injection, there have been only 2 failures in those areas, demonstrating excellent results.

- For the 2015 cable remediation program, over the past three years (2012-2014), the areas have 1 2 experienced the following cable and splice failures. 3 • Cable injection areas (6 areas, 55 failures) 4 • Cable Replacement (7 areas, 58 failures) 5 6 These statistics will be updated annually, by area, to demonstrate improvements. 7 8 **Corporate Continuous Improvement** 9 PowerStream has a strong culture of continuous improvement in many areas. The incorporation 10 of continuous improvements is a constant thread through all work performed within the Utility. 11 Some customer and asset related initiatives are noted below. 12 13 Journey to Excellence 14 One of the strongest corporate commitments to this culture is PowerStream's Journey to 15 Excellence (J2E), based on Excellence Canada's Progressive Excellence Program (PEP). One 16 of the six driving forces behind the journey is customer experience, where the "voice of the 17 customer" and customer satisfaction are a pillar to PowerStream's continued success. 18 19 J2E encourages continuous improvement through excellence, innovation and wellness in each 20 of its drivers. Continuous improvement across the organization will position PowerStream as a 21 leader in the energy sector; one that is customer-centric, innovative, results oriented, focused 22 and accountable. With a focus on excellence, innovation and wellness, PowerStream customers 23 will be continuously engaged to ensure they receive the energy services and solutions best 24 tailored for their unique requirements. 25 26 Customer Experience Plan 27 A strong customer experience focus has led to many initiatives such as the creation of a 28 Customer Experience Plan. The plan is a 2014/2015 corporate initiative that impacts staff 29 across the organization. The Customer Experience Plan identifies short and long term steps the 30 organization will take to continue to deliver excellent, reliable customer experiences.
- 31

### 1 <u>Workforce Management</u>

In 2013, PowerStream staff undertook a collective review of the systems in use for Asset Management/Asset Analytics/Work Force Management/Mobile. PowerStream concluded that its approach for managing the diverse and growing mobile workforce was no longer adequate. PowerStream determined that it would invest in a modern, mobile workforce management solution to address current business challenges. An automated solution with rationalized business processes will result in better coordination and scheduling of work leading to increased customer satisfaction.

9

10 The drivers to acquire a new Workforce Management solution include:

- a) Inadequate current tools: the current tools and processes for dispatching and reporting
   on work were inherited from multiple predecessor utilities. These tools are no longer
   sufficient to manage the volume and complexity of projects. Existing processes are
   cumbersome and require a great deal of manual intervention;
- b) Customer expectations: customers are looking for PowerStream to continually achieve
   efficiencies in the execution of their work and to enhance the delivery of customer
   service;
- c) Regulatory environment: there is an increased requirement for visibility into the life cycle
   of projects to ensure that project execution and spend levels are in line with approved
   budgets; and
- d) Technology: the ability to leverage advances in technology for mobile solutions to deliver
   field staff real-time work package information, reporting capabilities, and optimal
   resource schedules.
- 24

## 25 <u>C55 Software</u>

In 2013, PowerStream staff undertook a collective review of the systems in use for Asset
Management/Asset Analytics/Work Force Management/Mobile. Through an RFP process,
Copperleaf Technologies Inc. was the successful vendor for the Optimization portion of this
initiative. From January to September, 2014, the Optimization tool within C55 was implemented
and used for the first ever multi-year optimization.

PS-RFP-13-30 included both Phase 2 and Phase 3 of the Asset Management System. Phase 2 is a replacement of the current Capital Budget Management System (CBMS) and full Business Case input. Phase 3 is planned in 2016 and will tie the Investment Decision Tool to PowerStream's Asset Management Data so that the analytics solution can determine and communicate optimal asset program spending.

6

Phase 2, scheduled for 2015 implementation, will be designed for project leads to input, into one
system (C55), all budget and project justifications. This will streamline the process for budget
creation, business case writing and optimization.

10

All of these initiatives have an impact on the distribution system plan as they govern the approach PowerStream takes in developing projects and programs to deliver operational effectiveness, optimal value for capital spending and to provide value to customers while executing all works in a safe manner.

15

## 16 Asset Investment Planning Improvements

As outlined in Exhibit G, Tab 2, Section 5.3.1, PowerStream's Asset Management Planning
Process is comprised of several components, of which several include a key element of
continuous improvement.

20

## 21 Interdepartmental Committees

PowerStream has integrated several interdepartmental and cross functional committees to provide focus and direction on key technical issues. Of note, the *Asset Management Committee* was formed in 2013 and the *Asset Strategy Committee* was formed in 2014 to focus improvements on the quality and accuracy of distribution system assets, and to determine strategic decisions on asset deployment.

27

Other Committees contribute to continuous improvement through either through their post event
 review, or visioning. These include the:

- 30 Reliability Committee;
- Outage Performance Committee;

- 1 Smart Grid Committee; and
  - Distribution Automation Committee.
- 2 3
- 4 Reliability Performance

5 On an annual basis, PowerStream reviews its reliability indices and looks at programs or 6 projects that could be implemented to improve these metrics. An annual report is prepared, 7 projects/programs presented and selected, and monitoring of progress is performed monthly. 8 Refer to Exhibit G, Tab 2, Section 5.3.3, page 34 for additional information.

9

# 10 <u>Worst Performing Feeders</u>

PowerStream aggregates the outage records for all feeders in its entire service territory to establish annual reliability indices such as SAIFI, CAIDI and SAIDI. Even if most customers are satisfied with their current level of service, further reliability improvements can be achieved by identifying areas with exceptionally poor performance.

15

16 System Planning, on an annual basis in conjunction with System Control, identifies and issues 17 the list of 20 Worst Performing Feeder with the intent to recommend future maintenance and 18 capital work on the feeders.

19

20 This review is an analysis on the performance of feeders emanating from PowerStream owned

- 21 transformer stations, Hydro One owned transformer stations and municipal substation feeders.
- 22

# 23 The study reviews and:

- States PowerStream's criteria for worst performing feeders (WPF);
- Identifies WPFs based feeder historical reliability data and the application of the WPF
   criteria;
- Analyzes root causes of outages on these feeders;
- Proposes action plans to improve reliability for each WPF; and
- Incorporates targeted reliability improvement plans into the capital budget as warranted.

## 1 2013 and 2014 Extreme Weather Events

On the weekend of December 21-22, 2013, a significant ice storm moved through Southern
Ontario. Ice accumulation resulted in downed branches, trees and power lines, which resulted in
over 500,000 customers losing power in Ontario. This included over 92,000 customers without
power (at the peak of the event) in PowerStream's service territory, predominantly in Aurora,
Markham, Richmond Hill and Vaughan.

7

The majority of customers were restored within 24 hours of the completion of the storm, with 85 per cent of customers restored within 48 hours, and the full restoration of PowerStream's service territory being realized on December 30, 2013. Most importantly, the restoration efforts were completed without a serious injury to PowerStream staff or the general public. This ice storm was by far the most severe outage event in PowerStream's 10-year history, based on the number and duration of customer outages.

14

15 To help offset the impact of these challenging events, PowerStream was able to leverage its 16 Distribution Automation assets already existing and newly implemented in 2013. The 17 Supervisory Control and Data Acquisition (SCADA) was used extensively to re-direct the flow of 18 power through the distribution system which assisted in restoring power to many of the affected 19 customers in a very short timeframe. Also proving itself to be a power restoration resource, was 20 the Fault Detection, Isolation and (self) Restoration (FDIR) system. This system performs 21 automatic sectionalizing of main line feeders should it detect a fault. The first successful 22 automatic transfers took place in 2013 restoring power to large numbers following a fault event.

23

While there were many successes throughout the restoration, including the speed at which the priority sites were re-energized and the overall performance of PowerStream management and staff, there were also many lessons learned that were outlined in an internal report that were prioritized and acted upon.

28

The key findings and 37 action items in the internal report are intended to enhance PowerStream's emergency restoration and communication efforts, and focussed around the following areas:

- capital asset management;
   restoration management;
   communication strategy;
   emergency management philosophy;
- 5 customer care; and
  - technical issues.
- 6 7

8 One of the recommendations was to analyze and provide recommendations for improvements 9 to PowerStream's distribution grid to make the system more resilient to these types of events. 10 An RFP to acquire the services of an external consultant firm was issued and awarded with 11 respect to "System Hardening". A report was prepared, and several recommendations were 12 provided. These recommendations were reviewed internally by the Asset Strategy Committee, 13 and the results and recommendations from the Committee were presented to Senior 14 Leadership. A plan was developed to address system hardening, Refer to Exhibit G, Tab 2, 15 Section 5.4.5, page 20 for details.

16

On June 17<sup>th</sup> 2014, twelve poles were damaged on Warden Ave in Markham during an intense
thunderstorm. Environment Canada identified a micro-burst in the Markham area at the time
with wind speeds approaching 130km/h.

20

The faulted section was isolated from the system and the pole line was rebuilt to the current PowerStream standards over a two day period. No critical injuries were reported to PowerStream.

24

This incident was covered in the system hardening plan. Refer to Exhibit G, Tab 2, Section 5.4.5, page 20 for details related to capital expenditures as a result of the review.

- 27
- 28 Methods and Measures used for Distribution System Planning Process Performance

There are several metrics that are calculated and applied to create projects and projects for improvement. These occur at regular intervals, or as a response to an event.

## 1 <u>Health Index</u>

2 The Health Index for distribution assets identifies the current level and future risk of equipment

3 failure for the asset groups and corresponding level of risk in being able to provide a high level

4 of service to customers.

5

6 The Health Index metric is also used to provide an indication of the level of investment required

7 over a twenty year planning horizon per asset category allowing prioritization of investments

8 within the various asset groups. This prioritization ensures that only the facilities needing

9 rehabilitation are addressed, effectively continuously improving the capital spending value.

10

# 11 Large Outage Events

When a significant outage occurs (past a set customer minute interrupted threshold) thecustomer impact is analyzed by:

- geographic area;
- cause code;
- incidents of a similar nature;
- identifying if it is a worst performing feeder; and
- possible physical testing as an example, a tan-delta cable test.
- 19

This information, when combined with the asset condition assessment information, is then used to develop potential projects for capital investments, which are then passed through the Asset


22 Management Planning process.

23


# 24 Summary of Performance and Performance Trends

- 25 SAIDI, SAIFI and CAIDI are lagging indicators that measure performance after events to assess
- 26 outcomes and occurrences. PowerStream's interruption metrics for SAIDI, SAIFI, and CAIDI
- are detailed in Figure 3, Figure 4, and Figure 5 respectively. Performance for all
- 28 interruptions and all interruptions excluding loss of supply are provided.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.3 Performance Measurement for Continuous Improvement Page 13 of 19 Delivered: February 24, 2015




# Figure 3: Historical SAIFI



4 5

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.3 Performance Measurement for Continuous Improvement Page 14 of 19 Delivered: February 24, 2015



2 3

1

4 5

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.3 Performance Measurement for Continuous Improvement Page 15 of 19 Delivered: February 24, 2015






Figure 6: PowerStream compared to CEA Utilities; SAIFI



4 5 6

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.2.3 Performance Measurement for Continuous Improvement Page 16 of 19 Delivered: February 24, 2015



### Figure 8: PowerStream compared to CEA Utilities; CAIDI

# 1 2

3

As seen in Figure 6 to Figure 8, PowerStream has been, with the exception of 2013, slightly
better than the CEA average. The CEA numbers are all inclusive, in that it includes loss of
supply and major events days. 2013 was a difficult year for weather related events for
PowerStream, highlighted by the December ice storm.

8

# 9 Performance Focus

PowerStream categorizes outages in accordance with the cause codes designated by the
Canadian Electricity Association (CEA). Within these codes, there are outages that can be
considered "controllable" and others considered "uncontrollable".

13

Although there is no accepted definitive classification within CEA, and there are events that could be debated as either controllable or uncontrollable, for practical purposes, PowerStream applies the distinction as shown in Table 1.

- 17
- 18

(CEA Code #) Controllable factors	(CEA Code #) Uncontrollable factors
(5) Defective Equipment	(9) Foreign Interference (3 <sup>rd</sup> party event)
(1) Scheduled Outage (by P/S to do work)	(2) Loss of Supply (Hydro One)
(3) Tree Contact	(7) Adverse Environment (Weather Dependent)
	ie salt
(8) Human Element	(6) Adverse Weather (Weather Dependent)
	(4) Lightning (Weather Dependent)




2


3

# Table 1: Controllable and Uncontrollable Outage Cause Codes

Figure 9 details the average duration of annual outages (over the past five years excluding loss of supply and major event days) to a single customer, both in total and its contributions of controllable and uncontrollable events. Figure 10 further breaks down the controllable SAIDI by cause code.







Effects of Performance on the DS Plan
PowerStream has committed to maintain and achieve a modest improvement in system
reliability over the next several years as part of its corporate strategy and its commitment to
customers.
On an annual basis, PowerStream reviews its reliability indices and looks at programs or
projects that could be implemented to improve these performance metrics. This reliability
improvement initiative may result in projects/programs being proposed.
Further information can be found in Exhibit G, Tab 2, Section 5.3.3, page 34 - Impact of System
Renewal on Reliability.

1 2

3

4 5

6 7

8 9


### 1 5.3.1 ASSET MANAGEMENT PROCESS OVERVIEW

This section provides the Board and stakeholders with a high level overview of the information filed on a distributor's asset management process, including key elements of the process that have informed the preparation of the distributor's capital expenditure plan and therefore are referred to in response to requirements for more detailed information supporting the overall capital expenditure plan, budget allocations to categories of investments, or material projects/activities proposed for recovery in rates. The information provided should include but need not be limited to:

8

9	a) a description of the distributor's asset management objectives and related corporate goals, and the
10	relationships between them; where applicable, show and explain how the distributor ranks asset
11	management objectives for the purpose of prioritizing investments;
12	b) information regarding the components (inputs/outputs) of the asset management process used to
13	prepare a capital expenditure plan, identify and briefly explain the data sets, primary process steps,
14	and information flows used by the distributor to identify, select, prioritize and/or pace investments; e.g.
15	asset register
16	asset condition assessment
17	asset capacity utilization/constraint assessment
18	<ul> <li>historical period data on customer interruptions caused by equipment failure</li> </ul>
19	reliability-based 'worst performing feeder' information and analysis
20	reliability risk/consequence of failure analyses.
21	
22	Use of a flowchart illustration accompanied by explanatory text is recommended
23	
24	
25	PowerStream's Asset Management Planning Process
26	The capital expenditure plan provided in this DS Plan, specifically Exhibit G, Tab 2, Sections
27	5.4.1, 5.4.2, 5.4.4 and 5.4.5, is the product of PowerStream's asset management planning
28	process.
29	
30	The asset management planning process, more fully documented in this Section, can be
31	seen in Figure 1. It includes the following key elements:

1	a) Contributing Influences;
2	b) Asset Knowledge;
3	c) Asset Strategy and Planning;
4	d) Asset Management and Decision Making; and
5	e) Outputs: Programs and Projects.
6	



7 8

## Figure 1: Asset Management Planning Process

9

- 10 This process, in its simplest form, asks the questions:
- How did the distribution system perform?
- What needs to be done?
- What options are available?
- Which options are best?
- What will get approved?
- How can we get the work done?
- How well did we do?

18

1	a)	Contributing Influences
2		
3	i.	Corporate Strategic Objectives
4		PowerStream's asset management goals and objectives are aligned and consistent
5		with PowerStream's corporate objectives, included specifically in Exhibit G, Tab 2,
6		Section 5.2.1, page 2, and are summarized as follows:
7		<ul> <li><u>Foundation</u> - Build integrated technology platforms;</li> </ul>
8		Processes - Focus on continuous improvement of key processes – design
9		and build the network, operate and maintain the network;
10		<u>Customers</u> - Provide customers with cost effective, competitive distribution
11		rates; and
12		<u>Financial</u> - Provide an optimized rate of return.
13		
14		PowerStream's asset management planning process uses these corporate objectives
15		as guiding principles in the decision making process to ensure that effective short and
16		long term investment decisions are made which maximize the value of the assets to the
17		company and provide optimal value to customers.
18		
19	ii.	Customers
20		Also integral to the process is listening to customers to determine how their needs align
21		with the proposed capital plan. The information regarding customer engagement is
22		described in Exhibit 2, Tab 4, Section 5.4.2.
23		
24	iii.	Efficiencies
25		As described in Exhibit F, Tab 1 PowerStream strives to be continuously improving and
26		developing more efficient processes, including the application of technology.
27		
28	iv.	Policies and Procedures
29		As part of the overall process of making informed decisions, PowerStream makes use
30		of disciplined policies, standards and processes for maintaining the assets of the

1	company. These policies, standards and processes effectively form part of
2	PowerStream's asset management planning process.
3	
4	v. Regulations
5	PowerStream must comply with regulations, codes, guidelines, standards and practices
6	mandated by the agencies that regulate utilities in Ontario.
7	
8	b) Asset Knowledge
9	Asset knowledge comprises the practices for obtaining, storing and maintaining optimal
10	attribute and asset information on the distribution system and general plant.
11	
12	PowerStream has been applying more formal asset management principles for the
13	distribution system since 2007, when the initial Kinectrics Asset Condition Assessment
14	(ACA) study was performed. This approach concentrated its initial efforts on assets that
15	represented the highest priority, had the highest asset value and represented the highest
16	risk to PowerStream.
17	
18	This process was accomplished by grouping the assets into logical asset classes, and
19	these were further grouped into three priority categories, which were based on the asset
20	value to the business. The highest priority assets were power transformers, system spare
21	transformers, substation transformers, transformer station breakers, transformer station
22	230kV switches, substation breakers and Substation HV Switches and Fuses.
23	
24	Since the initial report, PowerStream has been gathering asset data and failure data and
25	have been adding assets to the ACA portfolio.
26	
27	The components of Asset Knowledge are as follows:
28	i) Asset Registers;
29	ii) Asset Condition Assessment (ACA);
30	iii) Asset Capacity Utilization/Constraint Assessment; and
31	iv) Inspection and Maintenance Practices.

1	These components are more fully described below.
2	
3	i. Asset Registers
4	Asset registers represent the primary sources of where information resides for the
5	various asset types. There are several systems used to acquire, update and maintain
6	the diverse set of assets in the company.
7	
8	The primary asset registers, which are the sources of asset data for PowerStream are:
9	<i>i.</i> Supervisory Control and Data Acquisition ("SCADA") system;
10	<i>ii.</i> Geographical Information System ("GIS") system;
11	iii. Outage Management System ("OMS");
12	<i>iv.</i> Cascade system;
13	v. Station drawing repository;
14	<i>vi.</i> FileNexus;
15	vii. Computer Information system;
16	viii. Fleet system; and
17	<i>ix.</i> Facilities system.
18	
19	The definitions for the various asset registers are below.
20	
21	i) SCADA – Supervisory Control and Data Acquisition
22	PowerStream's Supervisory Control and Data Acquisition (SCADA) system provides
23	real time (live) asset data on certain key assets that are in the field (e.g. stations,
24	automated switches, wholesale smart meters). The key assets allow the system
25	control operators to monitor asset status and performance and to configure the
26	distribution system on an ongoing basis in order to optimize system performance and
27	the supply of power to PowerStream's customers. Typical data collected through
28	SCADA is used to operate the distribution system and includes information such as
29	equipment status (on/off), current flow (amps) and alarms related to mission critical
30	station equipment (relay triggers).
31	

SCADA data is archived and provides a historical record of system performance that
 allows for detailed engineering and operating analysis to provide future direction and
 plans for improving system performance.

4

5

6

7

SCADA real time data is available to operations and engineering staff through the corporate networks via a web browser. Archived SCADA data is available to select users through a data historian application located on the corporate network.

8 9

# ii) Geographical Information System

PowerStream's Geographical Information System ("GIS") holds both locational and
attribute data on electrical distribution assets within PowerStream's service territory.
PowerStream's GIS data is relied upon by many departments within the organization
for operational, maintenance and design requirements.

14

21

15 The GIS department receives data from multiple sources which is subsequently 16 captured in the GIS. This process ensures an accurate record of the electrical 17 distribution network and connectivity is available. In addition, the key attributes 18 associated with each asset are also recorded. The information can then be queried 19 and extracted to satisfy specific requests for information (e.g. electrical connectivity, 20 age of assets, testing records, etc.).

22 Maintenance of GIS records is controlled by the GIS Department. The GIS Department 23 has instituted processes and procedures to capture, update and maintain 24 PowerStream's electrical distribution asset data. All GIS data entry including, but not 25 limited to, new plant, attribute updates, plant removal and any other spatial data must 26 be completed in the ESRI ArcFM environment following a version management 27 convention (ESRI ArcFM is a vendor name and product). All versions are put through a 28 quality assurance and quality control process by a senior GIS employee before posting 29 to the GIS production environment.

1 The majority of GIS information input (70%) is from capital programs that result in 2 additions of plant to the distribution system. Examples of this are drawings pertaining to 3 new subdivisions, new commercial and residential installations and capital works on 4 roads.

5

6 PowerStream has developed an Asset Tracking Form ("ATF") which is used to capture 7 individual asset information. In 2012, this moved from a paper based system to an 8 electronic system. The function of the ATF is to provide a standard form to capture 9 asset information gathered by the Lines & Construction staff in PowerStream. Lines & Construction staff complete the ATF for asset installations, removals and inspections of 10 11 major equipment such as transformer, switchgears, switches, poles, and splices. Upon completion of the ATF, the data is automatically provided to the GIS Department. The 12 13 GIS Department updates the required database systems with the attribute information.

14

The remaining 30% of GIS information input comes from operational sources (e.g. open points on feeders, discrepancy verification), maintenance sources (e.g. attribute information arising from inspection or maintenance), and other discrete sources (e.g. joint use, street lighting, land base, orthographic imaging, etc).

19

20

# iii) Outage Management System

21 The Outage Management System ("OMS") utilizes the GIS connectivity model and 22 inputs from smart meters, SCADA, Customer Information System ("CIS"), Interactive 23 Voice Recognition ("IVR") and manual input to provide dynamic system and outage 24 information and status. Outage calls, whether input automatically (as in smart meters) 25 or manually, are automatically grouped together as appropriate and predictive device 26 operation is generated. This application brings together multiple operational inputs and 27 provides a dynamic picture of PowerStream's distribution network performance. 28 Reliability performance statistics are generated from the OMS.

29

30 Asset performance reports (e.g. operations performance reports) are produced on a 31 regular basis and are provided to senior management for information and review. Outage notification alerts and other reliability related notifications are produced in real
 time as required.

iv) Cascade

Cascade is a Computerized Maintenance Management System ("CMMS"). This application aids in the efficient and timely maintenance of PowerStream's transformer and municipal substation assets.

9 Cascade receives real-time operational SCADA data, inspection data, test data, 10 equipment diagnostic data (and many other inputs) from the stations. Cascade data is 11 input, used and accessed by operational divisions such as Station Maintenance and 12 Protection and Control.

13

3 4

5

6

7

8

Handheld field devices or computer notebooks are used to upload and download data
 to/from the database for operational field use. Advanced algorithms in the Cascade
 software generate preventative maintenance orders and alerts based on operating
 conditions.

18 19

# v) Station Drawing Repository

The Station Drawing Depository ("SDR") holds data, predominately reference drawings, related to PowerStream's station facilities. Engineering drawings pertaining to PowerStream's transformer stations and municipal stations are relied on by both the Engineering and Operations departments who reference Station drawings during their day to day work. One common set of electronically stored drawings, controlled in a managed database, ensures accurate and efficient creation, editing, modification and access to Stations Drawings.

27

The Stations Design department leads the preparation and issue of design, construction, and as-built drawings for PowerStream's transformer stations, municipal stations, and telecommunication network. These drawings, once issued, are electronically stored in the SDR which is located on a file management system
 (SharePoint).

- The types of drawings residing in the Stations Drawing Repository are
  - System Drawings (communication drawings, etc.);
  - Transformer Stations civil, mechanical, wiring and electrical drawings;
    - Municipal Stations civil, mechanical, wiring and electrical drawings; and
    - Control Centres layout and schematics.

9 The process to add, modify, delete drawings in the SDR is strictly controlled and 10 administered by the Station Design department. Through the SDR, stakeholders in 11 engineering and operations can access draft drawings, construction drawings, "as-built" 12 drawings and archived (obsolete) drawings.

# 14 vi) FileNexus

FileNexus is a data repository that holds lines project construction drawings for new services, new subdivisions, new construction projects, line relocations and line rehabilitations. Engineering drawings are relied upon by design, construction and operations staff in their day-do-day work. One common place for storage is used so approved drawings, as-built drawings and any related documents to projects are available for access.

21

3 4

5

6

7

8

13

The process to add, modify, delete drawings is laid out as part of the process flow for each type of work and stage of work completion. Through FileNexus, design, construction and operations staff access the drawings throughout various stages of project completion.

26

# 27 vii) Information Systems

28 PowerStream manages the diverse information system related assets in various29 manners.

1	Software:
2	• Microsoft SCCM (System Centre Configuration Manager) – scans the
3	networks and tracks software applications in use, keeps usage statistics,
4	release levels, licensing details, and can be coordinated with Microsoft
5	licensing agreements to help address differences.
6	<ul> <li>License tracking is online through vendors portals and licensing VAR (Value</li> </ul>
7	Added Reseller) – which tracks licensing compliance and renewals.
8	
9	Hardware:
10	$\circ$ SCCM – (System Centre Configuration Manager) scans the network and
11	logs all hardware existing on system.
12	<ul> <li>SCOM – (System Centre Operations Manager) – integrates with SCCM</li> </ul>
13	and helps operate the hardware by monitoring and reporting the condition
14	and changes in the network.
15	
16	<ul> <li>Configuration Item (CI)/ Configuration Object Inventory (COI):</li> </ul>
17	This encompasses items within the IT architecture. As an example, a CI could
18	be "email" – which is complex combination of a number of assets such as
19	hardware, software, as well as proprietary information such as PowerStream's
20	email data – so a CI is used to encapsulate and refer to the complete asset
21	(which is more than the sum of its parts). COIs are tracked at the helpdesk
22	(HEAT) system – so that changes and service request can be associated to
23	them.
24	
25	viii) Fleet
26	PowerStream has implemented Web Fleet Assistant (WFA) as a fleet maintenance
27	software system.
28	
29	This software maintains a complete list of all fleet assets and their:
30	<ul> <li>assigned preventive maintenance schedule;</li> </ul>

1	• mandatory annual, semi-annual, quarterly inspections as per Highway Traffic Act
2	and CSA/ANSI and ESA standards;
3	<ul> <li>current age and repair history. Once a unit is removed from fleet the status</li> </ul>
4	changes to sold and the repair history stays in the system; and
5	km travelled.
6	
7	Data stored in this system can be analysed to develop capital replacement plans.
8	
9	ix) Facilities
10	PowerStream does not have a formal computer tracking software system for building
11	assets.
12	
13	There are formal maintenance contracts in place for building systems, such as HVAC,
14	back-up generators and Security Systems. Part of those contacts includes scheduled
15	regular maintenance for the units being serviced. The service includes
16	recommendations about preventative maintenance and recommendations for potential
17	capital remediation.
18	
19	Summary
20	As described, there are several key asset registers which contain a diverse amount of
21	assets, multiple sources of information and various procedures for obtaining the data.
22	Although these may appear separate and disparate, which could lead to challenges,
23	procedures that document the necessary steps have been created. Staff are
24	knowledgeable and periodic reviews of data quality are undertaken.
25	
26	ii. Asset Condition Assessment
27	Asset Condition Assessment (ACA) is the process of analysing the data from the asset
28	registers and determining a specific asset's health along with determining any potential
29	need for remediation.
30	

1 PowerStream's asset condition assessment data is maintained, within the various 2 asset registries, on the following key electrical distribution and general plant assets: 3 i) **Distribution transformers** ii) 4 **Distribution Switchgear** Wood Poles 5 iii) Load interrupter switches 6 iv) 7 V) Underground primary cables 8 vi) Mini-rupter switches 9 vii) Automated switches Power transformers 10 viii) 11 ix) Switchgear 12 X) Primary switches 13 xi) **Circuit breakers** 14 230kV switches xii) Reactors 15 xiii) 16 xiv) Capacitors 17 xv) Information systems Facilities 18 xvi) 19 xvii) Fleet 20 The ACA program includes the development of Health Indices, risk-based economic 21 analyses (probability of failure and criticality), and recommended Asset Sustainability 22 Plans (replacements). 23 24 The ACA involves collecting and interpreting condition and performance data to enable 25 informed investment decisions. The primary purpose of the ACA is to detect and 26 quantify long-term degradation, which would necessitate major capital expenditures. 27 The result of the ACA is an optimized life-cycle plan based on real asset sustainability. 28 29 30

## 1 Health Index

6

7 8

11


12

13

14

18

Asset Evaluations involve a technical condition assessment, wherein condition information is translated into a quantitative Health Index (HI). The HI is based on information such as equipment age, historical utilization, maintenance, and visual inspections.



9 The HI establishes the condition of the asset population relative to end of life. A 10 summary of the assets covered by ACA is below.

*i)* Distribution Transformers

Distribution Transformers condition data is collected in conjunction with PowerStream's distribution transformer inspection process.

PowerStream will continue to operate overhead transformers on a run-tofailure basis. It is expected that PowerStream will be able to manage the
replacement of overhead transformers as they fail.

19Single phase residential padmount transformers as three phase transformers20are generally run-to-failure assets. PowerStream, however, proposes to21replace selected single and three phase padmount transformers annually for22the five years of this DS Plan (and beyond). The units will be prioritized based23on the results of the inspection program and their loading history (based on24overloading).

1		It is expected that PowerStream will be able to manage the replacement of
2		padmount transformers as they age either to the point of failure, or deteriorate
3		to the point of the unit being deemed a safety hazard.
4		
5	ii)	Distribution Switchgear
6		Distribution switchgear condition data is collected on an ongoing basis as a
7		result of PowerStream's Switchgear inspection process.
8		
9		Distribution switchgear units comprise of Air, Oil, SF6, and Solid Dielectric
10		units. They are either manually operated or motor operated and SCADA
11		controllable.
12		
13		All switchgear units are visually inspected on a 3-year cycle. Dead front units
14		(PVI, Oil, Solid Dielectric) will have Infra-Red scan every 6 years. Air insulated
15		units will have a detailed inspection every 6 years, which will be completed
16		during the dry ice cleaning maintenance cycle (on a 6-year cycle).
17		
18		PowerStream plans to replace switchgear units annually for the five years of
19		this DS Plan (and beyond). The units will be prioritized based on the results of
20		the inspection program.
21		
22		The replacement strategy is to either eliminate the existing switchgear location
23		(if feasible), or replace existing switchgear unit with a new unit. PVI (SF6 style)
24		or SD (Solid Dielectric style) switchgear will be used for 27.6 kV, and PMH
25		(Air) switchgear will be used for 13.8 kV and below.
26		
27	iii)	Wood Poles
28		Wood pole condition data is collected on an ongoing basis as a result of
29		PowerStream's pole testing program.
30		Remediation recommendations are based on condition test results and
31		minimum physical life remaining. The Health index formulation is based on

1		condition, criticality of the location, number of circuits, number of attachments
2		(indicating level of risk at time of failure) and asset data collected on an
3		ongoing basis.
4		
5		PowerStream plans to remediate poles annually for the five years of this DS
6		Plan (and beyond).
7		
8	iv)	Underground Primary Cable
9		The condition of underground cable is correlated to the age of the cable. Other
10		factors exist such as loading and mechanical stress. Cable age and cable
11		failure statistics are the first step in prioritizing further testing to determine
12		cable condition.
13		
14		PowerStream performs Tan Delta cable tests to assist with the assessment of
15		cable condition. This testing data is used to:
16		• Determine which intervention method (replacement vs. injection) is more
17		suitable for a specific location;
18		• Determine the appropriate quantity and timing of cable intervention
19		(replacement/injection); and
20		<ul> <li>Validate and prioritize the cable replacement/injection projects.</li> </ul>
21		
22		Cable remediation is performed either by cable injection (a process that
23		extends cable life) or cable replacement.
24		
25	v)	Mini-Rupter Switches
26		Mini-Rupter switch condition data is collected on an ongoing basis as a result
27		of PowerStream's inspection program.
28		
29		PowerStream plans to replace switches annually for the five years of this DS
30		Plan (and beyond). The units will be prioritized based on the results of the
31		inspection program.

2       vi)       Automated Switches         3       Automated switch condition data is collected on an ongoing basis as a result of PowerStream's inspection program.         5       PowerStream plans to replace switches annually for the five years of this DS Plan (and beyond). The units will be prioritized based on the results of the inspection program.         9       Vii)       Transformer Stations         10       vii)       Transformer Stations         11       Transformer stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station were formulated based on industry best-practices through the Kinectrics model, and asset data collected on an ongoing basis.         16       17         17       Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.         20       viii)       Municipal Sub-stations         21       viii)       Municipal Sub-stations         22       available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.         23       together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on	1		
4       of PowerStream's inspection program.         5       9         6       PowerStream plans to replace switches annually for the five years of this DS         7       Plan (and beyond). The units will be prioritized based on the results of the inspection program.         9       9         10       viii)         7       Transformer Stations         11       Transformer Stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station were formulated based on industry best-practices through the Kinectrics model, and asset data collected on an ongoing basis.         16       17         17       Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.         20       21         21       viii)         Municipal Sub-stations         22       available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.         23       together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.         24       available. Healt	2	vi)	Automated Switches
5       PowerStream plans to replace switches annually for the five years of this DS         7       Plan (and beyond). The units will be prioritized based on the results of the inspection program.         9       viii)       Transformer Stations         10       viii)       Transformer Stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station were formulated based on industry best-practices through the Kinectrics model, and asset data collected on an ongoing basis.         16       17         17       Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.         20       viiii)       Municipal Sub-stations         21       viiii)       Municipal Sub-stations         22       available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.         23       planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.         24       planned replacements are ba	3		Automated switch condition data is collected on an ongoing basis as a result
6PowerStream plans to replace switches annually for the five years of this DS7Plan (and beyond). The units will be prioritized based on the results of the inspection program.910vii)10vii)Transformer Stations11Transformer Stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station were formulated based on industry best-practices through the Kinectrics model, and asset data collected on an ongoing basis.161117Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal Sub-stations23cogether to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.23gether to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.24available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.25best-practices through the Kinectrics model and asset data collected on an ongoing basis.26 <td>4</td> <td></td> <td>of PowerStream's inspection program.</td>	4		of PowerStream's inspection program.
7Plan (and beyond). The units will be prioritized based on the results of the inspection program.910vii)11Transformer Stations12together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station were formulated based on industry best-practices through the Kinectrics model, and asset data collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.23planned replacements are based on poor health indices, obsolescence such individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.29available with inability to operating the equipment.	5		
8       inspection program.         9       10       vii)       Transformer Stations         11       Transformer stations are a highly complex set of individual assets working         12       together to provide a functioning station. Demographic and condition data are         13       available. Health Indices on components of the station were formulated based         14       on industry best-practices through the Kinectrics model, and asset data         15       collected on an ongoing basis.         16       17         17       Planned replacements are based on poor health indices, obsolescence such         18       that the equipment is not able to be maintained, poor reliability statistics or         19       issues with inability to operating the equipment.         20       21       viii)         21       viii)       Municipal Sub-stations         22       Municipal stations are a highly complex set of individual assets working         23       together to provide a functioning station. Demographic and condition data are         24       available. Health Indices on components of the station are based on industry         25       best-practices through the Kinectrics model and asset data collected on an         26       orgoing basis.         27       28         28       Plan	6		PowerStream plans to replace switches annually for the five years of this DS
9         10       vii)       Transformer Stations         11       Transformer stations are a highly complex set of individual assets working         12       together to provide a functioning station. Demographic and condition data are         13       available. Health Indices on components of the station were formulated based         14       on industry best-practices through the Kinectrics model, and asset data         15       collected on an ongoing basis.         16       17         17       Planned replacements are based on poor health indices, obsolescence such         18       that the equipment is not able to be maintained, poor reliability statistics or         19       issues with inability to operating the equipment.         20       21         21       viii)         Municipal Sub-stations         22       Municipal Sub-stations         23       together to provide a functioning station. Demographic and condition data are         24       available. Health Indices on components of the station are based on industry         25       best-practices through the Kinectrics model and asset data collected on an         26       ongoing basis.         27       28         28       Planned replacements are based on poor health indices, obsolescence such         2	7		Plan (and beyond). The units will be prioritized based on the results of the
10vii)Transformer Stations11Transformer stations are a highly complex set of individual assets working12together to provide a functioning station. Demographic and condition data are13available. Health Indices on components of the station were formulated based14on industry best-practices through the Kinectrics model, and asset data15collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or29issues with inability to operating the equipment.	8		inspection program.
11Transformer stations are a highly complex set of individual assets working12together to provide a functioning station. Demographic and condition data are13available. Health Indices on components of the station were formulated based14on industry best-practices through the Kinectrics model, and asset data15collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or29issues with inability to operating the equipment.	9		
12together to provide a functioning station. Demographic and condition data are13available. Health Indices on components of the station were formulated based14on industry best-practices through the Kinectrics model, and asset data15collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121 <i>viii)</i> Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or29issues with inability to operating the equipment.	10	vii)	Transformer Stations
13available. Health Indices on components of the station were formulated based14on industry best-practices through the Kinectrics model, and asset data15collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or29issues with inability to operating the equipment.	11		Transformer stations are a highly complex set of individual assets working
14on industry best-practices through the Kinectrics model, and asset data15collected on an ongoing basis.161717Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)22Municipal Sub-stations23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	12		together to provide a functioning station. Demographic and condition data are
15collected on an ongoing basis.1617Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or20issues with inability to operating the equipment.	13		available. Health Indices on components of the station were formulated based
1617Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	14		on industry best-practices through the Kinectrics model, and asset data
17Planned replacements are based on poor health indices, obsolescence such18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	15		collected on an ongoing basis.
18that the equipment is not able to be maintained, poor reliability statistics or19issues with inability to operating the equipment.202121viii)Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	16		
<ul> <li>issues with inability to operating the equipment.</li> <li><i>viii)</i> Municipal Sub-stations</li> <li>Municipal stations are a highly complex set of individual assets working</li> <li>together to provide a functioning station. Demographic and condition data are</li> <li>available. Health Indices on components of the station are based on industry</li> <li>best-practices through the Kinectrics model and asset data collected on an</li> <li>ongoing basis.</li> <li>Planned replacements are based on poor health indices, obsolescence such</li> <li>that the equipment is not able to be maintained, poor reliability statistics or</li> <li>issues with inability to operating the equipment.</li> </ul>	17		Planned replacements are based on poor health indices, obsolescence such
<ul> <li>20</li> <li>21 viii) Municipal Sub-stations</li> <li>22 Municipal stations are a highly complex set of individual assets working</li> <li>23 together to provide a functioning station. Demographic and condition data are</li> <li>24 available. Health Indices on components of the station are based on industry</li> <li>25 best-practices through the Kinectrics model and asset data collected on an</li> <li>26 ongoing basis.</li> <li>27</li> <li>28 Planned replacements are based on poor health indices, obsolescence such</li> <li>29 that the equipment is not able to be maintained, poor reliability statistics or</li> <li>30 issues with inability to operating the equipment.</li> </ul>	18		that the equipment is not able to be maintained, poor reliability statistics or
21 <i>viii</i> )Municipal Sub-stations22Municipal stations are a highly complex set of individual assets working23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	19		issues with inability to operating the equipment.
Municipal stations are a highly complex set of individual assets working together to provide a functioning station. Demographic and condition data are available. Health Indices on components of the station are based on industry best-practices through the Kinectrics model and asset data collected on an ongoing basis. Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.	20		
23together to provide a functioning station. Demographic and condition data are24available. Health Indices on components of the station are based on industry25best-practices through the Kinectrics model and asset data collected on an26ongoing basis.272828Planned replacements are based on poor health indices, obsolescence such29that the equipment is not able to be maintained, poor reliability statistics or30issues with inability to operating the equipment.	21	viii)	Municipal Sub-stations
<ul> <li>available. Health Indices on components of the station are based on industry</li> <li>best-practices through the Kinectrics model and asset data collected on an</li> <li>ongoing basis.</li> <li>Planned replacements are based on poor health indices, obsolescence such</li> <li>that the equipment is not able to be maintained, poor reliability statistics or</li> <li>issues with inability to operating the equipment.</li> </ul>	22		Municipal stations are a highly complex set of individual assets working
<ul> <li>best-practices through the Kinectrics model and asset data collected on an ongoing basis.</li> <li>ongoing basis.</li> <li>Planned replacements are based on poor health indices, obsolescence such that the equipment is not able to be maintained, poor reliability statistics or issues with inability to operating the equipment.</li> </ul>	23		together to provide a functioning station. Demographic and condition data are
<ul> <li>26 ongoing basis.</li> <li>27</li> <li>28 Planned replacements are based on poor health indices, obsolescence such</li> <li>29 that the equipment is not able to be maintained, poor reliability statistics or</li> <li>30 issues with inability to operating the equipment.</li> </ul>	24		available. Health Indices on components of the station are based on industry
<ul> <li>27</li> <li>28 Planned replacements are based on poor health indices, obsolescence such</li> <li>29 that the equipment is not able to be maintained, poor reliability statistics or</li> <li>30 issues with inability to operating the equipment.</li> </ul>	25		best-practices through the Kinectrics model and asset data collected on an
<ul> <li>Planned replacements are based on poor health indices, obsolescence such</li> <li>that the equipment is not able to be maintained, poor reliability statistics or</li> <li>issues with inability to operating the equipment.</li> </ul>	26		ongoing basis.
<ul> <li>that the equipment is not able to be maintained, poor reliability statistics or</li> <li>issues with inability to operating the equipment.</li> </ul>	27		
30 issues with inability to operating the equipment.	28		Planned replacements are based on poor health indices, obsolescence such
	29		that the equipment is not able to be maintained, poor reliability statistics or
31	30		issues with inability to operating the equipment.
	31		

1 2

3

4

5

6

7

8

9

10

20

21

22

23

24

25

26

## ix) Computer Information Systems

Similar to the distribution system, PowerStream's computer assets are required to be reasonably current and in good working order. In 2012, PowerStream adopted the International Financial Reporting Standards (IFRS) system for accounting purposes. In doing so the "useful life" of a number of asset classes were reviewed. This serves as a guideline for planning purposes. Other factors such as reliability and the impact (cost) of failure remain the primary factors considered in IT asset management remediation decisions. This includes metering and billing related systems.

11 x) Facilities

Similar to the distribution system, PowerStream's building facilities are required to be reasonably current and in good working order. The four facilities are of various age demographics. The Cityview location is several years old, the north facility is in relatively fair condition but some items will require work as a result of aging. Lease hold improvements at Markham Operations Centre facility will also result in increased capital requirement and the Jane Street office is new and does not require work.

- 19 The areas of concern for PowerStream's facilities are:
  - Exterior (i.e. pavement, fencing, lighting, stores yard);
  - Interior (i.e. furniture);
    - Mechanical (i.e. Plumbing);
    - Structural (i.e. windows, doors, wall partitions);
      - HVAC (Heating & air conditioning); and
      - Equipment (major tools, lifts).
  - xi) Fleet

# PowerStream's fleet assets are required to be in good working order. Depending on the class of vehicle (heavy duty, medium duty, light duty or miscellaneous class) replacement is required when the vehicle reaches a

1	prescribed odometer reading or a prescribed engine hours reading and shows
2	an upward trend in unscheduled maintenance costs for last three years. Also
3	taken into account is the projected unscheduled maintenance cost based on a
4	technical assessment.
5	
6	iii. Asset Capacity Utilization/Constraint Assessment
7	With respect to annual system utilization, PowerStream annually undertakes planning
8	studies in the spring and produces a Feeder Balancing and System Reconfiguration
9	Plan, based on approved Planning Standards and PowerStream's Planning
10	Philosophy. The goal of this plan is to review system loading and make
11	recommendations to balance both transformer and feeder loading to within established
12	guidelines. The loading of PowerStream's transformer stations should not exceed the
13	limited time rating (LTR) for that station. Feeders should not be loaded above the
14	planning feeder limits. In order to meet summer peak, loads on all assets must be
15	reviewed against guidelines, and timely corrective actions taken to ensure limits are
16	respected.
17	
18	By implementing this plan, stations and feeders will be balanced and utilization of
19	assets will be optimized.
20	
21	iv. Inspection and Maintenance Practices
22	Inspection and maintenance comprise the physical gathering of attribute data on assets
23	and making immediate or planned corrections as required.
24	
25	The Inspections and Maintenance Practices are governed by the following internal
26	Procedures:
07	Vegetation Management Dressdure:
27	Vegetation Management Procedure;
28	Distribution Switchgear Inspection and Maintenance Procedure;
29	Inspection of Vault Rooms;
30	<ul> <li>Overhead Plant Inspection and Maintenance;</li> </ul>

1	Tan Delta Cable Testing;
2	<ul> <li>Underground Transformer and Inspection and Maintenance Procedure;</li> </ul>
3	<ul> <li>Load Interrupter Switch/Recloser Inspection and Maintenance Procedure;</li> </ul>
4	Pole Inspection and Testing; and
5	Vault Inspection and Maintenance.
6	As a result of continuous inspection and maintenance, projects/programs are
7	developed to address safety issues or operating issues.
8	c) Asset Strategy & Planning
9	Asset strategy and planning provide the framework for defining how projects and
10	programs must be designed to maintain compliance with standards, codes, policies and
11	procedures.
12	
13	The inputs for Asset Strategy and Planning are as follows:
14	i) Asset Planning Criteria;
15	ii) Capacity Requirement Assessments;
16	iii) Construction and Material Standards;
17	iv) Reliability Performance;
18	v) Worst Performing Feeder Assessment; and
19	vi) Interdepartmental Committees.
20	
21	i) Asset Planning Criteria
22	PowerStream has set criteria for planning limits and operational limits of the distribution
23	system. These are summarized as follows:
24	a. The Deterministic Planning Technique and the (N-1) contingency Criterion in
25	planning for station capacity has been adopted. This standard calls for zero
26	interruptions to customers as a result of any single outage to a major network
27	element, such as a station transformer or transmission line.

1	b.	The continued practice of DESN (dual element spot network) station construction
2		has been adopted. This requires two supply sources and two transformers at each
3		station.
4	С.	The overloading values will be in accordance with the transformer's 10 day LTR.
5		The 10 day LTR is the rating designed to respect conditions that can cause hot-
6		spot temperatures of the transformer to create loss of life.
7	d.	Feeders that egress from transformer stations are typically designed to carry in
8		excess of 600A in emergency conditions. PowerStream's Planning Philosophy
9		calls for adopting a feeder planning capacity of 400 Amps for normal conditions
10		and 600 Amps for contingency conditions, since;
11		• 400A is well within the rated current of components of all equipment on
12		the system;
13		• For contingency conditions, load on one feeder will go to two adjacent
14		feeders so that the other two feeders will have a loading of less than 600A
15		which is within the rated current of components of all equipment on the
16		system, specifically load interrupter switches;
17		<ul> <li>600A for backup feeders requires system reconfiguration; and</li> </ul>
18		• 600A load carrying capability for back-to-back represent the industry
19		defined first contingency.
20	e.	For the north territory, a triad model is applied for municipal sub-stations. This
21		model requires that at least three stations are tied together through open points
22		such that if one station is lost, all load from the triad supplied stations can be
23		supplied by the remaining stations.
24	f.	An "open grid" feeder design will be applied and provide for full backup capability
25		over peak loading periods through switching of load to an adjacent feeder or
26		multiple adjacent feeders.
27		
28		
29		
30	ii) Caj	pacity Requirement Assessments

At a minimum of every second year, PowerStream undertakes a planning study to review system peaks compared to system capacity, to determine if expansion to the transformation or distribution system is required. The objective is to identify the need for additional facilities with sufficient lead time for permit approvals, design, procurement, construction and commissioning prior to the load exceeding available capacity.

7 8

12

13

16

17

19

20

21

25

29

## iii) Construction and Material Standards

9 PowerStream has an extensive array of construction standards that have been
10 approved by a provincially licensed professional Engineer. These standards cover:

- Engineering and Construction Standards Guidelines;
  - Technical Data;
  - Voltages, Line Locations, and Clearances;
- Poles and Footings;
- Material Illustrations;
  - Overhead Distribution Standards;
  - Underground Distribution Standards;
- Services and Metering;
  - Street Lighting; and
    - Overhead and Underground Markings and Numbering.
- PowerStream has an extensive array of material standards that have been approved
  by a provincially licensed professional Engineer to support the construction standards.
  These standards cover:
- Anchors and guying;
  Cables and cable accessories;
- Splices and terminations;
  - Conductors and connectors;
- Fault indicators;

<ul> <li>Coverheard hardware and accessories;</li> <li>Underground hardware and accessories;</li> <li>Poles;</li> <li>Switches and switchgear;</li> <li>Transformers; and</li> <li>Netering.</li> <li>Netering.</li> <li>Netering.</li> <li>Netering.</li> <li>PowerStream has committed to improve system reliability over the next several years as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability indices and looks at programs or projects that could be implemented to improve these metrics. This reliability improvement initiative exceeds the minimum regulatory service quality standard expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Section 5.3.3, page 33 for further information.</li> <li>Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a pattern of higher incidence of outages over a three year period.</li> </ul>	1	<ul> <li>Fusing;</li> </ul>
<ul> <li>Underground hardware and accessories;</li> <li>Poles;</li> <li>Switches and switchgear;</li> <li>Transformers; and</li> <li>Transformers; and</li> <li>Metering.</li> <li><i>iv) Reliability Performance</i></li> <li>PowerStream has committed to improve system reliability over the next several years as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability indices and looks at programs or projects that could be implemented to improve these metrics. This reliability improvement initiative exceeds the minimum regulatory service quality standard expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
<ul> <li>Poles;</li> <li>Switches and switchgear;</li> <li>Transformers; and</li> <li>Transformers; and</li> <li>Metering.</li> <li><i>iv</i>) <i>Reliability Performance</i></li> <li>PowerStream has committed to improve system reliability over the next several years as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability indices and looks at programs or projects that could be implemented to improve these metrics. This reliability improvement initiative exceeds the minimum regulatory service quality standard expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
<ul> <li>Switches and switchgear;</li> <li>Transformers; and</li> <li>Metering.</li> <li><i>iv</i>) <i>Reliability Performance</i></li> <li>PowerStream has committed to improve system reliability over the next several years as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability target set for 2020.</li> <li>On an annual basis, PowerStream reviews its reliability indices and looks at programs or projects that could be implemented to improve these metrics. This reliability improvement initiative exceeds the minimum regulatory service quality standard expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>V Worst Performing Feeders Assessment</i> Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
<ul> <li>Transformers; and</li> <li>Metering.</li> <li><i>iv</i>) <i>Reliability Performance</i></li> <li>PowerStream has committed to improve system reliability over the next several years</li> <li>as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability target set for 2020.</li> <li>On an annual basis, PowerStream reviews its reliability indices and looks at programs</li> <li>or projects that could be implemented to improve these metrics. This reliability</li> <li>improvement initiative exceeds the minimum regulatory service quality standard</li> <li>expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving</li> <li>towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,</li> <li>Section 5.3.3, page 33 for further information.</li> <li><i>v</i>) <i>Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control</li> <li>department, identify and issue a list of the 20 Worst Performing Feeders, with respect</li> <li>to reliability and outages that exist in PowerStream's service territory. This report</li> <li>recommends future maintenance and capital work on these feeders with the intent to</li> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
<ul> <li>Metering.</li> <li>iv) Reliability Performance</li> <li>PowerStream has committed to improve system reliability over the next several years as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability target set for 2020.</li> <li>On an annual basis, PowerStream reviews its reliability indices and looks at programs or projects that could be implemented to improve these metrics. This reliability improvement initiative exceeds the minimum regulatory service quality standard expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li>v) Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
<ul> <li><i>iv)</i> Reliability Performance</li> <li>PowerStream has committed to improve system reliability over the next several years</li> <li>as part of the corporate "Strategic Direction - Five Years Critical Success Factors".</li> <li>PowerStream will strive towards meeting the reliability target set for 2020.</li> <li>On an annual basis, PowerStream reviews its reliability indices and looks at programs</li> <li>or projects that could be implemented to improve these metrics. This reliability</li> <li>improvement initiative exceeds the minimum regulatory service quality standard</li> <li>expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving</li> <li>towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,</li> <li>Section 5.3.3, page 33 for further information.</li> <li><i>Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control</li> <li>department, identify and issue a list of the 20 Worst Performing Feeders, with respect</li> <li>to reliability and outages that exist in PowerStream's service territory. This report</li> <li>recommends future maintenance and capital work on these feeders with the intent to</li> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>		
9iv)Reliability Performance10PowerStream has committed to improve system reliability over the next several years11as part of the corporate "Strategic Direction - Five Years Critical Success Factors".12PowerStream will strive towards meeting the reliability target set for 2020.130n an annual basis, PowerStream reviews its reliability indices and looks at programs15or projects that could be implemented to improve these metrics. This reliability16improvement initiative exceeds the minimum regulatory service quality standard17expected of PowerStream.181919A reliability target over the next several years. Refer to Exhibit G, Tab 2,21Section 5.3.3, page 33 for further information.22v) Worst Performing Feeders Assessment24Annually, the System Planning department, in conjunction with the System Control25department, identify and issue a list of the 20 Worst Performing Feeders, with respect26to reliability and outages that exist in PowerStream's service territory. This report27recommends future maintenance and capital work on these feeders with the intent to28performing feeders by their performance indices. These are feeders that demonstrate a		i Motoring.
10PowerStream has committed to improve system reliability over the next several years11as part of the corporate "Strategic Direction - Five Years Critical Success Factors".12PowerStream will strive towards meeting the reliability target set for 2020.131414On an annual basis, PowerStream reviews its reliability indices and looks at programs15or projects that could be implemented to improve these metrics. This reliability16improvement initiative exceeds the minimum regulatory service quality standard17expected of PowerStream.181919A reliability work plan has been developed to provide a general road map for moving20towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,21Section 5.3.3, page 33 for further information.22v) Worst Performing Feeders Assessment24Annually, the System Planning department, in conjunction with the System Control25department, identify and issue a list of the 20 Worst Performing Feeders, with respect26to reliability and outages that exist in PowerStream's service territory. This report27recommends future maintenance and capital work on these feeders with the intent to28improve their reliability. This is a reliability focused initiative that identifies the worst29performing feeders by their performance indices. These are feeders that demonstrate a		iv) Reliability Performance
12PowerStream will strive towards meeting the reliability target set for 2020.1314On an annual basis, PowerStream reviews its reliability indices and looks at programs15or projects that could be implemented to improve these metrics. This reliability16improvement initiative exceeds the minimum regulatory service quality standard17expected of PowerStream.181919A reliability work plan has been developed to provide a general road map for moving20towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,21Section 5.3.3, page 33 for further information.222323v) Worst Performing Feeders Assessment24Annually, the System Planning department, in conjunction with the System Control25department, identify and issue a list of the 20 Worst Performing Feeders, with respect26to reliability and outages that exist in PowerStream's service territory. This report27recommends future maintenance and capital work on these feeders with the intent to28improve their reliability. This is a reliability focused initiative that identifies the worst29performing feeders by their performance indices. These are feeders that demonstrate a	10	
13         14       On an annual basis, PowerStream reviews its reliability indices and looks at programs         15       or projects that could be implemented to improve these metrics. This reliability         16       improvement initiative exceeds the minimum regulatory service quality standard         17       expected of PowerStream.         18       19         19       A reliability work plan has been developed to provide a general road map for moving         20       towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,         21       Section 5.3.3, page 33 for further information.         22       23         23       v) Worst Performing Feeders Assessment         24       Annually, the System Planning department, in conjunction with the System Control         25       department, identify and issue a list of the 20 Worst Performing Feeders, with respect         26       to reliability and outages that exist in PowerStream's service territory. This report         27       recommends future maintenance and capital work on these feeders with the intent to         28       improve their reliability. This is a reliability focused initiative that identifies the worst         29       performing feeders by their performance indices. These are feeders that demonstrate a	11	as part of the corporate "Strategic Direction - Five Years Critical Success Factors".
14On an annual basis, PowerStream reviews its reliability indices and looks at programs15or projects that could be implemented to improve these metrics. This reliability16improvement initiative exceeds the minimum regulatory service quality standard17expected of PowerStream.181919A reliability work plan has been developed to provide a general road map for moving20towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,21Section 5.3.3, page 33 for further information.222323v) Worst Performing Feeders Assessment24Annually, the System Planning department, in conjunction with the System Control25department, identify and issue a list of the 20 Worst Performing Feeders, with respect26to reliability and outages that exist in PowerStream's service territory. This report27recommends future maintenance and capital work on these feeders with the intent to28improve their reliability. This is a reliability focused initiative that identifies the worst29performing feeders by their performance indices. These are feeders that demonstrate a	12	PowerStream will strive towards meeting the reliability target set for 2020.
15or projects that could be implemented to improve these metrics. This reliability16improvement initiative exceeds the minimum regulatory service quality standard17expected of PowerStream.18.19A reliability work plan has been developed to provide a general road map for moving20towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,21Section 5.3.3, page 33 for further information.22.23v) Worst Performing Feeders Assessment24Annually, the System Planning department, in conjunction with the System Control25department, identify and issue a list of the 20 Worst Performing Feeders, with respect26to reliability and outages that exist in PowerStream's service territory. This report27recommends future maintenance and capital work on these feeders with the intent to28improve their reliability. This is a reliability focused initiative that identifies the worst29performing feeders by their performance indices. These are feeders that demonstrate a	13	
<ul> <li>improvement initiative exceeds the minimum regulatory service quality standard</li> <li>expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving</li> <li>towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,</li> <li>Section 5.3.3, page 33 for further information.</li> <li><i>V</i>) Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control</li> <li>department, identify and issue a list of the 20 Worst Performing Feeders, with respect</li> <li>to reliability and outages that exist in PowerStream's service territory. This report</li> <li>recommends future maintenance and capital work on these feeders with the intent to</li> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	14	On an annual basis, PowerStream reviews its reliability indices and looks at programs
<ul> <li>expected of PowerStream.</li> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>v) Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	15	or projects that could be implemented to improve these metrics. This reliability
<ul> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>v) Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	16	improvement initiative exceeds the minimum regulatory service quality standard
<ul> <li>A reliability work plan has been developed to provide a general road map for moving towards the reliability target over the next several years. Refer to Exhibit G, Tab 2, Section 5.3.3, page 33 for further information.</li> <li><i>v) Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	17	expected of PowerStream.
<ul> <li>towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,</li> <li>Section 5.3.3, page 33 for further information.</li> <li><i>v) Worst Performing Feeders Assessment</i></li> <li>Annually, the System Planning department, in conjunction with the System Control</li> <li>department, identify and issue a list of the 20 Worst Performing Feeders, with respect</li> <li>to reliability and outages that exist in PowerStream's service territory. This report</li> <li>recommends future maintenance and capital work on these feeders with the intent to</li> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	18	
<ul> <li>Section 5.3.3, page 33 for further information.</li> <li><i>v)</i> Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	19	A reliability work plan has been developed to provide a general road map for moving
<ul> <li><i>v)</i> Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control</li> <li>department, identify and issue a list of the 20 Worst Performing Feeders, with respect</li> <li>to reliability and outages that exist in PowerStream's service territory. This report</li> <li>recommends future maintenance and capital work on these feeders with the intent to</li> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	20	towards the reliability target over the next several years. Refer to Exhibit G, Tab 2,
<ul> <li>v) Worst Performing Feeders Assessment</li> <li>Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	21	Section 5.3.3, page 33 for further information.
Annually, the System Planning department, in conjunction with the System Control department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a	22	
department, identify and issue a list of the 20 Worst Performing Feeders, with respect to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a	23	v) Worst Performing Feeders Assessment
to reliability and outages that exist in PowerStream's service territory. This report recommends future maintenance and capital work on these feeders with the intent to improve their reliability. This is a reliability focused initiative that identifies the worst performing feeders by their performance indices. These are feeders that demonstrate a	24	Annually, the System Planning department, in conjunction with the System Control
<ul> <li>27 recommends future maintenance and capital work on these feeders with the intent to</li> <li>28 improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>29 performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	25	department, identify and issue a list of the 20 Worst Performing Feeders, with respect
<ul> <li>improve their reliability. This is a reliability focused initiative that identifies the worst</li> <li>performing feeders by their performance indices. These are feeders that demonstrate a</li> </ul>	26	to reliability and outages that exist in PowerStream's service territory. This report
29 performing feeders by their performance indices. These are feeders that demonstrate a	27	recommends future maintenance and capital work on these feeders with the intent to
	28	improve their reliability. This is a reliability focused initiative that identifies the worst
30 pattern of higher incidence of outages over a three year period.	29	performing feeders by their performance indices. These are feeders that demonstrate a
	30	pattern of higher incidence of outages over a three year period.

2 Once the work has been performed on the worst performing feeders for a given year, 3 these feeders typically move off the list, and are replaced with the next group of worst 4 performing feeders that were next on the list. This annual ongoing review and 5 remediation should result in the improvement in feeder performance and, over time, 6 should contribute to maintaining the overall reliability of the distribution system.

8 In September 2009, PowerStream adopted the average of FAIDI (feeder average 9 interruption duration index - how long a customer has an outage) and FAIFI (feeder average interruption frequency index- how many times a customer has an outage) 10 11 method to determine the worst performing feeders (10 in the South service territory and 12 10 in the North service territory). One of the drawbacks of selecting feeders based on 13 FAIDI/FAIFI method is that it looks at the feeder level indices and ignores the impact 14 the feeder has on overall system reliability indices and directing resources on these feeders would not significantly improve the system level statistics. 15

16

1

7

In 2012, System Planning developed an updated methodology which ranked feeders
based on outage duration, the number of customers impacted and the total number of
outages (including momentary outages).

20

In order to not ignore smaller feeders with chronic issues, a blended approach was
 selected, whereby 10 feeders would be selected from the FAIDI/FAIDI list and 10
 feeders were selected from the customer minutes interrupted list plus the customer
 interrupted list and the outage list.

25

26

30

# vi) Interdepartmental Committees

- 27 PowerStream has several interdepartmental and cross functional committees to
  28 provide focus and direction on key technical issues. The functioning committees are:
- Asset Management Committee;
  - Asset Strategy Committee;

1	Distribution Automation;
2	Standards Committee;
3	Reliability Committee;
4	Outage Performance Committee;
5	Smart Grid Committee and
6	Optimization Committee.
7	These committees have the mandate to review specific system issues, industry
8	innovations and recommend programs or projects that will rectify respective issues or
9	suggest pilot projects.
10	
11	d) Asset Management & Decision Making
12	Asset management and decision making provide the framework for deciding which projects
13	and programs will be selected to become part of the capital expenditure plan.
14	
15	To generate potential projects or programs, the asset management and decision making
16	process considers:
17	Inputs from the asset registers;
18	<ul> <li>Asset Condition Assessment criteria as applicable;</li> </ul>
19	<ul> <li>Asset capacity utilization/constraint assessments;</li> </ul>
20	<ul> <li>Inspection and maintenance data;</li> </ul>
21	Asset planning criteria;
22	Standard related issues;
23	Reliability performance; and
24	Worst performing feeder analysis.
25	
26	The process also considers input from customers and recommendations from
27	interdepartmental committees. The proposed projects are then placed into the optimization
28	process and applied within the capital budget threshold to generate the optimal list of
29	projects/programs for a given year (projects with the highest value are included in the year's
30	portfolio).

1	The inputs for asset management and decision making are as follows:
2	i. Portfolio Optimization
3	ii. Business Cases
4	iii. Management and Reporting of the Capital Portfolio
5	
6	i. Portfolio Optimization
7	PowerStream has a robust capital planning process that utilizes software and a multi-
8	disciplinary review that helps to determine the relative value and risks associated with a
9	portfolio of projects. Refer to Exhibit G, Tab 2, Section 5.3.3, page 15 for a more
10	detailed outline of Asset Optimization.
11	
12	The annual business planning and budgeting process starts early in the year with the
13	Board of Directors revisiting the corporate strategy (which could lead to changes to the
14	Strategy Map). Operating and capital budgets are then prepared that align with and
15	support the corporate strategy. At the end of the year, the Five Year Budget Outlook is
16	presented to the Board of Directors for approval. The timeline is further outlined in
17	Table 1.
18	
19	

1

6

7

8

9

11

12

13

14

Timeline	Activity
February/March	Executive Management Team ("EMT") and Board of Directors hold a Strategic Planning Session and establish and re-affirm or adjust the corporate strategy. There may be some resulting edits to the Strategy Map.
April/May	The corporate strategy is communicated to the organization through the use of the Strategy Map.
Мау	There is an official "kick-off" of the budget process.
May to August	Detailed budgets for the next five years are prepared. Business unit leaders are asked to prepare business cases for those projects and programs that exceed a prescribed threshold.
September	Optimization of the proposed programs and projects occur. The Audit & Finance Committee and the Board of Directors are updated on the status of budget preparation.
October/November	The EMT reviews and finalizes the Five Year Budget.
December	The Five Year Budget is presented to the Audit and Finance Committee and then the Board of Directors for approval.
January/February	Performance reporting of the previous year baseline to actual is performed.
Table	1: Annual Business Planning and Budget Process Cycle
ii. Business Cases	
Business cases	s, either mini or full, are required to support all capital request
Business cases	are prepared in advance of the Optimization process to ensu
	or capital requests. Business cases can also be prepared during the

year for requests of current year's capital funds (outside of the capital budget process).

- 10 The required business case format is determined by:
  - Dollar value requested;
  - Program vs. non-program (specific projects) capital investment ; and
  - Inclusion within approved capital budget or after-the-fact.
- 15 Business cases are used to support a request for capital funding and must contain:
- an objective to be achieved;

1	<ul> <li>background information of the current state;</li> </ul>
2	<ul> <li>detailed analysis of status quo, including risk of not maintaining it;</li> </ul>
3	<ul> <li>review of possible alternatives;</li> </ul>
4	• detailed review of recommended alternative and the value it brings and why it
5	was chosen;
6	<ul> <li>timeframes / dates to show duration of project;</li> </ul>
7	<ul> <li>financial details associated with each alternative; and</li> </ul>
8	<ul> <li>financial analysis to capture both capital and OM&amp;A.</li> </ul>
9	
10	Full business cases are to be used for capital requests $\geq$ \$500K for specific projects,
11	and $\geq$ \$100k for information system related projects, and are completed for those
12	projects that are provided through the optimization process, or for capital requests $\geq$
13	\$250K after the capital budget has been approved for that year. Mini business cases
14	are required for all other capital requests regardless of the point in the budget cycle.
15	
16	iii. Management and Reporting on the Capital Portfolio
17	Good governance of the capital portfolio requires a consistent approach to reviewing
18	the status of spending, controlling the additions and removals of projects and approvals
19	of over expenditures as projects progress.
20	
21	PowerStream has procedures that outline the process and approval requirements for
22	these scenarios, and these are applied on an ongoing basis.
23	
24	Future Outlook
25	PowerStream's Asset Management Planning Process continues to evolve and recent focus has
26	been on three fronts.
27	
28	First, bringing to a common level, for all assets, the practices, guidance and directives for
29	managing distribution and station asset condition information and understanding of required

2 Management Committee and Asset Strategy Committee. 3 4 Second, to continue to acquire and refine the current status of the condition of the assets 5 through refinement of the inspection and maintenance program to ensure accurate and up-to-6 data exists within the appropriate asset registers. 7 8 Third, ensuring a robust capital planning and budgeting process for all capital spending in the 9 corporation, including optimizing all capital using the same "lens". This commenced with the 10 introduction of the Copperleaf's C55 asset management product and will continue with its 11 development and refinement. 12 13 e) Outputs 14 The output of the asset management planning process is either a program or a specific project. 15 16 • *Programs:* These are annual repetitive works, such as pole remediation, that are ongoing 17 with different locations set yearly, but with the same type of work performed. 18 • Projects: Specific location and type of work that is required to be performed to meet the 19 identified need. 20 21 22

capital spend for renewal of aging assets. This will continue through the efforts of the Asset

## 1 5.3.2 OVERVIEW OF ASSETS MANAGED

- 2 3 Appropriate regulatory assessment of DS Plans requires an understanding of the scope and depth of the 4 assets managed by a distributor. Distributors vary in terms of the types of assets managed (e.g. some 5 own high voltage equipment; others do not). Detailed characteristics and data on the assets covered by 6 the asset management process are to be filed, including but not necessarily limited to: 7 8 a) a description and explanation of the features of the distribution service area (e.g. urban/rural; 9 temperate/extreme weather; underground/overhead; fast/slow economic growth) pertinent for asset 10 management purposes, highlighting where applicable expectations for the evolution of these 11 features over the forecast period that have affected elements of the DS Plan; 12 b) a summary description of the system configuration, including length (km) of underground and 13 overhead systems; number and length of circuits by voltage level; number and capacity of 14 transformer stations; 15 c) information (in tables and/or figures) by asset type (where available) on the quantity/years in service 16 profile and condition of the distributor's system assets, including the date(s) the data was compiled; 17 and 18 d) an assessment of the degree to which the capacity of existing system assets is utilized relative to 19 planning criteria, referencing the distributor's asset related objectives and targets 20 where cited as a 'driver' of a material investment(s) included in the capital expenditure plan, 21 provide a level of detail sufficient to understand the influence of this factor on the scope and value 22 of the investment. 23 24 25 **PowerStream's Service Territory** 26 PowerStream's service territory is divided into two distinct geographic regions: north and south. 27 As depicted in Figure 1, the north consists of the municipalities of Barrie, Tottenham, Thornton, 28 Alliston, Beeton Bradford and Penetanguishene. The south consists of Vaughan, Markham, 29 Richmond Hill and Aurora. 30
- As of December 31, 2013, the north territory and the south territory are described with respect to customer counts and loads, in Table 1.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 2 of 61 Delivered: February 24, 2015



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 3 of 61 Delivered: February 24, 2015

	Customer Count		
	South		
Residential	247,269	69,496	89%
Under 50 kW	25,623	6,242	
USL	2,211	679	]
Over 50 kW	3,973	816	]
Large User > 5000kW	2	0	]
Sentinel	107	0	]
SL Customers	34	9	]
Total	279,219	77,242	Ţ
		-	
S/L Conn.	69,463	16,527	Ţ

	Consumption (kWh)				
	South North				
Residential	2,100,631,280	577,688,364	32%		
Under 50 kW	825,280,512	210,335,080			
USL	SL 11,446,580 3,098,971				
Over 50 kW	3,734,870,670	782,097,326			
Large User > 5000kW	78,428,435 0				
Sentinel	363,189 0				
S/L Customers	0				
Total	6,751,020,664 1,573,219,740				

S/L Conn.	47,355,824	12,812,619

1	

# Table 1: South and North Territories Statistics

2 3

As shown in Table 1, the majority of the customer count is residential (89%), however, they
represent only about 32% of the load.

6

7 PowerStream's service territory is a mixture of urban and rural (mostly urban), as indicated in

8 Table 2.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 4 of 61 Delivered: February 24, 2015

PowerStream Service Area South							
Municipality	Rural (sq km)	Urban (sq km)	Total (sq km)	Urban %			
Markham	71	141	212	67%			
<b>Richmond Hill</b>	22	80	102	78%			
Vaughan	64	210	274	77%			
Aurora	11	38	49	78%			
Total/Average	168	469	637	74%			
Ρ	owerStream	Service Area I	North				
P Municipality		<mark>Service Area I</mark> Urban (sq km)		Urban %			
				Urban % 90%			
Municipality	Rural (sq km)	Urban (sq km)	Total (sq km)				
Municipality Barrie	Rural (sq km) 8	Urban (sq km) 69	Total (sq km) 77	90%			
Municipality Barrie Bradford	Rural (sq km) 8 0	Urban (sq km) 69 17	Total (sq km) 77 17	90% 100%			
Municipality Barrie Bradford Penetanguishene	Rural (sq km) 8 0 6	Urban (sq km) 69 17 10	Total (sq km) 77 17 16	90% 100% 63%			
Municipality Barrie Bradford Penetanguishene Tottenham	Rural (sq km) 8 0 6 5	Urban (sq km) 69 17 10 10	Total (sq km) 77 17 16 15	90% 100% 63% 67%			


1 2

Table 2: Urban / Rural Mix within PowerStream

3

4 PowerStream has been a rapidly growing LDC, particularly in the south. Refer to Figure 2.


EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 5 of 61 Delivered: February 24, 2015



3

4 Heat maps, which represent areas of expanding capacity that require additional distribution 5 system facilities, are shown in Figures 3 to Figure 8. These areas will drive expansion of the 6 distribution system.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 6 of 61 Delivered: February 24, 2015



4 5 6

Figure 4: Heat Map - Barrie

Barrie

**Distribution System Plan** 

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 7 of 61 Delivered: February 24, 2015




Figure 5: Heat Map - Bradford






**Distribution System Plan** 

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 8 of 61 Delivered: February 24, 2015









2 3 4

5

1

- 1 System Configuration
- 2 PowerStream distributes electricity through its three phase primary distribution systems. These
- 3 are the 44 kilovolt (kV) sub-transmission, the 27.6 kV primary distribution system and the 13.8
- 4 kV, 8.32 kV and 4.16 kV primary distribution systems.
- 5

6 Although PowerStream has three primary distribution voltage levels, not all voltage levels are7 available throughout the PowerStream service territories.

8

9 Sub-transmission or distribution supply circuits, known as feeders, are typically arranged to run
10 radially out from transformer stations (owned by PowerStream or Hydro One Networks Inc).
11 Transformer stations "step" the voltage down from a transmission voltage of 230kV to a voltages
12 of 44kV or 27.6 kV.

13

Open points exist between feeders and determine the feeder geographical coverage. Open points are the physical end points of a feeders, and usually represent tie points between adjacent feeders.

17

Feeders directly supply pole mounted, pad mounted or vault type distribution transformers thatreduce the operating voltage to customer levels.

20

It is not possible to define the length of individual circuits in the distribution system, as the primary distribution system is constantly being assessed and open points changed to respect operational and planning limits.


24

## 25 PowerStream South

In the south service territory (except Aurora), PowerStream services customers directly at 27.6
kV from feeders emanating from transformer stations (PowerStream owned or Hydro One
owned). In some cases, municipal substations "step" the voltage down from 27.6 kV to a lower
primary distribution voltage. There are some customers supplied at 27.6 kV in Aurora.

- 30
- 31 Figure 9 depicts the south distribution system on an high level basis.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 10 of 61 Delivered: February 24, 2015



9 For both transformer and municipal stations, values shown are for 2013 peaks, and depict asset

- 10 utilization.
- 11

1 2

3 4

5 6

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 11 of 61 Delivered: February 24, 2015

TS	Transformer Capacity	Number of Feeders	10 day LTR (MVA)	Peak (MW)	Peak (MVA)	Ratio of Peak to LTR
Markham TS#1	2 x 83 MVA	8	90	91	100	112%
Markham TS#2	2 x 83 MVA	8	112	131	137	123%
Markham TS#3	2 x 83 MVA	8	112	143	153	68%
Markham TS#3E	2 x 83 MVA	8	112			00%
Markham TS#4	2x125 MVA	12	170	99	109	64%
Richmond Hill TS#1	2x125 MVA	12	170	170	184	108%
TS#1 Richmond Hill TS#2	2x83 MVA	8	112	105	113	101%
Vaughan TS#1	2 x 125 MVA	12	170	200	223	131%
Vaughan TS#1E	2 x 125 MVA	12	170	135	151	89%
Vaughan TS#2	2 x 125 MVA	12	170	147	156	92%
Vaughan TS#3	2 x 125 MVA	12	170	150	163	96%
Total		112	1,558	1,371	1,490	96%

1 2

Table 3: PowerStream South: PowerStream Owned Transformer Stations


3

TS	Number of Feeders	Feeder Rating (MVA)	Peak (MW)	Peak (MVA)	Ratio of Peak to LTR
Agincourt TS*	2	30	0	0	0%
Leslie TS	3	45	31	34	77%
Fairchild TS*	3	45	19	21	47%
Finch TS	2	30	9	10	33%
Woodbridge TS	4	60	47	52	87%
Buttonville	12	170	103	106	62%
Kleinburg	2	30	2	2	6%
Total	28	410	211	225	55%

Table 4: PowerStream South: Hydro One Owned Transformer Stations

\* 2 feeders were out of service in 2013

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 12 of 61 Delivered: February 24, 2015



3

1 2

4 Transformer Stations

5 The optimal ratio of peak to limited time rating (LTR) is 90% to 95%. This leaves capacity for 6 high loading periods. Values that exceed 95% are not desirable.

7

8 The transformer's LTR 10 day is used as the transformer station loading guide line for following9 reasons:

10

If one transformer fails in a typical dual element spot network (DESN) station, the
 remaining transformer will carry the load of the entire station. The transformer will lose

1	2% additional life in 10 days if it loaded at its LTR rating. It is not desirable to degrade
2	the transformer's life on purpose;
3	• Replacing the failed transformer with a system spare transformer is estimated to take 10
4	days; and
5	• For a transformer outage longer than 10 days, the transformer loading must be brought
6	to its name plate rating. This can be accomplished by load transfers of above name
7	rating to adjacent stations or by load shedding.
8	
9	Where the values in Table 3 are low (64%) at MTS#4 (the newest station), new developments in
10	the area will be adding capacity in the near term. The same is true for MTS#3 (68%).
11	
12	Where the values in Table 4 were low (0% and 47%) these Hydro One feeders were out of
13	service during the 2013 peak loading, and the loads appeared on the stations that were above
14	100% as seen in Table 3.
15	
16	Where the values above in Table 4 were low (6% and 33%), new developments in the area will
17	be adding capacity in the near term.
18	
19	In summary, the transformer station assets are, or are soon to be, at optimal limits. They are
20	being prudently utilized.
21	
22	Municipal Substations
23	Figures 11-13 detail the locations of the south municipal substations.
24	
25	

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 14 of 61 Delivered: February 24, 2015



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 15 of 61 Delivered: February 24, 2015



2 3

1

Table 5 indicates the loading on the south municipal substations. The south municipal sub-4 5 stations are lightly loaded. The loads on these stations have been passively converted to the 6 27.6 kV system as development and system changes occur.

MS Name	Transformer ID	Transformer Capacity	Peak (MVA)	Ratio of Peak to Name Plate Rating	Municipality
Amber MS	T1	10	3.0	19%	
John MS	T2	10	0.8	5%	
	T1	10	0.8	5%	
30111103	T2	10	3.7	23%	Markham
Morgan MS	T1	5	0.8	5%	
Baythorn MS	T1	7.5	0.4	3%	
Baythom WS	T2	7.5	3.8	24%	
King MS**	T1	5	1.5	9%	
Concord MS	T1	15	4.6	29%	Vaughan
Elder Mills MS**	T1	5	0.5	3%	
AMS#1	T1	10/13/16	6	37%	
AINIS#1	T2	10/13/16	8	48%	
AMS#2	T1	10/13/16	11	68%	
	T1	10/13/16	7	42%	
AMS#3	T2	10/13/16	11	66%	
AMS#4	T1	10/13/16	9	56%	
AM5#4	T2*	10/13/16	0	0%	Aurora
	T1	10/13/16	7	42%	
AMS#5	T2	10/13/16	5	30%	
AM8#6	T1	10/13/16	11	66%	
AMS#6	T2*	10/13/16	0	0%	
AMS#7	T1 (44/27.6kV)	10/13	1	5%	
AMS#8	T1 (44/27.6kV)	10/13	4	31%	

## 1 2

## Table 5: PowerStream South Municipal Substations

3

In 2015, a study will be performed to develop a long term strategy for conversion of the low
voltage systems to the 28kV system.

6

# 7 PowerStream North

8 PowerStream's north territory is characterized by a 44kV sub-transmission feeder distribution
9 system serviced from Hydro One owned transformer stations. These feeders are the primary

10 supply for the sub-stations that step-down a lower primary voltage for distribution. Refer to

Table 6 to Table 9 and Figure 14 to Figure 20. Values shown are for 2013 peaks and depictasset utilization.

3

In the north service territory (including Aurora), on the 44 kV sub-transmission system, PowerStream services directly multiple municipal substations and multiple customer-owned substations. The municipal substations transform the 44 kV sub-transmission voltage to primary distribution voltages of 4.16 kV, 8.32 kV and 13.8 kV. Direct customer connections are at the 44kV level, and are used for connections above a connected kVA load threshold.

- 9
- 10

Region	MS Name	Station Name	Number of Feeders	Transformer Capacity (ONAN/Max/Contingenc y)	2013 Peak (MVA)	Ratio of Peak to Contingency TX Rating in 2013	N-1 Contingency Ratio in 2013	Load of Proposed Developments and Annual Growth by 2018 (MVA)	N-1 Contingency Ratio with Developments by 2018
Barrie North	MS301 (13.8kV)	Anne North	4	22.5/25/39.9	13.2	33%	75%	8.8	97%
(13.8kV)	MS306 (13.8kV)	Little Lake	4	22.5/25/39.9	16.9	42%	7370	0.0	9776
Derrie Ceuth	MS303 (13.8kV)	Ferndale South	4	22.5/25/33.5	21.4	64%			
Barrie South-	MS305 (13.8kV)	Holly	4	22.5/25/33.5	23	69%	90%	4.6	97%
West (13.8kV)	MS302 (13.8kV)	Saunders	4	22.5/25/39.9	15.7	39%			
Devide Centl	MS307 (13.8kV)	Huronia	3	11.2/18.8/24.7	10.8	44%			
Barrie South-	MS304 (13.8kV)	Big Bay Point	4	22.5/25/39.9	23.5	59%	79%	6.2	88%
East (13.8kV)	MS308 (13.8kV)	Park Place	4	22.5/25/39.9	16.5	41%			
	MS406 (4.16kV)	Burton	3	5/7.6	3.6	47%	64%		73%
Barrie Allandale	MS414 (4.16kV)	Little	2	5.6/7.6	2.9	38%		1.4	
(4.16kV)	MS411 (4.16kV)	Innisfil	3	5/7.6	3.2	42%			
	MS410 (4.16kV)	Ferndale	2	5/7.6	3.5	46%			
Barrie West	MS402 (4.16kV)	Anne Temp	2	5.6/7.6	3.8	50%	85%	1.8	97%
Village (4.16kV)	MS413 (4.16kV)	Letitia	3	5/7.6	5.6	74%			
Barrie	MS405 (4.16kV)	Brock	4	11.2/15.1	4.9	32%			
Downtown	MS419 (4.16kV)	Perry	4	11.2/15.1	6.6	44%	59%	2.6	68%
(4.16kV)	MS415 (4.16kV)	Mary	4	11.2/15.1	6.4	42%			
	MS408 (4.16kV)	Cundles West	3	5/7.6	3.5	46%			
Barrie Queens	MS407 (4.16kV)	Cundles East	3	5/7.6	3.7	49%	79%	1.7	90%
Park (4.16kV)	MS409 (4.16kV)	Duckworth	3	5/7.6	4.8	63%			
	MS418 (4.16kV)	Wellington	4	11.2/15.1	6.8	45%			
Barrie Grove	MS417 (4.16kV)	St. Vincent	4	11.2/15.1	6.5	43%			
(4.16kV)	MS404 (4.16kV)	Blake	4	11.2/15.1	4.4	29%	56%	3.0	64%
· ·	MS412 (4.16kV)	Johnson	2	5/7.6	3.4	45%			

Table 6: PowerStream North - Barrie Municipal Substations

- 11
- 12 13
- . .
- 14
- 15

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 18 of 61 Delivered: February 24, 2015

Region	MS Name	Station Name	Number of Feeders	Transformer Capacity (ONAN/Max/Contingenc y)	Peak (MVA)	Ratio of Peak to Contingency TX Rating	N-1	Load of Proposed Developments and Annual Growth by 2018 (MVA)	Ratio with
	MS321 (13.8kV)	John	4	10/13.3/18	6.4	36%			
Bradford	MS322 (13.8kV)	Melbourne	3	10/13.3/18	9.8	54%	62%	10.3	040/
Brautoru	MS323 (13.8kV)	8th Line	3	10/13.3/18	9.6	53%	02%	10.5	81%
	MS324 (13.8kV)	Reagans	3	11.2/15/20.2	7.8	39%	1		

Table 7: PowerStream North - Bradford Municipal Substations

1 2

#### ~

# 3

#### 4

Region	MS Name	Station Name	Number of Feeders	Transformer Capacity (ONAN/Max/Contingenc y)	Peak (MVA)	Ratio of Peak to Contingency TX Rating	N-1 Contingency Ratio	Load of Proposed Developments and Annual Growth by 2018 (MVA)	Contingency Ratio with
	MS330 (13.8kV)	8th Avenue	2	11.2/15.1	10	66%			101%
Alliston (13.8kV)	MS331-T1 (13.8kV)	14th Line	2	11.2/15/20.2	8.7	43%	74%	9.5	
	MS331-T2 (13.8kV)	14th Line	2	11.2/15/20.2	7.3	36%			
	MS431 (4.16kV)	Dufferin	3	5/7.6	2.4	32%	700/	1.0	020/
Alliston (4.16kV)	MS432 (4.16kV)	Fletcher	2	5/7.6	3.6	47%	79%		92%
Beeton (13.8kV)	MS336 (13.8kV)	Patterson	2	7.5/10.1	4.8	48%	48%	2.2	69%
Tottenham	MS834 (8.32kV)	Nolan	2	10/15.2	4	26%	77%	3.2	112%
(8.32kV)	MS835 (8.32kV)	Mill	2	6/9.1	3	33%	11%	3.2	112%

## 5 6

# Table 8: PowerStream North – New Tecumseth Municipal Substations

- 7
- 8

Region	MS Name	Station Name	Number of Feeders	Transformer Capacity (ONAN/Max/Contingenc y)	Peak (MVA)	Ratio of Peak to Contingency TX Rating	N-1 Contingency	Load of Proposed Developments and Annual Growth by 2018 (MVA)	Contingency Ratio with
	MS421 (4.16kV)	Fox	2	5.6/7.6	3.4	45%			
Penetanguishene	MS422 (4.16kV)	Robert	2	5.6/7.6	2.8	37%	F-20/	1.0	<b>CO</b> 24
(4.16kV)	MS423 (4.16kV)	Bellisle	2	5.6/7.6	3.4	45%	53%	1.6	60%
	MS424 (4.16kV)	Centennial	4	6/9.1	2.5	27%			

Table 9: PowerStream North – Penetanguishene Municipal Substations

# 9

- 10
- 11

PowerStream's system planning philosophy for municipal sub-stations in the north requires a "triad" model of supply – where at least three stations (or 3 transformers) are tied together through open points such that loss if one station is lost, all load from the triad supplied stations can be supplied by the remaining stations. This criteria considers individual substation transformer ratings as well as the network's contingency capacity. The triad model ensures that adequate capacity is available at adjacent substations during contingency conditions in which
 there is a loss of a single substation in the network (N-1 scenario).

3

4 To determine the municipal substation utilization factor for networks that adhere to the triad 5 model, the historical peak substation loading should be evaluated against the combined 6 contingency maximum load capacity of N-1 substations divided by the total number of 7 substations in the area:

- 8
- N-1\*(Contingency Maximum Load [MVA])/N.
- 9 10

For example, if a service territory has four 10MVA substations with Oil Natural Air Forced (ONAF cooling), maximum normal load, and contingency maximum load (dual fan) ratings of 13 10MVA, 13.3MVA and 18MVA, respectively, then the substation utilization factor would be a 14 ratio of the historical peak substation loading to the combined contingency maximum load of all 15 remaining substations operating during the loss of a single substation divided by the total 16 number of available substations under normal operating conditions:

- 17
- 18

• historical peak loading/(18MVA\*[4-1]/4).

19

The "N-1 Contingency Ratio in 2013" column illustrates the utilization factor for each region in the service territory relative to the adjacent substations during contingency conditions when a substation is out of service and loads must be distributed to surrounding stations. The N-1 Contingency Ratio uses the contingency maximum rating at the substation. Regions were established based on the existing feeder network and transfer capability during contingency conditions.

26

The "Load of Proposed Developments and Annual Growth by 2018 (MVA)" column indicates the amount of load growth expected to be experienced in each region until 2018. For those regions where large developments are proposed or currently under construction the total load was used, while all other regions assumed the annual growth rate identified in the PowerStream North Load Forecast. It should be noted that 2018 was selected as the load growth horizon since PowerStream requires a minimum of three years to construct a new substation (Year 1: land
 purchase, Year 2: design, Year 3: construct), therefore the analysis assumes a land purchase in
 2015.

4

5 The "N-1 Contingency Ratio with Developments by 2018" column was added to illustrate the 6 utilization factor in each respective region by 2018 following the implementation of the 7 forecasted load.

8


9 The optimal ratio of "N-1 Contingency Ratio with Developments by 2018" is 90%, to leave room 10 for high loading periods. Higher values are not desirable. Based on these ratios, the substations 11 are being prudently utilized. As noted in Exhibit 2, Tab 2, Section 5.4.5, additional stations are 12 included in this DSP to meet the triad criteria.

13



16 17

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 21 of 61 Delivered: February 24, 2015



3 4 5

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 22 of 61 Delivered: February 24, 2015





Figure 17: Bradford Substation Locations

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 23 of 61 Delivered: February 24, 2015



1	
2	Figure 18: Penetanguishene Substation Locations
3	

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 24 of 61 Delivered: February 24, 2015



# Figure 19: Thornton Substation Locations





1 2 3



## 1 Asset Inventory

- 2 The summary inventory of major assets, including quantity, age and serviceability, are found in
- 3 Figures 21 to 50. A summary of the quantity of distribution system assets is shown in Tables 10
- 4 and 11.
- 5
- 6

PowerStream ACA 2014 Asset Counts							
Asset	Total						
Distribution Transformer	44,112						
Distribution Switchgear	1,821						
Wood Poles	38,070						
Underground Primary Cable (km)	8,220						
Min-Rupter Switch	433						
Automated Switch	360						

Table 10: Summary of Distribution System Assets

8 9


7

10

PowerStream ACA 2014 Asset Counts									
Asset		Total							
Power Transformers	TS	24							
Power mansformers	MS	72							
Circuit Breakers	TS	188							
CITCUIL Breakers	MS	210							
Drimony Switches	MS         210           TS         22           MS         58	22							
Primary Switches	MS	58							
220k) / Drimony Moting Units	combined	18							
230kV Primary Meting Units	separate	12							
Station Reactors	TS	34							
Station Service Transformers	TS	20							
includes spares									

Table 11: Summary of Station Assets

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 26 of 61 Delivered: February 24, 2015



2 3

1

4 Figure 21 indicates that there are thirteen power transformers that are 22 years and older, and

5 nine power transformers between 6 and 13 years old.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 27 of 61 Delivered: February 24, 2015

Location	Position	Manufacturer	MVA Nameplate	Age	Health Index Category	Health Index
Lazenby MTS1 - Richmond Hill MTS#1	T1	Hyundai	125	24	Good	74
J.V. Fry - Markham MTS#1	T1	Ferranti Packard	83	29	Good	75
Greenwood -Vaughan MTS #1	T2	ΠI	125	26	Good	75
A.M. Walker - Markham MTS#2	T1	ΠI	83	27	Good	75
Lazenby MTS1 - Richmond Hill MTS#1	T2	Hyundai	125	24	Good	75
Lazenby MTS2 - Richmond Hill MTS#2	T1	Pauwels	83	14	Good	77
D.H. Cockburn - Markham MTS#3 Expansion	T4	Pauwels	83	11	Good	77
D.H. Cockburn - Markham MTS#3 Expansion	T3	Pauwels	83	11	Good	77
D.H. Cockburn - Markham MTS#3	T2	ABB	83	24	Good	78
D.H. Cockburn - Markham MTS#3	T1	ABB	83	24	Good	78
A.M. Walker - Markham MTS#2	T2	Π	83	27	Good	78
Torstar - Vaughan MTS #2	T1	ABB	125	24	Good	79
Lazenby MTS2 - Richmond Hill MTS#2	T2	Pauwels	83	14	Good	80
Greenwood -Vaughan MTS #1 Expansion	T4	ABB	125	10	Good	81
J.V. Fry - Markham MTS#1	T2	Ferranti Packard	83	29	Good	82
Greenwood -Vaughan MTS #1	T1	ΠI	125	26	Good	85
Lorna Jackson - Vaughan MTS #3	T2	ABB	125	14	Good	85
Fabro TS -Markham TS#4	T1	ABB	125	7	Good	85
Fabro TS -Markham TS#4	T2	ABB	125	7	Good	85
Greenwood -Vaughan MTS #1 Expansion	T3	ABB	125	23	Very Good	86
Torstar - Vaughan MTS #2	T2	ABB	125	24	Very Good	89
Lorna Jackson - Vaughan MTS #3	T1	ABB	125	14	Very Good	91
D.H.Cochburn	Spare	Siemens	83	6	Very Good	98
Greenwood	Spare	ABB	125	6	Very Good	98

1


2

3

# Figure 22: Health Index - Transformer Station Power Transformers

4 Figure 22 indicates that the power transformers are either in good or very good health.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 28 of 61 Delivered: February 24, 2015



4 Figure 23 indicates that substation power transformers are widely dispersed in age, from new to 56 years of age.

- 5
- 6 7

1 2


- 8

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 29 of 61 Delivered: February 24, 2015

Location	Position	Status	Manufacturer	MVA Nameplate	Age	Health Index Category	Health Index
Melborne-322-T1	322-T1	Inservice	Federal Pioneer	10	39	Fair	64
BLAKE-404-T1	404-T1	Inservice		10	26	Good	72
John-321-T1	321-T1	Inservice	Moloney	10	38	Good	73
Dufferin-431-T1	431-T1	Inservice	Westinghouse	5	54	Good	73
8th Line-323-T1	323-T1	Inservice	Northern	10	25	Good	75
CUNDLES EAST-407-T1	407-T1	Inservice	General Electric	5	52	Good	78
ST. VINCENT-417-T1	417-T1	Inservice	 Π	10	28	Good	78
WELLINGTON-418-T1	418-T1	Inservice	Π	10	24	Good	78
Nolan-834-T1	834-T1	Inservice	Westinghouse	10	30	Good	78
LITTLE LAKE-306-T1	306-T1	Inservice	Federal Pioneer	20	25	Good	79
MARY-415-T1	415-T1	Inservice		10	25	Good	79
Bellisle-423-T1	423-T1	Inservice	Porter	5	40	Good	80
FERNDALE-410-T1	410-T1	Inservice	Westinghouse	5	30	Good	82
PERRY -419-T1	419-T1	Inservice	Federal Pioneer	10	24	Good	82
Centennial-424-T1	424-T1	Inservice	Markham Electric	6	22	Good	82
Mill St835-T1	835-T1	Inservice	Markham Electric	6	40	Good	82
Aurora MS#1-T2	T2	Inservice	FPE	7.5	39	Good	83
Aurora MS#3-T2	T2	Inservice	Northern Transformer	10	9	Good	83
ANNE TEMP-402-T1	402-T1	Inservice	C.G.E.	5	49	Good	83
Aurora MS#2-T1	T1	Inservice	Ferranti Packard	10	36	Good	84
ANNE NORTH-301-T1	301-T1	Inservice	Federal Pioneer	20	26	Good	84
BIG BAY POINT-304-T1	304-T1	Inservice	Federal Pioneer	20	25	Good	84
8th Ave-330-T1	330-T1	Inservice	Northern	10	24	Good	84
CUNDLES WEST-408-T1	408-T1	Inservice	Federal Pioneer	5	40	Good	84
INNISFIL-411-T1	411-T1	Inservice	Federal Pioneer	5	38	Good	84
JOHNSON-412-T1	412-T1	Inservice	Federal Pioneer	10	28	Good	84
LETITIA-413-T1	413-T1	Inservice	Federal Pioneer	5	38	Good	84
LITTLE-414-T1	414-T1	Inservice	C.G.E.	5	43	Good	84
Patterson-336-T1	336-T1	Inservice	B.G. High Voltage	7.5	25	Good	85
DUCKWORTH-409-T1	409-T1	Inservice	Westinghouse	5	47	Good	85
Amber MS-T2	T2	Inservice	Northern Transformer	7.5	39	Very Good	86
Amber MS-T1	T1	Inservice		10	41	Very Good	87
Aurora MS#3-T1	T1	Inservice	Northern Transformer	10	45	Very Good	87
Baythorn MS-T2	T2	Inservice	West	10	9	Very Good	87
John Street MS-T1	T1	Inservice	West	10	43	Very Good	87
Concord MS-T1	T1	Inservice	West	10	42	Very Good	88
Morgan MS-T2	T2	Inservice	West	5	42	Very Good	88
Aurora MS#6-T1	T1	Inservice	Northern Transformer	10	54	Very Good	89
FERNDALE SOUTH-303-T1	303-T1	Inservice	Federal Pioneer	20	9	Very Good	89
BROCK-405-T1	405-T1	Inservice		10	26	Very Good	89
BURTON-406-T1	406-T1	Inservice	Molonev	5	25	Very Good	89
Robert-422-T1	422-T1	Inservice	Federal Pioneer	5	29	Very Good	89
Aurora MS#5-T2	T2	Inservice	Moloney	5	41	Very Good	91
Reagans-324-T1	324-T1	Inservice	Northern	10	38	Very Good	91
Aurora MS#4-T1	T1	Inservice	Moloney	10	41	Very Good	92
Aurora MS#5-T1	T1	Inservice	Federal Pioneer	10	16	Very Good	92
John Street MS-T2	T2	Inservice	Ferranti Packard	5	25	Very Good	92
King MS-T1	T1	Inservice	Ferranti Packard	10	19	Very Good	92
SAUNDERS-302-T1	302-T1	Inservice	Federal Pioneer	20	31	Very Good	92
HURONIA-307-T1	307-T1	Inservice	Northern	10	26	Very Good	92
14th Line-331-T2	331-T2	Inservice	Northern	10	1	Very Good	92
Fox-421-T1	421-T1	Inservice	ABB	5	11	Very Good	92
Aurora MS#4-T2	T2	Inservice	Northern Transformer	10	18	Very Good	93
Aurora MS#6-T2	T2	Inservice	Northern Transformer	10	13	Very Good	93
Baythorn MS-T1	T1	Inservice	Federal Pioneer	10	19	Very Good	93
Aurora MS#1-T1	T1	Inservice	Northern Transformer	10	26	Very Good	94
Aurora MS#8-T1	T1	Commiss	Ferranti Packard	10	18	Very Good	94
HOLLY-305-T1	305-T1	Inservice	Ferranti	20	15	Very Good	94
Park Place-308-T1	308-T1	Inservice	Ferranti	20	15	Very Good	94
						,	
Aurora MS#7-T1	T1	Commiss	Moloney	5	38	Very Good	95

# Figure 24: Health Index - Substation Power Transformers

- 1 Figure 24 indicates that only one of the distribution power transformers is in fair condition, with
- 2 all others in good or very good condition.
- 3




- 8 ag
- 9

4 5

- 10
- 11

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 31 of 61 Delivered: February 24, 2015




# **PowerStream Station Circuit Breaker**

#### Figure 26: Health Condition – Circuit Breakers

2 3

- Figure 26 indicates that the vast majority of circuit breakers are in good or very good condition, 4
- 5 and 56 breakers range from fair to very poor.
- 6 7

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 32 of 61 Delivered: February 24, 2015



#### Figure 27: Installation Dates: Transformer Station 230kV Disconnect Switches

2 3

4 Figure 27 indicates that the 230 kV disconnect switches are widely dispersed in age, from two to

- 5 28 years of age.
- 6
- 7

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 33 of 61 Delivered: February 24, 2015

Transformer Station	Switch Designation	Manufacturer	Switch Type	Age	Health Index Category	Health Index
J.V. Fry - Markham MTS#1	8122T1-P21R	Markham Electric	4415-9 or	6	Good	81
J.V. Fry - Markham MTS#1	8122T2-P22R	Markham Electric	AA-0036	6	Good	81
D.H. Cockburn - Markham MTS#3	8126T1-C35P	Southern States	EV-2	6	Good	81
D.H. Cockburn - Markham MTS#3	8126T2-C36P	Southern States	EV-2	6	Good	81
Lazenby MTS1 - Richmond Hill MTS#2	8136T3-V71RP	GS T&D	AVB2301200M	9	Good	83
Lazenby MTS1 - Richmond Hill MTS#2	8136T4-V75RP	GS T&D	AVB2301200M	9	Good	83
A.M. Walker - Markham MTS#2	8124T1-C35P	Markham Electric	4415-9 or	6	Very Good	88
A.M. Walker - Markham MTS#2	8124T2-C36P	Markham Electric	AA-0036	6	Very Good	88
Torstar - Vaughan MTS #2	5121T1-V71RP	ABB	TTR-6	6	Very Good	91
Torstar - Vaughan MTS #2	5121T2-V75RP	ABB	TTR-6	6	Very Good	91
Lorna Jackson - Vaughan MTS #3	5122T1-V75RP	Alstom	CGVB	9	Very Good	98
Lorna Jackson - Vaughan MTS #3	5122T2-V74R	Alstom	CGVB	9	Very Good	98
D.H. Cockburn - Markham MTS#3 Expansion	8126T3-C35P	S&C	197031-BE12H1KMPTUVW1Y	9	Very Good	98
D.H. Cockburn - Markham MTS#3 Expansion	8126T4-C36P	S&C	197031-BE12H1KMPTUVW1Y	9	Very Good	98
Greenwood -Vaughan MTS #1	5120T1-V71RP	Southern States	EV-2	12	Very Good	100
Greenwood -Vaughan MTS #1	5120T2-V75RP	Southern States	EV-2	12	Very Good	100
Greenwood -Vaughan MTS #1 Expansion	5120T3-V71RP	Southern States	EV-2	12	Very Good	100
Greenwood -Vaughan MTS #1 Expansion	5120T4-V75RP	Southern States	EV-2	12	Very Good	100
Lazenby MTS1 - Richmond Hill MTS#1	8127T1-V71RP	Southern States	EV-2	12	Very Good	100
Lazenby MTS1 - Richmond Hill MTS#1	8127T2-V75RP	Southern States	EV-2	12	Very Good	100
Fabro TS - Markham TS#4	7110T1-P45	Southern States	EV-2	12	Very Good	100
Fabro TS - Markham TS#4	7110T2-P46	Southern States	EV-2	12	Very Good	100


2 Figure 28: Health Indices: Installation Dates: Transformer Station 230kV Disconnect Switches

3

1

4 Figure 28 indicates that all of the 230kV disconnect switches are in good or very good health.

5



## **PowerStream MS Primary Switch**

- 1 Figure 29 indicates that that substation primary disconnect switches are widely dispersed in
- 2 age, from four to 56 years of age.
- 3
- 4

Municipal Station	Switch ID	Switch Type		Switch Manufacturer	Fuse Type	Fuse Size	Primary Voltage	Age	Health Index Category	Health Inde
1S431-Dufferin	AB-431	Pole Mounted 46 kV ABS	Pole		SMD-2C	80E-119-1	44	54	Good	73
IS307 - Huronia Rd	AB-307	Pole Mounted 46 kV ABS	Pole		SMD-2C	300E-153-1	44	12	Good	73
ing MS	KINGT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	1A	125E	27.6	54	Good	74
S432-Fletcher	AB-432	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-153-1	44	44	Good	75
S305 - Holly	AB-305	Pole Mounted 46 kV ABS	Pole			N/A	44	15	Good	75
S406 - BURTON AVE	AB-406	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	41	Good	75
S409-Duckworth	AB-409	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-153-1	44	47	Good	75
S413 - Letitia	AB-413	Pole Mounted 46 kV ABS	Pole		SMD-2C	150E-153-1	44	38	Good	75
S418-Wellington	AB-418	Pole Mounted 46 kV ABS	Pole		SMD-2C	150E-119-1	44	41	Good	75
S423-Bellisle	AB-423	Pole Mounted 46 kV ABS	Pole		SMD-2C	80E-119-1	44	40	Good	75
S835-MILL St.	AB-835	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-153-1	44	40	Good	75
urora MS#2	AURMS2T1_SW1	46 kV Metalclad ALDUTI LIS	Enclosure	S&C Electric	SMD 2C	200E	44	8	Good	76
S404 - Blake	AB-404	Pole Mounted 46 kV ABS	Pole	Cao Liocaio	SMD-2C	200E-153-1	44	26	Good	77
S405-Brock	AB-405	Pole Mounted 46 kV ABS	Pole		SMD-2C	200E-153-1	44	26	Good	77
S410 - FERNDALE DR	AB-400	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	30	Good	77
S415-T1-Mary	LT-415	Pole Mounted 46 kV ABS	Pole		31VID-20	N/A	44	25	Good	77
S415 - St. Vincent	AB-417	Pole Mounted 46 kV ABS	Pole		SMD-2C	200E-153-1	44	25	Good	77
				S&C			44 44	28		
S336-Patterson	LT-336	46 kV Metalclad ALDUTI LIS	Enclosure	540	SMD-2C	150E-153-1	44		Good	77
S422-Robert	AB-422	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-153-1		29	Good	77
mber MS	AMBERT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	200E	27.6	43	Good	78
ohn Street MS	JOHNT1_SW1	SMD-40	Enclosure	S&C Electric	SMU-40	250E	27.6	41	Good	78
hn Street MS	JOHNT2_SW2	SMD-40	Enclosure	S&C Electric	SMU-40	250E	27.6	41	Good	78
urora MS#5	AURMS5T2_SW2	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Good	78
S330-8th Ave.	LT-330	46 kV Metalclad ALDUTI LIS	Enclosure	S&C	SMD-2C	150E-119-1	44	24	Good	78
S308 - Park Place	AB-308	Pole Mounted 46 kV ABS	Pole			N/A	44	5	Good	79
S407-Cundles East	AB-407	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	52	Good	79
S321-John	AB-321	Pole Mounted 46 kV ABS	Pole	Dominion Cutout	SMD-2C	150E-119-1	44	38	Good	79
S322-Melborne	AB-322	Pole Mounted 46 kV ABS	Pole		SMD-2C	150E-119-1	44	39	Good	79
S421-Fox	AB-421	Pole Mounted 46 kV ABS	Pole		SMD-2C	80E-119-1	44	18	Good	79
aythorn MS	BAYTHT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	300E ?	27.6	39	Good	80
aythorn MS	BAYTHT2 SW2	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	300E ?	27.6	39	Good	80
oncord MS	CONCT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	Unknown	27.6	15	Good	80
urora MS#3	AURMS3T2 SW2	46 kV Metalclad ALDUTI LIS	Enclosure	S&C Electric	SMD 2C	200E	44	8	Good	80
IS402 - ANNE TEMP	AB-402	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	49	Good	81
S408-Cundles West	LT-408	Pole Mounted 46 kV ALDUTI LIS	Pole	S&C	SMD-2C	100E-119-1	44	40	Good	81
S411 - INNISFIL ST	AB-411	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	38	Good	81
S412-Johnson	LT-412	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	28	Good	81
S414 - LITTLE AVE	AB-414	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-119-1	44	43	Good	81
S414 - LITTLE AVE S419 - PERRY ST	AB-414 AB-419		Pole		SIVID-20	N/A	44	43 24		81
S323-8th Line	LT-323	Pole Mounted 46 kV ABS Enclosed S&C 46KV LIS	Pole	S&C	SMD-2C	150E-119-1	44	24	Good Good	81
organ MS	MORGT2_SW2	SMD-20	Enclosure	S&C Electric	SMU-20	100K	27.6	38	Good	82
urora MS#3	AURMS3T1_SW1	46 kV Metalclad ALDUTI LIS	Enclosure	S&C Electric	SMD 2C	200E	44	8	Good	82
urora MS#4	AURMS4T1_SW1	46 kV Metalclad ALDUTI LIS	Enclosure	S&C Electric	SMD 2C	200E	44	8	Good	82
urora MS#4	AURMS4T2_SW2	46 kV Metalclad ALDUTI LIS	Enclosure	S&C Electric	SMD 2C	200E	27.6	8	Good	82
urora MS#5	AURMS5T1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Good	82
S324-Reagens	LT-324	Pole Mounted 46 kV ALDUTI LIS	Pole	S&C	SMD-2C	175E-119-1	44	16	Good	83
S424-Centennial	AB-424	Pole Mounted 46 kV ABS	Pole		SMD-2C	100E-153-1	44	22	Good	84
S834-Nolan Rd.	AB-834	Pole Mounted 46 kV ABS	Pole		SMD-2C	150E-153-1	44	30	Good	84
organ MS	MORGT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	125E	27.6	38	Very Good	88
der Mills MS	ELDERT1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SM-5	200E	27.6	57	Very Good	91
urora MS#6	AURMS6T1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Very Good	93
urora MS#6	AURMS6T2_SW2	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Very Good	93
urora MS#1	AURMS1T2_SW2	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Very Good	96
urora MS#1	AURMS1T1 SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Very Good	100
urora MS#7	AURMS7T1_SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E	44	8	Very Good	100
urora MS#8	AURMS8T1 SW1	Outdoor Pole Mounted 46 kV ALDUTI LIS	Pole	S&C Electric	SMD 2C	200E		8	Very Good	100
S331-T1-14TH LINE	LT-331-T1	Pole Mounted 46 kV ALDUTI LIS	Pole	S&C	SMD-2C	300E-153-1	44	11	Very Good	100
COOL IN THIS LINE	LT-331-T2	Pole Mounted 46 kV ALDUTI LIS	Pole	S&C	SMD-2C	300E-153-1	44	11	Very Good	100

5 6

Figure 30: Health Indices: Substation Primary Disconnect Switches


7

8 Figure 30 indicates that all of the substation primary disconnect switches are in good or very

9 good health.

- 10
- 11

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 35 of 61 Delivered: February 24, 2015



10 Figure 32 indicates that all capacitor banks are either in good or very good condition.

1 2


3

4 5 6

7

8

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 36 of 61 Delivered: February 24, 2015



4 Figure 33 indicates that the station reactors are widely dispersed in age, from four to 28 years of age.

- 5
- 6

1 2

3

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 37 of 61 Delivered: February 24, 2015

Transformer Ofsilen News	Transformer	nsformer Manufacturer		Health Index	Health
Transformer Station Name	ID	Manufacturer	Age	Category	Index
A.M. Walker - Markham MTS#2	T1	Trench	27	Very Good	96
A.M. Walker - Markham MTS#2	T2	Trench	27	Very Good	96
D.H. Cockburn - Markham MTS#3	T1	Trench	23	Very Good	96
D.H. Cockburn - Markham MTS#3	T2	Trench	23	Very Good	96
D.H. Cockburn - Markham MTS#3 Expansion	T3	Trench	11	Very Good	96
D.H. Cockburn - Markham MTS#3 Expansion	T4	Trench	11	Very Good	96
Fabro TS - Markham TS#4	T1X	Trench	5	Very Good	96
Fabro TS - Markham TS#4	T1Y	Trench	5	Very Good	96
Fabro TS - Markham TS#4	T2X	Trench	5	Very Good	96
Fabro TS - Markham TS#4	T2Y	Trench	5	Very Good	96
Greenwood -Vaughan MTS #1	T1X	Trench	26	Very Good	96
Greenwood -Vaughan MTS #1	T1Y	Trench	26	Very Good	96
Greenwood -Vaughan MTS #1	T2X	Trench	26	Very Good	96
Greenwood -Vaughan MTS #1	T2Y	Trench	26	Very Good	96
Greenwood -Vaughan MTS #1 Expansion	T3X	Trench	9	Very Good	96
Greenwood -Vaughan MTS #1 Expansion	T3Y	Trench	9	Very Good	96
Greenwood -Vaughan MTS #1 Expansion	T4X	Trench	9	Very Good	96
Greenwood -Vaughan MTS #1 Expansion	T4Y	Trench	9	Very Good	96
J.V. Fry - Markham MTS#1	T1	Trench	29	Very Good	96
J.V. Fry - Markham MTS#1	T2	Trench	29	Very Good	96
Lazenby MTS1 - Richmond Hill MTS#1	T1X	Trench	23	Very Good	96
Lazenby MTS1 - Richmond Hill MTS#1	T1Y	Trench	23	Very Good	96
Lazenby MTS1 - Richmond Hill MTS#1	T2X	Trench	23	Very Good	96
Lazenby MTS1 - Richmond Hill MTS#1	T2Y	Trench	23	Very Good	96
Lazenby MTS2 - Richmond Hill MTS#2	T1	Trench	13	Very Good	96
Lazenby MTS2 - Richmond Hill MTS#2	T2	Trench	13	Very Good	96
Lorna Jackson - Vaughan MTS #3	T1X	Trench	14	Very Good	96
Lorna Jackson - Vaughan MTS #3	T1Y	Trench	14	Very Good	96
Lorna Jackson - Vaughan MTS #3	T2X	Trench	14	Very Good	96
Lorna Jackson - Vaughan MTS #3	T2Y	Trench	14	Very Good	96
Torstar - Vaughan MTS #2	T1X	Trench	23	Very Good	96
Torstar - Vaughan MTS #2	T1Y	Trench	23	Very Good	96
Torstar - Vaughan MTS #2	T2X	Trench	23	Very Good	96
Torstar - Vaughan MTS #2	T2Y	Trench	23	Very Good	96

Figure 34: Health Indices: Station Reactors


1 2

2

3

Figure 34 indicates that all the station reactors are in very good health.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 38 of 61 Delivered: February 24, 2015



4 Figure 35 indicates that the station service transformers are widely dispersed in age, from four

- 5 to 28 years of age.
- 6

1

- 7
- 8

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 39 of 61 Delivered: February 24, 2015

TS ID	Power Transformer ID	SS Transformer Rating (KVA)	Age	Health Index	Health Index Category
J.V. Fry - Markham MTS#1	T1	225	29	75	Good
J.V. Fry - Markham MTS#1	T2	225	29	75	Good
A.M. Walker - Markham MTS#2	T1	225	27	75	Good
A.M. Walker - Markham MTS#2	T2	225	27	75	Good
Torstar - Vaughan MTS #2	T1	225	24	95	Very Good
Torstar - Vaughan MTS #2	T2	225	24	95	Very Good
Lazenby MTS1 - Richmond Hill MTS#1	T1	225	23	95	Very Good
Lazenby MTS1 - Richmond Hill MTS#1	T2	225	23	95	Very Good
D.H. Cockburn - Markham MTS#3	T1	225	24	95	Very Good
D.H. Cockburn - Markham MTS#3	T2	225	24	95	Very Good
Greenwood -Vaughan MTS #1	T1	225	8	100	Very Good
Greenwood -Vaughan MTS #1	T2	225	8	100	Very Good
Lorna Jackson - Vaughan MTS #3	T1	300	14	100	Very Good
Lorna Jackson - Vaughan MTS #3	T2	300	14	100	Very Good
Lazenby MTS1 - Richmond Hill MTS#2	T1	225	15	100	Very Good
Lazenby MTS1 - Richmond Hill MTS#2	T2	225	15	100	Very Good
D.H. Cockburn - Markham MTS#3 Expansion	T3	225	11	100	Very Good
D.H. Cockburn - Markham MTS#3 Expansion	T4	225	11	100	Very Good
Fabro TS - Markham TS#4	T1	150	3	100	Very Good
Fabro TS - Markham TS#4	T2	150	5	100	Very Good

2

1

## Figure 36: Health Indices: Station Service Transformer (TS Stations)


3

4 Figure 36 indicates that the station service transformers are in good or very good health.

5

6

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 40 of 61 Delivered: February 24, 2015



4 Figure 37 indicates that the primary metering units ranges from four to 14 years of age.

5 6

1 2

3

**Distribution System Plan** 

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 41 of 61 Delivered: February 24, 2015

TS ID	PMU ID	PMU MANUFACTURER	PMU MODEL NUMBER	PMU TYPE	INSULATING MEDIUM	Age	Health Index	Health Index Category
Greenwood -Vaughan MTS #1	5120-T1-PMU-W	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1	5120-T1-PMU-B	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1	5120-T2-PMU-R	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1	5120-T2-PMU-W	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1	5120-T2-PMU-B	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T3-PMU-R	Trench	N5-1050	Combined	Oil	8	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T3-PMU-W	Trench	N5-1050	Combined	Oil	9	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T3-PMU-B	Trench	N5-1050	Combined	Oil	9	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T4-PMU-R	Trench	N5-1050	Combined	Oil	9	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T4-PMU-W	Trench	N5-1050	Combined	Oil	9	93	Very Good
Greenwood -Vaughan MTS #1 Expansion	5120-T4-PMU-B	Trench	N5-1050	Combined	Oil	9	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-CT-R	Trench	OSKF-1050	СТ	Oil	9	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-CT-W	Trench	OSKF-1050	СТ	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-CT-B	Trench	OSKF-1050	СТ	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-CT-R	Trench	OSKF-1050	СТ	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-CT-W	Trench	OSKF-1050	СТ	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-CT-B	Trench	OSKF-1050	СТ	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-PT-R	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-PT-W	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T1-PT-B	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-PT-R	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-PT-W	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Lorna Jackson - Vaughan MTS #3	5122-T2-PT-B	Trench	UTS-1050-230	PT	Oil	14	93	Very Good
Fabro TS - Markham TS#4	7110-T1-PMU-R	Trench	N5-1050	Combined	Oil	14	100	Very Good
Fabro TS - Markham TS#4	7110-T1-PMU-W	Trench	N5-1050	Combined	Oil	5	100	Very Good
Fabro TS - Markham TS#4	7110-T1-PMU-B	Trench	N5-1050	Combined	Oil	5	100	Very Good
Fabro TS - Markham TS#4	7110-T2-PMU-R	Trench	N5-1050	Combined	Oil	5	100	Very Good
Fabro TS - Markham TS#4	7110-T1-PMU-W	Trench	N5-1050	Combined	Oil	5	100	Very Good
Fabro TS - Markham TS#4	7110-T1-PMU-B	Trench	N5-1050	Combined	Oil	5	100	Very Good


1 2

## Figure 38: Health Indices: Primary Metering Units (Transformer Stations)

3

4 Figure 38 indicates that all the primary metering units are in good health.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 42 of 61 Delivered: February 24, 2015



5 6

1


2

3

4

**Distribution System Plan** 

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 43 of 61 Delivered: February 24, 2015



## **PowerStream Protection and Control Relays**

1 2


3


4 5

6 7

**Distribution System Plan** 

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 44 of 61 Delivered: February 24, 2015






4 Figure 41 indicates that there is a significant amount of cable that is older than 25 years of age.

1

2

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 45 of 61 Delivered: February 24, 2015



#### 1 2

#### Figure 42: Distribution Transformer Health Assessment


#### 3

4 Figure 42 indicates roughly half of the transformers are in very good health, and that information


5 is missing on quite a few units, while there are still a considerable number of transformers in

6 poor or very poor health.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 46 of 61 Delivered: February 24, 2015




EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 47 of 61 Delivered: February 24, 2015




- 1 Figure 44 indicates that the majority of switchgear are in fair to very good health
- 2

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 48 of 61 Delivered: February 24, 2015




Distribution System Plan

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 49 of 61 Delivered: February 24, 2015



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 50 of 61 Delivered: February 24, 2015




#### PowerStream AUTOMATED SWITCH Health Index Classification

5

1 2

3

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.2 Overview of Assets Managed Page 51 of 61 Delivered: February 24, 2015



- 1 2
- 3

4 Figure 49 indicates that there are a considerable amount of wood poles greater than 30 years of

- 5 age.
- 6






Figure 50: Wood Poles Health Assessment

#### 1 Asset Utilization

As outlined in Exhibit G, Tab 2, Section 5.3.1, page 18, PowerStream undertakes planning studies to review system peaks relative to system capacity, either in the short term or the long term, in order to determine if expansion to the transformation or distribution system is required. For longer term projects, the objective is to identify the need for additional facilities with sufficient lead time to permit approvals, design, procurement, construction and commissioning prior to the peak demand load exceeding available capacity.

8

9 In November 2012, PowerStream completed a comprehensive long-term load forecast for a ten
10 year planning period (2013 to 2022) for the south service territory (Vaughan, Markham,
11 Richmond Hill and Aurora).

12

The results for PowerStream's south territory identified that additional power capacity in the Vaughan area is needed to supply the projected load growth in southern York Region in 2017. In 2017, all existing transformer stations will have reached their LTRs and the existing capacity of 1,750 MW will be exceeded.

17

The results for PowerStream's north territory identified the need for five municipal substations(plus land acquisition for a sixth) over the 2015 to 2020 time horizon within this DS Plan.

20

As indicated in Table 3 to Table 8, which detail the ratio of peak to planning limits, on pages 1117 in this Section:

- Transformer station utilization is higher on some stations, and will become acceptable when a new station is added in 2017 in the Vaughan area;
  Hydro One station utilization is acceptable;
  South municipal substations are lightly loaded, and are being converted to 28kV only as part of any coincident work in the area;
- The north substations have acceptable utilization as they provide for operational
   flexibility through the triad model.
- 30
- 31

1	Capital Investment Key Drivers						
2	In this DS Plan, PowerStream has developed a list of capital investment drivers and proposes						
3	investment programs based on these key drivers. The definition of the key drivers are						
4	below. Refer to Figure 51 on page 55.						
5							
6	<u>Service Requests (system access)</u>						
7	PowerStream has an obligation to connect a customer to its distribution system. This						
8	includes both traditional demand customers and distributed generation (DG) customers.						
9	Requests also can include system modifications for property or infrastructure						
10	development by government agencies, road authorities, developers or other entities						
11							
12	<u>Mandated Compliance (system renewal)</u>						
13	Compliance with all legal and regulatory requirements and government directives, such						
14	as compliance with the Ministry of Energy, Measurement Canada, the Ontario Energy						
15	Board, the Independent Electricity System Operator and/or other regulations.						
16							
17	Obsolescence (system renewal)						
18	Assets/asset installations that no longer align with PowerStream's current operating						
19	practices or current standards. This can include those assets that:						
20	<ul> <li>Are no longer manufactured;</li> </ul>						
21	<ul> <li>lack spare parts;</li> </ul>						
22	<ul> <li>lack of accessibility;</li> </ul>						
23	$\circ$ lack the ability to have maintenance performed on them; or						
24	$_{\odot}$ have operational constraints or conflicts, which can result in increased reliability						
25	and/or safety-related risks.						
26							
27	<u>Mitigate Failure Risks (system renewal)</u>						
28	Where there is the imminent risk of failure due to age or condition deterioration, and						
29	these potential failures will result in severe reliability impacts to customers as well as						
30	potential safety risks to crew workers or to the public, remediation, through						

31 refurbishment or replacement, is required.

1	•	Reliability (system service)
2		PowerStream has a mandate to maintain or improve reliability at a system level. In
3		pursuit of improved reliability, projects may be developed to improve feeder, station or
4		multiple feeder performance.
5		
6	•	Support Capacity Delivery (system service)
7		Where there are forecasted changes in load that will constrain the ability of the system to
8		provide consistent service delivery, or where forecasted load growth will render the
9		distribution system incapable of supplying the demand requirements, system relief,
10		through new builds or expansion, is required.
11		
12	•	System Efficiency (system service)
13		To provide customers with the best service possible, there is always a need to improve
14		restoration capability. This may also include projects to reduce system losses,
15		configuration of taps or open points to match loading or other projects to improve local
16		issues.
17		
18	•	Safety (system service and system renewal))
19		Where assets are known to have safety related hazards or risks, either to workers or the
20		general public, or where assets are an integral part of maintaining safe work practices,
21		and the failure of those assets would result in safety-related hazard/risk exposure, then
22		remediation, through refurbishment or replacement, is required.
23		
24	•	Capital Investment Support (general plant)
25		In order to support the resources (both human and machine) that are required to
26		operate, analyze, maintain and generally support the distribution system, renewal,
27		refurbishment, replacement or enhancement of assets (ie vehicles, buildings, IT
28		systems), are required.
29		
30		

#### <u>Customer Service (general plant)</u>

In order to provide improved customer service and an overall exceptional customer experience, replacement or enhancement of assets, are required.

3 4

1

2

		Primary Driver	Source
System Access	New Connections and Subdivisions Road Authority Metering Other Customer Initiated Work RGEN New Connections Other Misc	service requests	Developers, Customers, Road Authorities
System Renewal	UG Lines Planned Asset Replacement Distribution Lines - Emergency/Reactive Overhead - Lines Planned Asset Replacement Storm Hardening & Rear Lot Conversion Stations/P&C-Planned and Emergency Other Misc	mandated compliance obsolescence mitigate failure risks safety	Regulator Safety Authority PowerStream
System Service	Additional Capacity - Stations Additional Capacity - Lines Reliability Including Distribution Automation Station Safety & Security Smart Grid/RGEN - System Related Other Misc	reliability support capacity delivery system efficiency safety	PowerStream
General Plant	Customer Information System (CIS) IT and Info/Communication Systems Buildings and Emerging Operations Fleet Tools Interest Capitalization Smart Grid - Other Other Misc	capital investment support customer service	PowerStream

#### 5 6

Figure 51: Key Capital Investment Drivers

1 The sub-categories within each of the four main categories are described below.

2

3 New Connections and Subdivisions

This sub-category covers the costs to connect new customers to the system. The work is
divided into four programs – Layouts, New Services, New Subdivisions, and Secondary
Services.

7

Layouts consist of work to make ready the system for new residential infill services, upgrading
of residential services and small commercial services. A layout is completed for each customer.
The customer's service could be underground or overhead and is the connection from the main
plant on the boulevard to the building. Costs are shared between the customer and
PowerStream in accordance with the Distribution System Code ("DSC").

13

New Services consists of new and/or upgraded primary services to industrial, commercial and institutional customers. These services are normally underground from the existing distribution or sub-transmission system and up to and including the padmount transformer. In accordance with the DSC, these services are considered a connection and are 100% recoverable (deemed as 'Lies Along' – these are new services where facilities exist to service the customers).

19

New Subdivisions consist of the primary and secondary underground cables as well as transformers installed to the street line of each lot within a new residential "greenfield" subdivision development. In accordance with the DSC, the development cost is subject to an economic evaluation to determine the LDC share and the Developer share based on revenues generated from the development.

25

Secondary underground services are installed from the street to the meter base for each lot. This work allows for the connection of the secondary service to the padmount transformer which in turn provides power to the customer's unit. These services are installed as the houses within the development are built and are normally installed within five years of the new subdivision being installed. In accordance with the DSC, these service costs are put through the economic evaluation model and shared at time of the Offer to Connect ("OTC").

#### 1 Road Authority

2 As communities within PowerStream's service territory continue to grow, road construction, re-3 alignment and widening of existing roads as well as the installation of new water and sewer 4 infrastructure occur. This development work is controlled by Provincial, Regional and Municipal 5 authorities. Because PowerStream's distribution system is located on the road allowance, at 6 the request of the road authority, it must be relocated to accommodate this development work. 7 Each year, PowerStream reviews the five and ten year road authority plans for development to 8 identify where distribution system conflicts exist and to budget for resolution of these conflicts. 9 The majority of these projects involve relocating portions of the distribution system. These projects are usually cost shared with the road authority. This sub-category covers the costs for 10 11 these relocations.

12

#### 13 <u>Metering</u>

14 This sub-category involves the installation or replacement of meters. The work involves the 15 upgrades or replacement of wholesale or retail meters and includes Wholesale Meter Upgrades,

16 Failed Meter/Transformer Replacements, Meter Re-verifications and Smart Meters.

17

#### 18 Other Customer Initiated Work

19 This sub-category covers large customer projects due to the customer's emerging needs 20 throughout the year. Projects are typically required due to either a relocation required by a 21 customer or the expansion of the distribution system for the customer. In the case of 22 relocations, the customer typically pays 100% of the costs. In the case of a required expansion 23 of the distribution system, costs are shared as per the requirements of the Distribution System 24 Code ("DSC") and PowerStream's Conditions of Service ("COS").

25

This sub-category also covers the costs to connect new distributed generation customers to the system. In accordance with the DSC, these costs are shared by the customer and PowerStream. The customer is responsible to cover the cost of connection. PowerStream will cover system expansion costs at or below a distributed generation customer's renewable energy expansion cap.

- 1 RGEN New Connections
- 2 This sub-category covers the work required to connect FIT and microFIT renewable generators
- 3 to the distribution system.
- 4
- 5 <u>Other Miscellaneous</u>
- 6 This sub-category exists to permit the comparison and translation of historical data to future
- 7 proposed expenditures within the four categories (these exist is each of the four categories).
- 8

#### 9 UG Lines Planned Asset Replacement

- 10 This sub-category covers the remediation of underground assets as identified through the asset
- 11 condition assessment process. These yearly programs include:
- cable remediation (replacement and injection);
- switchgear replacement;
- mini-rupter switch replacement;
- 15 submersible transformer replacement; and
- 16 distribution transformer (padmount) replacement.
- 17
- 18 Distribution Lines Emergency / Reactive Replacement

This sub-category covers capital costs of repair and restoration of the distribution system. Work is required as a result of on-going power outages or identified through inspection as needing repair due to a hazardous safety condition or potential imminent failure. The work is divided into programs, specifically, replacement of failed distribution equipment, replacement of distribution equipment due to storm events, replacement of distribution equipment due to accidents and joint use pole removal.

25

#### 26 Overhead - Lines Planned Asset Replacement

- 27 This sub-category covers the replacement of overhead assets as identified through the asset
- 28 condition assessment process. These yearly programs include:
- pole remediation (replacement or reinforcement);
- automated switch replacement;
- fault indicator replacement; and

2 3

1

• 44kV porcelain insulator replacement.

3 Storm Hardening & Rear Lot Conversion

4 This sub-category covers construction of end-of-life rear lot supplied residential subdivisions by

- 5 conversion to front lot servicing and structural integrity projects for the overhead system.
- 6

### 7 Stations/P&C Planned and Emergency

8 This sub-category is for those Municipal Stations ("MS" – stations that transform from 44kV or 9 27.6 kV to a lower distribution voltage such as 13.8 kV) and Transformer Stations ("TS" – 10 stations greater than 100 MVA that transform from high voltages 230 kV to 27.6 kV). These 11 projects are not capacity driven, but are required to sustain PowerStream's fleet of transformer 12 and municipal substations. Sustainment activities include projects to replace worn out 13 equipment, improve reliability, enhance operability and maintainability as well as improve and 14 maintain safety.

15

## 16 Additional Capacity – Stations

17 This sub-category covers construction projects of new or upgrade of existing transformer and 18 municipal station capital projects that PowerStream must complete to provide sufficient capacity 19 to supply new customers and load growth from existing customers. Every year PowerStream 20 prepares a load forecast and studies the system to identify capacity short falls and recommends 21 projects to ensure sufficient capacity for customer load growth demands.

22

## 23 Additional Capacity - Lines

This sub-category covers construction of new or upgrade of existing distribution or subtransmission lines that PowerStream must complete to provide sufficient feeder and component capacity to supply new customers and load growth from existing customers. PowerStream uses the load forecast and studies the system to identify capacity short falls and recommends projects to ensure sufficient capacity for customer load growth demands.

- 29
- 30
- 31

#### 1 Reliability including Distribution Automation

This sub-category is for those projects required to sustain the distribution system and ensure reliability. These projects are identified through technical studies or through an identified reliability need. Included in this category are Voltage Conversion Projects, System Reconfiguration Projects, Radial Supply Remediation Projects, Distribution Automation Projects, Reliability Driven Projects and remote Fault Indicator Installation projects.

7

#### 8 Station Safety and Security

9 This sub-category covers projects to deal with either cyber or physical asset security.

10

#### 11 Smart Grid/RGEN System Related

This sub-category covers smart grid projects that would not have been completed in the normal course of PowerStream's everyday business and are pilots of new technology that may be considered for incorporation into the grid or are pilots to understand the impact of new technologies such as the electric vehicle. These projects were previously funded through a smart grid deferral account up to and including 2015.

17

#### 18 Customer Information System (CIS)

- 19 This sub-category covers projects that support the Customer Service division and technology to 20 enhance service to customers.
- 21

#### 22 Information Systems and Info/Communication Systems

This sub-category consists of new projects or upgrades to PowerStream's information
 technology or communication systems across the organization, covering hardware and
 application software.

26

#### 27 Buildings and Emerging Operations

- 28 This sub-category involves the purchase, replacement or rehabilitation of major assets related
- 29 to one of PowerStream's four main centres of operation.
- 30
- 31

1 <u>Fleet</u>

2 This sub-category involves the purchase or refurbishment of vehicles.

- 3
- 4 <u>Tools</u>

5 This sub-category involves the purchase of tools that are required for the ongoing operation, 6 construction, maintenance, and repair of the distribution system. Tools include power 7 measuring equipment, cutters and crimpers; relay testing equipment, communications testing 8 equipment, meter testing equipment and locating equipment. These purchased tools replace 9 worn out or broken tools used by the staff on a daily basis for their work.

10

## 11 Interest Capitalization

This sub-category covers monies for interest capitalization. Under Internal Financial Reporting Standards ("IFRS"), interest capitalization is defined as the borrowing costs that are directly attributable to the acquisition or construction of a qualifying asset cost. A qualifying asset is an asset that necessarily takes a substantial period of time to get ready for its intended use. PowerStream has determined this period of time as those projects that span over four months in duration. To assist in project management these costs are tracked in one category within the capital budget.

19

## 20 Smart Grid – Other

21 This sub-category covers projects that support PowerStream's Smart Grid Implementation Plan,

such as electric vehicle connections, home energy management technologies and dataanalytics.

- 24
- 25 <u>Safety</u>

26 Safety is an integral component of all projects/programs.

- 27
- 28

#### 1 5.3.3 ASSET LIFECYCLE OPTIMIZATION POLICIES AND PROCEDURES

An understanding of a distributor's asset lifecycle optimization policies and practices will support the regulatory assessment of system renewal investments and decisions to refurbish rather than replace system assets. Information provided should be sufficient to show the trade-off between spending on new capital (i.e. replacement) and life-extending refurbishment, and should include but need not be limited to:

- 7 a) A description of asset lifecycle optimization policies and practices, including but not necessarily
  8 limited to:
- a description of asset replacement and refurbishment policies, including an explanation of how
  (e.g. processes; tools) system renewal program spending is optimized, prioritized and scheduled
  to align with budget envelopes; and how the impact of system renewal investments on routine
  system O&M is assessed;
- 13 a description of maintenance planning criteria and assumptions; and
  - a description of routine and preventative inspection and maintenance policies, practices and programmes (can include references to the DSC).
- 15 16

14

6

- b) A description of asset life cycle risk management policies and practices, assessment methods and
   approaches to mitigation, including but not necessarily limited to the methods used; types of
   information inputs and outputs; and how conclusions of risk analyses are used to select and
   prioritize capital expenditures.
- 21

#### 22 Asset Replacement and Refurbishment (Remediation) Program and Policies

- PowerStream has several asset remediation programs for maintaining distribution system andgeneral plant integrity.
- 25
- 26 PowerStream makes assessments on whether an aged asset is suited for refurbishment or 27 replacement based on criteria that are pertinent to a given asset class.
- 28

A large contributor to the assessment process is the annual inspection of critical assets. Annual

- 30 inspections are completed on the distribution system for the overhead system, load interrupter
- 31 switches, padmount switchgear, vault rooms, padmounted switchgear, stations and poles. An
- 32 assessment is made and an asset will be categorized as a Code A, Code B or Code C:

1 • Code A: Corrective measures/follow-up are required at the earliest possible 2 opportunity (address immediately); 3 • Code B: Assessment required for corrective action for the next budget cycle; and 4 • Code C: No corrective measures are required. Follow the regular maintenance 5 cycle. 6 7 Additionally, testing is performed on cables to determine the health of the cable, and testing is 8 performed on wood poles to determine remaining strength. 9 10 These designations are applied to the distribution system assets as seen in Figure 1. This table 11 depicts, by asset, what the health index scores mean, what the inspection results mean, and 12 how the scores are prioritized

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.3 Asset Lifecycle Optimization Policies and Procedures Page 3 of 38 Delivered: February 24, 2015

Program	Health Index (max score = 100)	Inspection Results (Code A, B, C)	Prioritization Score (max score = 100)
Pole Replacement	not applicable	Used field inspection results to select replacement candidates. <b>Code A</b> = Very Bad, immediate replacement <b>Code B</b> = Fair, replacement candidate for next budget cycle <b>Code C</b> = Good condition, no replacement needed and maintain inspection	A higher point total yields greater replacement priority. (scored from % Remaining Strength, Condition, # of Transformers, # of Primary Conductors, # of Switches, Criticality of Pole and Age of Pole.) <b>NOTE</b> : Candidates will belong to one of the following groupings: - Remaining strength is less than 60 % - Remaining strength is greater than 60%, however other aspects of the pole are bad. (i.e but rot, insect infestation, decay, splitting, bending, leaning)
Cable Remediation: Cable Replacement	not applicable	TAN DELTA TEST RESULTS         Code A = Critically Aged. Intervention Required         Code B = Aged. Further study required. (Repeat testing evey 2 years based on test reults)         Code C = No Action Required/Repeat after 5 Years	A higher point total yields greater replacement priority. (scored from Age, Cable Condition, Service Quality and Financial Impact)
Cable Remediation: Cable Injection	not applicable	TAN DELTA TEST RESULTS Code A = Critically Aged. Intervention Required Code B = Aged. Further study required. (Repeat testing very 2 years based on test results) Code C = No Action Required/Repeat after 5 Years	A higher point total yields greater replacement priority. (scored from Age, Cable Condition, Service Quality and Financial Impact)
Switchgear Replacement	Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	Used field inspection results to select replacement candidates. <b>Code A</b> = Very Bad, immediate replacement <b>Code B</b> = Fair, replacement candidate for next budget cycle <b>Code C</b> = Good condition, no replacement needed and maintain inspection	not applicable
Mini-Rupter Switch Replacement	Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	Used field inspection results to select replacement candidates. <b>Code A</b> = Very Bad, immediate replacement <b>Code B</b> = Fair, replacement candidate for next budget cycle <b>Code C</b> = Good condition, no replacement needed and maintain inspection	not applicable
Automated Switch Replacement	(Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	Used field inspection results to select replacement candidates. Code A= Very Bad, immediate replacement Code B= Fair, replacement candidate for next budget cycle Code C= Good condition, no replacement needed and maintain inspection	not applicable
Submersible Transformer Replacement	Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	Used field inspection results to select replacement candidates. <b>Code A</b> = Very Bad, immediate replacement <b>Code B</b> = Fair, replacement candidate for next budget cycle <b>Code C</b> = Good condition, no replacement needed and maintain inspection	not applicable
Distribution Transformer Replacement	Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	Used field inspection results to select replacement candidates. <b>Code A</b> = Very Bad, immediate replacement <b>Code B</b> = Fair, replacement candidate for next budget cycle <b>Code C</b> = Good condition, no replacement needed and maintain inspection	not applicable
Station Equipment Replacement	Good Condition= high Health Index, >70 Fair Condition= middle Health Index, 51-70 Poor Condition= low Health Index, <51	NOTE: Inspection & testing results are used to generate the health index and replacement candidates.	not applicable

## Figure 1: Summary of Health Index Results, Inspection and Testing

2 Pole Remediation (replacement or reinforcement); • 3 Cable Remediation (replacement and injection); 4 • Switchgear Replacement; 5 Mini-Rupter Switch Replacement; 6 Automated Switch Replacement; 7 Submersible Transformer Replacement; 8 Distribution Transformer Replacement; • 9 Station Equipment Replacement (Substations & Transformer Stations); • 44kV Porcelain Insulator Replacement; 10 • 11 Fault Indicator Replacement; • 12 Storm Hardening and Rear Lot Remediation; • Information Systems; 13 • 14 Facilities: • 15 Information systems; • 16 Facilities Remediation; and • 17 • Fleet Replacement. 18 19 These are further described below. 20 21 Pole Remediation 22 Through an annual inspection and testing program, PowerStream monitors the condition of its 23 poles to ensure that they meet minimum requirements for safety and reliability. Among other 24 factors, PowerStream is guided in its pole assessment process by Clause 8.3.1.3 of CSA 25 Standard C22.3 No. 1-10, which states that: 26 27 "when the strength of a structure has deteriorated to 60% of the required capacity, the 28 structure shall be reinforced or replaced". 29 30 In the quote from the CSA standard, the reference to capacity is interchangeable with pole 31 strength for this program.

The remediation programs for maintaining the distribution system are:

Other considerations include pole condition information such as rot, decay, splitting, insect infestation, bending, and leaning. PowerStream believes that the remediation of poles exhibiting poor (or worse) condition is non-discretionary. The remediation is required to maintain compliance with the CSA code, as well as considerations for safety of the public and for workers operating in, on, or around the poles and their associated equipment.

6

When an existing pole is replaced, PowerStream must install the new pole according to the current standards. In most cases the existing associated components attached to the existing pole are also at end-of-life and therefore must also be replaced. Examples of the associated components are brackets, cross arms, down guys, anchors, ground wires, insulators, arresters, and fasteners. If in any particular case, the pole has transformers, switches, or other equipment with significant remaining life, these are salvaged and re-used.

13

14 When a pole in reinforced, the base will be restored to full strength. See Figure 2.




Figure 2: Pole Reinforcement Installation

PowerStream annually inspects and tests a portion of pole population. The pole remediation
 candidates are selected based on the combination worst candidates of the following two
 groupings:

• Poles that have less than 60% remaining strength (CSA reference); or

Poles that have more than 60% remaining strength but exhibit worsening conditions
such as rot, decay, splitting, insect infestation, bending, and leaning.

Poles are prioritized based on their assessed health index, the worst being selected forreplacement or reinforcement. See Figure 3 below.



## 25 Cable Remediation

PowerStream monitors the condition of its primary cables to ensure that they meet minimum requirements for safety and reliability. The asset demographics indicate that the oldest cables of the PowerStream cable population are at end-of-life, are deteriorating and are failing. To mitigate the effects of this, annual remediation efforts are required.

1 To manage the risk of large-scale primary cable failures, PowerStream has implemented a 2 cable remediation plan. The plan includes continuous work on assessing, prioritizing, and 3 remediating the worst cable segments by a combination of cable injection and cable 4 replacement.

5

6 PowerStream's approach to managing the high risk cable population is summarized below:

- 7 Use a cable prioritization system to select cable segment "candidates" for replacement 8 or injection;
- 9 Designate prioritized cable candidates for cable injection or cable replacement; •
- Address the cable aging issue by a combination of cable injection and cable 10 • 11 replacement on a prioritized basis;
- 12 Conduct testing to assess the condition of the cable; and
- 13 Select the preferred method. •
- 14


15 In 2011, PowerStream's System Planning division introduced cable injection (a process that 16 restores the insulation in a cable). This process extends cable life at approximately 15% of the 17 cost of cable replacement. PowerStream's preference is to inject cables as a first choice for 18 remediation. Research indicates that cable injection extends the life of cable for another 20 19 years, however, injection is only suitable and economical for some cable types and field 20 conditions. The initial trials were very successful - low cost and no subsequent failures. The 21 initial cable candidates were limited in age due to technical factors. In 2014, PowerStream did 22 additional research related to the technical factors, and determined that additional cable 23 candidates would be eligible for injection. This efficiency permits the remediation of the same 24 amount of cable at a lower overall cost, or alternatively, permits additional lengths to be 25 accomplished with an equivalent budget.

26

27 The cable replacement option is more expensive than the cable injection option with respect to 28 the initial capital cost, but it has the advantage of resulting in new cable that will be utilized for a 29 longer time. In comparing the two options, the extra life expected from injected cable is 20 30 years while the life of new cable is expected to be 50-55 years.

In order to determine the cable candidates to be selected for replacement or injection remediation means, PowerStream has developed a prioritization methodology which takes into consideration the physical condition of the cable along other factors such as age, impact to customer service and financial benefit. Figure 4 depicts the methodology used to screen and prioritize the candidates selected for injection or replacement.

6



10

11 Cable condition is the key driver and most heavily weighted factor in terms of determining12 cables for replacement/injection.

13

14 The cables that are proposed for remediation exhibit Code A results (advanced insulation 15 degradation) indicating that intervention is required.

16

In 2010, PowerStream's System Planning division introduced Tan Delta cable testing, a diagnostic method of testing cables to determine the quality of the cable insulation. This testing, when applied within the cable remediation program, provides improved data to assist in determining the optimal approach to remediation – does the cable need remediation, and if so, is injection or replacement the preferred approach? This efficiency results in ensuring that only poor cables are selected and if injected if appropriate. This lowers the overall cost of the
 program.

3

4 The remaining factors in the prioritization matrix (customer service, financial, age) have 5 decreasing factor weights with age being the lowest. In the absence of any other empirical 6 data, age is the default indicator of when the cable approaches end of life.

7

## 8 Switchgear Replacement

9 Pad- Mounted Switchgear units are used in distribution loops supplying residential subdivisions
10 and commercial/industrial customers. Switchgear units are used to isolate/control other
11 equipment, and to reconfigure the loops for maintenance, restoration or other operating
12 requirements.

13

Switchgear degradation depends on a number of factors, such as condition of mechanical
 components, contamination due to dirt, moisture and corrosion. The other important issues are
 obsolescence or product specific/generic defects.

17

Pad-mounted switchgear represent critical assets for the underground distribution system and have been identified to carry a significant reliability and safety risk due to condition, age, past design and installation practices. The population targeted for replacement consists of air and oil switchgears, based on safety and reliability concerns.

22

Appendix C (Table-1) of the Distribution System Code (DSC) sets out minimum inspection requirements for the distribution system and accordingly for urban environments the underground plant is inspected on a three year cycle. In addition ESA regulation 22/04 mandates that the distribution plant be inspected and any potential safety issues be rectified.

27

Based on the inspection results each year, and the health index calculation, a number of distribution switchgear are recommended for replacement due to safety concerns, age, and asset condition assessment information.

#### 1 Mini-Rupter Switch Replacement

Mini-rupter switches are found in distribution loops supplying industrial commercial/industrial
customers and are three pole-gang operated interrupter switches used for switching between
underground distribution circuits.

5

6 Mini-rupter degradation depends on a number of factors, such as condition of mechanical7 components, contamination due to dirt, moisture and corrosion.

8

9 Mini-rupter switches are critical assets that are typically installed in vault rooms and have been 10 identified to carry a significant reliability and safety risk due to condition, age and arc quenching 11 design. There have been several failures of the switches where there has been an arc flash 12 created between an energized component and ground potential. In this case the risk of injury is 13 more pronounced as these switches are located in confined vault rooms. Due to the safety risk 14 associated with failure of units, PowerStream's standard work practices have placed restrictions 15 on switching of these units live, which is contrary to the units performing their intended function. 16

Based on the inspection results each year, and the health index calculation, a number ofswitches are recommended for replacement due to safety concern, age, and ACA information.

19

20 Automated Switch Replacement

21 High service reliability and rapid response to power outages is critical to maintain reliability and

- 22 customer satisfaction.
- 23
- 24 Remotely controlled switches provide many benefits, which include:
- a rapid transfer of loads in emergencies;
- a reduction in restoration time (which improves reliability);
- a reduction in the number of customers affected by outages;
- flexibility to reconfigure the system to avoid feeder and station over loads during summer
   peak intervals;
- real time system readings;
- a reduction to the risk of personnel injury; and

- 1
- a platform for a complete distribution automation system.
- 2

There are identified locations where the automated switches are the end of life and cannot be
operated remotely. These locations are selected for replacement.

5

## 6 Submersible Transformer Replacement

7 This particular model of submersible transformers (known as pole trans or rocket ships) are 8 installed at the bottom of the street light poles, and are used to step down the primary voltage to 9 the lower secondary voltage to supply residential customers. These are a unique installation 10 that includes non-load break primary connections, submersible transformer, NX type fusing and 11 a metal clad covering supporting a municipal street light fixture.

12

These units date back to 1967 and are at their end-of-life. They are obsolete, are no longermanufactured and spare parts non-existent.

15

PowerStream has identified the population of transformers of this vintage type and commenced a program to replace transformers each year. The program will be completed within the five years included in this DS Plan.

19

## 20 Distribution Transformer Replacement

Distribution transformers are used in the underground distribution to step down the primary voltage to the lower secondary voltage for use by customers. These transformers may be single-phase or three-phase depending on the customer and type of load. Pad-mount transformers in PowerStream's distribution system consist of a range of transformers from single phase 50kVA units typically supplying residential customers to three phase 3,000 kVA units supplying industrial customers. These transformers are liquid filled, with mineral insulating oil and employ sealed tank construction.

28

29 Single phase distribution transformers are generally a run-to-failure asset, unless through 30 inspection, the units present a safety or environmental hazard. For larger three phase 31 distribution transformers supplying commercial or industrial customers, where reduction in 1 reliability impacts may be high, transformers may be replaced as they near the end-of-life or

- 2 where they have been identified as overloaded.
- 3

## 4 Station Equipment Replacement

5 Transformer stations are a highly complex set of assets working together to supply electricity to
6 the distribution system. Based on demographic and condition data, health indices have been
7 developed and asset data collected on an ongoing basis. Replacements are made as indicated
8 by the health indices.

9

## 10 <u>44kV Porcelain Insulator Replacement;</u>

PowerStream is experiencing a growing number of power interruptions due to insulator failure.
It has been found that the older vintage of 44kV porcelain insulators are prone to tracking and
flash over. PowerStream is proposing to replace all remaining legacy 44 kV porcelain insulators
with polymer type insulators (over the next four years).

15

# 16 Fault Indicator Replacement

PowerStream has deployed fault indicators throughout its distribution system, and the location of the installations are result of mergers of several predecessor utilities. There are several different types of fault indicators currently deployed on PowerStream distribution systems. Some areas have fault indicators heavily deployed, while others have limited numbers installed or no fault indicators at all. This program is a combination of adding fault indicators that are obsolete fault indicator is absent, as well as replacing older technology fault indicators that are obsolete or prone to malfunction.

24

Fault Indicators are significant to the distribution system to reduce fault locating times, improving outage response and, consequently, outage restoration times. The deployment of functional fault indicators are crucial to maintaining high levels of reliability and customer service and to achieving gains in operational efficiency.

- 29
- 30
- 31

#### 1 Storm Hardening and Rear Lot Remediation

PowerStream has a number of pockets of customers supplied by rear lot (backyard)
construction. In general, these areas are older neighbourhoods and the electrical supply
systems were installed between 1950 and 1970. As a result, the electrical components are
ageing and the assets are deteriorating.

6

Rear lot supply systems pose reliability, operations, safety, and customer service issues for
PowerStream. These concerns are either from a subdivision (many customers), or an individual
customer requesting an underground service in a rear lot supply area.

10

In 2012, a review of the rear lot pockets was performed. There are thirty-six (36) areas of various sizes. These assets are aging, with an average age of years forty-two (42) years, with the oldest being sixty-six (66) years old. These assets pose a potential safety risk to the public due to planting of trees and the installation of sheds and pools close to the lines. The assets are also more inaccessible compared to standard front lot design. Several potential options and associated costs were presented.

17

18 In the 2013 ice storm, the longest outage times were faced by customers supplied with rear lot 19 overhead systems. As a result, a second review of the options was performed, and 20 PowerStream is proposing to annually replace areas of the rear lots supplies with front lot 21 standard construction, until they are remediated. Additionally, PowerStream will be reinforcing 22 pole lines and moving equipment located in the basement in transformer stations to above 23 grade (to avoid flooding).

24

#### 25 Information Systems

PowerStream's computer assets are required to be reasonably current and in good working order, and the "useful life" has been determined in accordance with current accounting principles. Other factors such as reliability and the impact (cost) of failure remain the primary factors considered in IT asset management decisions.

- 1 Table 1 outlines the useful life of information system hardware. PowerStream continuously looks
- 2 for opportunities to extend the useful life of hardware (and software). The introduction of
- 3 virtualization, both on the client and server side, has the potential to reduce the dependency on
- 4 physical hardware.
- 5

Asset Class	Useful Life (years)
Switches/Routers	6
Servers (including servers and SAN)	5
MFP's (including all printers)	5
Desktops/Laptops (includes immaterial monitors)	4
Computer Software Application	4
Computer Software Operations (Operating Systems)	3
Table 1: Information System Hardwar	 e

6

7

8 PowerStream's policy, with respect to system software, is to maintain software as current as 9 practical, based on the version releases and the impacts of upgrades. Software is only 10 upgraded once all reasonable options are considered and deemed inadequate to meet current 11 business needs. Reasons to upgrade include:

- 12 Lack of vendor support;
- 13 Costly vendor support; •
- 14 Lack of compatibility with versions used by business partners and customers; •
- 15 New features can be obtained which provide additional functionality to improve • 16 efficiency;
- 17 Lack of compatibility with new software or hardware;
- 18 Probability of failure/service interruption; •
- 19 Support costs (once systems are beyond warranty); or •
- 20 Challenges with interoperability and integration. •

1 There is a direct benefit to our customers as the computer systems, such as the Customer

2 Information (billing) System or Outage Management System, are used to process information

3 necessary to provide the high level of service that our customers expect.

4

5 Facilities Remediation

6 PowerStream has four facilities with various age demographics. The Cityview Blvd head office 7 in Vaughan is seven years old and in good condition while the Patterson Road north office and 8 work yard facility in Barrie was built in the early nineties and is in fair condition. Lease hold 9 improvements at Markham Addiscott Road Operations Centre facility will also result in 10 increased capital requirement and the Jane Street in Vaughan office is new and does not 11 require work.

- 12 The areas of concern for PowerStream's facilities are:
- Exterior (pavement, fencing, lighting, stores yard);
- Interior (furniture);
- Mechanical (Plumbing);
- Structural (windows, doors, wall partitions);
- HVAC (Heating & air conditioning); and
- Equipment (major tools, lifts).
- 19


## 20 Fleet Replacement

PowerStream's fleet assets are required to be in good working order. Depending on the class of
vehicle (heavy duty, medium duty, light duty or miscellaneous class) replacement is required
when the vehicle reaches:

- a prescribed odometer reading: or
  a prescribed Engine Hours reading and shows an upward trend in Unscheduled Maintenance cost for last three years, and
  a high projected unscheduled maintenance cost (based on a technical assessment).
- 28 29

1	Optimized, Prioritized Spending Procedures and Risk Management
2	PowerStream's Capital Investment Process commences with the annual business planning and
3	budgeting process in the first quarter of each year, as described in Exhibit G, Tab 2, Section
4	5.3.1, page 25.
5	The following principles are applied on an annual basis to the process:
6	• Business Units develop their initial five year capital plans as part of the annual capital
7	planning cycle;
8	Business units prepare detailed budgets, justifications and business cases for projects,
9	and enter these into the Optimization tool;
10	• A Corporate Five Year Plan is compiled based on the submitted business unit five
11	proposed projects/programs as part of the capital planning cycle;
12	• The five year detailed budgets for all business units are prioritized through the
13	Optimization process; and
14	Approved and prioritized projects for years one and two are designed and readied for
15	execution in the next business year(s). Approved and prioritized projects for the
16	remaining three years are identified and design can be commenced only if warranted.
17	
18	For the five year budget cycle, these principles are applied across ten key steps as shown in
19	Figure 5. The detailed activities in each step are discussed in the following pages.
20	
21	

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.3 Asset Lifecycle Optimization Policies and Procedures Page 17 of 38 Delivered: February 24, 2015



1 2

Figure 5: Capital Budget Cycle

- 4 Key Step One Capital Budget Management System (CBMS) Entry
- 5 The Capital Budget Management System is one of the first tools applied in the budget cycle.
- 6 PowerStream's Capital Investment Process incorporates a ten year forward looking plan.
- 7 Business units that have major capital expenditures put together their own ten year8 departmental capital expenditure plans and five year budgets.
- 9 The business unit ten year capital expenditure plans are summarized into a Corporate Ten Year
  10 Capital Expenditure Plan. The information is combined from the following business units:
- Asset Investment Planning;
- Distribution Design;
- Operations;
- 14 Lines;
- Supply Chain Services;

- Smart Grid & Metering; and •
- 2 •
- 3

1

Information Services.

- 4 Early in the calendar year a request is sent out by Asset Investment Planning to all business 5 units in PowerStream to prepare ten year capital expenditure plans and five year budgets. 6 These plans are developed over the January to March period. The information in the Corporate 7 Ten Year Capital Expenditure Plan is used by the Finance Department in their financial models 8 to consider affordability. In addition, information in the first five year plan is used in rate 9 planning for the forward looking years.
- 10

11 In 2014, all project leads entered their project information (costs, year of expenditure, rationale 12 etc.) into the Capital Budget Management System (CBMS) tool, which is then loaded into the 13 Optimization tool for review and consolidation. In 2015, for efficiency gains, a project will be 14 proposed to allow direct entry of the budget data into the optimization tool. Refer to Exhibit G, 15 Tab 2, Section 5.2.3 page 7, for additional information.

16

17 These five year plans serve as the starting base for the development of the Corporate Capital 18 Expenditure Plan.

19

20 The business unit capital plans serve three purposes:

- 21 i) assist business units in their future planning and enable the business units to 22 provide solid five year budgets;
- 23 ii) forms the basis of the information provided in a rate application for the forward 24 looking years; and
- 25
- iii) provides the Finance team with information for financial planning.
- 26

27 Business units provide details in their five year budgets on forecast capital spending 28 requirements and describe the process by which they have determined the capital spending 29 requirements. Specific projects/programs and costs identified in the plans are generally 30 preliminary and the projects/programs identified in the plans may or may not be approved for 31 execution at this point.

## 1 Key Step Two – Input Data into Optimization Tool (Input into C55)

Data is entered into the Copperleaf C55 Optimization tool. Critical fields are entered including
details on the proposed investment, forecasts of the expenditures over the five year budget
horizon, answers to specific questions asked, based on the investment type, for both benefit
and risk.

6

7 The value and risk questionnaire was created using vendor expertise, existing practices and the
8 contribution of project leads as experts who request capital projects or programs.

9

Within Copperleaf's C55 program, all projects are valued (and optimized) based upon a Value Function. The Value Function is a weighting of a number of Value Measures. Value Measures can include risk mitigation, financial benefits, impacts on Key Performance Indicators (KPI), and cost. The Value Function was configured to reflect how projects contribute to PowerStream's strategic objectives as shown below. Questions were designed to provide value and scoring for these strategic elements, as noted in Exhibit G, Tab 2, Section 5.2.1, Figure 1.

EB-2015-0003 PowerStream Inc. **Rate Proposal** Exhibit G Tab 2 5.3.3 Asset Lifecycle Optimization Policies and Procedures Page 20 of 38 Delivered: February 24, 2015

13 (Shape and Influence positive advocacy)

F1 (increase shareholder value)

1	Financial Benefits:		4 Pillars	Corporate Strategic Objective	
2	-	Hard Financial Ber	nefits	Financial	F2 (provide an optimized rate of return)
3	-	Soft Financial Ben	efits	Processes	I1 (focus on continuous improvement)
4		Productivity	L		
5		,			
6		KPI Impacts:			
7		Reliability	r		
-	-	Reliability		Customers	C1 (deliver professional services and
8	-		_		exceptiopnal customer experience)
9	-	Reliability for Spare	es	Customers	C1 (deliver professional services and
10	-		-		exceptiopnal customer experience)
11	_	Customer Commu	nication	Customers	C3 (continue developing the PowerStream
			lioution		brand)
12				Customers	C1 (deliver professional services and
13	-	Customer Service	-		exceptiopnal customer experience)
14	-			Processes	I4 (develop a rate submission ready organization)
15	-	Rate Ready Organ	ization	E a la da a	
16	_	Environmental Imp	rovements	Foundation	E2 (ensure a safe and healthy workplace)
17	_	Employee Wellnes		Foundation	E1 (be a best in class employer)
			-		E4 (investigate and apply new and innovative
18	-	Technological Inno	valion	Foundation	technologies)
19 20			L		
20					
22		<b>Risk Mitigation:</b>			
23		IT Capacity	Foundation	E3 (b)	uild integrated technoogy platforms)
_	-				
24	-	Financial	Financial	F2 (p	rovide an optimaized rate of return)
25	-	Environmental	Foundation	E	1 (be a best in class employer)
26	-	Safety	Foundation	E2 (er	nsure a safe and healthy workplace)
27	-	Distribution	Customers	C2 (provide custome	r swith cost effective, competive distribution rates)

Processes

Financials

- 28 Compliance \_
- 29 30 Cost:
- 31 **Project Cost** \_

32

1 <u>Key Step Three – Complete Benefit Questionnaire</u>

Once project identification is complete, the business units, in conjunction with the Capital
Budget Supervisor, answer a series of questions about each project/program. The questions
posed are aligned with PowerStream's corporate goals and risk matrix.

5

6 The answers to the questions form the basis for scoring both the value of the project to the 7 corporation and its customers if the project is undertaken and the risk to the corporation and its 8 customers if the project is not completed in the planned year. The Capital Budget Supervisor 9 coordinates the business units across the organization to ensure that timelines are met, and 10 consistent interpretations of the answers are applied.

11

In addition to answering the benefit and risk questions required for scoring the projects/programs, for those projects/programs that exceed the materiality threshold, additional questions with respect to Chapter 5 of this rate filing are posed and business leads are required to provide the requisite information. Business cases, as appropriate, are also created. Once the questions on the projects are all answered, the data on the projects is ready for optimization. PowerStream utilizes Copperleaf's C55 product for optimizing multi-year portfolios.

18

19 The current configuration of PowerStream's Value Function and the Value Measures that20 comprise the Value Function is summarized below:

- Each of the Value Measures is calibrated to the same scale (1 value point approximately equal to \$1000). Consequently, within the Value Function, each of the Value Measures (except Project Cost) is weighed with the same value of +1. As
   Project Cost is a negative contributor to Project Value it is weighted with a cost of -1.
- All Value Measures are computed on an annual basis (e.g. the financial benefits for 2017 can be specified as being different than 2018). The stream of benefits (or costs) is converted to a single value for the Value Measure, by taking the Present Value of the stream, back to the beginning of the current fiscal year. The PV calculation uses the system defined discount rate.

- The Value of Risk Mitigation in all risk categories is computed using the same 1 2 methodology. The project owner specifies the Baseline Risk and the risk present if the 3 project is not completed. 4 Residual Risk: The risk present if the project is completed. The value of Risk • 5 Mitigated is computed as: Baseline Risk – Residual Risk. 6 For each risk the project owner specifies both the consequence and the probability of 7 Consequence 8 Projects in the following categories have been identified as Mandatory or Must Do 9 investments as PowerStream is mandated to complete these investments, 10 specifically: 11 • Emergency Restoration; 12 Subdivision Services; 13 Road Authority Projects; • 14 **Emerging Development Capital;** • 15 • Customer RGEN; 16 ICI projects; • 17 Subdivisions; • Layouts; and 18 • 19 Emerging customers. 20 These projects are flagged as "must do" and are considered as mandatory as part of the 21 optimization process. These projects have mitigated risk value as they are mitigating a 22 compliance risk. These projects are subtracted, by the system, from the constraint amount, 23 effectively reducing the amount of money available for competing projects and programs. 24 25 The value function combines all the value measures to compute the overall value of an 26 investment. The value of an investment reflects the total value that the project is bringing to 27 PowerStream, taking into account all of its financial benefits, impact on KPIs, risk mitigation and 28 costs. 29
- 30

#### 1 Key Step Four – Initiate Manager Review

Once a project lead has completed a project/program entry into C55, and automatic workflow
notification is produced to advise the Manager, Director or VP and the Capital Budget
Supervisor that the item is ready for review.

5

## 6 Key Step Five – Manager Review Projects/Program Values

Once a project/program, or series of projects/programs have been entered by project leads,
their respective managers, directors or vice-presidents can review, on an individual or
comparative basis, projects under their purview. Once reviewed and any follow-up questions
answered, the projects/programs are then ready for the optimization process.

11

### 12 Key Step Six – Set Budget Constraint

The Finance department sets several budget funding level constraints to allow for analysis and to establish financial criteria to permit the optimization results to be compared to the optimal funding amount. These levels are available for optimization runs to create varied constraint scenarios.

17

### 18 Key Step Seven – Run the Optimization

19 The C55 tool is capable of running multiple scenarios with the project/program list being 20 optimized for the greatest annual value. All capital projects/programs in the corporation are run 21 through the Optimizer tool with projects from IT, fleet, planning, station construction and lines 22 construction competing on value through the same tool. The multiple scenarios permit the 23 results to be compared under various constraints and risks. The software tool takes all the 24 projects/programs within the capital portfolio, calculates a numeric dollar value based on the 25 benefit and risk calculations and the initial capital cost, and uses that value in the optimization 26 process.

27

28 The C55 optimizer selects the combination of start dates of projects that brings the highest total

29 value to PowerStream while fitting within the specified financial constraints.

1 Until projects are compared with one or another and the financial constraints are specified it is 2 not known whether a project will be funded or not - so a project lead cannot know for certain 3 whether or not a project will be funded. 4 5 Key Step Eight – Prepare the Results of the Various Scenarios 6 With the constraints set and the "must do" projects/programs accounted for, the results of the 7 various scenarios are presented and reviewed by a multi-departmental senior optimization team, who discuss which projects must be approved as part of the five year capital budget. 8 9 Members of the senior optimizer team include key leaders from each of the business units who 10 have major capital spend across the corporation, as well as Rates & Regulatory department and 11 Organizational Effectiveness department representatives. 12 13 Projects that were scored negative, are generally deferred beyond the six year horizon but are 14 also discussed to ensure that any intangible benefits are considered. Once reviews and 15 dependencies are considered, optimization can be run several times to achieve that optimal 16 balance between the computation (science) and human element (art). 17 18 A decision is made on the preferred constraint scenario, and any project/program adjustments 19 and deliberations occur prior to finalizing the preferred listing. 20 21 Key Step Nine - Determining and Approving the Portfolio of Projects/Programs 22 The result from the senior optimization team is a proposed scenario of multi-year projects and 23 programs that will be approved by the PowerStream's Executive Management Team (EMT) and 24 the Audit and Finance Committee for approval prior to approval by the Board of Directors. 25 26 The proposed scenario is submitted for approval with the appropriate business case details. For 27 projects less than \$500,000 the information is in its "mini-business case" format for each project. 28 For any specific project or program that is greater than \$500,000 or for IT related projects 29 greater than \$100,000, a full business case is provided and submitted for approval. 30

In conjunction with this process, for a rate filing year, the DS Plan's Customer Engagement process, as detailed in Exhibit G, Tab 2, Section 5.4.2, considers the responses of PowerStream's customers and a detailed review is held to correlate the proposed plan to the engagement results.

5

## 6 Key Step Ten – Load the Approved Portfolio into JD Edwards

7 The approved first year portfolio of projects/programs is loaded into the JD Edwards financial

8 system so that it is available for all departments use within the project execution process,

- 9 enabling project/program implementation.
- 10

## 11 Maintenance Planning Criteria and Assumptions

PowerStream has two main capital activities related to maintenance, which are planned andunplanned maintenance.

14

## 15 Planned (Proactive) Inspection and Maintenance

Activities associated with PowerStream's annual distribution inspection and preventative maintenance program are detailed in Table 2. When an inspection is performed on a given set of assets, a rating code is assigned. If the rating code assigned warrants immediate replacement, the replacement cost will generally be capitalized, while repairs will generally be expensed.

1

	2015	2016	2017	2018	2019	2020
O & M COSTS	3,290,425	3,824,791	4,364,492	4,909,270	5,459,443	6,014,538
insulator washing	140,000	141,400	142,814	144,242	145,684	147,142
pole testing	185,000	186,850	188,719	190,606	192,512	194,437
underground cable testing	51,945	53,177	54,431	55,506	56,521	57,417
dry ice cleaning	353,295	356,829	360,397	363,999	367,640	371,317
infrared scanning	146,856	148,516	150,193	151,841	153,490	155,104
overhead switch maintenance	353,329	357,419	361,532	365,606	369,752	373,528
vegetation management	2,060,000	2,580,600	3,106,406	3,637,470	4,173,844	4,715,593

### 2 3

#### Table 2: Annual O & M Spending

4

5 A description of these is below.

6

## 7 Insulator Washing

8 Overhead line insulator washing is required annually to prevent failure in the distribution system.

9 Insulators become contaminated by road salt or other airborne contaminants which can result in

10 flashovers and interruption of power. Insulator washing is carried out without necessitating

11 isolation of the overhead circuits and the resulting customer interruptions. It also includes visual

12 inspection and identification of any damaged equipment in the main feeder infrastructure.

13

## 14 Pole Testing

As part of PowerStream's Asset Condition Assessment (ACA) Program, wood poles are inspected and tested. This work is performed by a contractor who submits electronic records of their inspections/tests to the Asset Investment Planning department. Results of the testing are used to determine candidates for pole remediation. Refer to Exhibit 2, Tab 4, Section 5.3.3 for information on the pole remediation program.

20

## 21 Underground Cable Testing

In 2012, PowerStream commenced a program to perform Very Low Frequency ("VLF") Tan
Delta testing of its underground cable to determine if there has been any deterioration in the
cable insulation. Targeted areas, based upon cable age and deteriorating performance, are

identified and tested, and the results and taken into consideration for the selection of areas for
cable remediation. Refer to Exhibit G, Tab 2, Section 5.3.3 for information on the cable
remediation program.

4

## 5 Dry Ice Cleaning

6 The dry-ice cleaning program for air-insulated pad-mounted switchgear and vault room 7 switchgear is a cleaning method that allows an efficient and cost effective maintenance of 8 switchgear. Air-insulated switchgear become contaminated with dirt, dust and road salt that can 9 lead to flashovers and equipment failure. The high pressure dry ice method of cleaning allows 10 for air-insulated switchgear to be cleaned without the necessity of isolating the equipment and 11 removing the unit from service. Switchgear is typically cleaned on a six year cycle unless a 12 location is determined to require more frequent cleaning due to high levels of contamination.

13

## 14 Infrared Scanning

PowerStream's Lines Department also uses infrared scanning to identify overheating components on its overhead and underground distribution system. As a result of the infrared scanning, equipment showing signs of overheating is scheduled for repair or replacement on a priority level based on the severity of the overheating.

19

## 20 Overhead Switch Maintenance

21 Maintenance of three phase gang operated switches, both manually operated and remotely 22 operated, is required to ensure the switches are free of contamination and operate smoothly 23 and efficiently. PowerStream currently maintains the switches over a five year cycle. 24 Maintenance of overhead switches requires isolation of the switches.

25

## 26 Vegetation Management

PowerStream's vegetation management program was historically based on a five-year tree trimming cycle, with adjustments for more densely treed, overhead areas. Targeted tree trimming that is not part of the regular five-year cycle was carried out directly as a result of outages caused by trees and as part of the worst performing feeder program. In assessing the effectiveness of the tree trimming program, it became evident that there was a trend toward increased "reactionary" tree trimming as a result of outages and to meet the needs of the worst performing feeder program. This was diverting resources away from the annual cycle trimming program and upon review it was determined that the five year trimming cycle was not adequate to keep up with tree growth across the service territory. As such the tree trimming cycle has been adjusted to a three year cycle across the territory.

6

Additionally, further vegetation management strategies were recommended by the System
Hardening review as a result of the ice storm. PowerStream has changed its policy for rear
yards and heavily treed front yards from a five year cycle to a two year cycle. Rural areas now
have a 4 year tree trimming cycle where previously they were not part of the tree trimming
cycle.

12

## 13 Unplanned (Reactive) Maintenance

Activities in this category are typically associated with equipment failures that are usually accompanied by outage trouble shooting and restoration. Power interruptions on the distribution system result from a variety of causes as indicated by the multitude of Canadian Electrical Association (CEA) cause codes. Responses to outages are performed by trouble crews.

18

Where the repairs made to the distribution system are minor, maintenance work orders are charged. This includes work such as splicing conductors, repairing guying and down grounds on poles, tightening loose attachments, painting rusted tanks, levelling uneven pad bases or repositioning shifted transformers and repairing secondary failures.

23

## 24 Impact of System Renewal on Routine O&M and Emergency/Reactive Repairs

- 25 Routine O&M
- 26 Although System Operations and Maintenance (O&M) and capital investments are interrelated,
- a significant portion of System O&M expenditures are directed to activities that are independent
- 28 of specific capital expenditure, including:
- Testing of assets for health condition assessments necessary to provide the information
   that is used to plan the capital programs;

- Regular maintenance activities to preserve asset performance over its expected life, 1 2 such as minor repairs, equipment adjustments or cleaning; 3 Vegetation management to maintain minimum clearance requirements for overhead conductors and equipment, both annually, and increased amounts as a result of 4 5 recommendations from the ice storm; 6 • Cyclical patrols and inspections undertaken as good utility practice and to comply with 7 minimum Distribution System Code requirements; and 8 • Corrective maintenance activities to address deficiencies caused by animal, pest, or 9 tree contacts or asset deterioration. 10 11 The information captured through O&M programs is necessary to enable the prioritization of 12 asset replacements for capital work and to ensure that the assets that remain in-service have 13 not surpassed their useful life. 14 15 As can be seen in Figure 6, PowerStream continues to add distribution system assets, steadily 16 increasing the volume of equipment that needs to be maintained and inspected. PowerStream 17 continues to monitor, test, inspect and maintain/repair all components of the distribution system
- 18 to ensure safety for its personnel and the public and to provide acceptable service to customers.
- 19

GIS Annual Facts 2009 vs 2014								
	2009	2014	Difference					
			# %					
Total Primary UG KM of Conductor Material	7172.4	8137.5	965.1	13.46%				
Distribution Transformers	40241	44192	3951.0	9.82%				
Switchgear	1744	1847	103.0	5.91%				
Meters (Service Points)	313880	356210	42330.0	13.49%				

20

Figure 6: Annual Fast Facts (2009-2014)

1 PowerStream anticipates additions from 2015 to 2020 to increase at a similar rate. The result is 2 that the O&M budget requirement is not expected to decrease and in fact increases annually. 3 With the exception of vegetation management, the year-over-year growth in O&M budgets are 4 small, despite the growing asset base (as shown in Table 2, page 26). 5 6 Emergency/Reactive Replacements 7 Although system renewal projects and emergency/reactive replacements are interrelated, a 8 portion of emergency/reactive replacements are directed to activities that are independent of 9 particular capital expenditure levels, including: 10 corrective maintenance activities to address deficiencies caused by animal, pest, or tree 11 contacts; 12 emergency maintenance resulting from vehicular accidents/vandalism; • 13 emergency maintenance resulting from severe weather and storms; • 14 • equipment failure due to deteriorated condition; and 15 equipment in poor condition as identified during system inspections. • 16 17 PowerStream's system renewal program has been designed to: 18 Hold system failures, and consequently, reliability, at a constant level (not get worse); 19 Strike a balance between affordable spending and tolerable risk; and • 20 Result in the levelling of capital reactive spending (emergency replacements). • 21 22 Within PowerStream's ACA models, curves have been developed to indicate a correlation 23 between asset condition/age and failures, and depict the likely expected number of failed units 24 over time. If proactive replacement of the worst assets can be performed, the level of 25 anticipated failures can be held to a steady state. 26

1 If the levels of proactive system replacement, when combined with the reactive system 2 replacements, fall within the anticipated annual failure rates within various asset classes, a 3 steady state can be achieved. This approach results in levels of capital spending that are 4 acceptable with the risk mitigated, provide level, paced capital spending and do not increase the 5 capital costs for reactive replacement.

6

7 Replacing selected unhealthy units with new units will improve reliability due to the failure on the

8 unhealthy units being avoided. Additionally, since the total population increases annually, and

9 this applies to all assets, there is an increased probability for asset failure as time goes on. This

10 balance of renewal and aging holds the overall system reliability at the same level.

11

As detailed in Exhibit G, Tab 2, Section 5.4.5, page17, proposed spending for *Distribution Lines – Emergency/Reactive Replacements* are summarized in Table 3. Additionally, reactive O&M is

13 – *Emergency/Reactive Replacements* are summarized in Table 3. Additionally, reactive O&M is

14 summarized. Expenditures will either be allocated to capital or O&M based on the required

15 repair and magnitude of the work performed.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.3.3 Asset Lifecycle Optimization Policies and Procedures Page 32 of 38 Delivered: February 24, 2015

	Actuals				Proposed					
	2011	2012	2013	2014	2015	2015 2016 2017 2018				2020
Distribution Lines - Emergency/Reactive Replace Capital	\$7,194,378	\$7,918,155	\$8,219,497	\$8,697,396	\$8,416,283	\$8,636,001	\$8,729,603	\$8,888,091	\$8,924,606	\$8,504,138
a) LIS - Unscheduled Replacement of	<i>\$7,134,370</i>	\$7,510,133	<i>30,213,437</i>	20,037,330	<i>30,410,203</i>	<i>\$8,030,001</i>	<i>30,723,003</i>	<i>30,000,031</i>	<i>30,324,000</i>	<i>30,304,130</i>
Failed (end of useful Life)		\$334,123.00	\$51,210.00	\$125,384.00	\$350,776.00	\$346,168.00	\$331,291.00	\$321,119.00	\$276,190.00	\$275,612.00
Distribution Equipment		\$55 IJ125100	\$51) <u>21</u> 0.00	¢125,50 moo	\$556,776.00	<i>\$5</i> 10,200.00	<i>\$551,251.00</i>	\$521,115.00	<i>\$270,230,000</i>	<i>\$275,612.00</i>
b) Non Recoverable replacement of										
Distribution Equipment due to	\$103,434.00	\$126,031.00	\$138,680.00	\$208,789.00	\$210,774.58	\$220,581.01	\$220,972.56	\$220,972.47	\$211,280.95	\$191,499.23
accident/vandalism	, ,	+	+,	1	+,	+	+	<i>q</i> ====,= · · · · ·	+)	<i>,,</i>
c) Recoverable Replacement of										
distribution equipment due to	\$137,439.00	\$714,253.00	\$807,981.00	\$816,842.00	\$530,442.20	\$530,600.67	\$545,432.33	\$560,875.95	\$570,984.37	\$580,023.22
Accidents/Vandalism	<i>,,</i>	<i>t</i> - <i>y</i>	+	T	<i>+</i> , · · <u>-</u> ·	+,	+- ·-, ··	<i></i>	<i>+</i>	<i></i>
d) Storm damage - Replacement of										
distribution equipment due to	\$428,418.00	\$482,911.00	\$767,149.00	\$1,160,050.00	\$999,784.75	\$1,000,232.43	\$1,005,602.71	\$1,005,624.45	\$1,010,352.34	\$1,010,159.38
storm.	+,	<i>+</i> ····/······	+,	+-,,	+	+-,,	+-,,	<i>+_,,.</i>	+-,,	+-,,
e) Switchgears - Unscheduled										
Replacement of Failed (end of		\$1,381,861.00	\$1,663,004.00	\$1,495,974.00	\$1,420,148.09	\$1,431,383.51	\$1,420,147.96	\$1,421,218.32	\$1,400,444.11	\$1,140,858.02
useful Life) Distribution Equipment		\$1,501,001.00	¢1,000,000 moo	<i>Q</i> 1,155,57 1100	¢1, 120,1 10.05	<i>Q</i> , 131, 303.31	<i>φ1</i> , 120,117130	<i>Q1</i> , 121,210.02	<i>\$1,100,11111</i>	<i>\$1,110,000101</i>
f) Unscheduled Replacement of										
Failed (end of useful Life) poles,	\$5,472,537.00	\$3,771,553.00	\$4,051,060.00	\$4,157,571.00	\$4,004,267.00	\$4,136,745.00	\$4,195,526.00	\$4,298,340.00	\$4,349,171.00	\$4,266,252.00
conductors & devices (S)	<i>\$</i> 3, 17 <b>2</b> ,337100	<i>\$3,772,333</i> .00	\$ 1,051,000.00	\$ 1,157,57 1.00	\$ 1,00 1,207.00	¢ 1,250,7 15100	¢ 1,133,320.00	¢ 1,230,3 10.00	<i>\$ 1,5 15,11 100</i>	\$ 1,200,202.00
g) Unscheduled Replacement of										
Failed (end of useful Life)										
Distribution Equipment - Poles,	\$1,052,550.00	\$1,107,423.00	\$740,413.00	\$732,786.00	\$900,090.00	\$970,290.00	\$1,010,630.00	\$1,059,941.00	\$1,106,183.00	\$1,039,734.00
conductors & devices (N)										
Distribution Lines -Reactive O & M	\$5,400,663.80	\$5,107,963.06	\$6,862,122.52	\$5,857,601.24	\$5,888,034.00	\$6,028,513.00	\$6,172,551.00	\$6,307,553.00	\$6,440,120.00	\$6,572,121.00
h) Inspections, Patrol, Testing	\$478,946.45	\$558,421.79	\$501,527.00	\$434,200.74	\$728,443.00	\$739,101.00	\$749,929.00	\$759,915.00	\$769,619.00	\$778,996.00
i) Accidents & Vandalism	\$530,023.70	\$348,177.74	\$355,100.84	\$528,236.75	\$408,551.00	\$417,861.00	\$427,351.00	\$435,491.00	\$443,139.00	\$450,133.00
i) Poles and Lines Hardware	\$686,710.96	\$630,138.29	\$524,338.75	\$683,144.97	\$577,254.00	\$589,761.00	\$602,520.00	\$613,512.00	\$623,834.00	\$633,461.00
k) Storm Damage	\$522,403.45	\$337,871.22	\$2,130,447.97	\$265,277.83	\$369,686.00	\$377,037.00	\$384,538.00	\$391,068.00	\$397,211.00	\$403,090.00
l) Cable Faults - Primary	\$1,488,438.22	\$1,608,997.25	\$1,725,815.28	\$1,949,015.66	\$2,201,209.00	\$2,258,403.00	\$2,317,214.00	\$2,374,693.00	\$2,432,340.00	\$2,491,112.00
m) Cable Faults - Secondary	\$1,042,341.74	\$1,013,225.11	\$968,755.14	\$1,392,126.37	\$1,030,677.00	\$1,059,857.00	\$1,089,858.00	\$1,119,514.00	\$1,149,470.00	\$1,179,856.00
n) Customer Premises	\$368,158.01	\$335,833.91	\$323,042.73	\$312,657.00	\$304,889.00	\$312,771.00	\$320,873.00	\$327,565.00	\$333,602.00	\$339,707.00
o) Switching for Control Room	\$102,177.94	\$138,348.30	\$160,101.14	\$120,907.91	\$101,848.00	\$104,271.00	\$106,746.00	\$108,849.00	\$110,808.00	\$112,626.00
p) Permanent Removals	\$181,463.33	\$136,949.45	\$172,993.67	\$172,034.01	\$165,477.00	\$169,451.00	\$173,522.00	\$176,946.00	\$180,097.00	\$183,140.00

1 2

## Table 3: Annual Emergency/Reactive Replacements (Capital and O&M)

3

On an overall annual basis, the total *for Distribution Lines – Emergency/Reactive Replacements*(capital) increases between 2015 to 2019, and commencing in 2020, the overall cost is
expected to commence decreasing. The *Distribution Lines – Reactive O&M*, increases annually.
Each individual line element has its own trending, as described below.

8

9 Item a) LIS - Unscheduled Replacement of Failed (end of useful Life) Distribution
 10 Equipment: This subcategory is trending downwards from 2015 to 2020 as a result of
 11 improved inspection and maintenance procedures and activities.

*Items b), c) and i) - Non Recoverable replacement of Distribution Equipment due to accidents/vandalism:* This subcategory is trending upwards by inflationary amounts from
 2015 to 2107, and trends downwards from 2018-2020 on recoverable as a focus on
 recovering these costs will be implemented.

*Items d) and k) - Storm Damage - Replacement of distribution equipment due to storms:*This sub-category is expected to trend upwards from 2015-2018, and then is expected to
trend downwards in 2019 and beyond as a result of storm hardening initiatives.

*Item e) Switchgears - Unscheduled Replacement of Failed (end of useful Life) Distribution Equipment:* This sub-category is expected to trend upwards from 2015-2018, and then is
 expected to trend downwards as a result of proactive replacement programs.

13

5

9

*Items f), g) and k) - Unscheduled Replacement of Failed (end of useful Life) Poles, Conductors and Devices:* This sub-category is expected to trend upwards from 2015-2018,
and then is expected to commence trending downwards as a result of remediation
programs.

18

21

*Item h) Inspections, Patrol, Testing*: This sub-category is expected to trend upwards by
 inflationary amounts.

*Item I) Cable Faults – Primary:* This sub-category is expected to trend upwards by
 inflationary amounts as the cable remediation program is expected to maintain the current
 levels.

25

*Item m) Cable Faults – Secondary:* This sub-category is expected to trend upwards as the
 secondary system ages and additional plant is installed. There is no proactive replacement
 program for this asset (run to failure).

29

*Item n) Customer Premises:* This sub-category is expected to trend upwards by inflationary
 amounts.

- *Item o) Switching for Control Room:* This sub-category is expected to trend upwards by
   inflationary amounts.
- 3

*Item p) Permanent Removals:* This sub-category is expected to trend upwards by
 inflationary amounts.

6

## 7 Impact of System Renewal on Reliability

As seen in Figure 7, 2013 was a difficult year for PowerStream. Since reliability indices are lagging, the rolling three year average SAIDI will have increased. Even though PowerStream will be within its historical three year average, PowerStream will not be using this as its indication of reliability improvement. Instead, PowerStream will be striving for targets determined by its Reliability Model.

13

In 2014, PowerStream created its Reliability Model. This model was designed to calculate a five year forward looking reliability projection in terms of SAIDI performance based on the past five years of reliability history and future planned capital system renewal reliability related improvements.

18

Within the model, outage causes are associated with controllable and uncontrollable factors that
are included in the Canadian Electrical Association outage cause codes. These are listed in
Table 4.

22


(CEA Code #) Controllable factors	(CEA Code #) Uncontrollable factors
(5) Defective Equipment	(9) Foreign Interference (3 <sup>rd</sup> party event)
(1) Scheduled Outage (by P/S to do work)	(2) Loss of Supply (Hydro One)
(3) Tree Contact	(7) Adverse Environment (Weather Dependent)
	ie salt
(8) Human Element	6) Adverse Weather (Weather Dependent)
	(4) Lightning (Weather Dependent)

23

24

## Table 4: Controllable and Uncontrollable Outage Cause Codes

- 1 The model breaks down SAIDI into its controllable and uncontrollable factors and identifies
- 2 contributions made by factors tied to weather, as weather has a significant impact on reliability
- 3 and makes up most of the uncontrollable SAIDI. Refer to Figure 7.
- 4





11

1 These are defined below:

- 'Baseline SAIDI' or starting point CMI (Customer Minutes of Interruption) is calculated by averaging the past five years SAIDI performance due to non-weather related outages.
  'Weather Outages' is calculated by averaging the SAIDI performance due to weather related outages over the past five years.
  'Increase in Scheduled Outages' is calculated using the yearly increase in capital spend
  - as a proportional guideline.
- \* 'Reliability Improvements' is calculated based on the CMI Savings achieved from each
   technical project or work program accounted for in the 5 Year Reliability Work Plan.
- 10

7

11 A list of the technical projects and work programs included in the 2015 to 2019 Reliability Work


12 Plan that impact SAIDI are shown in Table 5. The distribution system programs are described

13 starting on page 4 of this Section (5.3.3).

14

#	Description	Capital	O&M
1	Worst Performing Feeders (WPF)		Х
2	Inspection and Maintenance		Х
3	Pole Remediation	Х	
4	Cable Remediation	Х	
5	Switchgear Replacement	Х	
6	Mini-Rupter Switch Replacement Program	Х	
7	Automated Switch Replacement	Х	
8	Submersible Transformer Replacement	Х	
9	Distribution Transformer Replacement	Х	
10	44kV Insulators Replacement Program	Х	
11	Fault Indicator Program	Х	
12	Storm Hardening & Rear Lot Remediation	Х	
13	Distribution Automation	Х	
	Table 5: 2015 to 2019 Reliability Based Projects and	Program	<u>s</u>

- 1 Based on the Reliability Model calculations, the 5 year reliability forecast for 2015 to 2019 is
- 2 depicted in Figure 8.
- 3



- 4 5
- 6

Figure 8 breaks down the Future years' predicted SAIDI into its controllable and uncontrollable codes. The green bars indicate contributed SAIDI from controllable factors and red bars indicate contributed SAIDI from uncontrollable factors. The yellow bars are included to account for a certain level of uncertainty that arises in future years due to potential emerging reliability problems that are yet unknown. The blue line on the chart illustrates the total SAIDI prediction for each year. Since weather has appeared to be relatively unpredictable based on the analysis of previous
 year's performance, an upper and lower limit are included to create boundaries for the SAIDI
 targets. These are represented using grey dotted lines.

4

5 The upper and lower bounds are there to account for the unpredictable nature of the weather 6 and other emerging outages that could disrupt the targets. The upper limit is calculated using 7 three Standard Deviations of the average performance. The lower limit is calculated based on 8 the minimum SAIDI experienced in previous years, as it is expected that weather would not be 9 milder than has been in the past.

10

In summary, there is an expectation that the projects and programs will lead to a modest
 improvement in reliability to customers as the controllable portion of the SAIDI will decrease as
 the capital projects/programs and the O& M projects are implemented.

- 14
- 15
- 16

#### **5.4.1 CAPITAL EXPENDITURE PLAN SUMMARY** 1

2 This section elicits key information about a distributor's capital expenditure plan including, by category 3 (see section 5.1.1), significant projects and activities to be undertaken and their respective key drivers; 4 the relationship between investments in each category and a distributor's objectives and targets; and the 5 primary factors affecting the timing of investment in each category (or of projects within each category, if 6 significant). 7

8 The following information should be provided:

9

- 10 information on the capability of the distributor's system to connect new load or generation a) 11 customers in sufficient detail to convey the basis for the scope and quantum of investments 12 related to this 'driver':
- 13 b) total annual capital expenditures over the forecast period, by investment category (see section 14 5.4);
- 15 c) a brief description of how for each category of investment, the outputs of the distributor's asset 16 management and capital expenditure planning process have affected capital expenditures in that 17 category and the allocation of the capital budget among categories;
- 18 d) a list and brief description including total capital cost (table format recommended) of material 19 capital expenditure projects/activities, sorted by category;
- 20 information related to a Regional Planning Process or contained in a Regional Infrastructure Plan e) 21 that had a material impact on the distributor's capital expenditure plan, with a brief explanation as 22 to how the information is reflected in the plan;
- 23 f) a brief description of customer engagement activities to obtain information on their preferences 24 and how the results of assessing this information are reflected in the plan;
- 25 g) a brief description of how the distributor expects its system to develop over the next five years, 26 including in relation to load and customer growth, smart grid development and/or the 27 accommodation of forecasted renewable energy generation projects;
- 28 h) a list and brief description including where applicable total capital cost (table format 29 recommended) of projects/activities planned:
- 30 in response to customer preferences (e.g., data access and visibility; participation in • distributed generation; load management);
- 32 to take advantage of technology-based opportunities to improve operational efficiency, asset ٠ 33 management and the integration of distributed generation and complex loads; and

- 1 2
- to study or demonstrate innovative processes, services, business models, or technologies.
- 3

# 4 Capability of PowerStream to Connect New Load

5 As indicated in Exhibit G, Tab 2, Section 5.3.2 Table 3, PowerStream will have the capacity to

6 connect new customers with the construction of transformer and substations as proposed in

- 7 Exhibit G, Tab 2, Section 5.4.5.
- 8
- 9 As indicated in Exhibit G, Tab 2, Section 5.4.3 page 14, PowerStream should have the capacity
- 10 to connect new generation customers.
- 11

# 12 Total Annual Capital Expenditures by Investment Category

- 13 The annual capital expenditures by investment category is shown in Table 1, and is fully
- 14 described in Exhibit G, Tab 2, Section 5.4.4 and 5.4.5.
- 15

Historical					Proposed					
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
CATEGORY	Actual	Actual	Actual	Actual	Plan	Plan	Plan	Plan	Plan	Plan
Rate Base	\$'000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000
System Access	21,007	19,888	17,030	26,229	24,145	28,232	28,470	29,561	28,726	31,867
System Renewal	11,527	16,974	22,254	39,186	42,388	48,715	51,500	52,052	52,971	52,406
System Service	22,885	13,770	34,780	17,946	27,322	38,322	32,072	29,920	26,963	23,022
General Plant	7,877	24,200	19,593	26,148	24,545	17,531	19,458	13,867	16,741	18,106
Sub-Total	63,297	74,832	93,657	109,509	118,400	132,800	131,500	125,400	125,401	125,400
Non-Rate Base	2,278	1,196	2,628	1,364	2,489	-	-	-	-	-
Grand Total	65,575	76,028	96,285	110,873	120,889	132,800	131,500	125,400	125,401	125,400
System O&M	2,055	2,438	2,523	2,627	3,290	3,825	4,365	4,909	5,459	6,015

Table 1: Capital Expenditures by Investment Category

- 16
- 17
- 18
- 19
- 20
- 21
- 22

### 1 Outputs of the Plan

PowerStream's Asset Management Planning Process affects the proposed capital expendituresof the main categories in the manner described below.

4

# 5 <u>System Access</u>

6 The inputs and criteria of the Asset Management Planning Process plays a limited role in 7 determining capital expenditures within the System Access category. Instead, projects and 8 capital expenditures are determined from Business Cases primarily based on the following:

- a) Subdivision and New Connections: Short and long-term forecasts of growth in customer
  connections and load growth, based on historical figures. These are categorized as
  "must-do" projects.
- b) Road Authority Projects: Information obtained from municipalities, regions, etc, of future
  projects and proposed scopes. These are categorized as "must do" projects.
- c) Metering: Business Unit needs assessment of new and/or replacement retail and/or
   wholesale metering. The majority of these projects are considered "must-do".
- d) Other Customer Initiated Work: Business Unit needs assessment of expenditures
   required to facilitate customer work based on historical requests and costs. These are
   categorized as "must-do" projects.
- 19

The total dollar amount of the System Access category is determined from the sum of the individual projects within the category. Due to the "must-do" nature of most of the projects within System Access, they are not impacted by the C55 Optimization process. The total dollar amount of the System Access category is not set or impacted by an allocation of PowerStream's overall capital budget.

25

# 26 System Renewal

As more fully described in Exhibit G, Tab 2, Section 5.3.1, the Asset Management Planning Process, with its various inputs and criteria, is the main determinant of proposed projects and their expenditures within the System Renewal category. In particular, the recommendations from Asset Condition Assessments constitute the main driver for the origin of the majority of projects in the System Renewal category.

- 1 The level of spending for the majority of projects within System Renewal is determined by an 2 individual project-by-project assessment of criticality, asset condition, reliability and safety. 3 4 As more fully described in Exhibit G, Tab 2, Section 5.3.3 page 18, the allocation of the overall 5 capital budget to the System Renewal category, and the projects within that category, is 6 determined using Copperleaf's C55 Optimization software, limited by a fixed financial constraint 7 of the overall PowerStream capital budget. Projects determined to be "must-do" projects are 8 not optimized by the C55 software program. 9 10 The process is simplified to: 11 12 Business Units develop their initial five year capital plans as part of the annual capital 13 planning cycle; 14 Business units prepare detailed budgets, justifications and business cases for projects, 15 and enter these into the Optimization tool; A Corporate Five Year Plan is compiled based on the submitted business unit five 16 17 proposed projects/programs as part of the capital planning cycle; and 18 The five year detailed budgets for all business units are prioritized through the 19 Optimization process. 20 21 Approved and prioritized projects for years one and two are designed and readied for execution 22 in the next business year(s). Approved and prioritized projects for the remaining three years are 23 identified and design can be commenced only if warranted 24 25 System Service 26 Similar to the System Renewal category, the composition of the projects in the System Service 27 category are driven by the Asset Management Process. The main difference is that the Asset 28 Condition Assessment plays a lesser role in the Asset Management Process for determining the
- 29 projects and capital expenditures within the System Service category.
- 30

The various components (inputs) of the Asset Management Process result in a project-byproject listing that addresses the needs identified within the Process. The capital budget for each of the projects within the System Service category is determined from the scope of each project.

5

6 The allocation of the overall capital budget to the System Service category, and the projects 7 within that category, is determined using the Copperleaf C55 Optimization software, limited by a 8 fixed financial constraint of the overall PowerStream capital budget. Projects determined to be 9 "must-do" projects are not optimized by the C55 software program. The same process, as 10 stated in system renewal above, is applied.

11

# 12 General Plant

Depending on the type of project, Business Cases for individual projects constitute the main
 driver within the Asset Management Process for the majority of projects within the General Plant
 category.

16

The allocation of the overall capital budget to the General Plant category, and the projects within that category, is determined using the Copperleaf C55 Optimization software, limited by a fixed financial constraint of the overall PowerStream capital budget. Projects determined to be "must-do" projects are not optimized by the C55 software program. The same process, as stated in system renewal above, is applied.

22

# 23 Material Capital Expenditures

PowerStream's Capital Expenditure Plan includes a total of 71 Material Investment categoriesor projects, allocated as:

- 8 as System Access;
- 14 as System Renewal;
- 38 as System Service; and
- 11 as General Plant.
- 30

1 In accordance with OEB Guidelines, PowerStream's 2014 Materiality Threshold is calculated to

2 be \$771k, based on 0.5% of PowerStream's 2013 distribution revenue of \$154M. A listing of

- 3 the individual Material Investment Projects, sorted by category, is shown in Table 2 to Table 5.
- 4 5

Material Investments	2015	2016	2017	2018	2019	2020
System Access	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
New Connections and Subdivisions						
New Commercial Subdivision Development	1,600,010	1,601,908	1,603,808	1,605,707	1,607,607	1,609,506
New Residential Subdivision Development	7,895,964	8,633,109	9,392,346	9,759,944	10,135,066	10,517,394
New Subdivision Development - Secondary Service Lateral	1,989,034	2,173,796	2,364,815	2,458,773	2,554,113	2,650,954
O/H and U/G Residential Service Upgrades	928,921	984,657	1,043,737	1,106,360	1,172,741	1,243,109
Road Authority						
Road Authority Expenditures	6,258,891	9,701,973	8,678,858	8,356,668	5,718,617	6,221,949
Metering						
GS>50 MIST Meter Program Implementation	1,592,952	1,196,859	1,303,795	1,308,610	1,195,725	574,761
Residential Meter "ICON F" Meter Replacement Program	411,051	494,361	494,746	872,435	2,280,384	4,517,454
Other Customer Initiated Work						
Unforeseen Projects Initiated by the Customer	329,005	786,802	929,401	1,080,390	1,255,781	1,414,541
Total Material Investments System Access	21,005,828	25,573,466	25,811,508	26,548,888	25,920,034	28,749,669

Table 2: Material Investments - System Access

6

Material Investments	2015	2016	2017	2018	2019	2020
System Renewal	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
UG Lines - Planned Asset Replacement						
Cable Injection Program	4,024,219	4,138,312	4,255,465	4,375,771	4,499,323	4,626,21
Cable Replacement Program	11,718,862	12,538,684	13,607,273	14,288,297	15,085,861	15,340,18
Emerging Cable Replacement Projects	491,687	520,801	1,050,756	1,081,576	1,113,287	1,145,91
Submersible Transformer Replacement	1,040,300	620,000	-	-	-	-
Switchgear Replacement Program	2,003,445	2,327,404	2,462,129	2,533,373	2,606,624	2,681,94
Distribution Lines - Emergency/Reactive Replace						
Storm damage - Replacement of Distribution Equip due to Storms	999,785	1,000,232	1,005,603	1,005,624	1,010,352	1,010,15
Switchgears - Unscheduled Replacement of Failed Switchgear	1,420,148	1,431,384	1,420,148	1,421,218	1,400,444	1,140,858
Unscheduled Replacement of Other Failed Distribution Equip	4,904,357	5,107,035	5,206,156	5,358,281	5,455,354	5,305,986
Overhead Lines - Planned Asset Replacement						
Pole Replacement Program	4,645,383	4,933,143	5,570,700	5,870,246	6,241,483	6,244,37
Unforeseen Projects Initiated by PowerStream	1,046,472	1,070,527	1,093,812	1,117,360	1,141,172	1,165,266
Storm Hardening						
Storm Hardening & Rear Lot Supply	3,499,998	7,900,017	7,999,752	7,499,834	6,900,540	7,200,072
Stations/P&C - Planned & Emergency						
Planned Circuit Breaker Replacement Markham TS1&2, Lazenby TS1	747,766	-	-	1,087,788	1,119,281	-
Station Switchgear Replacement (ACA) 8th Line MS323	-	-	412,339	1,106,666	-	-
Station Switchgear Replacement (ACA) Patterson MS336	-	-	-	421,896	895,805	-

Table 3: Material Investments - System Renewal

Material Investments	2015	2016	2017	2018	2019	2020
System Service	(\$ )	(\$ )	(\$ )	(\$)	(\$ )	(\$)
Additional Capacity - Stations						
Letitia MS (MS413)- Increase Capacity from 5MVA to 10MVA Year 1 of I	-	-	-	644,864	1,389,927	-
Painswick South MS: New 44-13.8kV, 20 MVA, 4-Feeder Substation- yea	2,690,054	-	-	-	-	-
Patterson MS#2 - New 44-13.8kV, 2x5 MVA, 2-feeders MS, Year 1 of 2	-	-	-	-	749,000	1,931,978
New MS, Dufferin South MS#2 - Alliston	-	749,000	2,299,074	4,899,189	-	-
New MS, Harvie Rd. MS - Barrie	-	749,000	-	-	-	1,700,333
New MS, Little Lake MS#2 - Barrie	1,125,311	1,603,656	3,095,457	-	-	-
New MS, Melbourne MS#2 - Bradford	-	749,000	1,651,393	3,187,430	-	-
New MS, Mill Street MS#2 - Tottenham	-	642,000	1,821,953	3,529,079	-	-
Vaughan TS #4 - Build Station	10,249,162	11,226,183	422,915	-	-	-
Additional Capacity -Lines						
2x44kV circuits (23M22 & 23M23) from Midhurst TS2 to Essa Rd. and M	5,011,705	3,606,692	4,460,060	-	-	-
Add one 27.6 kV Cct on Steeles Ave From Jane St to Keels St	-	-	-	-	1,110,310	-
Add one Additional 27.6 kV Cct on Major Mack and 9th Line	-	-	-	-	-	1,248,939
Build double ccts 27.6kV pole line on 19th Ave between Leslie St and Ba	-	-	1,221,747	-	-	-
Install 2x13.8kV ccts Pole Line on Leslie St from Wellington St to St.John	-	1,131,418	-	-	-	-
Install Double Cct Pole Line on Major Mackenzie - Hwy 27 to Huntingtor	-	-	-	1,819,608	-	-
Install Double Ccts 27.6 kV Pole Line on 16th Ave from 9th Line to Reeso	-	-	-	-	1,302,301	-
Install one 44kV cct on Mapleview Drive West - Essa to Veterans	-	-	-	855,914	-	-
Install Two 27.6kV Ccts on 16th Ave from Hwy 404 to Woodbine Ave	-	1,108,593	-	-	-	-
Install two additional 27.6 kV ccts on Hwy 7 from Jane St to Weston Rd	-	-	-	-	-	2,084,275
Installation of two new circuits on Leslie Street - 19th Ave to Stouffville S	-	-	-	-	-	1,392,644
Markham TS #4 Feeder Egress Part 3	-	-	-	-	-	4,910,872
New 27.6kV Pole Line on 19th Ave from Leslie to Woodbine Ave	-	-	-	-	1,020,587	-
New 44 kV Feeder (13M7) Barrie TS X Huronia & Big Bay Pt. Rd Design	76,925	4,726,805	-	-	-	-
Pole Line Installation Double Cct on Major Mack - Huntington Rd to Hwy	-	-	-	-	1,307,147	-
Rebuild 27.6 kV pole line for 4 Ccts on Warden Ave from Major Mack to	-	-	-	2,061,719	-	-
Rebuild 27.6 kV pole line into 4 Ccts on Warden Ave from Hwy 7 to 16th	-	2,039,163	-	-	-	-
Rebuild 27.6 kV pole line on Warden Ave into 4 ccts from 16th Ave to M	-	-	2,050,441	-	-	-
Rebuild Pole Line on 14th Ave into 4 cct -From Warden Ave to Kennedy	-	-	1,206,790	-	-	-
Two Ccts on Birchmount Rd from ROW to 14th Ave	-	-	-	-	-	1,502,063
Two Ccts on Birchmount Rd from ROW to Enterprise	1,201,150	-	-	-	-	-
Vaughan TS#4 Feeder Integration	-	-	7,341,955	3,176,402	9,630,000	-
27.6 kV Pole Line on 14th Ave from Hwy 48 to 9th Line	-	2,039,163	-	-	-	-
27.6 kV Pole Line on Reesor Rd from Hwy 7 to 14th Ave	-	1,496,942	-	-	-	-
Double Circuit existing 23M8 Circuit from Bayfield & Livingstone to Little	-	-	-	-	2,395,509	-
Highway Crossing Remediation - Hwy 400/ Brock St.	-	-	-	1,038,486	-	-
Highway Crossing Remediation - Hwy 407/ East of Dufferin	1,100,409	-	-	-	-	-
Reliability including Dist. Auto.						
Distribution Automation Switches / Reclosers	1,850,276	1,530,249	2,080,457	2,283,805	2,354,895	2,409,740
Purchase of a Mobile Unit Station	-	-	-	-	-	885,481
Total Material Investments System Service	23,304,991	33,397,865	27,652,242	23,496,497	21,259,677	18,066,325

Material Investments	2015	2016	2017	2018	2019	2020
General Plant	(\$)	(\$ )	(\$)	(\$)	(\$ )	(\$)
Customer Information System (CIS)						
CIS Modifications	1,403,400	3,884,100	6,708,900	2,996,000	2,996,000	2,996,000
CIS Replacement Project	10,300,000	-	-	-	-	-
IT & Info/Communication Systems						
JD Edwards Application Upgrade	-	-	-	-	2,396,800	-
MSBPI	-	10,000	60,000	899,999	50,000	10,000
Phone System enhancement Upgrade	-	-	-	-	50,500	908,999
Storage Expansion (Data)	321,000	300,000	300,000	300,000	1,000,000	400,000
Work Force Management / Mobile Dispatch	1,605,000	2,675,000	802,500	802,500	535,000	535,000
Buildings & Emerging Operations						
Barrie Building Renovation Project 2015	3,149,489	-	-	-	-	-
Fleet						
Replace various Light and Medium Duty Vehicles	-	-	-	-	829,250	888,100
Replace various Single Bucket and Double Bucket Trucks	-	-	-	2,193,500	1,605,000	1,391,000
Interest Capitalization						
Interest Capitalization	1,000,000	1,020,000	1,040,000	1,061,000	1,082,000	1,104,000
Total Material Investments General Plan	17,778,890	7,889,100	8,911,400	8,252,999	10,544,550	8,233,100

<sup>2</sup> 3

Table 5: Material Investments - General Plant

4

# 5 Regional Planning

As indicated in Exhibit G, Tab 2, Section 5.1.4, PowerStream has participated in Regional
Planning, and as a result of this, PowerStream has capital expenditures related to Vaughan
Transformer Station #4, and the integration of the feeders from this station to the distribution
system. The total proposed capital expenditure for the station and related system integration is

10 \$42,046,617 between 2015 and 2020.

11

# 12 Customer Engagement Activities

13 As described fully in Exhibit G, Tab 2, Section 5.4.2, PowerStream performed a comprehensive

14 customer engagement process, and have reviewed those results against the proposed plan.

15

# 16 Five Year System Development

- 17 PowerStream's distribution system will continue to expand to accommodate:
- 18 new transformer and municipal station construction;
- the integration of feeders from the stations to the distribution system;
- enhancement of pole lines to accommodate growth areas; and

• smart grid.

- 2
- 3

These projects are noted within the categories of system access and system service.

4

# 5 Special Activities

- 6 PowerStream has a number of initiatives that are related to customer preferences, technology
- 7 or innovation. These are shown on Table 6. All these initiatives belong to the Smart Grid
- 8 category, and were initially submitted in PowerStream's GEA Plan, Exhibit B2, Tab 1, Schedule
- 9 2 in EB-2012-0161.
- 10

Innovation Projects	2015	2016	2017	2018	2019	2020
Smart Grid	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
System Service						
Operations Technologies Rate Based	-	535,000	535,000	535,000	535,000	535,000
Storage Technologies Rate Based	-	535,000	535,000	535,000	535,000	535,000
General Plant						
Data Analytics	-	267,500	267,500	267,500	267,500	267,500
Electrical Vehicle Technologies	-	535,000	535,000	535,000	535,000	535,000
Home Technologies	-	535,000	535,000	535,000	535,000	535,000
Total	-	2,407,500	2,407,500	2,407,500	2,407,500	2,407,500

11 12

13 Note: In accordance with OEB Filing Requirements, Smart Grid expenditures for Year 2015 are recorded in deferral account 1534,

15

16 A description of each of these categories is detailed below.

17

# 18 Alternative Energy Sources

19 Alternative Energy Sources is a new focus area that will investigate new distributed energy

20 sources and their integration with the distribution system. Examples include distributed storage

21 systems and microgrids. Integrating distributing energy assets into grid control systems has the

22 potential to address real-time power management issues and improve both grid and distributed

23 asset utilization.

24

As renewable energy sources continue to be developed throughout PowerStream's service territory and as electric vehicles continue to be introduced to the Southern Ontario marketplace,

<sup>14</sup> and are not shown as part of this Capital Expenditure Plan.

there is an increased need to better understand the electricity storage options available to local distribution companies. There have been significant technical advances in electricity energy storage systems such as inertial flywheels, pneumatic storage, hydraulic storage and advanced battery systems.

5

6 PowerStream considers energy storage to be an integral component of its Smart Grid strategy.
7 In that regard, it plans to investigate specific applications of various storage technologies and,
8 where practical and justifiable from an operational and financial viewpoint, recommend larger
9 scale deployment of the technology to the distribution grid as part of PowerStream rate based
10 capital expenditure program.

11

PowerStream has installed an operating microgrid at its Cityview Head Office and is using the technical and economical learnings from this project in microgrid discussions and planning.

14

## 15 Data Analytics

The Smart Meter/AMI system collects an enormous amount of data on customer energy usage, power quality and system performance. To be useful, this data must be made accessible to several key departments within PowerStream, namely System Planning, Engineering Design and Operations Control.

20

21 Over the five year plan period, PowerStream, with the assistance of contract personnel, will 22 develop user friendly Geographic User Interface (GUI) type database queries to provide easy 23 access to those personnel requiring this data. This real information on customer loading and 24 operational performance (outages, voltage levels, power quality, system & equipment loading, 25 efficiency and losses) will enhance existing tools used by technical staff and provide more 26 comprehensive and accurate information for planning, design and operational purposes. 27 PowerStream has developed a transformer loading tool that leverages smart meter data and is 28 replacing the existing CIS based transformer loading tool. Future Analytics work will leverage 29 this tool database (which integrates all PowerStream meter databases into one database) and 30 system and expand into new analysis opportunities.

### 1 <u>Electric Vehicles (EV)</u>

2 PowerStream has engaged in projects to better understand the impact of EV technology on its 3 distribution system. PowerStream is now working to identify and develop the potential benefits 4 EVs can provide. PowerStream recently deployed a vehicle-to-grid charging system that is 5 connected to its head office microgrid. Any learnings will be used to identify how this opportunity 6 can potentially provide storage services on the distribution system. Other EV investigations 7 include smart charger control, EV for load shifting purposes and re-purposing of spent EV 8 battery equipment. PowerStream engages closely with provincial and national EV industry 9 groups to identify and bring relevant learnings to our distribution system operations and 10 customers.

11

#### 12 Smart Home

Recently, the provincial government, the Ontario Energy Board and the IESO Smart Grid Forum
have placed an increased emphasis on Home Energy Management (HEM) applications and
have suggested that LDC's participate in some manner.

16

PowerStream has implemented two-way communication and control on its AMI network. This is being leveraged in the Home Area Network (HAN) residential project to provide real-time consumption data to customers over Zigbee meters as well as *verifiable* load control events. PowerStream is the LDC partner on Energate's Residential Dynamic Pricing project and Rogers Smart Home project, both of which are underway and are funded by the Ministry of Energy's Smart Grid Fund. PowerStream is leveraging the solutions and learnings of these projects to increase the energy savings and services provided to customers.

24

Information and trial results obtained from these initiatives are open to the industry stakeholdersand are shared at regular Smart Grid information exchange meetings.

# 1 5.4.2 CAPITAL EXPENDITURE PLANNING PROCESS OVERVIEW

- The information a distributor should provide includes, but need not be restricted to:
  a) a description of the distributor's capital expenditure planning objectives, planning criteria and
  assumptions used, explaining relationships with asset management objectives, and including
  where applicable its outlook and objectives for accommodating the connection of renewable
  generation facilities:
- b) if not otherwise specified in (a), the distributor's policy on and procedure whereby non-distribution
  system alternatives to relieving system capacity or operational constraints are considered,
  including the role of Regional Planning Processes in identifying and assessing alternatives;
- c) a description of the process(es), tools and methods (including where relevant linkages to the
  distributor's asset management process) used to identify, select, prioritise and pace the execution
- of projects in each investment category (e.g. analysis of impact of planned capital expenditures
  on customer bills);
- d) if not otherwise included in c) above, details of the mechanisms used by the distributor to engage
  customers for the purpose of identifying their needs, priorities and preferences (e.g. surveys,
  system data analytics, and analyses by rate class of customer feedback, inquiries, and
  complaints); the stages of the planning process at which this information is used; and the aspects
  of the DS Plan that have been particularly affected by consideration of this information; and
- e) if different from that described above, the method and criteria used to prioritise REG investments
   in accordance with the planned development of the system, including the impact if any of the
   distributor's plans to connect distributor-owned renewable generation project(s).
- 22
- 23 Capital Expenditure Planning Objectives
- 24 The capital expenditure planning objectives are detailed in Exhibit G, Tab 2, Section 5.3.3.
- 25

# 26 Identification, Selection and Prioritization of Projects

The identification, selection and prioritization of projects is detailed in Exhibit G, Tab 2, Section5.3.3.

29

# 30 Customer Engagement - General

- 31 PowerStream provides electricity and energy related services to more than 370,000 customers
- 32 throughout a large and diverse service territory, and has undertaken customer consultation

frequently with customers through a number of communication methods, including:
Customer transaction telephone survey;

activities as part of specific outreach on this DS Plan. PowerStream routinely communicates

- 5 Key Accounts outreach and management;
- 6 Customer Satisfaction Survey;
- Customer Experience Plan;
- 8 Communications and Social Media;
- Enhanced Communication Activities December 2013 Ice Storm Review; and
- Conservation and Demand Management outreach and activities.
- 11

1

### 12 Ongoing Customer Engagement

- PowerStream interacts with its residential and commercial customers regularly through itsnormal business practices.
- 15

PowerStream's customers range from small residential customers to large commercial and
industrial enterprises. PowerStream's service territory is home to some of the largest internet
and banking data centres, as well as major manufacturers and commercial service providers.

19

Focusing on customers and striving to be efficient while providing optimum service, in a safe and reliable way is at the forefront of PowerStream's operating philosophy. PowerStream's interactions with customers occur most frequently within the Customer Service Department, as well as through the Conservation and Demand Management (CDM) and Corporate Communications groups.

25

In addition to the ongoing communication efforts, PowerStream engages with its customers when capital work is to be performed in their area in order to address and alleviate any potential stakeholder concerns. Town halls, presentations and focus groups are used to communicate with specific customer groups ahead of any major projects being conducted in their area to ensure transparency and to encourage the customer base to become more educated about any ongoing projects that may impact them.

### 1 <u>Customer Transaction Telephone Survey</u>

The OEB has established service quality measures and standards that all distributors must meet. It is PowerStream's view that the OEB-regulated customer service requirements are a minimum requirement. PowerStream seeks to provide customers with the best experience possible when interacting with all LDC staff. Practices and procedures are reviewed based on changing customer needs and preferences. Focus groups are used to review practices and gather customer input in order to make revisions to the services provided.

8

9 In January 2014, a customer feedback process was implemented whereby customers are called 10 back seven days after they contact PowerStream's Call Centre. Approximately 800 residential 11 customers are contacted through this process on a weekly basis. Early results show that 79% 12 of customers are very or somewhat satisfied with their interaction with PowerStream. 13 PowerStream has moved from a reactive position to being proactive with customer needs by 14 learning from past situations and feedback surveys in order to mitigate the occurrence of similar 15 issues and deliver an exceptional customer experience.

16

#### 17 Key Accounts

PowerStream's large commercial and industrial users are provided with a specialized service designed to accommodate their unique needs. The Key Accounts team meet regularly with these large users to provide an update on PowerStream's activities and to address any concerns they may have. This feedback is shared internally and has led to targeted reliability investments in areas that were experiencing higher levels of service disruptions. This program also allows these customers to learn about CDM initiatives that may work to their advantage in managing their energy consumption.

25

### 26 <u>Customer Satisfaction Survey</u>

Since 2007, PowerStream has engaged a consultant group to conduct a customer satisfaction
study in order to gather third-party feedback from customers with the objective of using this
information to develop process improvements, implement new service offerings, and to better
understand the needs and preferences of customers.

1 Focus groups are held annually for residential customers and in-depth interviews are conducted 2 with key commercial account holders within the service territory. This research is conducted to 3 supplement quantitative data from the UtilityPulse Study, Rehab Study, Customer Transaction 4 Survey and an Online Customer Study. 5 6 In 2013, PowerStream's overall customer satisfaction score was 91 per cent, slightly above the 7 average, and for PowerStream, higher than any of the previous four years. Each year, the 8 results of the Customer Satisfaction Survey are used to develop and execute improvements. 9 For 2014, based on the 2013 survey results, the top action areas were: 10 11 Better communicate the extent to which PowerStream works with and assists local 12 communities: 13 • work to ensure that customer newsletters are concise and address topics important to 14 customers such as ways to keep electricity costs down through energy conservation; 15 focused assistance for key account customers, such as online energy usage tracking; 16 and 17 reinforce with customers that PowerStream is community owned. 18 19 Customer Experience Plan 20 As part of its commitment to continuous improvement, PowerStream drafted a Customer 21 Experience Plan in 2012 as a corporate initiative that touches all areas of the utility. Existing 22 PowerStream work was leveraged for the plan, including PowerStream's corporate strategy, 23 present customer satisfaction studies and customer segmentation work. The project involved 24 extensive employee and stakeholder engagement, including: 25 26 Interviews with executives, directors and managers; 27 Interviews with senior Ontario Energy Board staff and an intervener; 28 Completion of a survey by over 260 PowerStream staff; 29 • A Customer Experience Attribute Workshop; 30 • Focus Groups with front line staff; and 31 Regular Steering Committee and Project Team meetings.

Prioritizing the customer experience, engaging with customers and ensuring accountability are some of PowerStream's priorities coming out of the Customer Experience Plan. Near term priorities focus on driving cultural change, while longer term priorities focus on developing the tools and insights to effectively deliver and ensure that customer experience is a corporate priority.

6

# 7 Communications and Social Media

8 PowerStream is committed to providing customer-focused communications and to reaching out 9 to customers in the ways in which they want to be communicated with and where and when they 10 want the conversations to take place. Social media helps PowerStream to better understand, 11 respond to and attract the attention of specific audiences. It enables interactive communication 12 - the exchange of information, perspective and opinion - among multiple audiences, effectively, 13 efficiently, and in places where those conversations are taking place. The use of social media 14 also enhances the ability to engage PowerStream's customers and offers greater accessibility to 15 them including being able to reach out to them on specific issues.

16

# 17 Enhanced Communication Activities – December 2013 Ice Storm Review

18 In the aftermath of the December 2013 Ice Storm, PowerStream initiated a review conducted by 19 a third-party consultant in order to revise the utility's ability to respond to major events. The task 20 force made 35 key recommendations in a number of categories including external 21 communications and customer care, emergency restoration, capital asset management, system 22 hardening, and technical considerations. In response to the findings of this review, 23 PowerStream took actions to implement these recommendations. The utility is committed to 24 maintaining a customer focus as a core part of its operating philosophy and is making 25 improvements to its customer communications strategy as a result of the report's 26 recommendations:

- Implemented a "live agent" option in the Outage Interactive Voice Response (Outage
   IVR) system previously, customers could only leave a message, but now can speak to
   a Customer Service Representative (CSR) 365/24/7;
- CSRs are provided with better tools to assist customers with outages;

- Implemented a "One Number" solution where all published PowerStream phone
   numbers will be routed to the same location. Customers have the choice to either report
   an outage or speak to Customer Service to deal about typical issues (bill questions,
   etc.). The system also has the capability for broadcast type messages to let customers
   know about significant outages and updates in a given area;
- Developed a Crisis Communications Plan;
- Implemented a Customer callback option for customers who wish to receive a call after
   their power has been restored;
- 9 Created an Outage E-mail Notification Service;
- Developed an information package for Councils and municipal staff on utility operations
   and Emergency Preparedness; and
- Began Implementing an out-of-province Call Centre to be deployed in the event of very
   widespread outages.
- 14

# 15 Conservation and Demand Management

16 The Conservation and Demand Management team interacts with residential and business 17 customers. In addition to customer interviews and focus groups undertaken for specific 18 objectives, they participate in over 15 community events per year and hold events in retail 19 stores, reaching over 3,000 customers during events. PowerStream also engages customers 20 through the promotion of CDM programs by distributing handouts, placing print advertisements 21 in local newspapers, adding bill inserts, sending out direct mail pieces, GO Train Posters and 22 online advertisements.

23

The CDM group conducts ongoing market research studies to determine motivations, barriers and satisfaction levels of our customers related to conservation program participation. They also collect information related to preferred methods of communication. Through outreach surveys, PowerStream discovered that a high proportion of customers indicated that their communication preference is email. The CDM team therefore implemented an email marketing communication system to deliver conservation program messages as a result of the learnings obtained through the survey.

1	The CDM team has also undertaken a Residential Customer Segmentation Study in order to
2	classify PowerStream's residential customer base into distinct segments to further develop an
3	understanding of its customers and their needs. Over the course of this study, over 3,500
4	customer interviews were conducted. The segmentation work will assist in the utility's efforts to
5	tailor programs and services to the wants and needs of customers and will improve the
6	organization's understanding of customer perspectives on a number of topics, including:
7	Consumption habits & understanding of the impact of their electricity consumption on
8	the environment;
9	<ul> <li>PowerStream as a local hydro company &amp; level of trust;</li> </ul>
10	Customer Service Metrics; and
11	General attitudes and behaviours including feelings towards conservation, social
12	pressures, and motivations and barriers towards participation.
13	
14	Customer Engagement - DS Plan
15	PowerStream developed a customer engagement process with its residential and commercial
16	customers designed specifically to obtain feedback on this DS Plan.
17	
18	In the spring of 2014, PowerStream engaged Innovative Research Group Inc. ("Innovative"), a
19	national research and strategy firm to assist in determining how to incorporate customer needs
20	and preferences into the DS Plan.
21	
22	Throughout the summer and fall of 2014, PowerStream conducted a series of customer
23	engagement activities in preparation for completion of the DS Plan.
24	
25	The activities were focused specifically on the DS Plan and were designed to determine
26	customer preferences related to PowerStream's proposed capital plans. The DS Plan specific
27	engagement plan responded to OEB expectations articulated in the RRFE report that distributor
28	plans should take customer preferences into account.
29	
30	The DS Plan specific engagement activities are described below, as is PowerStream's response
31	to incorporating customer preferences into the DS Plan, per the Chapter 5 filing requirement.

1	<u>Engag</u>	ement Methods
2	There	were four engagement methods.
3		
4	i)	Online DSP Primer
5		The primer developed for this consultation process was available online to all
6		PowerStream customers from November 17, 2014 to December 22, 2014.
7		
8	ii)	Residential and GS>50 Focus Groups
9		These consultation sessions were led by Innovative and were structured around the
10		themes of the primer. Primer booklets were distributed and participants were asked to
11		read and complete the feedback questions. A subsequent discussion of each section
12		was facilitated by the moderator.
13		
14		Barrie – November 17, 2014
15		Markham – November 18, 2014
16		Vaughan – November 19, 2014
17		
18	iii)	<u>GS&lt; 50 – Workshops</u>
19		These sessions were structured around the content of the primer and the DS Plan.
20		PowerStream made a detailed presentation with customers having the opportunity to
21		pose questions to staff. Innovative then facilitated breakout groups where participants
22		were guided through the primer sections and then asked to fill in their answers to the
23		questions independently. A subsequent discussion of each section was facilitated by the
24		moderators.
25		
26		• Barrie – December 9, 2014
27		Richmond Hill – December 10, 2014
28		
29	iv)	Key Accounts – Presentation and Feedback
30		These sessions were structured around the content of the primer and the DS Plan.
31		PowerStream made a detailed presentation with customers having the opportunity to

pose questions to staff. Innovative then facilitated a feedback session where
 participants were guided through the primer sections and then asked to fill in their
 answers to the questions independently. A subsequent discussion of each section was
 facilitated by the moderator.

- 5
- 6

• December 10, 2014

7

8 PowerStream developed a primer to be used as the predominant consultation tool for the variety 9 of engagement methods used in this process. The goal of the primer was to translate 10 PowerStream's proposed plans for the distribution system into a plain language document that 11 customers could relate to. The primer discussed the challenges the distribution system faces 12 and how the utility intends to address them. Feedback was collected through relevant questions 13 posed after each section of the primer with the intent of educating customers about the 14 electricity distribution system and gathering their input on specific plans and projects proposed 15 in the DS Plan.

16

Participants were generally satisfied with the service being provided by PowerStream, with 91 per cent reporting that they were either very satisfied (46 per cent) or somewhat satisfied (45 per cent), though many indicated that they were only somewhat familiar with the electricity system and PowerStream's services.

21

# 22 Rate Impacts

Proposed estimated bill impacts were presented for each rate class and major capital projects
discussed to provide a background for PowerStream's proposed activities for 2016-2020.

25

Generally, customers accepted the proposed rate increases, but there was a concern from some business customers that PowerStream had not demonstrated that they had looked for internal efficiencies prior to going to customers for the increase. There was some discussion during focus groups of PowerStream paying for increased capital budget requirements through the company's profits.

1 The majority of customers surveyed online and in focus groups indicated that they were 2 supportive of the increase. These customers believe that the rate increase is reasonable and 3 that they support it, or that they don't like it but think that the rate increase is necessary:

4

Of 1,553 online survey respondents, 67 per cent were supportive of the increase, or which 19
per cent thought it was reasonable, and 48 per cent didn't like it but thought it was necessary.
26 per cent were opposed to the rate increase and thought it was unreasonable. Similar results
were seen in focus groups, however both key accounts and GS > 50 customers were slightly
less supportive, with greater numbers indicating that they opposed the increase.

10

## 11 PowerStream Focus

## 12 System Reliability and Restoration Time

PowerStream was pleased to discover that most customers are satisfied with the levels of reliability they currently receive. This is consistent with the capital expenditure plan which is designed to maintain current reliability levels (no degradation). Modest improvements due to the remediation of worst performing assets are expected (refer to Exhibit G, Tab 2, Section 5.3.3 p.34). An example of remediation projects that will have a positive effect on system reliability is cable remediation, described in Exhibit G, Tab 2, Section 5.2.3.

19

Approximately seven in ten customers identified that they have experienced at least one outage during unusual weather and six-in-ten reported having experienced an outage excluding during times of extreme weather situations. However, when asked to describe the length of their outages, most reported having had their power restored within one hour and 29 per cent had their power restored within 15 minutes. No serious concerns regarding current restoration times were identified by the majority of customers.

26

27 Despite these results, some commercial customers expressed concerns about small, 28 momentary outages that can negatively affect sensitive machinery. A small number of key 29 accounts customers pointed to poor reliability as a serious concern for their businesses. 30 PowerStream addresses concerns these through the worst performing feeder assessments and 31 ongoing reliability committee discussions on problematic areas.

#### 1 Aging Infrastructure

When presented with PowerStream's plans for addressing the concern of aging equipment, it was found that customers generally accepted PowerStream's current practices for replacing distribution assets. More than half of the participants in the online survey indicated that their preference is to continue investing to reduce power outages as opposed to scaling back infrastructure investment to reduce the impact on electricity rates.

7

#### 8 Investment in New Technologies

9 Customers were able to see some benefits of investing in new technologies as they indicated a
10 desire for increased communication from the utility. At the same time, PowerStream received
11 some specific feedback regarding the implementation of the new CIS system. Some customers
12 were unable to see the added benefit of implementing a new system.

- GS < 50 customers in focus groups were most likely to question the need for the new</li>
   billing system. They reported consistently receiving bills and did not see how this
   investment would improve their reliability.
- The results of the online primer survey indicated that 48 per cent of respondents view
   investments in technology as important and should be a priority for PowerStream. Just
   over a third (34 per cent) indicated that investments in new technology are more of a
   luxury than a necessity and should therefore be a low priority for PowerStream.
- New technology was seen as a solution to improving communication for key accounts
   customers. This particular customer class had 62 per cent of respondents who believed
   that investments in new technology should be a priority for PowerStream.

There was a sense during the in-person focus group sessions that PowerStream had not made the business case for this major investment and that the perceived value of implementing this system was not shared across all customer classes. PowerStream has strengthened its business case for this expenditure. Refer to Appendix A, Material Investments, for detailed project information.

28

### 29 Storm Hardening

PowerStream customers had varying views on the need to prepare for extreme weather events.
Some see it as a necessary investment in order to ensure safety, however, because future

weather is seen as unpredictable, and past experiences during major events have been
 generally positive, this is seen as an area in which major investments are not necessary.

3

PowerStream's approach to storm hardening is consistent with customer preferences because a modest approach to investments is being taken in order to balance risks and cost. PowerStream commissioned a review of the utility's response the 2013 Ice Storm. The purpose of the review was to identify lessons learned and to develop action plans to enhance performance should another major incident occur. The report outlined 15 recommendations, of which four were chosen for capital projects, including a project to replace all rear lot supplies on an annual basis until all are remediated.

11

12 Customers expressed concern related to the improvement of communication during outages. 13 Many participants in residential focus groups and the online survey indicated that better 14 communication from the utility was the main way that PowerStream could improve its service to 15 customers during extreme weather events. This was also identified as an area for improvement 16 coming out of the review conducted in 2014. As a result, PowerStream has made a number of 17 improvements to increase the volume and accuracy of communications to customers during 18 outages. Two of these process improvements are described below:

19

PowerStream has implemented an Outage Notification Service which allows customers
 to register to receive emails when an outage occurs at their location. These notifications
 include status updates if there are changes to the incident as well as a final notification
 once power has been restored; and

II. A social media strategy has been developed in order to leverage best practices from
 emerging communication technology to enable PowerStream to effectively address the
 volume of messages and to provide the best information to customers.

PowerStream derived significant benefits from the enhanced level of customer engagement
conducted during the preparation of the DS Plan. The utility values input from customers and
was extremely pleased to confirm the level of general support customers have for the utility's
plans and approach to investment.

- 1 Refer to Appendix C to Appendix F for the materials used and the reports provided by
- 2 Innovative.
- 3
- 4

## 1 5.4.3 SYSTEM CAPABILITY ASSESSMENT FOR RENEWABLE ENERGY GENERATION

2

This section provides information on the capability of a distributor's distribution system to accommodate REG, including a summary of the distributor's load and renewable energy generation connection forecast by feeder/substation (where applicable); and information identifying specific network locations where constraints are expected to emerge due to forecast changes in load and/or connected renewable generation capacity.

8

9	In relation to renewable or other distributed energy generation connections, the information that must be
10	considered by a distributor and documented in an application (where applicable) includes:

- 11 a) applications from renewable generators over 10kW for connection in the distributor's service area;
- b) the number and the capacity (in MW) of renewable generation connections anticipated over the
  forecast period based on existing connection applications, information available from the IESO and
  any other information the distributor has about the potential for renewable generation in its service
  area (where a distributor has a large service area, or two or more non-contiguous regions included
  in its service area, a regional breakdown should be provided);
- c) the capacity (MW) of the distributor's distribution system to connect renewable energy generation
   located within the distributor's service area;
- d) constraints related to the connection of renewable generation, either within the distributor's system
   or upstream system (host distributor and/or transmitter); and
- e) constraints for an embedded distributor that may result from the connections
- 22
- 23

### 24 Applications from Renewable Generators over 10kW

As of August 1<sup>st</sup> 2014, PowerStream has connected eighty four Feed-In Tariff (FIT) applications for a total of 16,016 kW of generation (item F3 from Table 1). In addition, there are 203 projects, totaling 36,448 kW (item F4 from Table 1), that have been approved by PowerStream for connection and are currently being constructed. PowerStream's FIT breakdown is seen in Table 1.

Item	Process Description	Project Count	Capacity (kW)				
F1	Total FIT applications received by IESO	314	56,326				
F2	Total FIT applications approved by IESO	204	36,583				
F3	Total FIT applications approved by PowerStream	203	36,448				
F4	Total FIT projects connected by PowerStream	84	16,016				
L	Table 1: FIT Projects						

# 2

3

The 203 connected, or about to be connected FIT generators, are dispersed throughout PowerStream's territory. Projects are located predominately in Markham, Richmond Hill, Barrie and Vaughan however, there are also scattered projects located in the smaller communities of Aurora, Alliston, and Bradford. Table 2 details the FIT Generators by geographic region (as of Aug.1 2014):

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.3 System Capability Assessment for Renewable Energy Generation Page 3 of 14 Delivered: February 24, 2015


		FIT		
		Projects	Generation (kW)	
	Allliston	2	135	
	Barrie	23	2,892	
	Beeton			
Northern Region	Bradford	4	590	
	Penetang	2	325	
	Thornton			
	Tottenham	2	350	
	Northern Sub Total	33	4,292	

	Aurora	6	831.8
Southern Region	Markham	59	9,353
Obulient Region	Richmond Hill	17	3,743
	Vaughan	88	18,229
	Southern Sub Total	170	32,156

Southern Sub Total

	Total Projects	203	36,448
2	·		
3	Table 2: FIT Generators by G	eographi	<u>c Region</u>
4			
5	Number and Capacity (MW) of Renewable Connect	tions Ant	icipated
6	Planned Development		
7	PowerStream has projected Renewable Generation gr	rowth for	2015-2020 based on existing F
8	data and industry expectations.		
9			
10	Renewable Generation growth for 2015-2020 has b	een esti	mated based on PowerStream
11	existing FIT/MicroFIT data from 2009-2014 and the	e expect	ed evolution of the IESO's F
12	program.		

- 1 As of August 1st 2014, PowerStream customer FIT and microFIT submissions to the IESO have
- 2 totaled 3,031 applications, grossing over 76MW of potential generation. The 2012-2014
- 3 application data, illustrated in Figure 1, indicates a strong average monthly growth rate to date.



- 10 source is broken down as shown in Table 3:
- 11

Fuel Type	FIT	MicroFIT	
Solar photovoltaic - Roof Top	314	2,717	
Table 3: Fit/MicroFIT Volumes			

- 1 The project size distribution is seen in Figure 2, which illustrates limited interest in projects over
- 2 250kW and no interest in projects greater than 500kW.




Figure 2: Project Size Distribution

3

# 4 5

6 PowerStream's regions are predominantly made up of urban areas which are ideal for roof top 7 solar, but less attractive for larger ground mount solar or wind installations. Therefore, because 8 there is limited potential for major wind or other ground mount projects, and economically viable 9 roof tops are finite, installations are expected to slow down over the next six years. This 10 assumes that FIT program pricing continues to provide less than ten year payback for 11 commercial rooftop installations.

12

# 13 Program Progression

14 In order to create a six year projection of FIT growth in PowerStream's distribution area, some 15 assumptions were made regarding the program's future direction.

16

17 The IESO's FIT Program has been relatively unchanged since its inception in 2009. Following


- 18 three years of Renewable Generation experience, valuable insight has been gained into the
- 19 public demand for green energy and potential capacity constraints caused by the distribution

1	grid. Based on these lessons learned, IESO made adjustments to the FIT program in 2012,				
2	considering some of the following potential changes:				
3	Price Point Drop to reflect the current market per unit costs of retail generation				
4	equipment;				
5	New Funding Model to make smaller FIT projects more financially feasible; and				
6	Generation Caps to slow the FIT program down to manageable levels but still				
7	maintain the current job creation model.				
8					
9	The above items were taken into consideration when developing PowerStream's six year				
10	Anticipated Generator Connections model.				
11					
12	Anticipated Generator Connection Applications				
13	Based on PowerStream's 2009-2014 FIT/microFIT data and future assumptions regarding the				
14	4 IESO's FIT program, it is expected that application submissions will remain steady through				
15	2015, begin to decline in 2016, and continue to descend through 2018. Table 4 outlines the				
16	expected decline:				
47					


	Applications/year	Cumulative Applications
2010	666	666
2011	1038	1704
2012	36	1740
2013	1005	2745
2014	286	3031
2015	215	3245
2016	161	3467
2017	121	3527
2018	60	3587
2019	0	3587
2020	0	3587

Table 4: Actual and Projected Application Volumes

- 1 The IESO currently has Renewable Generation applications totaling 76MW for PowerStream's
- 2 service territory. Based on PowerStream's anticipated FIT connection model, projected growth
- 3 for Renewable Generation in PowerStream's territory will pursue the trend depicted in Figure 3.
- 4



Following steady growth through 2014, the Renewable Generation growth rate is expected to peak and begin to decline in 2016 through 2018. PowerStream's Renewable Generation load is expected to reach 107.7MW by 2020. Refer to Figure 4.




#### **Projected Renewable Generation Cumulative Growth**

3 4

1 2

5 PowerStream North Renewable Generation Growth


6 The IESO currently has Renewable Generation applications totaling 11.044MW for
7 PowerStream North. Based on projected growth PowerStream expects this number to reach
8 16.11 MW by 2018. Figure 5 illustrates Renewable Generation growth in the North between
9 2009 and 2020.



- 7 2018. Figure 6 illustrates Renewable Generation growth in the South between 2010 and 2020.
- 8

3 4

5



#### South Renewable Generation Cumulative Growth

## Figure 6: Growth in PowerStream South

3

1

2

## 4

# 5 **PowerStream Capacity (MW) for Connection per Station**

6 North Distribution System Assessment

PowerStream North consists of the municipalities of Alliston, Barrie, Beeton, Bradford West
Gwillimbury, Penetanguishene, Thornton, and Tottenham. The North area contains thirty-nine
Municipal Stations and six Hydro One owned Transformer Stations ("TS"). Due to the size of
FIT projects, most are connected directly to Hydro One TS's.

11

# 12 <u>Station Capacity:</u>

- 13 PowerStream North currently has 33 FIT projects that are connected or about to be connected
- 14 to five of Hydro One's TS's, resulting in the allocation and capacity shown in Table 5:
- 15

Connected Transformer Station Hydro One Owned	TS Thermal Capacity (kW) (Max Rating)	Hydro One Allocated Capacity (kW)	PowerStream Allocated Capacity (kW)	Estimated Remaining TS Capacity (kW)
EVERETT TS	63,800	2,000	716	1,284
HOLLAND TS	96,600	2,000	736	1,264
MIDHURST TS				
DESN1	119,400	3,500	2,237	1,263
MIDHURST TS				
DESN2	71,500	5,000	1,918	3,082
BARRIE TS	68,500	5,000	1,957	3,043

Table 5: North TS Allocation

Maximum North Capacity (kW)

9,936 \*

2

3

4

1

\*Note: PowerStream North's Potential Capacity incorporates upstream Hydro One TS Allocated Capacity.

5 6

7 Hydro One TS Thermal Capacity is much higher and is shared with Hydro One on a first come,

first serve basis. Therefore, remaining TS capacity can be increased when required by 8 9 PowerStream.

10

11 Limiting Factors:

12 Customer accessibility to Hydro One Transformer Stations in and around the Barrie area 13 provides a significant attraction for FIT projects.

14

15 There are potential access constraints for larger projects connecting in the North. Typically,

16 PowerStream will require projects greater than 1MW to connect directly to 44kV lines which are

17 only available in specific locations throughout the Northern region.

### 1 South Distribution System Assessment

2 PowerStream South consists of the municipalities of Aurora, Markham, Richmond Hill, and

3 Vaughan. The South area contains eleven PowerStream owned Transformer Stations and six

4 Hydro One Transformer Stations.

5

## 6 <u>Station Capacity:</u>

7 PowerStream South currently has 170 FIT projects that have been connected or about to be

8 connected, resulting in the allocation and capacity shown in Table 6 and Table 7.

- 9
- 10

Connected Transformer Station PowerStream Owned	TS Capacity (kW) (Max Rating)	Current Load from FIT projects (kW)	Remaining TS Capacity (kW)
	42.000	F 444	0.400
VAUGHAN MTS #1	13,600	5,414	8,186
VAUGHAN MTS #1 E	97,500	2,964	94,535
VAUGHAN MTS #2	10,200	5,056	5,143
VAUGHAN MTS #3	125,500	8,816	116,683
RHMTS#1	12,000	2,461	9,538
RHMTS#2	48,000	1,730	46,269
MARKHAM MTS #1	56,000	1,930	54,069
MARKHAM MTS #2	56,000	2,093	53,906
MARKHAM MTS #3	102,400	788	101,611
MARKHAM MTS #3 E	89,600	9,955	79,645
MARKHAM MTS #4	97,500	771	96,729

Max PowerStream South Capacity (kW)

666,314 Max

11 12

Table 6: South TS Allocation, PowerStream Owned TS

\*Note: PowerStream South's Potential Capacity incorporates upstream Hydro One TS Capacity.

14 15

- 16
- . \_
- 17
- 18

Connected Transformer Station Hydro One Owned	TS Thermal Capacity (kW) · (Max Rating)	Hydro One Allocated Capacity (kW)	PowerStream Allocated Capacity (kW)	Remaining TS Capacity (kW)
AGINCOURT TS	59,600	1,000	200	800
ARMITAGE TS DESN 1	119,600	2,000	504	1,496
ARMITAGE TS DESN 2	120,400	2,000	1,446	554
BUTTONVILLE TS TS Z Bus	34,000	5,000	1,166	3,834
BUTTONVILLE TS TS Q Bus	38,800	5,000	2,416	2,584
FINCH TS DESN 1	40,700	2,000	500	1,500
LESLIE TS DESN 1	18,400	2,000	71.4	1,929
WOODBRIDGE TS DESN1	23,600	3,000	558	2,442

Maximum Hydro One South Capacity (kW) 15,139 Max\*

2 3

#### 3

#### Table 7: South TS Allocation, Hydro One Owned TS

\*Note: PowerStream South's Potential Capacity incorporates upstream Hydro One TS Capacity.

4 5

Hydro One's TS Thermal Capacity is much higher and is shared with Hydro One on a first
come, first serve basis, and as such, the remaining TS capacity can be increased when required
by PowerStream.

9

# 10 System Constraints

PowerStream has mitigated system constraints in terms of short circuit limits at Markham TS's by installing fault level reduction reactors to increase the station short circuit capacity. In addition, PowerStream completed the WiMax Communication Network for the purpose of Data Transfer and Generator Tripping.

15

16 In 2014, 2015 and 2016, PowerStream will complete Station Wiring Modifications for WiMax.

17 These projects will accommodate connection of future FIT projects to stations and be able to

18 facilitate remote shutdown and transfer trip protection function.

19

20 Station capacity constraint exists with the following Hydro One stations:

- 1 1. Kleinburg TS
- 2 2. Leslie TS DESN 2
- 3 The following is a summary of Renewable Generation expenditures planned for 2014 to 2020.
- 4 1. 2014 Station Wiring Modifications for WiMax
- 5 2. 2015 Station Wiring Modifications for WiMax
- 6 3. 2016 Station Wiring Modifications for WiMax
- 7
- Based on a calculated remaining maximum capacity of 691MW and a projected load of only
  75.7MW by 2020, PowerStream feels confident that it has capacity in place to accept future
- 10 renewable generation projects.
- 11

In conclusion, PowerStream's proactive Renewable Generation planning since 2009 has
created a solid foundation for generator connections, and has developed a robust strategy to
accommodate generation in the next six years.

15

# 16 Customer Constraints

- 17 Commencing in 2009, and up to the present time, no customer constraints were experienced.
- 18
- 19 The potential constraints are as follows:
- Insufficient individual pad mount or pole mount transformer capacity; or
- Increased voltage at the customer end due to number of DG connections.
- 22
- 23

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 1 of 14 Delivered: February 24, 2015

#### 1 5.4.4. CAPITAL EXPENDITURE SUMMARY

The purpose of the information filed under this section is to provide the Board and stakeholders with a 'snapshot' of a distributor's capital expenditures over a 10 year period, including five historical years and five forecast years. Note that where a distributor's internal investment planning framework does not align with the investment categories defined here, best efforts are expected to 'map' investments to these categories.

7

8 Despite the 'multi-purpose' character of a project or activity, for 'summary' purposes the entire costs of 9 individual projects or activities are to be allocated to one of the four investment categories on the basis of 10 the primary (i.e. initial or 'trigger') driver of the investment. Note, however, that for material projects, a 11 distributor must estimate and allocate costs to the relevant investment categories when providing 12 information to justify the investment, as this assists in understanding the relationship between the costs 13 and benefits attributable to each driver underlying the investment. In any event, the categorization of an 14 individual project or activity for the purposes of these filing requirements should not in any way affect the

- 15 proper apportionment of project costs as per the DSC.
- 16

Table 2 illustrates how information filed under this section includes a distributor's actual and forecast (i.e.
proposed) capital expenditures over the historical and forecast periods. System operations and
maintenance (O&M) costs are also shown to reflect the potential impact, if any, of capital expenditures on
routine system O&M. Note that 'Plan' expenditures over the historical period refer to a distributor's
previous plan for capital expenditures after adjustments (if any) occasioned by the Board's decision on
the relevant prior application.

Brief explanatory notes should be provided to explain the factor(s) and/or circumstances underlying marked changes in the share of total investment represented by a given investment category over the forecast period relative to 'actual' spending over the historical period. For example, a large expenditure over a relatively short period for a 'one-off' project (e.g. a distribution station) can cause a temporary 'step change' in category C spending compared to the trend in actual expenditures over the historical period While year over year 'Plan vs. Actual' variances for individual investment categories are expected, explanatory notes should be provided where:

- for any given year "Total" 'Plan' vs. 'Actual' variances over the historical period are markedly
   positive or negative; or
- a trend for variances in a given investment category is markedly positive or negative over the
   historical period.

1	This section is designed to provide a summary of PowerStream's capital expenditures over a 10
2	year period. This includes five historical years and five forecast years. As this is PowerStream's
3	first Application with a DS Plan, pursuant to the Chapter 5 Requirements, there is no data
4	provided as to the 'Plan' values for the historical period. Only actual data is provided for the
5	purpose of this summary.
6	
7	Explanatory Notes on Variances in Capital Expenditure Summary
8	PowerStream has completed Appendix 2-AB in compliance with the Chapter 2 Filing
9	Requirements and Chapter 5 Requirements. PowerStream has provided a summary of
10	Appendix 2-AB by category below.
11	
12	Tables that provide a summary of the historical 2011-2014 and proposed 2015-2020 capital
13	expenditures are provided immediately below in Table 5.4.4.1, and at the end of this Section in
14	Table 5.4.4.2.
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 3 of 14 Delivered: February 24, 2015

		Histo	orical					Proposed		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
CATEGORY	Actual	Actual	Actual	Actual	Plan	Plan	Plan	Plan	Plan	Plan
Rate Base	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000	\$ '000
System Access	21,007	19,888	17,030	26,229	24,145	28,232	28,470	29,561	28,726	31,867
System Renewal	11,527	16,974	22,254	39,186	42,388	48,715	51,500	52,052	52,971	52,406
System Service	22,885	13,770	34,780	17,946	27,322	38,322	32,072	29,920	26,963	23,022
General Plant	7,877	24,200	19,593	26,148	24,545	17,531	19,458	13,867	16,741	18,106
Sub-Total	63,297	74,832	93,657	109,509	118,400	132,800	131,500	125,400	125,401	125,400
Non-Rate Base	2,278	1,196	2,628	1,364	2,489	-	-	-	-	-
Grand Total	65,575	76,028	96,285	110,873	120,889	132,800	131,500	125,400	125,401	125,400
System O&M	2,055	2,438	2,523	2,627	3,290	3,825	4,365	4,909	5,459	6,015

Table 5.4.4.1: Capital Expenditure Summary

#### 1 a) System Access

2 System Access investments are comprised of projects outside of PowerStream's control that 3 are required to meet customer service obligations in accordance with the Distribution System 4 Code ("DSC") and PowerStream's Conditions of Service. 5 6 These projects include: 7 New Connections for customers (subdivisions, industrial/commercial/institutional (ICI), 8 service layouts); 9 • Metering: 10 • Road Authority projects; and 11 Other customer initiated work. 12 13 PowerStream uses an economic evaluation methodology as prescribed by the DSC to 14 determine the amount, if any, of capital contributions for each project; with such capital 15 contribution amounts incorporated into the annual capital budget. These investments are 16 typically a high priority, cannot be deferred, and must proceed as planned. 17 Historical year over year variances between 2011, 2012, 2013 and 2014 are primarily due to 18 19 increased Road Authority projects for York Region, Simcoe County and the eleven 20 Municipalities. 22 The level of system access expenditures in each of 2011 to 2014 historical years was as 23 follows: 24 • 2011 actuals (IFRS) were \$21,007,331 (net), with capital contributions of \$29,560,811. 25 26 • 2012 actuals (IFRS) were \$19,887,614 (net), with capital contributions of \$30,943,103. 27 The decrease from 2011 of \$1,119,717 (net) was primarily due a decrease in Road 28 Authority projects. 29

- 21

1 2 3 4	•	2013 actuals were \$17,030,429 (net), with capital contributions of \$19,271,865. The decrease of \$2,857,185 (net) from 2012 was primarily due to a decrease in Road Authority projects and Subdivision projects.
5	•	2014 actuals were \$26,228,894 (net), with capital contributions of \$22,876,343. The
6		increase of \$9,198,465 from 2013 was mainly due to an increase in Road Authority
7		projects.
8		
9	The lev	vel of System Access expenditures from 2015 to 2020 is as follows:
10	٠	The forecast for 2015 is \$24,145,118 (net), with capital contributions of \$19,804,601.
11		The decrease from 2014 is \$2,083,776, primarily due to a decrease in Road Authority
12		projects, offset by increased expenditures in Metering (for installing interval meters for
13		GS customers over 50kW).
14		
15	•	The forecast for 2016 is \$28,232,154 (net), with capital contributions of \$21,499,743.
16		The increase from 2015 is \$4,087,036 is primarily due to an increase in Road Authority
17		Projects, and also an increase in New Connections.
18		
19	•	The forecast for 2017 is \$28,469,723 (net), with contributions of \$22,623,132. The
20		modest increase from 2016 is \$237,569, is primarily due to an increase in New
21		Connections, offset by a slight decrease in Road Authority projects.
22		
23	•	The forecast for 2018 is \$29,560,667 (net), with capital contributions of \$23,383,253.
24		The increase from 2017 of \$1,090,944 is primarily due to an increase in Metering and
25		New Connection projects.
26		
27	•	The forecast for 2019 is \$28,726,052 (net), with capital contributions of \$23,203,090.
28		The decrease compared to 2018 of \$834,615 is primarily due to a significant decrease
29		in Road Authority expenditures, offset by increased expenditures in both Metering and
30		New Connections.

1 The forecast for 2020 is \$31,866,709 (net), with capital contributions of \$24,573,604. 2 The increase compared to 2019 of \$3,140,657, is primarily due to increased Metering 3 project expenditures, and also smaller increases in Road Authority and New 4 Connections project expenditures. 5 6 Overall, System Access expenditures over 2016 to 2020 remains consistent within the range of 7 \$28M to \$32M, with variations year to year due to adjustments to the priorities of the relative mix 8 of initiatives being proposed each year. 9 10 b) System Renewal 11 PowerStream's System Renewal investments are for the purposes of the replacing or 12 refurbishing distribution assets (primarily overhead lines, underground lines, and stations 13 equipment) which extend the service life of assets. These assets are replaced either due to 14 aging and/or deteriorating condition. 15 16 Historic system renewal expenditures from 2011 to 2014 years were as follows: 17 2011 actuals (IFRS) were \$11,527,321 (net); • 18 2012 actuals (IFRS) were \$16,974,392 (net). The increase from 2011 of \$5,447,071 was 19 • 20 due to a higher level of investment in the overhead lines replacement projects and 21 programmes, and to a lesser degree, increases in the cable replacement and cable 22 injection projects and programs. 23 24 2013 actuals were \$22,253,782 (net). The increase from 2012 of \$5,279,390 was due to • 25 a significant increase in work and expenditures for cable replacement and cable injection 26 programs. There were also increase expenditures for distribution transformer 27 replacement projects. 28 29 2014 actuals were \$39,185,754 (net). The increase from 2013 of \$16,931,972 was due • 30 to a large increase in expenditures for cable replacement and cable injection projects 31 and programs.

1 The level of system renewal expenditure from 2015 to 2020 is as follows:

The forecast for 2015 is \$42,388,193 (net). The increase from 2014 of \$3,202,439 is primarily due increased investments in rear lot conversions and overhead line assets replacement projects.
The forecast for 2016 is \$48,714,625 (net). The increase from 2015 of \$6,326,432 is due to new investments in storm hardening initiatives.

- The forecast for 2017 is \$51,500,169 (net). The increase from 2016 of \$2,785,544 is
  due to increased investments in cable replacement and injection projects and programs,
  with modest increased investments in overhead line assets replacement projects.
- The forecast for 2018 is \$52,051,932 (net). The increase from 2017 \$551,763 is
   primarily due to increased investment in the cable replacement and injection projects
   and also increased investment in station equipment renewal projects.
- 16

12

- The forecast for 2019 is \$52,970,854 (net). The increase from 2018 of \$918,922 is
   primarily due to increased investments in cable replacement and injection projects and
   programs.
- 20
- The forecast for 2020 is \$52,405,780 (net). The modest decrease from 2019 of
   \$565,074is primarily due to further reductions in investments related to stations
   equipment renewal projects.

Overall, System Renewal expenditures over the 2016 to 2020 Test Years remains consistent within the range of \$48M to \$52M, with variations year to year due to adjustments to the priorities of the relative mix of assets being proposed to be replaced each year.

27

#### 28 c) System Service

Investments in this category are modifications to PowerStream's distribution system that ensure
 operational objectives are met and future customer requirements can be addressed. Projects

are driven by initiatives to improve system reliability and/or system capacity constraints. These
 are necessary as greater demands are placed on the system from increasing customer
 requirements, increased capacity for stations and lines, distribution automation, embedded
 generation (RGEN), and Smart Grid initiatives (distribution related) including energy storage.

5 These investments are required to support the operation, reliability and expansion of the 6 distribution system. PowerStream classifies these investments in sub-categories of capacity, 7 reliability, and security.

8

9 The level of System Service expenditure in each of the 2011 to 2014 historical years is as10 follows:

- 2011 actuals (IFRS) were \$22,885,200 (net);
- 12

2012 actuals (IFRS) were \$13,770,295 (net). The significant decrease from 2011 of
 \$9,114,905 is due to a large decrease in expenditures related to transformer and
 municipal substation projects, and also decreased expenditures in line extension
 projects.

17

2013 actuals were \$34,780,350 (net). The large increase from 2012 of \$21,010,055 was
 due to increased expenditures for cable replacement and cable injection projects and
 programmes, increase expenditures in additional capacity lines projects (new feeders),
 increased expenditures for overhead lines projects, and increased expenditures for
 distribution automation.

23

2014 actuals were \$17,946,354 (net). The large decrease from 2013 of \$16,833,996
 was primarily due to re-categorization of cable replacement and cable injection projects
 from the System Service category into the System Renewal category. However, the total
 PowerStream cable replacement and cable injection expenditures increased slightly in
 2014 compared to 2013.

29

30 The level of System Service expenditure from 2015 to 2020 is as follows:

- The forecast expenditure for 2015 is \$27,321,977 (rate base net). If capital spending recorded in the smart grid deferral account is included, the total is \$28,473,343 (net).
   The increase from 2014 of \$9,375,623 is a result of increased investments for capacity-driven lines projects, and also increased investments for capacity-driven stations projects. The major of the increased expenditures is a result of the new Vaughan VTS#4 (capacity-driven stations project).
- The forecast expenditure for 2016 is \$38,321,819 (net). The significant increase from
   2015 of \$10,999,842 is primarily due to increased expenditures in capacity-driven lines
   projects.
- 11

- The forecast expenditure for 2017 is \$32,071,882 (net). The decrease from 2016 of
   \$6,249,937 is due to a significant decrease in investments for capacity-driven stations
   projects partially offset by a increase in investments for capacity-driven lines projects.
- The forecast expenditure for 2018 is \$29,920,325 (net). The decrease from 2017 of
   \$2,151,557 is primarily due to significant decreases in investments for capacity-driven
   lines projects partially offset by an increase in capacity-driven stations projects.
- 19

15

- The forecast expenditure for 2019 is \$26,963,080 (net). The decrease from 2018 of
   \$2,957,245 is primarily due to a large decrease in investments for capacity-driven
   stations projects, partially offset by an increase in capacity-driven lines projects.
- 23

The forecast expenditure for 2020 is \$23,022,061 (net). The decrease from 2019 of
 \$3,941,019 is primarily due to decreased investments in capacity-driven lines projects
 and line extension projects, offset by increased investments in capacity-driven stations
 projects.

28

Overall, System Service expenditures generally decline over the 2016 to 2020 Test Years from a high of \$32M to a low of \$23M, with variations year to year due to adjustments to the priorities of the relative mix of initiatives being proposed each year.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 10 of 14 Delivered: February 24, 2015

#### 1 d) General Plant

Investments in this category are modifications, replacements or additions to PowerStream's assets where these assets are not part of the electrical distribution system. General Plant projects include investments in information systems, communication systems, vehicles, buildings/facilities and tools and equipment necessary to support the operation and maintenance of the distribution system. General Plant also includes specific Smart Grid pilot projects and initiatives that do not pertain to the distribution system, such as home technologies and electric vehicles.

9

10 The level of general plant expenditure in the historical period 2011 to 2014 was as follows:

11

2011 actuals (MIFRS) was \$7,876,939 (net);

12

2012 actuals (MIFRS) was \$24,199,799 (net). The increase of \$16,322,860 versus 2011
 actuals was primarily due to increased expenditures for the replacement CIS system,
 furniture and ancillary requirements to equip the new Jane Street operations centre, and
 land purchase next to PowerStream's head office at 161 Cityview Boulevard in Vaughan.

17

2013 actuals were \$19,592,930 (net). The decrease from 2012 of \$4,606,869 was
 primarily due to the large one-time expenditure incurred in 2012 for the land purchase in
 Vaughan not recurring in 2013, offset by a significant increase in expenditures for the 2<sup>nd</sup>
 year of the implementation of the new CIS system.

22

2014 actuals were \$26,148,062 (estimated net), an increase of \$6,555,132 from 2013.
 The multi-year initiatives to replace PowerStream's Customer Information System continued into 2014.

26

27 The level of general plant expenditure from 2015 to 2020 is provided below.

28

The forecast for 2015 is \$24,544,709 (rate base net). If capital spending recorded in the smart grid deferral account is included, the total is \$25,882,209 (net). The decrease from 2014 of \$1,603,353 is primarily due to a decrease in investments for the new CIS

1		system, offset by increased investments in buildings, and also increased investments for
2		IT information and communication systems.
3		
4	•	The forecast for 2016 is \$17,631,419 (net). The decrease from 2015 of \$6,913,290 is
5		primarily due to decreased investments in the new CIS system.
6		
7	•	The forecast for 2017 is \$19,557,978 (net). The increase from 2016 of \$1,926,559 is
8		primarily due to increased investments in CIS and also increased investment in IT
9		information and communication systems.
10		
11	•	The forecast for 2018 is \$13,966,910 (net). The decrease from 2017 of \$5,591,068 is
12		primarily due to decreased investments for CIS-related systems, along with decrease
13		investments for IT information and communication systems.
14		
15	•	The forecast for 2019 is \$16,840,554 (net). The increase from 2018 of \$2,873,644 is
16		primarily due to increased investments in IT information and communication systems.
17		
18	•	The forecast for 2020 is \$18,205,522 (net). The increase from 2019 of \$1,364,968 is
19		primarily due to increased investments in IT information and communication systems.
20		
21	Overa	II, General Service expenditures remain generally consistent through the 2016 to 2020

22 Test Years within the range of \$14M to \$19M, with variations year to year due to adjustments to

- 23 the relative mix of initiatives being proposed each year.
- 24

	2015	2016	2017	2018	2019	2020	
	Proposed	Proposed	Proposed	Proposed	Proposed	Proposed	Total
General Plant	\$24,544,709	\$17,631,419	\$19,557,978	\$13,966,910	\$16,840,554	\$18,205,522	\$110,747,091
System Access	\$24,145,118	\$28,232,154	\$28,469,723	\$29,560,667	\$28,726,052	\$31,866,709	\$171,000,423
System Renewal	\$42,388,194	\$48,714,625	\$51,500,169	\$52,051,933	\$52,970,854	\$52,405,780	\$300,031,555
System Service	\$27,321,977	\$38,321,819	\$32,071,882	\$29,920,325	\$26,963,080	\$23,022,061	\$177,621,144
Grand Total	\$118,399,998	\$132,900,017	\$131,599,752	\$125,499,835	\$125,500,540	\$125,500,071	\$759,400,213

EB-2015-0003 PowerStream Inc. **Rate Proposal** Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 12 of 14 Delivered: February 24, 2015

	2015	2016	2017	2018	2019	2020	Overall
	Proposed	Proposed	Proposed	Proposed	Proposed	Proposed	Total
General Plant	21%	13%	15%	11%	13%	15%	15%
System Access	20%	21%	22%	24%	23%	25%	23%
System Renewal	36%	37%	39%	41%	42%	42%	40%
System Service	23%	29%	24%	24%	21%	18%	23%
Grand Total	100%	100%	100%	100%	100%	100%	100%

<sup>1</sup> 2

3

#### Table 5.4.4.2: Summary of Proposed Expenditures All Categories 2015-2020


4

5 Charts 5.4.4.3 to 5.4.4.8 are visual depictions, in pie chart form, of the annual percentages of

6 each of the four categories within the proposed capital expenditure plan for each of the years


7 from 2015 to 2020. Chart 5.4.4.9 depicts the total split of the 4 categories for the entire plan.

8



9 10

11



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 13 of 14 Delivered: February 24, 2015




Chart 5.4.4.5: Breakdown of Proposed Expenditures 2017






Chart 5.4.4.6: Breakdown of Proposed Expenditures 2018





8 9

1

2 3

4

5 6

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.4 Capital Expenditure Summary Page 14 of 14 Delivered: February 24, 2015





Chart 5.4.4.8: Breakdown of Proposed Expenditures 2020



1 2

#### 1 5.4.5. JUSTIFYING CAPITAL EXPENDITURES

2

## 3 As indicated in Chapter 1, the onus is on a distributor to provide the data, information and analyses

- 4 necessary to support the capital-related costs upon which the distributor's rate proposal is based. Filings
- 5 must enable the Board to assess whether and how a distributor's DS Plan delivers value to customers,
- 6 including by controlling costs in relation to its proposed investments through appropriate optimization,
- 7 prioritization and pacing of capital-related expenditures.
- 8

#### 9 5.4.5.1 Overall plan

10 The Board's assessment of DS Plans includes the costs of material projects/activities included in the DS 11 Plan, as well as the costs represented by the respective shares of the overall DS Plan budget allocated to 12 each of the four investment categories. Information to be provided in this section pertains to the latter; the 13 former is addressed in section 5.4.5.2.

14

To support the overall quantum of investments included in a DS Plan by category, a distributor shouldinclude information on:

- comparative expenditures by category over the historical period;
- the forecast impact of system investment on system O&M costs, including on the direction and
   timing of expected impacts;
- the 'drivers' of investments by category (referencing information provided in response to sections
   5.3 and 5.4), including historical trend and expected evolution of each driver over the forecast
   period (e.g. information on the distributor's asset-related performance and performance targets
   relevant for each category, referencing information provided in section 5.2.3);
- information related to the distributor's system capability assessment (see section 5.4.3)
- 25

# 26 5.4.5.2 Material investments

27 The focus of this section is on projects/activities that meet the materiality threshold set out in Chapter 2 of

- 28 the Filing Requirements for Electricity Transmission and Distribution Applications. However, distributors
- are encouraged in all instances to consider the applicability of these requirements to ensure that all
- 30 investments proposed for recovery in rates, including those deemed by the applicant to be distinct for any
- 31 other reason (e.g. unique characteristics; marked divergence from previous trend) are supported by
- 32 evidence that enables the Board's assessment according to the evaluation criteria set out below. The
- 33 level of detail characterizing the evidence filed by a distributor to support a given investment
- 34 project/activity should be proportional to the materiality of the investment.
- 35

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.5 Justifying Capital Expenditures Page 2 of 36 Delivered: February 24, 2015

#### 1 Overall Plan (2011-2020)

2 The section provides the justification and supporting information for the level of investments that 3 have been included in the PowerStream's DS Plan. The data, information and analysis that are 4 necessary to support the capital costs within this rate proposal are presented with references to 5 previous detailed sections as applicable. As previously identified in Sections 5.3.3 and 5.4.2 of 6 this DS Plan, the capital expenditures required in this DS Plan are supported by methodologies, 7 measures, and planning processes that are intended to provide value to customers. 8 9 **Comparative Expenditures by Category** 10 Comparative expenditures by category over the historical period were provided in Exhibit G, Tab 11 2, Section 5.4.4 on Table 5.4.4.1. 12 13 Forecast Impact on System Operating & Maintenance Costs 14 Refer to Exhibit G, Tab 2, Section 5.3.3, page 27. 15 16 a) System Access 17 System Access investments are mandatory, non-discretionary projects initiated by customers or 3<sup>rd</sup> parties. These projects include: 18 19 new connections and subdivisions (including industrial/commercial/institutional (ICI) i. 20 connections and service layouts); 21 Road Authority projects that require the relocation of distribution system assets; ii. 22 iii. metering; 23 other customer initiated work; and iv. 24 **RGEN FIT/microFit.** v. 25 PowerStream uses the economic evaluation methodology prescribed by the Distribution System Code (DSC) to determine the level, if any, of capital contributions for each project, 26 27 with such levels incorporated into the annual capital budget. These investments are typically 28 a high priority, cannot be deferred, and must proceed as planned. A summary of the 29 proposed 2015-2020 system access expenditures is shown in Table 5.4.5.1 below. 30 31

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.5 Justifying Capital Expenditures Page 3 of 36 Delivered: February 24, 2015

	2015	2016	2017	2018	2019	2020
System Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. New Connections and Subdivisions	13,671	14,718	15,801	16,404	17,037	17,674
ii. Road Authority	6,259	9,702	8,679	8,357	5,719	6,222
iii. Metering	3,887	3,025	3,060	3,720	4,715	6,556
iv. Other Customer Initiated Work	329	787	929	1,080	1,256	1,415
v. RGEN FIT/microFIT (Net Rate Base)	-	-	-	-	-	-
v. RGEN FIT/microFIT (Gross Rate Base)	280	137	110	-	-	-
Total System Access (Rate Base)	24,145	28,232	28,470	29,561	28,726	31,867

#### Table 5.4.5.1: System Access Proposed Expenditures

5 *i. New Connections and Subdivisions* 

6 This is a perpetual capital expenditure comprised of non-discretionary projects initiated by 7 customers or developers, where investment is required to enable customers to connect to 8 PowerStream's distribution system. This program includes customer service requests, 9 such as new and upgraded service connections for residential, commercial and industrial 10 customers.

11

PowerStream uses the economic evaluation methodology as prescribed by the Distribution System Code (DSC) to determine the amount, if any, of capital contributions for each project, with the net investment required incorporated into the annual capital budget. These investments cannot be deferred and must proceed as planned.

16

20

22

17 Expenditures related to customer connection project costs are forecasted based on a18 number of factors which include:

- historical levels of activity and investment;
  - known projects in the planning stage;
- a review of economic factors; and
  - predicted civil contractor cost adjustments of 3% for labour and materials.

23 While these factors are the basis for the forecasts, there is a high likelihood that actual 24 expenditures will vary significantly from projections and from year to year. Annual plans 1 are tracked monthly and new forecasts are issued quarterly as new customer connection 2 information becomes available.

The 2016 to 2020 investment requirements for the installation of new service infrastructure, as provided in Table 5.4.5.2, are aligned with the increasing trend in the volume of new customer connections and cost escalations for contractors. Refer to Exhibit H, Tab 3 for a detailed discussion on historical and future customer growth.

7 8

3 4

5

6

	2015	2016	2017	2018	2019	2020
System Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. New Connections and Subdivisions	13,671	14,718	15,801	16,404	17,037	17,674

9 10

11 12

#### Table 5.4.5.2 Proposed Investment for New Connections and Subdivisions

- 13 In addition to assessing the historical expenditures of past years, PowerStream also 14 performs assessments of municipal forecasts, the current customer requests project 15 schedule, and potential future projects based upon discussions with customers and 16 developers in the determination of future investment to support customer connections.
- 17 PowerStream also coordinates its plans as much as possible with the York/Simcoe 18 Regions on planning for customer connections. Ultimately, system access projects are driven by decision points external to PowerStream, and due to factors outside of 19 20 PowerStream's control, there is a high likelihood for actual expenditures to vary 21 considerably from original projections year to year.
- 22

#### 23 ii. Road Authority Projects

24 Projects in this category involve the relocation of PowerStream's distribution system 25 assets to support road relocation and road reconstruction projects at the request of the 26 Regions of York, Simcoe County, or the Ministry of Transportation or the local 27 municipalities. The initiation and timing of these projects is outside of PowerStream's 28 control and therefore the timing and value of investment required by PowerStream is 29 subject to change.

Road Authority projects are customer initiated and PowerStream is obligated under the Distribution System Code and its Conditions of Service to perform these projects and incur its share of related expenditures. These investments cannot be deferred by PowerStream and must proceed when and where required by the customer. PowerStream follows the Public Service Works on Highways Act, 1990 and associated regulations governing the recovery of costs related to road reconstruction work by collecting contributed capital for 50% of labour and labour saving devices.

- 9 Capital contributions toward the cost of all customer demand projects are collected by
  10 PowerStream in accordance with the DSC and the provisions of the Conditions of Service.
- The forecast investments for the 2016 to 2020 are provided below in Table 5.4.5.3.
  Timelines for the execution of these projects are dictated by York Region, Simcoe County,
  the local municipalities, or the Ministry of Transportation.
- 15

8

11

16 PowerStream coordinates its proposed distribution system projects, as much as possible, 17 with these stakeholders in order to maximize efficiencies and minimize disruptions to the 18 public. PowerStream holds regular planning discussions with the Region of York, Simcoe County, the municipalities, and the Ministry of Transportation, and also actively 19 20 participates in Public Utilities Coordinating Committee (PUCC) meetings in order to better 21 identify the scope and number of road authority projects forecast in future years. Lead 22 times for notification of projects typically range from 6 to 36 months, depending on the 23 scope of the project.

24

PowerStream's proposed investment expenditures for 2016 is based upon the scope and volume of the road authority driven projects planned for that year. The 2017 to 2020 proposed investment expenditures are based on a trended forecast based on the historical number of projects initiated from 2011 to 2014 with the latest forecasts for 2015 and 2016. The complete 2015 to 2020 investment requirements is shown in Table 5.4.5.3 below.

<ul> <li><u>Table 5.4.5.3</u>: Proposed Investment for Road Authority Projects</li> <li><i>iii. Metering</i></li> <li>Metering investments includes the installation and replacement of PowerStream's reand wholesale metering assets, in compliance with standards from Measurement Cana and the IESO. The work includes:</li> <li>installation of new and replacement metering for residential and multi-unit residen customers;</li> </ul>			2015	2016	2017	2018	2019	2020
<ul> <li><u>Table 5.4.5.3: Proposed Investment for Road Authority Projects</u></li> <li><i>iii. Metering</i></li> <li>Metering investments includes the installation and replacement of PowerStream's re and wholesale metering assets, in compliance with standards from Measurement Cana and the IESO. The work includes: <ul> <li>installation of new and replacement metering for residential and multi-unit residen customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already ha an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments.</li> </ul> </li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal explates, metering requirements to support new connections and conversion of muters indential to suite metering, and metering equipment requirements</li> </ul>	Systen	n Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
<ul> <li><i>iii. Metering</i></li> <li>Metering investments includes the installation and replacement of PowerStream's reand wholesale metering assets, in compliance with standards from Measurement Canadand the IESO. The work includes: <ul> <li>installation of new and replacement metering for residential and multi-unit resident customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (for customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already here an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale deliver points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments.</li> </ul> </li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of mutersidential buildings from bulk to suite metering, and metering equipment requirements</li> </ul>	ii. Roa	d Authority	6,259	9,702	8,679	8,357	5,719	6,222
<ul> <li>Metering investments includes the installation and replacement of PowerStream's reand wholesale metering assets, in compliance with standards from Measurement Canara and the IESO. The work includes: <ul> <li>installation of new and replacement metering for residential and multi-unit resident customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already he an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> </li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of muters interview.</li> </ul>		Table 5.4.5.3	: Proposed	d Investme	nt for Road	Authority	Projects	
<ul> <li>Metering investments includes the installation and replacement of PowerStream's reand wholesale metering assets, in compliance with standards from Measurement Canara and the IESO. The work includes: <ul> <li>installation of new and replacement metering for residential and multi-unit resident customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already he an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> </li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muters interval wholes to support new connections and conversion of muters interval wholes to support new connections and conversion of muters interval wholes to support new connections and conversion of muters are index to support new connections and conversion of muters interval wholes to support new connections and conversion of muters index to support new connections and conversion of muters index to support new connections and conversion of muters index to support new connections and conversion of muters index to support new connections and conversion of muters index to support new connections and conversion of muters index to support new connect</li></ul>								
<ul> <li>and wholesale metering assets, in compliance with standards from Measurement Canal and the IESO. The work includes:</li> <li>installation of new and replacement metering for residential and multi-unit residen customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already ha an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mutersidential buildings from bulk to suite metering, and metering equipment requirements	iii. Me	tering						
<ul> <li>and the IESO. The work includes:</li> <li>installation of new and replacement metering for residential and multi-unit residen customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already ha an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muters induced plannet buildings from bulk to suite metering, and metering equipment requirements		·						
<ul> <li>installation of new and replacement metering for residential and multi-unit residen customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already ha an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidential buildings from bulk to suite metering, and metering equipment requirements		-		compliance	e with stand	dards from	Measuren	nent Cana
<ul> <li>customers;</li> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already has an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale deliver points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muters and buildings from bulk to suite metering, and metering equipment requirements	and							
<ul> <li>installation of interval meters for new industrial/commercial/institutional (I customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already hat an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale deliver points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muters and buildings from bulk to suite metering, and metering equipment requirements	•		nd replace	ment mete	ring for rea	sidential a	nd multi-ur	nit resident
<ul> <li>customers;</li> <li>installation of interval meters for existing GS&gt;50 customers who do not already has an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale deliver points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muresidential buildings from bulk to suite metering, and metering equipment requirements								
<ul> <li>installation of interval meters for existing GS&gt;50 customers who do not already ha an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muresidential buildings from bulk to suite metering, and metering equipment requirements</li> </ul>	•		rval mete	rs for ne	ew indust	rial/comme	ercial/institu	utional (IC
<ul> <li>an interval meter;</li> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of more residential buildings from bulk to suite metering, and metering equipment requirements								
<ul> <li>installation or replacement of IESO-registered wholesale meters at wholesale delive points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of more residential buildings from bulk to suite metering, and metering equipment requirements	•		I meters fo	or existing	GS>50 cu	stomers wh	no do not a	already ha
<ul> <li>points;</li> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of must residential buildings from bulk to suite metering, and metering equipment requirements								
<ul> <li>inspection and replacement of defective meters;</li> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> </ul> The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal explates, metering requirements to support new connections and conversion of muresidential buildings from bulk to suite metering, and metering equipment requirements	•	-	ement of IE	ESO-registe	ered whole	sale meter	rs at whole	sale delive
<ul> <li>Interval Meter support infrastructure investments (MV90); and</li> <li>Smart Meter support infrastructure investments.</li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal expidates, metering requirements to support new connections and conversion of muresidential buildings from bulk to suite metering, and metering equipment requirements</li> </ul>		•						
<ul> <li>Smart Meter support infrastructure investments.</li> <li>The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations.</li> <li>These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal explanates, metering requirements to support new connections and conversion of murresidential buildings from bulk to suite metering, and metering equipment requirements</li> </ul>	•							
The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.4. Propose meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements	•					/90); and		
meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements	•	Smart Meter support	infrastruct	ure investr	nents.			
meter replacements are to address anticipated meter failures and for the replacement expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements								
expired meters in compliance with Measurement Canada regulations. These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements					•			•
These investments cannot be deferred by PowerStream and must be completed planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements		-		-			-	placement
planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements	exp	bired meters in complia	ance with in	vieasureme	ent Canada	regulation	15.	
planned to meet customer needs and maintain regulatory compliance. Investments meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements	Th	asa invostments can	not ha dat	forrod by	PoworStro	am and n	nust ha a	omploted
meters are forecasted primarily through the review of the number of meter seal exp dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements				-				-
dates, metering requirements to support new connections and conversion of mu residential buildings from bulk to suite metering, and metering equipment requirements	-				•			
residential buildings from bulk to suite metering, and metering equipment requirements		•	•	•				•
		<b>.</b>						
· · · · · · · · · · · · · · · · · · ·		-			•	• •		
					,			0

	2015	2016	2017	2018	2019	2020					
System Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)					
iii. Metering	3,887	3,025	3,060	3,720	4,715	6,556					
Table 5.4.5.4: Proposed Investment for Metering 2015-2020											
v. Other Customer Initiated Work											
Projects in this cate	Projects in this category involve the relocation of PowerStream's distribution system										
assets (poles, anch	ors, transf	formers, ca	ables) to :	support re	quests fro	m custom					
developers and othe											
•			0								
projects are dictated	•		•								
notification of projects typically range from 1 to 12 months, depending on the scope of the											
	s typically i	ange nom	1 to 12 mo	ntns, deper	nding on the	e scope of					
project.		ange nom	1 to 12 mo	ntns, deper	nding on the	e scope of					
		-				·					
project.	gated unde	r the DSC	and its Co	nditions of	Service to	perform th					
project. PowerStream is oblig	gated unde	r the DSC of related	and its Cor expenditur	nditions of es. These	Service to investmen	perform th					
project. PowerStream is oblig projects and incur indeferred by PowerSt	gated unde its share o ream and r	r the DSC of related must proce	and its Cor expenditur ed when ar	nditions of es. These nd where re	Service to investmen equired by	perform th its cannot the custor					
project. PowerStream is oblig projects and incur deferred by PowerSt capital contributions	gated unde its share o ream and r toward the	r the DSC of related must proce e cost of a	and its Cor expenditur ed when ar Il customer	nditions of es. These nd where re demand p	Service to investmen equired by projects are	perform th its cannot the custor e collected					
project. PowerStream is oblig projects and incur is deferred by PowerSt capital contributions PowerStream in acco	gated unde its share o ream and r toward the ordance with	r the DSC of related must proce e cost of a h the DSC	and its Cor expenditur ed when ar Il customer and the pro	nditions of es. These nd where r demand p visions of it	Service to investmen equired by projects are	perform th its cannot the custor e collected ins of Servio					
project. PowerStream is oblig projects and incur is deferred by PowerSt capital contributions PowerStream in acco PowerStream's prop	gated unde its share of ream and r toward the ordance with osed inves	r the DSC of related must proce e cost of a h the DSC	and its Cor expenditur ed when ar Il customer and the pro enditures fo	nditions of es. These nd where re demand p visions of it or 2016 to	Service to investmen equired by projects are s Condition 2020 are	perform th its cannot the custor e collected ns of Servio based on					
project. PowerStream is oblig projects and incur is deferred by PowerSt capital contributions PowerStream in acco	gated unde its share of ream and r toward the ordance with osed inves enditures of	r the DSC of related must proce e cost of a h the DSC stment expe	and its Cor expenditur ed when a Il customer and the pro enditures fo nitiated fron	nditions of es. These nd where re demand p visions of it or 2016 to n 2011 to 2	Service to investmen equired by projects are s Condition 2020 are 2014 with la	perform th its cannot the custor e collected hs of Servio based on atest foreca					

	2015	2016	2017	2018	2019	2020
System Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
iv. Other Customer Initiated Worl	329	787	929	1,080	1,256	1,415

- 23

# Table 5.4.5.5: Proposed Investment for Other Customer Initiated Work

v. RGEN FIT/microFIT

Table 5.4.5.5.

Projects in this category involved the connection of FIT and microFIT renewable generation to PowerStream's distribution system in accordance with requests from OPA-

contracted participants. Timelines for the execution of these projects are dictated by the
 generator.

3

PowerStream is obligated under the DSC and its Conditions of Service to connect these
projects. These investments cannot be deferred by PowerStream and must proceed when
and where required by the customer. Capital contributions toward the cost of all the RGEN
connection projects are collected by PowerStream in accordance with the DSC and the
provisions of its Conditions of Service.

9

PowerStream does not propose any <u>ne</u>t expenditure for the years 2015 to 2017 as all FIT and microFIT connections are 100% funded by capital contributions from the customer. As there is some uncertainty if the IESO programs will continue after 2017, PowerStream has elected not to propose any expenditure for this initiative in 2018 or after. The forecast investments (net and gross) for 2016 to 2020 are provided below in Table 5.4.5.6.

15

System Access	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
v. RGEN FIT/microFIT (Gross Rate Base)	280	137	11	-	-	-
v. RGEN FIT/microFIT (Net Rate Base)	-	-	-	-	-	-

16 17

Table 5.4.5.6: Proposed Investment for RGEN FIT/microFIT

18 10

# 19 b) System Renewal

System renewal investments are projects and programs directed toward the replacement or
 rehabilitation of equipment due to being beyond useful life and/or deteriorating condition.
 These projects are classified as controllable as the initiation and timing of these projects is
 largely within PowerStream's control.

24

As described in Exhibit G2, Tab 2, Section 5.4.4 page 6, PowerStream's System Renewal project expenditures have ranged from \$11.527 M to \$42.388 M during the 2011 to 2015 period. The 2016 forecast of \$48.715 M, an increase of \$6.327 M over 2015, is intended to provide the necessary funding to maintain the health of the distribution system, in particular for the underground cable and asset replacement programs, overhead lines and asset

replacement programs, and rear lot conversion projects. A summary of the proposed 2015-

2 2020 System Renewal expenditures is shown in Table 5.4.5.7 below.

3

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. UG Lines - Planned Asset Replacement	20,687	21,601	22,862	23,781	24,666	25,186
ii. Distribution Lines - Emergency/Reactive Replac	8,416	8,636	8,730	8,888	8,925	8,504
iii. Overhead Lines - Planned Asset Replacement	7,698	7,907	9,082	8,558	9,144	9,022
iv. Storm Hardening& Rear Lot Conversion	3,500	7,900	8,000	7,500	6,900	7,200
v. Stations/P&C - Asset Replacement	2,087	2,671	2,827	3,325	3,336	2,493
Total System Renewal	42,388	48,715	51,500	52,052	52,971	52,406

4 5

6 7

## Table 5.4.5.7: Proposed System Renewal Expenditures 2015-2020

8 i. Underground Lines - Planned Asset Replacement

9 This category of investments includes various projects and programs for the replacement 10 or rehabilitation of cable, switchgear and pad-mounted transformers that comprise the 11 main components of the underground distribution system. Since the distribution system 12 assets in this category were originally engineered, constructed and connected as a complete system, the majority of the planned replacement of these assets is also optimally 13 14 and holistically done as a system. For example, the replacement of padmount 15 transformers and switchgears is frequently incorporated into the cable replacement projects to which they are connected. Therefore, the 2015-2020 proposed expenditures 16 17 for Underground Lines and Assets is shown as a combined budget for cable replacement, 18 padmount transformers replacement, and switchgear replacement. The combined forecast 19 investments for 2016 to 2020 are provided in Table 5.4.5.8.

- 20
- 21

#### i) Cable Replacement and Rehabilitation Projects

PowerStream has approximately 8,200 km of underground primary cable length in service, the vast majority of which is direct buried with the balance in duct. A significant percentage of these cables are at, or near, end of life, and are starting to fail with increased frequency.

1	Refer to Section Exhibit G, Tab 2, 5.3.2, Overview of Assets Managed, for the
2	demographics of cables.
3	
4	There are two methods of cable remediation for addressing the cable aging issue:
5	
6	<ul> <li>Cable Replacement – replace existing cable with new cable; and</li> </ul>
7	• Cable Injection – extend existing cable service life by injecting a fluid compound
8	into the cable to rehabilitate the insulation.
9	
10	PowerStream's approach for maintaining the cable population, once they have been
11	identified by age or failure, is summarized below:
12	a) PowerStream conducts testing to determine the condition of the cable and to rank
13	the order of severity of condition; and
14	b) PowerStream uses a cable prioritization system to select which cables should be
15	scheduled for replacement and which cables should be scheduled for injection.
16	While the Cable Replacement option is more expensive than the Cable Injection option
17	with respect to initial capital cost, it does have the advantage of new cable that will be
18	utilized for a longer period of time (50-55 years).
19	
20	The Cable Injection option is less expensive and is intended to extend the life of cable
21	by 20 years. As the cable gets older, the cable insulation may develop a premature
22	aging process caused by a phenomenon known as "water treeing". Water trees will
23	reduce the breakdown strength of the insulation and eventually lead to cable failure.
24	The Cable Injection process injects silicone chemicals down the strands of the cable.
25	The silicone fluid diffuses out of the strands through the strand shield and into the
26	insulation. The fluid then polymerizes with water (or moisture) and the silicone
27	molecule grows and fills all water trees and voids. This increases the dielectric strength
28	of the cable and thus extends the life of the cable. It should be noted that cable
29	dielectric failure may result from causes other than "water treeing" alone. Some
30	examples include impurity, presence of by-products, contaminants, gas, electric trees,

1	etc. As a result, there are many cases where the cable injection process is not
2	effective.
3	
4	PowerStream first began cable injection pilot projects in 2011 and, because of the
5	success of the pilot projects, has continued and expanded the program in the years
6	since.
7	
8	Cable Injection is only viable for a specific demographics of cable. The criteria for
9	selecting cable injection candidates are listed below.
10	• Pre 1989;
11	Not solid core;
12	Not strand-filled;
13	<ul> <li>Concentric neutral not corroded significantly;</li> </ul>
14	No electrical trees present (cable injection only can repair water trees and not
15	electrical trees); and
16	<ul> <li>Only a few splices within a cable segment.</li> </ul>
17	
18	Starting in 2012, PowerStream began conducting cable testing (Tan Delta tests) to
19	further assess the condition of cable to:
20	• Determine which intervention method (replacement vs. injection) is more suitable
21	to a specific location;
22	Determine the appropriate quantity and timing of cable intervention (replacement
23	or injection); and
24	<ul> <li>Validate and prioritize the cable replacement/injection projects.</li> </ul>
25	
26	The Tan Delta test results helped PowerStream determine the severity of cable
27	degradation and to prioritize the specific cables for injection or replacement.
28	
29	Based on the findings of the Asset Condition Assessment, and a detailed analysis of
30	success and costs of the two remediation techniques, PowerStream proposes to
31	remediate specific underground cables in specific areas with:
32	

1	• the cable injection program at the rate of 100 km/year until 2036. It is estimated
2	that the Cable Injection program will take at least 22 years to complete all the
3	suitable cable available for rehabilitation; and
4	<ul> <li>to replace underground cables at a rate of 30 km/year. It is estimated that the</li> </ul>
5	Cable Replacement program will continue at the same rate of km replaced per
6	year after 2036, at which time the amounts will increase.
7	
8	Detailed justification information on the cable replacement and injection projects can be
9	found in the Material Investments section in Appendix A to this DS Plan.
10	
11	ii) Switchgear Replacement Program
12	PowerStream has approximately 1825 distribution switchgear units in service.
13	According to the Kinectrics Inc. Report "Asset Amortization Study for the Ontario
14	Energy Board", the useful life of pad-mounted switchgear is 20-45 years with a typical
15	useful life of 30 years.
16	
17	Refer to Exhibit G, Tab 2, Section 5.3.2, Overview of Assets Managed, for the
18	demographics of switchgear.
19	
20	Refer to Exhibit G, Tab 2, Section 5.3.2, Overview of Assets Managed, for the health
21	index for switchgear. Among the switchgear population in PowerStream South, there
22	are approx. 1,000 units that are PMH (air insulated) type. The operational concerns of
23	PMH units in PowerStream South are listed below.
24	• PMH units are live-front and are an obsolete design. They are not approved for
25	new installations and for planned replacement of existing units in the 27.6 kV
26	system. PowerStream's long-term plan is to eventually phase out all PMH units in
27	the 27.6 kV system and replace them with either SF6 or solid dielectric dead front
28	gear;
29	PMH units require regular maintenance (dry-ice cleaning);
30	• PMH units are rated at 25 kV nominal, but are operated at 27.6 kV. This
31	increases the risk of flash over, especially with the presence of contamination
32	and moisture; and

- 1 Failure rate of PMH units is high. PowerStream has experienced cases of flash 2 over in units that are not old. 3 It is expected that as the existing distribution switchgear units age and deteriorate with 4 time, inspection and analysis results will show a growing number of switchgear units in 5 poor condition and requiring replacement. 6 7 To address the deteriorating switchgear condition concerns, PowerStream proposes to 8 replace 31-36 of the worst units/year. It is expected that the switchgear replacement 9 program will be an on-going program to maintain the integrity of the distribution system. 10 11 Detailed justification information on the switchgear replacement projects can be found 12 in the Material Investments section in Appendix A of this DS Plan. 13 14 iii) Transformer Replacements (Padmount) PowerStream has approximately 40,000 underground transformers, both padmount 15 16 and submersible. in service. According to the Kinectrics Inc. Report "Asset 17 Amortization Study for the Ontario Energy Board", the useful life of a padmount 18 transformer is 25-45 years with a typical useful life of 40 years. 19 20 PowerStream normally operates its pole tops and single phase residential padmount 21 transformers on a run-to-failure approach (except for those transformers that pose a 22 safety or environmental risk). 23 24 In order to reduce the increased costs associated with unplanned three phase 25 transformers failures, in 2013, PowerStream initiated a proactive replacement project.
- 26 This proactive replacement project replaces the worst pad-mounted and submersible 27 transformers based on the annual inspection program results and historical transformer 28 loading information.
- 30 Where necessary, PowerStream also performs remediation work (re-connection and/or 31 an additional transformer) at specific locations of legacy delta/wye distribution 32 transformers in order to ensure compliance with ESA directives.

Refer to Exhibit G, Tab 2, Section 5.3.2, *Overview of Assets Managed*, for the
 demographics of distribution transformers.

PowerStream experienced 50, 66 and 78 underground transformer failures (including
padmount transformer and submersible transformer) in 2011, 2012, and 2013
respectively, an average of 65 failures per year.

8 PowerStream proposes the replacement of 60 padmount transformers per year, 9 prioritized according to worst condition based on the results of the inspection program 10 and transformer loading analysis. Forecasted expenditures are based on historical 11 average replacement costs.

12 13

3

7

#### iv) Mini-Rupter Switches

PowerStream has approximately 433 mini-rupter switches in service. Mini-rupters are described as high-capacity isolating switches found in vaults in commercial/industrial areas. According to the Kinectrics Inc. Report *"Asset Amortization Study for the Ontario Energy Board"*, the useful life of UG vault switches is 20-50 years with a typical useful life of 35 years.

19

This Project has been implemented to replace end-of-life switch units to maintain system reliability and customer service. On a prioritized basis, each year PowerStream will inspect, review, and select a number of switch units for replacement. The locations and priority are determined based on the results from the Asset Condition Assessment (ACA) process and internal stakeholders.

25

The existing Mini-Rupter switches design and connection do not provide sufficient access to allow field staff to perform switching and maintenance operations under normal and emergency situations, thus impairing service to affected customers. These switches are open to dirt and contamination and susceptible to flashover affecting system reliability. PowerStream is intending to replace the mini-rupter switches with either a solid dielectric switch, or alternatively a way 6 switch, depending on space and existing configuration limitation. 1 Mini-Rupter switch failures pose a safety risk to operations staff. The Mini-Rupter switch 2 is located within an enclosed vault room. The Mini-Rupter switch may fail when 3 operations staff is working on the unit or other equipment within the vault. When the 4 Mini-Rupter switch fails, there may be flashover or fire, which may result in personal 5 injury.

6

10

13

PowerStream proposes to replace 15 of the worst units/year. It is expected that the minirupter switch replacement program will be an on-going program to maintain the integrity
of the distribution system.

11 Detailed justification information on the mini-rupter switch replacement projects can be 12 found in the Material Investments section in Appendix A of this DS Plan.

14 The total for all these initiatives related to underground line assets (cable, switchgear, 15 transformers, mini-rupters) is as shown in the following Table 5.4.5.8.

16

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. UG Lines - Planned Asset Replacement	20,687	21,601	22,862	23,781	24,666	25,186

Table 5.4.5.8: Proposed UG Lines Expenditures 2015-2020

18 19 20

17

# ii. Distribution Lines – Emergency/Reactive Replacement

Projects in this category involved the immediate replacement of PowerStream's
distribution system assets (poles, transformers, switches, switchgear, cable, conductor,
insulators, guys, anchors, etc) due to unanticipated failure, storms, motor vehicle
accidents, vandalism, etc.

25

PowerStream's Emergency/Reactive forecasts expenditures for 2016 to 2020 are based
on historical spending during the period of 2011 to 2013, and are shown in Table 5.4.5.9
below.

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
ii. Distribution Lines - Emergency/Reactive Replace	8,416	8,636	8,730	8,888	8,925	8,504

#### Table 5.4.5.9: Proposed Distribution Lines – Emergency/Reactive Expenditures

4

#### 5 iii. Overhead Lines – Planned Asset Replacement

6 This category of investments includes projects for the replacement of poles, insulators, and 7 switches that comprise the main components of the overhead distribution system. It also 8 includes discrete voltage conversion projects. Depending on geographical area and 9 distribution system characteristics, the replacement of these individual assets are often 10 combined into the same project, and as such, the proposed capital expenditures for the 11 assets in this category has also been combined into one budget.

12 13

# i) Pole Replacement Program

PowerStream has over 40,000 wood poles in service. A significant percentage of these poles are at, or near, end of life, and their condition has deteriorated to the point that there is a high probability of failure. According to Kinectrics Inc. Report *"Asset Amortization Study for the Ontario Energy Board*", the useful life of wood poles is 35-75 years with a typical useful life of 45 years. For IFRS depreciation purposes, PowerStream uses 40 years as the useful life for poles.

20

21 Refer to Section Exhibit G, Tab 2, 5.3.2, *Overview of Assets Managed*, for the 22 demographics of wood poles.

23

It is expected that as the existing poles age and deteriorate, inspection and testing results will show an increasing number of poles in poor condition and requiring replacement. Assuming an equal installation age profile of poles through its distribution system, theoretically 2.5% of the poles would require replacement every year. Since the majority of poles in PowerStream's distribution system are of later vintage, PowerStream's experience has shown that only 1% of the pole population are expected to be found in poor condition every year (over the next 5 years). As such,,

- PowerStream proposes to only replace 400 poles per year to keep up with the aging
   pole demographics (1% of 40,000 poles = 400 poles).
  - It is expected that the pole replacement program will be an on-going program to maintain the integrity of the distribution system and to protect public safety.
    - Detailed justification information for the Pole Replacement program can be found in the Material Investments section in Appendix A of this DS Plan.
- 9 10

5

6 7

8

## ii) Replacement of 44 kV porcelain insulators

PowerStream is experiencing a growing number of power interruptions due to insulator failure. It has been found that the older vintage of 44kV porcelain insulators are prone to tracking and flash over. It is estimated that there are over 1,660 of these insulators in the PowerStream distribution system. PowerStream is proposing to replace all remaining legacy 44 kV porcelain insulators with polymer type insulators over the next four years (415 units per year).

17 18

# iii) Fault Indicator replacement program

19 Since PowerStream was the result of mergers of several "predecessor" utilities, there 20 are several different types of fault indicators currently deployed on PowerStream 21 distribution systems. Some areas have fault indicators heavily deployed, while others 22 have limited numbers installed or no fault indicators at all. This program is a 23 combination of adding fault indication to areas where fault indication is absent, as well 24 as replacing older technology fault indicators that are obsolete or prone to malfunction. 25 In addition, second generation fault indicators installed over the past 10-15 years are 26 battery operated and the batteries are reaching end of life, necessitating the change 27 out of the fault indicators or where possible replacement of the batteries. The Fault 28 Indicator Deployment Plan requires the deployment of a standard, modern fault 29 indicator. Levels of spending remain constant at \$500,000 per annum from 2015 30 through 2017, then increases to \$635,000 by 2023. Increased expenditures are to 31 account for inflation and also to budget for the costs of communications infrastructure 32 to connect to SCADA fault indicators at strategic locations.

- 1 *iv*)Replacement of end-of-life RTU-controlled automated switches
- PowerStream has approximately 340 Remote Terminal Unit (RTU) automated switches
  in service. According to the Kinectrics Inc. Report *"Asset Amortization Study for the Ontario Energy Board"* the operational useful life of these automated switches is 25
  years, with an IFRS useful life of 40 years.
- 6

RTU controlled switches (predominantly SCADA-Mates) provide rapid transfer of loads
in emergencies, reduce restoration time which improves reliability, provide flexibility to
reconfigure the system to avoid feeder and station overloads during summer peak.

10 There are a number of existing overhead RTU-controlled switches that are at or close 11 to end-of-life, and will eventually fail to open or close remotely. Through annual 12 inspection and maintenance programs, PowerStream will identify the units that are in 13 the worst condition and require replacement. PowerStream proposes to replace 5 of 14 these RTU-controlled switches each year for the next 10 years.

15 16

#### v) Voltage Conversion Projects - 8kV and 13.8 kV to 27.6kV

- 17 The following voltage conversion projects are included in the Overhead Lines and18 Assets Planned Replacement program:
- 2015 Elder Mill MS Conversion- Part 2 (3F2);
  - 2015/2016 Miller Avenue Markham 27.6kV Conversion;
    - 2017 Concord MS Conversion to 27.6 kV Phase 3;
    - 2017 Hwy 27 from Major Mack to Nashville 27.6kV Conversion; and
    - 2019 Elder Mill MS Conversion Part 3.
- 23 24

25

26

27

20

21

22

Detailed justification information for the voltage conversion projects can be found in the Material Investments section of Appendix A to this DS Plan.

PowerStream's total proposed investment expenditures for Overhead Lines - Planned Asset Replacement for 2016 to 2020 is based on the planned replacement or rehabilitation of 400 poles/year, 415 – 44kV porcelain insulators/year, and 5 remotecontrolled switches/year. Also, these proposed expenditures include the five voltage conversion projects between 2015 and 2019 as noted above. Historic per unit costs

have been used to determine the 2016 to 2020 Test Year investment requirements, which are shown in Table 5.4.5.10 below.

3

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
iii. Overhead Lines - Planned Asset Replacement	7,698	7,907	9,082	8,558	9,144	9,022

Table 5.4.5.10: Proposed Overhead Line Planned Expenditures 2015-2020

5 6

7

4

# iv. Storm Hardening & Rear Lot Conversion

8 Exhibit G, Tab 2, Section 5.2.3 page 10, refers to a study performed as a result of the 9 December 21<sup>st</sup> 2013 ice storm. Included in the study report was a series of 10 recommendations. This category covers the capital work that PowerStream must 11 complete to harden (strengthen) the overhead distribution system to withstand the 12 frequency and severity of storms (wind, rain, ice) that have been experienced the last 13 few years and, according to meteorologists, is expected to become more common in 14 the future.

15

16 The vast majority of PowerStream's overhead distribution system has been designed 17 and constructed to legacy standards for the typical wind and ice loadings commonly 18 experienced at that time. Over the past 15 years, the increased frequency and severity 19 of extreme weather events has led to improvements to construction standards for all 20 new distribution system construction, however, parts of the existing distribution system 21 needs remedial work to bring it up to the latest standards.

As noted in Exhibit G, Tab 2, Section 5.2.3, PowerStream has a number of pockets of customers (mainly residential) being supplied by rear lot construction. In accordance with the consultant's report, PowerStream will adopt full conversion for rear lots and recommend completion over 15 years. The projects will be prioritized based on age, asset condition, customer needs and reliability.

28

22

PowerStream's proposed rear lot conversion investment expenditures for 2016 to 2020
is based on historical expenditures of similar type construction work. The proposed

1	investments are based on estimated construction costs of approximately \$12,400 per
2	customer.
3	
4	Initiatives included in the Storm Hardening program include:
5	a) Grade 1/Composite Poles for Strategic Locations:
6	PowerStream will continue development of composite pole standards and consider
7	use of composite poles and Grade 1 construction in future construction of poles
8	with 3 or more circuits or critical poles as defined.
9	
10	b) Periodic in-line Anchoring :
11	PowerStream will review existing lines and determine additional anchoring needs,
12	both in-line anchors and storm-guying. PowerStream plans to reinforce all poles
13	that carry 4 circuits, 1500 poles in all.
14	
15	c) Flood Avoidance:
16	Relocate all existing flood sensitive equipment (switches, breakers, relays, etc)
17	located in existing transformer stations to be above grade. PowerStream plans to
18	complete this work over four years.
19	
20	d) Rear Lot Remediation:
21	Convert to full front lot current standard over 15 years.
22	
23	PowerStream's proposed investment expenditures for 2016 to 2020 is based on
24	combination of available resources and affordability.
25	
26	The forecasted Storm Hardening and Rear Lot Conversion investments for 2016 to 2020
27	are provided below in Table 5.4.5.11.
28	
	2015 2016 2017 2018 2019 2020

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
iv. Storm Hardening & Rear Lot Conversion	3,500	7,900	8,000	7,500	6,900	7,200

Table 5.4.5.11: Proposed Storm Hardening Expenditures 2015-2020

1 v. Stations/P&C - Asset Replacement

Projects in this category include the planned and unscheduled replacement of assets related to Stations and also Protection and Control (P&C) for transformer stations connected to the provincial transmission system, and distribution substations supplied from inside the distribution system. The assets covered by this program includes transformers, circuit breakers and switchgear, capacitors, reactors, RTUs, relays, and SCADA control systems for the eleven 230kV transformer stations and 54 municipal substations owned by PowerStream.

10 The level of investment for the planned replacement of specific station related assets 11 are to address anticipated end of life equipment failure and meet the reliability 12 requirements of the IESO Market Rules and Standards.

13

9

14 The level of investment for the unscheduled replacement of station related assets is 15 determined from the historical expenditures during the 2011 to 2013 period. The 16 forecast investments for 2016 to 2020 are provided below in Table 5.4.5.12.

17

	2015	2016	2017	2018	2019	2020
System Renewal	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
v. Stations/P&C - Asset Replacement	2,087	2,671	2,827	3,325	3,336	2,493

Table 5.4.5.12: Proposed Stations/P&C Expenditures 2015-2020

19

18

## 20 21

# 22 c) System Service

PowerStream's forecasted System Service expenditures levels represent the minimum
 expenditures necessary to support the related initiatives through 2016 to 2020.

25

System Service investments address capacity, reliability, safety, security and Smart
 Grid/RGEN initiatives. A summary of the proposed 2015-2020 System Service expenditures
 is shown in Table 5.4.5.13 below.

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 5.4.5 Justifying Capital Expenditures Page 22 of 36 Delivered: February 24, 2015

	2015	2016	2017	2018	2019	2020
System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. Additional Capacity - Stations	14,115	16,175	9,439	12,261	2,629	4,296
ii. Additional Capacity -Lines	9,203	17,769	17,232	11,698	18,182	12,153
iii. Reliability including Dist. Auto.	3,943	3,159	4,183	4,658	4,550	5,161
iv. Station Safety & Security	62	149	149	234	533	341
v. Smart Grid/RGEN - System Related	1,151	1,070	1,070	1,070	1,070	1,070
Total System Service	28,473	38,322	32,072	29,920	26,963	23,022

<sup>1</sup> 2

3 4

#### Table 5.4.5.13: Summary of System Service Expenditures 2015-2020

5 Note: The above 2015 Smart Grid/RGEN amounts are Non-Rate base and, as directed by the OEB, will

6 be recorded in OEB deferral account 1534. The above 2016-2020 Smart Grid/RGEN amounts will no

7 longer be recorded in deferral accounts, as prescribed by the OEB Filing Requirements, Chapter 2.

8 9

#### i. Additional Capacity – Stations

10 This category of investments includes projects for the construction of new, or the 11 expansion of existing transformer stations and municipal substations. Proposed 12 investments under this category for 2016 to 2020 are projects intended to ensure stations 13 (both TSs and MSs) have peak loadings maintained at or below their planning ratings. 14 Since the scope of both of these types of projects are very similar, proposed capital 15 expenditures for the assets in this category has also been combined into one budget.

16 17

#### i) Additional Capacity Station Projects at Transformer Stations

Proposed TS additional capacity investments during 2016 to 2020 are related to expenditures for the completion of the Vaughan VTS#4 transformer station where the first aspects of this project (land purchase and environmental assessment) started in 2014. The in-service date for Vaughan VTS#4 station is scheduled for spring 2017, and the construction of additional new feeder connections for this station is scheduled for 2017-2020. The detailed justification for the Vaughan VTS#4 project was provided in PowerStream's 2014 EDR Application EB-2013-0166.

In addition, PowerStream is proposing expenditures in 2020 related to purchase ofland for the new Markham MTS#5.

- 27
- 28

1	ii) Additio	nal Capacity Station Projects at Municipal Stations
2	Propos	sed investments for Additional Capacity MS projects are intended to maintain
3	the loa	ading of existing municipal stations at or below their computed firm kVA
4	ratings	. In addition, the proposed investments are designed to ensure sufficient
5	spare of	capacity exists such that if there is a loss of one station, the neighbouring two
6	station	s can accommodate the lost capacity.
7		
8	PowerStrear	n has proposed investments for 7 new MSs and Increase Capacity at 3 MSs
9	in 2016 to 20	)20:
10	• New 44	4kV MS – Painswick South (Barrie) – construction 2015, in service 2016;
11	• New 4	4kV MS - Mill St. MS#2 (Tottenham) - construction 2016-2018, in service
12	2019;	
13	• New 4	4kV MS - Harvie Rd. MS (Barrie) - construction 2020, in service 2021 (land
14	2016);	
15	• New 44	4kV MS - Dufferin MS#2 (Alliston) – construction 2016-2018, in service 2019;
16	• New 4	4kV MS - Little Lake MS#2 (Barrie) - construction 2015-2017, in service
17	2018;	
18	• New 4	4kV MS - Melbourne MS#2 (Bradford) – construction 2016-2018, in service
19	2019;	
20	• New 4	4kV MS - Patterson MS#2 (Beeton) - construction 2019-2020, in service
21	2021;	
22	<ul> <li>Increase</li> </ul>	se Capacity – Aurora MS6 (Aurora) – construction 2016-2017, in service
23	2018;	
24	<ul> <li>Increase</li> </ul>	se Capacity – Aurora MS4 (Aurora) – construction 2019-2020, in service
25	2021; a	and
26	<ul> <li>Increase</li> </ul>	se Capacity – Letitia MS (Barrie) – construction 2018-2019, in service 2020;
27		
28	As reference	ed in Exhibit G, Tab 2, Section 5.3.1, PowerStream undertakes a planning
29	study to revi	ew system peaks compared to system capacity, to determine if expansion to
30	the transforr	nation or distribution system is required. Additionally, PowerStream will be
31	investigating	alternative capacity solutions under the Regional Planning IRRP process, as
32	noted in Ex	hibit G, Tab 2, Section 5.2.2. The capacity reviews will be performed to

quantify loads and needs, and depending on the results of the alternative supply solutions, the plans stated for additional capacity at municipal stations may be altered.The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.14.Detailed information on the Material Investments under this category can be found in Appendix A of this DS Plan.

	2015	2016	2017	2018	2019	2020
System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. Additional Capacity - Stations	14,115	16,175	9,439	12,261	2,629	4,296

- Table 5.4.5.14: Proposed Additional Capacity Stations Expenditures 2015-2020
- 11

12

9 10

1

2

3 4

5 6

7

8

### ii. Additional Capacity – Lines

Proposed investments under this category for 2016 to 2020 are projects intended to maintain feeder peak loading below 400 amps under normal conditions and to comply with calculated feeder egress ratings during normal and contingency conditions. This is required to maintain reliable supply to customers.

17

21

23

24

The majority of projects under this category support load growth within the various
 municipalities of PowerStream's service area for servicing new subdivisions, industrial
 loads, and commercial and institutional developments.

# 22 The projects types include:

- additional feeder circuits added to existing pole lines;
- line extensions; and
  - the rebuild of existing feeder circuits using higher capacity conductor.
- 25 26

The forecast investments for 2016 to 2020 are provided below in Table 5.4.5.15. Detailed information on the Material Investments under this category can be found in Appendix A of this DS Plan.

		2015	2016	2017	2018	2019	2020
	System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
1	ii. Additional Capacity -Lines	9,203	17,769	17,232	11,698	18,182	12,153
2	Table 5.4.5.15: Propose	ed Addition	al Capacit	y – Lines E	xpenditure	es 2015-20	<u>20</u>
3							
4	iii. Reliability Investments inc	luding Dist	ribution Au	tomation			
5	Reliability driven investme	nts are pro	ojects prop	osed to ma	aintain or i	mprove cu	rrent levels
6	of service to customers.	Feeders w	ith deterio	rating relia	ability stati	stics are t	argeted for
7	review and remedial action	n plans are	developed	l to improv	e reliability		
8							
9	Reliability investments in	2016 to	2020 are	focused o	n initiative	es to impr	ove feeder
10	reliability, and the deployr	nent of dis	tribution a	utomation a	assets and	l systems i	dentified in
11	PowerStream's GEA Plan	filed in EB	-2012-016	1.			
12							
13	Improvements to distributi	on automa	ation is a k	ey compor	nent of Pov	werStream	's reliability
14	improvement efforts for th	ne worst p	erforming	feeders an	d poor pe	rforming a	reas of the
15	13.8kV and 27.6kV distril	oution syst	em. In ge	neral, distr	ibution au	tomation v	/ill improve
16	power outage restoration	and there	fore syster	n reliability	. The dec	ision on q	uantity and
17	location of automation ec	uipment is	made on	a case-to	-case bas	is and gui	ded by the
18	following three criteria:						
19							
20	Economic Consideratio	<i>n</i> : the cost	of a distrib	ution auto	mation pro	ject must b	e less than
21	the benefit of the re	liability im	provement	, calculate	ed using o	customer	interruption
22	frequency and duration						
23							
24	Feeder Loading Cons	ideration:	to facilitate	e back-up	and eme	rgency loa	d transfer,
25	distribution automation	equipment	must be ir	nstalled so	that the fe	eder segm	ent loading
26	can be limited to a certa	ain thresho	ld, based o	on specific	feeder con	figuration;	and
27							
28	System Control Cons	ideration:	to facilita	te control	room op	perations,	distribution
29	automation equipment	must be ins	stalled bas	ed on spec	ific feeder	operating o	conditions.

1 As part of Distribution Automation, automatic feeder restoration projects are planned for 2 the Vaughan, Richmond Hill and Markham transformer stations each year of the DS Plan. 3 Each project involves the implementation of Automatic Feeder Restoration capabilities on 4 two feeders transformer at two stations over а two year period.

5

Also, upgrades to the existing transformer and bus differential protections are planned
 because the existing relays are approaching the end of their expected life. New relays will
 provide fault recording capabilities which, when the data is analyzed, will allow
 improvement to relay settings and/or optimize the fuse settings on the distribution feeders.

10

11 Other distribution automation initiatives include the installation of SCADA-controlled 12 switches and reclosers, improvements to SCADA infrastructure including communication 13 networks, and distribution feeder fault indicator installation.

14

The forecasted Reliability investments, including Distribution Automation, for 2016 to 2020
are provided below in Table 5.4.5.16. Detailed information on the Material Investments
under this category can be found in Appendix A of this DS Plan.

18

	2015	2016	2017	2018	2019	2020		
System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)		
iii. Reliability including Dist. Auto.	3,943	3,159	4,183	4,658	4,550	5,161		
Table 5.4.5.16: Proposed Reliability Expenditures 2015-2020								

20 21

22

19

# iv. Station Safety and Security

Station Safety and Security investments are required to address projects identified through project prioritization as requiring investment to address safety risks and also risks of equipment damaged from physical and cyber intrusions and the present lack of acceptable levels of equipment monitoring. Justification on a project basis is included in the material project templates provided in Appendix A.

28

29 Station video surveillance systems have been added to increase station security as well 30 as monitor equipment operation during switching functions. Fixed infrared cameras have been added to one station to monitor equipment temperatures of outdoor station
 equipment.

3

Proposed expenditures in 2016 – 2017 include initiatives to strengthen the security
 systems of the Operations' network and critical cyber assts. PowerStream recognizes that
 expenditures are needed to maintain compliance with the North American Electricity
 Reliability Council's Critical Infrastructure Program (NERC-CIP) for protecting the
 Operations' Cyber Assets from cyber-attack. The effort will focus on the further
 segmentation of the network; implementing Electronic Security Perimeters (ESP) within
 Physical Security Perimeters (PSP).

11

12 This proposed initiative will further strengthen the security of critical assets, as no outside 13 third party will access to the physical plant. Critical Operations' data will not be integrated 14 into the "cloud" and remain within the sphere of the Operations' Department.

16 Other proposed security expenditures under this category in 2016-2020 include station 17 switchyard lighting improvements.

18

21

15

Safety investments under this category for 2016 to 2020 are projects designed to address
 safety deficiencies or potential environmental risks present in the distribution system.

- 22 The safety investments include the following initiatives:
  - Oil containments systems for transformer stations; and
  - Transformer station switchgear arc flash prevention.
- 24 25

26

27

23

The forecasted Station Safety & Security investments for 2016 to 2020 are provided below in Table 5.4.5.17.

28

	2015	2016	2017	2018	2019	2020
System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
iv. Station Safety & Security	62	149	149	234	533	341

29 30 31

Table 5.4.5.17: Proposed Station Safety & Security Expenditures 2015-2020

1 v. Smart Grid/RGEN Investments

Proposed projects in this category are related to initiatives to support the continuation of
PowerStream's Smart Grid Implementation Plan as detailed in PowerStream's GEA Plan
submitted in EB-2012-0161 (Exhibit B2, Tab1, Schedule 2). In accordance with OEB
guidelines, Smart Grid/RGEN expenditures in Year 2016, and after, are no longer
recorded in deferral accounts. Proposed Smart Grid/RGEN investments under the
System Service category include programs and expenditures related to:

- 8
- 9 Smart Grid energy storage technologies;
- Smart Grid distribution system operations technologies; and
- RGEN projects to facilitate transfer trip communication between renewable generators
   and the station relays at transformer stations.
- 13 The forecast Smart Grid investments for 2016 to 2020 are provided below in Table 14 5.4.5.18.
- 15

	2015	2016	2017	2018	2019	2020
System Service	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
v. Smart Grid/RGEN - System Related	1,151	1,070	1,070	1,070	1,070	1,070

- 16 17
- 18

#### Table 5.4.5.18: Proposed Smart Grid Expenditures 2015-2020

19

20 Note: The above 2015 Smart Grid/RGEN amounts will be through the OEB-approved Smart Grid Deferral

21 Account 1534. Smart Grid/RGEN investments in 2016-2020 will be included as part of the regular rate

22 base capital accounts in accordance with OEB Filing Requirements Chapter 2.

23

#### 24 d) General Plant

The proposed investments in General Plant projects are focused on a new Customer Information Systems (CIS), Information Technology (IT) and Information Systems, Communication Systems, Buildings/Facilities, Fleet, Tools, Interest Capitalization and Smart Grid – (non-distribution system related). A summary of all the proposed 2015-2020 General Plant expenditures is shown in Table 5.4.5.19 below.

	2015	2016	2017	2018	2019	2020
General Plant	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
i. Customer Service	11,703	3,991	6,816	2,996	2,996	3,103
ii. IT & Info/Communication Systems	5,302	7,560	7,016	4,587	7,244	8,318
iii. Buildings & Emerging Operations	3,696	655	713	779	899	1,208
iv. Fleet	2,274	2,600	2,161	2,386	2,573	2,424
v. Tools	570	467	473	820	709	711
vi. Interest Capitalization	1,000	1,020	1,040	1,061	1,082	1,104
vii. Smart Grid - Other	1,338	1,338	1,338	1,338	1,338	1,338
Total General Plant	25,882	17,631	19,558	13,967	16,841	18,206

2

1

#### Table 5.4.5.19: Summary of General Plant Expenditures 2015-2020

3 4

5

6

7

8

#### i. Customer Service

Proposed investments under this category for 2016 to 2020 are projects designed to maintain, enhance or upgrade critical customer information infrastructure and systems. They include:

- CIS replacement Completion of Phase 1 and Go Live (2015);
- 9 IVR (incoming voice recognition) technology replacement;
- 10 customer centre workforce management;
- 11 fieldworker system changes & equipment replacement;
- customer process and system improvements ;
- 13 customer web portal & mobile applications; and
  - remote disconnect meters & load limiters.
- 14 15 16

The forecast Customer Service expenditures for 2016 to 2020 are provided below in Table 5.4.5.20.

17 18

2015	2016	2017	2018	2019	2020
(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
11,703	3,991	6,816	2,996	2,996	3,103
d Custome	er Servic	<u>e Expen</u>	ditures 2	2015-202	<u>20</u>
n the cus	tomer s	ervice n	roiects (	ran he i	found ir
	(\$ 000) 11,703 Custome	(\$ 000) (\$ 000) 11,703 3,991 Customer Servic	(\$ 000) (\$ 000) (\$ 000) 11,703 3,991 6,816 Customer Service Expen	(\$ 000)         (\$ 000)         (\$ 000)         (\$ 000)         (\$ 000)           11,703         3,991         6,816         2,996           Customer Service Expenditures 2	(\$ 000) (\$ 000) (\$ 000) (\$ 000) (\$ 000)

23 Material Investments section in Appendix A of this DS Plan.

1 ii. IT & Info/Communication Systems 2 This category of investments includes both investments directly initiated by the Information 3 Services Department (IT), and also other investments of Information and Communication 4 Systems projects driven by the business needs of other departments. Since the scopes of 5 both these types of investments are very similar, proposed capital expenditures for the 6 projects and initiatives in this category have also been combined into one budget. 7 8 i) Information Services (IT) 9 Proposed investments under this category for 2016 to 2020 are projects designed to 10 maintain, enhance or upgrade critical information technology infrastructure, systems 11 and applications. They include: 12 client hardware & operating systems; 13 servers & infrastructure; 14 application software; • the main telecom system; 15 16 customer information systems enhancements; and 17 • enterprise resource planning (ERP) enhancements. 18 ii) Information/Communication Systems 19 20 Proposed investments under this category for 2016 to 2020 are projects designed to 21 maintain, enhance or upgrade information and communications systems for improving 22 operational efficiencies within the other business units. They include: 23 Financial and accounting systems database and software upgrades; 24 GIS database and software upgrades and improvements; 25 C55 Asset analytics software for capital program optimization & monitoring; and 26 Work Force Management initiatives. 27 The combined total forecast IT & Information/Communication Systems expenditures for 28 2016 to 2020 are provided below in Table 5.4.5.21. 29 30

		2015	2016	2017	2018	2019	2020
	General Plant	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
1	ii. IT & Info/Communication Systems	5,302	7,560	7,016	4,587	7,244	8,318
2	Table 5.4.5.21: Proposed IT & Ir	1fo/Comr	nunicatio	on Expe	nditures	2015-20	)20
3							
4	Detailed justification information	on IT ו	<sup>–</sup> projec	ts can	be fou	ınd in	the Material
5	Investments section in Appendix	A of this	DS Plan	•			
6							
7	iii. Buildings and Emerging Operations						
8	As indicated in Exhibit G, Tab 2, S	ection 5	.3.3 pag	e 14, th	e major	ity of Po	owerStream's
9	buildings are of recent construction a	and are g	generally	in good	shape.		
10							
11	PowerStream's Vaughan and Marl	kham fa	cilities a	are relat	ively ne	W, SO I	major capital
12	replacement expenditures are not a	nticipate	d within	this DS	Plan. T	he Barri	e (Patterson)
13	operations centre is in relatively	good c	ondition	but so	me cor	nponent	s are being
14	renovated through 2014-2015 to u	pdate th	ne buildi	ng to c	urrent s	tandards	s, rejuvenate
15	aging mechanical systems and to inc	rease s	pace utili	zation a	nd effici	ency.	
16							
17	Based on regular assessments of	building	g conditi	on, it is	appare	ent that	all buildings
18	require various minor investments	to ma	intain ir	n a goo	od state	of rep	air, improve
19	productivity within the work enviro	nment,	accomm	odate g	rowth ir	n the w	orkforce and
20	address identified health and safety	risks.					
21							
22	Expenditures for the maintenance	and c	peration	s of P	owerStr	eam's t	ouildings are
23	increasing year over year, in p	art, du	e to re	quired	externa	l repair	s, structural

improvements required to address shortcomings in existing systems and layouts.

24

1	Proposed expenditure for facilities are based on the following categories and components:
2	
3	Interior (furniture);
4	<ul> <li>Exterior (pavement, fencing, lighting, stores yard);</li> </ul>
5	Mechanical (plumbing);
6	Structural (windows, doors, wall partitions);
7	HVAC (heating & air conditioning);
8	<ul> <li>Equipment (major tools, lifts); and</li> </ul>
9	Other (Emerging Operations).
10	
11	The forecast Buildings and Emerging Operations investments for 2016 to 2020 are
12	provided below in Table 5.4.5.22.
13	
	2015 2016 2017 2018 2010 2020

		2015	2016	2017	2018	2019	2020	1
	General Plant	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	
14	iii. Buildings & Emerging Operations	3,696	655	713	779	899	1,208	
15	Table 5.4.5.22: Proposed Buildings &	& Emergi	ng Opera	tions Ex	penditure	es 2015-2	2020	
16								
17	Detailed justification information o	n facilitie	es projec	cts can	be foun	d in the	Materia	al
18	Investments section in Appendix A o	f this DS	Plan.					
19								
20	iv. Fleet							
21	Proposed investments under this c	ategory	for 2016	to 2020	) are pro	ojects de	signed to	0
22	maintain and/or replace vehicles ne	cessary t	o suppor	t the ope	eration a	nd maint	enance o	of
23	the distribution system. PowerStrea	m manag	ges a flee	et of ove	r 250 he	avy duty	and ligh	it
24	duty vehicles, trailers, and other mot	oile equip	ment.					
25								
26	PowerStream's replacement guidelin	e for flee	t assets	is as follo	ows:			
27	Heavy duty vehicles: Replaced	l when t	he vehic	le reach	es 250,0	000 km,	or 12000	0
28	engine-hours, and shows an u	pward tr	end in u	Inschedu	iled maii	ntenance	costs ir	n
29	previous three years.							

1	• Medium duty vehicles: Replaced when vehicle reaches 200,000 km and shows an									
2	upward trend in uns	scheduled r	maintenan	ce costs in	previous t	hree years	3.			
3	• Cars, utility vehicle	es, passeng	ger vans:	Replaced	when veh	nicle reach	es 200,000	0 km		
4	and shows an upwa	ard trend in	unschedu	led mainte	nance cos	ts in previo	ous three ye	ears		
5	• Pickup trucks: Re	placed whe	en vehicle	reaches 2	275,000 kr	m and sho	ows an up	ward		
6	trend in unschedule	ed maintena	ance costs	in previou	s three yea	ars.				
7										
8	Miscellaneous fleet:									
9	<ul> <li>pole trailers: 20 ye</li> </ul>	ar replacen	nent							
10	• tension machines:	15 year rep	placement							
11	<ul> <li>reel trailers: 15 yea</li> </ul>	ar replacem	ient							
2	<ul> <li>forklifts: 15 year re</li> </ul>	placement								
3	<ul> <li>traffic signals – tecl</li> </ul>	nnical asse	ssment on	condition a	and estima	ated repairs	S.			
4	<ul> <li>loaders - technical</li> </ul>	assessmen	t on condit	ion and es	timated re	pairs.				
15										
6	The forecast Fleet exp	enditures f	or 2016 to	2020 are p	provided be	elow in Tal	ble 5.4.5.23	3.		
7										
		2015	2016	2017	2018	2019	2020			
	General Plant	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)			
8	iv. Fleet	2,274	2,600	2,161	2,386	2,573	2,424			
9	Table 5.	4.5.23: Pro	posed Fle	et Expendi	tures 2015	-2020				
20										
21	Detailed justification ir	nformation f	leet projec	ts can be f	ound in the	e Material	Investment	ts		
22	section in Appendix A	of this DS I	Plan.							

- 23
- 24 *v. Tools*

Projects in this category are for the purchase of tools and equipment required for crews to carry out their day-to-day work, maintenance activities, and testing and diagnostic activities.

28

Expenditures in this category are for purchases of all major Lines tools and equipment that have an individual value greater than \$1000 and with a life expectancy of more than one

1 year. Day-to-day line work requires a variety of specialty tools that allow workers to safely 2 and efficiently construct and maintain the distribution system. Examples of required tools 3 and equipment are: 4 • barriers used in live line operations; 5 hoisting equipment; 6 temporary grounding devices; 7 temporary secondary service jumpers; • live line rubber cover up; 8 9 live line tools, such as switch sticks; 10 tension stringing equipment including replacement ropes, travelers, brackets; ladders, test meters, manhole entry systems & gas detectors. Etc;. 11 12 hydraulic presses and crimpers; 13 various test equipment; 14 • traffic control signs, lights, cones, etc.; 15 equipment for Locating; and • PPE (personal protective equipment). 16 17 18 The forecast Tools expenditures for 2016 to 2020 are provided below in Table 5.4.5.24. 19

	2015	2016	2017	2018	2019	2020
General Plant	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)	(\$ 000)
v. Tools	570	467	473	820	709	711
Table 5.4.5.24: Propo	sed Too	l Expen	ditures 2	015-202	<u>0</u>	
Detailed justification information of	n the to	ools pro	ojects ca	an be fo	ound in	the Mat
Investments section in Appendix A o	f this D					

24 25

26 vi. Interest Capitalization

Interest Capitalization for 2016 to 2020 are IFRS-recognized expenditures to capture
 interest expense on capital spending that is in the "Work-In-Progress" stage before being
 energized or deemed used and useful.

2 Table 5.4.5.25. 3 4 2019 2017 2015 2016 2018 2020 **General Plant** (\$ 000) (\$ 000) (\$ 000) (\$ 000) (\$ 000) (\$ 000) vi. Interest Capitalization 1,000 1,020 1,040 1,061 1,082 1,104 5 6 Table 5.4.5.25: Proposed Interest Capitalization Expenditures 2015-2020 7 8 vii. Smart Grid - Other 9 Proposed projects in this category are related to initiatives to support PowerStream's 10 Smart Grid Implementation Plan as detailed in PowerStream's GEA Plan submitted in EB-11 2012-0161. In accordance with OEB Filing Requirements, Smart Grid expenditures in 12 Year 2016, or after, are no longer recorded in deferral account 1534 13 14 Proposed investments include programs and expenditures unrelated to the distribution 15 system for the purpose of: facilitate electric vehicle connections; 16 · home energy management technologies; and 17 18 data analytics. 19 20 The forecast Smart Grid investments for the 2016 to 2020 Test Years are provided below 21 in Table 5.4.5.26. 2015 2016 2017 2018 2019 2020 **General Plant** (\$000) (\$000) (\$ 000) (\$ 000) (\$ 000) (\$000) vii. Smart Grid - Other 1,338 1,338 1,338 1,338 1,338 1,338 22 23 Table 5.4.5.26: Proposed Smart Grid – Other Expenditures 2015-2020 24 25 Note: Smart Grid investments in 2015 will be through the OEB-approved Smart Grid Deferral Account 26 1534. Smart Grid investments in 2016-2020 will be included as part of the regular rate base capital 27 accounts. 28 29

The forecast Interest Capitalization expenditures for 2016 to 2020 are provided below in

#### 1 Material Investments

- 2 PowerStream has provided all of its material investment templates, which have been designed
- 3 to address Section 5.4.5.2 of the Filing Requirements, attached to this DS Plan as Appendix A.
- 4
- 5 A summary of the projects that exceed the materiality threshold can be found in Exhibit G, Tab
- 6 2, Section 5.4.1, Table 2 to Table 5.

7

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix A: Project Investment Summaries Delivered: February 24, 2015



# Appendix A

# **Project Investment Summaries**

Delivered: February 24, 2015

**Distribution System Plan** 

	Pi	roject Code		Report Start Year	Number of Years	Scale
Power	<b>X</b>	101	1896	2015	6	Dollars
Stream	D	roject Name				
Project Summar				New Commercial Sub	division Development	
Major Category	System Access					
Project Overview 1. Additional Information	Sorvico Torritory		PowerStream S	outh		
	Service Territory					
	Location			South Service Area		
	Scope		due to green fi commercial/in	nderground Commercial/Indus eld development. The OTC pro dustrial units. Estimated cost opment. Depending on the ou %.	ovides the estimated cost for a s are for infrastruture only and	subdivision containing I not including transformers
	Justification			28 of the Electricity Act, distrib distribution system.	utors have an obligation to pro	ovide connection for new
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2015			
	Parent WO#		308137			
	Job Number		C00405			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk M		Not Applicable			
	Comparative Information on E Historical Projects (if any)	Equivalent		asis PowerStream continues to vary year to year based on ma		
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			al/industrial subdivisions requ ution requirements.	ire an economic evaluation to	determine PowerStream's
	1a. Main Driver		•	ts. This is a regulatory require	ment based on the prescribed	economic evaluation
	1b. Priority and Reasons for Pr	iority	Not Applicable			
	1c. Qualitative and Quantitativ Project and Project Alternative		Represents cap	ital contributed for investmen	t in new developments.	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
		+17				
	4. Coordination, Interoperabili	ty	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Priori	ity	PowerStream a	issesses the connection of new	customers on an annual basis	;.
	Factors Relating to Customer P or Input	Preferences		has input into the electrical de e for determining the site plan	-	
	Factors Affecting the Final Cost Project	t of the	The number of	customer connections vary fro	om year to year.	
	How Controlled Costs have bee Minimized	en	selected throug Customer has l	ervice is provided by PowerStre gh a competitive RFP process w been presented with an OTC, th and uses the services of a qual	which provides best costs and c ne Customer always has the op	cost certainty. After the otion to to pursue an
	Identify if Other Planning Obje Met by the Project, if so, which		Not Applicable			
	Options Considered and Summ Analysis	nary of	Not Applicable			
	Results of Final Economic Evalu applicable	uation, if	Final economic	evaluations are done on a sub	division by subdivision basis.	
	System Impacts (Nature, Magn Costs)	nitude and	Not Applicable			

L

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	5		10	1896	2(	015		6	Do	llars
Project Summary I	Report		Project Name		<u>New Com</u>	nmercial Sub	odivision De	velopment		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ (9,969)	\$ 229,226	\$ 954,433	\$ 546,045	\$ 1,000,008	\$ 1,001,908	\$ 1,003,808	\$ 1,005,707	\$ 1,007,607	\$ 1,009,506
	\$1,200,0 \$1,000,0 \$800,0 \$600,0 \$400,0 \$200,0 \$ \$(200,0	000 000 000 - 2011	2012	2013	2014	2015 201	6 2017	2018	2019	2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	101	1911	2015	6	Dollars
		Project Name				
Project Summar	v Report			New Commercial Sub	division Development	
	yncport					
Major Category	System Access					
Project Overview	•					
1. Additional Information	Service Territory		PowerStream N	North		
	Location			North Service Area		
	Scope		due to green fi commercial/ind	nderground Commercial/Indus eld development. The OTC pro dustrial units. Estimated cost tent is \$600,000. Depending c bute 100%.	ovides the estimated cost for a for infrastruture only and not	subdivision containing including transformers for
	Justification			28 of the Electricity Act, distrib distribution system.	utors have an obligation to pr	ovide connection for new
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2015			
	Parent WO#		308138			
3. General Information on the	Job Number	k Managamant	C00425			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risl Comparative Information o			pasis PowerStream continues to	o have new customer connecti	ions. The value and number
	Historical Projects (if any)		of connections	vary year to year based on ma	rket and new construction de	mands.
	Total Capital and OM&A Cos Renewable Energy Generati Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			al/industrial subdivisions requ ution requirements.	ire an economic evaluation to	determine PowerStream's
	1a. Main Driver		methodology.	ts. This is a regulatory require	ment based on the prescribed	economic evaluation
	1b. Priority and Reasons for	·	Not Applicable			
	Project and Project Alternat		Represents cap	ital contributed for investmen	t in new developments.	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperal	bility	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Pri	ority	PowerStream a	assesses the connection of new	r customers on an annual basis	5.
	Factors Relating to Custome or Input	er Preferences		has input into the electrical de e for determining the site plan		
	Factors Affecting the Final C Project	Cost of the	The number of	customer connections vary fro	om year to year.	
	How Controlled Costs have Minimized	been	selected throug Customer has b	ervice is provided by PowerStro gh a competitive RFP process v been presented with an OTC, t and uses the services of a qua	vhich provides best costs and o he Customer always has the op	cost certainty. After the otion to to pursue an
	Identify if Other Planning Ol Met by the Project, if so, wh		Not Applicable			
	Options Considered and Sur Analysis	nmary of	Not Applicable			
	Results of Final Economic Ev applicable	valuation, if	Final economic	evaluations are done on subd	ivision by subdivision basis.	
	System Impacts (Nature, Ma Costs)	agnitude and	Not Applicable			
						Pa

			Project Code		Report Start Y	ear	Number of Years	Scale	
Power Stream	5		10:	1911	20	015	6	Do	llars
Project Summary	Project Summary Report				<u>New Corr</u>	nmercial Sul	odivision Developm	<u>ent</u>	
	2011	2012	2013	2014	2015	2016	2017 201	3 2019	2020
Expenditures Historical/Planned	\$ 3,110	\$ 87,031	\$ 411,217	\$ 703,622	\$ 600,000	\$ 600,000	\$ 600,000 \$ 60	),000 \$ 600,000	\$ 600,000
	\$800,000 \$700,000 \$600,000 \$500,000 \$400,000 \$300,000 \$200,000 \$100,000 \$-	2011	2012	2013	2014 20	15 2016	2017 2018	2019	2020

	F	Project Code		Report Start Year	Number of Years	Scale
Power Stream	5	101	1887	2015	6	Dollars
Sircuit	E F	Project Name				
Project Summar				New Residential Sub	division Development	
Major Category	System Access					
Project Overview	Consider Towitteen		Description	S		
1. Additional Information	Service Territory Location		PowerStream S	South Service Area		
	Scope		Subdivision - U due to green fi residential unit estimated to b to be normal si and serviced re lots x \$3,502.00 subdivision is 5 through transfe contribution ha	nderground Residential Distibuted eld development. The OTC process. Estimated serviced/installed e installed in 2015 are 3100. Natarting from 2013. Average co	ovides the estimated cost for a ed residential lots are as follow ote that the subdivision lot all ost of a serviced lot is \$3,502.0 ly and constructed up to the s stream's average cash contribu- or "Option B" PowerStream pa gization of the residential sub al upstream. There are 1176	subdivision containing vs: Total number of lots location by the city supposed 00. Estimated cost of installed treet line) is as follows: 3100 ution for a residential lys 55% to the developer division. PowerStream hours allocated for the
	Justification			28 of the Electricity Act, distrib	utors have an obligation to pr	ovide connection for new
2. General Project Information (OEB)	Contributed Capital		-	distribution system. Ipital Residential Subdivision		
	Fiscal Year		2015			
	Parent WO#		300757			
	Job Number		C00400			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	-				
	Comparative Information on Historical Projects (if any)	Equivalent		basis PowerStream continues to vary year to year based on ma		
	Total Capital and OM&A Cost Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		New residentia contribution re	Il subdivisions require an econo quirements.	omic evaluation to determine	PowerStream's capital
	1a. Main Driver		Service Reques methodology.	ts. This is a regulatory require	ment based on the prescribed	economic evaluation
	1b. Priority and Reasons for P	riority	Not Applicable			
	1c. Qualitative and Quantitati Project and Project Alternativ		Represents cap	ital contributed for investmen	t in new developments.	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabi	lity	Not Applicable			
	5. Economic Development		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	6. Environmental Benefits Factors Affecting Timing/Prior	rity	Not Applicable PowerStream a	assesses the connection of new	r customers on an annual basis	5.
	Factors Relating to Customer or Input	Preferences		has input into the electrical de e for determining the site plan		
	Factors Affecting the Final Co Project	st of the	The number of	customer connections vary fro	om year to year.	
	How Controlled Costs have be Minimized	een	selected throug Customer has l	ervice is provided by PowerStro gh a competitive RFP process v been presented with an OTC, t and uses the services of a qua	which provides best costs and one customer always has the op	cost certainty. After the ption to to pursue an
	Identify if Other Planning Obj Met by the Project, if so, whic		Not Applicable			
	Options Considered and Sumi Analysis	mary of	Not Applicable			Pg
						' y

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			101	1887	20	)15		6	Do	llars
Droject Summe	n. Donort		Project Name		New Res	idential Sub	division Dev	velopment		
Project Summa	гу керог							velopment		
	applicable System Impa	al Economic Ev cts (Nature, Ma		Final economic Not Applicable		e done on a sub	odivision by sub	odivision basis.		
	Costs) 2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
								A 7045 444		A A
xpenditures Historical/Planned	\$9,000,0	000	\$ 2,173,637	\$ 3,739,864	\$ 5,970,964	\$ 6,548,610	\$ 7,148,346	\$ 7,345,444	\$ 7,547,865	\$ 7,750,2
xpenditures Historical/Planned		000	\$ 2,173,637	\$ 3,739,864	\$ 5,970,964	\$ 6,548,610	\$ 7,148,346	\$ 7,345,444	\$ 7,547,865	

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	5	101	1906	2015	6	Dollars
Siledin		Project Name				
Project Summar				New Residential Sub	division Development	
Major Category	System Access					
Project Overview						
1. Additional Information	Service Territory		PowerStream N			
	Location Scope		Subdivision - U due to green fir residential unit estimated to be 1000. Average lots (infrastrutu \$3.50 million "Option A". Fo time of energiz removal upstre	eld development. The OTC pro- s. Estimated serviced/installe e designed in 2015 are 1300. e cost of a serviced lot is \$3,50 ure only and constructed up to PowerStream's average cash o r "Option B" PowerStream pay ation of the residential subdiv	ution System Developer request ovides the estimated cost for a ed residential lots are as follow Total number of lots estimate 0.00. Estimated cost of instal the street line) is as follows: contribution for a residential su ys 55% to the developer throug ision. PowerStream contributio ocated for the Engineering Adm .85 hours.	subdivision containing vs: Total number of lots d to be installed in 2015 are led and serviced residential 1000 lots x \$3,500.00/lot = ubdivision is 55% up front for gh transfer payment at the on has increased due to the
	Justification			28 of the Electricity Act, distrib distribution system.	utors have an obligation to pro	ovide connection for new
2. General Project Information (OEB)	Contributed Capital		-	pital Residential Subdivision		
	Fiscal Year		2015			
	Parent WO#		305033			
3. General Information on the Project/Activity (OEB)	Job Number Risks to Completion and Risk	Management	C00420 Not Applicable			
	Comparative Information on Historical Projects (if any)	Equivalent			o have new customer connecti arket and new construction der	
	Total Capital and OM&A Cost Renewable Energy Generatio Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		New residentia contribution re		omic evaluation to determine	PowerStream's capital
	1a. Main Driver		Service Reques methodology.	ts. This is a regulatory require	ment based on the prescribed	economic evaluation
	1b. Priority and Reasons for P	Priority	Not Applicable			
	1c. Qualitative and Quantitati Project and Project Alternativ		Represents cap	ital contributed for investmen	t in new developments.	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabi	ility	Not Applicable			
	5. Economic Development 6. Environmental Benefits		Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Prior	rity			v customers on an annual basis	
	Factors Relating to Customer or Input	Preferences			sign of the distribution system is and layout with final approva	
	Factors Affecting the Final Co Project	st of the	The number of	customer connections vary fro	om year to year.	
	How Controlled Costs have be Minimized	een	selected throug Customer has b	gh a competitive RFP process v been presented with an OTC, t	eam and its contractor. Powe which provides best costs and c he Customer always has the op lified contractor for the work t	cost certainty. After the otion to to pursue an
	Identify if Other Planning Obj Met by the Project, if so, whic		Not Applicable			
	Options Considered and Sum Analysis	mary of	Not Applicable			
						Pg

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		101	1906	2015		6		Dollars	
			Project Name							
Project Summary	Report				<u>New Res</u>	idential Sub	division Dev	<u>velopment</u>		
	Results of Fina applicable System Impac Costs)			Final economic		e done on a sub	odivision by sub	division basis.		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
					¢ 4 005 000	¢ 2,094,400	ć 2.244.000	ć 2.444.500	¢ 2 E 97 200	¢ 2767 1
xpenditures Historical/Planned	\$ 153,587	\$ 2,275,398	\$ 1,625,717	\$ 217,038	\$ 1,925,000	\$ 2,084,499	\$ 2,244,000	\$ 2,414,500	\$ 2,587,200	\$ 2,707,1

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	5	101892		2015	6	Dollars
biream		Project Name				
Project Summar			New S	ubdivision Developm	ent - Secondary Service	Lateral
Major Category	System Access					
Project Overview 1. Additional Information	Service Territory	Pow	erStream S	outh		
	Location			outh Service Area		
	Scope	This	expenditur	e pertains to secondary service	ice lateral installation for new	subdivisions for OTC's signed ir
		seco each servi conr the o typio cabl 3300 is ap	ndary under ice cable, sp nection of the customer's cally installe es. The sec D services (3 oproximatel	erground services from the so vork involves trenching and olices at the street line and the secondary service to the unit. There are 2 - types co ed within a subdivision. The ondary service installation to 8/0 - 2970 & 250MCM - 330) y \$500.00 (cost includes: co	v subdivision developments, th ervice tails terminated at the st packfill and supply and installat ermination in the meter base. pad-mounted transformer which f secondary services based on a y are 3/0 and/or 250MCM alum reakdown is as follows: 90% - 3 The total cost to install a 3/0 ntract labour + connection fee	reet line to the meter base for ion of the duct, secondary This work will allow for the ch, in turn provides power to a pre-determined length ninium, 600V rated secondary b/0 and 10% - 250MCM cables. or 250MCM secondary service
	Justification		ices = \$1.65 er section 2		ibutors have an obligation to p	rovide connection for new
2. General Project Information (OEB)	Contributed Capital	build		distribution system.		
	Fiscal Year	2015				
	Parent WO#	3008				
	Job Number	C004				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk					
	Comparative Information on Historical Projects (if any)				to have new customer connect narket and new construction de	
	Total Capital and OM&A Cost Renewable Energy Generatic Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary			l and commercial/industrial capital contribution require	subdivisions require an econon ments.	nic evaluation to determine
	1a. Main Driver		vice Request hodology.	ts. This is a regulatory requi	rement base on the prescribed	economic evaluation
	1b. Priority and Reasons for F	Priority Not	Applicable.			
	1c. Qualitative and Quantitat Project and Project Alternativ		resents cap	ital contributed for investme	ent in new developments.	
	2. Safety	Not	Applicable.			
	3. Cyber-Security, Privacy	Not	Applicable.			
	4. Coordination, Interoperab	ility Not	Applicable.			
	5. Economic Development	Not	Applicable.			
	6. Environmental Benefits	Not	Applicable.			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Prio	rity Pow	erStream a	ssesses the connection of n	w customers on an annual bas	is.
	Factors Relating to Customer or Input				lesign of the distribution system ans and layout with final approv	
	Factors Affecting the Final Co Project	st of the The	number of	customer connections vary	rom year to year.	
	How Controlled Costs have b Minimized	selec Cust	cted throug comer has b	h a competitive RFP process een presented with an OTC	ream and its contractor. Power which provides best costs and the Customer always has the c alified contractor for the work	cost certainty. After the option to to pursue an
	Identify if Other Planning Ob Met by the Project, if so, whi	ectives are Not	Applicable.			

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	-		101	1892	20	)15		6	Dol	lars
			Project Name		S. 1. 11. 1. 1. 1.			<b>.</b>		
Project Summar	y Report			<u>New S</u>	Subdivision	Developmer	nt - Seconda	ary Service	<u>Lateral</u>	
	Analysis Results of Fin applicable	idered and Sun al Economic Ev cts (Nature, Ma	aluation, if	Not Applicable Final economic Not Applicable	c evaluations ar	e done on a sul	odivision by sub	division basis.		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	\$ 1,119,100	\$ 1,380,902	\$ 2,156,481	\$ 2,071,136	\$ 1,503,989	\$ 1,649,281	\$ 1,799,275	\$ 1,850,799	\$ 1,902,270	\$ 1,953,7
	\$2,500,0	000								
	\$2,000,0						-			
	\$1,500,0	000								
	\$1,000,0	000								

	Proj	ect Code		Report Start Year	Number of Years	Scale
Power Stream		1019	914	2015	6	Dollars
Direction	Proj	ect Name				
Project Summar	-		New S	ubdivision Developme	nt - Secondary Service	Lateral
Major Category Project Overview	System Access					
1. Additional Information	Service Territory	F	PowerStream I	North		
	Location	F	PowerStream I	North Service Area		
	Scope				ce lateral installation for new s subdivision developments, the	
		s c t t i i	secondary und each lot. This service cable, s connection of the customer's typically install cables. The se 1000 services ( is approximate	erground services from the se work involves trenching and b plices at the street line and te the secondary service to the p unit. There are 2 - types of ed within a subdivision. They condary service installation br 3/0 - 900 & 250MCM - 100) ly \$485.00 (cost includes: con	rvice tails terminated at the sti ackfill and supply and installati rmination in the meter base. T ad-mounted transformer whic secondary services based on a are 3/0 and/or 250MCM alum eakdown is as follows: 90% - 3, The total cost to install a 3/0 o tract labour + connection fee + al PS contribution in 2015 for N	reet line to the meter base for on of the duct, secondary This work will allow for the h, in turn provides power to pre-determined length inium, 600V rated secondary 70 and 10% - 250MCM cables. r 250MCM secondary service meter+PS inspection) 1000
	Justification	ι	Under section		butors have an obligation to pr	
2. General Project Information (OEB)	Contributed Capital	C	Contributed Ca	ipital 0%		
	Fiscal Year	2	2015			
	Parent WO#	3	305034			
	Job Number	C	C00430			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Man					
	Comparative Information on Equ Historical Projects (if any)				o have new customer connect arket and new construction de	
	Total Capital and OM&A Costs fo Renewable Energy Generation po Projects (if any)		D			
4. Evaluation Criteria (OEB)	Project Summary			I and commercial/industrial s capital contribution requiren	ubdivisions require an econom nents.	ic evaluation to determine
	1a. Main Driver		Service Reques methodology.	ts. This is a regulatory requir	ement base on the prescribed	economic evaluation
	1b. Priority and Reasons for Prior	rity M	Not Applicable			
	1c. Qualitative and Quantitative A Project and Project Alternatives	Analysis of F	Represents cap	ital contributed for investme	nt in new developments.	
	2. Safety	1	Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperability	1	Not Applicable			
	5. Economic Development	1	Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Priority	F	PowerStream a	assesses the connection of ner	v customers on an annual basi	5.
	Factors Relating to Customer Pre or Input				esign of the distribution system ns and layout with final approv	
	Factors Affecting the Final Cost o Project	f the T	The number of	customer connections vary fr	om year to year.	
	How Controlled Costs have been Minimized	s ( 2	selected throu Customer has	gh a competitive RFP process been presented with an OTC,	ream and its contractor. Powe which provides best costs and the Customer always has the o alified contractor for the work t	cost certainty. After the potion to to pursue an
	Identify if Other Planning Objecti Met by the Project, if so, which o	ves are	Not Applicable			
						Pg

			Project Code		Report Start \	'ear	Number of Ye	ars	Scale	
Power Stream	-		101	1914	2	015		6	Dol	llars
			Project Name							
Project Summary	/ Report			<u>New S</u>	Subdivision	<u>Developme</u>	nt - Second	ary Service	<u>Lateral</u>	
	Options Consid Analysis Results of Fina applicable System Impact Costs)	l Economic Ev	aluation, if	Not Applicable Final economic Not Applicable	c evaluations a	re done on a sul	odivision by sub	division basis.		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	\$ 264,641	\$ 335,371	\$ 272,439	\$ 277,081	\$ 485,045	\$ 524,515	\$ 565,540	\$ 607,974	\$ 651,843	\$ 697,
	\$800,000									

	Project C	ode	Report Start Year	Number of Years	Scale
Power Stream		101872	2015	6	Dollars
	Project N	ame			
Project Summar			O/H and U/G Resid	ential Service Upgrades	
•					
Major Category	System Access				
Project Overview					
1. Additional Information	Service Territory	PowerStrea			
	Location		· · · · · · · · · · · · · · · · · · ·	an, Markham, Richmond Hill, Au	
	Scope	Connect (O completed l initiated by PowerStrea total cost of credits are l for undergre transformat equivalent t	TC) residential subdivision. Typi by Line staff. Examples of upg the customer Over head co- m Primary service upgrade the new service minus the over based on the following: 1. Up bound service. 2. Service conne- ion is provided. For services ab ransformation credit will be given	quest for residential service upg cally only a disconnect and a re- rades are as follows: - Fuses to nductor / under ground cable re- i.e. Farm Service The custome orhead credits as outlined in the to 30m of overhead service cab ctions at no charge. 3. For servi- ove 200amps or services requir- ven. The 2015 budget was pre- rvice Designs for 2015 is 793 with	connect is required to be o breaker panel change eplacement initiated by r contribution is based on the Distribution System Code. The le at no charge or equivalent ces up to 200amps, ing their own transformer, an epared in March 2014 and
	Justification			ributors have an obligation to p	rovide connection for buildings
2. General Project Information (OEB)	Contributed Capital		ution system.   Capital Layouts – O/H – U/G R	esidential Service Upgrades	
		<b>••</b> ••			
	Fiscal Year	2015			
	Parent WO#	300798			
	Job Number	C00340			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manage				
	Comparative Information on Equivale Historical Projects (if any)	nt Proposed ex	penditures are based on histo	ical figures of number of conne	ctions and costs.
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 n of			
4. Evaluation Criteria (OEB)	Project Summary	Not Applica	ble.		
· · ·	1a. Main Driver	Service Req			
	1b. Priority and Reasons for Priority	Not Applica			
	1c. Qualitative and Quantitative Analy Project and Project Alternatives				
	2. Safety	Not Applica			
	3. Cyber-Security, Privacy	Not Applica			
	4. Coordination, Interoperability	Not Applica			
	5. Economic Development	Not Applica			
	6. Environmental Benefits	Not Applica			
<ol> <li>Category-Specific Requirements for Each Project/Activity (OEB)</li> </ol>	Factors Affecting Timing/Priority	Not Applica	ble.		
	Factors Relating to Customer Preferer or Input	Customer a		ervice upgrade they require, suc existing overhead service to be	
	Factors Affecting the Final Cost of the Project	Not Applica	ble.		
	How Controlled Costs have been Minimized			stream and its contractor. Pow s which provides best costs and	
	Identify if Other Planning Objectives a Met by the Project, if so, which ones	re Not Applica	ble.		
	Options Considered and Summary of Analysis	Not Applica	ble.		
	Results of Final Economic Evaluation, applicable	if Not Applica	ble.		

			Project Coo	le	Report Start Y	ear	Number of Years	Scale
Power Stream	5			101872	20	015	6	Dollars
Project Summary Report			Project Nar	ne	<u>O/H and I</u>	<u>J/G Reside</u>	ntial Service Upgrades	
	2011	2012	2013	2014	2015	2016	2017 2018	2019 2020
Expenditures Historical/Planned	\$ 524,456	\$ 425,449	\$ 503,5	84 \$ 633,063	\$ 554,580	\$ 587,854	\$ 623,126 \$ 660,514	4 \$ 700,145 \$ 742,154
	\$800,000 \$700,000 \$600,000 \$500,000 \$400,000 \$300,000 \$200,000 \$100,000 \$ -	) ) ) ) )	2012	2013	2014 20			2019 2020

Lacian Another Series Carbon Series Series Series Carbon Series Series Series Carbon Series Series Series Carbon Series S		Project C	ode	Report Start Year	Number of Years	Scale
Project Summary Report         Off and U/G Residential Service Logandes           More Catagory         Space Service Service Service Acad Service	Power Stream	<b>X</b>	101873	2015	6	Dollars
Project Summary Weight         Off and USE Residential Service Logandes           View Colligon         Service Lemmary         ProvedService Month Service Acet[Arma, Alliton, Beelon, Bardon, Thorton, Peersang, Tottan, Isonand Long Millar, Millar, Meelon, Service Logandes and a of an offer to Context (DTC) reductional addition, Tables (DC), and a power for residencial addition (DC), and a power for residencial addition, Tables (DC), and a power for residencial addition (DC), and a power for residencial addition (DC), and a power for residencial addition, Tables (DC), and a power for residencial additing (DC), and a po		Project N	lame			
Depict Decision         Server Tentrory         Reversion         Reversion           1. Additional Information         Server Tentrory         Reversion         Reversion <td< th=""><th>Project Summar</th><th></th><th></th><th>O/H and U/G Resider</th><th>ntial Service Upgrades</th><th></th></td<>	Project Summar			O/H and U/G Resider	ntial Service Upgrades	
Project Overview						
1. Additional Information     Service Transmission     WeenScience Month       2. Additional Information     Signed Science Month     Signed Science Month       2. Canceral Project Information     Mail Science Month     Science Month       3. Serveral Information on the Project Informatio		System Access				
2. Seneral indentition on the indentition of th	1. Additional Information				iston, Beeton, Bradford, Thort	on, Penetang., Tottenham)
2. General Project Information on the Searcher 1007 Searcher 100		Scope	Connect (OTC completed by by the custom Primary servic new service m based on the underground is provided. Fo transformatio	) residential subdivision. Typica Line staff Examples of upgrad er Over head conductor / u e upgrade i.e. Farm Service T inus the overhead credits as ou following: 1. Up to 30m of ove service. 2. Service connections or services above 200amps or se n credit will be given. The 20	Ily only a disconnect and a reco les are as follows: - Fuses to lender ground cable replacemen the customer contribution is ba- utlined in the Distribution Syste- erhead service cable at no char at no charge. 3. For services u- ervices requiring their own trais 15 budget was prepared in Mar	onnect is required to be breaker panel change initiated t initiated by PowerStream. ased on the total cost of the em Code. The credits are ge or equivalent for p to 200amps, transformation hsformer, an equivalent rch 2014 and based on the
A General Information on the Project (I any)       Not Applicable.         Project/Activity (OEB)       Comparative information on Equivalent information i	2. General Project Information (OEB)		Contributed C	apital Layouts – O/H – U/G Res	idential Service Upgrades	
3. Seneral Information on the Project (I any)       Risks to Completion and Risk Manageem       Not Applicable.         Notes and Comparative Information on Equivalent Representations and costs. Historical figures of number of connections and costs. Historical Topics (I any)       Project Comparative Information on Equivalent Representations and costs.         A. Evaluation Criteria (OEB)       Representations for Priority       Not Applicable.         Project Summary       Not Applicable.       Service Requests.         1. Subitive and Quantitative Analysis       Not Applicable.       Not Applicable.         2. Copalitative and Quantitative Analysis       Not Applicable.       Not Applicable.         3. Cordination, Interoperability       Not Applicable.       Not Applicable.         3. Cordination, Interoperability       Not Applicable.       Not Applicable.         5. Category-Specific Requirements for Friend (Service Mergeration Profestion Revelopment       Not Applicable.       Not Applicable.         5. Category-Specific Requirements for Gringer friend Cost of the Project Areting Tribing/Priority       Not Applicable.       Not Applicable.         5. Category-Specific Requirements for Gringer friend Cost of the Project Areting Interoperability       Not Applicable.       Not Applicable.         6. Evoronmental Benefits       Not Applicable.       Not Applicable.       Not Applicable.         6. Evoronmental Benefits       Not Applicable.			2015			
Comparative information on Equivalent Historical Projects (If any)       Proposed expenditures are based on historical figures of number of connections and costs.         4. Evaluation Criteria (OEB)       Test Capital and OM&A Costs for Renewable Energy Generation portion of Projects (If any)       Not Applicable.         4. Evaluation Criteria (OEB)       Projects (If any)       Not Applicable.         10. Project Summary       Not Applicable.         11. Cualitative and Quantitative Analysis of S. Category-Specific Requirements for Each Project Attentives       Not Applicable.         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         3. Cober-Security, Privacy       Not Applicable.         5. Category-Specific Requirements for Each Project Attentiation, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Relating to Customer Preference or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, an has input into the route of the underground service.         8. Category-Specific Requirements for Each Project, How Controlled Costs have been Minimized       Not Applicable.         9. Cottorolled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RPP process which provides best costs and cost cert	3. General Information on the		ment Not Applicable	2.		
4. Evaluation Criteria (OEB)       Renewable Energy Generation portion of Projects (if may)       Not Applicable.         4. Evaluation Criteria (OEB)       Project Summary       Not Applicable.         1b. Priority and Reasons for Priority       Not Applicable.         2. Cualitative and Quantitative Analysis       Not Applicable.         2. Sofety       Not Applicable.         3. Coordination, Interoperability       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Froirity       Rectors Affecting Timing/Priority         5. Category-Specific Requirements for Priority       Not Applicable.         6. Environmental Benefits       Not Applicable.         7. Category-Specific Requirements for Froirity.       Not Applicable.         8. Coordination, Interoperability       Not Applicable.         9. Extors Affecting Timing/Priority       Not Applicable.         9. Extors Affecting Timing/Priority       Not Applicable.         9. Factors Affecting Timing/Priority       Not Applicable.         9. Factors Affecting Timing/Priority       Not Applicable.         9. Project       Not Applicable.         9. Project       Not Applicable.         9. Project       Not Applicable.         9. Project       Not Applicable. <t< td=""><td>Project/Activity (OEB)</td><td></td><td>ent Proposed expo</td><td>enditures are based on historic</td><td>al figures of number of connec</td><td>tions and costs.</td></t<>	Project/Activity (OEB)		ent Proposed expo	enditures are based on historic	al figures of number of connec	tions and costs.
4. Evaluation Criteria (OEB)       Project Summary       Not Applicable.         1. Main Driver       Service Requests.         1. D. Priority and Reasons for Priority       Not Applicable.         1. Cualitative and Quantitative Applicable.       Project Alternatives         2. Safety       Not Applicable.         3. Cyber-Security, Privary       Not Applicable.         5. Condenic Development       Not Applicable.         5. Economic Development       Not Applicable.         6. Environmental Beenfis       Not Applicable.         Factors Affecting the Final Cost of the service upgrade they require, such as 200A or 400A. The ansign over head service.         Priore       Not Applicable.         How Controlled Costs have been Minimized       Soutement Service Iprovided by PowerStream and its contractor. PowerStreams's ontertations.         Priore       Options Constance Favioaution, singuit the duvenoup access which provides best costs and cot		Renewable Energy Generation portion				
1b. Priority and Reasons for Priority       Not Applicable.         1c. Qualitative and Quantitative Analysis       Not Applicable.         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Ecteonomic Development       Not Applicable.         6. Environmental Benefits       Not Applicable.         7. Stategory-Specific Requirements for Eactor Affecting Timing/Priority       Not Applicable.         7. Stategory-Specific Requirements for Pactors Affecting Timing/Priority       Not Applicable.         8. Factors Affecting Timing/Priority       Not Applicable.         9. rout work and the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and as input into the route of the underground service.         8. Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Not Applicable.         Verty thy Project, if so, which ones       Not Applicable.         Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable       Not Applicable.         System Impacts (Mature, Magnitude and Specificable       Not Applicable.	4. Evaluation Criteria (OEB)		Not Applicable	2.		
In Constitution and Quantitative Analysis of Not Applicable.         Project and Project Alternatives         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements or Each Project/Activity (OEB)       Not Applicable.         5. Category-Specific Requirements or Each Project/Activity (OEB)       Factors Affecting Timing/Priority       Not Applicable.         Factors Affecting Timing/Priority       Not Applicable.       Not Applicable.         Factors Affecting the Final Cost of the Project       Not Applicable.       Not Applicable.         How Controlled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         Identify if Other Planning Objectives are Not Applicable.       Not Applicable.         Options Considered and Summary of Analysis       Not Applicable. </td <td></td> <td>1a. Main Driver</td> <td>Service Reque</td> <td>sts.</td> <td></td> <td></td>		1a. Main Driver	Service Reque	sts.		
Project and Project Alternatives         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Earbier Project/Activity (OEB)       Not Applicable.         5. Category-Specific Requirements for Input       Not Applicable.         7. Safety       Not Applicable.         8. Coordination, Interoperability       Not Applicable.         9. Consolid Development       Not Applicable.         9. Consolid Development       Not Applicable.         9. Controlled Costs Affecting Timing/Priority       Not Applicable.         9. Controlled Costs Relating to Customer Preferences       The Customer determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         9. Factors Affecting the Final Cost of the Project       Not Applicable.         Project       How Controlled Costs have been       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         10. Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable.       Not Applicable.         9. System Impacts (Nature, Magnitude and       Not Applicable.		1b. Priority and Reasons for Priority	Not Applicable	2.		
3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not Applicable.         6. Environmental Benefits       Not Applicable.         Factors Relating to Customer Preferences or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Not Applicable.         Identify if Other Planning Objectives are Met by the Project, if so, which ones       Not Applicable.         Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable       Not Applicable.         System Impacts (Nature, Magnitude and       Not Applicable.			rsis of Not Applicable	2.		
4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Relating to Customer Preferences or Input       Not Applicable.         Factors Relating to Customer Preferences or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable System Impacts (Nature, Magnitude and Not Applicable.       Not Applicable.         Not Applicable.       Not Applicable.		2. Safety	Not Applicable	2.		
S. Economic Development       Not Applicable.         S. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Affecting Timing/Priority       Not Applicable.         Factors Relating to Customer Preferences or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable       Not Applicable.         System Impacts (Nature, Magnitude and System Impacts (Nature,		3. Cyber-Security, Privacy	Not Applicable	2.		
6. Environmental Benefits       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Affecting Timing/Priority       Not Applicable.         Factors Relating to Customer Preferences or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         Identify if Other Planning Objectives are Met by the Project, if so, which ones       Not Applicable.         Options Considered and Summary of Analysis       Not Applicable.         Results of Final Economic Evaluation, if applicable System Impacts (Nature, Magnitude and System Impacts (Nature, Magnitude and       Not Applicable.		4. Coordination, Interoperability	Not Applicable	2.		
5. Category-Specific Requirements for Eactors Affecting Timing/Priority       Not Applicable.         Factors Relating to Customer Preferences or Input       The Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.         Factors Affecting the Final Cost of the Project       Not Applicable.         How Controlled Costs have been Minimized       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.         Identify if Other Planning Objectives are Met by the Project, if so, which ones       Not Applicable.         Options Considered and Summary of Analysis Results of Final Economic Evaluation, if applicable.       Not Applicable.         System Impacts (Nature, Magnitude and Not Applicable.       Not Applicable.		5. Economic Development	Not Applicable	2.		
Factors Relating to Customer Preferences or InputThe Customer determines the size of the service upgrade they require, such as 200A or 400A. The Customer also determines if they want an existing overhead service to be changed to underground, and has input into the route of the underground service.Factors Affecting the Final Cost of the ProjectNot Applicable.How Controlled Costs have been MinimizedConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.Identify if Other Planning Objectives are Met by the Project, if so, which onesNot Applicable.Options Considered and Summary of AnalysisNot Applicable.Results of Final Economic Evaluation, if applicableNot Applicable.System Impacts (Nature, Magnitude and Not Applicable.Not Applicable.	5. Category-Specific Requirements for					
Factors Affecting the Final Cost of the ProjectNot Applicable.How Controlled Costs have been MinimizedConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.Identify if Other Planning Objectives are Met by the Project, if so, which onesNot Applicable.Options Considered and Summary of AnalysisNot Applicable.Results of Final Economic Evaluation, if applicableNot Applicable.System Impacts (Nature, Magnitude and Not Applicable.Not Applicable.			Customer also	determines if they want an ex	isting overhead service to be c	
How Controlled Costs have been MinimizedConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was selected through a competitive RFP process which provides best costs and cost certainty.Identify if Other Planning Objectives are Met by the Project, if so, which onesNot Applicable.Options Considered and Summary of AnalysisNot Applicable.Results of Final Economic Evaluation, if applicableNot Applicable.System Impacts (Nature, Magnitude and System Impacts (Nature, Magnitude and System Impacts (Nature, Magnitude and System Impacts (Nature, Magnitude and System Impacts (Nature, Magnitude and Summary Stream)Not Applicable.					service.	
Met by the Project, if so, which ones Options Considered and Summary of Analysis Results of Final Economic Evaluation, if applicable System Impacts (Nature, Magnitude and Not Applicable.		How Controlled Costs have been				
Analysis Results of Final Economic Evaluation, if Not Applicable. applicable System Impacts (Nature, Magnitude and Not Applicable.			re Not Applicable	2.		
applicable System Impacts (Nature, Magnitude and Not Applicable.			Not Applicable	2.		
			if Not Applicable	2.		
		System Impacts (Nature, Magnitude a Costs)	nd Not Applicable	2.		Pg

			Pro	ject Code			Rep	oort Start Ye	ear		Nu	mber of Yea	ars		Scale	5		
Power Stream	5			101873			2015		6			Dollars						
Project Summary Report			Pro	ject Name			<u>0</u>	)/H and L	J/G	Resider	ntia	l Service	e Up	ogrades				
	2011	2012		2013		2014		2015		2016		2017		2018		2019		2020
Expenditures Historical/Planned	\$ 376,288	\$ 305,203	\$	258,596	\$	292,829	\$	374,341	\$	396,802	\$	420,611	\$	445,846	\$	472,597	\$	500,955
	\$600,000																	
	\$500,000																	
	\$400,000																	
	\$300,000						_											
	\$200,000																	
	\$100,000														-			
	\$-	2011		2012	202	13 2	014	201	.5	2016		2017	1	2018	20:	19	2020	

Project Summary Major Category Project Overview 1. Additional Information	Project Name	PowerStream I PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Varie Penetanguishe	North North Service Territory y projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Pol		Dollars
Major Category Project Overview	System Access Service Territory Location	PowerStream I PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Varie Penetanguishe	North North Service Territory y projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Pol	on of PS's plant. Estimated bas	
Major Category Project Overview	System Access Service Territory Location	PowerStream I PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Varie Penetanguishe	North North Service Territory y projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Pol	on of PS's plant. Estimated bas	
Major Category Project Overview	System Access Service Territory Location	PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	North North Service Territory y projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Pol	on of PS's plant. Estimated bas	
Project Overview	Service Territory Location	PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	North Service Territory projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Polo		
-	Location	PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	North Service Territory projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Polo		
1. Additional Information	Location	PowerStream I Road authority Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	North Service Territory projects that require relocatic ey Creek Floodway U/G potent p St Eccles to Toronto St. Polo		
		Road authority Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	projects that require relocation ey Creek Floodway U/G potent p St Eccles to Toronto St. Pole		
	Scope	Barrie: Whisk Barrie: Dunlo Bradford: Vario Penetanguishe	ey Creek Floodway U/G potent p St Eccles to Toronto St. Pol		
		Barrie: Dunlo Bradford: Vario Penetanguishe	p St Eccles to Toronto St. Pol		ed on historical Data.
		Penetanguishe	D		
		-	ous Road Improvements		
			ne: Harriett St - Jeffrey St to E		
			:h: Dayfoot - Prospect to Main rious road improvement project		
			pital estimated at 33% of the g		ical cost estimates
		The Cit less of	lead at the little and the Ba		
	Justification	accomodate ro	local Municipalities requires Po ad works	owerstream to relocate the dis	tribution system to
2. General Project Information (OEB)	Contributed Capital		apital Road Authority		
, , , ,	·				
	Fiscal Year	2015			
	Parent WO#				
	Job Number	C00230			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Management	-	I schedule of the road projects ne Municipalities.	is non-controllable and based	on the road projects being
	Comparative Information on Equivalent		spend on PS North Road Autho	rity projects is \$2.0M gross_\$0	6M contributed and \$1.4M
	Historical Projects (if any)	net.		, , , , , , , , , , , , , , , , , , ,	
	Total Capital and OM&A Costs for	0			
	Renewable Energy Generation portion of Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary	Service Reques	sts. The City's and local Munici	palities requires PowerStream	to relocate the distribution
		system to acco	modate road works.		
	1a. Main Driver		are non-controllable and are a	requirement of the Public Ser	vice Works on Highways Act
	1b. Priority and Reasons for Priority	R.S.O. 1990, Cl	are non-controllable and are a	requirement of the Public Se	nvice Works on Highways Act
	10. Fridity and Reasons for Fridity	R.S.O. 1990, Cl		requirement of the Fubic Ser	vice works on highways Act
	1c. Qualitative and Quantitative Analysis o	f These projects	are non-controllable and the s	cope is defined and determine	ed by the limits and amount of
	Project and Project Alternatives	road work / ro	ad widening being done by the	Municipality.	
	2. Safety	The relocation	of the distribution system nee	ds to be done in advance of th	e road work. PS Crews cannot
			the same time and space as the		
	3. Cyber-Security, Privacy	Not Applicable			
	4. Coordination, Interoperability	Not Applicable			
	5. Economic Development	Not Applicable			
	6. Environmental Benefits	Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Priority	advanced or de	timing of the projects are drive eferred within a calendar year ures, economic development, to	based on various constraints s	
	Factors Relating to Customer Preferences		efined and determined by the I		k / road widening being done
	or Input	by the Municip			
	Factors Affecting the Final Cost of the Project	The scope is de by the Municip	efined and determined by the l pality.	imits and amount of road wor	k / road widening being done
	How Controlled Costs have been		ervice is provided by PowerStre	eam and its contractor. Powe	rStream's contractor was
	Minimized		gh a competitive RFP process v		
	Identify if Other Planning Objectives are	Not Applicable			
	Met by the Project, if so, which ones				
	Options Considered and Summary of	Not Applicable			
	Analysis				
	Results of Final Economic Evaluation, if	Not Applicable			
	applicable				Pg

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Stream	-		101	.764	2015		6		Dollars	
			Project Name							
Project Summary				Road A	Authority Ex	penditure P	<u>S North</u>			
	System Impact Costs)	s (Nature, Ma		These projects road work / ro				l and determine	ed by the limits	and amount
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ 459,509 \$	\$ 757,793	\$ 171,112	\$ 2,939,959	\$ 1,251,353	\$ 1,565,594	\$ 1,499,841	\$ 1,556,975	\$ 1,616,522	\$ 1,682,54
	\$3,500,00	0								

Instrument       Instrument       Instrument       Instrument       Instrument       Instrument         1 <th></th> <th>Proj</th> <th>ject Code</th> <th></th> <th>Report Start Year</th> <th>Number of Years</th> <th>Scale</th>		Proj	ject Code		Report Start Year	Number of Years	Scale
Project Summary Leport         Read Authority Expenditure PS South           Status Crasport         Spectra Acces           Trobert Device         Non-Status Crasport           Status Crasport         Search Territory           Search Territory         Non-Status Crasport           Search Territory <td< th=""><th>Power</th><th>5</th><th>1017</th><th>762</th><th>2015</th><th>6</th><th>Dollars</th></td<>	Power	5	1017	762	2015	6	Dollars
Project Summary Leport         Read Authority Expenditure PS South           Status Crasport         Spectra Acces           Trobert Device         Non-Status Crasport           Status Crasport         Search Territory           Search Territory         Non-Status Crasport           Search Territory <td< th=""><th>Sirean</th><th>Proj</th><th>iect Name</th><th></th><th></th><th></th><th></th></td<>	Sirean	Proj	iect Name				
Project Devices         ProverSide and Subtransition         Service Territory Location         ProverSide and Subtl Service Territory ProverSide and Subtl Service Territory ProverSide and Subtl Service Territory           Support         Support         VOIR SEGMONT THE Ansates and Evaluation Territory ProverSide and Subtl Service Territory ProverSide and Subtless ProverSide and Subsless ProverSide and Subtless ProverSide and Subtle	Project Summar	,			Road Authority Exp	penditure PS South	
Project Devices         ProverSide and Subtransition         Service Territory Location         ProverSide and Subtl Service Territory ProverSide and Subtl Service Territory ProverSide and Subtl Service Territory           Support         Support         VOIR SEGMONT THE Ansates and Evaluation Territory ProverSide and Subtl Service Territory ProverSide and Subtless ProverSide and Subsless ProverSide and Subtless ProverSide and Subtle	Major Category	System Access					
1. Additional information       Spring Promy (Control Control Contro Control Control Contro Control Control Control Control Contro Con							
Steps         Wite EFG0101101 Approximate Lengther Intervention, Existing Control Wite Steps Intervention, Steps Intervententervention, Steps Intervention, Steps Intervention		Service Territory	F	PowerStream S	South		
4. Evaluation Criteria (DEB)     Number     Contributed Capital       5. Category-Specific Requirements for Restormance of the road projects in an obscit on the value of the road projects in an obscit on the value of the			)   	YORK REGION : Major Mack to Langstaff Road Markham No a YRRT Y2.2 Yon 400 and Go Tra AURORA Blue Woodsend Cre RICHMOND HII	19th Avenue at Leslie Street In Hwy 48, Markham, King Road from Dufferin St to Keele St, V pparent conflicts, St. John's Si ge St Major Mackenzie Dr to tocks to Yonge Highway 7, Vaug grass Drive Bluegrass Drive, Au scent, Aurora, L Portage Avenue from Bathu	I from Yonge Street to Bond C Yaughan, Major Mackenzie fro deRoad from Bayview Ave to I 19th Ave, Richmond Hill, H2 han, Irora, Skyview Lane, Aurora, rst east, Richmond Hill, Madi	rescent King, Richmond Hill, m Donald Cousins to 9th Line, Leslie St, Aurora, HWY 7 - Pine Valley to Hwy Steeplechase Avenue, Aurora, son Avenue from Bathurst
2. General Project Information (OE) 2. Gontributed Capital Contributed Capital Road Authonity 2. General Information on the Project Activity (OE) 3. General Information on the Project Activity (OE) 4. Evaluation Criteria (OEB) 4. Evaluation Criteria (OEB) 4. Evaluation Criteria (OEB) 5. Conception Criteria (Criteria (OEB) 5. Concepti		lutification	S	St, Richmond F MARKHAM, M	iill, iller Avenue from Birchmont to	o Kennedy, Markham	
Parent WO#         COCOD           3. General Information on the Project/Activity (OEB)         Risks to Completion and Risk Management Risks to Completion and Risk Management Project/Activity (OEB)         The timing and schedule of the road projects is non-controllable and base on SSM gross, \$1.5M contributed, and S3.5M net.           4. Evaluation Criteria (OEB)         Project S(if any)         Project S(if any)         Projects (if any)           4. Evaluation Criteria (OEB)         Project S(if any)         The Region's and local Municipalities requires PowerStream to relocate the distribution system to accompate road works.           1. Main Driver         The Region's and local Municipalities requires PowerStream to relocate the distribution system to accompate road works.           1. Main Driver         These projects are non-controllable and are a requirement of the Public Service Works on Streiget and Project Alternatives           1. Coulitative and Quantitative Analysis of Project Alternatives         The scope is defined and determined by the limits and amount of road work. PS Crews cannet active Work (road widening being done Project Alternatives)           2. Safety         The relocation of the distribution system needs to be done in advance of the road wroic Projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on policial prosinces, economic devinpent, trafic flow, etc.           5. Cotegonty-Specific Requirements for Factors Affecting Timing/Priority E	2. General Project Information (OEB)		ä	accomodate ro	ad works.		
Job Number     C00200       3. General Information on the Project/Activity (OEB)     Risks to Completion and Risk Manageme in the Municipalities.     The timing and schedule of the road projects is non-controllable and base on the road projects being advanced by the Municipalities.       Comparative Information on Equivalent Historical Projects (if any)     Historical Projects (if any)     The Road Authority budget for the next few years has been increased use to increased road widenings due to by York Region's rapid bus transit projects and increased road projects by York Region.       4. Evaluation Criteria (OEB)     Total Capital and OM&A Costs for Projects (if any)     0       4. Evaluation Criteria (OEB)     Project Summary     The Region's and local Municipalities requires Power/Stream to relocate the distribution system to accomodate road works.       1.0. Main Driver     Section Region's and local Municipalities requires Power/Stream to relocate the distribution system to accomodate road works.       1.0. Main Driver     The section Region's and local Municipalities requires Power/Stream to relocate the distribution system react and work.       1.0. Main Driver     The section Region's and local Municipalities.       1.0. So 1990, CHAFTER P.49     Localitative and Quantitative Analysis of The scope is defined and determined by the limits and amount of road work. Pro 3 Crews came or safely work in the same time and space as the Road Crews.       2. Safety     The relocation of the distribution system needs to be done in advance of the road work. PS Grews came or safely work in the same time and space as the Road Crews.       3. Coheromental Benefit		Fiscal Year	2	2015			
3. General Information on the Project/Activity (CEB)       Risks to Completion and Risk Managemen advanced by the Municipalities.       The timing and schedule of the road projects is non-controllable and based on the road projects bing advanced by the Municipalities.         9. Comparative Information on Equivalent Historical Projects (if any)       The Road Authority budget for the next few years has been increased due to increased road widenings due to by York Region's and local Municipalities requires PowerStream to relocate the distribution system to accompdate road works.         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       The Region's and local Municipalities requires PowerStream to relocate the distribution system to accompdate road works.         1a. Main Driver       The Region's and local Municipalities requires PowerStream to relocate the distribution system to accompdate road works.         1b. Priority and Reasons for Priority       These projects are non-controllable and are a requirement of the Public Service Works on Highways Act R.S.O. 1990. CHAFTER P.49         2. Capitalative and Quantitative Analysis of Project and Project Alternatives       The relocation of the distribution system needs to be done in advance of the road work / road work. PS Crews canno safely work in the same time and space as the Road Crews.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Extors Relating to Customer Preference or Input       The scope and timing of the projects are driven by the Municipalities. Planned ro		Parent WO#					
Project/Activity (OEB)       advanced by the Municipalities.         Project/Activity (OEB)       Comparative Information on Equivalent Historical Projects (if any)       Historical y in PS South Territory, the Road Authority spend has been \$5M gross, \$1.5M contributed, and \$3.5M net.         A: Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         4: Evaluation Criteria (OEB)       Project Summary       The Region's and local Municipalities requires PowerStream to relocate the distribution system to accomodate road works.         1a: Main Driver       Service Requests. These projects are non-controllable and are a requirement of the Public Service Works on Highways Act RS.0. 1990, CHAPTER P.49         1b: Priority and Reasons for Priority       These projects are non-controllable and are a requirement of the Public Service Works on Highways Act RS.0. 1990, CHAPTER P.49         1c: Qualitative and Quanitative Analysis       The relocation of the distribution system needs to be done in advance of the road work. PS Crews cannot safely work in the same time and space as the Road Crews.         3: Cyber-Security, Privacy       Not Applicable.         4: Evaluation (DEB)       Economic Development         6: Environmental Benefits       Not Applicable.         5: Category-Specific Requirements for Each Project/Activity (OEB)       Factors Relating to Customer Preferences The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a cleandar year based on van		Job Number	(	C00200			
Historical Projects (if any)       \$3.5M net.         The Road Authority budget for the next few years has been increased road widenings due to by York Region's rapid bus transit projects and increased road projects by York Region.         4. Evaluation Criteria (DEB)       Project Summary       The Region's and local Municipalities requires PowerStream to relocate the distribution system to accomodate road works.         1a. Main Driver       Service Requests. These projects are non-controllable and are a requirement of the Public Service Works on Highways Act R.S.O. 1990, CHAPTER P.49         1b. Priority and Reasons for Priority       These projects are non-controllable and are a requirement of the Public Service Works on Highways Act R.S.O. 1990, CHAPTER P.49         1c. Qualitative and Quantitative Analysis of Project and Project Alternatives       The relocation of the distribution system needs to be done in advance of the road work. PS Crews cannor safely work in the same time and space as the Road Crews.         5. Category Specific Requirements for Each Project/Activity (DEB)       Factors Relating to Customer Preferences or input         6. Environmental Benefits       Not Applicable.         5. Category Specific Requirements for Factors Relating to Customer Preferences or input       The scope is additermined of the multipalities. Planned road projects may be advanced or deference within a calendar year based on various constraints such as budget, or based on political pressures, economic development, trafic flow, etc.         5. Category Specific Requirements for Factors Relating to Customer Preferences or input       The scope and timing of the proje		Risks to Completion and Risk Ma		-		is non-controllable and based	on the road projects being
4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         4. Evaluation Criteria (OEB)       Project Summary       The Region's and local Municipalities requires PowerStream to relocate the distribution system to accomodate road works.         1a. Main Driver       Service Requests. These projects are non-controllable and are a requirement of the Public Service Works on Highways Act R.S.O. 1990, CHAPTER P.49         1b. Priority and Reasons for Priority       The service is defined and determined by the limits and amount of road work / road widening being done broject and Project Alternatives         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Affecting Timing/Priority       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based mixed on various constraints such as budget, or based on policital pressures, economic development, traffic flow, etc.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Affecting Timing/Priority       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based mixed on various constraints such as budget, or based on policial pressures, economic development, traffic flow, etc.         5. Category-Specific Requirements f					PS South Territory, the Road Au	រthority spend has been \$5M ខ្	gross, \$1.5M contributed, and
Renewable Energy Generation portion of Projects (if any)Renewable Energy Generation portion of Projects (if any)4. Evaluation Criteria (DEB)Project SummaryThe Region's and local Municipalities requires PowerStream to relocate the distribution system to accomodate road works.1a. Main DriverService Requests. These projects are non-controllable and are a requirement of the Public Service Works on Highways Act R.S.O. 1990, CHAPTER P.491b. Priority and Reasons for PriorityRescope is defined and determined by the limits and amount of road work / road widening being done project and Project Alternatives2. Cualitative and Quantitative Analysis of Project AlternativesThe relocation of the distribution system needs to be done in advance of the road work. PS Crews cannot safey work in the same time and space as the Road Crews.3. Cyber-Security, PrivacyNot Applicable.4. Coordination, InteroperabilityNot Applicable.5. Category-Specific Requirements for Each Project/Activity (DEB)Factors Relating to Customer Preferem and acced or deferred within a calendar year based on various constraints such as budget, or based on policial pressures, economic development, traffic flow, etc.5. Category-Specific Requirements for ProjectFactors Relating to Customer Preferem acced or deferred within a calendar year based on various constraints such as budget, or based on policial pressures, economic development, traffic flow, etc.5. Category-Specific Requirements for ProjectThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on policial pressures, economic developm							-
S. Category-Specific Requirements for       S. Coordination, Interoperability       Not Applicable.         S. Category-Specific Requirements for       Factors Affecting Timing/Priority       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Affecting the Final Cost of the Project soft based on political pressures, economic development, traffic flow, etc.       The scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.		Renewable Energy Generation po		D			
<ul> <li>n Highways Act R.S.O. 1990, CHAPTER P.49</li> <li>1b. Priority and Reasons for Priority</li> <li>1c. Qualitative and Quantitative Analysis of</li> <li>1c. Qualitative and Quantitative Analysis of</li> <li>1c. Qualitative and Project Alternatives</li> <li>2. Safety</li> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> <li>Not Applicable.</li> <li>4. Coordination, Interoperability</li> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> <li>Not Applicable.</li> <li>5. Category-Specific Requirements for</li> <li>Factors Affecting Timing/Priority</li> <li>Factors Affecting the Final Cost of the</li> <li>project and Projects are final Cost of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.</li> <li>Factors Relating to Customer Preferences or Input.</li> <li>Factors Affecting the Final Cost of the Final Cost of the spoiled and determined by the limits and amount of road work / road widening being done political pressures, economic development, traffic flow, etc.</li> <li>Factors Affecting the Final Cost of the spoiled and determined by the Imits and amount of road work / road widening being done political pressures, economic development, traffic flow, etc.</li> <li>Factors Affecting the Final Cost of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.</li> <li>Factors Relating to Customer Preferences or Input.</li> <li>Factors Affecting the Final Cost of the project are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendary war based on various constraints such as budget, or based o</li></ul>	4. Evaluation Criteria (OEB)	Project Summary		•		PowerStream to relocate the	distribution system to
R.S.O. 1990, CHAPTER P.49         1c. Qualitative and Quantitative Analysis of Project and Project Alternatives       The scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.         2. Safety       The relocation of the distribution system needs to be done in advance of the road work. PS Crews cannon safely work in the same time and space as the Road Crews.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Factors Affecting Timing/Priority         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Affecting the Final Cost of the Project		1a. Main Driver				trollable and are a requireme	nt of the Public Service Works
Project and Project Alternatives       by the Municipality.         2. Safety       The relocation of the distribution system needs to be done in advance of the road work. PS Crews cannom safely work in the same time and space as the Road Crews.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Eactors Affecting Timing/Priority       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Affecting the Final Cost of the Project       The scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.         How Controlled Costs have been       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was <td></td> <td>1b. Priority and Reasons for Prior</td> <td></td> <td></td> <td></td> <td>requirement of the Public Ser</td> <td>rvice Works on Highways Act</td>		1b. Priority and Reasons for Prior				requirement of the Public Ser	rvice Works on Highways Act
S. Cyber-Security, PrivacyNot Applicable.4. Coordination, InteroperabilityNot Applicable.5. Conomic DevelopmentNot Applicable.6. Environmental BenefitsNot Applicable.5. Category-Specific Requirements forFactors Affecting Timing/PriorityFactors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was						imits and amount of road wor	k / road widening being done
4. Coordination, InteroperabilityNot Applicable.5. Economic DevelopmentNot Applicable.6. Environmental BenefitsNot Applicable.5. Category-Specific Requirements for Each Project/Activity (OEB)Factors Affecting Timing/PriorityThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was		2. Safety			•		e road work. PS Crews cannot
5. Economic DevelopmentNot Applicable.5. Category-Specific Requirements for Each Project/Activity (OEB)Factors Affecting Timing/PriorityThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was		3. Cyber-Security, Privacy	1	Not Applicable			
6. Environmental BenefitsNot Applicable.5. Category-Specific Requirements for Each Project/Activity (OEB)Factors Affecting Timing/PriorityThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was		4. Coordination, Interoperability					
5. Category-Specific Requirements for Eactors Affecting Timing/Priority       Factors Affecting Timing/Priority       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Relating to Customer Preferences or Input       The scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.         Factors Affecting the Final Cost of the Project       The scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.         How Controlled Costs have been       Construction service is provided by PowerStream and its contractor. PowerStream's contractor was							
Each Project/Activity (OEB)advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Relating to Customer Preferences or InputThe scope and timing of the projects are driven by the Municipalities. Planned road projects may be advanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was						and the second second second	
or Inputadvanced or deferred within a calendar year based on various constraints such as budget, or based on political pressures, economic development, traffic flow, etc.Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was		Factors Affecting Timing/Priority	ā	advanced or de	eferred within a calendar year	based on various constraints s	
Factors Affecting the Final Cost of the ProjectThe scope is defined and determined by the limits and amount of road work / road widening being done by the Municipality.How Controlled Costs have beenConstruction service is provided by PowerStream and its contractor. PowerStream's contractor was			ā	advanced or de	eferred within a calendar year	based on various constraints s	
			of the T	The scope is de	fined and determined by the l		k / road widening being done

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	5		10	1762	20	015		6	Do	llars
			Project Name							
Project Summary	Report				Road A	<u>Authority Ex</u>	penditure P	<u>S South</u>		
		ner Planning O roject, if so, wl		Not Applicable						
	Analysis	idered and Su		Not Applicable						
	applicable	al Economic E		Not Applicable						
	System Impa Costs)	cts (Nature, M	agnitude and	The scope is d by the Municip		ermined by the	limits and amou	int of road wor	k / road wideni	ng being do
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	\$ 7,077,271	\$ 2,055,042	\$ 2,342,483	\$ 10,956,175	\$ 5,007,538	\$ 8,136,379	\$ 7,179,017	\$ 6,799,693	\$ 4,102,094	\$ 4,539,
	\$12,00	0,000								
	\$10,00	0,000								
	\$8,00	0,000				1		1		
	\$6,00	0,000								
	\$4,00	0,000								
	\$2.00	0,000		·····						
	\$2,00									
	<i>\$2,00</i>	\$-	11 2012	2013	2014	2015 2	016 2017	7 2018	2019	2020


1	F	Project Code		Report Start Year	Number of Years	Scale
Power Stream		103	637	2015	6	Dollars
Sircum	F	Project Name				
Project Summary	Report			GS>50 MIST Meter P	rogram Implementation	
Major Category	System Access					
Project Overview	System Access					
1. Additional Information	Service Territory Location		The General Se	•	50) meters are spread-out throndos, plazas and other comm	• ,
	Scope		to access their meter which is mechanical me implement a co customers to a available for do analyse the dat outside of our setup the head system. Deploy have all custom	data in 15 minute or hourly in manually read once a month. ters within our system with m ommunication system to bring ccess their energy data in inte ownload in the Green Button f ca or to easily compare a facili service territory. In the curren -end system and build the cus ment of the meters will be ph hers moved over by August 21	tervals since the current mete The scope of this project is to eters capable of providing tha g the data back to the head-en rval granularity for better ener ormat to allow customers to u cy within our service territory to t year, we will be building the tomer interface to allow us to	replace the 4,500 electro- t level of granularity, as well d system, allowing our rgy decisions. The data will be tilise off-the-shelf software to to other facilities regardless if communication infrastructure, implement the end-to-end comply with the OEB ruling to ng opportunities to leverage
2. General Project Information (OEB)	Justification Contributed Capital		Project is an OE Contributed Ca		tion System Code amendmen	t, pursuant to section 70.2 of
	Fiscal Year Parent WO# Job Number		2015			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	Management		een currently identified, othe oject management technique	r than the standard project risl 5.	ks which will be actively
	Comparative Information on Historical Projects (if any)	Equivalent	Estimated costs presentment p		nditures of similar meter, com	nunication and data
	Total Capital and OM&A Cost Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		<ul> <li>Meters capab</li> <li>Communication</li> </ul>		of three components; ion from the meter to the Hea nner that provides the maximu	
			costs to our cus for opportuniti The constraint approved mete	stomers, where possible favou es to leverage PowerStream's to fully leverage this low-cost	ring the lower cost option. Po currently deployed Wi-Max sy Wi-Max solution is the availab ommunication protocol. Wher	stem in order to lower costs. ility of Measurement Canada
			PowerStream v	vill be leveraging our Operatic	nal Data Store for data collect	ion and data presentment.
	1a. Main Driver				meter solution that meets the ing the data value to the custo	e customer needs as defined in mer.
	1b. Priority and Reasons for P	Priority		as this is a mandated activity u d by August 21, 2020	nder Ontario's Distribution Sys	stem Code (DSC) which needs
	1c. Qualitative and Quantitati Project and Project Alternativ		no alternative t PowerStream c Canada approv need to upgrad	that avoids the need to replac continues to engage with Meter al of meters capable of suppo	e the meter. er Manufacturers to determine rting cheaper communication upport the additional data loa	options that don't rely on the
	2. Safety		No safety drive	rs identified.		

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	5		10	03637	20	)15		6	Dol	lars
	k		Project Name	2						
Project Summary	Report				<u>GS&gt;50 MI</u>	<u>ST Meter P</u>	rogram Impl	ementation	L	
	4. Coordination	n, Interoperat	pility	-		-			to utilise these n	
	5. Economic De							nergy data and	the additional of	apability to
5. Category-Specific Requirements for Each Project/Activity (OEB)	6. Environment Factors Affectio		ority		ental benefits ha on to be comple					
	Factors Relatin or Input	g to Custome	r Preferences	MaRS EDAP e consistent for monthly (typi Getting data i away with a lo	xpressed the po mat when they cally manually) f n a machine rea	sition that large have buildings for internal ben dable and com nd effort involve	e property mana across multiple chmarking, ener mon (Green But ed in accessing e	agers see a lot utilities they co rgy manageme ton Download energy consum	ives at meetings of value in gettir ollect and assimi nt and reporting My Data) forma ption data for th request.	ng data in a late data g purposes. t would do
	Factors Affectin Project	ng the Final C	ost of the	1) meter costs 2) re-installati 3) higher com	ion and cross ph	asing of comple is associated wi	ex metering con th reaching insid	de/subterrane	an meter locatio ble	ns
	How Controlled Minimized Identify if Othe Met by the Pro	er Planning Ob	ojectives are		ive down costs.	technology, Po	werStream cont	inues to engag	ge with meter/co	ommunicat
	Options Consid Analysis Results of Final			Not Applicabl Not Applicabl						
	applicable System Impact Costs)	s (Nature, Ma	gnitude and	Not Applicabl	e.					
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ - \$	÷ -	\$-	\$ -	\$ 1,592,952	\$ 1,196,859	\$ 1,303,795	\$ 1,308,610	\$ 1,195,725	\$ 574,
	\$1,800,000	)								
	\$1,600,000	,								
	\$1,400,000									
	\$1,200,000									
	\$1,000,000	ر 				1	**			
	\$800,000	)					······			
	\$600,000	)								_
	\$400,000	)								
	\$400,000 \$200,000 \$ -									

	Ρ	roject Code		Report Start Year	Number of Years	Scale
Power Stream	5	102	2175	2015	6	Dollars
Project Summar		roject Name	Resid	dential Meter "ICON F"	Meter Replacement Pr	<u>ogram</u>
Major Category	System Access					
Project Overview 1. Additional Information	Service Territory		PowerStream	South		
	Location			neter was installed in the City ' meters are scattered through		: deployment of smart meters. erritory.
	Scope		replacement o PowerStream's meters in conju meters procure the "ICON F" n generation sm upgradeability	unction with the depreciation ed and installed in 2007. Durin neter did not meet all encrypti art meters installed at PowerS	neters. There are appoximatel oject is the 2nd year of a 9 yea of the meter. This project is lin ng the Bell WurldTech security on data requirements. The "IC tream. The "ICON F" meters a I by the single phase contractor	y 136000 "ICON F" meters in r program, designed to replace mited to single phase smart audit it was determined that CON F" meters are the first re limited in their firmware r. Meters will be scrapped
	Justification		encryption but security audit i The "ICON F" n meters are lim in areas that h through the cu	urity and Privacy is important to the data encryption is not up t was determined that the "IC neters are the first generation ited in their firmware upgrade ave ICON F meters deployed. Irrent financial model of depre f the meter population based	to current industry standards. ON F" meter did not meet all e smart meters installed at Pow ability. Future smart grid deple The meters must be replaced a ciation. The ICON F meter rep	During the Bell WurldTech encryption data requirements. erStream. The "ICON F" oyed projects would be limited as an end of life program lacement program emulates
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2015			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk N Comparative Information on E Historical Projects (if any)			s are based on historical expe	nditures of similar meter repla	cement projects.
	Total Capital and OM&A Costs Renewable Energy Generation		0			
4. Evaluation Criteria (OEB)	Projects (if any) Project Summary			neter was installed in the City ' meters are scattered through		: deployment of smart meters. erritory.
			replacement o PowerStream's meters in conju meters procure the "ICON F" m generation sm upgradeability	unction with the depreciation ed and installed in 2007. Durin neter did not meet all encrypti art meters installed at PowerS	neters. There are appoximatel oject is the 2nd year of a 9 yea of the meter. This project is lin ng the Bell WurldTech security on data requirements. The "IC tream. The "ICON F" meters a I by the single phase contractor	y 136000 "ICON F" meters in r program, designed to replace mited to single phase smart audit it was determined that CON F" meters are the first re limited in their firmware r. Meters will be scrapped
	1a. Main Driver		During the Bell encryption dat	sts. This project is limited to si I WurldTech security audit it w a requirements. The "ICON F" The "ICON F" meters are limit	as determined that the "ICON meters are the first generatio	F" meter did not meet all n smart meters installed at
	1b. Priority and Reasons for Pr	riority	Not Applicable			
	1c. Qualitative and Quantitative Project and Project Alternative			tives are limited to the type and the type and the type and the need to replace the term of term o		ent meter. However, there is
	2. Safety		Not Applicable			Pg <sup>2</sup>
						' y

			Project Code		Report S	Start Year		Number o	f Years		Scale	
Power Stream	5		10	2175		2015			6		Dol	lars
	•		Project Name									
Project Summary	Report			<u>Resi</u>	dential	Meter "	ICON F"	<u>Meter Re</u>	eplac	ement Pro	<u>gram</u>	
	3. Cyber-Securi	ty, Privacy		Because the "	CON F" n	neters are	first generat	tion smart	neters	installed in 2	007, and data	encryption v
				not a concern implemented			lo not meet	the data er	ncrypti	on requireme	nts that have b	een
	4. Coordination	, Interoperab	ility	Not Applicable	2							
	5. Economic De	velopment		None.								
	6. Environment			Not Applicable.								
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affectin		prity		d priority			t will be de	termir	ned by seal da	te, model, and	serial
	Factors Relating or Input	g to Custome	Preferences	Not Applicable	2.							
	Factors Affectin Project	ig the Final Co	ost of the	Factors affecti 1) Meter type 2) Meter featu 3) Manufactur 4) Ability to ne 5) Cost of met	er of Meters er of Meters	ter volume dis	counts from	the meter			cating with the	meters.
	How Controlled	l Costs have b	een	Controllable c	osts will b	pe minimi	ed through	a compreh	ensive	work plan an	d competitive r	neter pricin
	Minimized Identify if Other Met by the Proj			Not Applicable	2.							
	Options Conside Analysis	ered and Sun	nmary of	Not Applicable	2.							
	Results of Final applicable	Economic Ev	aluation, if	Not Applicable	2.							
	System Impacts Costs)	s (Nature, Ma	gnitude and	Not Applicable	2.							
	2011	2012	2013	2014	201	15	2016	2017		2018	2019	2020
Expenditures Historical/Planned	\$ - \$	-	\$ -	\$ -	\$ 41	1,051 \$	494,361	\$ 494,	746 \$	872,435	\$ 2,280,384	\$ 4,517,4
	\$5,000,000	T										
	\$5,000,000 \$4,500,000											
	\$4,500,000 \$4,000,000											
	\$4,500,000 \$4,000,000 \$3,500,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000	· · · · · · · · · · · · · · · · · · ·										
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000 \$1,500,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000 \$1,500,000											
	\$4,500,000 \$4,000,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000 \$1,500,000 \$1,000,000		2012	2013	2014	2015	5 201(	5 20		2018	2019	2020

	Pr	roject Code		Report Start Yea <b>r</b>	Number of Years	Scale
Power	5	101	1763	2015	6	Dollars
Siream	Pr	roject Name				
Project Summar	y Report		<u>Unfo</u>	reseen Projects Initiate	d by the Customer PS	<u>North</u>
Major Category	System Access					
Project Overview						
1. Additional Information	Service Territory Location		PowerStream PowerStream	North North Service Territory		
	Scope			ojects, Typically these project e project can be a complete ne		
	Justification		10% annual inc	are requested by a customer a crease. It is expected with the equests for u/g and/or o/h relo	Places to Grow Act and zero se	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital Emerging Customer		
	Fiscal Year		2015			
	Parent WO#					
3. General Information on the Project/Activity (OEB)	Job Number Risks to Completion and Risk N	Nanagement	C00235 These projects	are non-controllable and are o	Iriven by the Customer's sched	lule.
	Comparative Information on E Historical Projects (if any)	Equivalent	The level of ac	tivity/demand in Customer Rel	ocation Requests can fluctuate	e from year-to-year.
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Unforeseen Pro	ojects, Typically these project	s are line extension to supply p	oower to new and existing
	1a. Main Driver		Service Reques	sts. These projects are typically rances/driveways, clearances t	required due to conflicts that	-
	1b. Priority and Reasons for Pr	iority		controllable projects and are o		
	1c. Qualitative and Quantitativ Project and Project Alternative		The EDS needs	to be relocated due to a confl	ict with the Customer's develo	pment project.
	2. Safety		The relocation EDS.	of the EDS may be a result of t	he need to maintain safety cle	earances to PowerStream's
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabili	ty	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Priori	ity	These projects	are non-controllable and are o	Iriven by the Customer's sched	lule.
	Factors Relating to Customer P	Preferences		are typically required due to c eways, clearances to overhead		has such as location of
	or Input Factors Affecting the Final Cost Project	t of the	The final costs	of the project are dependent on of a section of overhead line	on the available space to reloca	
	How Controlled Costs have bee Minimized	en		ervice is provided by PowerStro gh a competitive RFP process v		
	Identify if Other Planning Obje Met by the Project, if so, which		Not Applicable			
	Options Considered and Summ Analysis	nary of	Not Applicable			
	Results of Final Economic Evalu	uation, if	Not Applicable			
	System Impacts (Nature, Magn Costs)	nitude and	Not Applicable			



	F	Project Code		Report Start Year	Number of Years	Scale
Power Stream		101	1761	2015	6	Dollars
	F	Project Name				
Project Summar	ry Report		<u>Unfo</u>	reseen Projects Initiate	d by the customer PS S	<u>South</u>
Major Category	System Access					
Project Overview						
1. Additional Information	Service Territory		PowerStream S			
	Location			South Service Territory		
	Scope				s are line extension to supply p w line build or upgrade from 1	_
	Justification		10% annual ind		and are Non-Controllable. The Places to Grow Act and zero se location	
2. General Project Information (OEB)	Contributed Capital			apital Emerging Customer		
	Fiscal Year		2015			
	Parent WO#					
	Job Number		C00210			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	Management	These projects	are non-controllable and are o	driven by the Customer's sched	ule.
	Comparative Information on Historical Projects (if any)	Equivalent	The level of act	tivity/demand in Customer Rel	ocation Requests can fluctuate	from year-to-year.
	Total Capital and OM&A Cost Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		customers. Th	e project can be a complete ne	s are line extension to supply p we line build or upgrade from 1 to proximity of the developme	ph to 3ph. Or it can require
	1a. Main Driver		Service Reques	sts. These projects are typically rances/driveways, clearances t	y required due to conflicts that	the development has such as
	1b. Priority and Reasons for P	riority		controllable projects and are o		
	1c. Qualitative and Quantitati Project and Project Alternativ		The EDS needs	to be relocated due to a confl	ict with the Customer's develo	pment project.
	2. Safety		The relocation EDS.	of the EDS may be a result of t	he need to maintain safety cle	arances to PowerStream's
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabi	lity	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Factors Affecting Timing/Prior	rity	These projects	are non-controllable and are o	lriven by the Customer's sched	ule.
	Factors Relating to Customer or Input	Preferences		are typically required due to c eways, clearances to overhead	onflicts that the development l lines, etc.	has such as location of
	Factors Affecting the Final Co Project	st of the		ng of a section of overhead line	on the available space to reloca might be required. This would	
	How Controlled Costs have be Minimized	een			eam and its contractor. Powe which provides best costs and c	
	Identify if Other Planning Obj Met by the Project, if so, whic		Not Applicable			
	Options Considered and Sumi Analysis	mary of	Not Applicable			
	Results of Final Economic Eva applicable	luation, if	Not Applicable			
	System Impacts (Nature, Mag Costs)	nitude and	Not Applicable			

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		101	1761	20	15		6	Do	llars
Project Summary I	Report		Project Name	<u>Unfc</u>	oreseen Pro	jects Initiate	d by the cu	stomer PS S	South	
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ 1,449,123	\$ (692,016)	\$ 388,781	\$ 776,335	\$ 279,618	\$ 677,544	\$ 808,502	\$ 946,668	\$ 1,099,428	\$ 1,254,572
	\$2,000, \$1,500, \$1,000, \$500, \$(500, \$(1,000,	000 000 000 5 - 201 000)	1 2012	2013	2014	2015 20	16 2017	2018	2019	2020

		Project Code	Report Start Year	Number of Years	Scale
Pow Stream	ver <b>s</b>	100835	2015	6	Dollars
Project Sur	nmary Report	Project Name	Cable Injection P	rogram - 2015 to 2020	)
					-
Aajor Category	System Renewal				
Project Overview	Sonvice Territory	DoworStro	am North & South		
L. Additional Information	Service Territory Location		eam North & South cations in PowerStream		
	Scope	Carry out	cable injection to approx. 105-12	15 km per year of existing in-	service underground primary X
		cable to m	naintain system reliability and cu	stomer service.	
		a prioritiz injection. PowerStre cable). The component reliability capability if too man manage th comprom To manag remediati worst cab cable injet Cable injet and cost e	end the life of end-of-life primar ed basis, each year PowerStream eam has a considerable quantity e oldest cables of this cable popu- nt of the underground electrical and customer service are negati- to replace or repair the faulted by cable failures occur at the sam he large-scale and cascading out- ised and reliability will be unacce e the risk of large-scale cable fail on plan. The plan includes contir le segments by a combination of ction will improve the cable insu ction cost is lower in comparisor iffective for some cable types an able population is summarized b	of underground primary cab ulation are at end-of-life and distribution system when a c vely affected. For small-scale cable segments under reactive te time, PowerStream would ages. If this happens, the dist eptable to the customers. lures, PowerStream must imp uous work on assessing, price cable injection and cable rep lation and extend the life of the to cable replacement cost, l d field conditions. PowerStree	e in service (approx. 8,220 km are failing. Since cable is the m able segment fails, system outages, PowerStream has the re emergency response; howev not have sufficient resources t ribution system integrity will b olement a proactive cable pritizing, and remediating the placement. It is expected that the cable by another 20 years. but the method is only suitable
		prioritized • Conduct • Use the • The cabi • The cabi level from PowerStre (approx. 1	the cable aging issue by a comb l basis. The splices will be replace t esting to determine the condit cable prioritization system to se le injection program will stay at a le replacement program will stay year 23 onward. sam's 22-year Cable Remediation 05-115 km injection and 25 km r st will increase by 3% per year to ost.	ed when the cable is injected ion of the cable. lect cable replacement and c a stable level for 22 years, thu y at a stable level for 22 years an Plan will address on averag replacement) at a cost of \$15	able injection candidates. en terminate. , and then will increase to high e 130-140 km of cable per year .7M per year (2015 dollars). Th
		phenome insulation the strand into the ir and fills al the life of According km per ye 22 years is population cable perf PowerStre point that According km per ye • Replace	ble gets older, the cable insulation non known as "water treeing". V and eventually lead to cable fail ls of the cable. The silicone fluid isulation. The fluid then polymer l water trees and voids. This incr the cable. It is expected that cab to PowerStream's 22-year Cable ar from 2015 – 2036. s the optimal time period to get n. If PowerStream shortens the t formance faster. However, to do eam extends the time frame bey they are no longer suitable can to PowerStream's 22-year Cable ar from 2015 – 2036 This quant ment of "Left-behind" segments	Vater trees will reduce the br ure. Cable injection process will diffuse out of the strand izes with water (or moisture eases the dielectric strenght ble injection will extend the li e Remediation Plan, we inten the benefit of the injection p ime frame, PowerStream will so, PowerStream will have to ond the 22 years, the cable so didates for cable injection. e Remediation Plan, we inten ity includes two parts: from the injection projects (2	eakdown strength of the will inject silicone chemicals do s through the strand shield an ) and the silicone molecule gro h of the cable and thus extend fe of end-of-life cable by 20 ye d to inject on an average of 12 rogram for the targeted cable I receive the benefit of improv o increase the annual budget. egments may deteriorate to the d to replace on an average of
2. General Project Information (O	EB) Contributed Capital		ment of "Main-stream" segment ed Capital 0%	د ا د km per year).	
	Fiscal Year	2015			

Fiscal Year Parent WO# Job Number 2015

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		100	0835	2015	6	Dollars
		Project Name				
Project Summary	Report			Cable Injection Pro	gram - 2015 to 2020	
3. General Information on the Project/Activity (OEB)			work. Risk Managem work sites thro constant durin both contracto operational iss	ent: PowerStream has retained oughout the year under multi-y g the term of the Master Servi rs are kept competitive. Regul ues are resolved promptly; but	nternal and external) to comp d two cable injection service pr rear Master Service Agreement ce Agreement. The quality of v ar progress meetings are held dget performance is monitored	roviders working at different ts. The unit prices are kept vork and responsiveness for to ensure technical and d; and projects are on track.
	Comparative Information o Historical Projects (if any)		Therefore the pat the same level	proposed annual budget for 20	he same level of cable injection 015 onward is a continuation o	
	Total Capital and OM&A Cos Renewable Energy Generati Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		XLPE cable to n	naintain system reliability and		
	1a. Main Driver		This project is performed the life	part of PowerStream's long-ter of end-of-life primary cable to	is project is system reliability a m cable injection program. Ca maintain system reliability an review, test and select suitabl	ble injection is carried out to d customer service. On a
	1b. Priority and Reasons for	Priority	population is a service to the c	t end-of-life and requires reha customers. If not rehabilitated,	derground primary cable in ser bilitation in order to maintain the cable population will get Stream and not tolerable by th	system integrity and reliable older and will fail more often
	1c. Qualitative and Quantita of Project and Project Alterr			vever this approach is not prac	llow the cable to fail and be re tical or viable as it will have a	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	<ol> <li>Coordination, Interoperat</li> <li>Economic Development</li> </ol>	DIIITY	Not Applicable Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perfe Deterioration or Failure:	d	not rehabilitate manageable by Cable is the ma segment fails, s PowerStream of requirements f are required to oldest cables oo To manage the Remediation P worst cable seg PowerStream's • Conduct test • Use a cable p	ed, the cable population will g y PowerStream and not toleral ain component of the undergro system reliability and custome monitors the condition of its p for safety and reliability. The ar- b keep pace with the annual ag f the PowerStream cable popu- erisk of large-scale primary cab lan. The plan includes continue gments by a combination of ca s approach to manage the high ing to assess the condition of t prioritization system to select co	bund electrical distribution sys r service are negatively affecter rimary cables to ensure that the set demographics indicate that ing and deterioration of cables ilation are at end-of-life and ar ole failures, PowerStream has i ous work on assessing, prioritize ble injection and cable replace or sk cable population is summ	n to the level that is not tem and when a cable id. iey meet minimum at annual remediation efforts s, and specifically, that the re failing. mplemented a Cable zing, and remediating the ement. harized below: eplacement or injection.
	1. Condition of Asset vs. Typ and Performance Record	oical Life Cycle	Useful Life of n		ortization Study for the Ontari s 25 years. Many of PowerStre ail if not rehabilitated.	
	2. Number of Customers in I Class Potentially Affected by		Approximately	19,779. See calculation of the	is figure in 3. below.	

		Ρ	Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		100	1835	20	15		6	Dol	lars
Project Summary	v Report	Ρ	Project Name		<u>Cable In</u>	jection Prog	gram - 2015	5 to 2020		
	3. Quantitative Co (frequency or dur and associated ris	ration of inte		For 115000 m	f Failure is: 0.5 f				o 57 failures) pe	er year
				<ul><li>customers and</li><li>Average num</li><li>Projected nu</li><li>Average CMI</li></ul>	012 Control Roc d 3,577,118 CMI nber of custome umber of custom l for 1 failure is: All for 57 failures	ers affected by 1 ners affected by 3,577,118/123	L failure is: 42,7 57 failures is: 1 = 29,082 CMI	24/123 = 347 co 347 x 57 = 19,77	ustomers	2,724
	4. Qualitative Cus satisfaction, custo associated risk le	omer migrati			have negative ir and financial lo				-	ise
	5. Value of Custo Factors Affecting		ng, if any	High Not Applicable	2.					
	Consequences fo Including Implica Implementing		m Costs		or emergency ca or 57 cable failur					
		tions of Not	ect Timing, if any Not M System Costs • O of Not • O Factors This pot	• O&M Cost fo This project is	• ·	re repairs = \$10 -term cable ren	,000 x 57 = \$57 nediation progr	0,000.	t will help avoid	a total of !
	Including Implica Implementing	tions of Not ifety Factors ct Benefits an parison (if the ewal and has tra cost, provi	nd Costs with e project is s been	• O&M Cost for This project is potential cable The main alter situations. How	part of the long e failures and 1,	re repairs = \$10 -term cable ren 657,674 potent nothing" and a	,000 x 57 = \$57 nediation progr ial CMI. llow the cable	0,000. am. The projec to fail and be re	placed under e	mergency
	Including Implica Implementing Reliability and Sa Analysis of Projec Alternative Comp "like for like" ren- configured at ext	tions of Not ifety Factors ct Benefits an parison (if the ewal and has tra cost, provi	nd Costs with e project is s been	• O&M Cost for This project is potential cable The main alter situations. How	part of the long e failures and 1, native is to "do wever this appro	re repairs = \$10 -term cable ren 657,674 potent nothing" and a	,000 x 57 = \$57 nediation progr ial CMI. llow the cable	0,000. am. The projec to fail and be re	placed under e	mergency
enditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Projec Alternative Comp "like for like" ren- configured at ext analysis of projec	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	• O&M Cost for This project is potential cable The main alter situations. How service and sys	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custon 2020
enditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Project Alternative Comp "like for like" ren configured at ext analysis of project 2011	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	• O&M Cost for This project is potential cable The main alter situations. How service and sys	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custon 2020
enditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Projec Alternative Comp "like for like" ren- configured at ext analysis of projec <b>2011</b> \$ 349,694 \$	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020
penditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Projec Alternative Comp "like for like" ren- configured at ext analysis of projec <b>2011</b> \$ 349,694 \$ \$7,000,000	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020
penditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Project Alternative Comp "like for like" ren- configured at ext analysis of project <b>2011</b> \$ 349,694 \$ \$7,000,000 \$6,000,000	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020
penditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Project Alternative Comp "like for like" ren- configured at ext analysis of project <b>2011</b> \$ 349,694 \$ \$7,000,000 \$6,000,000 \$5,000,000 \$3,000,000	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020
penditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Project Alternative Comp "like for like" ren configured at ext analysis of project <b>2011</b> \$ 349,694 \$ \$7,000,000 \$6,000,000 \$5,000,000 \$3,000,000 \$2,000,000	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020
penditures Historical/Planned	Including Implica Implementing Reliability and Sa Analysis of Project Alternative Comp "like for like" ren- configured at ext analysis of project <b>2011</b> \$ 349,694 \$ \$7,000,000 \$6,000,000 \$5,000,000 \$3,000,000	tions of Not fety Factors ct Benefits an parison (if the ewal and has tra cost, provi ct benefits) 2012	nd Costs with e project is s been ide an <b>2013</b>	O&M Cost for This project is potential cable The main alter situations. How service and system 2014	or 57 cable failur part of the long e failures and 1, mative is to "do wever this appro stem reliability. 2015	re repairs = \$10 -term cable ren 657,674 potent nothing" and a bach is not prac 2016	,000 x 57 = \$57 nediation progr ial CMI. Ilow the cable tical or viable a <b>2017</b>	0,000. ram. The projec to fail and be re is it will have a n <b>2018</b>	placed under e negative impact 2019	mergency t on custom 2020

joins:			Project Code	Report Start Year	Number of Years	Scale
Project Summary Report         Cable Replacement Program - 2015 to 2021           Major Category         System Reneval         Project Stream North & South         Yunnus location in Provestream           1. Additional Information         Socie         Provestream North & South         Yunnus location in Provestream           1. Additional Information         Socie         Provestream North & South         Yunnus location in Provestream           1. Additional Information         Socie         Provestream North & South         Yunnus location in Provestream           1. Additional Information         Socie         Provestream Nate, N	Pow	er	100851	2015	6	Dollars
Additional Information         Spatial Renewal Project Overware Li Additional Information         PowerStream North & South Various locations in PowerStream Northerm Caller Information Power a prostream Northerm Northerm Northerm Northerm Northerm Northerm Northerm Northerm Northerm Northerm a prostream Northerm Northerm PowerStream Northerm Nort	Jirean		Project Name		•	•
<ul> <li>Project Devrive</li> <li>Additional Information</li> <li>Seque</li> <li>PowerStream North &amp; South</li> <li>Various Location</li> <li>Seque</li> <li>Justification</li> <li>Internation</li> <li>Seque</li> <li>Justification</li> <li>Internation</li> <li>Seque</li> <li>This project is part of PowerStream's long-term calls empediation program. Cable remediation program. Cable replacement to a province capability to replace cable and reliability will be unacceptible to the cable spinoret transport remediation program. Cable replacement to a province cable spinoret transport remediation and cable replacement on protocol data. The program of tags at a cable cable spinoret cable spinoret transport remediation of tag the program. Cable replacement to a province cable spinoret transport resource cable spinoret transport remediation program. Cable remediatis in protocol cable spinoret transport remediati</li></ul>	Project Sun	nmary Report		Cable Replacement F	Program - 2015 to 202	<u>0</u>
<ul> <li>Additional Information</li> <li>Service Ferritory</li> <li>Location</li> <li>Scope</li> <li>Carry out cable replacement to approx. 25 Im pay wer desiting in-service underground prediction and cable operations in PowerStream Nill review, test and activation program. Cable remediation program. Cable replacement in reprose receive. Cable and cable replacement. The cable replacement cable replacement remediation program. Cable replacement in reprose remediation progr</li></ul>	Major Category	System Renewal				
Location       Variance locations: in PowerStream Status         Scope       Carry out called reglesement to approximary table to maintian system reliability and customer a prioritized basis, each year PowerStream Status (in s-write underground principacito).         Austification       This project is part of PowerStream Status (in s-write underground principacito).         PowerStream has a considerable quantity of underground principacito service (provid- a prioritized basis, each year PowerStream Status (in s-write underground principacito).         PowerStream has a considerable quantity of underground principacito service (provid- apprioritized basis, each year PowerStream Status (in s-write groups).         PowerStream has a considerable quantity of underground principacito service (provid- ingentity).       The underground decirated distribution system when a cable service (provid- tion approxide).         To manage the large scale and coaciding outputs.       This happen, the distribution system when a cable segment table, so company cable failures normal set and when the cable reglesement at proxide or remediation plan. The plan includes: continuous were address the scale segment table, so continuous were cable injection and cable replacement to approxi- cable injection cost is lower in companison to cable replacement at proxide or remediation plan. The plan includes: continuous were address the cable.         • Address the cable aging issue by a continuous were address the cable were cable injection cost is lower in companison to cable replacement and cable replacement to and cost effective for some cable signed and the cable.         • Address the cable aging issue by a conthinaction.       ReverStream's agroup		Sonvice Territory	DoworStroa	m North & South		
<ul> <li>cable to maintain system reliability and customer service.</li> <li>This project is part of program. Spate mediation program. Cable remetation a prioritized basis, each year HowerStream Vill revey, text and select suitable cable agence in pretion.</li> <li>ProverStream's a considerable cable dispet of the constraint system reliability and customer a prioritized basis, each year HowerStream Vill revey, text and select suitable cable agence in pretion.</li> <li>ProverStream's a considerable cable signed on the constraint system reliability and customer service.</li> <li>ProverStream's a considerable cable signed on the constraint system reliability and customer service are negatively affecting distribution system when a cable signer.</li> <li>ProverStream's and constraint section of cable injection.</li> <li>ProverStream would not have sufficient remains the distribution system integend reliability and customer service are negatively affecting and remains when reliability and customer service.</li> <li>To manage the ingress calls and customer service cable injection and cable replacement 1 is expected and customer service cable injection on cable injection on cable injection and cable replacement 1. It expects cable injection customers.</li> <li>Address the cable aging issue by a combination of cable injection and cable replacement on and cable replacement 1. It expects and below.</li> <li>Address the cable aging issue by a combination of cable injection and cable replacement on and cable injection and cable replacement and cable injection and cable replacement and cable injection and</li></ul>	1. Additional information					
<ul> <li>out to extend the life of end-of-life privary calles to maintain system reliability and custome a prioritized bask, such year NewsYsteam will review, list and select satislable calles segment rejection.</li> <li>PowesYsteam has a considerable quantity of underground primary cable in service (approx: cable). The oldest cables of this cable population are at end-of-life and are failing. Since table couplating to the underground electrical distribution system reliability and custome service are negatively of the underground and relative relative table segments under reactive energinary respons if foo many cable failures occur at the same time. PowesYsteam would not have sufficient to manage the large-cale and casarding outages. If this happens, the distribution system integ compromised and reliability will be unacceptable, the distribution system integ compromised and reliability will be unacceptable, the distribution system integ compromised and reliability will be unacceptable, the distribution system integ compromised and reliability will be unacceptable, the distribution of cable injection and cable replacement as promoting, and remedia wors cable segments by a combination of cable injection and cable replacement as promoting and remedia wors cable segments by a combination of cable injection and cable replacement on prioritized basis. The splice will be replaced when the cable is injected.</li> <li>Address the cable aging issue by a combination of cable injection and cable replacement o prioritized basis. The splices will be replaced when the cable is injected.</li> <li>Address the cable epidement program will say at sable level for 22 years, and then will increase level of ministration as 25 km replacement as a basel level for 22 years, and then will increase level of ministration as 25 km replacement is a constant. Since the segment segments are applicable will be replaced when the cable is injected.</li> <li>Address the cable replacement program will say at sable level for 22 years, and then will</li></ul>		Scope				ice underground primary XLPE
<ul> <li>prioritized basis. The splices will be replaced when the cable is injected.</li> <li>Conduct testing to determine the condition of the cable.</li> <li>Use the cable prioritization system to select cable replacement and cable injection candida</li> <li>The cable injection program will stay at a stable level for 22 years, then terminate.</li> <li>The cable ingelacement program will stay at a stable level for 22 years, and then will increal level from year 23 onward.</li> <li>PowerStream's 22-year Cable Remediation Plan will address on average 130-140 km of cable (approx. 105-115 km injection and 25 km replacement) at a cost of \$15.7M per year (2015 du annual cost will increase by 3% per year to account for general cost increase due to inflation external cost.</li> <li>As the cable gets older, the cable insulation may develop a premature aging process caused phenomenon known as "water treeing". Water trees will reduce the breakdown strength of insulation and the cable. The silicone fluid will diffuse out of the strands through the strand into the insulation. The fluid then polymerizes with water (or moisture) and the silicone not and fills all water trees and voids. This increases the delectric strength of the cable and three the betenft of the injection program for the targeted data cable injection will reduce the preakdown strength of the cable. In the septent that cable injection will be power/stream intends to inject average of 115 km per year from 2015 – 2036. The period of 22 years is the optimal time per the beneft of the injection program for the targeted data be population. The Power/stream short frame, Power/stream will have to increase the annual budget. If Power/stream short frame, Power/stream will have to alle injection will have to repla average of 25 km per year from 2015 – 2036. The guard of 22 years is the optimal time per the beneft of the injection program for the sole injection will all the sole injection will all the sole performance faster. Howey Power/stream short frame, Power/stre</li></ul>			out to exter a prioritized injection. PowerStrea cable). The component reliability ar capability to if too many manage the compromise To manage remediation worst cable cable inject Cable inject and cost eff	nd the life of end-of-life primary d basis, each year PowerStream werd oldest cables of this cable popula of the underground electrical di nd customer service are negative or pelace or repair the faulted ca cable failures occur at the same elarge-scale and cascading outag ed and reliability will be unaccep the risk of large-scale cable failu n plan. The plan includes continu segments by a combination of c ion will improve the cable insula- tion cost is lower in comparison t fective for some cable types and	cable to maintain system relia will review, test and select sui f underground primary cable ation are at end-of-life and ar stribution system when a cab ely affected. For small-scale or ble segments under reactive time, PowerStream would no es. If this happens, the distrik table to the customers. res, PowerStream must imple ous work on assessing, priori able injection and cable replat tion and extend the life of the o cable replacement cost, bu field conditions. PowerStream	ability and customer service. C table cable segments for cable in service (approx. 8,220 km o e failing. Since cable is the ma le segment fails, system utages, PowerStream has the emergency response; howeve ot have sufficient resources to bution system integrity will be ment a proactive cable tizing, and remediating the cement. It is expected that e cable by another 20 years. t the method is only suitable
2. General Project Information (OEB) Contributed Capital Contributed Capital 0%			prioritized b • Conduct t • Use the ca • The cable • The cable level from y PowerStrea (approx. 10 annual cost external cost external cost As the cable phenomeno insulation a the strands into the insu- and fills all the life of th According t average of 2 the benefit frame, Pow PowerStrea the 22 year: candidates According t average of 2 • Replacem	basis. The splices will be replaced esting to determine the condition able prioritization system to sele- injection program will stay at a sere replacement program will stay at ear 23 onward. m's 22-year Cable Remediation I 5-115 km injection and 25 km rej will increase by 3% per year to a st. e gets older, the cable insulation on known as "water treeing". Wa nd eventually lead to cable failur of the cable. The silicone fluid w ulation. The fluid then polymeriz water trees and voids. This increa- ne cable. It is expected that cable o PowerStream's 22-year Cable F 115 km per year from 2015 – 203 of the injection program for the erStream will receive the benefit m will have to increase the annu s, the cable segments may deteri for cable injection. o PowerStream's 22-year Cable F 25 km per year from 2015 – 2036 ent of "Left-behind" segments fr	I when the cable is injected. In of the cable. A contract of the cable. A cable replacement and cables A cable level for 22 years, then a the stable level for 22 years, and Plan will address on average 12 placement) at a cost of \$15.71 A	le injection candidates. terminate. Ind then will increase to highe 30-140 km of cable per year M per year (2015 dollars). The ase due to inflation and ing process caused by a kdown strength of the I inject silicone chemicals dow hrough the strand shield and nd the silicone molecule grow of the cable and thus extends of end-of-life cable by 20 year am intends to inject on an he optimal time period to get PowerStream shortens the tim ince faster. However, to do so tends the time frame beyond ire no longer suitable am intends to replace on an parts:
	2. General Project Information (OI	EB) Contributed Capital	Contributed	l Capital 0%		
Fiscal Year 2015		Fiscal Year	2015			

Fiscal Year Parent WO# Job Number

Image: transmission of the second			Project Code		Report Start Year	Number of Years	Scale
Cately Replacement Program - 2015 to 2022      Cately Replacement Program - 2015 to 2022      Cately Replacement Replacement Index Management     Replacement Replacement Replacement Replacement Replacement     Replacement Replacement Replacement Replacement     Replacement Replacement     Replace	Power Stream	-	100	0851	2015	6	Dollars
A General Internation on the respect/Activey (Orci)         Fields to Completion and Fields Management.         Bits Production in cost and staff resource protein and external protection costs at affect work link.           2. General Internation on the respect/Activey (Orci)         Fields to Completion and Fields Management.         Note: The staff resource protein and completed in the start at contractor working at affected work and provide a mole protect.         Note: The staff resource protein and completed in the start at contractor working at affected work and provide a mole protect.           Comparative Information on Equivalant Management.         Provestream has budget and completed the same level of about station of the coble replacement work load in the staff resource and completed in the same level.           1. Train Capital and DABA Comm for molecular protection protection of the coble replacement work load of the coble replacement work.         Provestream has budget and completed the same level of about staff or coble replacement work.           1. Train Capital and DABA Comm for molecular protection protection protection and the staff at the staff. The staff at the staff.         Provestream has budget and complete the proposal at the staff at the			Project Name				
Propert/Advancy (0F8)     vox.       A. Management: PowerStream has resided an external contractory working at different work sites throughout the year under a multipress interting and whole service are contraction.     Additional for the year under a multipress interting and whole or service and under service and	Project Summary	/ Report			Cable Replacement Pl	rogram - 2015 to 2020	
Hatorical Projects (if any)     Therefore the proposed annual budget for 2015 onward is a continuation of the cable replacement program at the ane level.       • Sublication Criteria (OBB)     Projects (if any)       • A. Sublication Criteria (OBB)     Project (if any)       • Carly our cable replacement to approx. 25 km per year of existing in-service underground primary XUE cable to maintain system reliability and customer service.       • La. Main Driver     Miligate Falture Risk. The main driver for this project system reliability and customer service.       • La. Main Driver     Miligate Falture Risk. The main driver for this project system reliability and customer service.       • La. Noint Driver     Project Simmary       • La. Project Jand Reasons for Priority     ProverStream has a very large quantity of underground primary cable in service. A portion of the cable population is at end-of-life and requires rehabilitation of drive to another service.       • La. Couldable and Quantitative Acad Qu		Risks to Completion and Ris	k Management	work. Risk Managem throughout the Agreement. Re	ent: PowerStream has retained 9 year under a multi-year EPC ( gular progress meetings are ho	d an external contractor worki Engineering Procurement Con eld to ensure technical and op	ng at different work sites Istruction) Master Service
Remember Perges Generation portion of Project 5 (amonay         Carport C S (amonay)         Carport C S (amonay)           4. Polulation Criteria (DEB)         Project 5 amonay         Carbon comaintain system reliability and customer service. This project is part of PowerStream Nong-term customer program to replace and of-fire primary cable to maintain system reliability and customer service. An portion of the cable population is at end-of-file and requires rebuiltice. On a profitze basis, each year PowerStream will review, test and select suitable cable segments for cable replacement.           10. Priority and Reasons for Priority         PowerStream has a very large quantity of underground primary cable in service. A portion of the cable population is at end-of-file and requires rebuiltiset. the cable population will get older and will fail once often to the level that is not manageable by FowerStream and not tolerable by the customers.           12. Qualitative and Quantitative Analysis of Project and Project Alternatives         An atternative is to do nothing and allow the cable to fail and be replaced under emergency situations. However this apprach is not recommended because it will have a negative impact on customer service and system clabibility.           2. Safety         Not Applicable.           3. Corder Sourchy, Provay         Not Applicable.           4. Cordination, Interoperability         Not Applicable.           5. Category-specific Requirements for and system clabibity.         The second proves for and value customer service will have a negative inpact of the second consequences of Asset Reformance Deterformance Record         Not Applicable.           5. Catego			n Equivalent	Therefore the	proposed annual budget for 20		
1. Main Driver       Militigate Fallure Risk. The main driver for this project is system reliability and customer service.         1. Main Driver       Militigate Fallure Risk. The main driver for this project a system reliability and customer service. On a prioritized basis, each year PowerStream will review, test and select suitable cable segments for cable replacement.         1. D. Priority and Reasons for Priority       PowerStream will review, test and select suitable cable segments for cable replacement.         1. D. Priority and Reasons for Priority       PowerStream has a very large quantity of underground primary cable in service. A portion of the cable population is and of life and requires rehabilitation in order to maintain system milegity and reliable service to the customers. If not rehabilitated, the cable population will get older and will fail more often to the level that is not manageable by PowerStream and not tolerable by the customers. If not rehabilitated is and manageable by PowerStream and not tolerable by the customers.         2. Safety       Not Applicable.       Not Applicable.         3. Cheer Security. Privacy       Not Applicable.       Not Applicable.         6. Environmental Bendits       Description of the Relationship between the sort and not tolerable by the customers.       PowerStream and not tolerable by the customers.         5. Category-Specific Requirements for Eable replaced inder emergency situation.       Not Applicable.       Not Applicable.         8. Category-Specific Requirements for Eable replacements.       PowerStream and not tolerable ty the customers.       Categore the annot and the replacement. </td <td></td> <td>Renewable Energy Generati</td> <td></td> <td>0</td> <td></td> <td></td> <td></td>		Renewable Energy Generati		0			
13. Priority and Reasons for Pliority       PowerStream Surgeth reliability and customer service. On a protincited bias, each year PowerStream will review, test and select suitable cable segments for cable replacement.         13. Priority and Reasons for Pliority       PowerStream will review, test and select suitable cable segments for cable replacement.         13. Priority and Reasons for Pliority       PowerStream will review, test and select suitable cable segments for cable replacement.         14. Cualitative and Cuantitative Analysis       An alternatives to do nothing and allow the cable to fail and be replaced under emergency situations.         15. Claulitative and Cuantitative Analysis       An alternatives is to do nothing and allow the cable to fail and be replaced under emergency situations.         16. Cualitative and Cuantitative Analysis       An alternatives in the customers. In the crustomers. The replacement is used to a service and system reliability.         2. Safety       Not Applicable.         3. Cyber-Security. Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category Specific Requirements for Eaking the Relationable between the Asset Characteristics and Consequences of Asset Performance       Not Applicable.         5. Category Specific Requirements for Eaking the Relationable between the Asset Characteristics and Consequences of Asset Performance       Not Applicable.         6. Invironmental Beenfits       Not Applicable.       Not Applicable.         7. Category Specific R	4. Evaluation Criteria (OEB)	Project Summary					e underground primary XLPE
second polation is at end-of-life and equires rehabilitation in order to maintain system integrity and reliable second will fail more often to the level that is not manageable by PowerStream and not tolerable by the customers.         1: C. Qualitative and Quanitative Analysis       An alternatives is to do nothing and allow the cable to fail and be replaced under emergency situations. However this approach is not recommended because it will have a negative impact on customer service and system reliability.         2: Safety       Not Applicable.         3: Contention, Interoperability       Not Applicable.         4: Coordination, Interoperability       Not Applicable.         5: Category-Specific Requirements for       Description of the Relationship between the sale composition will get older and will fail more often to the level that is not measeable by PowerStream and not toolen to the level that is not measeable to four dotting and allow the cable company and will fail more often to the level that is not measeable to PowerStream and not toolen to the level that is not measeable to PowerStream and not toolen to the level that is not measeable to PowerStream and not toolen to able specified.         5: Category-Specific Requirements for affect and end faile more off and the reformance Deterioration or Failure:       Cable is the main component of the mediation will get older and will fail more often to the level that is not measeable to PowerStream and not toolen to able specifical, that the oldes cables of the PowerStream and not toolen of the powerStream is manageable to PowerStream and not toolen to able specifical, that the oldes cables of the PowerStream is manageable to PowerStream is not memorement.         5: Category-Specific Requiremen		1a. Main Driver		This project is primary cable t	oart of PowerStream's long-ter to maintain system reliability a	m cable replacement program nd customer service. On a price	n to replace end-of-life pritized basis, each year
of Project Alternatives       However this approach is not recommended because it will have a negative impact on customer service and system reliability.         2. Safety       Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Economic Development       Not Applicable.         6. Environmental Benefits       Not Applicable.       Not Applicable.         7. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If not rehabilitated, the cable population will get older and will fail more often to the level that is not manageable by PowerStream and not Lorable by the customers. Cable is the main component of the underground electrical distribution system and when a cable segment fails, system reliability and customer service are negatively affected. PowerStream monitors the confiltion of 15 primary cables to ensure that they meet minimum requirements for safety and reliability. The asset demographics indicate that annual remediation efforts are required to keep pace with the annual aging and deterioration or cables, and specifically, that the oldest cables of the PowerStream cable population is summarized below: - Conduct testing to assess the condition of the cable. - Use a cable prioritization system to select cable population is summarized below: - Conduct testing to assess the condition of the cable. - Use a cable prioritizati		1b. Priority and Reasons for	Priority	population is a service to the c	t end-of-life and requires reha customers. If not rehabilitated,	bilitation in order to maintain the cable population will get	system integrity and reliable older and will fail more often
3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If not rehabilitized, the cable oppolation will get older and will fail more often to the level that is not manageable by PowerStream and not tolerable by the customers. Cable is the main component of the underground electrical distribution system and when a cable segment fails, system reliability. The asset demographics indicate that annual remediation efforts are required to keep pace with the annual aging and deterioration of cables, and specifically, that the oldest cables of the PowerStream able population are at end-of-life and are failing. To manage the risk of large-scale primary cable failures, PowerStream has implemented a Cable Remediation Plan. The plan includes continuous work on assessing, prioritizing, and remediating the worst cable segment by a cable population is summarized below: - Conduct testing to assess the condition or cable injection and cable replacement. PowerStream Saproach to manage the high risk cable population is summarized below: - Conduct testing to assess the condition or cable injection or cable replacement. - Use a cable prioritized cable candidates for cable injection or cable replacement. - Designate prioritized cable candidates for cable injection or cable repla				However this a	pproach is not recommended		
4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Decription of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Each Project/Activity (OEB)       Each Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         Deterioration or Failure:       Consequence of Asset Performance Deterioration or Cable: performance Deterioration or Cable: performance Deterioration or Cable: performance Asset Performance Performance Performance Performance Performance Performance Perequence Pailure:       Not Applicable.		2. Safety		Not Applicable			
S. Economic Development       Not Applicable.         S. Category-Specific Requirements for       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If the asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If the asset Amongpanet of the underground electrical distribution system and when a cable segment fails, system main component of the underground electrical distribution system and when a cable segment fails, system nenitors the condition of its primary cables to ensure that they meet minimum requirements for safety and reliability. The asset demographics indicate that annual remediation efforts required to keep pace with the annual aging and deterioration of cables, and specifically, that the oldest cables of the PowerStream cable population are at end-of-life and are failing. To manage the risk of large-scale primary cable failures, PowerStream has implemented a Cable Remediation Plan. The plan includes continuous work on assessing, and remediation flan, the plan includes continuous work on assessing, and remediation efforts.         Use a cable prioritization system to select cable segment as implemented a cable segment assess the condition of reable, and specifically the users the point replacement.         Use a cable prioritization system to select cable segment candidates for rep							
6. Environmental Benefits       Not Aplicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       There were 103, 123, 133 and 113 cable and splice failures in 2011, 2012, 2013 and 2014 respectively. If not rehabilitated, the cable population will get older and will fail more often to the level that is not manageable by PowerStream and not tolerable by the customers.         Cable is the main component of the underground electrical distribution system and when a cable segment fails, system reliability. The asset demographics indicate that annual remediation efforts are required to keep pace with the annual aging and deterioration of cables, and specifically, that the oldest cables of the PowerStream cable population are at end-of-life and are failing. To manage the risk of large-scale primary cable failures, PowerStream has implemented a Cable Remediation Plan. The plan includes continuous work on assessing, prioritizing, and remediating the workstream's approach to manage the high risk cable population is summarized below: • Conduct testing to assess the condition of the cable. • Use a cable prioritization system to select cable segment candidates for replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Desi			bility				
Each Project/Activity (OEB)the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:not rehabilitated, the cable population will get older and will fail more often to the level that is not manageable by PowerStream and not tolerable by the customers. Cable is the main component of the underground electrical distribution system and when a cable segment fails, system reliability and customer service are negatively affected. PowerStream monitors the condition of its primary cables to ensure that they meet minimum requirements for safety and reliability. The asset demographics indicate that annual remediation efforts are required to keep pace with the annual aging and deterioration of cables, and specifically, that the oldest cables of the PowerStream cable population are at end-of-life and are failing. To manage the risk of farge-scale primary cable failures, PowerStream has implemented a Cable Remediation Plan. The plan includes continuous work on assessing, prioritizing, and remediating the worst cable segments by a combination of cable injection and cable replacement. PowerStream's approach to manage the high risk cable population is summarized below: • Conduct testing to assess the condition of rable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable injection or cable replacement. • Designate prioritized cable candidates for cable is 25 years. Many of PowerStream's existing cable segments are older than 25 years and are							
and Performance RecordUseful Life of non-tree retardant XLPE cable is 25 years. Many of PowerStream's existing cable segments are older than 25 years and are expected to fail if not rehabilitated.2. Number of Customers in Each CustomerApproximately 4,511. For the calculation of this figure, please refer to 3. below.		Description of the Relations the Asset Characteristics and Consequences of Asset Perfo	d	There were 100 not rehabilitate manageable by Cable is the ma segment fails, s PowerStream in requirements f are required to oldest cables o To manage the Remediation P worst cable seg PowerStream's • Conduct test • Use a cable p	3, 123, 133 and 113 cable and ed, the cable population will ge of PowerStream and not toleral an component of the undergro system reliability and custome monitors the condition of its pr or safety and reliability. The as beep pace with the annual ag f the PowerStream cable popu- risk of large-scale primary cab lan. The plan includes continue gments by a combination of ca a approach to manage the high ing to assess the condition of t rioritization system to select c	et older and will fail more ofte ole by the customers. Dund electrical distribution sys r service are negatively affecte imary cables to ensure that th set demographics indicate that ing and deterioration of cable ilation are at end-of-life and an ile failures, PowerStream has i Dus work on assessing, prioriti ble injection and cable replace risk cable population is summ he cable. able segment candidates for m	n to the level that is not tem and when a cable ed. sey meet minimum at annual remediation efforts s, and specifically, that the re failing. mplemented a Cable zing, and remediating the ement. harized below: eplacement or injection.
			vical Life Cycle	Useful Life of n	on-tree retardant XLPE cable i	s 25 years. Many of PowerStre	
				Approximately	4,511. For the calculation of	this figure, please refer to 3. b	elow.

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	-		100	0851	20	)15		6	Dol	lars
			Project Name							
Project Summary	/ Report				Cable Rep	lacement P	rogram - 20	015 to 2020		
	3. Quantitative (frequency or d and associated	luration of in		For 25000 m	of Failure is: 0.5				13 failures) per	' year
				<ul><li>customers an</li><li>Average nu</li><li>Projected n</li><li>Average CN</li></ul>	2012 Control Ro nd 3,577,118 CMI mber of custom number of custom All for 1 failure is: CMI for 13 failure	ers affected by 2 ners affected by 3,577,118/123	1 failure is: 42,7 / 24 failures is: = 29,082 CMI	724/123 = 347 c 347 x 13 = 4,512	ustomers	2,724
	satisfaction, cus	stomer migra			s have negative in the and financial lo				-	ise
		1 - C		High						
	Factors Affectin	ng Project Tin	ning, if any	Not Applicab	le.					
	Consequences	for O&M Syst	tem Costs	O&M Cost	for omorgonou co	bla failura rana		fatt		
		cations of No			for 13 cable failu					
	associated risk level) 5. Value of Customer Impact Factors Affecting Project Timing, Consequences for O&M System Including Implications of Not Implementing Reliability and Safety Factors Analysis of Project Benefits and Alternative Comparison (if the p "like for like" renewal and has bo	ot	• O&M Cost f	for 13 cable failu s part of the long	re repairs = \$10 g-term cable ref	),000 x 13 = \$13 nabilitation pro	80,000.	ect will help avo	id a total o	
	Implementing Reliability and S Analysis of Proj Alternative Con	Safety Factor ject Benefits a nparison (if t enewal and h xtra cost, pro	and Costs with he project is las been povide an	• O&M Cost f This project is potential cab The main alte situations. He	for 13 cable failu s part of the long le failures and 3	re repairs = \$10 g-term cable ref 78,006 potentia nothing" and a oach is not prac	0,000 x 13 = \$13 nabilitation pro I CMI. Illow the cable	30,000. gram. The proje to fail and be re	eplaced under e	mergency
	Implementing Reliability and S Analysis of Proj Alternative Com "like for like" re configured at e	Safety Factor ject Benefits a nparison (if t enewal and h xtra cost, pro	and Costs with he project is las been povide an	• O&M Cost f This project is potential cab The main alte situations. He	for 13 cable failu s part of the long le failures and 3 ernative is to "do pwever this appr	re repairs = \$10 g-term cable ref 78,006 potentia nothing" and a oach is not prac	0,000 x 13 = \$13 nabilitation pro I CMI. Illow the cable	30,000. gram. The proje to fail and be re	eplaced under e	mergency t on custor
nditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011	Safety Factor iect Benefits : nparison (if ti enewal and h xtra cost, pro ect benefits) 2012	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability.	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011	Safety Factor iect Benefits a mparison (if ti enewal and h xtra cost, pro ect benefits) 2012 3 2,219,486	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Com "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$	Safety Factor ject Benefits : mparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 5 2,219,486	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$ \$18,000,00	Safety Factor iect Benefits : mparison (if t enewal and h xtra cost, pro- ect benefits) 2012 5 2,219,486	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custo 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$ \$18,000,00 \$16,000,00	Safety Factor ject Benefits : mparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 5 2,219,486	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$ \$18,000,00 \$16,000,00 \$14,000,00	Safety Factor iect Benefits : nparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 5 2,219,486 10 10 10 10 10 10 10 10 10 10	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$ \$18,000,00 \$16,000,00 \$14,000,00	Safety Factor ject Benefits : mparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 3 2,219,486 0 0 0 0 0 0 0 0 0 0	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj 2011 \$3,917,735 \$ \$18,000,00 \$16,000,00 \$14,000,00 \$10,000,00	Safety Factor iect Benefits : nparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 2	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S           Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj           2011           \$3,917,735           \$18,000,00           \$16,000,00           \$12,000,00           \$10,000,00           \$8,000,00	Safety Factor ject Benefits : mparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 3 2,219,486 0	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020
enditures Historical/Planned	Implementing Reliability and S           Analysis of Proj Alternative Con "like for like" re configured at e analysis of proj           2011           \$3,917,735           \$18,000,00           \$16,000,00           \$12,000,00           \$10,000,00           \$6,000,00	Safety Factor iect Benefits : nparison (if ti enewal and h xtra cost, pro- ect benefits) 2012 5 2,219,486 10 10 10 10 10 10 10 10 10 10	and Costs with he project is las been ovide an 2013	O&M Cost if This project is potential cab The main alte situations. He service and se 2014	for 13 cable failu s part of the long le failures and 3 ernative is to "do owever this appr ystem reliability. 2015	re repairs = \$10 g-term cable reh 78,006 potentia nothing" and a oach is not prac 2016	0,000 x 13 = \$13 habilitation pro I CMI. Ilow the cable tical or viable a <b>2017</b>	30,000. gram. The proje to fail and be re as it will have a 2018	eplaced under e negative impact	mergency t on custor 2020

	Project C	ode	Report Start Year	Number of Years	Scale
Power Stream	-	100890	2015	6	Dollars
	Project N	lame	-		-
Project Summa	ry Report		Emerging Cable Re	eplacement Projects	
Major Category	System Renewal				
Project Overview	•				
1. Additional Information	Service Territory		North & South		
	Location Scope		ion in PowerStream North and e replacement on various locati		nder this category will be
	Stope	evaluated by allocated are	planning in conjunction with Sy sufficent to replace 2 km of prin	stem Operation, Lines and Cu	stomer Services. The funds
	Justification	in residential	subdvision. has approx. 7,836 km of under	ground primary cable length	the vast majority of which is
		direct buried and South wh during the bu have to be ad (Customer Mi CMI's. As the or industrial s Typically thes cable (end of	and the rest is in duct. Current hich target a particular subdivisi dget cycle. However due to cor ldressed as they emerge. In 20 inutes of Interruption) in the De cable system get older we exp ub divisions will have to be adc e projects require a very fast re life cable which is beyond repa planning in conjunction with Sy	ly we have a planned Cable re on based on age/outage infor ndition of the cables and outa 14 the cable and splices are the effective Equipment category a ect that the failures will increa- tressed in emergency as oppo sponse due to criticality of the ir). The projects submitted un	eplacement projects for North mation and are submitted ges; some section/area will he leading cause of CMI and contributed to over 3M ase and some of this residentia sed to planned replacement. e account or condition of the der this category will be
2. General Project Information (OEB)	Contributed Capital	Contributed (	Capital 0%		
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manage	the year and	provals can impact completion completed by years end. Cable he following budget year.		
	Comparative Information on Equivale Historical Projects (if any)	ent The full 'Emer	rging Cable Replacement' budge	et was spent in previous budg	et years.
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 n of			
4. Evaluation Criteria (OEB)	Project Summary	throughout the with System (	; Cable Replacement budget is u ne year. Projects submitted und Operation, Lines and Customer ior industrial and residential cal	er this category will be evalua Services. The funds allocated	ated by planning in conjunction are sufficent to address
	1a. Main Driver	Mitigate Failu	ire Risks. The main driver for th	is project is reliability and cus	stomer service.
		Program. The	s aging cable is replaced follow e Emerging Cable Replacement dgeted year that occur without	Project is intended to address	<i>,</i> ,
	1b. Priority and Reasons for Priority	These project	s are required as often the cab	le is very end of life or is beyc	ond repair.
	1c. Qualitative and Quantitative Analy of Project and Project Alternatives		addressed under the Emerging d under the planned program, b		e that would normally have
	2. Safety 3. Cyber-Security, Privacy 4. Coordination, Interoperability 5. Economic Development	Not Applicabl Not Applicabl Not Applicabl Not Applicabl	e. e.		
5. Category-Specific Requirements for	<ol> <li>Environmental Benefits</li> <li>Description of the Relationship between</li> </ol>	Not Applicabl	e. performs cable testing on aged	cable in order to plan and p	rioritize cable replacement
Each Project/Activity (OEB)	the Asset Characteristics and Consequences of Asset Performance	needs.	placement program is intended		
	Deterioration or Failure:	repair.	pracement program is intended	to address the caples which a	are end of me and beyond
			ences include power outages, un counts in industrial areas often		

			Project Code		Report Start Y	'ear	Number of Yea	ars	Scale		
Power Stream			100	0890	2	015	e	6	Dol	lars	
Project Summar	y Report		Project Name	Emerging Cable Replacement Projects							
	1. Condition of As and Performance		cal Life Cycle	Emerging Cab	le portfolio are	cable is typicall approaching en anned replacem	d of life. The er				
	2. Number of Cus Class Potentially A			100 (typically)							
	3. Quantitative Co (frequency or dur and associated ris	ation of inte		is able to find is lost, and the When the cab outages which estimate of 2 industrial loop CMI (Custome The CMI is est CMI = (10 cust industrial loca For residentia	switching mether ere is risk that s le is not replace will have a neg failures per yea or 21,600 CMI r Minutes of In imated as follow comers x 3 hour tion. I location:		bower to affecte may not be rest e will likely acce system reliabili be 3,600 CMI (Cu loop. For indust x 2 failures/yea	ed customers. I tored until the elerate resultin ity and customer ustomer Minut trial location: r = 3600 per ha	However, switcl faulted cable is g in increased c er service. Base es of Interruptic es of Interruptic	ning diversit replaced. ustomer d on the on) in a	
	<ol> <li>Qualitative Cus satisfaction, custo associated risk lev</li> <li>Value of Custon Factors Affecting</li> </ol>	omer migrat vel) mer Impact	ion and	very fast respo beyond repair High	onse due to crit ).	ble Faults are oc icality of the acc nent project is i	count or conditi	on of the cable	e (end of life cab		
	Consequences for Including Implicat Implementing Reliability and Sat	r O&M Syste tions of Not	em Costs	Not Applicable	e. Cable Replacer	nent project wa	s developed to :			lity	
	Analysis of Projec Alternative Comp "like for like" rend configured at extr analysis of projec	arison (if th ewal and ha ra cost, prov	e project is s been	Cable replace	ment cost unde	positive custom or the emerging ability to address	budget are the		were planned r	replacement	
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	
penditures Historical/Planned	\$ 119,989 \$ 3	1,968,435	\$ 1,463,874	\$ 1,070,775	\$ 491,687	\$ 520,801	\$ 1,050,756	\$ 1,081,576	\$ 1,113,287	\$ 1,145,9	
	\$2,000,000 \$1,500,000										
	\$1,000,000										
	\$ -	2011	2012	2013	2014	2015 202	16 2017	2018	2019	2020	

	Project Cod	e	Report Start Year	Number of Years	Scale
Power	<b>X</b>	102870	2015	6	Dollars
Sfream	Project Nan	ne			
Project Summar	y Report	<u>Subm</u>	ersible Transformer Rep	olacement - 2015-2016	- North
Major Category	System Renewal				
Project Overview 1. Additional Information	Service Territory	PowerStream	North		
	Location		ons in the PowerStream North		
	Scope	For 2015 budg transformers.	get year, it is proposed to replac The 12 submersible transform of Cundles Road E.). The associa	ers are located in the "Cundles	Road E. South" area in
	Justification	operations sw provide suffici normal and er customers. T transformers, were installed dating back to are non-existe system which using non-load energized. As primary syster isolation can a customers at a The fuse is con metal structur cannot be see such as descri being bolted t physical size o which require The vault that and the transf limited. The la approved grou non-jacketed o non-existent. their work zor connected to. above reasons PowerStream		g submersible transformers inc o perform switching and maint cing customer service and relia nd no longer purchased by Por- taff as "Rocketships" or "Stree g poles. These "Rocketship" un ey are obsolete, no longer ma- sed many concerns with contir owing 9 items: 1. The transfo- is they cannot be connected o must be isolated when work is a of interruption when an unpl ding the circuit configuration a ork becomes very complicated berglass support system held in g through the bolts to the grou ossible to confirm without dist ted in the fuse housing being b circuit. 5. Replacement part: ive line techniques and require involve disconnection, potent dersized. There is only 8 cm (3 ment is next to impossible and also prevents access to the po- ole. 8. The primary cable inst orcentric neutral wires have co- tho rely on system neutral to b prised of many tee taps which ourn-off", several services can I is should be replaced. The issu of July 7, 2010. The Reliability	luded in this proposal do not enance operations under bility level to the affected werStream. These submersible tlight Pole Transformers", its are of very old vintage, nufactured, and spare parts bued operation of this supply rmer units are connected r disconnected while required on any part of the anned event occurs. 2. The nd may disrupt up to 100 l because of the fusing design. n place with metal bolts to a nded equipment. This path mantling the unit. 4. Failures by-passed and the terminations is are not available. 6. The es a "hands on" approach ial testing and grounding. 7. inch) between the vault wall work on connections is very tential test points and alled between these units is proded significantly or are the able to effectively ground several services may be be out of power. For the ues were discussed in the Committee have agreed that
2. General Project Information (OEB)	Contributed Capital Fiscal Year	Contributed C 2015	apital 0%		
	Parent WO#	308145			
	Job Number	C00715			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manageme	work. Risk Managen transformer re of the submer meetings amo requirements;	on in cost and staff resource (ir nent: PowerStream has budgete eplacement for the past four ye rsible transformer replacement ongst all involved parties to go o regular progress meetings to e lget performance is monitored;	ed and completed the same levers. Therefore the proposed we program. Some of the tasks to over the project details, schedurensure technical and operation	vel of work with submersible york for 2015 is a continuation o manage the risk are: Ile, logistics, and resource
	Comparative Information on Equivalent Historical Projects (if any)	PowerStream replacement f submersible to	the continuation of PowerStree has budgeted and completed t for the past four years. Therefor ransformer replacement progra batch of the identified high ris	he same level of work with sul re the proposed work for 2015 Im.	omersible transformer is a continuation of the
	Total Capital and OM&A Costs for Renewable Energy Generation portion o Projects (if any)	0 f			

	Project Code	Report Start Year	Number of Years	Scale				
Stream Stream	102870	2015	6	Dollars				
Project Summary Report	Project Name Submersible Transformer Replacement - 2015-2016 - North							
4. Evaluation Criteria (OEB) Project Summary	For 2015 budget year, it is proposed to replace 12 submersible transformers with pad mount transformers. The 12 submersible transformers are located in the "Cundles Road E. South" area in Barrie (Sou Cundles Road E.). The associated cables will also be replaced. The exact schedule and logistics will be determined by Lines, System Control, Capital Design, an Planning to achieve co-ordination of work and to minimize customer disruption.							
1a. Main Driver	This project is	re Risks. The main driver for th the last batch of PowerStream' l-of-life submersible transforme	s long-term submersible trans	former replacement program				
1b. Priority and Reasons for	order to main	batch of the identified high ris tain system integrity and reliab dition, the transformers need t illures occur.	le service to the customers. If i	not replaced, the transformers				
	operations sw The existing su field staff to p thus reducing The transform transformers, were installed	North identified 57 submersible itching procedure. Jubmersible transformers include erform switching and maintena customer service and reliability ers are obsolete and no longer referred to by the operations s at the bottom of street lighting 1967 and are at end-of-life. Th tent.	ed in this proposal do not prov nce operations under normal v level to the affected custome purchased by PowerStream. T taff as "Rocketships" or "Stree g poles. These "Rocketship" un	vide sufficient access to allow and emergency situations, rs. hese submersible tlight Pole Transformers", its are of very old vintage,				
1c. Qualitative and Quantita Project and Project Alternat	summarized u 1. The transfo connected or work is requir unplanned ev 2. The isolatio 100 customer 3. Trouble res to a non-cond have occurred opening, and 4. Failures suc terminations l 5. Replacemen 6. The physica approach whi As described a	n can affect several transforme s at a time. ponse work becomes very comp uctive fiberglass support system passing through the bolts to th is impossible to confirm withou h as described in item 3 above being bolted together in order t at parts are not available. I size of the units restricts any u	non-load break equipment wh As a result, portions of the circ ystem, resulting in approx. 18 rs pending the circuit configur olicated because of the fusing in held in place with metal bolt be grounded equipment. This p t dismantling the unit. have resulted in the fuse hous to restore the circuit.	hich means they cannot be uit must be isolated when hours of interruption when an ation and may disrupt up to design. The fuse is connected s to a metal structure. Faults bath cannot be seen from any ing being by-passed and the requires a "hands on"				
2. Safety	areas that are when the pub	ransformer failures pose safety accessible to the public. The tra- lic in close proximity of the unit transformer tank, which may r	ansformers may fail when staf When the transformer fails, t					
3. Cyber-Security, Privacy	Not Applicable	2.						
4. Coordination, Interoperat	bility Not Applicable	2.						
5. Economic Development 6. Environmental Benefits	resulting in oi	e. former contains oil, transforme being spilled onto the ground. amination can be eliminated.						

		Project Code		Report Start Year	Number of Years	Scale					
Bower		FTOJECT COUE				Stale					
Stream		102	2870	2015	6	Dollars					
	_	Project Name									
Project Summary	Project Summary Report			Submersible Transformer Replacement - 2015-2016 - North           etween         Transformers are used to step down the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage that supplement of the primary voltage to a lower secondary voltage to a lower							
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perfo Deterioration or Failure:	d	customers. An are old and un access pit, ope obsolete, no lo not allow for sy required to be In 2010 Lines N operations swi The existing su field staff to pe thus reducing of The transformers, n	are used to step down the prim number of submersible transfo ique installations that include a n air fusing in a metalclad stree inger manufactured and spare witching resulting in consideral performed on the units or in the lorth identified 57 submersible tching procedure. bmersible transformers include erform switching and maintena customer service and reliability ers are obsolete and no longer referred to by the operations st at the bottom of street lighting	rmers are installed at the botto a submersible transformer in a etlight fixture and fixed primar parts are non-existent. The fixe ole outage disruptions to custo he general vicinity. • transformer locations to be re- ed in this proposal do not prov nce operations under normal a • level to the affected customer purchased by PowerStream. The taff as "Rocketships" or "Street	om of street light poles. These small congested ground y connections. They are ed primary connection does omers whenever work is etrofitted to meet a new ide sufficient access to allow and emergency situations, rs. hese submersible clight Pole Transformers",					
			dating back to parts non-exist Operations sta	1967 and are at end-of-life. Th	ey are obsolete, no longer are	manufactured, and spare					
			1. The transfor connected or c	mer units are connected using lisconnected while energized. In any part of the primary sectors of the sectors o	As a result, portions of the circ	uit must be isolated when					
			2. The isolatior 100 customers	a can affect several transforme at a time.	rs pending the circuit configura	ition and may disrupt up to					
	1. Condition of Asset vs. Typ and Performance Record	ical Life Cycle	to a non-condu	ponse work becomes very comp active fiberglass support systen passing through the bolts to the bove.	held in place with metal bolts	s to a metal structure. Faults					
	2. Number of Customers in E Class Potentially Affected by		Approximately	87. For the calculation of this	figure, please refer to 3. below	ν.					
	3. Quantitative Customer Im (frequency or duration of in and associated risk level)		For 12 transfor	Failure is: 0.2 failure per year							
	4. Qualitative Customer Imp		customers and • Average num • Projected nu • Average CMI • Projected CM Transformer fa	ber of customers affected by 1 mber of customers affected by for 1 failure is: 33,434/4 = 8,35 11 for 2.4 failures is: 8,359 x 2.4 ilures have negative impact to	failure is: 144/4 = 36 custome 2.4 failures is: 36 x 2.4 = 87 cu 9 CMI = 20,060 CMI system reliability and custome	rs stomers er service. Outages cause					
	satisfaction, customer migra associated risk level)	ition and		and financial loss to customers y) if people are in close proxim							
	5. Value of Customer Impact Factors Affecting Project Tim		High Not Applicable								
	Consequences for O&M Syst Including Implications of No Implementing			r 1 emergency transformer fail r 2.4 emergency transformer fa							
	Reliability and Safety Factor	S	avoid a total of	the last batch the submersible f 2.4 potential transformer failt afety risk (potential personal ir	ures and 20,060 potential CMI.	The project will also help					

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	7		102	870	20	015		6	D	ollars
Project Summary Report			Project Name	<u>Subme</u>	ersible Tran	sformer Rep	blacement -	2015-2016	- North	
	Alternative C "like for like" configured a	roject Benefits a omparison (if th renewal and ha extra cost, pro oject benefits)	ne project is as been	avoid a total of	f 2.4 potential	he submersible transformer failt ential personal ir	ures and 20,060	potential CMI.	. The project w	ill also help
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	\$ 6,451	\$ 508,952	\$ 1,168,202	\$ 856,776	\$ 1,040,300	\$ 620,000	\$-	\$-	\$-	\$
	\$1,400,0	000 –								
	\$1,200,0									
	\$1,000,0					<u> </u>				
	<i>\</i>									
	\$800 (									
	\$800,0									
	\$600,0	000								
		000								
	\$600,0 \$400,0 \$200,0	000								

	Projec	t Code	Report Start Year	Number of Years	Scale
Power Stream	5	100859	2015	6	Dollars
Direan	Projec	t Name			•
Project Summar			Switchgear Replaceme	ent Program - 2015 to 2	<u>020</u>
Major Category	System Renewal				
Project Overview 1. Additional Information	Service Territory	PowerStrea	m North & South		
	Location	Various loca	ations in PowerStream		
	Scope				ociated U/G terminations, fault
				will be jointly determined by Lir	nes, System Control, Capital
	Justification	This project replacement customer set of switchget the Asset Co Control, Cap component reliability de ACA model utilities to id Board (OEB generally co company ca of the ACA	t is carried out to replace end- ervice. On a prioritized basis, ea ar units for replacement. The lo podition Assessment (ACA) pro- bital Design, and System Planni of PowerStream distribution si- eteriorate, they should be repla- and methodology, which were dentify and prioritize asset repl ) in many rate submissions by to posidered by the electricity indu- nuse to justify and prioritize to Technical Report on Distribution he methodology to take into co- he effect of distribution switched d Inspection) - Condition Factor	of-life switchgear units to main ach year PowerStream will inspe- ocations and priority are determ cess, and discussion and feedba ng. Background: The distribu ystem. As these units get older aced to maintain system reliabil	ect, review, and select a number nined based on the results from ack among Lines, System ition switchgear units are critical and their functionality and ity and customer service. The ave been used by many electric itted to the Ontario Energy lel and methodology are a tools and process that a listribution assets. An extract a attached. This document mation to calculate the health meters (e.g. Age, Infrared
2. General Project Information (OEB)	Contributed Capital Fiscal Year Parent WO#	Contributed	l Capital 0%		
3. General Information on the	Job Number Risks to Completion and Risk Mana	gement Risk: Eluctur	ation in cost and staff resource	s (internal and external) to com	nlete high annual volume of
Project/Activity (OEB)		work. Risk Manag replacemen of the switc manage the logistics, an	ement: PowerStream has budg t work load in 2014. Therefore hgear replacement program at risk are: meetings amongst all d resource requirements; regu	eted and is completing the sam	e level of switchgear or 2015 onward is a continuation quantity). Some of the tasks to project details, schedule, technical and operational
	Comparative Information on Equiv Historical Projects (if any)		m conducts field inspections ar		placement program. Each year e and select suitable candidates
	Total Capital and OM&A Costs for Renewable Energy Generation port Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	and locks.	The exact locations, schedule, a	on will include associated U/G to and logistics will be jointly deter hieve co-ordination of work and	mined by Lines, System Control,
	1a. Main Driver	This project switchgear	is part of PowerStream's long- units to maintain system reliab	oject is system reliability and cu term switchgear replacement p ility and customer service. On a ect suitable switchgear units for	rogram to replace end-of-life prioritized basis, each year
	1b. Priority and Reasons for Priority	population service to th to the level	is at end-of-life and requires re ne customers. If not replaced, t that is not manageable by Pow		system integrity and reliable et older and will fail more often the customers. In addition, the

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		10	0859	2015	6	Dollars
Direction		Project Name				
Project Summary	Report	<u> </u>	<u>S</u>	witchgear Replacemen	t Program - 2015 to 20:	<u>20</u>
	1c. Qualitative and Quantita Project and Project Alternat		Please refer to	explanation above.		
	2. Safety		on the unit or	lures pose safety risk to staff ar when the public is in close prov r rupture of the enclosure, whi	kimity to the unit. When the sw	vitchgear unit fails, there may
	<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperal</li> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>	bility	spilled onto th	e. e. pil-filled switchgear units, switc e ground. Because the oil-filled		
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics an Consequences of Asset Perf Deterioration or Failure:	d	subdivisions ar	witchgear units are used in dist nd commercial/industrial custo nd to reconfigure the distributic	mers. Switchgear units are uti	lized to isolate/control other
			established by are selected ba	verStream inspects padmount s the OEB Distribution System C ased on a combination of inspe The following factors are used t	ode and ESA Regulation 22/04 ction results ( physical condition	. Replacement "candidates" on) and a calculated asset
			<ul> <li>Equipment a</li> <li>Structural int</li> <li>Presence of '</li> <li>Condition of</li> <li>Condition of</li> </ul>	tegrity "hotspots" mechanical mechanism		
			Switchgear uni replaced	its that have been classified to	have a "poor" health index co	ndition are proposed to be
			switchgear pop PowerStream a	, 24, and 28 switchgear failures pulation will get older and will and not tolerable by the custor v, and select suitable switchgea	fail more often to the level tha ners. On a prioritized basis, ea	t is not manageable by
	1. Condition of Asset vs. Typ and Performance Record	bical Life Cycle	Useful Life of s	he Kinectrics Report "Asset Am witchgear is 30 years. Many un years and are expected to fail n	its of PowerStream's existing s	
			switchgear uni switchgear ena compared to the the cables are	f the switchgear will be replace its are sealed units and all inter ables these units to be relativel he switchgear they are replacir connected to the switchgear th ponent to dirt and moisture. SFG s are sealed.	nal live parts are encapsulated y free from contamination and g. SF6 switchgear are "dead fr prough insulated connectors th	I. The inherent design of SF6 I moisture issues, as ont" units which means that hus eliminating exposure of
	2. Number of Customers in Class Potentially Affected by		Approximately	17982. For the calculation of	this figure, please refer to 3. b	elow.
	3. Quantitative Customer In (frequency or duration of in and associated risk level)		For 36 switchg	f Failure is: 0.5 failure per year		
			<ul><li>934,458 CMI</li><li>Average num</li><li>Projected nu</li><li>Average CMI</li></ul>	012 Control Room data, there ober of customers affected by 1 mber of customers affected by for 1 failure is: 934,458/24 = 3 Al for 18 failures is: 38,936 x 18	failure is: 23,968/24 = 999 cu 18 failures is: 999 x 18 = 17,98 8,936 CMI	stomers
	satisfaction, customer migra associated risk level)	ation and	Switchgear fail inconvenience	lures have negative impact to s and financial loss to customers	ystem reliability and customer	oppage).
	5. Value of Customer Impac	t	High			Pg

		Р	Project Code		Report Start Ye	ear	Number of Yea	rs	Scale		
Power Stream	-		100	)859	20	)15	6	j	Do	llars	
			Project Name								
Project Summary Report				<u>S</u>	witchgear R	Replacemen	t Program - :	2015 to 202	<u>20</u>		
	Factors Affecting Project Timi		ng, if any	Not Applicable	·.						
	Factors Affecting Project Timing, if any Consequences for O&M System Costs Including Implications of Not Implementing Reliability and Safety Factors Analysis of Project Benefits and Costs with Alternative Comparison (if the project is "like for like" renewal and has been configured at extra cost, provide an			<ul> <li>O&amp;M Cost for 1 emergency switchgear failure replacement = \$98,800 per failure</li> <li>O&amp;M Cost for 18 emergency switchgear failure replacement = \$98800 x 18 = \$1,778,400</li> <li>This project is part of the long-term switchgear replacement program. The project will help avoid a of 18 switchgear failures and 700,848 potential CMI. The project will also help reduce some safety (potential personal injury) that may result due to switchgear failures.</li> <li>Costs with This project is part of the long-term switchgear replacement program. The project will help avoid a of 18 switchgear failures and 700,848 potential CMI. The project will also help reduce some safety (potential personal injury) that may result due to switchgear failures.</li> </ul>							
		ra cost, provi	been	(potential pers		it may result du	e to switchgear	failures.			
	configured at extr analysis of project 2011	ra cost, provi t benefits) 2012	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018	2019		
enditures Historical/Planned	configured at extr analysis of project	ra cost, provi t benefits)	been ide an 2013	2014	onal injury) tha 2015	2016		2018			
enditures Historical/Planned	configured at extr analysis of project 2011	ra cost, provi t benefits) 2012 662,337	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018			
enditures Historical/Planned	configured at extr analysis of project 2011 \$ 566,295 \$	ra cost, provi t benefits) 2012 662,337	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018			
enditures Historical/Planned	configured at extr analysis of project 2011 \$ 566,295 \$ \$3,000,000	ra cost, provi t benefits) 2012 662,337	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018			
enditures Historical/Planned	configured at extranalysis of project         2011         \$ 566,295 \$         \$3,000,000         \$2,500,000         \$2,000,000	ra cost, provi t benefits) 2012 662,337	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018			
enditures Historical/Planned	configured at extranalysis of project         2011         \$ 566,295 \$         \$3,000,000         \$2,500,000         \$2,000,000         \$1,500,000	ra cost, provi t benefits) 2012 662,337	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018		2020 \$ 2,681,	
enditures Historical/Planned	configured at extranalysis of project         2011         \$ 566,295 \$         \$3,000,000         \$2,500,000         \$2,000,000	ra cost, provi t benefits) 2012 662,337 \$	been ide an 2013	2014	onal injury) tha 2015	2016	2017	2018			

	Proj	ect Code		Report Start Year	Number of Years	Scale
Power Stream	5	101800	1	2015	6	Dollars
Direan	Proj	ect Name				8
Project Summar	-		orm dama	age - Replacement of	distribution equipment of	<u>due to storm.</u>
	<b>Г</b>					
Major Category Project Overview	System Renewal					
1. Additional Information	Service Territory	Pov	werStream S	outh		
	Location	Pov	werStream S	outh - (Vaughan, Markham, F	lichmond Hill, Aurora)	
	Scope	pol dist ligh dist	es, transfori tribution sys htning, or an tribution sys	ners, conductors, and switch tem can be impacted by sign y combination thereof. Such	es, that are damaged during sto ficant weather events involvin weather events can cause sign omponents are replaced prom	g wind, snow, ice, sleet, hail, ificant damage to the
	Justification	disr gen any	ruption to o neral public.	ptimal system operation, and In such events, therefore, fai	o distribution systems, resultir can also create safety hazards ed distribution equipment is p ers, and return the system to i	for utility personnel and the promptly replaced to remove
2. General Project Information (OEB)	Contributed Capital		ntributed Ca	pital 0%		
	Fiscal Year	201	15			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Mar	nagement Not	t Applicable			
	Comparative Information on Equ Historical Projects (if any)	iivalent For	actual histo	prical information for Powerst	ream South - Please see chart	and graph below.
	Total Capital and OM&A Costs for Renewable Energy Generation po Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary	pol dist ligh dist	es, transfori tribution sys itning, or an tribution sys	ners, conductors, and switch tem can be impacted by sign y combination thereof. Such	es, that are damaged during sto ficant weather events involvin weather events can cause sign omponents are replaced prom	g wind, snow, ice, sleet, hail, ificant damage to the
	1a. Main Driver	Safe	ety. Damag	e due to storms that exceed t	he rated design capacity of the	e equipment.
	1b. Priority and Reasons for Prior		t Applicable			4
	1c. Qualitative and Quantitative A Project and Project Alternatives	Analysis of Not	t Applicable			
	2. Safety	Not	t Applicable			
	3. Cyber-Security, Privacy	Not	t Applicable			
	4. Coordination, Interoperability		t Applicable			
	5. Economic Development 6. Environmental Benefits		t Applicable			
5. Category-Specific Requirements for	6. Environmental Benefits Description of the Relationship be		t Applicable		a already failed or been damag	ged by the storms, this Project
Each Project/Activity (OEB)	the Asset Characteristics and Consequences of Asset Performa Deterioration or Failure:	is th			on assets to safe operating cor	
	<ol> <li>Condition of Asset vs. Typical L and Performance Record</li> <li>Number of Customers in Each of Class Potentially Affected by Asset</li> </ol>	Customer 0	t Applicable			
	3. Quantitative Customer Impacts (frequency or duration of interru and associated risk level)	s Not	t Applicable			
	4. Qualitative Customer Impacts ( satisfaction, customer migration a		t Applicable			
	associated risk level)					Pg

		1	Project Code		Report Start Ye	ear	Number of Year	rs	Scale	
Power Stream	5		101	1800	20	)15	6	i	Dol	llars
			Project Name		-				_	
Project Summary R	Project Summary Report			Storm dama	age - Repla	cement of d	istribution ed	quipment di	ue to storm.	<u>.</u>
5	. Value of Custo	omer Impact		Low						
F	actors Affecting	g Project Timi	ing, if any	Not Applicable						
Ir	Consequences fo ncluding Implica mplementing			Not Applicable						
A A	Reliability and Sa Analysis of Proje Alternative Com like for like" rer	ect Benefits an Iparison (if th	nd Costs with e project is	Not Applicable Assets and Equ		ed under this Pro	oject are always	"like for like" r	enewal.	
c	onfigured at ex inalysis of proje		vide an							
c			vide an 2013	2014	2015	2016	2017	2018	2019	2020
c a	nalysis of proje	ect benefits)	2013	<b>2014</b> \$ 1,158,364						
c a	nalysis of proje 2011	2012 306,122	2013							
c a	2011 \$ 297,226 \$ \$1,400,000	ect benefits)         2012         306,122	2013							
c a	2011 \$ 297,226 \$ \$1,400,000 \$1,200,000	2012 306,122	2013							
c a	2011 \$ 297,226 \$ \$1,400,000	2012 306,122	2013							
c a	2011 \$ 297,226 \$ \$1,400,000 \$1,200,000	2012         306,122	2013							
c a	2011 297,226 \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000	2012         306,122	2013							
c a	2011 297,226 \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000	2012         306,122         )         -         )         -         )         -         )         -         )         -         )         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -	2013							
c a	2011 297,226 \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000	2012         306,122         )         -         )         -         )         -         )         -         )         -         )         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -         -	2013							
c a	2011 297,226 \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000	2012         306,122	2013							

	Pr	roject Code		Report Start Year	Number of Years	Scale
Power Stream	-	101	1860	2015	6	Dollars
oncan	Pr	roject Name				•
Project Summar		-	Storm dam	age - Replacement of	distribution equipment c	lue to storm.
Major Catagory	System Renewal					
Major Category Project Overview	System Renewal					
1. Additional Information	Service Territory		PowerStream I	North		
	Location		PowerStream	North		
	Scope		poles, transfor distribution sys lightning, or ar distribution sys	mers, conductors, and switch stem can be impacted by sign by combination thereof. Such	ergency replacement of major es, that are damaged during sto ficant weather events involving weather events can cause signi components are replaced prom ds over the past few years.	orm activity. PowerStream's g wind, snow, ice, sleet, hail, ificant damage to the
	Justification		disruption to o general public.	ptimal system operation, and In such events, therefore, fai	o distribution systems, resultin can also create safety hazards led distribution equipment is p ers, and return the system to i	for utility personnel and the romptly replaced to remove
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2015			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk N	lanagement	Not Applicable			
	Comparative Information on E Historical Projects (if any)	quivalent	For actual histo	prical information for Powers	ream North - Please see chart a	and graph below.
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Expenditures in	n this category are for the em	ergency replacement of major	line distribution assets, such as
	1a. Main Driver		Safety. Damag	e due to storms that exceed t	he rated design capacity of the	e equipment.
	1b. Priority and Reasons for Pri	iority	Not Applicable			
	1c. Qualitative and Quantitative Project and Project Alternative		Not Applicable			
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabilit	ty	Not Applicable			
	5. Economic Development		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ul> <li>6. Environmental Benefits</li> <li>Description of the Relationship the Asset Characteristics and</li> <li>Consequences of Asset Perforn</li> <li>Deterioration or Failure:</li> </ul>			pertaining to this Project hav	e already failed or been damag on assets to safe operating con	
	1. Condition of Asset vs. Typica and Performance Record	I Life Cycle	Not Applicable			
	2. Number of Customers in Eac Class Potentially Affected by As		0			
	3. Quantitative Customer Impa (frequency or duration of inter and associated risk level)		Not Applicable			
	<ol> <li>Qualitative Customer Impact satisfaction, customer migratio associated risk level)</li> </ol>		Not Applicable			
	5. Value of Customer Impact		Low			
	Factors Affecting Project Timin	g, if any	Not Applicable			
	Consequences for O&M System Including Implications of Not Implementing	n Costs	Not Applicable			Pg
	,					' 9

		F	Project Code		Report Start	Year	Number of Ye	ars	Scale	
Power Stream			101	.860	2015		6		Dollars	
Project Summary Report		Project Name	Storm dam	age - Rep	acement of	distribution e	equipment d	<u>ue to storm.</u>		
	Reliability and Analysis of Pro Alternative Cou "like for like" ro configured at e analysis of pro	ject Benefits ar mparison (if the enewal and has extra cost, prov	e project is s been	Not Applicable Assets and Equ		ced under this P	roject are alway	s "like for like" r	renewal.	
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ 131,192 \$	\$ 176,789	\$ 95,186	\$ 1,686	\$ 209,93	7 \$ 209,663	\$ \$ 212,173	\$ 212,542	\$ 214,409	\$ 214,0
	\$250,000									
	\$200,000						1			
	\$200,000 \$150,000									
	\$150,000									

	Project Cod	e	Report Start Year	Number of Years	Scale
Power Stream		101808	2015	6	Dollars
	Project Nan	ne			
Project Summary	y Report	Switchgears -	Unscheduled Replace	ment of Failed Distribut	tion Equipment
Major Category	System Renewal				
Project Overview					
1. Additional Information	Service Territory	PowerStream			
	Location		South - (Vaughan, Markham, R		
	Scope	system. Switch can be section protect under transfers, isola outage situation serviceable eq	are covers the cost of emergene ngear units are key components alised or tied together. They ca ground cables that serve custor ation for planned or emergency ons. Failed switching units are r uipment in order to restore po figuration. This budget is based	s on a distribution system, pro- in also contain a combination mer locations. These switchgea work, and switching operation emoved from the distribution wer to customers and return t	viding points where feeders of fuses or breakers that ar units facilitate load ns to restore power during system and are replaced with he system to its normal
	Justification	customer outa switching loca imperative for	itchgear equipment has an adv ages and mainline feeders can a tions, a switchgear failure has a a failed unit to be replaced im its normal operating state.	lso be affected. Because switc an adverse impact on system o	hgear units provide strategic peration. Therefore, it is
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manageme	risks to safety	of associated equipment (cable and speedy equipment replace le replacing equipment and res	ment. Crews analyse and deal	with hazards on a case-by-
	Comparative Information on Equivalent Historical Projects (if any)		gear units are replaced each ye uture planned expenditures.	ear on an emergency basis, and	d the historic costs are the
	Total Capital and OM&A Costs for Renewable Energy Generation portion o Projects (if any)	O			
4. Evaluation Criteria (OEB)	Project Summary	-	ear typically results in custome estore power to customers.	r outages. The failed equipme	nt is repalced promptly with a
	1a. Main Driver	Safety. Outag	e restoration.		
	1b. Priority and Reasons for Priority		of failed equipment is a top prie stem to its normal operating co		
	1c. Qualitative and Quantitative Analysis Project and Project Alternatives		the failed switchgear promptly a abnomal operating state. This		ut power and the system
	2. Safety	Failed switchg replacement.	ear could present potential saf	ety risks, which are mitigated a	as part of the restoration and
	3. Cyber-Security, Privacy	Not Applicable	2.		
	4. Coordination, Interoperability	Not Applicable	2.		
	5. Economic Development		failed switchgear could have ar Ild be without power due to th		development, as business
5. Category-Specific Requirements for Each Project/Activity (OEB)	6. Environmental Benefits Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:	Not Applicable Not Applicable			
	1. Condition of Asset vs. Typical Life Cycle and Performance Record	e Not Applicable	2.		
	2. Number of Customers in Each Custom Class Potentially Affected by Asset Failur				

		Project Code	2	Report Start Ye	ar	Number of Yea	ars	Scale	
Power Stream	-	1	01808	20	15		6	Do	llars
		Project Nam	e						
Project Summary	/ Report	5	Switchgears -	Unschedule	ed Replace	ment of Fail	ed Distributi	on Equipmo	<u>ent</u>
	and associated risk	tion of interruptions	Rsk of failure is the proactive S	gear failures occ s higher with eq Switchgear Repla d switchgear wo	uipment of old acement Progra	er vintage. The am.	se units are targ	eted for replac	ement unde
	satisfaction, custom associated risk level	ner migration and		ing the equipme					
	5. Value of Custome	er Impact	High						
	Factors Affecting Pr	oject Timing, if any	Equipment is r	eplaced immedi	iately.				
	Consequences for C Including Implicatio Implementing		Not Applicable	2.					
	Reliability and Safet	ty Factors	Not replacing	equipment wou	ld have an adve	erse impact on i	reliability and pr	resent potentia	l safety risks
	Alternative Compar "like for like" renew		h Not Applicable	2.					
	Alternative Compar "like for like" renew configured at extra analysis of project b	rison (if the project is val and has been cost, provide an	h Not Applicable	2015	2016	2017	2018	2019	2020
<penditures historical="" planned<="" td=""><td>Alternative Compar "like for like" renew configured at extra analysis of project b 2011 2</td><td>rison (if the project is val and has been cost, provide an penefits)</td><td>2014</td><td></td><td></td><td></td><td></td><td></td><td></td></penditures>	Alternative Compar "like for like" renew configured at extra analysis of project b 2011 2	rison (if the project is val and has been cost, provide an penefits)	2014						
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project b 2011 2 \$ - \$ 1,5	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project to 2011 2 \$ - \$ 1,: \$1,800,000 -	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project b 2011 2 \$ - \$ 1,2 \$ 1,800,000 - \$1,600,000 -	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar         "like for like" renew         configured at extra         analysis of project b         2011       2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,400,000	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar         "like for like" renew         configured at extra         analysis of project b         2011       2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,200,000	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar         "like for like" renew         configured at extra         analysis of project b         2011       2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,400,000	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar         "like for like" renew         configured at extra         analysis of project b         2011       2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,2         \$       -       \$ 1,200,000	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project to 2011 2 \$ - \$ 1,: \$1,800,000 - \$1,600,000 - \$1,400,000 - \$1,200,000 - \$1,200,000 -	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project to 2011 2 \$ - \$ 1,7 \$1,800,000 - \$1,600,000 - \$1,400,000 - \$1,200,000 - \$1,000,000 - \$1,000,000 -	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar "like for like" renew configured at extra analysis of project to 2011 2 \$ - \$ 1,: \$1,800,000 - \$1,600,000 - \$1,200,000 - \$1,200,000 - \$1,000,000 - \$600,000 -	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					
xpenditures Historical/Planned	Alternative Compar         "like for like" renew         configured at extra analysis of project to         2011       2         \$       -       \$       1,2         \$       -       \$       1,2         \$       -       \$       1,2         \$       -       \$       1,2         \$       -       \$       1,2         \$       -       \$       1,2         \$       -       \$       1,200,000       -         \$       \$       1,200,000       -         \$       \$       \$       \$       -         \$       \$       \$       \$       -         \$       \$       \$       \$       -         \$       \$       \$       -       \$         \$       \$       \$       -       \$         \$       \$       \$       -       \$         \$       \$       \$       -       \$         \$       \$       \$       -       \$         \$       \$       \$       -       \$         \$       \$       \$       -       \$	rison (if the project is val and has been cost, provide an benefits) 2012 2013 197,589 \$ 1,580,28	2014	2015					

Instal		Project Code		Report Start Year	Number of Years	Scale
Perject Summary Report  Suitchagens - Unscheduled Replacement of Failed Distribution Equipment  Project Summary Report  Stroke Trainer  Project Summary Report  Stroke Trainer  Project Summary Report  Stroke Trainer  Addition of Summary  Stroke Trainer	Power Stream	10	01848	2015	6	Dollars
Second Progeno Control of the Control of Control of the Control of Control of Control of the Control of Contro Control of Control of Control of Control of Control of Control of		Project Name				
Project Overview         Additional information         Sortics Territory         Provestimate Name           1. Additional information         Sortics Territory         Provestimate Name         Provestimate Name           1. Subject Name         Sortics Territory         Provestimate Name         Provestimate Name           1. Subject Name         Sorge         Provestimate Name         Provestimate Name           2. Sorge         Provestimate Name         Provestimate Name         Provestimate Name           2. Sorge         Provestimate Na	Project Summar	ry Report <u>S</u>	witchgears -	Unscheduled Replace	ment of Failed Distribu	ition Equipment
Depict Overview         Additional Information         Sortical Territory         Prevent Arram Nuch           1. Additional Information         Sortical Territory         Prevent Arram Nuch         Prevent Arram Nuch           1. Additional Information         Screen         Prevent Arram Nuch         Prevent Arram Nuch           1. Additional Information         Screen         Prevent Arram Nuch         Prevent Arram Nuch           1. Additional Information         Screen         Prevent Arram Nuch         Prevent Arram Nuch           1. Additional Information         Screen         Prevent Arram Nuch         Prevent Arram Nuch           2. Screen         Screen         Prevent Arram Nuch         Prevent Arram Nuch           2. Screen         Screen         Prevent Arram Nuch         Prevent Arram Nuch           2. Screen         Screen         Prevent Arram Nuch         Screen Information Prevent Screen         Prevent Arram Nuch           2. Screen         Autimic of anticity Prevent Screen         Screen Information Prevent Screen         Prevent Screen         Prevent Screen           2. Screen Information on Prevent Screen         Prevent Screen         Prevent Screen         Prevent Screen         Screen Information on Prevent Screen           3. General Information on Prevent Screen         Prevent Screen         Prevent Screen         Prevent Screen	Major Category	System Renewal				
2. Additional Information         Service Transport         Service Transport           2. Genice         Service Transport         Service Transport         Service Transport           3. Genice         Service Transport         Service Transport         Service Transport           4. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport           5. Service Transport         Service Transport         Service Transport         Service Transport		.,				
Spin         Spin         Discrepatibility covers the out of energiency projectement of abids withing part with the output of a bins of interest proveer outputs of abids withing part with spin bits of abids with abids w	-	Service Territory	PowerStream	North		
2. General Project Information of the Capital C		Location	PowerStream	North		
2. General Project Information (OED) Contributed Capital Contributed Capital Contributed Capital OP as an adverse impact on ystem optication. The enclosed investigation of the system to its normal operating state. 3. General Project Information (OED) Contributed Capital Contributed Capital OP Capital Contributed Capital Con		Scope	system. Switch can be section protect under transfers, isola outage situation serviceable eq	ngear units are key components alised or tied together. They ca ground cables that serve custor ation for planned or emergency ons. Failed switching units are r uipment in order to restore po	s on a distribution system, pro in also contain a combination mer locations. These switchge work, and switching operation emoved from the distribution wer to customers and return	oviding points where feeders of fuses or breakers that ear units facilitate load ons to restore power during a system and are replaced wit the system to its normal
3. General Information on the Project/Activity (OEB)     Facal Year Parent WOB Job Number     2015       3. General Information on the Project/Activity (OEB)     Res to Completion and Risk Management Risk to Completion and Risk Management Risk to Completion and Risk Management Risk to Safety and speedy equipment and restoring power to customers as quickly as possible.       4. Evaluation Criteria (OEB)     Comparative Information on Equivalent Historical Projects (if any)     Several switchgear units are replaced each year on an emergency basis, and the historic costs an bistorical Projects (if any)       4. Evaluation Criteria (OEB)     Total Capital and OM&A Costs for Project (if any)     0       7. Evaluation Criteria (OEB)     Project Summary 1.0. Min Driver     Safety. Outge restoration.       1.0. Priority and Reasons for Priority 1.0. Priority and Reasons for Priority 1.0. Spec-Security, Privacy     Not replacing the failed switchgear promptly would leave customers without power and the syst would be in an abnomal operating configuration, and mitigate any potential safety risks.       5. Category-Specific Requirements for Each Project (if Reports)     Failed switchgear could present potential safety risks, which are mitigated as part of the syst would be in an abnomal operating configuration, and mitigate as part of the syst model be without power due to the failure.       5. Category-Specific Requirements for Friget and Project Information on Failures:     Not Applicable.       6. Condination, Interoperating to A specificable.     Not Applicable.       7. Category-Specific Requirements of Asset Freformance Each Project/JActivity (OEB)     Not Applicable.		Justification	customer outa switching loca imperative for	ages and mainline feeders can a tions, a switchgear failure has a a failed unit to be replaced im	lso be affected. Because swit in adverse impact on system of	chgear units provide strategic operation. Therefore, it is
3: General Information on the Project/Activity (DEB)       Parent WOF Job Number       Risk 10 Completion and Risk Management Risk 10 Comparitive Information on Equivalent Risk 10 Comparitive Information II Risk Management Risk 10 Comparitive Information Represent Risk 10 Comparitive Information II Risk 10 Comparitive Information II Risk 10 Comparitive II Risk 10 ComparitiII Risk 10 Comparitive II Risk 10 Comparitive II Risk 10	2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
3. General Information on the Project/Activity (OEB)       Parent WOP Job Number       Res 10 Completion and Risk Management Risk 10 Completion and Risk Management Field Switchgar units are replaced each year on an emergency basis, and the historic costs and basis for the future planned expenditures.         4. Evaluation Criteria (OEB)       Comparative Information on Equivalent Historical Projects (If any)       Several switchgar units are replaced each year on an emergency basis, and the historic costs and basis for the future planned expenditures.         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Nenewable Energy Generation portion of Projects (If any)       Parent WOP Fore Summary 12. Diority and Reasons for Priority       Falled switchgar units are replaced each year on an emergency basis, and the historic costs and basis for the future planned expenditures.         5. Evaluation Criteria (OEB)       In Diority and Reasons for Priority 12. Diority and Reasons for Priority       Falled switchgear cupical presults in customer outages. The failed equipment is an oppriority in order to restore power to affected customer replacement of Failed equipment is a top priority in order to restore power to affected customer scotter the system to its sommal operating configuration, and mitigate any potential safety risks, which are mitigated as part of the restoral Not Applicable.         5. Ectagory-Specific Requirements for Each Project Characteristics and Consequences of Asset Performance Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Description of the Relationship between and Performance Record Las Peterhalany Affectab		Fiscal Year	2015			
3. General Information on the Project/Activity (OEB)       Risks to Completion and Risk Manageem in the condition of associated equipment (cables, terminations, etc) and on-site conditions may principle caption of the condition of associated equipment (cables, terminations, etc) and on-site conditions may principle caption of the condition of associated equipment (cables, terminations, etc) and on-site conditions may principle caption of the condition of associated equipment and restoring power to customers as quickly as possible.         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Reinwolke Energy Generation portion of Projects (if any)       0         4. Evaluation Criteria (OEB)       Project Summary       Failed switchgear typically results in customer outages. The failed equipment is repalced prompt and measure in portion of Project (if any)         5. Cotegory-Specific Requirements for Priority and Reasons for Priority       Not replacing the failed switchgear could present potential safety risks. Which are mitigated as part of the restore power to affected custome restore the system to its normal operating configuration, and mitigate as part of the restore power to affected custome restore the system could be in an abnomal operating state. This afternative is not acceptable.         5. Category-Specific Requirements for Priority       Solyter-Security. Privacy       Not replacing failed switchgear could have an adverse impact on economic development, as bus customers ould be without power due to the failure.         5. Category-Specific Requirements for Description of the fleationship between the system could be without power due to the failure.       Not Applicable.         6. Environmental Benefits       No			-010			
3. General Information on the Project/Activity (OEB)       Risk to Completion and Risk Management Teplacement. (Cables, terminations, etc) and on-site conditions may prisk to safety and speedy equipment replacement. Crews analyse and deal with hazards on a case basis while replacing equipment and restoring power to customers as quickly as possible.         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (If any)       0         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (If any)       0         5. Category Specific Requirements for Each Category Specific Requirements for Project (If any)       Failed switchgear cupical equipment is to priority in order to restore power to affected custome restore the system to its normal operating configuration, and mitigate any potential safety risks.         5. Category Specific Requirements for Project Alternatives       Commerable Restrict Project Alternatives       Not replacing the failed switchgear could present potential safety risks, which are mitigated as part of the restoral customer Sould be in an abnomal operating configuration, and mitigate any potential safety risks.         5. Category Specific Requirements for Each Project Alternatives       Coordination, Interoperability       Not Applicable.         6. Environmental Benefits       Description of the Relationship between the system for Category Specific Requirements for Each Project Alternatives and Category of Asset Performance Ecced       Not Applicable.         1. Condition of Asset vs. Typlical Life Cycle       Not Applicable.       No						
4. Evaluation Criteria (OEB)       Historical Projects (if any)       basis for the future planned expenditures.         4. Evaluation Criteria (OEB)       Project Jummary       Failed switchgear typically results in customer outages. The failed equipment is repalced prompt         1a. Main Driver       Safety. Outage restoration.       Repalcement of failed equipment is a top priority in order to restore power to affected customer         1b. Priority and Reasons for Priority       Replacement of failed equipment is a top priority in order to restore power to affected customer         1c. Qualitative and Quantitative Analysis of Nor replacing the failed switchgear promptly would leave customers without power and the syst would be in an abnomal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restorat Not Applicable.         3. Coordination, Interoperability       Not Applicable.         5. Ectepory-Specific Requirements for Description of the Relationship between Each Project/Activity (OEB)       Ectivition of Asset vs. Typical Life Cycle and Performance Record 2.         1. Condition of Asset vs. Typical Life Cycle and Performance Record 2.       Not Applicable.         2. Subertially Affected by Asset Failures       Not Applicable.         3. Quantitative Customers in Each Customers in Ea			risks to safety	and speedy equipment replace	ment. Crews analyse and dea	I with hazards on a case-by-
A. Evaluation Criteria (OEB)       Renewable Energy Generation portion of Project Summary       Failed switchgear typically results in customer outages. The failed equipment is repalced prompt Ia. Main Driver         A. Evaluation Criteria (OEB)       Project Summary       Failed switchgear typically results in customer outages. The failed equipment is repalced prompt Ia. Main Driver         B. Priority and Reasons for Priority       Replacement of failed equipment is a top priority in order to restore power to affected custome restore the system to its normal operating configuration, and mitigate any potential safety risks.         I.C. Qualitative and Quantitative Analysis of Project Alternatives       Not replacing the failed switchgear promptly would leave customers without power and the syst would be in an abnomal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restoral 3. Cyber-Security, Privacy         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       E. Evironmental Benefits       Not Applicable.         5. Category-Specific Requirements for Failures       I. Condition of Asset vs. Typical Life Cycle       Not Applicable.         2. Sumber of Customers in Each Customer       200       200         2. Sugnitiative Customer in Each Customer       Several switchgear failures occur per anum, and replacement and restoration					ear on an emergency basis, an	d the historic costs are the
1a. Main Driver       Safety. Outage restoration.         1b. Priority and Reasons for Priority       Replacement of failed equipment is a top priority in order to restore power to affected custome restore the system to its normal operating configuration, and mitigate any potential safety risks.         1c. Qualitative and Quantitative Analysis of Project Alternatives       Not replacing the failed switchgear promptly would leave customers without power and the system vould be in an abnomal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restoral Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not Applicable.         6. Environmental Benefits       Not Applicable.         Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Deterioration or Failure:       200         2. Quantitative Customer in Each Customer Class Potentially Affected by Asset Failures       Several switchgear failures occur per annum, and replacement and restoration can take several Rs of failure is higher with equipment of older vintage. These units are targeted for replacement		Renewable Energy Generation portion of	0			
1b. Priority and Reasons for Priority       Replacement of failed equipment is a top priority in order to restore power to affected custome restore the system to its normal operating configuration, and mitigate any potential safety risks.         1c. Qualitative and Quantitative Analysis of Project Alternatives       Not replacing the failed switchgear promptly would leave customers without power and the system to its normal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restoral 3. Cyber-Security, Privacy         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Oroget Consequences of Asset Performance Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cyce and Performance Deterioration or Failure:       Not Applicable.         3. Quantitative Customer Impacts (frequency or duration of interruptions)       Several switchgear failures occur per annum, and replacement and restoration can take several Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement	4. Evaluation Criteria (OEB)	Project Summary	Failed switchg	ear typically results in custome	r outages. The failed equipme	ent is repalced promptly with
Sector       1.c. Qualitative and Quantitative Analysis of Project and Project Alternatives       Not replacing the failed switchgear promptly would leave customers without power and the syst would be in an abnomal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restoral 3. Cyber-Security, Privacy         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not Applicable.         6. Environmental Benefits       Not Applicable.         9. Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle       Not Applicable.       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle       Not Applicable.       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle       Not Applicable.       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle       Not Applicable.       200         2. Number of Customers in Each Customer       200       200         3. Quantitative Customer Impacts (frequency or duration of Interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several Insk of failure is higher with equipment of older vintage. These units are targeted for replac		1a. Main Driver	Safety. Outag	e restoration.		
Project and Project Alternatives       would be in an abnomal operating state. This alternative is not acceptable.         2. Safety       Failed switchgear could present potential safety risks, which are mitigated as part of the restoral Not Applicable.         3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Environmental Benefits       Not Applicable.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.       Not Applicable.         2. Number of Customers in Each Customer       200       200         3. Quantitative Customer Impacts (requency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several and restoration can take several and restoration or prelacement of older vintage. These units are targeted for replacement		1b. Priority and Reasons for Priority				
3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not replacing failed switchgear could have an adverse impact on economic development, as bus customers could be without power due to the failure.         6. Environmental Benefits       Not Applicable.         Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.         2. Number of Customers in Each Customer       200         3. Quantitative Customer Impacts (frequency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several Insert of older vintage. These units are targeted for replacement						
3. Cyber-Security, Privacy       Not Applicable.         4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not replacing failed switchgear could have an adverse impact on economic development, as bus customers could be without power due to the failure.         6. Environmental Benefits       Not Applicable.         Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.         2. Number of Customers in Each Customer       200         3. Quantitative Customer Impacts (frequency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several Increase of a set and performance and performance in the several Increase of the provide the providet the provide the provide the provide the provide the p		2. Safety	Failed switche	ear could present potential safe	ety risks, which are mitigated	as part of the restoration and
4. Coordination, Interoperability       Not Applicable.         5. Economic Development       Not replacing failed switchgear could have an adverse impact on economic development, as bus customers could be without power due to the failure.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.       Not Applicable.         2. Number of Customers in Each Customer Class Potentially Affected by Asset Failure       Not Applicable.       200         3. Quantitative Customer Impacts (frequency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several In Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement			-		,,	,
5. Economic Development       Not replacing failed switchgear could have an adverse impact on economic development, as bus customers could be without power due to the failure.         5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.       Not Applicable.         3. Quantitative Customer Impacts (frequency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several I Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement						
5. Category-Specific Requirements for Each Project/Activity (OEB)       Description of the Relationship between the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:       Not Applicable.         1. Condition of Asset vs. Typical Life Cycle and Performance Record       Not Applicable.         2. Number of Customers in Each Customer Class Potentially Affected by Asset Failure       Not Applicable.         3. Quantitative Customer Impacts (frequency or duration of interruptions       Several switchgear failures occur per annum, and replacement and restoration can take several I Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement			Not replacing	failed switchgear could have ar		c development, as business
Each Project/Activity (OEB) the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure: 1. Condition of Asset vs. Typical Life Cycle and Performance Record 2. Number of Customers in Each Customer Class Potentially Affected by Asset Failure 3. Quantitative Customer Impacts (frequency or duration of interruptions Several switchgear failures occur per annum, and replacement and restoration can take several l Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement		6. Environmental Benefits	Not Applicable	2.		
and Performance Record 2. Number of Customers in Each Customer Class Potentially Affected by Asset Failure 3. Quantitative Customer Impacts (frequency or duration of interruptions Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement		the Asset Characteristics and Consequences of Asset Performance	Not Applicable	2.		
<ul> <li>2. Number of Customers in Each Customer</li> <li>200</li> <li>Class Potentially Affected by Asset Failure</li> <li>3. Quantitative Customer Impacts (frequency or duration of interruptions</li> <li>Several switchgear failures occur per annum, and replacement and restoration can take several l Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement</li> </ul>			Not Applicable	2.		
(frequency or duration of interruptions Rsk of failure is higher with equipment of older vintage. These units are targeted for replacement		2. Number of Customers in Each Customer	200			
			Rsk of failure i	s higher with equipment of old	er vintage. These units are ta	

		Р	Project Code		Report Start Y	ear	Number of Yea	irs	Scale	
Power Stream	-		101	1848	20	)15	e	5	Dol	llars
		P	Project Name							
Project Summar	ry Report	Ļ	<u>S</u> 1	witchgears -	Unschedu	ed Replace	ment of Faile	ed Distribut	ion Equipme	ent
	4. Qualitative Cu satisfaction, cust associated risk le	tomer migratio			-		nave a significan ould have a dele			
	5. Value of Custo			High						
	Factors Affecting		ng, if any	Equipment is r	eplaced immed	liately.				
	Consequences fo Including Implica Implementing		m Costs	Not Applicable	2.					
	Reliability and Sa	afety Factors		Not replacing e	equipment wou	Ild have an adve	erse impact on r	eliability and p	resent potentia	l safety risk
	Alternative Com "like for like" rer	newal and has	s been							
		newal and has tra cost, provi	s been	2014	2015	2016	2017	2018	2019	2020
enditures Historical/Planned	"like for like" rer configured at ex analysis of proje	newal and has tra cost, provi ect benefits)	s been ide an 2013							
oenditures Historical/Planned	"like for like" rer configured at ex analysis of proje 2011 \$ - \$	newal and has tra cost, provi cct benefits) 2012	s been ide an 2013							<b>2020</b> \$ 130,
penditures Historical/Planned	"like for like" rer configured at ex analysis of proje	newal and has tra cost, provi cct benefits) 2012	s been ide an 2013 \$ 82,718							
penditures Historical/Planned	<pre>"like for like" rer configured at ex analysis of proje 2011 \$ - \$ \$250,000</pre>	newal and has tra cost, provi cct benefits) 2012	s been ide an 2013							
enditures Historical/Planned	<pre>"like for like" rer configured at ex analysis of proje 2011 \$ - \$ \$ \$250,000 \$200,000</pre>	newal and has tra cost, provi cct benefits) 2012	s been ide an 2013 \$ 82,718							
penditures Historical/Planned	"like for like" rer         configured at ex         analysis of proje         2011         \$       -         \$       -         \$250,000         \$200,000         \$150,000	newal and has tra cost, provi cct benefits) 2012	s been ide an 2013 \$ 82,718							

	Project	t Code		Report Start Year	Number of Years	Scale
Power	<b>S</b>	1018	24	2015	6	Dollars
Sirean	Project	Name				
Project Summar		. Hume	<u>Unsch</u>	eduled Replacement of	Failed Equipment - Po	les, etc
Major Category Project Overview	System Renewal					
Project Overview 1. Additional Information	Service Territory	Р	owerStream S	South		
	Location	Р	owerStream S	outh - (Vaughan, Markham, R	chmond Hill, Aurora)	
	Scope	c e T c ti v p	omponents fa equipment is re hese conditio alls from mem hermographic vhere equipmo personnel and	il. In some cases, particularly v eplaced on an emergency basis ins are usually identified during obers of the public. Inspections scanning, which reveals "hot s ent has deteriorated to the po public safety and system reliab	regular inspections, during "d can take the form of planned pots" due to deterioration of	ectors, and transformers, the ate where failure is imminent. Irive-bys" by field crews, or by line patrols or infra-red live components. In cases there are potential threats to ent is also promptly replaced.
	Justification	t ir	he safety and mmediately to	integrity of the distribution systematics restore power to customers,	in outages to customers, but a stem. Therefore, such failed eq remove any safety hazards, an	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	ng configuration. pital 0%		
	Fiscal Year	2	015			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manag	r	eplacement. C		zards on a case-by-case basis v	and speedy equipment while replacing equipment and
	Comparative Information on Equiva Historical Projects (if any)		listorical numl expenditures.	per of events and associated co	osts are the basis for estimatin	g future planned
	Total Capital and OM&A Costs for Renewable Energy Generation porti Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary				rmers, and accessories) is repla	
	1a. Main Driver	р	promptly with	a new asset to restore power t		
	1b. Priority and Reasons for Priority				prity in order to restore power nfiguration, and eliminate any	
	1c. Qualitative and Quantitative Ana Project and Project Alternatives	alysis of T	here are no vi	able alternatives to the promp	t replacement of failed equipr	nent.
	2. Safety	S	afety could be	e adversely impacted by not pr	omptly undertaking the replac	ement of failed assets.
	3. Cyber-Security, Privacy	N	ot Applicable			
	4. Coordination, Interoperability	Ν	lot Applicable			
	5. Economic Development	Ν	lot Applicable			
	6. Environmental Benefits	Ν	lot Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relationship betw the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:		lot Applicable			
	1. Condition of Asset vs. Typical Life and Performance Record	Cycle N	lot Applicable			
	2. Number of Customers in Each Cus Class Potentially Affected by Asset F		.000 (typically)			
	3. Quantitative Customer Impacts (frequency or duration of interruption and associated risk level)		/aries			

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			101	1824	2	015		6	Dol	lars
			Project Name							
Project Summar	y Report		-	<u>Unsch</u>	eduled Rep	lacement of	Failed Equ	iipment - Po	<u>les, etc</u>	
	4. Qualitative Cus satisfaction, custo associated risk lev	omer migrat		Customer satis equipment fail		be adversely im	pacted if power	r was not restor	ed promptly fol	lowing
	5. Value of Custor			High						
	Factors Affecting			Failed equipme	ent is replaced	promptly.				
	Consequences for Including Implicat Implementing			Not Applicable						
	Reliability and Sa	fety Factors	i	Not replacing e hazards.	equipment imr	nediately would	adversely impa	act reliability an	d potentially cre	eate safety
	Analysis of Projec Alternative Comp "like for like" rem configured at ext analysis of projec	earison (if th ewal and ha ra cost, prov	ie project is is been	Not Applicable						
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
enditures Historical/Planned	\$ 5,472,537 \$	3,771,533	\$ 4,051,060	\$ 4,157,571	\$ 4,004,267	\$ 4,136,745	\$ 4,195,526	\$ 4,298,340	\$ 4,349,171	\$ 4,266,
	\$6,000,000									
	\$5,000,000									
	\$4,000,000									
	40.000.000									
	\$3,000,000									
	\$3,000,000									

	Proje	ct Code	Report Start Year	Number of Years	Scale
Power	<b>X</b>	101844	2015	6	Dollars
Stream	Proje	ct Name			
Project Summary			duled Replacement of	Failed Distribution Equip	- Poles, Etc.
Major Category Project Overview	System Renewal				
Project Overview 1. Additional Information	Service Territory	PowerStrea	m North		
	Location	PowerStrea	m North		
	Scope	-		ductors, devices and transforme	
		equipment These cond calls from n thermograp where equi	is replaced on an emergency li itions are usually identified du nembers of the public. Inspect shic scanning, which reveals "h pment has deteriorated to the	ly with poles, terminations, conr pasis if they are found to be in a s ring regular inspections, during " ions can take the form of planne tot spots" due to deterioration of point where failure is imminent eliability. Therefore, such equipm	state where failure is imminent. 'drive-bys" by field crews, or by d line patrols or infra-red f live components. In cases , there are potential threats to
	Justification	the safety a immediatel	nd integrity of the distribution y to restore power to custome	ults in outages to customers, but a system. Therefore, such failed e rs, remove any safety hazards, a	equipment is replaced
2. General Project Information (OEB)	Contributed Capital		rating configuration. I Capital 0%		
	Fiscal Year Parent WO#	2015			
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Man	replacemer		n hazards on a case-by-case basis	
	Comparative Information on Equi Historical Projects (if any)	valent Historical n expenditure		d costs are the basis for estimati	ng future planned
	Total Capital and OM&A Costs for Renewable Energy Generation po Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary	Failed equi	oment (poles, conductors, trar	sformers, and accessories) is rep	laced with new assets.
	1a. Main Driver	promptly w	ith a new asset to restore pow		
	1b. Priority and Reasons for Priori			priority in order to restore powe g configuration, and eliminate an	
	1c. Qualitative and Quantitative A Project and Project Alternatives	nalysis of There are n	o viable alternatives to the pro	ompt replacement of failed equip	oment.
	2. Safety	Safety could	d be adversely impacted by no	t promptly undertaking the repla	acement of failed assets.
	3. Cyber-Security, Privacy	Not Applica	ble		
	4. Coordination, Interoperability	Not Applica	ble		
	5. Economic Development	Not Applica			
	6. Environmental Benefits	Not Applica			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relationship be the Asset Characteristics and Consequences of Asset Performan Deterioration or Failure:		d below.		
	1. Condition of Asset vs. Typical Li and Performance Record			ram are in a failed state.	
	2. Number of Customers in Each C Class Potentially Affected by Asset		ally)		
	3. Quantitative Customer Impacts (frequency or duration of interrup and associated risk level)			type of asset that has failed, loca oad interrupted at the time of fa	

			Project Code		Report Start Ye	ar	Number of Yea	ars	Scale	
Power Stream			101	1844	20	15		6	Do	llars
			Project Name							
Project Summar	y Report			<u>Unschedu</u>	led Replace	ment of Fai	led Distribu	<u>tion Equip -</u>	Poles, Etc.	
	4. Qualitative ( satisfaction, cu associated risk	istomer migrat		Customer satis equipment fail		e adversely im	pacted if power	r was not restore	ed promptly fo	llowing
	5. Value of Cus			High						
	Factors Affection		The programm				fined start and e ling, weather co		-	
	Consequences Including Impli Implementing							l distribution sys to capital than C		it have alre
	Alternative Co	ject Benefits a	and Costs with ne project is	Not Applicable Failed overhea		ystem assets re	placed under t	his programme a	are "like for like	2".
	configured at e analysis of pro	extra cost, prov	vide an							
	configured at e	extra cost, prov	vide an 2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	configured at e analysis of pro	extra cost, prov ject benefits) 2012	2013					<b>2018</b> \$ 1,059,941		
penditures Historical/Planned	configured at e analysis of pro 2011 \$ 1,052,550	extra cost, prov ject benefits) 2012 \$ 1,107,423	2013							
penditures Historical/Planned	configured at e analysis of pro 2011	2012 \$ 1,107,423	2013							
penditures Historical/Planned	configured at e analysis of pro 2011 \$ 1,052,550 \$ \$1,200,000	2012 \$ 1,107,423 0 0	2013							
penditures Historical/Planned	configured at e analysis of program         2011         \$ 1,052,550         \$ 1,052,550         \$ 1,200,000         \$ 1,000,000         \$ 800,000         \$ 600,000	extra cost, providenti cos	2013							
penditures Historical/Planned	configured at e analysis of pro           2011           \$ 1,052,550           \$ 1,200,000           \$ 1,000,000           \$ 8800,000           \$ 6600,000           \$ 4400,000	extra cost, providente         get benefits)         2012         \$ 1,107,423         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	2013							
penditures Historical/Planned	configured at e analysis of program         2011         \$ 1,052,550         \$ 1,052,550         \$ 1,200,000         \$ 1,000,000         \$ 800,000         \$ 600,000	extra cost, providente         get benefits)         2012         \$ 1,107,423         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	2013							<b>2020</b> \$ 1,039,

	Project	Code	Report Start Year	Number of Years	Scale
Power	5	100867	2015	6	Dollars
Sneum	Project	Name			
Project Summar	y Report		Pole Replacement Pi	rogram - 2015 to 2020	
Major Category	System Renewal				
Project Overview					
1. Additional Information	Service Territory Location Scope	Various locatio	North & South ons in PowerStream 0 poles, including approx. 370	pole replacements and approv	x. 30 pole reinforcements.
	Justification	them (conduct pole's physical intended func protect public replaced. One C22.3 No. 1-10 pole structure or replaced". Every year, on to the pole co PowerStream' requirements. PowerStream two categories Category 1: Po the requireme Category 2: Po rot, decay, spl which pose a s In 2014 Power 25-30% of rep situations such removed in ne Proposed Rem It is expected results will sho To address the approx. 370 re	has deteriorated to 60% of the a prioritized basis, a number of nditions and remaining strengt s goals to maintain public & sta will select the annual pole repl s: uses that have less than 60% re- ent of CSA Standard C22.3 No. 2 when that have more than 60% re- itting, insect infestation, bendi safety risk to employees and pu- Stream completed a pilot proj- lacement cost. The reinforcem- n as poles with butt decay, crac- ter future due to road widening that as the existing poles age a by a number of poles in poor co- e pole condition concern, it is re- endation poles and approx. 3 rogram will be an on-going pro-	reet lights, telecommunication gth deteriorate, the pole may o maintain the integrity of the ram has revealed that a numb ment is "percent remaining st ard C22.3 No. 1-10 states that e required design capacity, the of poles are proposed for repla h. The pole remediation will h aff safety, system reliability, ar accement and reinforcement of maining strength which are ne L-10 Clause 8.3.1.3. emaining strength but exhibit ng and leaning, and present a ublic. ect on pole reinforcement. Po ent method is cost effective an k at ground level, carpenter a g. nd deteriorate, on a rolling ba ondition and requiring replace ecommended to remediate 40 30 reinforcement poles. It is ex-	n attachments, etc.). As a become inadequate for its distribution system, and to ber of poles need to be trength" as per CSA Standard "when the strength of a wood e structure shall be reinforced accement or reinforcement due have positive impact on and to meet OEB & CSA candidates from the following meded to be addressed to meet worsening conditions such as high probability of failure le reinforcement cost is only and suitable for a certain nts, poles that will be usis, inspection and testing ement or reinforcement. D0 poles per year, including xpected that the pole
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year Parent WO# Job Number	2015			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manag	work. Risk Managerr replacement e pole remediat amongst all in requirements;	on in cost and staff resource (in nent: In 2013 & 2014 PowerStra each year. Therefore the propo- ion program at the same level. volved parties to go over the p regular progress meetings to a get performance is monitored,	eam budgeted, and completed sed annual budget for 2015 or Some of the tasks to manage roject details, schedule, logist ensure technical and operation	the same level of pole nward is a continuation of the the risk are: meetings ics, and resource
	Comparative Information on Equiva Historical Projects (if any)	PowerStream PowerStream	the continuation of PowerStre budgeted, and completed the conduct field inspection and us replacement or reinforcemen	same level of pole replacements the inspection result to price	nt each year. Each year
	Total Capital and OM&A Costs for Renewable Energy Generation portio Projects (if any)	0 on of			
4. Evaluation Criteria (OEB)	Project Summary	pole reinforce	proposed to remediate 400 pol ment. The exact locations, scho II, Capital Design, and System F uption.	edule, and logistics will be join	itly determined by Lines,
					Pa

	Project Code	Report Start Year	Number of Years	Scale
Power Stream	100867	2015	6	Dollars
	Project Name			
Project Summary Report		Pole Replacement Pr	<u>rogram - 2015 to 2020</u>	
1a. Main Driver	This project of-life poles	ompliance. The main driver for t is part of PowerStream's long-ter to maintain the integrity and saf tream will inspect, review, and s	rm pole remediation program ety of the distribution system.	to replace and reinforce end- On a prioritized basis, each
1b. Priority and Reasons for	end-of-life a to the public The risk of p rises directly sustaining it snow, ice an instantaneo normally pro deteriorates Because poli the conditio a substantia have sufficie equipment a deteriorates example) co	In has a very large quantity of wo nd requires replacement or reinf ole failure arising from pole conc as pole condition deteriorates. I load under normal operating co d wind loads, or external impact is loads which exceed the ability vide for a substantial margin of , this margin shrinks and eventue es are physically interconnected in of neighbouring poles. A series impact to one pole (for example nt load bearing capacity to supp t a safe distance above the grou , the reserve load bearing capaci uld produce instantaneous loads connected poles at the same tim	biocement in order to maintain dition (as distinct from other fa While a pole that is in poor co- onditions, the presence of any , acting individually or in comb of the pole to sustain. Pole d load bearing capacity over act ally disappears. by conductors, the risk of pole s of poles in good condition me a, due to a vehicle collision) be ort the damaged or severed p nd. However, as the conditior ty of the poles diminishes, and which create a domino effect	n system integrity and safety actors such as vehicle impacts) ondition may be capable of abnormal factors such as bination, may cause lesign and specifications ual or peak loads; as a pole e failure is also influenced by ay be capable of withstanding cause neighbouring poles ole and maintain energized n of interconnected poles d the same vehicle impact (for
	As such, safe the pole syst and clear of supporting t Total pole fa to the public the roadway In addition t reliability im associated fo	ences of pole failure primarily af clearances and limits of approa- em is to suspend equipment ope any potential approach or conta he equipment. ilure (i.e., the complete loss of st and utility workers. In addition, can result in vehicle damage. o immediate risks to safety, total pacts. Even under ideal environ seeders can interrupt power to hu epairs can be effected, any may o	ch are defined and must be me erating at high voltages at a sa ct by people, vehicles, or othe cructural integrity and function since many poles are adjacen pole failure also presents pot mental conditions, the loss of indreds or thousands of custor	aintained. A key function of fe height above the ground or objects, in addition to simply n) creates unacceptable risks at to roadways, a collapse into centially severe and prolonged one or more poles and the mers for several hours before
1c. Qualitative and Quantit of Project and Project Alter	· · · · · · · · · · · · · · · · · · ·	to above for details.		
2. Safety	or when the	pose safety risk to staff and the public in close proximity of the t ad transformer or overhead swite	unit. When the pole falls, there	
<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interopera</li> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>	Not Applicat In the case t	le.		

<b></b>		1				
_		Project Code		Report Start Year	Number of Years	Scale
Power Stream		100	0867	2015	6	Dollars
	-	Project Name				
Project Summary	/ Report			Pole Replacement Pr	ogram - 2015 to 2020	
Cotogony Charifie Dequirements for	Description of the Delations	hin botwoon	Through on on	nual increastion and testing pro	aron DowerStroom monitors	the condition of its poles to
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perfo Deterioration or Failure:	d	ensure that the PowerStream i Association ("C	nual inspection and testing pro ey meet minimum requiremen s guided in its pole assessmen (SA") Standard C22.3 No. 1-10,	ts for safety and reliability. Ar process by Clause 8.3.1.3 of C which states that:	nong other factors, Canadian Standards
				ength of a wood pole structure hall be reinforced or replaced"		e required design capacity,
			bending, and land here in the second se	rations include pole condition i eaning. PowerStream believes ary in view of compliance with workers operating in, on, or ar	that the replacement of poles the CSA code, as well as consi	exhibiting poor condition is iderations for safety of the
			The pole repla following two	cement and reinforcement car categories:	didates are selected based on	the combination of the
			meet the requ Category 2: Po rot, decay, spli	les that have less than 60% ren irement of CSA Standard Claus les that have more than 60% re tting, insect infestation, bendii s a safety risk to employees an	e 8.3.1.3. emaining strength but exhibit v ng, and leaning and present a	worsening conditions such as
	1. Condition of Asset vs. Typ and Performance Record	iical Life Cycle	Useful Life of v are older than is only one of t relatively your	ne Kinectrics Report "Asset Am vood poles is 45 years. There a 45 years and are expected to f the many factors affecting the g poles have deteriorated phy acking, leaning, bending.	re poles in PowerStream's exis ail if not replaced or reinforce ohysical condition of wood pol	sting pole population which d. It should be noted that age les. There are cases where
	2. Number of Customers in I Class Potentially Affected by		Approximately	2000. For details on the calcu	lation, please refer to 3. belov	v.
	3. Quantitative Customer Im (frequency or duration of in and associated risk level)		For 400 poles: • Frequency of • Estimated av	f Failure is: 0.05 failure per yea f Failure is: 0.05 failure x 400 = erage number of customers af ojected number of customers :	20 failures. fected by 1 failure is = 100 cus	
			CMI for 1 pole	erruption = 3 hours per interru failure = 100 customers x 3 ho e failures = 18,000 CMI x 20 = 3	ur x 60 min = 18,000 CMI	
	4. Qualitative Customer Imp satisfaction, customer migra associated risk level)			ave negative impact to system and financial loss to customer		•
	5. Value of Customer Impact		High			
	Factors Affecting Project Tin	ning, if any	Not Applicable			
	Consequences for O&M Syst Including Implications of No Implementing			r 1 emergency pole failure rep r 20 emergency pole failure re		
	Reliability and Safety Factor	S	pole failures a	part of the long-term pole rem nd 360,000 potential CMI. The /) that may result due to pole f	project will also help reduce so	
	Analysis of Project Benefits a Alternative Comparison (if t "like for like" renewal and h configured at extra cost, pro analysis of project benefits)	he project is as been	poorest condit	configured to be the lowest co ions. The main alternative wo r they fail. However, due to th tion.	uld be the "do nothing" option	n, and only to replace poles

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		100	0867	20	)15		6	Dol	llars
Project Summary	Report		Project Name		Pole Repl	lacement Pi	<u>ogram - 20</u>	<u>15 to 2020</u>		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$1,638,822	\$ 4,111,507	\$ 5,045,992	\$ 4,872,277	\$ 4,645,383	\$ 4,933,143	\$ 5,570,700	\$ 5,870,246	\$ 6,241,483	\$ 6,244,377
	\$7,000,4 \$6,000,4 \$5,000,4 \$4,000,4 \$3,000,4 \$2,000,4 \$1,000,4 \$1,000,4 \$1,000,4		2012	2013	2014	2015 20:	16 2017	2018	2019	2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		10:	1355	2015	6	Dollars
Project Summar		Project Name		Unforeseen Projects In	itiated by PowerStrean	<u>1</u>
Major Category	System Renewal					
Major Category Project Overview 1. Additional Information	System Renewal Service Territory Location Scope Justification		Unforeseen Pro safety, integrity In past 2011 th However, the 2 replacement p Unforeseen Pro and 40% North assets are bein immediate rep projects. *Asse Maintenance p	North and South Service Territo ojects: These projects addres and reliability of the system. E Emerging project South budg 2012 budget was reduced to \$5 roject was added to the project	s asset replacement or system get was \$777,248 and North bu 590,206 (South) and \$368,953 t portfolio. It is recommended herging portfolio is recommend ds will increase as the infrastru- al inspection and maintenance ldress the following projects: Switchgear, Elbow) identified nent candidates to maintain th	udget was \$616,065. (north) as an Emerging Cable to increase the budget for ded to be budgeted 60% South ucture is aging and more program that require *Overhead system upgrade by Inspection and ne system intergity and
2. General Project Information (OEB)	Contributed Capital Fiscal Year Parent WO#		Contributed Ca	apital 0%		
3. General Information on the Project/Activity (OEB)	Job Number Risks to Completion and Risk Comparative Information of Historical Projects (if any)		Experience has Not Applicable	shown that each year brings s	everal unforeseen concerns th	nat need immediate attention.
	Total Capital and OM&A Cos Renewable Energy Generatio Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			dget is intended to cover Unfo ade to maintain the safety,inte		
	1a. Main Driver		Annual inspect strategize and	ain driver for the project is safe ion results for assets such as p make appropriate remediatior lentified that need immediate	oles, switchgear, transformers plans for aging infrastructure	, etc. allow Engineering to
	1b. Priority and Reasons for	Priority	This project is p	prioritized as an ongoing yearly	<pre>/ project to address immediate</pre>	e concerns as they happen.
	1c. Qualitative and Quantita Project and Project Alternati		quality of the c to legitimate co The alternative alternative is n suficient funds A third option	need to be available to enable is to provide less funds in the L	t gives engineering the ability t fiscal year and budget any ac ograms are finding assets that these replacements. Unforeseen budget however, e	to provide appropriate action tion for a future year. This need to be replaced ASAP and
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperate</li> <li>Economic Development</li> <li>Environmental Benefits</li> <li>Description of the Relations the Asset Characteristics and Consequences of Asset Perford Deterioration or Failure:</li> </ol>	hip between	Not Applicable Not Applicable Not Applicable Not Applicable As described b	elow.		
	1. Condition of Asset vs. Typ and Performance Record	ical Life Cycle	•	details of the work to be perfo sset condition is not available.	•	snown until such a time as it is ${\sf Pg}$

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			101	1355	20	)15		6	Dol	llars
			Project Name							
Project Summar	y Report				<u>Unforeseer</u>	n Projects In	itiated by P	owerStream	<u>1</u>	
	2. Number of	Customers in E	ach Customer	0						
	Class Potentia	lly Affected by	Asset Failure							
	3. Quantitative (frequency or and associated	duration of int			details of the w Quantitative Cu				nown until such	a time as
	4. Qualitative satisfaction, construction, c	ustomer migra			details of the w Qualitative Cust			s Project is unk	nown until such	n a time as
		stomer Impact		Medium	dotaile of the	white he read	mod under the			o time co
	Factors Affect	ing Project Tim	ing, ir any		factor affecting				nown until such	i a time as
		s for O&M Syst ications of Not		Not Applicable	2.					
	Reliability and	Safety Factors oject Benefits a	s and Costs with		e programme "L		ects Initiated by	PowerStream'	' under the Syst	em Renev
	Reliability and Analysis of Pro Alternative Co "like for like" i configured at analysis of pro	oject Benefits a imparison (if th renewal and ha extra cost, pro oject benefits)	and Costs with ne project is as been vide an	In general, the category will b	e programme "U pe "like for like".					
	Reliability and Analysis of Pro Alternative Co "like for like" of configured at analysis of pro 2011	oject Benefits a omparison (if th renewal and ha extra cost, pro oject benefits) <b>2012</b>	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" of configured at analysis of pro 2011	oject Benefits a omparison (if th renewal and ha extra cost, pro oject benefits) <b>2012</b>	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018		2020
enditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" of configured at analysis of pro 2011	oject Benefits a omparison (if the renewal and has extra cost, pro- oject benefits) 2012 \$ 1,499,516	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" i configured at analysis of pro 2011 \$ 1,076,240	oject Benefits a omparison (if the renewal and has extra cost, pro- oject benefits) 2012 \$ 1,499,516	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" i configured at analysis of pro 2011 \$ 1,076,240 \$4,500,00	oject Benefits a imparison (if the renewal and has extra cost, pro- oject benefits) 2012 \$ 1,499,516	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" u configured at analysis of pro 2011 \$ 1,076,240 \$4,500,00 \$4,000,00	oject Benefits a omparison (if the renewal and has extra cost, pro- oject benefits) 2012 \$ 1,499,516	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and         Analysis of Pro         Alternative Co         "like for like" u         configured at         analysis of pro         2011         \$ 1,076,240         \$4,500,00         \$4,500,00         \$3,500,00	pject Benefits a pmparison (if the renewal and has extra cost, pro- bject benefits) 2012 \$ 1,499,516	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
enditures Historical/Planned	Reliability and         Analysis of Pro         Alternative Co         "like for like" u         configured at         analysis of pro         2011         \$ 1,076,240         \$4,500,00         \$3,500,00         \$3,000,00	pject Benefits a pmparison (if the renewal and have extra cost, pro- pject benefits) 2012 \$ 1,499,516 00 00 00 00 00	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
penditures Historical/Planned	Reliability and         Analysis of Pro         Alternative Co         "like for like" u         configured at         analysis of pro         2011         \$ 1,076,240         \$4,500,00         \$3,500,00         \$2,500,00	pject Benefits a pmparison (if the renewal and has extra cost, pro- pject benefits) 2012 \$ 1,499,516 00 00 00 00 00 00 00	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
penditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" of configured at analysis of pro           2011           \$ 1,076,240           \$ 4,500,00           \$ 3,500,00           \$ 3,000,00           \$ 2,500,00           \$ 2,000,00	pject Benefits a mparison (if the renewal and have extra cost, pro- pject benefits) 2012 \$ 1,499,516 00 00 00 00 00 00 00 00 00	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
penditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" in configured at analysis of pro 2011 \$ 1,076,240 \$4,500,00 \$3,500,00 \$3,000,00 \$2,500,00 \$1,500,00	pject Benefits a imparison (if the renewal and has extra cost, pro- bject benefits) 2012 \$ 1,499,516 00 00 00 00 00 00 00 00	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". <b>2015</b>	2016	2017	2018	2019	2020
penditures Historical/Planned	Reliability and Analysis of Pro Alternative Co "like for like" in configured at analysis of pro 2011 \$ 1,076,240 \$4,500,00 \$3,500,00 \$3,500,00 \$2,500,00 \$1,500,00 \$1,500,00	pject Benefits a imparison (if the renewal and has extra cost, pro- bject benefits) 2012 \$ 1,499,516 00 00 00 00 00 00 00 00 00 00 00 00 00	and Costs with ne project is as been vide an 2013	In general, the category will b	e programme "L pe "like for like". \$ 1,046,472	2016	2017 \$ 1,093,812	2018	2019	2020

	F	Project Code	Report Start Year	Number of Years	Scale
Power					
Power Stream	<b>~</b>	103659	2015	6	Dollars
Built to		Project Name	Storm Llardoning	& Rear Lot Supply	
Project Summa	ry keport		Storm Hardening	<u>a Real Lot Supply</u>	
Major Category	System Renewal				
Project Overview 1. Additional Information	Service Territory	PowerStre	am North & South		
	Location Scope	Complete system ard better in t 1. Convers 2. Periodio 3. Relocat	cations in PowerStream the work for the Storm Hardening e changed out, reinforced, and relo he future. The work program inclu ion of rear lot overhead supply sy storm guying and in-line guying a on of flood sensitive equipment ir ese include battery, battery charge	ocated to enable the distributi des: stem to front lot underground nd anchoring for pole lines tha o Stations from below grade to	on system to withstand storms supply system. at have 4 circuits on them. above grade or to safer
	Justification	This proje Hardening During the to the vari trees in clu retained C recommen future. Th Some of tl work prog 1. Convers 2. Periodic 3. Relocat height. Th	December 2013 ice storm in Onta ous factors, including the heavy w ose proximity of the distribution sy IMA to review the distribution sys adations to make the distribution se e Ice Storm Hardening Report was ne recommendations from the rep	a to implement the recomment ario, PowerStream experienced eight of the ice on various dist rstem. Subsequent to the ice s tem and produce the Ice Storr system stronger and withstance discussed among various depart ort were adopted for implement stem to front lot underground nd anchoring for pole lines that a Stations from below grade to	d many prolonged outages due ribution components and on torm event, PowerStream has n Hardening Report with I the storm better in the artments within PowerStream. entation. The proposed capital supply system. at have 4 circuits on them.
		through Si resulted in customers Vaughan. of the com December PowerStre damage to power line were gene the type o PowerStre equally oc phase or s power to distributio to the dist services) a PowerStre respect to submitted PowerStre	d: On the weekend of Decembe buthern Ontario. Ice accumulation in PowerStream's service territor The vast majority of customers wighetion of the storm, and full rest 30, 2013. The freezing rain prod am's service territory. It was this the overhead primary and second scausing outages. There were lin rally the result of the weight of th f failures that occurred, the failure am normally relies on to provide of curred in the backup feeders. A si econdary lines for which there is r the customer. PowerStream wan n system against ice storms of this ribution design standards, upgrad nd vegetation management practi am has retained a consulting firm, the capability to withstand severe the Ice Storm Hardening Report. I am resulted in a prioritzed work p rams were proposed to be implem	a resulted in downed branches ower in Ontario. This included y, predominantly in Aurora, M vithin PowerStream's territory oration in PowerStream's serv uced significant damage to the damage to the tree canopy the dary distribution system. The i- nited pole or transformer failu- e failed tree canopy and not the swere widespread such that I quick restoration of power wer gnificant number of the failure to backup and direct restoration ted to consider ways to to effe- nature and storms in general e of old systems to present da- ces. CIMA, to review PowerStream is ce storm in the future. CIMA Extensive discussions among v rograms that were proposed f	i, trees and power lines, which , at its peak, over 92,000 arkham, Richmond Hill and were restored within 24 hours ice territory was realized on e tree canopy in at then caused significant failed trees came down on the res and those that occurred he ice itself. In addition to backup feeders that re unavailable as failures as also occurred in the single on was required to re-establish actively "harden" the . These may include changes y standards (i.e. rear yard n's distribution system with has completed the review and arious departments in for implementation. These
2. General Project Information (OEB)	Contributed Capital	Contribute 2016	ed Capital 0%		
	Parent WO# Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	Management Risk: Fluct work.	uation in cost and staff resource (i	nternal and external) to comp	lete high annual volume of

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		10	3659	2015	6	Dollars
Project Summary	Report	Project Name		Storm Hardening	& Rear Lot Supply	
	Comparative Information o Historical Projects (if any)	n Equivalent		has completed similar rear lot uipment project.	project, pole line replacement	and reinforcement project,
	Total Capital and OM&A Cos Renewable Energy Generati Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		system are cha storm better in 1. Conversion of 2. Periodic stor 3. Relocation of height. These i	work for the Storm Hardening inged out, reinforced, and relo the future. The work program of rear lot overhead supply sys rm guying and in-line guying ar f flood sensitive equipment in nclude battery, battery charge AC, UPS, and equipment stora	cated to enable the distribution includes: tem to front lot underground s and anchoring for pole lines that Stations from below grade to r, inverter, feeder switch, capa	n system to withstand ice supply system. t have 4 circuits on them. above grade or to safer
	1a. Main Driver		Mitigate Failur	e Risks. To maintain safety, sys	tem reliability and customer s	ervice.
	1b. Priority and Reasons for	Priority	deteriorating. that must be a 2. PowerStrear risk because if public safety w 3. All seven of the basement inverters and c operation of th causing damag electric shock h environment. I	m has many pockets of rear lot The rear lot supply system pos ddressed. m has many pole lines that care these poles collapse under sto vill be at risk. Strengthening the PowerStream's transformer st of the switchgear buildings. It i distribution panels are not expine estation. Should a flood occu te to the equipment and possit hazard when electrical equipm For these reasons, all non-wate level or, at the very least, elev	es many safety, reliability and ry 4 circuits on them. These po rm, many customers will enco ese poles will reduce the risk. ations that have indoor type so is imperative that the battery to osed to water. These component r in the basement, submersed oly create prolonged outages. The ent is subjected to water lead ertight equipment in the baser	customer service concerns le lines are conserdered high unter power outage, and witchgear have equipment in banks, battery chargers, ents are crucial to the equipment could maloperate There is also a significant ing to an unsafe working nents should be relocated to
	1c. Qualitative and Quantita of Project and Project Alterr		customer servi An alternative emergency. Ho	Il reduce safety risk to custome ce in the the event of major st is to do nothing and allow the owever this approach is not rec reliability, and customer service	orm. system to fail under major sto commended because it will hav	rm and be replaced under
	2. Safety		-	stribution lines and poles in re- serious public safety concerns		reaking and falling during
	<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperal</li> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>	bility	Not Applicable Not Applicable Not Applicable Not Applicable			

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		103	3659	2015	6	Dollars
Project Summary	Report	Project Name		Storm Hardening	& Rear Lot Supply	
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perfe Deterioration or Failure:	d	In comparison power during a repair/replace before they can lf the replacem because the cri- rear lot. More frequent When a rear lo however, trees power line. The PowerStream because if thes safety will be a All seven of Po basement of th and distributio station. Should to the equipme	has many pole lines that carry a e poles collapse under storm, t risk. werStream's transformer stati he switchgear buildings. It is im n panels are not exposed to w a flood occur in the basemen	customers have to wait longer ain access to the back yard to ed areas, the crews must also pole, transformer) is necessar nt (e.g. large crane) to reach o aimal contact, and lack of acce the area was likely clear of ot electrical equipment, and ma creases the risk of animals con 4 circuits on them. These pole many customers will encount ons that have indoor type swi perative that the battery ban later. These components are co t, submersed equipment coul ged outages. There is also a sig	er for the crews to restore identify, locate, isolate, and clear or trim the vegetation y, the outage time will extend over customer houses to the ss for PowerStream crews: ustruction. Over time, y make contact with the tact with electrical equipment. lines are considered high risk er power outage, and public tchgear have equipment in the ks, battery chargers, inverters rucial to the operation of the d maloperate causing damage gnificant electric shock hazard
	1. Condition of Asset vs. Typ and Performance Record	oical Life Cycle	time frame). It power. As a res- ice storm. 2. 4-circuit pole does a typical p and more custo 3. Flood sensiti flooding in stat charger, invert (Uninetrrupted	e lines are critical part of the d	ccess to the backyard to main to customers. This is especial istribution system because the its. 1 circuit). If the pole collap utage. In below grade at stations man er outage. The high risk equipr nk, AC distribution panel, DC	ain, repair, and restore y more difficult in the event of ey carry more circuits than use, 4 feeders be out of service y be damaged in the event of nent are: battery, battery distibution panel, UPS
	2. Number of Customers in I Class Potentially Affected by		Approximately	1000. For details on the calco	ulation of this figure, please re	fer to 3. below.
	3. Quantitative Customer Im (frequency or duration of in and associated risk level)		<ul> <li>Estimated nu</li> <li>Estimated nu</li> <li>Duration of in</li> <li>CMI per 1 fai</li> </ul>	Failure is: 0.5 failure per year mber of customers affected b mber of customers affected b nterruption is: 4 hours per inte lure is: 2000 x 4 hour x 60 min ailure is: 480,000 x 0.5 = 240,0	y 1 failure is: 2,000 customers y 0.5 failure is: 2,000 x 0.5 = 1, erruption. = 480,000 CMI	000 customers
	4. Qualitative Customer Imp satisfaction, customer migra associated risk level)		-	cause inconvenience and fina failure poses safety hazards to		closing, production stoppage).
	5. Value of Customer Impact Factors Affecting Project Tin		High Not Applicable			
	Consequences for O&M Syst Including Implications of No Implementing Reliability and Safety Factor	ot	• O&M Cost fo This project is p potential failur	r 1 failure = \$100,000 per failu r 0.5 failure = \$100,000 x 0.5 = part of the long-term Storm Ha e and 240,000 potential CMI. I pole lines collapsing and floo	\$50,000. ardening Program. The project n addition, this project also re	duce safety hazards
				,		

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream			103	3659	20	15		6	Dol	llars
	L.		Project Name							
Project Summary	Report				<u>Storm</u>	Hardening	& Rear Lot	<u>Supply</u>		
	Analysis of Pro Alternative Co "like for like" i configured at analysis of pro	omparison (if t renewal and h extra cost, pro	as been ovide an		e is the risk of so	ing" and only re ome pole lines f e it will have a i	ailing and large	scale equipme	nt to fail and he	ence this
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$-	\$-	\$ -	\$ -	\$ 3,499,998	\$ 7,900,017	\$ 7,999,752	\$ 7,499,834	\$ 6,900,540	\$ 7,200,07
	¢0,000,00	0								
	\$9,000,00									
	\$8,000,00	00					1			
	\$8,000,00 \$7,000,00	00								
	\$8,000,00	00 00								
	\$8,000,00 \$7,000,00 \$6,000,00	00 00								
	\$8,000,00 \$7,000,00 \$6,000,00 \$5,000,00	00								
	\$8,000,000 \$7,000,000 \$6,000,000 \$5,000,000 \$4,000,000	00 00 00 00 00								
	\$8,000,000 \$7,000,000 \$6,000,000 \$5,000,000 \$4,000,000 \$3,000,000	10								
	\$8,000,000 \$7,000,000 \$6,000,000 \$5,000,000 \$4,000,000 \$3,000,000 \$2,000,000	10            10            10            10            10            10            10            10            10            10            10            10            10	2012	2013	2014 2	015 201	6 2017	2018	2019	2020

	Project	t Code	Report Start Year	Number of Years	Scale
Power Stream	5	101012	2015	6	Dollars
Sircum	Project	t Name			
Project Summar			cuit Breaker Replacemer	nt Markham TS#1&2 &	Lazenby TS#1
Major Category	System Renewal				
Project Overview					
1. Additional Information	Service Territory	PowerStrean	n South		
	Location	Markham TS	#2, Markham TS#1 & Lazenby TS	5#1	
	Scope		of the following 27.6 kV feeder		
		- J Bus 27.6k - The four Y E	/ feeder breakers 24M1, 24M3, 2 Bus 27.6kV feeder breakers at M	24M7 at Markham TS2 (2015) arkham TS1 (2015)	
			ichmond Hill (Lazenby) TS1 feed		
	Justification	supported by the cannibali Sustainment	eakers at all of these stations ar the manufacturer. Spare parts zation of stock that we have on and Station Design & Standards uit breakers at PowerStream's tr	are not commercially available hand. Due to operational cond have jointly developed the at	e but can be recovered through cerns, System Planning, Station tached plan to replace the
			an is subject to annual re-assess		
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Mana	mitigated by	equipment has a long lead time standardizing replacement equi This risk will be mitigated by bo	pment and by placing orders e	early. Outage availability is
	Comparative Information on Equiva Historical Projects (if any)	following rep - Markham T - Markham T - Markham T - Vaughan TS	s a continuation of the Station C lacements have been undertake S#2 M5 OX 36 breaker in 2003 S#1 OX 36 feeder breakers on B S#2 OX 36 feeder breakers on Q #1 all ABB HKSA breakers in 2001-2 #2 ABB HKSA breakers in 2011-2	en: bus in 2010 bus in 2014 9-2010	ogram begun in 2009. The
	Total Capital and OM&A Costs for Renewable Energy Generation port Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	Assessment ( - M1, M3 and - Four OX 36	27.6 kV circuit breakers at the fo ACA) Model as requiring replace I M7 OC 36 breakers on Markha feeder breakers on Markham TS A feeder breakers on Richmond	ement due to obsolescence an m TS#2 J bus 5#1 Y bus	d historical failures.
	1a. Main Driver	Obsolescence issues.	e. The main driver for this proje	ct is to maintain system reliait	iity and resolve obsolescence
		-	kers are obsolete in that these t <sup>.</sup> commercially available.	ypes of breaker are no longer	manufactured and spare parts
	1b. Priority and Reasons for Priority		h because this equipment is con to affect a large number of cust		
	1c. Qualitative and Quantitative Ana Project and Project Alternatives	existing equi requirement	oment would warrant emergences and could result in lengthy cus be more costly than proactive re	cy replacement resulting in nor tomer interruptions. Replacer	n-budgeted funding nent of failed equipment is
	2. Safety		nent equipment will mitigate the	e potential safety concerns if o	ne of the existing breakers
	<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperability</li> </ol>	Not Applicab Not Applicab			
	5. Economic Development 6. Environmental Benefits	Not Applicab Replacing the	le. e breakers reduces the risk that :	SF6 gases could be vented into	the atmosphere.
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relationship betw the Asset Characteristics and Consequences of Asset Performance Deterioration or Failure:	are no longe	36 breakers are considered obs commercially available.	solete and have a history of pro	emature failure. Spare parts
					Pg

		Project (	Code	Report Start	Year	Number of Yea	ars	Scale	
Power Stream			101012		2015		6	Do	llars
Direcuin		Project I	Name			<u>.</u>			
Project Summar	y Report		<u>Planned Ci</u>	rcuit Breaker	Replaceme	nt Markham	<u>TS#1&amp;2 &amp; l</u>	Lazenby TS	<u>5#1</u>
	1. Condition of A and Performanc	Asset vs. Typical Life C e Record	whereas th	oosed time of rep e typical life expe kers are consider	ctancy of a brea	ker is 35 years o	or more. Howev	ver, GEC OX 36	
		istomers in Each Cust Affected by Asset Fa		tely 4000					
		Customer Impacts uration of interruptio isk level)		of failure is estim is of this type and		er breaker per y	ear and is basec	d on typical ind	ustry statist
		istomer Impacts (cust tomer migration and evel)		one of these circu dential, commer			ead impact to th	he supply of ele	ectricity to
	5. Value of Custo Factors Affecting	omer Impact g Project Timing, if an		cuit breaker, swite Il are considered					next five ye
	Consequences for Including Implica Implementing	or O&M System Costs ations of Not	perhaps no replacemen interruptio replacemen	xers are replaced, It have to be cust Int resulting in nou ns. Replacement Int. Replacement Ints for spare equi	om made. Failur n-budgeted fund of failed equipm of these breaker	e of the existing ing requiremen tent is expected	g equipment wo ts and could res to be more cos	ould warrant en ult in lengthy c tly than proact	nergency ustomer ive
	Reliability and S	afety Factors	Renlaceme		o moro roliablo				
	Alternative Com "like for like" rei	ect Benefits and Costs parison (if the projec newal and has been tra cost, provide an	with From a con		ctive, this is a lik	e-for-like replac			quipment w
	Alternative Com "like for like" rei configured at ex	ect Benefits and Costs parison (if the projec newal and has been tra cost, provide an	with From a con t is require red	figuration perspe	ctive, this is a lik	e-for-like replac	cement but the r		quipment w 2020
penditures Historical/Planned	Alternative Com "like for like" rei configured at ex analysis of proje	ect Benefits and Costs parison (if the projec newal and has been tra cost, provide an ct benefits)	with From a con t is require red	figuration perspe luced maintenand	ctive, this is a lik te and parts will <b>2016</b>	e-for-like replac be readily availa	2018	replacement ec	2020
penditures Historical/Planned	Alternative Com "like for like" rer configured at ex analysis of proje 2011 \$ - \$ \$1,200,000 \$1,000,000	ect Benefits and Costs parison (if the project newal and has been tra cost, provide an ct benefits) 2012 201 201 201 201 201 201 201 201 20	with From a con t is require red 3 2014	figuration perspe luced maintenand 2015	ctive, this is a lik te and parts will <b>2016</b>	e-for-like replace be readily availa <b>2017</b>	2018	replacement ec	2020
penditures Historical/Planned	Alternative Com "like for like" ren configured at ex analysis of proje 2011 \$ - \$ \$1,200,000	ect Benefits and Costs parison (if the project newal and has been tra cost, provide an ect benefits) 2012 201 - \$	with From a con t is require red 3 2014	figuration perspe luced maintenand 2015	ctive, this is a lik te and parts will <b>2016</b>	e-for-like replace be readily availa <b>2017</b>	2018	replacement ec	2020
penditures Historical/Planned	Alternative Com "like for like" rer configured at ex analysis of proje 2011 \$ - \$ \$1,200,000 \$1,000,000 \$800,000	ect Benefits and Costs parison (if the project newal and has been tra cost, provide an act benefits) 2012 201 - \$	with From a con t is require red 3 2014	figuration perspe luced maintenand 2015	ctive, this is a lik te and parts will <b>2016</b>	e-for-like replace be readily availa <b>2017</b>	2018	replacement ec	2020
xpenditures Historical/Planned	Alternative Com "like for like" rer configured at ex analysis of proje 2011 \$ - \$ \$1,200,000 \$1,000,000 \$800,000 \$600,000	ect Benefits and Costs parison (if the project newal and has been tra cost, provide an ect benefits) 2012 201 - \$	with From a con t is require red 3 2014	figuration perspe luced maintenand 2015	ctive, this is a lik te and parts will <b>2016</b>	e-for-like replace be readily availa <b>2017</b>	2018	replacement ec	2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	102	2730	2015	6	Dollars
encum	<b>k</b>	Project Name			•	
Project Summary	Report		Statio	on Switchgear Replace	ment (ACA) 8th Line N	<u>IS323</u>
Major Category	System Renewal					
Project Overview						
1. Additional Information	Service Territory		PowerStream N	North		
	Location		Bradford			
	Scope			f 15kV switchgear at 8th Line I V switchgear line-up with arc r		
	Justification		manufacturer. cannibalization Sustainment ar obsolete circuit	akers are considered "obsolete Spare parts are not commercia of stock that we have on han nd Station Design & Standards t breakers at PowerStream's tr is subject to annual assessme	ally available but can be recoven d. Due to operational concerns have jointly developed the att ansformer stations and munic	ered through the s, System Planning, Station sached plan to replace the ipal stations for the next 8
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year Parent WO# Job Number		2017			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risl	k Management	Equipment has installation in 2	a long lead time. This risk wil 2018.	l be mitigated by ordering the	equipment in 2017 for
	Comparative Information of Historical Projects (if any)	n Equivalent		similar to this proposed replac d materials are used and field		
	Total Capital and OM&A Cos Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		requiring repla up is to be repl	6 switchgear has been identific cement due to obsolescence, v aced with a new metal-clad 15 cream's standard and will be ho	very poor condition and histor 5kV switchgear line-up with are	ical failures. The existing line-
	1a. Main Driver		Obsolescence. reliability risk.	Existing assets are considered	obsolete and reaching end of	life and are considered a
	1b. Priority and Reasons for	Priority	number of cust station requirir	high due to the very poor cond comers in the event of a failure ng load transfer to another sta nd may result in overloading o	e. A failure could result in com tion. Such a transfer could be	plete loss of supply from the
	1c. Qualitative and Quantita Project and Project Alternat		funding require equipment is e	existing equipment would warr ements and could result in leng xpected to be more costly that a proactive replacement.	gthy customer interruptions.	Replacement of failed
	2. Safety		could seriously	gear does not meet current sa injure personnel in the proxin Int construction meets PowerS	nity. The proposed new metal-	
	3. Cyber-Security, Privacy	ailita	Not Applicable			
	4. Coordination, Interoperat	JIILY	Not Applicable			
	<ol> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> </ol>		Not Applicable	cement of existing switchgear,	the risk of leaks of SEG gas int	o the environment will be
	o. Environmental benefits		reduced.	concine or existing switchgedi,	the flak of leaks of 510 gas lift	
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perfo Deterioration or Failure:	d	equipment is to		mpared with the existing equi	er, the proposed replacement oment. The new equipment is
	1. Condition of Asset vs. Typ and Performance Record	ical Life Cycle		replacement, the existing swite ormance issues and is consider		
	2. Number of Customers in E Class Potentially Affected by		Approximately	2000		

		Project	Code	Report St	art Year	Number of Yea	ars	Scale	
Power Stream	-		102730		2015		6	C	Dollars
		Project	Name						
Project Summary	y Report			Station Swite	hgear Replac	ement (ACA)	8th Line M	<u>S323</u>	
	3. Quantitative Co (frequency or dur and associated ris	ration of interruption	ons for brothypica	ency of failure is es eakers of this type a illy be in the order o e duration.	and condition. A s	upply interruptio	n due to a feed	er breaker fa	ilure would
		stomer Impacts (cus omer migration and vel)	stomer Failur			impact the electr	icity supply to r	many residen	tial, commer
	5. Value of Custo		High						
	Factors Affecting	Project Timing, if a		similar switchgear r dered to be of high					hough all are
	Consequences for Including Implicat Implementing	r O&M System Cost tions of Not	the ex requir	ng switchgear has h kisting equipment w rements and could ted to be more cos	ould warrant eme esult in lengthy cu	rgency replacements istomer interrupt	ent resulting in	non-budgete	d funding
	Alternative Comp	fety Factors ct Benefits and Cost parison (if the proje ewal and has been	s with From	roposed replaceme a configuration per technologically adv	spective, this is a l	ke-for-like replac	ement but the	replacement	equipment is
	Analysis of Projec Alternative Comp "like for like" ren	ct Benefits and Cost parison (if the proje ewal and has been ra cost, provide an	ct is more	roposed replaceme a configuration per	spective, this is a l anced, requiring r	ke-for-like replac	ement but the	replacement	equipment i / features.
penditures Historical/Planned	Analysis of Projec Alternative Comp "like for like" rend configured at ext analysis of projec	ct Benefits and Cost parison (if the proje ewal and has been ra cost, provide an ct benefits)	ct is more	roposed replaceme a configuration per technologically adv	spective, this is a l anced, requiring r	ike-for-like replac educed maintena <b>2017</b>	ement but the nce and has im	replacement proved safety 2019	equipment i / features.
penditures Historical/Planned	Analysis of Project Alternative Comp "like for like" rend configured at ext analysis of project 2011	ct Benefits and Cost parison (if the proje ewal and has been ra cost, provide an ct benefits) 2012 20	ts with From ct is more	roposed replaceme a configuration per technologically adv	spective, this is a l anced, requiring r <b>2016</b>	ike-for-like replac educed maintena <b>2017</b>	ement but the nce and has im 2018	replacement proved safety 2019	equipment is / features. 2020

		Project Code		Report Start Year	Number of Years	Scale
Power	5	102	2732	2015	6	Dollars
Siream		Project Name				
Project Summar	y Report	,	<u>Statio</u>	n Switchgear Replacer	nent (ACA) Patterson M	<u>MS336</u>
Maior Coloran	Curtain Dan and					
Major Category Project Overview	System Renewal					
1. Additional Information	Service Territory		PowerStream I	North		
	Location		Alliston			
	Scope			of 15kV switchgear at Pattersor V switchgear line-up with arc r		
	Justification		manufacturer. cannibalization Sustainment an obsolete circui	akers are considered "obsolete Spare parts are not commercia of stock that we have on hand nd Station Design & Standards t breakers at PowerStream's tr n is subject to annual re-assess	ally available but can be recove d. Due to operational concerns have jointly developed the att ansformer stations and munic	ered through the s, System Planning, Station cached plan to replace the
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2018			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Ris	k Management	Equipment has installation in 2	s a long lead time. This risk wil 2019.	l be mitigated by ordering the	equipment in 2018 for
	Comparative Information o Historical Projects (if any)	n Equivalent		similar to this proposed work h rials are used and field crews h		of times in recent years.
	Total Capital and OM&A Co Renewable Energy Generati Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		requiring repla to be replaced	6 switchgear has been identific cement due to obsolescence, p with a new metal-clad 15kV sv s standard and will be housed i	poor condition and historical favorical favorical favorical favorical favorical favority and the second second	ailures. The existing line-up is
	1a. Main Driver		Obsolesence. reliability risk.	Existing assets are considered of	obsolete and reaching end of I	ife and are considered a
	1b. Priority and Reasons for	Priority	large number of the station req	high due to the poor conditior of customers in the event of a f uiring load transfer to another and may result in overloading c	ailure. A failure could result in station. Such a transfer could	n complete loss of supply from
	1c. Qualitative and Quantita Project and Project Alternat		funding require equipment is e	existing equipment would warr ements and could result in leng xpected to be more costly than n proactive replacement.	gthy customer interruptions. F	Replacement of failed
	2. Safety		potential safet	gear does not meet current sat y concerns if one of the existin ar line-up with arc resistant co	g breakers failured violently. T	he proposed new metal-clad
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperal	bility	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits			cement of existing switchgear,	the risk of leaks of SF6 gas into	o the environment will be
5. Category-Specific Requirements for Each Project/Activity (OEB)	Description of the Relations the Asset Characteristics and Consequences of Asset Perf Deterioration or Failure:	d	From a configu equipment is te	ration perspective, this is a like echnologically enhanced as con quire less maintenance and me	mpared with the existing equip	er, the proposed replacement oment. The new equipment is
	<ol> <li>Condition of Asset vs. Typ and Performance Record</li> <li>Number of Customers in Class Potentially Affected by</li> </ol>	Each Customer	history of perfo	replacement, the existing swite ormance issues and is consider 1500		old. Existing switchgear has a

		Pr	roject Code		Report Star	e real	Number of Ye		Scale	
Power Stream	-		102	2732		2015		6	D	ollars
		Pr	roject Name							
Project Summary	/ Report	_		<u>Stati</u>	on Switch	gear Replace	ment (ACA)	Patterson N	<u>//S336</u>	
	3. Quantitative Cu (frequency or dura and associated ris	ation of inter		for breakers	of this type ar	mated to be 0.1 p nd condition. A su 2 hours until load	pply interruptic	on due to a feed		
	4. Qualitative Cust satisfaction, custo associated risk lev	omer migratio		Failure of this commercial a			mpact the supp	ly of electricity t	to many reside	ntial,
	5. Value of Custon			High						
	Factors Affecting F	Project Timin	g, if any	-	-	placement project r very high priority				ough all are
	Consequences for Including Implicat Implementing		n Costs	the existing e requirements	equipment wo s and could re	her maintenance ould warrant emer sult in lengthy cu y than proactive r	gency replacem tomer interrup	ent resulting in	non-budgeted	funding
	Reliability and Saf Analysis of Project Alternative Compa "like for like" rene	t Benefits and arison (if the ewal and has I	project is been	From a config	guration pers	t equipment is mo pective, this is a lil nced, requiring re	e-for-like replac	cement but the	replacement e	quipment i
	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project	t Benefits and arison (if the ewal and has b a cost, provid	project is been	From a config	guration pers	pective, this is a lil	e-for-like replac	cement but the	replacement e proved safety	quipment i
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project 2011 \$ - \$	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project 2011 \$ - \$ \$1,000,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project 2011 \$ - \$ \$ \$1,000,000 \$900,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project \$ - \$ \$ \$1,000,000 \$900,000 \$800,000 \$700,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project \$ - \$ \$ \$1,000,000 \$900,000 \$800,000 \$700,000 \$600,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project Alternative Compa "like for like" rene configured at extr analysis of project 2011 \$ - \$ \$1,000,000 \$900,000 \$800,000 \$700,000 \$600,000 \$500,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project         Alternative Comparing         "like for like" renerconfigured at extranalysis of project         2011         \$       -       \$         \$1,000,000         \$900,000         \$800,000       \$         \$700,000       \$         \$500,000       \$         \$400,000       \$	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
eenditures Historical/Planned	Analysis of Project         Alternative Comparing         "like for like" renerconfigured at extranalysis of project         2011         \$       -       \$         \$1,000,000         \$900,000         \$800,000       \$700,000         \$500,000       \$500,000         \$400,000       \$300,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
penditures Historical/Planned	Analysis of Project         Alternative Compa         "like for like" rene         configured at extranalysis of project         2011         \$       -         \$1,000,000         \$900,000         \$800,000         \$700,000         \$500,000         \$400,000         \$300,000         \$200,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil nced, requiring re	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020
enditures Historical/Planned	Analysis of Project         Alternative Comparing         "like for like" renerconfigured at extranalysis of project         2011         \$       -       \$         \$1,000,000         \$900,000         \$800,000       \$700,000         \$500,000       \$500,000         \$400,000       \$300,000	t Benefits and arison (if the ewal and has l ra cost, provid t benefits)	project is been de an	From a config more techno	guration pers logically adva	pective, this is a lil	e-for-like replac duced maintena	cement but the ance and has im 2018	replacement e proved safety 2019	quipment i features. 2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	100	462	2015	6	Dollars
Sirean		Project Name				
Project Summary	v Report	i roject Name	Letitia N	MS (MS413)- Increase	Capacity from 5MVA to	10MVA
Major Category	System Service					
Project Overview	Consider Touritour		Den se Character A	N		
1. Additional Information	Service Territory		PowerStream N	North		
	Location		Barrie			
	Scope		from 5MVA to 44/4.16kV tran service by sum	tails design and construction n 10MVA and add one 4.16 kV fo sformer, four 4.16kV vacuum o mer 2019. The project includes station construction, equipmen	eeder. The upgraded substatio circuit breakers and feeders. Th s engineering design, purchase	n will include a 10 MVA ne substation is to be in- of station equipment,
	Justification		peak load on N	new substation is required to p /IS413 was 112% of the ONAN led in the near future in the ev	rating. The contingency maxim	um station load of 7.6MVA
			conditions.			0/
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2018			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Comparative Information o		-	sk to completion is procuring t d commissioning prior to the 2		t to ensure it is available for
	Historical Projects (if any) Total Capital and OM&A Co	sts for	0			
	Renewable Energy Generati Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary		from 5MVA to 44/4.16kV tran service by sum	tails design and construction n 10MVA and add one 4.16 kV for sformer, four 4.16kV vacuum of mer 2019. The project includes station construction, equipmen	eeder. The upgraded substatio circuit breakers and feeders. Th s engineering design, purchase	n will include a 10 MVA ne substation is to be in- of station equipment,
	1a. Main Driver		The 2013 summer load of 7.6MVA	ity Delivery. The main driver o ner peak load on MS413 was 1 A may be exceeded in the near ency conditions.	12% of the ONAN rating. The o	contingency maximum station
	1b. Priority and Reasons for	Priority		igh priority. The 2013 summer ansfer capacity will become lin		6 of the ONAN rating and
	1c. Qualitative and Quantita Project and Project Alternat	tives	addition of a for resulting increa	upgrade would improve the re ourth feeder and provide a stat ase in station capacity would a s without exceeding the contin	tion capacity increase to accon lso allow contingency transfers	nmodate future growth. The
			implement a 25 station; howev additional cost	er outage at the upgraded stat	n. The 2x5MVA alternative pro 5 times greater than the cost o available transfer capability to	ovides redundancy at the of a single 10MVA station. The adjacent stations in the event
			-	'do-nothing' alternative is not NAN rating and contingency tra		
	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interopera</li> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>	bility	Not Applicable Not Applicable Not Applicable Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Print in terms of Cost Impact, wh	oject Expressed				

		I	Project Code		Report Start	/ear	Number of Yea	ars	Scale	
Power Stream			100	0462	2	015		6	Do	llars
		-	Project Name							
Project Summar	ry Report			<u>Letitia</u>	<u>MS (MS41:</u>	<u> 3)- Increase</u>	Capacity fro	om 5MVA to	<u>10MVA</u>	
	Regional Electri Requirements v applicable			Not Applicable	e.					
	Description of I Technology, if a		of Advanced	Not Applicable	e.					
		iability , efficie	ency, safety or	addition of a f resulting incre	fourth feeder a ease in station o	ld improve the r nd provide a sta capacity would a seding the contir	tion capacity in Iso allow contir	crease to accom agency transfers	modate future	growth. T
	Factors Affectin	ng Timing/Prio	rity			on equipment to ay affect the tim				nissioning
	Analysis of Proj Alternative Con Nothing" Altern factors if applic	nparison, inclu native (includir	iding "Do-	addition of a f resulting incre	fourth feeder a ease in station o	ld improve the r nd provide a sta capacity would a reding the contir	tion capacity in Iso allow contir	crease to accom gency transfers	modate future	growth. T
					ernative to the	single 10MVA 44	4/4.16kV statior	n transformer co		
				implement a 2 station; howe additional cos of a transform substations in The remaining	ernative to the 2x5MVA 44/4.1 wer, initial cost at is difficult to j her outage at th the area. g 'do-nothing' a		4/4.16kV statior on. The 2x5MVA 5 times greater available transf tion and the use viable because	a transformer co alternative pro than the cost o er capability to of 10MVA tran the 2013 summ	vides redundar f a single 10MV adjacent station sformers at all her peak load on	ncy at the /A station. ns in the ev other n MS413 w
	2011	2012	2013	implement a 2 station; howe additional cos of a transform substations in The remaining	ernative to the 2x5MVA 44/4.1 wer, initial cost at is difficult to j her outage at th the area. g 'do-nothing' a	single 10MVA 4 6kV configuratic estimates are 1 fustify given the ne upgraded stat	4/4.16kV statior on. The 2x5MVA 5 times greater available transf tion and the use viable because	a transformer co alternative pro than the cost o er capability to of 10MVA tran the 2013 summ	vides redundar f a single 10MV adjacent station sformers at all her peak load on	ncy at the /A station. ns in the er other n MS413 w r future.
nditures Historical/Planned	2011 \$ - \$		<b>2013</b> \$ -	implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the O	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to her outage at th the area. g 'do-nothing' a DNAN rating and	single 10MVA 4 6kV configuratio estimates are 1. justify given the ne upgraded stat Iternative is not d contingency tr	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent statio sformers at all her peak load of ited in the near	ncy at the /A station. ' ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned		; -		implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to join ner outage at the the area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ns in the e other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$	0		implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ns in the e other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$	0		implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000			implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ' ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000	0 0		implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ' ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000 \$1,200,000			implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ' ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000			implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ' ns in the evo other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000			implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. ' ns in the ex other n MS413 w r future. 2020
enditures Historical/Planned	\$ - \$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000			implement a 2 station; howe additional cos of a transform substations in The remaining 112% of the C	ernative to the 2x5MVA 44/4.1 ever, initial cost st is difficult to joner outage at the othe area. g 'do-nothing' a DNAN rating and 2015	single 10MVA 44 6kV configuration estimates are 1. justify given the ne upgraded state Iternative is not d contingency trong 2016	4/4.16kV station on. The 2x5MVA 5 times greater available transf ion and the use viable because ansfer capacity <b>2017</b>	a transformer co alternative pro than the cost o er capability to e of 10MVA tran the 2013 summ will become lim	vides redundar f a single 10MV adjacent station sformers at all her peak load on ited in the near 2019	ncy at the /A station. <sup>-</sup> ns in the ex other n MS413 w r future. 2020

	Project Co	ode	Report Start Year	Number of Years	Scale
Power Stream	-	100043	2015	6	Dollars
	Project Na				
Project Summar	y Report	Painswic	ck South MS: New 44-13.	<u>8KV, 20 IVIVA, 4-Fee</u>	eder Substation
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory Location Scope	The project vicinity of Y	et and Mapleview Drive area in Bate to the set of the design and construction the design and construction of the design and	on of a new 44/13.8kV, 20 e in Barrie. The project inc	ludes engineering design, purchas
	Justification	MS307. The its ONAN ra maximum r back-up mo available w transfer of	ed substation is required to provi e 2013 summer peak load on MS3 ating in 2015. Capacity relief is rec normal load rating at that time. Ti odel. Currently load transfers are rith Park Place MS308. In the ever 50% load to each adjacent station y maximum load by 2017.	404 was 104% of the ONAN quired for MS304 in 2016, he proposed station is also possible between MS304 it of a transformer failure	V rating, while MS307 will exceed since the station will exceed its o required to establish a "triad" and MS307, with limited transfers at MS304 and the subsequent
2. General Project Information (OEB)	Contributed Capital	Contribute	d Capital 0%		
	Fiscal Year	2015			
	Parent WO#	311302			
	Job Number	C00851			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managen	also risk as	potential risk of delay when attain sociated with potential delays in e in and installation.		
	Comparative Information on Equivale Historical Projects (if any)	nt Not Applica	able.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 of			
4. Evaluation Criteria (OEB)	Project Summary	vicinity of Y	entails the design and construction onge Street and Mapleview Drive equipment, approvals, substation	e in Barrie. The project inc	ludes engineering design, purcha
	1a. Main Driver	MS304 and MS307 will	pacity Delivery. The main driver of Huronia MS307. The 2013 summ exceed its ONAN rating in 2015. ( exceed its maximum normal load	er peak load on MS304 w Capacity relief is required	as 104% of the ONAN rating, whi
		model. Und limited trar subsequent	nal driver is to establish a station l der the current conditions, load tr nsfers available with Park Place M t transfer of 50% load to each adj contingency maximum load by 20	ansfers are possible betw S308. In the event of a tra acent station, the new loa	een MS304 and MS307, with Insformer failure at MS304 and t
	1b. Priority and Reasons for Priority	MS304 ON/ accommod	riority is given to the new station AN rating and contingency transfe ated beyond 2017. Investments h ubstation land for the start of cor	ers among existing adjacer ave already been made to	nt stations cannot be

	Project Code		Report Start Year	Number of Years	Scale
Stream	100	0043	2015	6	Dollars
	Project Name				
Project Summary Report		Painswick S	South MS: New 44-13.	<u>8kV, 20 MVA, 4-Feede</u>	r Substation
1c. Qualitative and Qu         of Project and Project .         2. Safety         3. Cyber-Security, Private         4. Coordination, Interce         5. Economic Developments for oject/Activity (OEB)         Regional Electricity Infraguirements of Cost Impace         Regional Electricity Infraguirements which a applicable         Description of Incorport Technology, if applicate         Identify any reliability         coordination benefits         Factors Affecting Timin         Analysis of Project Benefits	antitative Analysis Alternatives Alternatives acy operability tent fits of Project Expressed t, where practicable rastructure ffect Project, if ration of Advanced ole , efficiency, safety or ng/Priority tefits and Costs with n, including "Do-	The new subst developments. transfer an out The 'do-nothim the ONAN ratin in 2016, since t alternative wo capacity for loa The alternative station has an breakers, repla not large enou Limited load tr ONAN rating a relief will be re Not Applicable Not Applicable The new subst future develop conditions thr Factors that co equipment pro- installation. The new subst developments. transfer an out The 'do-nothin the ONAN ratin in 2016, since t alternative wo capacity for loa	2. 2. 2. 2.	bility of service to existing cus cy back-up configuration wou is the other existing stations. ause the 2013 summer peak I is ONAN rating in 2015. Capaci imum normal load rating at th tion of future load growth in t nditions. 7 site was considered, however tchgear manufactured in 1978 here is no building at this site bort the clearances required for 07, and MS308 can take place this, there are no other viable 2016. 016. 017. 016. 018. 019. 019. 019. 019. 019. 019. 019. 019	tomers and future Id provide enough capacity if pad on MS304 was 104% of ty relief is required for MS30 at time. The do-nothing he area or provide adequat er, it was rejected because t . Due to the age of the MS3 and the property foot print or a larger 20MVA station. until 2015 while exceeding and economic alternatives a deconomic alternatives a ed capacity for existing and pility during contingency lude potential delays in s in station construction and tomers and future id provide enough capacity to ty relief is required for MS30 iat time. The do-nothing he area or provide adequat er, it was rejected because t . Due to the age of the MS3 and the property foot print

D			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			10	0043	20	)15		6	Do	ollars
Project Summary			Project Name		South MS: I	New 44-13.	8kV, 20 MV	A, 4-Feede	r Substatior	<u>1</u>
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ -	\$-	\$ -	\$ -	\$ 2,690,054	\$-	\$ -	\$ -	\$ -	\$ -
	\$3,000,0 \$2,500,0 \$2,000,0 \$1,500,0 \$1,000,0 \$500,0	00								
	\$		2012	2013	2014 2	015 201	6 2017	2018	2019	2020

Project Overview 1. Additional Information S L	System Service Service Territory Location Scope	102 Project Name	PowerStream M Beeton	2015 son MS#2 - New 44-13	6 .8kV, 2x5 MVA, 2-feed	Dollars ers MS
Major Category     S       Project Overview     I. Additional Information       S     L	System Service Service Territory Location Scope	Project Name	PowerStream M Beeton	son MS#2 - New 44-13	.8kV, 2x5 MVA, 2-feed	ers MS
Major Category     S       Project Overview     I. Additional Information       S     L	System Service Service Territory Location Scope		PowerStream M Beeton	son MS#2 - New 44-13	.8kV, 2x5 MVA, 2-feed	<u>ers MS</u>
Project Overview 1. Additional Information S L	Service Territory Location Scope		Beeton			
Project Overview 1. Additional Information S L	Service Territory Location Scope		Beeton			
1. Additional Information S	Location Scope		Beeton			
	Scope			North		
S			<del>.</del>			
			Beeton, suitabl service by sum	tails the purchase of a station s le for constructing a new 2x5M mer 2022. The project includes station construction, equipmer	IVA, 44-13.8kV, 2-feeder muni s engineering design, purchase	cipal substation to be in- of station equipment,
, ,	ustification		there is only or supplied from a other substatic separate transit the station transit In addition, the residential dev	ons. The new 2x5MVA Patterso formers at the substation, which nsformers or loss of MS336.	n; Patterson MS336. The entire Patterson MS there are no po n MS#2 would provide redund th would allow transfer capabi equired to provide capacity fo next five years. This additional	e Beeton 13.8kV network is ssible contingency transfers to lancy in the form of two lity in case of loss of one of r the new Sorbara (600 home) 1.5MVA of residential load
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Teen Merry		2010			
	Fiscal Year		2019			
	Parent WO#					
J	ob Number					
3. General Information on the R Project/Activity (OEB)	Risks to Completion and Risk	< Management	Road in Beetor Rayville resider	sk to completion is securing the n. The area surrounding the pro- ntial subdivisions and there is a available which will mean add	pposed site is being developed risk that the property cost wi	ll rise and/or the preferred
	Comparative Information or Historical Projects (if any)	n Equivalent	construction pe substation, res property. The p	h MS, a new 44/13.8kV 20MVA ending completion in 2016. The ulting in the purchase and den project highlighted the importa sure it is available when a new	ere was difficulty locating and nolition of two residential hom ance of identifying and purcha	securing available land for the les in order to secure a
R	Fotal Capital and OM&A Cos Renewable Energy Generatio Projects (if any)		0			
	Project Summary		Beeton, suitabl service by sum	tails the purchase of a station s le for constructing a new 2x5M mer 2022. The project includes station construction, equipmer	IVA, 44-13.8kV, 2-feeder muni s engineering design, purchase	cipal substation to be in- of station equipment,
1	La. Main Driver		conditions. Cur 13.8kV networ contingency tra in the form of t	ity Delivery. The main driver o rrently there is only one substa k is supplied from the single M ansfers to other substations. Th two separate transformers at t of the station transformers or le	tion located in Beeton; Patter S336. Upon loss of Patterson I ne new 2x5MVA Patterson MS he substation, which would al	son MS336. The entire Beeton MS there are no possible #2 would provide redundancy
			be built over th	drivers is to provide capacity fo ne next five years. This additior 36 to exceed its ONAN rating in	nal 1.5MVA of residential load	
1	Lb. Priority and Reasons for	Priority	The entire Bee	nigh priority. Currently there is ton 13.8kV network is supplied e contingency transfers to othe	from the single MS336. Upon	
			Rayville resider	e vicinity of the proposed station ntial subdivisions and there is a available which will mean add	a risk that the property cost wi	ll rise and/or the preferred

			Project Code		Report Start	Year	Number of Yea	irs	Scale	
Power Stream			10	2412		2015	(	5	Do	llars
			Project Name	_						
Project Summar	y Report			Patte	rson MS#2	<u>2 - New 44-13</u>	8.8kV, 2x5 M	VA, 2-feed	lers MS	
	1c. Qualitativ Project and F		titative Analysis of natives	under conting of two separa one of the sta The 'do-nothin under conting The proposed because the d	ency conditio te transforme tion transform ng' alternative ency conditio 2x5MVA subs ual transform	ns. The new 2x5N rs at the substationers or loss of MS e is not viable bec	IVA Patterson N on, which would 336. ause there is cu ion was selected ransfer capabili	1S#2 would pro l allow transfer rrently no back d over the alte ty in case of lo	ovide redundan r capability in ca k-up substation rnative 1x10MV ss of one of the	cy in the form ise of loss of in Beeton A configuration station
	2 Safaty			Not Applicable	2					
	2. Safety	rity Drivoou								
	<ol> <li>Cyber-Sect</li> <li>Coordination</li> </ol>			Not Applicable Not Applicable						
	5. Economic			Not Applicable						
	6. Environme			Not Applicable						
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to C	ustomers of	Project Expressed where practicable							
	Regional Elec Requirement applicable			Not Applicable	2.					
		of Incorporat	ion of Advanced	Not Applicable	e.					
	Technology,									
			fficiency, safety or	The new subs	tation will pro	vide reliability be	nefits by provid	ing a backup u	ınder contingen	cy conditions
	coordination		Driority	The availabilit	v of land for a	ale in the vicinity	of Daufaat Stra	at and Highlan	d Road will affe	ct the timing
	Factors Affec	ting Timing/	Priority	the substation			of Dayroot Stree	et and Highlan	id Road will affe	ct the timing
	Alternative C	comparison, i ernative (incl	ts and Costs with including "Do- luding qualitative	under conting of two separa	ency conditio te transforme	ns. The new 2x5N	/IVA Patterson N on, which would	IS#2 would pr	ovide redundan	cy in the forn
				The 'do-nothing under conting	-	e is not viable bec ns.	ause there is cu	rrently no bacl	k-up substation	in Beeton
				because the d	ual transform	station configurat er design allows plishes a triad con	ransfer capabili	ty in case of lo	ss of one of the	station
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ -	\$ -	\$ -	\$-	\$-	\$ -	\$-	\$-	\$ 749,000	\$ 1,931,97
	\$2,500,									
	\$2,000,0									
	\$1,500,0	000								
	1									
	\$1,000,0	000								
	\$500,6	000								
	\$500,6		11 2012	2013	2014	2015 20	16 2017	2018	2019	2020

	Pro	ject Code	Report Start Year	Number of Years	Scale
_ Power	5	101569	2015	6	Dollars
Stream	-				2011010
Duele et Comme		ject Name	Now MS, Duffori	n South MS#2 - Alliston	
Project Summar	укерог		New MO, Dullen		
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory	PowerStre	eam North		
	Location		t and Industrial Pkwy area, Allis		
	Scope	Alliston, a summer 2	nd constructing a new 2x10MV	eering design, purchase of stat	al substation to be in-service by
	Justification	(MS331-T developm	1/T2). With a proposed 6MVA V	Valton ICI development, as well e next four to six years, 14th Lin	le capacity relief to 14th Line MS I as a 3.5MVA Tall Tree residentia Ie MS (MS331) is expected to
		nearby M experienc 2x10MVA MS331-T2	S330 for any potential transfers es an outage the backup transf Dufferin South MS#2 would pr	is only 15.1MVA. As of 2016, if er station will exceed the contir	ngency maximum rating. The nev would allow the load from either
					due to the limited availability of rvice no later than summer 2019.
2. General Project Information (OEB)	Contributed Capital	Contribut	ed Capital 0%		
	Fiscal Year Parent WO#	2016			
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Ma	Industrial developm	Parkway in Alliston. The area so ent and there is a risk that the	g the required land in the vicini urrounding the proposed site is property cost will rise and/or th (44kV and 13.8kV) costs will be	part of the Walton ICI ne preferred site will not be
	Comparative Information on Eq Historical Projects (if any)	constructi substatior property.	on pending completion in 2016 n, resulting in the purchase and	demolition of two residential h portance of identifying and pure	nd securing available land for the nomes in order to secure a
	Total Capital and OM&A Costs for Renewable Energy Generation p Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary	Alliston, a later than	nd constructing a new 2x10MV summer 2019. The project incl	ion site in the vicinity of Duffer A, 44/13.8 kV, 4 feeder municip udes engineering design, purch ment installation, and commis	al substation to be in-service no ase of station equipment,
	1a. Main Driver	(MS331-T developm	1/T2). With a proposed 6MVA V	e next four to six years, 14th Lin	l as a 3.5MVA Tall Tree residentia
		20.2MVA, 15.1MVA. exceed th configurat	while the contingency maximu As of 2016, if one of the substa e contingency maximum rating tion that would allow the load f	tions experiences an outage th The new 2x10MVA Dufferin Se	or any potential transfers is only e backup transfer station will outh MS#2 would provide a triad ) to be divided between the new

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	101	.569	2015	6	Dollars
Project Summar	y Report	Project Name		<u>New MS, Dufferin S</u>	outh MS#2 - Alliston	
	1b. Priority and Reasons for	Priority	property cost v and 13.8kV) co	vill rise and/or the preferred s sts will be incurred.		will mean additional line (44kV
				ansfers should be addressed p	num load at MS330 and MS33 romptly.	1-11 beyond 2016 during
	1c. Qualitative and Quantita Project and Project Alternati		Walton ICI deve triad contingen	elopment, and the 1,400 home	Id provide enough capacity to	nent. In addition, the resulting
			additional tran of 2019 to acco alternative wou to the exceede area surroundi	sfers beyond 2017 are not recommodate the proposed Walto uld not accommodate continged to a contingency maximum load ng the proposed site is being o nd/or the preferred site will no	load transfers to take place be ommended since relief will be on and Tall Tree developments ency transfers between MS331 and the lack of other 13.8kV su leveloped by Walton and there t be available which will mean	required before the summer . In addition, the do-nothing and MS330 beyond 2016 due Jbstations in the vicinity. The e is a risk that the property
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperat	oility	Not Applicable			
	<ol> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>		Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Pro in terms of Cost Impact, whe					
	Regional Electricity Infrastru Requirements which affect F applicable		Not Applicable			
	Description of Incorporation Technology, if applicable	of Advanced	Not Applicable			
	Identify any reliability , effici coordination benefits	iency, safety or	Walton ICI dev	elopment, as well as a 3.5MVA	its by providing the required c Tall Tree residential developn capability during contingency	nent. In addition, the
	Factors Affecting Timing/Price	ority		of land for sale in the vicinity ubstation construction.	of Dufferin St and Industrial Pl	wy in Alliston will affect the
	Alternative Comparison, incl	luding "Do-	Walton ICI deve triad contingen	elopment, and the 1,400 home	Id provide enough capacity to	ment. In addition, the resulting
			additional tran of 2019 to acco alternative wor to the exceede area surroundi	sfers beyond 2017 are not recommodate the proposed Walto uld not accommodate continged to a contingency maximum load ng the proposed site is being o nd/or the preferred site will no	load transfers to take place be ommended since relief will be on and Tall Tree developments ency transfers between MS331 and the lack of other 13.8kV so leveloped by Walton and there t be available which will mean	required before the summer . In addition, the do-nothing and MS330 beyond 2016 due Jbstations in the vicinity. The e is a risk that the property

			Project Code		Report Start Y	'ea <b>r</b>	Number of Yea	ars	Scale	
Stream	-		101	1569	2	015		6	De	ollars
Project Summary	Report		Project Name		New MS	S, Dufferin S	outh MS#2	- Alliston		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
penditures Historical/Planned	\$-	\$-	\$-	\$-	\$-	\$ 749,000	\$ 2,299,074	\$ 4,899,189	\$-	\$
	\$6,000,00 \$5,000,00 \$4,000,00 \$3,000,00	00								
	\$5,000,00 \$4,000,00	00 00 00 00								

		Project Code		Report Start Year	Number of Years	scale
Power Stream	5	101	1542	2015	6	Dollars
		Project Name				
Project Summar	y Report	-		<u>New MS, Harvie</u>	<u>Rd. MS - Barrie</u>	
Major Category	System Service					
Project Overview	System service					
1. Additional Information	Service Territory		PowerStream	North		
	Location		Harvie Rd and	Veterans Drive, Barrie		
	Scope		Barrie, and cor summer 2020.	tails the purchase of a station s nstructing a new 44/13.8kV, 20 The project includes engineeri struction, equipment installati	MVA, 4 feeder municipal subs ng design, purchase of station	tation to be in-service by
	Justification		MS (MS303). T respectively. C backup betwee by 132% durin	new Substation is required to p he 2013 summer peak load on apacity relief for MS305 & MS3 en MS303 & MS305 exceeded t g the 2013 summer peak. The l ults in the contingency maximu <i>r</i> ely.	MS305 & MS303, was 102% a 03 is required in 2016 and 20: the contingency maximum loa imited transfer of 50% MS305	nd 95% of the ONAN rating, 19, respectively. Contingency d of 33.5MVA at each station load during contingency
			availability of l	d purchase has been deferred and in the area and the require ne land needs to be purchased	ement for Harvie MS to be in-s	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2016/2020			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	k Management	Drive in Barrie property cost		posed site is fast being develo	of Harvie Road and Veterans ped and there is a risk that the will mean additional line (44kV
	Comparative Information or Historical Projects (if any)	n Equivalent	construction p substation, res property. The	th MS, a new 44/13.8kV 20MV/ ending completion in 2016. The sulting in the purchase and den project highlighted the importa sure it is available when a new	ere was difficulty locating and nolition of two residential hon ance of identifying and purcha	securing available land for the nes in order to secure a
	Total Capital and OM&A Cos Renewable Energy Generatio Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Barrie, and cor summer 2020.	tails the purchase of a station s nstructing a new 44/13.8kV, 20 The project includes engineeri struction, equipment installati	, MVA, 4 feeder municipal subs ng design, purchase of station	tation to be in-service by
	1a. Main Driver		and Ferndale (	ity Delivery. The main driver of MS303) which experienced a 2 ively. Capacity relief for MS305	013 summer peak load of 102	% and 95% of their ONAN
			model. Under would not allo MS303 & MS3 the 2013 sumr	driver is to establish a station b the current conditions, the loss w all station load to be supplie 05 exceeded the contingency n ner peak. The limited transfer o cy maximum load being exceed	s of a station transformer durin d by the adjacent stations. Co naximum load of 33.5MVA at e of 50% MS305 load during con	ng the summer peak period ntingency backup between each station by 132% during tingency conditions results in
	1b. Priority and Reasons for	Priority	property cost	the proposed station site is fas will rise and/or the preferred si ssts will be incurred.		ore there is a risk that the will mean additional line (44kV
				ceeding the contingency maxin ansfers should be addressed pr		nd MS308 beyond 2015 during

	Proje	ect Code		Report Start Yea <b>r</b>	Number of Years	Scale
Stream		1015	542	2015	6	Dollars
	Proje	ect Name				
Project Summary	y Report			<u>New MS, Harvie</u>	e Rd. MS - Barrie	
	1c. Qualitative and Quantitative A Project and Project Alternatives	- -	developments. transfer an out The 'do-nothin already experie	ation would improve the relial The resulting Triad contingen -of-service station load across g' alternative is not recommer enced a 2013 summer peak lo for MS305 & MS303 is require	cy back-up configuration wou the other existing stations. Inded because Holly (MS305) a ad of 102% and 95% of their O	ld provide enough capacity t nd Ferndale (MS303) have NAN rating, respectively, an
			would not allow load transfers i developed and	w the accommodation of futur n contingency conditions. In a there is a risk that the proper n additional line (44kV and 13	e load growth in the area or p ddition, the area surrounding ty cost will rise and/or the pre	provide adequate capacity for the proposed site is fast bei
	2. Safety	1	Not Applicable			
	3. Cyber-Security, Privacy	1	Not Applicable			
	4. Coordination, Interoperability	1	Not Applicable			
	5. Economic Development	1	Not Applicable			
	6. Environmental Benefits	1	Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project in terms of Cost Impact, where pr		Not Applicable			
	Regional Electricity Infrastructure Requirements which affect Project applicable		Not Applicable			
	Description of Incorporation of A Technology, if applicable	dvanced I	Not Applicable			
	Identify any reliability , efficiency coordination benefits	ť	future develop	ation will provide reliability be ments in the area and providi ough the Triad configuration.		
	Factors Affecting Timing/Priority		The availability the substation	of land for sale in the vicinity construction.	of Harvie Road and Veterans	Drive will affect the timing c
	Analysis of Project Benefits and C Alternative Comparison, including Nothing" Alternative (including q factors if applicable)	g "Do- d	developments.	ation would improve the relial The resulting Triad contingen -of-service station load across	cy back-up configuration wou	
			already experie capacity relief would not allov load transfers i developed and	g' alternative is not recommen enced a 2013 summer peak los for MS305 & MS303 is require w the accommodation of futu n contingency conditions. In a there is a risk that the proper n additional line (44kV and 13	ad of 102% and 95% of their O d in 2016 and 2019, respective re load growth in the area or p ddition, the area surrounding ty cost will rise and/or the pre	NAN rating, respectively, an ely. The do-nothing alternation provide adequate capacity for the proposed site is fast being the second site is fast being the

			Project Code		Report Start \	/ea <b>r</b>	Number of Years		Scale	
Stream			101	542	2	015	6		Do	llars
Project Summary			Project Name		Nev	<u>w MS, Harvie</u>	e Rd. MS - Bar	rie		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ - \$	-	\$ -	\$ -	\$-	\$ 749,000	\$ - \$	-	\$-	\$ 1,700,333
	\$1,800,000 \$1,600,000 \$1,200,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000 \$400,000 \$200,000 \$200,000 \$-	2011	2012	2013	2014	2015 202	16 2017	2018	2019	

	Project Code		Report Start Year	Number of Years	Scale
Power Stream	1	01584	2015	6	Dollars
Project Summar	Project Nam	e	<u>New MS, Little La</u>	ake MS#2 - Barrie	
Major Category	System Service				
Project Overview 1. Additional Information	Service Territory Location Scope Justification	The project en East in Barrie, no later than approvals, sul The proposed Cur Little Lake MS maximum nor North Barrie i Lake MS (MS3 substations in MS306) does backup transf new 20MVA L MS301 or MS conditions, th	and Livingstone St E area, Barri ntails the purchase of a station s , and constructing a new 44/13. summer 2018. The project inclu bstation construction, equipment I new Substation is required to p adles and Little Lake commercia 5 (MS306) is expected to exceed rmal load in 2017. Is composed of primarily 4.16kV 806) and Anne North MS (MS30 De Barrie north is 39.9MVA. The in not exceed the maximum; how	site in the vicinity of St. Vinc 8kV, 20MVA, 4 feeder munic ides engineering design, pur nt installation, and commiss provide capacity relief to Litt I developments totalling 8.8 its ONAN rating in the sum substations, with only two 1). The contingency maximu ndividual loading for each ex- ever, if one of the substation num rating of 39.9MVA duri a triad configuration that we e Lake MS#2 and the remain gency maximum load of 39. to take place in 2015 due to	tle Lake MS (MS306). With the MVA over the next five years, mer of 2016 and exceed its existing 13.8kV stations; Little im load for either of the 20MVA kisting substation (MS301 & ns experiences an outage the ing the 2017 summer peak. The ould allow the load from either ning station during contingency 9MVA.
2. General Project Information (OEB)	Contributed Capital Fiscal Year	Contributed C	Capital 0%		
	Parent WO# Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemer	Livingstone St there is a risk	risk to completion is securing th treet East in Barrie. The area sur that the property cost will rise nal line (44kV and 13.8kV) costs	rrounding the proposed site and/or the preferred site wi	is fast being developed and
	Comparative Information on Equivalent Historical Projects (if any)	construction   substation, re property. The	outh MS, a new 44/13.8kV 20MV/ pending completion in 2016. Th esulting in the purchase and den project highlighted the importa issure it is available when a new	ere was difficulty locating ar nolition of two residential h ance of identifying and purc	nd securing available land for the omes in order to secure a
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	East in Barrie, no later than	•	8kV, 20MVA, 4 feeder munic des engineering design, pur	

	Proje	ct Code	Report Start Year	Number of Years	Scale
Power Stream		101584	2015	6	Dollars
	Projec	ct Name			-
Project Summary	/ Report		<u>New MS, Little La</u>	<u>ake MS#2 - Barrie</u>	
	1a. Main Driver	(MS306). Wit next five year exceed its ma An additiona model. North Little Lake M 20MVA subst & MS306) do backup trans new 20MVA	acity Delivery. The main driver of h the proposed Cundles and Litt rs, Little Lake MS (MS306) is exp aximum normal load in 2017. I driver is to establish a station b Barrie is composed of primarily S (MS306) and Anne North MS ( ations in Barrie north is 39.9MV es not exceed the maximum; ho fer station will exceed the maxir Little Lake MS#2 would provide i306 to be divided between Littl	tle Lake commercial developm ected to exceed its ONAN rationacted to exceed the substationacted to exceed to exceed the substationacted to exceed to exc	ents totalling 8.8MVA over the ng in the summer of 2016 and nditions using the "Triad" v two existing 13.8kV stations; imum load for either of the each existing substation (MS301 ns experiences an outage the g the 2017 summer peak. The ild allow the load from either
	1b. Priority and Reasons for Priorit	y The vicinity o property cost	nereby not exceeding the contin f the proposed station site is fas will rise and/or the preferred s costs will be incurred.	st being developed and therefo	
	1c. Qualitative and Quantitative Ar Project and Project Alternatives	contingency t nalysis of The new subs development	xceeding the contingency maxir transfers should be addressed p station would improve the relial s. The resulting Triad contingen ut-of-service station load across	romptly. pility of service to existing cust cy back-up configuration woul	omers and future
		2015, but add summer of 20 addition, the Barrie North substations in risk that the J	ing' alternative provides limited ditional transfers beyond 2016 a D18 to accommodate the propose do-nothing alternative would n beyond 2017 due to the exceed in the vicinity. The area surround property cost will rise and/or the e (44kV and 13.8kV) costs will b	re not recommended since re sed Cundles and Little Lake co ot accommodate contingency ed contingency maximum load ling the proposed site is fast b e preferred site will not be ava	lief will be required before the mmercial developments. In transfers between stations in d and the lack of other 13.8kV eing developed and there is a
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperability</li> <li>Economic Development</li> <li>Environmental Benefits</li> <li>Benefits to Customers of Project Exin terms of Cost Impact, where prace</li> </ol>		le. le. le.		
	Regional Electricity Infrastructure Requirements which affect Project applicable	Not Applicab	le.		
	Description of Incorporation of Ad Technology, if applicable Identify any reliability, efficiency, s coordination benefits	safety or The new subs			
	Factors Affecting Timing/Priority	conditions th The availabili	rough the Triad configuration. ty of land for sale in the vicinity the substation construction.		

		Project (	Code	Report Start Y	ear	Number of Years		Scale	
Power Stream			101584	2	015	6		Do	ollars
		Project I	Name						
Project Summary	Report			New	MS, Little La	ake MS#2 - Ba	arrie		
	Analysis of Project B Alternative Compari Nothing" Alternative factors if applicable)	ison, including "D e (including qualit	tative development tative transfer and The 'do-no 2015, but a summer of addition, the Barrie Nort substations risk that the	out-of-service stand hing' alternative p dditional transfers 2018 to accommo le do-nothing alte h beyond 2017 du in the vicinity. Th	tion load across provides limited beyond 2016 a date the propose mative would no e to the exceede e area surround Il rise and/or the	load transfers to ta re not recommend ed Cundles and Life ot accommodate c ed contingency ma ing the proposed s preferred site wil	stations. ake place be ded since reli ttle Lake com contingency t aximum load site is fast be	tween MS306 ef will be requ nmercial devel ransfers betwo and the lack c ing developed	to MS301 i lired before opments. In een station of other 13. and there
	2011 20	012 201	13 2014	2015	2016	2017	2018	2019	2020
	<u> </u>	<u> </u>	<u> </u>						
enditures Historical/Planned	\$ - \$	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
enditures Historical/Planned	\$ - \$	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
enditures Historical/Planned	\$ - \$ \$3,500,000 - \$3,000,000 -	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
enditures Historical/Planned		- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
enditures Historical/Planned	\$3,000,000 -	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
enditures Historical/Planned	\$3,000,000 - \$2,500,000 -	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	_	\$ -	\$
enditures Historical/Planned	\$3,000,000 - \$2,500,000 - \$2,000,000 -	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	_	\$ -	\$
enditures Historical/Planned	\$3,000,000 - \$2,500,000 - \$2,000,000 - \$1,500,000 -	- \$	- \$	\$ 1,125,311	\$ 1,603,656	\$ 3,095,457 \$	-	\$ -	\$
penditures Historical/Planned	\$3,000,000 - \$2,500,000 - \$2,000,000 - \$1,500,000 - \$1,000,000 -	2011 2	- \$	\$ 1,125,311	\$ 1,603,656		-	\$ -	\$

		Project Code		Report Start Yea <b>r</b>	Number of Years	Scale
Power Stream	-	1024	455	2015	6	Dollars
Shedhi		Project Name			•	
Project Summar				<u>New MS, Melbour</u>	ne MS#2 - Bradford	
Major Category	System Service					
Project Overview 1. Additional Information	Service Territory		PowerStream N	North		
	Location Scope		The project en Drive in Bradfo service by sum	rd, and constructing a new 44 mer 2019. The project include	ea - Bradford site in the vicinity of Holland S /13.8kV, 20MVA, 4 feeder mur s engineering design, purchase nt installation, and commission	nicipal substation to be in- of station equipment,
	Justification		and Reagans (N under construc The 2013 summ station load of either MS321 c Under continge MS321 the con	MS324). Currently there is a 50 ttion, as well as a proposed inc ner peak load on MS322 was 9 18MVA being exceeded in 20 or MS324 with the forecasted ency conditions when MS322 I tingency maximum load at eit	0 home residential developme dustrial & commercial develop 28% of the ONAN rating, with t 16 in the event of an adjacent oad growth from current and oad is equally divided among t her station will be exceeded in	ment (FNB) north of 8th Line. he contingency maximum station load transfer from proposed developments. the adjacent MS324 and 2019.
			would result in	•	ne MS322 is located on leased used land from the Township o	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year Parent WO# Job Number		2016			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk		Melbourne Dri a risk that the p	ve in Bradford. The area surro	he preferred site will not be av	t being developed and there is
			At this time, th PowerStream i	· · · · ·	ssed interest in selling the leas	ed Melbourne MS land to
	Comparative Information on Historical Projects (if any)		construction po substation, res property. The p possible to ens	ending completion in 2016. Th ulting in the purchase and der project highlighted the import ure it is available when a new	A, 4-feeder substation in Barrie ere was difficulty locating and nolition of two residential hon ance of identifying and purcha substation is required. At this lelbourne MS land to PowerSt	securing available land for the nes in order to secure a sing property as early as time, the Town of Bradford
	Total Capital and OM&A Cost Renewable Energy Generatio Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Drive in Bradfo service no later	rd, and constructing a new 44 r than summer 2019. The proje	site in the vicinity of Holland S /13.8kV, 20MVA, 4 feeder mur ect includes engineering desigr on, equipment installation, and	nicipal substation to be in- n, purchase of station
	1a. Main Driver		(MS322), John east of Middlet (FNB) north of contingency m load transfer fr developments.	(MS321), and Reagans (MS324 cown Road under construction 8th Line. The 2013 summer pe aximum station load of 18MV/ om either MS321 or MS324 w Under contingency condition	eak load on MS322 was 98% of	ne residential development ial & commercial developmen the ONAN rating, with the e event of an adjacent station from current and proposed divided among the adjacent
	1b. Priority and Reasons for F		property cost v		t being developed and therefo ite will not be available which	ore there is a risk that the will mean additional line (44k\
				ceeding the contingency maxir d be addressed promptly.	num load at MS322 beyond 20	)19 during contingency Pg

	Pr	oject Code		Report Start Year	Number of Years	Scale
Power Stream	-	1024	455	2015	6	Dollars
Project Summary		oject Name		<u>New MS, Melbourr</u>	ne MS#2 - Bradford	
	1c. Qualitative and Quantitative Project and Project Alternatives	S	future resident would also allo contingency m A possible alter implement a 2: station; howev no additional f adjacent statio The remaining MS322 was 98' exceeded in 20 forecasted load MS322 load is either station v developed and	tial, industrial, and commercial ow contingency transfers from aximum station load. rnative to the single 20MVA 44 x10MVA 44/13.8kV configurati rer, initial cost estimates are 1. eeders. The additional cost is o uns in the event of a transform 'do-nothing' alternative is not % of the ONAN rating, with the D16 in the event of an adjacent d growth from current and pro equally divided among the adj will be exceeded in 2019. In ad	developments. The resulting i any adjacent out-of-service sta 4/13.8kV station transformer co on. The 2x10MVA alternative p 5 times greater than the cost of lifficult to justify given the ava er outage at the proposed stat recommended because the 2C contingency maximum station station load transfer from eith posed developments. Under co acent MS324 and MS321 the co dition, the area surrounding the ty cost will rise and/or the present	increase in station capacity ations without exceeding the provides redundancy at the of a single 20MVA station, with ilable transfer capability to ion. 2013 summer peak load on n load of 18MVA being her MS321 or MS324 with the ontingency conditions when ontingency maximum load at
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperabilit</li> <li>Economic Development</li> <li>Environmental Benefits</li> <li>Benefits to Customers of Project in terms of Cost Impact, where</li> </ol>	ty ct Expressed	Not Applicable Not Applicable Not Applicable Not Applicable Not Applicable			
	Regional Electricity Infrastructu Requirements which affect Proj applicable	ire	Not Applicable			
	Description of Incorporation of Technology, if applicable	Advanced	Not Applicable			
	Identify any reliability , efficient coordination benefits			ments in the area and providing		
	Factors Affecting Timing/Priorit			of land for sale in the vicinity ubstation construction.	of Holland Street West and Me	elbourne Drive will affect the
	Analysis of Project Benefits and Alternative Comparison, includ Nothing" Alternative (including factors if applicable)	ing "Do- qualitative	future resident would also allo	tial, industrial, and commercial	developments. The resulting i	increase in station capacity
			implement a 2 station; howev no additional f	rnative to the single 20MVA 44 x10MVA 44/13.8kV configurati rer, initial cost estimates are 1. eeders. The additional cost is o ons in the event of a transform	on. The 2x10MVA alternative p 5 times greater than the cost c lifficult to justify given the ava	provides redundancy at the of a single 20MVA station, with ilable transfer capability to
			MS322 was 98 exceeded in 20 forecasted load MS322 load is either station w developed and	'do-nothing' alternative is not % of the ONAN rating, with the 116 in the event of an adjacent d growth from current and pro equally divided among the adj will be exceeded in 2019. In ad I there is a risk that the proper In additional line (44kV and 13	e contingency maximum station station load transfer from eith posed developments. Under c acent MS324 and MS321 the c dition, the area surrounding th ty cost will rise and/or the pres	n load of 18MVA being ner MS321 or MS324 with the ontingency conditions when ontingency maximum load at ne proposed site is fast being

			Project Code		Report Start	Yea <b>r</b>	Number of Yea	ars	Scale	
Power Stream	5		10	2455	2	2015		6	Do	llars
Project Summary			Project Name		<u>New N</u>	<u>//S, Melbour</u>	<u>ne MS#2 - E</u>	<u>Bradford</u>		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$-	\$-	\$ -	\$ -	\$-	\$ 749,000	\$ 1,651,393	\$ 3,187,430	\$-	\$
	\$3,500,00 \$3,000,00 \$2,500,00 \$2,000,00 \$1,500,00 \$1,000,00 \$500,00	0 0 0								

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		101	1068	2015	6	Dollars
Silean		Project Name				
Project Summar	ry Report	-,		New MS, Mill Stree	t MS#2 - Tottenham	
Major Category	System Service					
Project Overview	oystelli oerriee					
1. Additional Information	Service Territory		PowerStream	North		
	Location		Mill St E and M	IcCurdy Dr area, Tottenham		
	Scope		Street East and feeder municip replace the exi engineering de	tails the purchase of a station s d McCurdy Drive in Tottenham, bal substation to be in-service r isting Mill St. MS (MS835), whic esign, purchase of station equip d commissioning.	suitable for constructing a ne no later than summer 2019. Th ch is currently located on lease	w 2x5MVA, 44-8.32 kV, 3- e new Mill Street MS#2 is to d land. The project includes
	Justification		(500 home), ar Street and Que	new substation is required to p nd LRG (335 home) residential o een Street area of Tottenham. red its ONAN rating in the sumr	developments to be built over This additional 3.2MVA of resid	
			outage, the ba 9.1MVA in 201 transformers a	ere are only two substation loc ckup transfer to Mill St MS835 6. The new 2x5MVA Mill St MS t the substation, which would or surrounding substations.	would exceed its contingency #2 would provide redundancy	maximum load rating of in the form of two separate
				oted that the existing Mill St M need to maintain the leased lar		and the new substation would
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2016			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	< Management	McCurdy Drive Ballymore and	sk to completion is securing the in Tottenham. The area surrou Nordstar residential subdivisic site will not be available which	unding the proposed site is be ons and there is a risk that the	ing developed by the property cost will rise and/or
	Comparative Information or Historical Projects (if any)	n Equivalent	construction p substation, res property. The	th MS, a new 44/13.8kV 20MV/ ending completion in 2016. The sulting in the purchase and den project highlighted the importa sure it is available when a new	ere was difficulty locating and nolition of two residential hom ance of identifying and purcha	securing available land for the les in order to secure a
	Total Capital and OM&A Cos Renewable Energy Generatic Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Tottenham, an by summer 20 currently locat	tails the purchase of a station s d constructing a new 2x5MVA, 19. The new Mill Street MS#2 is ed on leased land. The project station construction, equipmen	44-8.32 kV, 3-feeder municipa s to replace the existing Mill St includes engineering design, p	al substation to be in-service . MS (MS835), which is urchase of station equipment,
	1a. Main Driver		(450 home), N next five years	ity Delivery. The main driver o ordstar (500 home), and LRG (3 in the Mill Street and Queen S d will cause Mill St. MS835 to e	335 home) residential develop treet area of Tottenham. This	ments to be built over the additional 3.2MVA of
			substation loca Mill St MS835 Mill St MS#2 w	driver is to establish a back-up ated in Tottenham. If Nolan MS would exceed its contingency r rould provide redundancy in th llow transfer capability in case	834 were to experience an ou naximum load rating of 9.1MV e form of two separate transfo	tage, the backup transfer to A in 2016. The new 2x5MVA prmers at the substation,
				oted that the existing Mill St M need to maintain the leased lar		and the new substation would
						_

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		101	1068	2015	6	Dollars
		Project Name				
Project Summary	y Report			New MS, Mill Stree	<u>t MS#2 - Tottenham</u>	
	1b. Priority and Reasons for I	Priority	subdivisions ar available which In addition, con	nd there is a risk that the prope movill mean additional line (44) ntingency transfers from Nolar	ing developed by the Ballymor erty cost will rise and/or the pr kV and 8.32kV) costs will be inc n MS834 are not possible beyo d should be addressed prompt	eferred site will not be urred. nd 2016 without exceeding
	1c. Qualitative and Quantitat Project and Project Alternati		in the Ballymo maximum load	re, Nordstar, and LRG resident	bility of service to existing custo ial developments. The resulting onfiguration at the new substa Jolan MS834.	g increase in contingency
			approximately the remainder the do-nothing MS835 beyond substations in that the prope	100A, but additional relief wil of the proposed Ballymore, Ne alternative would not accome 2016 due to the exceeded co the vicinity. The area surround	load transfers to take place be be required before the summ ordstar, and LRG residential de modate contingency transfers l ntingency maximum load and t ing the proposed site is being eferred site will not be availabl	er of 2019 to accommodate velopment loads. In addition, between Nolan MS834 and the lack of other 8.32kV developed and there is a risk
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperab	oility	Not Applicable			
	5. Economic Development	·	Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Pro in terms of Cost Impact, whe					
	Regional Electricity Infrastruc Requirements which affect P applicable		Not Applicable			
	Description of Incorporation Technology, if applicable	of Advanced	Not Applicable			
	Identify any reliability , efficience coordination benefits	ency, safety or	Ballymore, Nor		nefits by providing the require elopments in the area and prov e substations in Tottenham.	
	Factors Affecting Timing/Pric	prity	of the substati	on construction. The final com	of Mill Street East and McCurc pletion dates for the Ballymore timing for the required station	e, Nordstar, and LRG

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	-		101	1068	20	15	1	6	Do	ollars
			Project Name							
Project Summar	y Report				<u>New M</u>	S, Mill Stree	<u>t MS#2 - To</u>	<u>ttenham</u>		
			luding "Do- ding qualitative	maximum load from Nolan MS The 'do-nothin approximately the remainder the do-nothing MS835 beyond substations in that the prope line (44kV and The 'do-nothin approximately	at the new sul sag' alternative p 100A, but addi of the propose alternative wo 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs w g' alternative p 100A, but addi of the propose	ostation would p rovides limited tional relief will d Ballymore, No buld not accomm e exceeded con e area surround e and/or the pre vill be incurred. rovides limited tional relief will d Ballymore, No	load transfers t be required be ordstar, and LRG nodate conting ntingency maxin ing the propose eferred site will load transfers t be required be ordstar, and LRG	o take place bet fore the summe G residential dev ency transfers b num load and th ed site is being d not be available o take place bet fore the summe G residential dev	ween MS835 er of 2019 to a relopment loa etween Nolan he lack of othe eveloped and e which will me ween MS835 er of 2019 to a relopment loa	and MS834 of accommodate ds. In addition MS834 and er 8.32kV I there is a rise ean addition and MS834 of accommodate ds. In addition
				substations in that the prope	l 2016 due to th the vicinity. The rty cost will rise	ne exceeded con e area surround	ntingency maxin ing the propose eferred site will	num load and the stand the stand the site is being d not be available	ne lack of othe eveloped and	er 8.32kV there is a r
	2011	2012	2013	substations in that the prope	l 2016 due to th the vicinity. The rty cost will rise	ne exceeded con e area surround e and/or the pre	ntingency maxin ing the propose eferred site will	num load and tl ed site is being d	ne lack of othe eveloped and	er 8.32kV I there is a ri
penditures Historical/Planned	<b>2011</b> \$ -	<b>2012</b> \$ -	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and tl ed site is being d not be available	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean addition
penditures Historical/Planned	\$ -	\$ -	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean additior
penditures Historical/Planned	\$ -	\$ - 000	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean additior
penditures Historical/Planned	\$ - \$4,000,0 \$3,500,0	\$ - 000	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean additior
penditures Historical/Planned	\$ -	\$ - 000 - 000 - 000 -	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean additior
penditures Historical/Planned	\$ - \$4,000,0 \$3,500,0 \$3,000,0	\$ -	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ris ean addition
penditures Historical/Planned	\$ - \$4,000,0 \$3,500,0 \$3,000,0 \$2,500,0	\$ -	<b>2013</b> \$ -	substations in that the prope line (44kV and	d 2016 due to th the vicinity. The rty cost will rise 8.32kV) costs v 2015	e exceeded cor e area surround e and/or the pre vill be incurred. 2016	ntingency maxin ing the propose eferred site will <b>2017</b>	num load and th ed site is being d not be available 2018	ne lack of othe eveloped and e which will me 2019	er 8.32kV I there is a ri ean addition

\$500,000

\$-

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	100	)420	2015	6	Dollars
Sircan		Project Name				
Project Summar	y Report	-,		Vaughan TS #4	4 - Build Station	
Maior Cotocom	Sustan Carries					
Major Category Project Overview	System Service					
1. Additional Information	Service Territory Location Scope Justification		Construction o In order to me feeder capacity extensive trans possible. It is d	rner of Kipling & Kirby, Vaugha f VTS#4 et the forecast capacity deficie y must be commissioned in the smission facilities and correspo	ncy in the summer of 2017, ac spring of 2017. Accordingly, nding right-of-way acquisition djacent to existing rights-of-w	options which require must be developed as soon as ay in the study area or locate a
2. General Project Information (OEB)	Contributed Capital Fiscal Year Parent WO# Job Number		Contributed Ca 2015 311304 C00850	apital 0%		
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risl	k Management	Approvals by a can disrupt the	uthorities, electrical equipmen project schedule. A consultan esolving issues that may arise	t will be contracted to aide in	
	Comparative Information o Historical Projects (if any)	n Equivalent		project will be PowerStream's s sformer station design will be b		
	Total Capital and OM&A Cos Renewable Energy Generati Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			presents the risk, value and cos ad growth through additional t		-
	1a. Main Driver		that a new TS i	ity Delivery. VTS#4 Needs Asse s required in Vaughan to meet smission facilities and correspo	the load growth. Accordingly,	options which require
	1b. Priority and Reasons for	Priority	municipalities.	performed a 2011-2020 load for According to the load forecast in the spring of 2017 in order t	, additional transformation an	d feeder capacity must be
	1c. Qualitative and Quantita Project and Project Alternat		-	ansformer stations and feeders erational flexibility of transferri tion system.		-
			disruptions giv	s obligated to provide the load en the status quo. If adequate re is a strong probability that n	backup facilities are not avail	able during contingency
			Knowingly run	ning equipment beyond establ	ish guidelines does not repres	ent good utility practice.
	2. Safety		recent transfor	nt will be installed following Po mer station projects. PowerStr ipment selected reducing the	ream maintnenace groups will	
	<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperat</li> </ol>	bility	protocols that		· · · ·	roducts that use cmmunication be integrated into an
	5. Economic Development		development.		orth Vaughan. This is expecte	d to be attractive for business
5. Category-Specific Requirements for Each Project/Activity (OEB)			the risk of the	built at all, there is a risk of no	customers. System reliability	omer needs as well as increase would likely decrease by way an satisfied.

		P	roject Code		Report Start Y	ear	Number of Yea	irs	Scale	
Power Stream			100	0420	20	)15		5	C	ollars
Project Summary	v Report	P	roject Name		Va	ughan TS #4	4 - Build Sta	<u>tion</u>		
	Regional Electricity Infrastructure Requirements which affect Project applicable			premature equinement of the second seco	uipment failure s. Running feed	ting stations an s and reduce life ers beyond the nal to the squa	e of existing ass re normal ratin	ets. PowerStre g (i.e. 400 Amp	am may not b	e able to supp
	Description of Incorporation of Advanced Technology, if applicable Identify any reliability , efficiency, safety of coordination benefits Factors Affecting Timing/Priority			transformers.		ig equipmnet w integrated into			-	
						s more reliable o witchgear reduc			-	
				Approvals by a project schedu		equipment deliv	very lead times	can be factors	that could cau	ise delays in t
	Analysis of Project	ct Renefits and	d Costs with	A new transfor	mer station is a	np of PowerStr	eam's single la	oost invostmor	nts The const	ruction will
	Analysis of Projec Alternative Comp Nothing" Alternat factors if applicab	parison, incluc itive (including	ding "Do-	ensure regulat continue to op increase once Capacity will ir be served.Utili	ory compliance perate it system the new statior ncrease an addi ty Practice in te	is achieved in t	erms of serving fective manner will allow for n This will ensure lization and loa	our customers . It shows Goo nore feeder tie additional load	b. It will allow d Service relia s and backup d growth and	PowerStrean bility will options. Syste
	Alternative Comp Nothing" Alternat	parison, incluc itive (including	ding "Do-	ensure regulat continue to op increase once Capacity will ir be served.Utili	ory compliance perate it system the new statior ncrease an addi ty Practice in te	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset ut	erms of serving fective manner will allow for n This will ensure lization and loa	our customers . It shows Goo nore feeder tie additional load	b. It will allow d Service relia s and backup d growth and	PowerStrean bility will options. Syst customers ca
penditures Historical/Planned	Alternative Comp Nothing" Alternat factors if applicat	parison, incluc itive (including ble)	ding "Do- g qualitative	ensure regulat continue to op increase once Capacity will ir be served.Utili meet transform	ory compliance berate it system the new statior ncrease an addi ty Practice in te mer station and 2015	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset ut feeder loading	erms of serving fective manner will allow for n This will ensure lization and loa guide lines. <b>2017</b>	our customers It shows Goo hore feeder tie additional load d security. It v	b. It will allow d Service relia s and backup d growth and vill enable Pov	PowerStrean bility will options. Syst customers ca verStream to
penditures Historical/Planned	Alternative Comp Nothing" Alternat factors if applicab	parison, includ itive (including ble) 2012 - \$	ding "Do- g qualitative	ensure regulat continue to op increase once Capacity will in be served.Utili meet transform	ory compliance berate it system the new statior ncrease an addi ty Practice in te mer station and 2015	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset uti feeder loading 2016	erms of serving fective manner will allow for n This will ensure lization and loa guide lines. <b>2017</b>	our customers It shows Goo hore feeder tie additional load d security. It v	b. It will allow d Service relia s and backup d growth and vill enable Pov	PowerStream bility will options. Syst customers ca verStream to
penditures Historical/Planned	Alternative Comp         Nothing" Alternation         factors if applicate         \$       -         \$       -         \$12,000,000         \$10,000,000         \$8,000,000	parison, includ itive (including ble) 2012 - \$	ding "Do- g qualitative	ensure regulat continue to op increase once Capacity will in be served.Utili meet transform	ory compliance berate it system the new statior ncrease an addi ty Practice in te mer station and 2015	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset uti feeder loading 2016	erms of serving fective manner will allow for n This will ensure lization and loa guide lines. <b>2017</b>	our customers It shows Goo hore feeder tie additional load d security. It v	b. It will allow d Service relia s and backup d growth and vill enable Pov	PowerStream bility will options. Syst customers ca verStream to
penditures Historical/Planned	Alternative Comp Nothing" Alternation factors if applicate 2011 \$ - \$ \$12,000,000 \$10,000,000	parison, includ itive (including ble) 2012 - \$ 0	ding "Do- g qualitative	ensure regulat continue to op increase once Capacity will in be served.Utili meet transform	ory compliance berate it system the new statior ncrease an addi ty Practice in te mer station and 2015	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset uti feeder loading 2016	erms of serving fective manner will allow for n This will ensure lization and loa guide lines. <b>2017</b>	our customers It shows Goo hore feeder tie additional load d security. It v	b. It will allow d Service relia s and backup d growth and vill enable Pov	PowerStream bility will options. Syst customers ca verStream to
penditures Historical/Planned	Alternative Comp         Nothing" Alternation         factors if application         \$       -       \$         \$12,000,000         \$10,000,000         \$8,000,000         \$6,000,000	parison, includ itive (including ble) 2012 - \$ - \$	ding "Do- g qualitative	ensure regulat continue to op increase once Capacity will in be served.Utili meet transform	ory compliance berate it system the new statior ncrease an addi ty Practice in te mer station and 2015	is achieved in t in a safe and ef is in service. It tion 170 MVA. erms of asset uti feeder loading 2016	erms of serving fective manner will allow for n This will ensure lization and loa guide lines. <b>2017</b>	our customers It shows Goo hore feeder tie additional load d security. It v	b. It will allow d Service relia s and backup d growth and vill enable Pov	PowerStream bility will options. Syst customers ca verStream to

	Project Co	de	Report Start Year	Number of Years	Scale
Power Stream		100963	2015	6	Dollars
Stream					
Project Summar	Project Na		its (23M22 & 23M23) fr	om Midhurst TS2 to Ess	a Rd/Mapleview Dr
Project Summar		2.2.1 11(1 01100			
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory	PowerStream			
	Location		Fownship and Barrie	an af annualizataly 17km/a af	Duddlad size its frame Midle unst
	Scope	TS2 to Essa Ro construct 201 Street, and w construct 201 intersection o 2017) will be Mapleview Dr	bad and Mapleview Drive in thi 5) will encompass the area from est along Sunnidale Road to Do 6) will be south from the inters of Dunlop Street West and High south from Highway 27 and Du	on of approximately 17km's of ree segments. The first segment m Midhurst TS2, west along Car obson Road. The second segmen section of Sunnidale Road and D way 27. The final segment (Pha nlop Street West to the interse to be in-service by summer 201 and commissioning.	: (Phase 1 - design 2013, son Road, south along Anne nt (Phase 2 - design 2014, Dobson Road to the se 3 - design 2015, construct ction of Essa Road and
	Justification	to the west, V Salem/Lockha and 13M1 fee Center #1 is c years, Data Ce Data Center # years, and Da years. Three c executed Ope conditions, i.e load. Based o exceed 400A 600A in 2020. be exceeded i Barrie south a centers is sati	Welham Road to the east, Big B art Road to the south. The Barr eders. There are four large data urrently contracted for 10MVA enter #2 is currently contracted f3 is currently contracted for 5N ta Center #4 is currently contra- of the data centers have made erating Agreements with Power e., loss of their normal supply, t n the contingency condition re in 2014, with feeder 13M5 exce Feeders 23M5 and 13M6 will of in 2020 and 2022, respectively. area can be supplied, as well as isfied under contingency condition the capacity requirement, Pow I capacity (166MVA) of Midhurs	bacity relief to the Barrie south a ay Point Road and Harvie Road e south area is currently suppli- centers currently located in the with expansion plans to reach l for 5.5MVA with provisions to AVA with expansion plans to re- acted for 2MVA with plans to re- capital contributions for back-u Stream for dual supply. This me he back-up feeder must be able quirements feeder 13M1 and 1. eeding the 600A thermal limit in exceed 400A in 2015 and 2016, The new feeders will ensure th ensuring that the contractual a ions.	to the north and ed by the 23M5, 13M5, 13M6 e Barrie south area; Data 20MVA over the next 8-10 go to 11MVA at any time, ach 20MVA over the next 8-10 ach 10MVA within the next 5 p feeder supply and have eans that under contingency e to supply the full facility 3M5 summer peak loading will n 2017 and 13M1 exceeding respectively, while 600A will at future load growth in the greements with the data
2. General Project Information (OEB)	Contributed Capital	Contributed 0	Capital 0%		
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managem	The ramping the project. C	up of the scheduled customer l	ne required approvals from the oad at each of the data centers Ine for Phase 1 outside of the B	will also impact the timing of
	Comparative Information on Equivalen Historical Projects (if any)		ojects for new circuits have tak ith construction.	en 6-8 months to obtain the ne	cessary approvals before
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 of			
4. Evaluation Criteria (OEB)	Project Summary	TS2 to Essa Ro construct 201 Street, and w construct 201 intersection o 2017) will be Mapleview Dr	bad and Mapleview Drive in thi 5) will encompass the area from est along Sunnidale Road to Do 6) will be south from the inters of Dunlop Street West and High south from Highway 27 and Du	on of approximately 17km's of ree segments. The first segment m Midhurst TS2, west along Car obson Road. The second segmer section of Sunnidale Road and E way 27. The final segment (Pha nlop Street West to the interse to be in-service by summer 201 and commissioning.	: (Phase 1 - design 2013, son Road, south along Anne nt (Phase 2 - design 2014, Dobson Road to the se 3 - design 2015, construct ction of Essa Road and

	0-	oject Code		Report Start Year	Number of Years	Scale
Bowers	FI				Number of reals	
Stream		100963		2015	6	Dollars
	Pri	oject Name				
Project Summary	Report	New 2x44kV	circuit	<u>s (23M22 &amp; 23M23) fro</u>	m Midhurst TS2 to Ess	sa Rd/Mapleview Dr
	1a. Main Driver 1b. Priority and Reasons for Prior	south a four lar for 10N contrac contrac is curre centers Agreen their no conting 2014, v Feeder 2020 ar can be under o An add contrac capacit terms o	area. Bar rge data VIVA with cted for s cted for s ently con s have m ments with ormal su gency col- with feed rs 23M5 a nd 2022, supplied continge ditional d ctual obl ty is not u of the Mi	pply, the back-up feeder must ndition requirements feeder 1 ler 13M5 exceeding the 600A t and 13M6 will exceed 400A in respectively. The new feeders d, as well as ensuring that the o ncy conditions. river is to maximize the usage igation with Hydro One to utili utilized, PowerStream will nee idhurst expansion CCRA.	by the 23M5, 13M5, 13M6 and the Barrie south area; Data Centric AVA over the next 8-10 years, to 11MVA at any time, Data Centric reach 20MVA over the next 8 to reach 10MVA within the next tack-up feeder supply and have ly. This means that under contric be able to supply the full facil 3M1 and 13M5 summer peak thermal limit in 2017 and 13M 2015 and 2016, respectively, v is will ensure that future load g contractual agreements with the of capacity at Midhurst TS#2. The full capacity (166MVA) d to pay Hydro One for any stru- hermal limits will be exceeded	d 13M1 feeders. There are ter #1 is currently contracted Data Center #2 is currently enter #3 is currently -10 years, and Data Center #4 et 5 years. Three of the data e executed Operating tingency conditions, i.e., loss of lity load. Based on the loading will exceed 400A in 1 exceeding 600A in 2020. while 600A will be exceeded in prowth in the Barrie south area he data centers is satisfied PowerStream has a of Midhurst TS#2. If this randed capacity under the
	1c. Qualitative and Quantitative Project and Project Alternatives	beyond the urg e Analysis of The two s capacit supply capacit would annual The do meet th In addir feeder	d 2017 un gency to vo circuits ty relief t contract ty of Mid result in lly. o-nothing he contra- ition, the	nder contingency conditions. T secure additional capacity in B s would add approximately 50 to the existing feeders for future tual obligations during conting hurst TS#2 to reduce the stran cost savings realized from line galternative is not recommend actual agreements to supply the status-quo will have limited a e dual supply data center requ	The contractual obligations for marrie south. MVA of capacity to the Barrie re growth and ensure that Pow ency conditions. The feeders w inded capacity under the CCRA. I loss reductions resulting in ap led since PowerStream will be ne data centers under conting djacent feeder transfers upon	at a risk of not being able to ency conditions beyond 2017. loss of any Barrie south
		not ecc Constru study. <sup>–</sup> Barrie s	onomical ucting a The alter south alc	to cross Kempfelt Bay utilizing Ily viable, with initial cost estin new transformer station in Bai mative encompasses the const ong an existing transmission co estimates for the proposed alt	nates exceeding \$26 million. rrie was covered in the 2010 H rruction of 15km of 230kV tran prridor and the construction of	lydro One led South Simcoe Ismission line from Essa TS to
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ul> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> <li>4. Coordination, Interoperabilit</li> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> <li>Benefits to Customers of Projection terms of Cost Impact, where</li> <li>Regional Electricity Infrastructure</li> <li>Requirements which affect Projection of Incorporation of Technology, if applicable</li> <li>Identify any reliability, efficient coordination benefits</li> <li>Factors Affecting Timing/Prioritit</li> </ul>	y Not Ap Not Ap Not Ap Not Ap Not Ap not Ap ret Expressed practicable Not Ap sect, if Advanced Not Ap cy, safety or thereby help re	oplicable. oplicable w feeder y increas		reases reliability to customers	. The new feeders will also
			One for I	Phase 1 outside of the Barrie s		timing of the feeder
						Pg 2

		P	Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	-		100	0963	20	)15		6		Dollars
Project Summary Report Analysis of Project Benefits a Alternative Comparison, incl			d Costs with	x44kV circui The two circui	·	proximately 50	MVA of capacit	y to the Barrie s	south area, t	hereby provic
	Nothing" Alternativ factors if applicable		g qualitative	capacity of Mi would result in annually. The do-nothin	ctual obligations dhurst TS#2 to r n cost savings re g alternative is ractual agreeme	reduce the strar ealized from line not recommenc	nded capacity u loss reduction led since Power	nder the CCRA. s resulting in ap rStream will be	In addition, oproximately at a risk of n	the new feed \$63,000 ot being able
				In addition, th	e status-quo wi he dual supply o	ll have limited a	djacent feeder	transfers upon	loss of any E	arrie south
					e to cross Kemp				urst TS to Es	a/Mapleview
				not economica Constructing a study. The alte Barrie south a	e to cross Kemp ally viable, with new transform ernative encomp long an existing t estimates for t	initial cost estin er station in Ba passes the const transmission co	nates exceeding rrie was covere truction of 15kr prridor and the	g \$26 million. d in the 2010 H n of 230kV tran construction of	ydro One leo smission line	l South Simco e from Essa TS
	2011 2	2012	2013	not economica Constructing a study. The alte Barrie south a	ally viable, with new transform ernative encomp long an existing	initial cost estin er station in Ba passes the const transmission co	nates exceeding rrie was covere truction of 15kr prridor and the	g \$26 million. d in the 2010 H n of 230kV tran construction of	ydro One leo smission line	l South Simco e from Essa TS
penditures Historical/Planned	2011 Z	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simco e from Essa TS 25 MVA static
penditures Historical/Planned	2011 2 \$ - \$ \$6,000,000 -	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	I South Simco from Essa TS 25 MVA static 2020
penditures Historical/Planned	\$ - \$	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simcc e from Essa TS 25 MVA static 2020
penditures Historical/Planned	\$ - \$	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simcc e from Essa TS 25 MVA static 2020
penditures Historical/Planned	\$ - \$	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simcc e from Essa TS 25 MVA static 2020
penditures Historical/Planned	\$ - \$ \$6,000,000 - \$5,000,000 - \$4,000,000 -	2012	2013 \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simcc e from Essa TS 25 MVA static 2020
penditures Historical/Planned	\$       -       \$         \$6,000,000       -         \$5,000,000       -         \$4,000,000       -         \$3,000,000       -	2012	<b>2013</b> \$ -	not economica Constructing a study. The alte Barrie south a The initial cost	ally viable, with new transform ernative encomp long an existing t estimates for t 2015	initial cost estin er station in Ba passes the const transmission co he proposed alt <b>2016</b>	nates exceeding rrie was covere truction of 15kr prridor and the cernative was \$ <b>2017</b>	g \$26 million. d in the 2010 H n of 230kV tran construction of 140 million. <b>2018</b>	ydro One leo Ismission line f a new 75/1	d South Simcc e from Essa TS 25 MVA static 2020

	Project	Code	Report Start Year	Number of Years	Scale				
Power Stream	5	100912	2015	6	Dollars				
oncum	Project	Project Name							
	Ac	Add one 27.6 kV Cct on Steeles Ave From Jane St to Keele St by Rebuilding Existing							
Project Summar	ry Report	2 cct Pole line into 4 ccts							
Major Category	System Service								
Project Overview	-,								
1. Additional Information	Service Territory Location	PowerStream On Steeles A	n South ve from Jane St to Keele St in Va	ughan					
	Scope	This project and extend f	is to rebuild the existing 2 ccts prevention of the second seco	ole line on Steeles Ave from Ja					
	Justification	located with of Steeles Av	icial Plan Amendment (OPA) 620 in the southern portion of the C renue between Keele and Jane S entred on a proposed station sit	ty of Vaughan (see key map). I treets directly north of York Ur	t is located on the north side niversity in the City of Toronto				
		mixed use hi accommodat office/comm and built for including the	function of this Secondary Plan gher density buildings in a comp te 5,500 residential units for a p ercial space generating approxir m will be in response to, and su spadina Subway extension, a c es and complements the develop	act pedestrian-friendly urban otential population of 11,000 p nately 4,000 employees. The p oportive of, the higher order tr ommuter parking lot and a bus	form. The Plan is expected to bersons and 83,000 sq.m. of roposed land uses, densities ansit infrastructure plans, sterminal. The Plan also				
			mand for OPA 620 is estimated t IW, a new feeder is required for		peak demand from TTC subwa				
			will extend 21M2 from Jane St to new development in the Steeles		supply capacity to TTC subway				
			will also increase supply reliabili ele St area by adding a new feec						
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%						
	Fiscal Year Parent WO#	2019							
3. General Information on the Project/Activity (OEB)	Job Number Risks to Completion and Risk Manag	Capital desig Another risk	get approval from the City of To n will start the design of the pro is the load ramping up schedule monitor the load growth in Stee	ject in advance and should get after the subway is in service.					
	Comparative Information on Equiva Historical Projects (if any)	l <mark>lent</mark> Not Applicat	le.						
	Total Capital and OM&A Costs for Renewable Energy Generation porti	0 on of							
4. Evaluation Criteria (OEB)	Projects (if any) Project Summary	This project i	is to rebuild the existing 2 ccts p	ole line on Steeles Ave from Ja	ne St to Keele St into 4 ccts.				
		Feeder 21M2	2 will be extended to Keele St an	d Steeles Ave area.					
	1a. Main Driver		ver for this project is to support v subway is in service.	the capacity delivery in the Ke	ele St and Steeles Ave area				
	1b. Priority and Reasons for Priority		bway will be in service in 2015 a	nd a few new commercial proj	jects are under design in the				
	1c. Qualitative and Quantitative Ana Project and Project Alternatives		will extend one feeder (future tv Iso significantly improve power						
	2. Safety	Not Applicat	le.						
	3. Cyber-Security, Privacy	Not Applicat	le.		Pg				


		Project C	Code	Report Start Y	'ea <b>r</b>	Number of Yea	rs	Scale	
Power Stream	-		100912	2	015	é	i	Do	llars
Project Summar	y Report	Project M Adc	lame I one 27.6 kV C		es Ave From 2 cct Pole lir			y Rebuilding	Existin
	4. Coordination, In		Not Applicable						
	5. Economic Devel 6. Environmental E		Not Applicable						
Category-Specific Requirements for			Not Applicable essed Not Applicable						
ch Project/Activity (OEB)		ipact, where practi							
	Regional Electricity Requirements whi applicable	/ Infrastructure ch affect Project, if	Not Applicable	2.					
		prporation of Advar licable	nced Not Applicable	2.					
	Identify any reliabi coordination bene		ety or Not Applicable	2.					
	Factors Affecting T	iming/Priority	The load ramp	ing up schedul	e will affect the	timing and prio	rity of this proj	ject.	
			with This project w	ill extend one f	eeder (future tw	vo) into the area	and increase	capacity by 40 N	
	· · · · · · · · · · · · · · · · · · ·		ative alternatives is	the status quo xisting facilities		g, (i.e., not build	project as pro	oposed), but to s	Th supply loa
			peaks of the e	PA 620 is suppli xisting feeders 55M11 20 55M12 30 20M8 360	were: 0A 0A	M11 & 55M12 fi	rom Finch TS a	is well as 20M8 f	rom VTS:
			feeders are re obligation to s schedule of th	quired as the d upply new cust	evelopment pro tomers along Ste elopment. If loa	gresses. Status eeles Ave. The ir	Quo will jeopa npact severity	nt in the OPA 62 rdize PowerStre and timing will nothing" optior	am's depend o
	2011	2012 201	feeders are re obligation to s schedule of th sufficient capa	quired as the d upply new cust e OPA 620 dev	evelopment pro tomers along Ste elopment. If loa	gresses. Status eeles Ave. The ir	Quo will jeopa npact severity	rdize PowerStre and timing will	am's depend or
penditures Historical/Planned	2011 \$ - \$	2012 201 - \$	feeders are re obligation to s schedule of th sufficient capa	quired as the d upply new cust e OPA 620 dev city for future	evelopment pro comers along Ste elopment. If loa load growth.	gresses. Status eeles Ave. The ir d grows as proj	Quo will jeopa npact severity ected, the "do	rdize PowerStre and timing will nothing" optior	am's depend or n may not <b>202</b> 1
penditures Historical/Planned			feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not <b>202</b> 1
penditures Historical/Planned	\$ - \$		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend o n may not <b>202</b>
penditures Historical/Planned	\$ - \$		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend o n may not <b>202</b>
penditures Historical/Planned	\$ - \$		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not <b>202</b> 1
penditures Historical/Planned	\$ - \$ \$1,200,000 \$1,000,000		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not <b>202</b> 0
penditures Historical/Planned	\$ - \$ \$1,200,000 \$1,000,000		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not 2020
penditures Historical/Planned	\$ - \$ \$1,200,000 - \$1,000,000 - \$800,000 -		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not <b>202</b> 0
xpenditures Historical/Planned	\$ - \$ \$1,200,000 - \$1,000,000 - \$800,000 - \$600,000 -		feeders are re obligation to s schedule of th sufficient capa 3 2014	quired as the d upply new cust e OPA 620 dev icity for future <b>2015</b>	evelopment pro tomers along Ste elopment. If loa load growth. 2016	gresses. Status i eeles Ave. The ir d grows as proj 2017	Quo will jeopa npact severity ected, the "do 2018	rdize PowerStre and timing will nothing" optior 2019	am's depend or n may not <b>202</b> 0

	Projec	t Code	Report Start Year	Number of Years	Scale
Power	<u> </u>	101487	2015	6	Dollars
Sirean	Projec	t Name			
Project Summa			one Additional 27.6 kV	Cct on Major Mack and	9th Line
Major Category	System Service				
Project Overview 1. Additional Information	Service Territory	PowerStream	n South		
	Location		ack Dr from 9th Line to the we	est in Markham	
	Location	-	rom Major Mack to the south		
	Scope	This project	is to:		
			-	CNR to 9th Line, approx 1.3 km.	
			on 9th Line from Bur Oak Ave	e to Major Mack Dr tion as per PowerStream's stand:	ard
	Justification			vo ccts on Major Mack and 9th L	
	Justinearion				
				portion of a circuit that feeds a c bical of long rural lines with isola	
		There are no	pure radial feeders in Power	Stream. All of PowerStream's fee	eders have normal open ties
				e supplied from different directi re is only one path between any	
		second cct s	tops half way and is a radial si	of Hwy 48, but only one cct goe upply. There are two ccts on 9th	Line north of 16th Ave, but
		only one cct	goes all the way to Major Ma	ck Dr. The second cct stops half	way and is a radial supply.
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year	2020			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Mana			Markham in time. project in advance and should ge	et the approvals in place in time.
				, 0	
	Comparative Information on Equiv Historical Projects (if any)	alent Not Applical	ble.		
	Total Capital and OM&A Costs for Renewable Energy Generation port Projects (if any)	0 ion of			
4. Evaluation Criteria (OEB)	Project Summary	This project	is to:		
		-add one 27 -add one cct		-	
	1a. Main Driver	Reliability.			
	1b. Priority and Reasons for Priority	Insufficient a	and lack of back-up connectio	ns between feeders in this area.	
	1c. Qualitative and Quantitative An Project and Project Alternatives	alysis of This project	will create one additional tie	petween ccts on 9th Line and Ma	ajor Mack Dr.
	2. Safety	Not Applical			
	3. Cyber-Security, Privacy	Not Applical			
	4. Coordination, Interoperability	Not Applical			
	5. Economic Development 6. Environmental Benefits	Not Applical			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project Ex in terms of Cost Impact, where proc				
	Regional Electricity Infrastructure Requirements which affect Project, applicable	Not Applical if	ble.		
	Description of Incorporation of Adv Technology, if applicable	anced Not Applical	ble.		
	recimology, ir applicable				Pg

		Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Stream	2	10	1487	20	)15		6	Do	llars
		Project Name							
Project Summary Repo	rt		<u>Add o</u>	ne Additiona	al 27.6 kV C	<u>ct on Major</u>	Mack and 9	<u>oth Line</u>	
coordi Factor Analys Altern Nothir	y any reliability , ef nation benefits s Affecting Timing/I is of Project Benefi ative Comparison, i ng" Alternative (incl s if applicable)	Priority is and Costs with ncluding "Do-	Reliability per The alternativ growth from e Customers on supplies will e alternate path the more seve The status que area. Existing	formance of the e is status quo, existing facilities Major Mack Dr xperience longe is to supply the ere the impact w o option current and future urba n in this area.D	e existing feeder i.e.,do nothing, . It will impact F between Hwy 4 r outages when affected custom vill be. :ly does not mee nization in the a	s will affect the (i.e., not build p owerStream di 8 and 9th Line components o hers. The longer et PowerStream area necessitate	timing and prices oroject as prope stribution syste are on a radial s f the radial feed the radial feed s the radial feed of s "Open Grid Ness the need for a	ority. osed), but to su m in two follov supply. Custon der fail since th er and the mon letwork" philos additional feed	ving aspects: ners on radial ere are no re customers, sophy for this ers and grid
xpenditures Historical/Planned \$	c 2012	2013 ¢	2014 č	<b>2015</b> \$ -	\$ -	2017 ¢	2018 ¢	2019 \$ -	\$ 1,248,93
\$	1,400,000 1,200,000 1,000,000 \$800,000								

	Projec	t Code	Report Start Year	Number of Years	Scale
Power		101480	2015	6	Dollars
Stream	Broiog	t Namo			
Project Summa		t Name <mark>Build double c</mark>	cts 27.6kV pole line on	19th Ave between Leslie	St and Bayview Ave
•					
Major Category	System Service				
Project Overview 1. Additional Information	Service Territory Location Scope Justification	On 19th Install 2 To suppl Bayview The Lesli approxim details. As per H 5W/sq.ft would be	Ave) e North development may acco nately 19,300 people and emplo emson report, each retail or cor each job accounts for 1.5kW. E 20 MW. There presently is no f	e from Leslie St to Bayview Ave rth that is bounded by Elgin Mills mmodate approximately 6,250 ho yment of approximately 3,200 jol nmercial job needs 300 square fe Based on 2.5kW per unit and 1.5 k feeder on 19th Ave so a new pole	busing units with a population of bs. See the attachment for more et floor space, and assuming W per job, the total demand line is required.
		19th Ave would be PowerSt	between Leslie St and Bayview required since there is no feed ream has an obligation to provid	ment impact the loading of the for Ave. As long as the development ler on 19th Ave now. de adequate electricity supply to se e service for anticipated future log	starts in 2017, these feeders service loads within its service
2. General Project Information (OEB)	Contributed Capital	Contribu	ted Capital 0%		
	Fiscal Year Parent WO#	2017			
3. General Information on the Project/Activity (OEB)	Job Number Risks to Completion and Risk Mana	gement The risk	s to get approval from the Town	n of Richmond Hill in time.	
		Capital d	esign will start the design of the	e project in 2016 and should get t	he approvals in place in 2016.
			r risk the 19th widening work so h the town to coordinate the so	chedule may impact the pole line hedule.	construction. PowerStream will
	Comparative Information on Equiv Historical Projects (if any)	alent Not App	icable.		
	Total Capital and OM&A Costs for Renewable Energy Generation port Projects (if any)	0 ion of			
4. Evaluation Criteria (OEB)	Projects (in any) Project Summary 1a. Main Driver	Support		19th Ave from Leslie St to Bayvie driver for this Investment is to su ea.	
				nodate approximately 6250 housi yment of approximately 3200 job	
		5W/sq.ft	, then each requires 1.5kW. Bas	mmercial job needs 300 square fe ed on 2.5kW per unit and 1.5 kW ve, so new pole line is required.	
	1b. Priority and Reasons for Priority		e development of properties in w loads will be significantly cor	this area started in 2014. Witho nstrained.	ut new feeders, the ability to
	1c. Qualitative and Quantitative An Project and Project Alternatives	alysis of A new po	le line is required to supply the	new development. Please refer	to analysis provided below.
	2. Safety 3. Cyber-Security, Privacy 4. Coordination, Interoperability	Not App Not App Not App	icable.		
	5. Economic Development	Not App	icable.		
	6. Environmental Benefits	Not App	icable.		Pa

			Project Code		Report Start Ye	ear	Number of Yea	irs	Scale	
Power Stream			101	1480	20	15		5	Do	llars
Project Summar	Project Name <u>Build d</u>	louble ccts 2	27.6kV pole	line on 19t	h Ave betwe	en Leslie S	St and Bayv	ew Ave		
Category-Specific Requirements for ach Project/Activity (OEB)			oject Expressed ere practicable	Not Applicable						
		ctricity Infrastru s which affect		Not Applicable						
	Description of Technology,	of Incorporation	n of Advanced	Not Applicable						
	Identify any i coordination		iency, safety or	This project wi		·				
	Factors Affecting Timing/Priority						t impact the loa ould be required	-	-	
	Alternative C	comparison, inc								
	factors if app			Leslie St betwe failure on Lesli	en Elgin Mills E	d and 19th Ave gin Mills Ed and	etween Leslie S , but it is a radia d 19th will cause	al supply witho	ut this project.	Any pole
				North develop time. Two 27.6 load south of t	ment is estimat kV feeders are his developmer	ed to be 20MW required to sup It too. These cu	slie St and Bayv / when fully bui oply the new loa istomers will be Ave to supply n	lt out, but no t d because the supplied from	ime line is availa existing feeders circuits surrour	able at this supply oth iding the
				-			obligation to su e schedule of th		-	n Ave. The
	2011									



Projec	t Code	Report Start Year	Number of Years	Scale
	102372	2015	6	Dollars
Projec		<u>ccts Pole Line on Leslie</u>	e St from Wellington St	to St.John's Sdrd
System Service				
Service Territory Location	Leslie St from	Wellington St to St.John's Sdrd		
Scope	At the south	end of the Leslie St (north of We	ellington St), there are two exi	
	pole lines will	l be relocated. The scope of wor	k is to install two pole lines: or	_
Justification	need one add	litional 13.8kV cct. It was initiall	y planned to installed two 13.8	
	bounded by t Street on the	he Town of Newmarket on the south and Marsh Creek on the	north, Highway 404 on the eas west. The 2C Planning Area co	t, just north of Wellington nsists of approximately 445
Contributed Capital	Contributed (	Capital 0%		
Fiscal Year Parent WO# Job Number	2016			
Risks to Completion and Risk Mana				the design of the project in
Comparative Information on Equiv	Region defers	s the road widening work.	slie St widening project. The p	roject will be deferred if York
Historical Projects (if any)				
Total Capital and OM&A Costs for Renewable Energy Generation port Projects (if any)	0 ion of			
Project Summary				
	pole lines will	l be relocated. The scope of wor	rk is to install two pole lines: or	
1a. Main Driver	The lands in t approximatel opportunities The residenti commercial d Aurora MS7 &	he 2C Secondary Plan Area are y 8,000 residents in approx 3,10 s over the next 20 years. al units will be on the west side levelopment will be on the east & MS8. 2C land is currently sup	intended to accommodate 00 units and between 5,200 and of Leslie St and will be supplie side of Leslie St and will suppli plied by a 13.8kV feeder 5F2. I	d 6,400 employment d by 13.8kV feeders.The ed by 27.6kV feeders from
	Project   System Service   Service Territory   Location   Scope   Justification   Justification   Contributed Capital   Fiscal Year   Parent WO#   Job Number   Risks to Completion and Risk Manage   Comparative Information on Equive   Historical Projects (if any)   Project Summary	Project Name Install 2x13.8kVSystem ServiceService Territory LocationPowerStream This project V At the south on the east si york Region i pole lines will 44kV ccts and 44kV ccts and uet o anticipJustificationThe develop red one add due to anticipJustificationThe develop red one add due to anticipContributed CapitalContributed Capital approx 3000Contributed CapitalContributed Capital approx 3000Fiscal Year Parent WO# Job Number2016 The risk is to 2015 and sho The other risi Region defers Not ApplicableTotal Capital and OM&A Costs for Project Summary0 At the south on the east si York Region i pole lines will 44kV ccts and At the south on the east si York Region i pole lines will 44kV ccts and At the south on the east si on the east si opportunities The lands in the east si opportunities the resident i the resident i 	102372     2015       Project Name     Install 2x13.8kV ccts Pole Line on Leslie       System Service     PowerStream South       Service Territory     PowerStream South       Location     This project will depend on YA Leslie St wide       Scope     At the south end of the Leslie St (north of Wa on the east side has two 44kV ccts and two 27.6kV ccts, one on the will be relocated. The scope of won yakk ccts and two 27.6kV ccts, one on the will be contributed future road widening Vesile St from Welling work.       Justification     The development is idenfied in the Aurora St need on additional 13.8kV cct, was initial we to anticipated future road widening work will be relocated. The scope of won yakk ccts and two 27.6kV ccts, one on the will be contributed future road widening work will be relocated at the norther bounded by the Town of Newmarket on the Street on the south and Streek on the south and Streek on the Street on the south and Streek on the Street on the south and Streek Streek on the south and Streek on the south and Streek on the sou	102372     2015     6       Prejet Name     Install 2x13 SkV ccts Pole Line on Leslie St from Wellington St       System Service     Service Torritory       Scope     At the south and the use is St from Wellington St to SL John's Sdrd in Aurora, approx 1.5 km.       Scope     At the south and of the use is St from Wellington St to SL John's Sdrd in Aurora, approx 1.5 km.       Justification     PowerStream South Lessie St from Wellington St to SL John's Sdrd in Aurora, approx 1.5 km.       Justification     At the south and of the use is St (north of Wellington St, there are two ed on the east side has two 44kV ccts and two 27.6kV ccts. The one on the west or Region is going to widening Leslie St from Wellington St to SL John Sd pole lines on 44kV ccts and two 27.6kV ccts, one on the west side with two 13.8kV ccts.       Justification     The development is identified in the Aurora Secondary plan as area 22 and it need one additional 13.8kV cct, two sin Intial Polamed to installed two 13.8k due to anticipated future road widening work.       Contributed Capital     Contributed Capital Ots       Contributed Capital     Contributed Capital Ots       Fiscal Year     2016       Parent WO3     The ins is its no get approval from York Region in time. Capital design will star 2015 and should get the approvals in place in 2015.       Total Capital and OM&A Costs for Reserved Bie Entry Science Stop Strom of the south end of the Leslie St (north of Wellington St, there are two end in the east side has two 44kV ccts and three 27.6kV ccts. The one not we region defers the road widening work.       Comparative i

L

			Project Code		Report Star	t Year	Number of Yea	rs	Scale				
Power Stream			10	2372		2015	6	i	De	ollars			
Project Summar	y Report		Project Name Insta		<u> ccts Pole</u>	Line on Lesli	e St from We	ellington St	to St.John'	<u>s Sdrd</u>			
	1b. Priority a	and Reasons for	r Priority	come. The ex	isting 13.8kV	2C land has started feeders don't have	e sufficient capac	ity to supply t	he new load.				
					o rebuild the	lening Leslie St in 2 existing 1 cct 13.8 ne future.							
		ve and Quantita Project Alterna		f This project v 300A or 7000		13.8kV feeder to r	erouted to supp	y 2C land and	increase suppl	y capacity b			
	2. Safety				ct in case of p	e a alternate suppl ole failures on Bay		ig customers o	n Wellington.	t will reduc			
		urity, Privacy		Not Applicab									
		ion, Interopera	bility	Not Applicab									
	Development		Not Applicab	le.									
		ental Benefits		Not Applicable.									
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project Expressed in terms of Cost Impact, where practicable				le.								
		quirements which affect Project, if plicable		Not Applicable.									
	Technology,	Description of Incorporation of Advanced Technology, if applicable Identify any reliability , efficiency, safety or			ty or This project will add one 13.8kV feeder to supply 2C land. It will increase reliability.								
	coordination Factors Affec	benefits	iority	-		ening project sche act the loading of		-	he project. Th	e progress			
	Alternative 0	Comparison, ind ernative (includ	cluding "Do-	viable as the		posed project is to er can not supply t	-		alternative is r	ot consider			
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020			
Expenditures Historical/Planned	\$ -	\$ -	\$ -	\$ -	\$ .	\$ 1,131,418	\$ -	\$ -	\$-	\$			
	\$1,200,	000											
	\$1,000,	000					<b>1</b>						
	¢000	000											
	\$800,												
	\$600 <i>,</i>	000											
	\$400,	000 -											
	\$200,	000											
		\$200,000											
		\$- 2011	L 2012	2013	2014	2015 20	16 2017	2018	2019	2020			

	Project C	ode	Report Start Year	Number of Years	Scale
Power Stream	-	100904	2015	6	Dollars
	Project N	ame	-		
Project Summa	ry Report	Install Double	Cct Pole Line on Major	Mackenzie - Hwy 27 to	Huntington Rd
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory Location	PowerStream	South to Huntington Rd This project	will depend on Vork Region ro	ad widening work
					-
	Scope		ble 27.6kV ccts pole line To ins on Hwy 27, and Huntington Rd	tall LIS at intersections To con	nect the new ccts to the
	Justification	To supply nev	v development on Major Mack load growth areas in Vaughan a		on Rd. It includes following
		Kleindor Deve			
			elopment is part of OPA160 initi		d population of approximately
			and 1,000 residential dwelling development area that is locate		Aackenzie Drive east side or
			d west of Regional Road 27. The		
		Nashville Heig	ghts Development		
		-	ficial Plan Amendment No. 699		signations and policies to
			in Block 61 West within the Kle ent area is approximately 185 h		is bounded on the west by
			oad, on the east by the CP rail li		
			ng Nashville Road.	-, , - <u>,</u> - <u>,</u> - <u>,</u> -	
			a planned population of approx		_
			y 700 jobs. Based on 2.7kW per	unit and 1.5 kW per job, the to	otal demand would be 8 MW.
			<u>n Employment Area</u> Ighan Employment Area Seconc	larv Plan sets out detailed noli	ries to create a large economi
			or York Region. With over 500 h		_
			llow the City of Vaughan to attr	–	
			t Regional road and provincial h		
			e approximately 20,120 employ	,	acant land on both sides of
		-	nzie Drive that has been zoned load from these lands will be si		r this development is
		estimated to	be 50MW to 80 MW when fully rs are required to supply the ne	built out, but no time line is a	
		Hwy 50 in 201	s going to widen Major Macken L5 and 2019. There is opportuni ble 27.6kV ccts in conjunction w	ty for PowerStream to rebuild	the existing single phase 4.8
2. General Project Information (OEB)	Contributed Capital	Contributed C	Capital 0%		
	Fiscal Year	2018			
	Parent WO#	2010			
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manage	rebuild Major	get approval from the City of Va Mack Dr in 2017. The pole line pital design will work closely wi	construction schedule will dep	pend on road widening
	Comparative Information on Equivale Historical Projects (if any)	nt Not Applicabl	e.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 n of			
4. Evaluation Criteria (OEB)	Project Summary	This project is customers.	to build two 27.6kV ccts to sup	ply new customers on Major N	Najor Dr and existing
	1a. Main Driver		city Delivery. single phase 4.8kV cct on Major 6kV supply for a new subdivisi		
		widening the	eeders don't have sufficient cap road, and the existing 4.8kV ne ltimate requirement.		-

	Pr	oject Code		Report Start Year	Number of Years	Scale				
Power Stream	-	100	904	2015	6	Dollars				
	Pr	oject Name	ie							
Project Summar	y Report	Ins	tall Double	<u>Cct Pole Line on Major</u>	Mackenzie - Hwy 27 t	<u>o Huntington Rd</u>				
	1b. Priority and Reasons for Pri		expected in the	d on both sides of Major Mack e coming years. Existing pole ction with the road widening p	line has to be relocated due t	o road widening work. Build				
	1c. Qualitative and Quantitativ Project and Project Alternative	S	also establist ti	ll add two 27.6kV ccts to the a es between feeders on Hwy 2 ty in the west part of Vaughan	7 and feeders on Huntington					
	2. Safety		Not Applicable							
	3. Cyber-Security, Privacy		Not Applicable							
	4. Coordination, Interoperabilit		Not Applicable							
	5. Economic Development		Not Applicable							
	6. Environmental Benefits		Not Applicable							
Category-Specific Requirements for ach Project/Activity (OEB)	Benefits to Customers of Projection in terms of Cost Impact, where		Not Applicable							
	Regional Electricity Infrastructu Requirements which affect Pro applicable		Not Applicable							
	Description of Incorporation of Technology, if applicable	f Advanced	Not Applicable							
	Identify any reliability , efficien coordination benefits		power supply r	eliability in the west part of Va	aughan.					
	Factors Affecting Timing/Priori		by the road wi	ine will be built as per Major N dening schedule.						
	Analysis of Project Benefits and Alternative Comparison, includ Nothing" Alternative (including	ling "Do-		is to "do nothing" and to sup distribution system in two follo		facilities. It will impact				
	factors if applicable)		Reliability							
			has adopted "C Kleindor develo pole failure on Heights develo	ngle phase 4.8kV cct on Major Open Grid Network" planning p opment is supplied from Hwy 2 the cable will cause large scale pment is supplied from Huntir e on the cable or pole line on H	philosophy, i.e., loop supply v 27 through a radial undergrou e and prolonged outages to t ngton Rd through a radial unc	vith normal open points. The und cable, meaning that any ne customers. The Nashville erground cable, meaning the				
			to the custome	ers.						
				ngle phase 4.8kV cct on Major supply Kleindor development	-					
				e will jeopardize PowerStream'						

			Project Code		Report Start	Year	Number of Ye	ars	Scale	
Power Stream	5		100	)904		2015		6	Do	ollars
Project Summary	•		Project Name Ins	tall Double	Cct Pole I	<u>_ine on Majo</u>	or Mackenzie	e - Hwy 27 to	Huntingtor	<u>n Rd</u>
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ - \$	\$-	\$-	\$-	\$-	\$ -	\$-	\$ 1,819,608	\$-	\$
	¢2,000,00									
	\$2,000,00									
								and a second		
	\$1,600,00	00								
	\$1,600,00 \$1,400,00	10 10								
	\$1,600,00 \$1,400,00 \$1,200,00	10 10								
	\$1,600,00 \$1,400,00 \$1,200,00 \$1,000,00	10								
	\$1,600,00 \$1,400,00 \$1,200,00 \$1,000,00 \$800,00									
	\$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000									
	\$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000 \$400,000									
	\$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000									

Project Code	Report Start Year		Number of Years	Scale			
100237	2015		6	Dollars			
Project Name Install Do	buble Ccts 27.6 kV Pole	Line or	16th Ave from 9th Lir	ne to Reesor Road			
	verStream South						
	Avenue from 9th Line to Rees						
The	existing feeders on 16th Ave is	a non-star	ndard 3/0 three phase feeder				
9th I	project is install double ccts 2 Line to Reesor Rd to increase s Box Grove areas; one of the fa	upply capa	city and reliability to Markha	m East development of Cornell			
	existing conductor size of the a acity to supply the new develop			-			
	project will provide 40 MVA sun nell and Box Grove both in the		•	Iress the loading issue of			
	project will form 27.6kV feede might arise as a result of radia			he risk of customer outages			
Hwy	Cornell Community is bounded 7 to the south, and 9th Line to a approximately 26,000 people.	the west.	It will accommodate approxi	mately 8,500 dwelling units			
Cont	tributed Capital 0%						
2019	9						
Risk Management The	risk is to get approval from the	City of Ma	arkham in time.				
Сарі	ital design will start the design	of the proj	ect in 2018 and should get th	e approvals in place in 2018.			
n on Equivalent Not )	Applicable.						
Costs for 0 ration portion of							
9th I	project is install double ccts 27 Line to Reesor Rd to increase s Box Grove areas; one of the fa	upply capa	city and reliability to Markha	m East development of Cornell			
Corr deve 27.6	Support Capacity Delivery. The main driver for this project is to support the capacity delivery in the Cornell and Box Grove area. This project is to form a loop supply arrangement for the Cornell development. It also allow feeder 24M3/24M6 to back up feeder 24M4/24M5. This project (Extend 27.6kV circuits 24M4/24M5 on 16th Ave from 9th Line to Reesor Rd) is an interim step of the ultimat supply plan for the Cornell area and Box Grove areas.						
1. Ac 2. Pr 3. Cc	ddresses the reliability issue of rovide alternate supply route for onsistent with the original Mar	Cornell an or Cornell o kham TS4 t	d Box Grove both in the shor development to increase relia feeder integration plan and b	bility. usiness case.			
	1. A 2. P 3. C	<ol> <li>Addresses the reliability issue of</li> <li>Provide alternate supply route for</li> <li>Consistent with the original Mar</li> </ol>	<ol> <li>Addresses the reliability issue of Cornell an</li> <li>Provide alternate supply route for Cornell 6</li> <li>Consistent with the original Markham TS4</li> </ol>	<ul> <li>for Priority</li> <li>High. Installing two additional 27.6kV circuits on 16th Ave will:</li> <li>1. Addresses the reliability issue of Cornell and Box Grove both in the shor</li> <li>2. Provide alternate supply route for Cornell development to increase relia</li> <li>3. Consistent with the original Markham TS4 feeder integration plan and b</li> <li>4. It also addresses the reliability issue of 24M4/24M5 which supply Markh</li> </ul>			

Image: Notice of the second	Coad cilities. It will eeder on Ave, and 2013. upply the normal open
Project Summary Report       Install Double Ccts 27.6 kV Pole Line on 16th Ave from 9th Line to Reeson R         1c. Qualitative and Quantitative Analysis of Project and Project Alternatives       The alternative to this project is to "do nothing", but still supply load growth from existing fact impact PowerStream distribution system in two following aspects:         16th Ave is the northern boundary of Cornell development. There is an existing three phase for 16th Ave (24M7). Feeder 24M7 supplies loads on east of 9th Line between Hwy 7 and Steeles load on Reesor Rd between Steeles Ave and Major Mack Dr. The peak of 24M7 was 346A in 2 The conductor size on 16th Ave and Reesor is 3/0 AL and does not have enough capacity to su new development and provide backup capacity when needed.         Reliability       PowerStream has adopted "Open Grid Network" planning philosophy, i.e., loop supply with no points. All existing supplies to Cornell and Box Grove are radial from 9th Line, meaning that and points. All existing supplies to Cornell and Box Grove are radial from 9th Line, meaning that and points.	cilities. It will eeder on 5 Ave, and 2013. upply the normal open
Project and Project Alternativesimpact PowerStream distribution system in two following aspects: 16th Ave is the northern boundary of Cornell development. There is an existing three phase for 16th Ave (24M7). Feeder 24M7 supplies loads on east of 9th Line between Hwy 7 and Steeles load on Reesor Rd between Steeles Ave and Major Mack Dr. The peak of 24M7 was 346A in 2 The conductor size on 16th Ave and Reesor is 3/0 AL and does not have enough capacity to su new development and provide backup capacity when needed.Reliability PowerStream has adopted "Open Grid Network" planning philosophy, i.e., loop supply with n points. All existing supplies to Cornell and Box Grove are radial from 9th Line, meaning that a	Feeder on 5 Ave, and 1013. upply the normal open
form a 27.6kV loop around Cornell and Box Grove via 9th Line, 14th Ave, Hwy 7, Reesor Rd an <b>Capacity</b> 16th Ave is the northern boundary of Cornell development. There is an existing three phase f 16th Ave (24M7). Feeder 24M7 supplies loads on east of 9th Line between Hwy 7 and Steeles load on Reesor Rd between Steeles Ave and Major Mack Dr. The peak of 24M7 was 346A in 2 conductor size on 16th Ave and Reesor is 3/0 AL and does not have enough capacity to supply development and provide backup capacity when needed. The status quo option currently does not meet PowerStream's "Open Grid Network" philosop area. Existing and future urbanization as well as the hospital expansion in Cornell area necess need for additional feeders and grid reconfiguration in this area.	planned to nd 16th Ave. eeder on Ave, and 013. The y the new
2. SafetyNot Applicable.3. Cyber-Security, PrivacyNot Applicable.4. Coordination, InteroperabilityNot Applicable.5. Economic DevelopmentNot Applicable.6. Environmental BenefitsNot Applicable.5. Category-Specific Requirements forBenefits to Customers of Project Expressed	
Each Project/Activity (OEB) in terms of Cost Impact, where practicable Regional Electricity Infrastructure Requirements which affect Project, if Requirements which affect Project, if	
applicable Description of Incorporation of Advanced Not Applicable. Technology, if applicable Identify any reliability, efficiency, safety or The main benefit is to increase supply reliability to Cornell area.	
coordination benefitsFactors Affecting Timing/PriorityA number of residential and commercial projects are under construction now in Cornell area. customers and load are expected in the years to come.	New
Analysis of Project Benefits and Costs with Alternative Comparison, including "Do- Nothing" Alternative (including qualitative factors if applicable)The Project Benefits include: 1. Addresses the reliability issue of Cornell and Box Grove. 2. Provide alternate supply route for Cornell development 3. Consistent with the original Markham TS4 feeder integration plan and business case.	
The "do nothing" alternative discussed above is not viable for the following reasons: a) Does not meet short term and long term supply needs of the Cornell and Box Grove develo open grid network philosophy. b) Customers will be at risk of lengthier outages if loop supply is not in place.	pments and

			Project Code		Report Star	t Year	Number of Ye	ars	Scale	
Power Stream			100	100237		2015		6		llars
Project Summary Report		Project Name Instal	II Double Co	<u>cts 27.6 k</u>	V Pole Line o	n 16th Ave I	from 9th Lin	e to Reesor	Road	
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$-	\$-	\$ -	\$ -	\$-	- \$ -	\$-	\$ -	\$ 1,302,301	\$ -
	\$1,400,0	000								
	\$1,200,0	000								
	\$1,000,0	000								
	\$800,0	000								
	\$600,0	000								
	\$400,0	000								
	\$200,0	000								
	\$	2011	2012	2013	2014	2015 20	16 2017	2018	2019	2020
	L									

	Project Coc	e	Report Start Year	Number of Years	Scale
Power	<u> </u>	103651	2015	6	Dollars
Project Summa	Project Nar		ne 44kV cct on Maplevie	ew Drive West - Essa to	o Veterans
Major Category	System Service				
Project Overview		<b>D</b>			
1. Additional Information	Service Territory Location	PowerStream On Manleview	v Drive West east of Essa Road	to Veterans Drive	
	Scope		dditional 44kV circuit to existing		along Mapleview Drive. To
			as required to sectionalize the		
	Justification	to the north a	uth-West area is bounded by Hi and Salem Road to the south. Th ders, which each experienced l	ne Barrie South-West area is cu	urrently supplied by the 23M5
		currently cont Data Center # Based on the facility, feeder	b) large data centers currently lo tracted for 10MVA with expans 22 is currently contracted for 5.5 contingency condition requiren r 23M5 summer peak loading w contingency load transfer, whi	on plans to reach 20MVA over MVA with provisions to go to nents and considering the anti- ill exceed 400A in 2015 and ex	the next 8-10 years, while 11MVA at any time. cipated load growth at each ceed the 600A thermal limit in
		(23M5). The E and two addit feeders will in however, only contingency c feeder along I	section of Mapleview Drive bet issa/Mapleview area will have a tional 44kV feeders (23M22 & 2 acrease capacity to the Barrie So y the single 23M5 spans the sec capacity and transfer options to Mapleview adjacent feeders in ad and therefore reliability in th	new 44kV feeder (23M26) sup 3M27) to be in-service by 2018 buth-West area in response to tion from Essa Road to Veterar a single 44kV feeder. In additi the Barrie South-West area wil	bplying Holly MS in Q2 of 2015 3. These three new 44kV the data center load growth, ns Drive, thereby limiting ion a loss of the single 23M5 Il not be able to pick-up the
2. General Project Information (OEB)	Contributed Capital Fiscal Year	Contributed C 2018	Capital 0%		
2. General Project Information (OEB)	Fiscal Year Parent WO#		Capital 0%		
<ol> <li>General Project Information (OEB)</li> <li>General Information on the Project/Activity (OEB)</li> </ol>	Fiscal Year	2018		e required approvals from the	city in the allotted timeframe.
3. General Information on the	Fiscal Year Parent WO# Job Number	2018 nt The greatest r Some past pro			
3. General Information on the	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manageme Comparative Information on Equivalent	2018 nt The greatest r Some past pro proceeding wi	risk to completion is securing th pjects for new circuits have take		
3. General Information on the	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manageme Comparative Information on Equivalent Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion of	2018 nt The greatest r Some past pro proceeding with 0 f To add one actionstall switch a	risk to completion is securing th ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder.	along Mapleview Drive. To
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manageme Comparative Information on Equivalent Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	2018 nt The greatest r Some past pro proceeding wi 0 f To add one ac install switch a Support Capa- the three new	risk to completion is securing th ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f city Delivery. The main driver o v 44kV feeders in the Essa/Map	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder. If the project is to extend the a eview area to the load growth	ecessary approvals before along Mapleview Drive. To additional capacity provided by at Veterans/Mapleview. The
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manageme Comparative Information on Equivalent Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any) Project Summary	2018 nt The greatest r Some past pro- proceeding without 0 f To add one action of Main Support Capacithe three new section of Main The project is	risk to completion is securing th ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f city Delivery. The main driver o v 44kV feeders in the Essa/Map	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a eeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr	along Mapleview Drive. To additional capacity provided by at Veterans/Mapleview. The rently has a single 44kV feeder.
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manageme Comparative Information on Equivalent Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any) Project Summary 1a. Main Driver	2018 nt The greatest r Some past pro- proceeding wi 0 To add one ac install switch a Support Capac the three new section of Ma The project is utilized to sup of The additiona Veteran/Map	risk to completion is securing the ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the for city Delivery. The main driver of v 44kV feeders in the Essa/Map pleview Drive West between Essa high priority since the addition oport future load growth.	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a eeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr al capacity offered by the three simately 30MVA of additional o also help establish a back-up fe	ecessary approvals before along Mapleview Drive. To additional capacity provided by that Veterans/Mapleview. The rently has a single 44kV feeder. e new 44kV feeders could be capacity to the
3. General Information on the Project/Activity (OEB)	<ul> <li>Fiscal Year</li> <li>Parent WO#</li> <li>Job Number</li> <li>Risks to Completion and Risk Manageme</li> <li>Comparative Information on Equivalent Historical Projects (if any)</li> <li>Total Capital and OM&amp;A Costs for Renewable Energy Generation portion of Projects (if any)</li> <li>Project Summary</li> <li>1a. Main Driver</li> <li>1b. Priority and Reasons for Priority</li> <li>1c. Qualitative and Quantitative Analysis Project and Project Alternatives</li> </ul>	2018 nt The greatest r Some past pro- proceeding wi 0 To add one ac install switch a Support Capac the three new section of Ma The project is utilized to sup of The additiona Veteran/Mapl supply at the of The 'do-nothing three new 444 Veterans/Map	risk to completion is securing the ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f city Delivery. The main driver of v 44kV feeders in the Essa/Map pleview Drive West between Ess high priority since the addition oport future load growth. Il 44kV circuit would add approvi leview area. The feeder would a data center load during conting mg' alternative is not recommer kV feeders in the Essa/Maplevie oleview area.	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr al capacity offered by the three kimately 30MVA of additional d also help establish a back-up fe rency conditions.	along Mapleview Drive. To additional capacity provided by a t Veterans/Mapleview. The rently has a single 44kV feeder. e new 44kV feeders could be capacity to the eeder to maintain a dual
3. General Information on the Project/Activity (OEB)	<ul> <li>Fiscal Year</li> <li>Parent WO#</li> <li>Job Number</li> <li>Risks to Completion and Risk Manageme</li> <li>Comparative Information on Equivalent Historical Projects (if any)</li> <li>Total Capital and OM&amp;A Costs for Renewable Energy Generation portion of Projects (if any)</li> <li>Project Summary</li> <li>1a. Main Driver</li> <li>1b. Priority and Reasons for Priority</li> <li>1c. Qualitative and Quantitative Analysis Project and Project Alternatives</li> <li>2. Safety</li> </ul>	2018 nt The greatest r Some past pro- proceeding without 0 f To add one action install switch action Support Capacithe three new section of Mai The project is utilized to sup of The additional Veteran/Mapl supply at the of The 'do-nothing three new 444 Veterans/Mapl Not Applicable	risk to completion is securing the ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the city Delivery. The main driver of a 44kV feeders in the Essa/Map pleview Drive West between Ess high priority since the addition oport future load growth. If 44kV circuit would add approvise leview area. The feeder would data center load during conting ng' alternative is not recommer kV feeders in the Essa/Maplevie oleview area. e.	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr al capacity offered by the three kimately 30MVA of additional d also help establish a back-up fe rency conditions.	along Mapleview Drive. To additional capacity provided by a t Veterans/Mapleview. The rently has a single 44kV feeder. e new 44kV feeders could be capacity to the eeder to maintain a dual
3. General Information on the Project/Activity (OEB)	<ul> <li>Fiscal Year</li> <li>Parent WO#</li> <li>Job Number</li> <li>Risks to Completion and Risk Manageme</li> <li>Comparative Information on Equivalent Historical Projects (if any)</li> <li>Total Capital and OM&amp;A Costs for Renewable Energy Generation portion of Projects (if any)</li> <li>Project Summary</li> <li>1a. Main Driver</li> <li>1b. Priority and Reasons for Priority</li> <li>1c. Qualitative and Quantitative Analysis Project and Project Alternatives</li> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> </ul>	2018 nt The greatest r Some past pro- proceeding with 0 f To add one act install switch a Support Capac the three new section of Ma The project is utilized to sup of The additiona Veteran/Mapl supply at the a The 'do-nothing three new 441 Veterans/Map Not Applicable	risk to completion is securing the ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f city Delivery. The main driver of v 44kV feeders in the Essa/Map pleview Drive West between Ess high priority since the addition oport future load growth. Il 44kV circuit would add approview leview area. The feeder would a data center load during conting ing' alternative is not recommer kV feeders in the Essa/Maplevie oleview area. e. e.	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr al capacity offered by the three kimately 30MVA of additional d also help establish a back-up fe rency conditions.	along Mapleview Drive. To additional capacity provided by a t Veterans/Mapleview. The rently has a single 44kV feeder. e new 44kV feeders could be capacity to the eeder to maintain a dual
3. General Information on the Project/Activity (OEB)	<ul> <li>Fiscal Year</li> <li>Parent WO#</li> <li>Job Number</li> <li>Risks to Completion and Risk Manageme</li> <li>Comparative Information on Equivalent Historical Projects (if any)</li> <li>Total Capital and OM&amp;A Costs for Renewable Energy Generation portion of Projects (if any)</li> <li>Project Summary</li> <li>1a. Main Driver</li> <li>1b. Priority and Reasons for Priority</li> <li>1c. Qualitative and Quantitative Analysis Project and Project Alternatives</li> <li>2. Safety</li> </ul>	2018 nt The greatest r Some past pro- proceeding without 0 f To add one action install switch action Support Capacithe three new section of Mai The project is utilized to sup of The additional Veteran/Mapl supply at the of The 'do-nothing three new 444 Veterans/Mapl Not Applicable	risk to completion is securing the ojects for new circuits have take ith construction. dditional 44kV circuit to existing as required to sectionalize the f city Delivery. The main driver of 44kV feeders in the Essa/Map pleview Drive West between Es high priority since the addition oport future load growth. Il 44kV circuit would add approvieve leview area. The feeder would a data center load during conting ng' alternative is not recommer kV feeders in the Essa/Maplevie oleview area. e. e. e.	en 6-8 months to obtain the ne 1x44kV & 2x13.8kV pole line a reeder. If the project is to extend the a eview area to the load growth sa Road to Veterans Drive curr al capacity offered by the three kimately 30MVA of additional d also help establish a back-up fe rency conditions.	along Mapleview Drive. To additional capacity provided by a t Veterans/Mapleview. The rently has a single 44kV feeder. e new 44kV feeders could be capacity to the eeder to maintain a dual

			Project Code		Report Start Y	ear	Number of Ye	ears	Scale	
Power Stream			10	3651	2	015		6	D	ollars
Project Summary	Report		Project Name		e 44kV cct	on Maplevie	ew Drive W	est - Essa to	Veterans	
5. Category-Specific Requirements for Each Project/Activity (OEB)			oject Expressed ere practicable	Not Applicable	·.					
	Regional Electricity Infrastructure Requirements which affect Project, if applicable			Not Applicable						
	Technology, i			Not Applicable						
	Identify any recordination		iency, safety or					g more 44kV circ ons which increa		to customer:
	Factors Affect	ting Timing/Pri	ority	Securing the reference		als from the city	in the allotte	d timeframe may	affect the tin	ning of the
	Analysis of Project Benefits and Costs with Alternative Comparison, including "Do- Nothing" Alternative (including qualitative factors if applicable)			Veteran/Maple supply at the c The 'do-nothin	eview area. The lata center load g' alternative i V feeders in th	e feeder would a d during conting s not recommer	also help estat ency condition nded because	A of additional c olish a back-up fe ns. the additional cap unable to supply	eder to maint	ain a dual ed by one of
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
					<u> </u>		1			
xpenditures Historical/Planned	\$ -	\$ -	Ş -	Ş -	\$-	\$ -	\$-	\$ 855,914	\$-	\$
xpenditures Historical/Planned	\$ - \$900,000 \$800,000 \$700,000	\$ -	Ş -	\$ -	Ş -	Ş -	\$ -	\$ 855,914	\$ -	\$
xpenditures Historical/Planned	\$800,000 \$700,000 \$600,000	\$ -	Ş -	\$ -	Ş -	Ş -	\$ -	\$ 855,914	\$ -	\$
xpenditures Historical/Planned	\$800,000 \$700,000	\$ -	<b>\$</b> -	\$ -	Ş -	Ş -	\$ -	\$ 855,914	\$ -	\$
xpenditures Historical/Planned	\$800,000 \$700,000 \$600,000 \$500,000	\$ -	\$ -	\$ -	Ş -	Ş -	\$ -	\$ 855,914	\$ -	\$
xpenditures Historical/Planned	\$800,000 \$700,000 \$600,000 \$500,000 \$400,000 \$300,000 \$200,000	\$ -	<b>\$</b> -		\$ -	Ş -	\$ -	\$ 855,914	\$ -	\$
Expenditures Historical/Planned	\$800,000 \$700,000 \$600,000 \$500,000 \$400,000 \$300,000	\$ -	<b>\$</b> -	<b>\$</b> -	<b>\$</b> -	<b>\$</b> -	\$ -	\$ 855,914	\$ -	\$

	Project Code		Report Start Year	Number of Years	Scale
Power Stream	1	03633	2015	6	Dollars
biream	Project Nam	e			
Project Summar			27.6kV Ccts on 16th A	ve from Hwy 404 to Wo	odbine Ave
Major Category Project Overview	System Service				
1. Additional Information	Service Territory	PowerStream	South		
	Location	On 16th Ave f	rom Hwy 404 to Woodbine Ave	in Markham	
	Scope	closure of But 404 to Woodk	as been designed under WO#31 tonville Airport. This project is t pine Ave by rebuilding the existi 6th Ave where permitted.	o install two additional 27.6k	ccts on 16th Ave from Hwy
	Justification	The objective MTS4 feeder i it will off load developments Business Park Inventory - Fa parks that are approx. 50MV area of Leslie new feeder is Richmond Hill loaded to the Richmond Hill been at their Richmond Hill TS2 do not ha to increase by has been tran of new feeder its 10 day Lim Richmond Hill	of this project is to re-route two integration plan. This project is Richmond Hill RH-TS1 and RH-T is in Richmond Hill will be the Be and Leslie North. According to Il 2011", there are approx. 209 bounded by Hwy 404/Leslie St, V, so two to three new feeders North is approx. 620 hectares. A required. In total, three to fo these developments are close is supplied by Richmond Hill TS LTR's since 2009. The peak in Ju TS2. They exceeded their LTRs ve extra capacity to supply new 7MW every year in Richmond I sferred to MTS4 after four feed rs from MTS4, the peak of Butto ited Time Rating (LTR) of 153 M and Markham. This project is ,000 for CMI based on \$2 per CI	to provide additional 40 MVA "S2 that exceeded their LTRs in aver Creek Business Park, Hea o Town of Richmond Hill's "Va- hectares of vacant employmer (Elgin Mills Rd/16th Ave. The t are required for the proposed Approx 5,000 residential units ur feeders are required to sup to Richmond Hill TS1 and TS2 ected to increase by 7MW eve (1, TS2 and Buttonville TS. Rich by 2012 was 165 MW on Richm by 12MW and 20 MW respect loads anticipated in the devel Hill. Buttonville TS is at its LT ers on Rodick Rd are put in sen nville TS will decrease to 120 f W. The freed up capacity can I going to save 20,000 CMI. The	capacity to Richmond Hill and 2012. The major future dford Business Park, Barker cant Employment Land it land in these three business otal estimated new load is development. The total land have been proposed, so one ply these developments in , but TS1 and TS2 have been ery year in Richmond Hill. imond Hill TS1 and TS2 have bond Hill TS1, 120MW on ively. Richmond Hill TS1 and opments. The load is expected R in 2012, but 40MW's of load vice in May 2013. As a result dW in 2013 and will be below be used to supply new loads in e risk of deferring one year
2. General Project Information (OEB)	Contributed Capital	Contributed C	Capital 0%		
	Fiscal Year	2016			
	Parent WO#	_010			
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemer			arkham, York Region, Transpor	t Canada as well MTO in time.
	Comparative Information on Equivalent Historical Projects (if any)	Not Applicabl	e.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	Install Two Ac	lditional 27.6kV Ccts on 16th Av	e from Hwy 404 to Woodbine	Ave in 2016.
	1a. Main Driver	Support Capa Hill.	city Delivery. The main driver fo	or this project is to support cap	pacity delivery in Richmond
	1b. Priority and Reasons for Priority		is project has been approved in rport closure schedule and MTC		
	1b. Priority and Reasons for Priority 1c. Qualitative and Quantitative Analysis Project and Project Alternatives	Buttonville Ai	rport closure schedule and MTC	)'s Hwy 404 widening schedule	<u>.</u>
	1c. Qualitative and Quantitative Analysis Project and Project Alternatives	Buttonville Ai	rport closure schedule and MTC needed to provide 40 MVA of I	)'s Hwy 404 widening schedule	<u>.</u>
	1c. Qualitative and Quantitative Analysis	Buttonville Ai	rport closure schedule and MTC needed to provide 40 MVA of I e.	)'s Hwy 404 widening schedule	<u>.</u>
	<ul><li>1c. Qualitative and Quantitative Analysis of Project and Project Alternatives</li><li>2. Safety</li></ul>	Buttonville Ai of This project is Not Applicabl	rport closure schedule and MTC needed to provide 40 MVA of I e. e.	)'s Hwy 404 widening schedule	<u>.</u>
	<ol> <li>1c. Qualitative and Quantitative Analysis</li> <li>Project and Project Alternatives</li> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> </ol>	Buttonville Ai of This project is Not Applicabl Not Applicabl	rport closure schedule and MTC needed to provide 40 MVA of I e. e. e.	)'s Hwy 404 widening schedule	2.
	<ol> <li>Qualitative and Quantitative Analysis of Project and Project Alternatives</li> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperability</li> <li>Economic Development</li> <li>Environmental Benefits</li> </ol>	Buttonville Ai of This project is Not Applicabl Not Applicabl Not Applicabl Not Applicabl Not Applicabl	rport closure schedule and MTC needed to provide 40 MVA of I e. e. e. e. e.	)'s Hwy 404 widening schedule	2.
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ol> <li>1c. Qualitative and Quantitative Analysis of Project and Project Alternatives</li> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> <li>4. Coordination, Interoperability</li> <li>5. Economic Development</li> </ol>	Buttonville Ai of This project is Not Applicabl Not Applicabl Not Applicabl Not Applicabl Not Applicabl Not Applicabl d Not Applicabl	rport closure schedule and MTC needed to provide 40 MVA of I e. e. e. e. e.	)'s Hwy 404 widening schedule	2.

			Project Code		Report Start Y	ear	Number of Ye	ars	Scale	
Power Stream			103	3633	2	015		6	Do	ollars
			Project Name							
Project Summary	Project Summary Report			Install Two	27.6kV Cc	ts on 16th A	ve from Hw	vy 404 to Wo	odbine Ave	<u>)</u>
	Regional Electri Requirements v applicable			Not Applicable	2.					
	Description of I Technology, if a		of Advanced	Not Applicable	2.					
	Identify any rel coordination be	iability , effici	ency, safety or	This project w increase suppl		IVA capacity from	m Buttonville T	S to the Richmo	ond Hill area. It	will also
	Factors Affectir	ng Timing/Pric	ority	Buttonville Air	port is expecte	d to close in Oct	2015. The clos	sing date will aff	ect the project	schedule.
	Analysis of Proj Alternative Con Nothing" Alterr factors if applic	nparison, incl native (includi	uding "Do-	also increase s	supply reliability	γ. This is the le	ast cost altern	ative. The "do i		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
enditures Historical/Planned	<b>2011</b> \$ - \$	2012	2013 \$ -	2014 \$ -	<b>2015</b> \$ -	<b>2016</b> \$ 1,108,593		<b>2018</b> \$ -	<b>2019</b> \$ -	\$
enditures Historical/Planned	2011 \$ - \$ \$1,200,000	5 -	2013 \$ -					<b>2018</b> \$ -		
enditures Historical/Planned	\$ - \$	; - 	2013 \$ -					\$ -		
enditures Historical/Planned	\$ - \$	; - 	2013 \$ -					\$ -		
enditures Historical/Planned	\$ - \$ \$1,200,000 \$1,000,000	-	2013 \$ -					\$ -		
enditures Historical/Planned	\$ - \$ \$1,200,000 \$1,000,000 \$800,000		2013 \$ -					\$ -		
penditures Historical/Planned	\$ - \$ \$1,200,000 \$1,000,000 \$800,000 \$600,000		2013 \$ -					2018		\$

	Project Cod	e	Report Start Year	Number of Years	Scale
Power Stream		100924	2015	6	Dollars
	Project Nam				
Project Summary	r Report	Install two a	additional 27.6 kV ccts o	n Hwy 7 from Jane St t	<u>o Weston Rd</u>
Major Category	System Service				
Project Overview	•				
1. Additional Information	Service Territory	PowerStream	South		
	Location	on Hwy 7 fror	n Jane St to Weston Rd in Vaugl	han - 2km	
	Scope	This project is Center (VMC)	to reroute two 27.6kV feeders	(21M3 & 21M4) to supply new	load in Vaughan Metro
	Justification	ccts into 4 cct installing 2 cc design stage a design plan. The project o St/Hwy 7 area	chieved by rebuilding the existin s, or installing a new 2 ccts pole t in underground ductbank, or c and coordinate with York Region bjectives are to re-route two 21 a, and to install switches or swit ro Center development that is e	Ine on the opposite side of the combination of above options. n's Hwy 7 widening work and the M3& 21M4 27.6kV ccts from V ccts around the compared of the combined of the size of the combined	he exsting pole line, or It will be determined in the he City of Vaughan's urban Veston Rd/Hwy 7 east to Jane is required to supply the
		these feeders 21M5 21M11 20M19	ere are four feeders supplying a were: 401A 280A 361A 433A	area: 21M5, 21M11, 20M19, 2(	0M20. The peak demands of
		The above fee	eders were close or exceeded Po	owerStream's feeder loading g	uide line of 400A.
		plan, two fee used to suppl	oad growth in VMC, more feede ders from VTS4 will off load exis y new growth in VMC area (40M ded and supply VMC too (40 M	ting feeder 21M3 and 21M4 fr IVA). In additional, two other	om VTS2 so that they can be
2. General Project Information (OEB)	Contributed Capital	Contributed (	Capital 0%		
	Fiscal Year Parent WO# Job Number	2020			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manageme		get approval from the City of Va project and should get the appr		e. Capital design will start the
	Comparative Information on Equivalent Historical Projects (if any)	Not Applicabl	e.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	and Jane St fr pole line, or in determined in	bjectives will be achieved by reb om 2 ccts into 4 ccts, or installir nstalling 2 cct in underground d n the design stage and coordina pan design plan.	ng a new 2 ccts pole line on the uct bank, or combination of al	e opposite side of the exsting pove options. It will be

	Projec	t Code	Report Start Year	Number of Years	Scale
Power Stream	<b>X</b>	100924	2015	6	Dollars
Project Summar		t Name Install two a	additional 27.6 kV ccts o	n Hwy 7 from Jane St to	o Weston Rd
	1a. Main Driver 1b. Priority and Reasons for Priority	area. The dev master plan, t feeders. As of 2013, th these feeders 21M5 21M11 20M19 20M20 The above fee To meet the lo plan, two feed used to supply In additional,	city Delivery. The main driver for relopment of the VMC that may the north west corner of VMC (S ere are four feeders supplying a were: 401A 280A 361A 433A eders were close to, or exceeded bad growth in VMC, more feeded ders from VTS4 will off load exis y new growth in VMC area (40M two other feeders 20M17 and 2 the development of VMC is under	d, PowerStream's feeder loadir ers are required in VMC area. A ting feeder 21M3 and 21M4 fro VA).	out. As per the consultant's load and require four 27.6kV DM20. The peak demands of ng guide line of 400A. As per VTS4 feeder integration om VTS2 so that they can be
	1c. Qualitative and Quantitative An Project and Project Alternatives		needed to add 40 MVA supply xplored for supplying 40 MVA to		
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperability</li> <li>Economic Development</li> <li>Environmental Benefits</li> <li>Benefits to Customers of Project Exin terms of Cost Impact, where pra</li> <li>Regional Electricity Infrastructure</li> <li>Requirements which affect Project,</li> </ol>	cticable Not Applicable	e. e. e. e.		
	Applicable Description of Incorporation of Adv Technology, if applicable Identify any reliability, efficiency, s coordination benefits Factors Affecting Timing/Priority Analysis of Project Benefits and Cos Alternative Comparison, including Nothing" Alternative (including qua factors if applicable)	vanced Not Applicable afety or This project w VMC develope sts with This project w 'Do- No other optic	vill increase supply capacity to V ment ramping up schedule will i vill extend two feeders into the V on was determined to be econc	impact the timing and priority. VMC area to increase load capa omically viable. The "do nothin	acity by 40 MVA.

			Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream	Stream			0924	20	015	6	6	Do	ollars
Project Summary Report			Project Name	<u>Install two a</u>	dditional 27	7.6 kV ccts o	n Hwy 7 fror	m Jane St t	o Weston R	<u>8d</u>
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$-	\$ -	\$ -	\$ -	\$ -	\$ -	\$-	\$-	\$ -	\$ 2,084,27
	\$2,500,0	000								
	\$2,000,0	000								
	\$1,500,0	000								
	\$1,000,0	000								
	\$500,0	000								
	\$	201	1 2012	2013	2014	2015 20	16 2017	2018	2019	

	Pr	oject Code		Report Start Year	Number of Years	Scale
Power	<u> </u>	1025	546	2015	6	Dollars
Silean	Pr	oject Name				
Project Summar		-	ation of two	o new circuits on Leslie	Street - 19th Ave to St	touffville Sideroad
Major Category	System Service					
Project Overview	System Service					
1. Additional Information	Service Territory	P	PowerStream S	South		
	Location	C	On Leslie Stree	t from 19th Ave to Stouffville	Sideroad in Richmond Hill.	
	Scope			e line on Leslie St from 19th A		
	1			as per PowerStream's design		
	Justification	р - а V 6	provide backup The Leslie Nor approximately West Gormley 5 MW. Two 27.	to 12M6 to increase supply r th development may accomm 19,300 people and employme will have approx 1,500 resider 6kV feeders are required for t	eliability to Richmond Hill nort odate approximately 6250 hou nt of approximately 3200 jobs tial units and small commerci hese developments. Based or	using units with a population of al units. The estimated load is
2. General Project Information (OEB)	Contributed Capital	C	Contributed Ca	pital 0%		
	Fiscal Year	2	2020			
	Parent WO#	2				
	Job Number					
3. General Information on the	Risks to Completion and Risk N	lanagement T	The risk is to ge	et approval from the Town of I	Richmond Hill in time. Capital	design will start the design of
Project/Activity (OEB)		t	the project and	I should get the approvals in p	lace in advance.	
	Comparative Information on E Historical Projects (if any)	quivalent N	Not Applicable			
	Total Capital and OM&A Costs Renewable Energy Generation		)			
4. Evaluation Criteria (OEB)	Projects (if any) Project Summary	li	nstall two new	circuits on Leslie Street from	19th Ave to Stouffville Sideroa	ad in Richmond Hill.
	1a. Main Driver	N h ju C V	North and Wes nousing units v obs. Based on on 19th Ave so West Gormley	2.5kW per unit and 1.5 kW per new pole line is required.	levelopment may accommoda ately 19,300 people and emplo r job, the total demand would tial units and small commerci	
	1b. Priority and Reasons for Pri	ority H	High. The infra	structure development for thi	s area started in 2014.	
	1c. Qualitative and Quantitative Project and Project Alternative		The existing po development.	le line on Leslie St is a single p	hase 16kV cct. New pole line i	s required to supply the new
	2. Safety	Ν	Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabilit		Not Applicable			
	5. Economic Development	Ν	Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project in terms of Cost Impact, where		Not Applicable			
	Regional Electricity Infrastructu Requirements which affect Pro applicable		Not Applicable			
	Description of Incorporation of Technology, if applicable		Not Applicable			
	Identify any reliability, efficien coordination benefits Factors Affecting Timing/Priorit			l increase reliability for custor f the Leslie North and Gormley		
	Analysis of Project Benefits and Alternative Comparison, includ Nothing" Alternative (including factors if applicable)	d Costs with T ing "Do- p qualitative T	This project is r phase loads an	needed, since there is only one d cannot provide backup need g" alternative is not viable as i	single phase cct on Leslie St t s between ccts on 19th Ave a	hat cannot supply future three nd ccts on Stouffville Sideroad. ity for the future
						Pg

_			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream			10	2546	20	915		6	Do	llars
Project Summary Report			Project Name Insta	Illation of two	o new circui	ts on Leslie	Street - 19t	<u>th Ave to St</u>	ouffville Sid	<u>eroad</u>
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ -	\$-	\$ -	\$ -	ş -	\$-	\$ -	\$-	\$ -	\$ 1,392,64
	\$1,600,000	)								
	\$1,400,000	)								
	\$1,200,000	)								
	\$1,000,000	)								
	\$800,000	)								
	\$600,000	)								
	\$400,000	)								
	\$200,000	)								
	\$-		1							-
		2011	2012	2013	2014 20	2016	5 2017	2018	2019	2020

	F	Project Code		Report Start Year	Number of Years	Scale
Power	5	100	337	2015	6	Dollars
Sirealin	F	Project Name				
Project Summar				Markham TS #4 Fe	eder Egress Part 3	
Major Category	System Service					
Project Overview						
1. Additional Information	Service Territory Location		PowerStream S		e in Markham, approx. 1.5km	
	Scope					eeders from MTS4 to 14th Ave
				-	to Rodick, and crossing Hwy 40 ad installation from Miller Ave	_
	Justification		Steelcase area, different transr	and Warden Ave/14th Ave are nission line so it will also incre	o the distribution system to in ea. This project will also provic ase supply reliability. There wi pacity is required for the new g	de supply capacity from Il be intensification in the
			demand high so different transo transmission lin	upply diversity, i.e., feeders fro nission lines. MTS4 is supplied	L4th Av area, mostly supplied b om different buses, different tr from a different 230kV transm rs from MTS4 will provide tran	ansformer stations and even hission line than the 230kV
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2020			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk I	Management	-	t approval from the City of Ma n advance and should get the a		ital design will start the design
	Comparative Information on Historical Projects (if any)	Equivalent	-Four feeders f		rom MTS4: a Yorktech Blvd via undergrou Rd via underground ductbank	
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			_	n's Part 3. This project is to ins ders will be connected to exist	
	1a. Main Driver		Markham area Hwy 404 and K	and to improve reliability. Thennedy Rd. Many of them requormer stations. These four ne	r this project is to support the nere are many data center cust uire higher than average reliab w feeders will add MTS4 into t	tomers on 14th Ave between ility and supplies from two
	1b. Priority and Reasons for P	riority	will be 7 MW b	_	75-14th Ave will be in service	tial load is 2 MW and ultimate in 2015. The initial load will
	1c. Qualitative and Quantitative Project and Project Alternative			l extend four feeders into the supply the new load.	area and increase capacity by a	80 MVA. There is no other
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabil	lity	Not Applicable			
	5. Economic Development 6. Environmental Benefits		Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Proje in terms of Cost Impact, when					
	Regional Electricity Infrastruct Requirements which affect Pr applicable		Not Applicable			
	Description of Incorporation of Technology, if applicable	of Advanced	Not Applicable			
						Pg

			Project Code		Report Star	t Year	Ν	lumber of Yea	rs	Scale	
Power Stream	-		100	337		2015		6	5	C	ollars
Project Summary Report			Project Name								
Project Summar	y Report				<u>Mark</u>	ham TS	#4 Fee	der Egres	<u>s Part 3</u>		
	Identify any re coordination b Factors Affecti Analysis of Pro Alternative Co Nothing" Alter	enefits ng Timing/Prio ject Benefits a mparison, inclu	rity nd Costs with uding "Do-	Ave/Warden A Customers loa This project is alternatives ha	Ave area. d ramping up needed to ex ave been exp	o schedule v stend four f lored and d	will impace eeders in letermine	ct the timing a to the area, a ed to be more	and priority. nd increase loa costly. The "d	ad capacity by	80 MVA. Oth
	factors if appli		2013	2014	2015	20:		2017	2018	2019	2020
xpenditures Historical/Planned	\$ -	\$-	\$-	\$-	\$-	\$	- \$	5 -	\$-	\$-	\$ 4,910,8
	\$6,000,00										
	\$4,000,00 \$3,000,00										
		0									
	\$3,000,00	0									

	Project	Code	Report Start Year	Number of Years	Scale
Power	<b>X</b>	102545	2015	6	Dollars
Stream	Droiost	Nama			
Project Summar	Project		.6kV Pole Line on 19th A	Ave from Leslie to Woo	dbine Ave
•					
Major Category	System Service				
Project Overview 1. Additional Information	Service Territory	PowerStream	n South		
	Location	On 19th Ave	from Leslie St to Woodbine Ave		
	Scope	Build 2 ccts p	ole line between Leslie St and W	Voodbine Ave.	
		Install switch	es as per PowerStream's design	standard.	
	Justification	This project i			
			wer supply reliability for Markha pply capacity to future developm		mond Hill and
			erational flexibility in Markham		
		Euturo Dovol	opmont Markham		
			opment- Markham kham's Official Plan Amendmen	t No. 113 (OPA 113) has been a	approved by the Region of
			6). The lands subject to ROPA 46		
			roposed land uses of OPA 113 a		
			A 113 area in Markham. Honda n a 19-hectare parcel of land fac		
			d by 2x1000 kVA and 1x750 kVA		Light while the complex is
			ary load estimate is 30 MW whe		nd two 27.6 kV feeders are
		required for	this development.		
		Future Devel	opment- Richmond Hill		
			slie Secondary Plan area encom	passes a land area of approxim	nately 577 hectares and is
			Bayview Avenue, Highway 404, I	-	
			mmercial buildings (including Co uction at north east corner of Le		een completed and more are
		under constr			
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year	2019			
	Parent WO#				
	Job Number				
3. General Information on the	Risks to Completion and Risk Manage	ement The main risl	is to get approval from the Tow	vn of Richmond Hill and city of	Markham as well MTO in
Project/Activity (OEB)			design will start the design of t		
			other risk the 19th widening wor In will work with the town to coo		le line construction.
		rowcroticum			
	Comparative Information on Equival	ent Not Applicab	le.		
	Historical Projects (if any)				
	Total Capital and OM&A Costs for	0			
	Renewable Energy Generation portion				
	Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary		s pole line between Leslie St an		
	1a. Main Driver		acity Delivery. The main driver f		
			rovide back up for the existing of		
	1b. Priority and Reasons for Priority		isting customer on Woodbine Av		
		-	n Woodbine Ave will cause prolo	-	
	1c. Qualitative and Quantitative Anal	vsis of The existing	customers on Woodhine Ave no	rth of Flgin Mills are on a radia	l supply. The backup needs to
	Project and Project Alternatives	-	/arden Ave (east) or Leslie St (W		supply. The backup fleeds to
			ere is only a single phase cct on V		Is and 19th Ave and therefore
			vide backup for customers on W	oodbine Ave without being re	built into a 3-phase line. The
	2 Safaty		nly from Leslie St.		
	2. Safety 2. Cyber Security, Brivacy	Not Applicab			
	3. Cyber-Security, Privacy	Not Applicab			
	<ol> <li>Coordination, Interoperability</li> <li>Economic Development</li> </ol>	Not Applicab Not Applicab			
	6. Environmental Benefits	Not Applicab			
5. Category-Specific Requirements for					
Each Project/Activity (OEB)	in terms of Cost Impact, where pract				
					Pa

			Project Code		Report Sta	art Year	N	umber of Yea	rs	Scale	
Power Stream			10	2545		2015		6	i	Do	llars
	Project Summary Report		Project Name								
Project Summary	Report			<u>New 27</u> .	.6kV Pole	e Line on 19	th Ave	e from Les	lie to Woo	<u>dbine Ave</u>	
	Regional Electri Requirements v applicable			Not Applicabl	le.						
	Description of I Technology, if a		of Advanced	Not Applicabl	le.						
	Identify any rel coordination be	enefits									
	Factors Affectir			feeders.						ne loading and u	
	Analysis of Proj Alternative Con Nothing" Altern	mparison, inclu native (includi	uding "Do-	lower than av			e as cus	tomers will co	ontinue to rem	ain on radial su	ipply and h
	factors if applic										
	factors if applic	2012	2013	2014	2015	2016		2017	2018	2019	2020
penditures Historical/Planned			<b>2013</b> \$ -	<b>2014</b> \$ -	<b>2015</b> \$	- \$	- \$		<b>2018</b> \$ -	<b>2019</b> \$ 1,020,587	<b>2020</b> \$
penditures Historical/Planned		2012	<b>2013</b> \$ -								
penditures Historical/Planned	<b>2011</b> \$ - \$	2012	2013 \$ -								
penditures Historical/Planned	<b>2011</b> \$ - \$ \$1,200,000	<b>2012</b>	2013 \$ -								
penditures Historical/Planned	2011       \$       -       \$1,200,000       \$1,000,000	<b>2012</b>	2013 \$ -								
penditures Historical/Planned	2011         \$       -       \$         \$       -       \$         \$1,200,000       \$         \$1,000,000       \$         \$800,000       \$	2012	2013 \$ -								
penditures Historical/Planned	2011 \$ - \$ \$1,200,000 \$1,000,000 \$800,000 \$600,000	2012 	2013 \$ -								

	Project Code		Report Start Year	Number of Years	Scale
Power	10	0959	2015	6	Dollars
Project Summar	Project Name y Report		vV Feeder (13M7) Barri	e TS X Huronia & Big E	Bay Pt. Rd
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory	PowerStream	North		
	Location	Barrie			
	Scope	Huronia and B Dyment Road/ Road to the er new build Fair Big Bay Point F crossing alread	tails the design and construction ig Bay Point Road. The new circo John Street along John Street t and of the existing pole line befor view Road to Little Avenue, Fai Road past Huronia to the existing dy exists and the 13M7 breaker sumer 2017. The project includes 3.	cuit will require rebuilding the o Anne Street, along Anne Str re Fairview Road, 300m of new rview Road from Little Avenue ng LT-B35115 switch. It should at Barrie TS is currently idle. T	existing pole line from eet to Essa Road, along Essa w build Essa Road and 550m e to Big Bay Point Road, along be noted that the Hwy 400 The new feeder is to be in-
	Justification	from the City of indicates that needs to be se Corridor Inten load. Two othe additional unit (Painswick MS future develop by the 23M25 loaded to 30.2 proposed 8.6N in 2014 and th substations in	er is required to provide capaci of Barrie on proposed developr there are a number of resident rviced. There are two developr sification Plan that will result ir er residential developments cu ts with an estimated 0.8MVA or ) is currently being constructed oments. The existing Big Bay Po 44kV feeder in the current syst MVA (396A) during the summe AVA (113A) of residential load, e 600A thermal limit will be ex the Barrie south-east area can ad growth without exceeding th	nents in the Sandringham Driv ial subdivisions that will result nents currently under conside a 3,137 residential units totalin rrently registered and under d load. A new 20MVA 44/13.8k in the Yonge/Mapleview area int Road MS and the future Pa em configuration. However, w or 2013 peak and the future Pa the 23M25 feeder will exceed ceeded in 2018. The new feed be supplied accordingly in ord	e and Big Bay Point Road area in new load growth that ration as part of the Yonge g an estimated 7.8MVA of raft approval will result in 295 V 4 feeder substation to service the proposed answick MS would be supplied with Big Bay Point Road MS inswick MS supplying the the 400A feeder planning limit er will ensure that the er to accommodate the
2. General Project Information (OEB)	Contributed Capital	Contributed Ca	apital 0%		
	Flored Manage	2015			
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Management	-	sk to completion is securing th p of the proposed residential c		
	Comparative Information on Equivalent Historical Projects (if any)	proceeding wi	jects for new circuits have take th construction. Information f his planned project.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	Huronia and B Dyment Road/ Road to the er new build Fair Big Bay Point F crossing alread	tails the design and construction ig Bay Point Road. The new circ John Street along John Street t ad of the existing pole line befor view Road to Little Avenue, Fai Road past Huronia to the existin dy exists and the 13M7 breaker sumer 2017. The project includes g.	cuit will require rebuilding the o Anne Street, along Anne Str re Fairview Road, 300m of new rview Road from Little Avenue ng LT-B35115 switch. It should at Barrie TS is currently idle. T	existing pole line from eet to Essa Road, along Essa w build Essa Road and 550m e to Big Bay Point Road, along be noted that the Hwy 400 The new feeder is to be in-

	Project Co	de	Report Start Year	Number of Years	Scale		
Power Stream		100959	2015	6	Dollars		
Project Summary	Project Na y Report		kV Feeder (13M7) Barri	<u>e TS X Huronia &amp; Big E</u>	<u>Bay Pt. Rd</u>		
	1a. Main Driver	south-east are eight years. A the Yonge/Ma MS and the fu configuration. peak and the feeder will exe 2018. The nev accordingly in	er of the project is to provide ca ea. The area has 8.6MVA of pro new 20MVA 44/13.8kV 4 feede upleview area to service the pro ture Painswick MS would be su However, with Big Bay Point R future Painswick MS supplying ceed the 400A feeder planning v feeder will ensure that the su order to accommodate the and of the 44kV feeders.	posed residential development r substation (Painswick MS) is posed future developments. T pplied by the 23M25 44kV fee oad MS loaded to 30.2MVA (39 the proposed 8.6MVA (113A) o limit in 2014 and the 600A the bstations in the Barrie south-ea	t to take place over the next currently being constructed in the existing Big Bay Point Road der in the current system OGA) during the summer 2013 of residential load, the 23M25 rmal limit will be exceeded in ast area can be supplied		
	1b. Priority and Reasons for Priority	2018 upon co	er is high priority since thermal mpletion of the new Painswick le adjacent feeder are limited d	MS and the proposed resident			
	1c. Qualitative and Quantitative Analys Project and Project Alternatives	providing capa The new feed distance of the	it would add approximately 30 acity relief to the existing 23M2 er would also provide cost savin e existing feeder from Midhurs lting in approximately \$100,000	5 and ensuring supply capacity ngs realized from line loss redu t TS (15km) to a much shorter o	to the new Painswick MS. ctions by decreasing the		
		during the sur (113A) of resid limit in 2014 a accommodatio	ng' alternative is not viable beconner 2013 peak and the future dential load, which would resul nd the 600A thermal limit in 20 on of future residential load gro in contingency conditions.	Painswick MS will be supplyin t in the 23M25 feeder exceedir 018. The do-nothing alternative	g the proposed 8.6MVA ng the 400A feeder planning e would not allow the		
	2. Safety	Not Applicable	2.				
	3. Cyber-Security, Privacy	Not Applicable	2.				
	4. Coordination, Interoperability	Not Applicable	2.				
	5. Economic Development	Not Applicable	2.				
	6. Environmental Benefits	Not Applicable	2.				
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project Expres in terms of Cost Impact, where practica		2.				
	Regional Electricity Infrastructure Requirements which affect Project, if applicable	Not Applicable.					
	Description of Incorporation of Advanc Technology, if applicable	ed Not Applicable	2.				
	Identify any reliability , efficiency, safet coordination benefits	east area, the will also help	er will produce reliability benef reby increasing transfer options reduce line losses by reducing t rter distance from Barrie TS (7.	s which increases reliability to o he distance of the existing feed	customers. The new feeder		
	Factors Affecting Timing/Priority	Securing the r feeder constru	equired approvals from the city uction.	r in the allotted timeframe may	y affect the timing of the		

			Project Code		Report Start Y	ear	Number of Yea	rs	Scale	
Power Stream			10	0959	20	15	e	5	Do	ollars
	•		Project Name		-					
Project Summary	Report			<u>New 44</u>	<u>kV Feeder (</u>	<u>13M7) Barri</u>	<u>e TS X Hurc</u>	onia & Big E	<u>Bay Pt. Rd</u>	
	Alternative Cor Nothing" Altern factors if applic	native (includi		The new feede distance of the (7.5kms), resu The 'do-nothir during the sun (113A) of resic limit in 2014 a accommodatio	er would also pr e existing feede lting in approxin ng' alternative is nmer 2013 peal dential load, wh and the 600A the	ovide cost savir r from Midhurst nately \$100,000 a not viable beca a and the future ich would result ermal limit in 20 dential load gro	5 and ensuring ings realized from t TS (15km) to a 0 of annual savir ause Big Bay Poi Painswick MS v t in the 23M25 f 018. The do-noth bowth in the area	n line loss redu much shorter o ngs. nt Road MS wa vill be supplyin eeder exceedir ning alternative	ctions by decre distance from F as loaded to 30 g the proposed ag the 400A fee e would not allo	easing the Barrie TS 0.2MVA (396 d 8.6MVA eder planni ow the
enditures Historical/Planned	<b>2011</b> \$ - \$	<b>2012</b>	<b>2013</b> \$ -	<b>2014</b> \$ -	<b>2015</b> \$ 76,925	<b>2016</b> \$ 4,726,805	<b>2017</b> \$ -	<b>2018</b> \$ -	<b>2019</b> \$ -	<b>2020</b> \$
penditures Historical/Planned	\$ - \$	5 -	<b>2013</b> \$ -	<b>2014</b> \$ -				<b>2018</b> \$ -		
enditures Historical/Planned	\$ - \$	 00	<b>2013</b> \$ -	<b>2014</b> \$ -				<b>2018</b> \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,00 \$4,500,00		<b>2013</b> \$ -	<b>2014</b> \$ -				<b>2018</b> \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,000 \$4,500,000 \$4,000,000		<b>2013</b> \$ -	<b>2014</b> \$ -				<b>2018</b> \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,00 \$4,500,00 \$4,000,00 \$3,500,00		<b>2013</b> \$ -	<b>2014</b> \$ -				<b>2018</b> \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,000 \$4,500,000 \$4,000,000		2013 \$ -	<b>2014</b> \$ -				2018 \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,000 \$4,500,000 \$3,500,000 \$3,000,000		2013 \$ -	<b>2014</b> \$ -				2018 \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,00 \$4,500,00 \$3,500,00 \$3,000,00 \$2,500,00		2013 \$ -	2014 \$ -				2018 \$-		
penditures Historical/Planned	\$ - \$ \$5,000,000 \$4,500,000 \$4,500,000 \$3,500,000 \$3,000,000 \$2,500,000 \$2,500,000	20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -       20     -	2013 \$ -	2014 \$ -				2018 \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,000 \$4,500,000 \$3,500,000 \$3,500,000 \$2,500,000 \$2,000,000 \$1,500,000		2013 \$ -	2014 \$ -				2018 \$ -		
penditures Historical/Planned	\$ - \$ \$5,000,00 \$4,500,00 \$4,500,00 \$3,500,00 \$3,000,00 \$2,500,00 \$1,500,00 \$1,000,00		2013 \$ - 	2014 \$ -	\$ 76,925		\$ -	2018 \$ -		\$

	Project C	ode	Report Start Year	Number of Years	Scale
Power	<b>X</b>	100913	2015	6	Dollars
Stream	Project N	ame			
Project Summar			allation Double Cct on M	<u> Major Mack - Huntingtor</u>	n Rd to Hwy 50
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory	PowerStream		v EQ in Vaughan approx 2km	
	Location		ck Dr from Huntington Rd to Hw		
	Scope		epends on York Region road wid s of this project is to install doub	-	Aaior Mack Dr from
		Huntington Ro	d to Hwy 50 in Vaughan, approx ccts on Hwy 50, and Huntingto	. 2km., install LIS at intersection	-
	Justification	To supply new below: Kleindor Deve	v developments on Major Mack	between Hwy 50 and Hunting	ton Rd that are summarized
		Kleindor deve 3,000 people, The Kleindor o CP railway and	lopment is part of OPA160 initia and 1,000 residential dwelling i development area that is locate d west of Regional Road 27. The	units. d on the north side of Major M	lackenzie Drive, east side or
		Vaughan's Off guide growth The Amendme	<u>hts Development</u> icial Plan Amendment No. 699 ( in Block 61 West within the Klei ent area is approximately 185 h pad, on the east by the CP rail li	nburg-Nashville Community. ectares (457 acres) in size and	is bounded on the west by
		by lots frontin OPA 699 has a	g Nashville Road. I planned population of approxi I 700 jobs.Based on 2.7kW per t	mately 8,000 people, 2,625 re	sidential dwelling units and
		The West Vau opportunity for	n Employment Area ghan Employment Area Second or York Region. With over 500 h	ectares of employment design	ated lands, this area will
		with excellent accommodate	low the City of Vaughan to attra Regional road and provincial h approximately 20,120 employe nzie Drive that has been zoned a	ighway access. The Secondary ees. There are 1,400 acres of vi	Plan is planned to
		estimated to b	load from these lands will be sig be 50MW to 80 MW when fully s are required to supply the new	built out, but no time line is av	
		opportunity fo	going to widen Major Mackenz or PowerStream to rebuild the e ith the pole line relocation proj	existing single phase 4.8 kV cct	
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year Parent WO# Job Number	2019			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manager	-	et approval from the City of Va Mack Dr in 2019. The pole line		
	Comparative Information on Equivale Historical Projects (if any)		will work closely with the Regio	on and City to coordinate the p	project.
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 of			
4. Evaluation Criteria (OEB)	Project Summary		to build two ccts on Major Mac both side of Major Mack.	k Dr between Huntington Rd a	and Hwy 50 to supply new
	1a. Main Driver	Support Capa Vaughan Wes	city Relief. The main driver for t t area. There is one single phas ting feeders don't have sufficien	e 4.8kV cct on Major Mack Dr	between Huntington and Hwy

	Project Co	le	Report Start Year	Number of Years	Scale
Power Stream		100913	2015	6	Dollars
	Project Na				
Project Summar	y Report	Pole Line In:	stallation Double Cct on	Major Mack - Hunting	<u>gton Rd to Hwy 50</u>
	1b. Priority and Reasons for Priority	customers a	acant land on both sides of Majo are expected in the coming years ork. Building 2 ccts in conjunctio ct.	. The existing pole line has	to be relocated due to road
	1c. Qualitative and Quantitative Analysi Project and Project Alternatives	It will also e	will add two 27.6kV ccts to the a stablish ties between feeders or ly reliability in the west part of V	Hwy 50 and feeders on Hur	
	2. Safety	Not Applica			
	3. Cyber-Security, Privacy	Not Applical			
	4. Coordination, Interoperability	Not Applica			
	5. Economic Development	Not Applica	ble.		
	6. Environmental Benefits	Not Applica	ble.		
Category-Specific Requirements for ch Project/Activity (OEB)	Benefits to Customers of Project Expres in terms of Cost Impact, where practica		ble.		
	Regional Electricity Infrastructure Requirements which affect Project, if applicable	Not Applica	ble.		
	Description of Incorporation of Advance Technology, if applicable	d Not Applica	ble.		
	Identify any reliability , efficiency, safety coordination benefits	increase pov	wer supply reliability in the west	part of Vaughan.	-
	Factors Affecting Timing/Priority	the road wid	le will be built as per Major Mac dening schedule.		
	Analysis of Project Benefits and Costs w Alternative Comparison, including "Do- Nothing" Alternative (including qualitat	impact Pow	ternative is to "do nothing" and erStream distribution system in		wth from existing facilities. It
	factors if applicable)	Reliability			
		has adopted Kleindor dev pole failure Heights dev	e single phase 4.8kV cct on Major d "Open Grid Network" planning velopment is supplied from Hwy on the cable will cause large sca elopment is supplied from Hunti lure on the cable or pole line on omers.	philosophy, i.e., loop supply 50 through a radial undergr le and prolonged outages to ngton Rd through a radial u	y with normal open points. T round cable, meaning that an o the customers. The Nashvill nderground cable, meaning t
		Capacity			
		There is one	e single phase 4.8kV cct on Major / to supply Kleindor developmen		
		Nashville He Kleindor and	quo will jeopardize PowerStream eights developments. The impact d Nashville Heights development m will not be able to supply new	: severity and timing will dep t. The "do nothing" alternati	pend on the schedule of the ive is not viable because

_			Project	Code		Report Start	Year	Ν	lumber of Yea	rs	Scale	
Power Stream				1009	13		2015		6	5	Do	llars
Project Summary	Report		Project		e Line Inst	allation Do	uble Cct c	on Ma	ajor Mack ·	- Huntingtor	n <mark>Rd to Hw</mark> y	<u> 50</u>
	2011	2012	20	13	2014	2015	2016		2017	2018	2019	2020
xpenditures Historical/Planned	\$-	\$-	\$	-	\$-	\$-	\$	- ¢	\$-	\$ -	\$ 1,307,147	\$ -
	\$1,400,	000										
	\$1,200,	000										
	\$1,000,	000										
	\$800,	000										
	\$600,	000										
	\$400 <i>,</i>	000										
	\$200,	000										
		S- 202	L1	2012	2013	2014	2015	2016	6 2017	2018	2019	2020
	L											

	Project C	ode	Report Start Year	Number of Years	Scale
Power Stream	-	100909	2015	6	Dollars
	Project N	ame			
Project Summar	y Report	ebuild 27.6 kV	pole line for 4 Ccts on V	Varden Ave from Major	Mack to Elgin Mills
Major Category	System Service				
Project Overview	System Service				
1. Additional Information	Service Territory	PowerStream	n South		
	Location	On Warden A	Ave from Major Mack Dr to Elgir	Mills Rd in Markham - 2 km	
	Scope		existing single cct pole line into a jor Mack Dr to Elgin Mills Rd in		
	Justification		eder 12M10/12M11 to Markhar ea and new urban area north of		
		Markham to north Markha Mackenzie D	s working on an Official Plannin both sides of Warden Ave to pr am Future Urban Area covers al rive to the south, the Hydro Cor rin Mills Road to the north, and	ovide opportunities for urban bout 1,288 hectares (3,183 acr ridor and Woodbine Avenue t	growth to the year 2031. The es bordered by Major o the west, the northerly City
		neighbourho 300 hectares the Future U population o	ly 675 hectares (1,668 acres) of ods, located primarily between (741 acres) located north of Elg rban Area is intended to accom f approximately 38,000 persons oads are expected on both side	Major Mackenzie Drive and El in Mills Road are designated f modate approximately 12,000 , and approximately 19,000 jol	gin Mills Road. Approximate or employment uses. In total, residential units with a bs. It is expected approx. 60
		new 27.6kV f	urban area, they expect to see b eeders are required for the Hw 10/12M11 are planned to be re- north.	404 Development and urban	expansion in Markham. Two
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
2. General Project Information (OEB)	Fiscal Year Parent WO#	Contributed	Capital 0%		
3. General Information on the	Fiscal Year	2018 ment The risk is to Hwy 7 widen South Townc	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time	d to Warden Ave project to ext ital Design has started the des	tend 12M10/12M11 from ign of the project in advance
2. General Project Information (OEB) 3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number	2018 ment The risk is to Hwy 7 widen South Townc and should g road widenin	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time ig schedules.	d to Warden Ave project to ext ital Design has started the des	tend 12M10/12M11 from ign of the project in advance
3. General Information on the	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion	2018 ment The risk is to Hwy 7 widen South Townc and should g road widenin nt Not Applicab	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time ig schedules.	d to Warden Ave project to ext ital Design has started the des	tend 12M10/12M11 from ign of the project in advance
3. General Information on the	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for	2018 ment The risk is to Hwy 7 widen South Townc and should g road widenin nt Not Applicab 0 n of Rebuild the e	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time ig schedules.	d to Warden Ave project to exi ital Design has started the des e. Capital Design will also coor	tend 12M10/12M11 from ign of the project in advance dinate with York Region for
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	2018 Ment The risk is to Hwy 7 widen South Townc and should g road widenin Not Applicab 0 A of Rebuild the e Major Mack to Support Capa Markham No Woodbine Av	get approval from the City of M ing from South Towncenter Blvd tenter Blvd to Warden Ave. Cap et the approvals in place in time g schedules. le.	d to Warden Ave project to exi ital Design has started the des e. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N	tend 12M10/12M11 from ign of the project in advance dinate with York Region for r future on Warden Ave from e capacity devlivery in of Major Mack between Markham Official Plan
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any) Project Summary	2018 Ment The risk is to Hwy 7 widen South Townc and should g road widenin Not Applicab 0 0 Rebuild the e Major Mack t Support Capa Markham No Woodbine Av Amendment	get approval from the City of M ing from South Towncenter Blvd tenter Blvd to Warden Ave. Cap et the approvals in place in time g schedules. le. existing pole line into 4 ccts, 2 co to Elgin Mills in Markham. acity Delivery. The main driver for orth area . There is a load growt ve and Kennedy Rd. Based on p	d to Warden Ave project to exi ital Design has started the des e. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N are required for the Hwy 404	tend 12M10/12M11 from ign of the project in advance dinate with York Region for r future on Warden Ave from e capacity devlivery in of Major Mack between Markham Official Plan Development in Markham.
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any) Project Summary 1a. Main Driver	2018 Ment The risk is to Hwy 7 widen South Townc and should g road widenin Not Applicab 0 Rebuild the e Major Mack to Support Capa Markham No Woodbine Av Amendment High. The ex	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time g schedules. le. existing pole line into 4 ccts, 2 cd to Elgin Mills in Markham. acity Delivery. The main driver f orth area . There is a load growt ve and Kennedy Rd. Based on p (OPA), two new 27.6kV feeders isting feeders supplying Markha	d to Warden Ave project to exi ital Design has started the des c. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N are required for the Hwy 404 m north don't have sufficient	tend 12M10/12M11 from ign of the project in advance rdinate with York Region for r future on Warden Ave from the capacity devlivery in to of Major Mack between Markham Official Plan Development in Markham. capacity for future growth.
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivaler Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any) Project Summary 1a. Main Driver 1b. Priority and Reasons for Priority 1c. Qualitative and Quantitative Analy	2018 Ment The risk is to Hwy 7 widen South Townc and should g road widenin Not Applicab 0 Rebuild the e Major Mack t Support Capa Markham No Woodbine Av Amendment High. The ex	get approval from the City of M ing from South Towncenter Blvd renter Blvd to Warden Ave. Cap et the approvals in place in time g schedules. le. existing pole line into 4 ccts, 2 cd to Elgin Mills in Markham. acity Delivery. The main driver f orth area . There is a load growt ve and Kennedy Rd. Based on p (OPA), two new 27.6kV feeders isting feeders supplying Markha will increase supply capacity by a le.	d to Warden Ave project to exi ital Design has started the des c. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N are required for the Hwy 404 m north don't have sufficient	tend 12M10/12M11 from ign of the project in advance rdinate with York Region for r future on Warden Ave from the capacity devlivery in to of Major Mack between Markham Official Plan Development in Markham. capacity for future growth.
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any) Project Summary 1a. Main Driver 1b. Priority and Reasons for Priority 1c. Qualitative and Quantitative Analy Project and Project Alternatives 2. Safety	2018 ment The risk is to Hwy 7 widen South Townc and should g road widenin Not Applicab 0 Rebuild the e Major Mack to Support Capa Markham No Woodbine Av Amendment High. The ex sis of This project v north. Not Applicab	get approval from the City of M ing from South Towncenter Blvd tenter Blvd to Warden Ave. Cap et the approvals in place in time g schedules. le. existing pole line into 4 ccts, 2 cd to Elgin Mills in Markham. acity Delivery. The main driver for th area . There is a load growt ve and Kennedy Rd. Based on p (OPA), two new 27.6kV feeders isting feeders supplying Markha will increase supply capacity by a le. le.	d to Warden Ave project to exi ital Design has started the des c. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N are required for the Hwy 404 m north don't have sufficient	tend 12M10/12M11 from ign of the project in advance rdinate with York Region for r future on Warden Ave from the capacity devlivery in to of Major Mack between Markham Official Plan Development in Markham. capacity for future growth.
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Risk Manager Comparative Information on Equivale Historical Projects (if any) Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any) Project Summary 1a. Main Driver 1b. Priority and Reasons for Priority 1c. Qualitative and Quantitative Analy Project and Project Alternatives 2. Safety 3. Cyber-Security, Privacy	2018 ment The risk is to Hwy 7 widen South Townc and should g road widenin nt Not Applicab 0 Rebuild the e Major Mack t Support Capa Markham No Woodbine Av Amendment High. The ex sis of This project v north. Not Applicab Not Applicab	get approval from the City of M ing from South Towncenter Blvd tenter Blvd to Warden Ave. Cap et the approvals in place in time ag schedules. le. existing pole line into 4 ccts, 2 cc to Elgin Mills in Markham. acity Delivery. The main driver f orth area . There is a load growt we and Kennedy Rd. Based on p (OPA), two new 27.6kV feeders isting feeders supplying Markha will increase supply capacity by a le. le.	d to Warden Ave project to exi ital Design has started the des c. Capital Design will also coor ets now and 2 ccts provision fo for this project is to support th h in the new urban area north reliminary information from N are required for the Hwy 404 m north don't have sufficient	tend 12M10/12M11 from ign of the project in advance rdinate with York Region for r future on Warden Ave from the capacity devlivery in to of Major Mack between Markham Official Plan Development in Markham. capacity for future growth.

		Project Coo	le	Report Start Y	Year	Number of Yea	ars	Scale	
Power Stream			100909	2	2015		6	De	ollars
Project Summar			ouild 27.6 kV p		4 Ccts on W	arden Ave	from Major I	Mack to El	gin Mills
Category-Specific Requirements for ach Project/Activity (OEB)	Benefits to Customer in terms of Cost Impa			е.					
	Regional Electricity Ir Requirements which applicable		Not Applicable	е.					
	Description of Incorp Technology, if applica	able							
	Identify any reliability coordination benefits	S							
	Factors Affecting Tim Analysis of Project Be				scheduled in Mar feeders into the a				priority.
			I ha main altai		o nothing" but t				
	Nothing" Alternative factors if applicable)	son, including "Do- (including qualitat	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H	th is supplied b was 384A on 10 wy 404 North c eeders in Markl eeders 12M10/2 ng" alternative	o nothing", but to by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents.	10M2 on Woo 12M12. They o new urban exp t have sufficien little load now t will jeopardize	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti PowerStream'	2M12 on War icient capacity pply new cust lized. s obligation to	rden Ave. T y to supply omers. o supply nev
	Nothing" Alternative	(including qualitat	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H	th is supplied b was 384A on 10 wy 404 North c eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban	10M2 on Woo 12M12. They o new urban exp t have sufficien little load now t will jeopardize	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti PowerStream'	2M12 on War icient capacity pply new cust lized. s obligation to	rden Ave. Th y to supply r omers. o supply new epend on th
<penditures historical="" p="" planned<=""></penditures>	Nothing" Alternative factors if applicable)	(including qualitat	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North leese developme	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents.	10M2 on Woo 12M12. They o new urban exp t have sufficien little load now t will jeopardize n area. The imp	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream? act severity and	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Th y to supply r omers. o supply new
xpenditures Historical/Planned	Nothing" Alternative factors if applicable)         2011       20	112 2013	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b>	10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Tł y to supply r omers. o supply new epend on th <b>2020</b>
Expenditures Historical/Planned	Nothing" Alternative factors if applicable)         2011       20.         \$       -       \$	112 2013	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b>	10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Ti y to supply r omers. o supply nev epend on th <b>2020</b>
Expenditures Historical/Planned	Nothing" Alternative factors if applicable)   2011   \$    \$   \$ <td>112 2013</td> <td>ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th</td> <td>th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015</td> <td>by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b></td> <td>10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017</td> <td>dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018</td> <td>2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019</td> <td>rden Ave. Ti y to supply r omers. o supply nev epend on th <b>2020</b></td>	112 2013	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b>	10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Ti y to supply r omers. o supply nev epend on th <b>2020</b>
xpenditures Historical/Planned	Nothing" Alternative factors if applicable)           2011         20           \$         -         \$           \$2,500,000         -         -           \$2,000,000         -         -	112 2013	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b>	10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Ti y to supply r omers. o supply nev epend on th <b>2020</b>
xpenditures Historical/Planned	Nothing" Alternative factors if applicable)         2011       20         \$       -       \$         \$2,500,000       -       -         \$2,000,000       -       -         \$1,500,000       -       -	112 2013	ve Markham nord peak in 2013 v loads in the Hy The existing fe Conversely, fe The "do nothin customers in H schedule of th	th is supplied b was 384A on 10 wy 404 North o eeders in Markl eeders 12M10/2 ng" alternative Hwy 404 North tese developme 2015	by two feeders by DM2 and 232A on development and ham North do no 12M11 have very is not viable as in and future urban ents. <b>2016</b>	10M2 on Woo 12M12. They of new urban exp t have sufficien little load now t will jeopardize n area. The imp 2017	dbine Ave and 1 do not have suff pansion. It capacity to su and are not uti e PowerStream's act severity and 2018	2M12 on War icient capacity pply new cust lized. s obligation to timing will de 2019	rden Ave. Tł y to supply r omers. o supply new epend on th <b>2020</b>

	Project C	ode	Report Start Year	Number of Years	Scale
Power Stream		100905	2015	6	Dollars
Project Summa	Project N		V pole line into 4 Ccts of	on Warden Ave from H	wy 7 to 16th Ave
Major Catagony	System Service				
Major Category Project Overview	System Service				
1. Additional Information	Service Territory Location Scope	To rebuild th	n South we from Hwy 7 to 16th Ave in N e existing 27.6kV pole line into en Ave. To install two 27.6kV co	4 ccts pole line or install a new	
	Justification	404 North an York Region i Markham to north Markh Mackenzie D limits and Elg Approximate neighbourho 300 hectares the Future U population o MW of new I For the new 1 new 27.6kV f	eder 12M10/12M11 to Markhar ea and new urban area north o s working on an Official Plannin both sides of Warden Ave to pr am Future Urban Area covers al rive to the south, the Hydro Con in Mills Road to the north, and ly 675 hectares (1,668 acres) of ods, located primarily between (741 acres) located north of Elg rban Area is intended to accom f approximately 38,000 persons oads are expected on both side urban area, they expect to see I eeders are required for the Hw lers 12M10/12M11 have planne n Markham north.	f Major Mack between Woodb g Amendment which expands ovide opportunities for urban bout 1,288 hectares (3,183 acr rridor and Woodbine Avenue t the Robinson Creek to the eas developable lands are designa Major Mackenzie Drive and El in Mills Road are designated for modate approximately 12,000 , and approximately 12,000 o and approximately 19,000 jol s of Warden Ave north of Majo puilding permit issued in 2017 y 404 Development and urban	ine Ave and Kennedy Rd. the Urban Area of the City of growth to the year 2031. The es bordered by Major o the west, the northerly City t. ited for future gin Mills Road. Approximately or employment uses. In total, residential units with a os. It is expected approx. 60 or Mackenzie Dr. and new houses in 2018. Two expansion in Markham.
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year Parent WO# Job Number	2016			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manager	Hwy 7 widen South Townc	ing from South Towncenter Blv enter Blvd to Warden Ave. Cap et the approvals in place in time	d to Warden Ave project to exi ital Design has started the des	tend 12M10/12M11 from ign of the project in advance
	Comparative Information on Equivale Historical Projects (if any)	nt Not Applicab	le.		
	Total Capital and OM&A Costs for Renewable Energy Generation portior Projects (if any)	0 n of			
4. Evaluation Criteria (OEB)	Project Summary	design if a ne	s to add two ccts on Warden Av w 2 ccts pole line can be install s pole into 4 ccts on the west si	ed on the east side of Warden	
	1a. Main Driver	north. Basec	acity Delivery. The main driver l on preliminary information fro equired for the Hwy 404 Develo	m Markham Official Plan Ame	

5. Category-Specific Requirements for Each Project/Activity (OEB)	1c. Qualitativ Project and P 2. Safety 3. Cyber-Secu 4. Coordinatio 5. Economic I 6. Environme	roject Alternat Irity, Privacy on, Interopera	Project Name <u>Ret</u> ative Analysis of		V pole line	2015 into 4 Ccts of oply capacity by 4	on Warden A	6 Ave from Hv		Ave
. Category-Specific Requirements for	1c. Qualitativ Project and P 2. Safety 3. Cyber-Secu 4. Coordinatio 5. Economic I 6. Environme	roject Alternat Irity, Privacy on, Interopera	Ret ative Analysis of	This project w north.				Ave from Hv	vy 7 to 16th	Ave
	<ul> <li>Project and P</li> <li>2. Safety</li> <li>3. Cyber-Secu</li> <li>4. Coordination</li> <li>5. Economic I</li> <li>6. Environme</li> </ul>	roject Alternat Irity, Privacy on, Interopera		north.	ill increase sup	oply capacity by 4	IO MVA and will			
	<ol> <li>Cyber-Secu</li> <li>Coordination</li> <li>Economic I</li> <li>Environme</li> </ol>	on, Interopera		Not Applicable				also increase s	upply reliability	/ to Markha
	<ol> <li>4. Coordination</li> <li>5. Economic I</li> <li>6. Environme</li> </ol>	on, Interopera			e.					
	5. Economic I 6. Environme			Not Applicable	e.					
	6. Environme	Development	bility	Not Applicable	e.					
				Not Applicable	e.					
	Demefite to C	ntal Benefits		Not Applicable	e.					
			oject Expressed ere practicable	Not Applicable	e.					
		tricity Infrastru s which affect		Not Applicable	e.					
			n of Advanced	Not Applicable	e.					
		eliability , effic	ciency, safety or	This project w	vill increase sup	oply reliability to	Markham north	).		
	Factors Affect	ting Timing/Pr	iority	Customers loa	ad ramping up	schedule in Mar	kham north area	a will impact th	e timing and pr	iority.
	Alternative C	omparison, ind				o nothing" and o bution system ca		oly load growth	from existing f	acilities. It
	factors if app			peak in 2013 v loads in the Hy North do not l	was 384A on 10 wy 404 North o have sufficient	by two feeders b DM2 and 232A o development an capacity to supp	n 12M12. They o d new urban exp oly new custome	do not have suf pansion. The er ers.	ficient capacity xisting feeders	to supply
				The "do nothin North and fut	ng" alternative ure urban area 5. The "do noth	12M11 have ver e will reduce Pow a. The impact sev ning" option is no	verStream's abil erity and timing	ity to supply ne g will depend or	ew customers ir n the schedule	of these
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ -	\$ -	\$ -	\$ -	\$-	\$ 2,039,163	\$-	\$-	\$-	\$
	\$2,500,0	000								
	\$2,000,0	000 -					<b></b>			
	¢1 F00 4	000								
	\$1,500,0									
	\$1,000,0	000								
	\$500,0	000 -								
	ç	5-	1	1 1				1	1 1	

	Pr	oject Code		Report Start Year	Number of Years	Scale
_ Power		100	)229	2015	6	Dollars
Stream						
Project Summar		oject Name Rebui	ild 27.6 kV p	ole line on Warden Ave	e into 4 ccts from 16th /	Ave to Major Mack
,	,					
Major Category	System Service					
Project Overview						
1. Additional Information	Service Territory		PowerStream S			
	Location			e from 16th to Major Mackenz		
	Scope			existing pole line on Warden A les are framed already for 4 co		oth Ave to Major Mack Dr.
	Justification		This project is r capacity and re	necessary to reroute feeder 12 liability to Hwy 404 North area	M10/12M11 to Markham Nort a. The feeders are planned to	
			Ave/major ma	ck area to supply new growth i	n Markham North.	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2017			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk M	lanagement	Hwy 7 widenin South Towncer	g from South Towncenter Blvd hter Blvd to Warden Ave. Capi the approvals in place in time	to Warden Ave project to exte tal Design has started the design	end 12M10/12M11 from gn of the project in advance
	Comparative Information on Ed Historical Projects (if any)	quivalent	Not Applicable			
	Total Capital and OM&A Costs f Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary			o add two ccts on Warden Ave 4 ccts on the east side of War		Dr by rebuilding the existing
	1a. Main Driver		North. Based of	ty Delivery. The main driver for on preliminary information from are required for the Hwy 404	m Markham Official Plan Amer	
	1b. Priority and Reasons for Prio	ority	High. The exist load growth.	ing feeders supplying Markhar	n north don't have sufficient c	apacity to provide for future
	1c. Qualitative and Quantitative Project and Project Alternatives		This project wil north.	l increase supply capacity by 4	0 MVA and will also increase s	upply reliability to Markham
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabilit	ty	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Projec in terms of Cost Impact, where		Not Applicable			
	Regional Electricity Infrastructu Requirements which affect Proj applicable		Not Applicable			
	Description of Incorporation of Technology, if applicable	Advanced	Not Applicable			
	Identify any reliability , efficient coordination benefits					
	Factors Affecting Timing/Priorit			d ramping up schedule in Mark		
	Analysis of Project Benefits and Alternative Comparison, includi Nothing" Alternative (including factors if applicable)	ing "Do-	alternative is to	o "do nothing". However, that	alternative is not a viable opt	

			Project Code		Report Star	t Year	Numbe	er of Years		Scale	
Power Stream	5		100	229		2015		6		D	ollars
Project Summary	Report		Project Name <u>Rebui</u>	ld 27.6 kV	pole line c	on Warden /	Ave into	4 ccts fro	om 16th /	Ave to Majo	or Mack
xpenditures Historical/Planned	<b>2011</b> \$ -	2012	2013 \$ -	<b>2014</b> \$ -	<b>2015</b>	2016		017	2018	2019	2020
	\$ -	\$ -	Ş -	Ş -	Ş -	- \$	- \$ 2,0	50,441 \$	-	\$ -	\$
	\$2,000, \$2,000, \$1,500,	000									
	\$1,000,	000									
	\$500,	000									

	Pro	ject Code		Report Start Year	Number of Years	Scale
Power	<u> </u>	101499		2015	6	Dollars
Siream	Pro	ject Name				
Project Summar			Pole L	ine on 14th Ave into 4	cct -From Warden Ave	to Kennedy Rd
Major Category Project Overview	System Service					
1. Additional Information	Service Territory		Stream S			
	Location Scope	This pı the de	roject is t sign if a ı		om Warden Ave to Kennedy Ro talled on the north side of 14t	d. It will be determined during h Ave instead of rebuilding the
	Justification	going	to extend		apacity and reliability to the su ea between Warden Ave and I	bject area. This project is Kennedy Rd. This will increase
		There from t pole fa not sp north	are a few he same ailures or are them side of 14	big customers along 14th Av pole line on the south side of 14th Ave and the auto transf from power outages. This pro-	14th Ave. The customers will I er scheme on the secondary si oject will enable customers to Il not cause outages to these c	eir facilities; however, they are ose both supplies in case of de of their transformers will
2. General Project Information (OEB)	Contributed Capital	Contri	buted Ca	pital 0%		
	Fiscal Year	2017				
	Parent WO#					
3. General Information on the	Job Number Risks to Completion and Risk Ma	nagement The ris	sk is to ge	et approval from the City of M	arkham in time. Capital design	has started the design of the
Project/Activity (OEB)				ould get the approvals in place		Ũ
	Comparative Information on Equination on Equination Equination (1997) Automatical Projects (if any)	uivalent Not Ap	oplicable.			
	Total Capital and OM&A Costs fo Renewable Energy Generation p Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary	existin	-	ne on the south side of 14th A	een Warden Ave and Kennedy ve from 2 ccts to 4 ccts or buil	Rd either by rebuilding the d a new 2 ccts pole line on the
	1a. Main Driver	Markh	iam area		or the project is to support the It was also increase supply re	
	1b. Priority and Reasons for Prio	ultima initial	te load w load will	vill be 7 MW by 2018. Anothe	ll be 10 MW by 2020. The exis	e will be in service in 2015. The
		supply	diversity		ations, and from pole lines on	nat customers in the area have different sides of road to
	1c. Qualitative and Quantitative Project and Project Alternatives	be 26N signific mainta	V12 and cantly im ained eve	26M4 in 2014. 26M12 will be prove power supply diversity		5 from MTS4. This project will upply to customers will be
	2. Safety	Not Ap	oplicable.			
	3. Cyber-Security, Privacy		oplicable.			
	4. Coordination, Interoperability		oplicable.			
	5. Economic Development 6. Environmental Benefits		oplicable. oplicable.			
5. Category-Specific Requirements for	Benefits to Customers of Project	Expressed Not Ap				
Each Project/Activity (OEB)	in terms of Cost Impact, where p	racticable				
						Dev

			Project Code		Report Star	t Year	Number of Yea	rs	Scale	
Power Stream			10	1499		2015	6	5	Do	ollars
	ĥ		Project Name							
Project Summary	Report		<u>Re</u>	ebuild Pole	Line on 14	4th Ave into 4	cct -From W	arden Ave	to Kennedy	<u>/ Rd</u>
	coordination be Factors Affectin	which affect P ncorporation applicable iability , effici enefits ng Timing/Pric ect Benefits a nparison, incl native (includi	Project, if of Advanced ency, safety of prity and Costs with uding "Do-	Customers lo The main ber subject area. path from Po The main alte	e. /ill also provid ad ramping u lefit of this pr In addition, so werStream.	de supply reliabilit p schedule will im oject of this proje ome existing custo s project is to "do	pact the timing a ct is to provide a omers along 14th nothing", howey	nd priority. dditional load Ave already r	capacity of 40 I equested alterr	nate supply
	2011	2012	2013	allow PowerS	tream to sup 2015	ply the new load g	rowth. <b>2017</b>	2018	2019	202
enditures Historical/Planned	\$ - \$		\$ -	\$ -	\$ -	- \$ -	\$ 1,206,790		\$ -	\$
	\$1,400,000									
	\$1,000,000									
	\$600,000	,								
	\$400,000	-								
	\$200,000	)								

	Project Co	de	Report Start Year	Number of Years	Scale
Power	5	102547	2015	6	Dollars
Sileuin	Project Na	me			
Project Summar			wo Ccts on Birchmount	Rd from ROW to 14th	Ave
Major Category Project Overview	System Service				
1. Additional Information	Service Territory	PowerStream	South		
	Location		nt Rd from ROW to 14th Ave in		
	Scope		s from Hydro One Right of Way o feeders 26M15 and 26M16 or		area
	Justification		driver for this investment is to ir		
		existing feede there are man they are on th supplies in ca transformers historically be Ave to Kenne on 14th Ave f	enter projects are underway and ers don't have sufficient capacity ny industrial customers along 14 ne same pole line on the south s se of pole failures on 14th Ave a does not prevent them from po een poor. A new pole line has be dy Rd. The three feeders from N from Warden Ave is on the same th Ave fails, it will take the three the area.	y for the new load and new fee Ith Ave that have two supplies side of 14th Ave. Those custom and the auto transfer scheme of wer outages. Reliability for the een proposed on the north side ATS3 (26M13, 26M15, and 26M e pole line, if a pole on Warder	eders are required. In addition to their facilities; however, hers in that area lose both on the secondary side of their e feeders in this area has e of 14th Ave from Warden A16) that supplies customers in Ave between the right of way
2. General Project Information (OEB)	Contributed Capital	Contributed (	Capital 0%		
	Fiscal Year	2020			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managem		get approval from the City of M vance and should get the approv		n will start the design of the
	Comparative Information on Equivalen Historical Projects (if any)	t Not Applicabl	e.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion Projects (if any)	0 of			
4. Evaluation Criteria (OEB)	Project Summary		to build 2 ccts pole line on Birc feeders 26M15 and 26M16 to 1		
	1a. Main Driver		city Delivery. The main driver f ery in Markham Warden-Denise		eliability and support the
	1b. Priority and Reasons for Priority	ultimate load	ata center at 371 Gough Rd has will be 7 MW by 2018. Anothe Il be 5MW and the ultimate loa	er data center at 4175-14th Ave	
	1c. Qualitative and Quantitative Analys Project and Project Alternatives		vill extend two feeders 26M15 a upply diversity and reliability to		Sirchmount area. This project
	2. Safety	Not Applicabl	e.		
	3. Cyber-Security, Privacy	Not Applicabl			
	4. Coordination, Interoperability	Not Applicabl	e.		
	5. Economic Development	Not Applicabl			
	6. Environmental Benefits	Not Applicabl			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Project Expres in terms of Cost Impact, where practica		e.		
	Regional Electricity Infrastructure Requirements which affect Project, if applicable	Not Applicabl	e.		
	Description of Incorporation of Advance Technology, if applicable	ed Not Applicabl	e.		
	Identify any reliability , efficiency, safet coordination benefits	This project w	vill also provide supply reliability vill also provide an alternate sup d in case of pole failures on the	oply path for the existing custo	-
					Pg

			Project Code		Report Start	<b>Year</b>	Number of Yea	rs	Scale	
Power Stream	5		10	2547	2	015	é	i		Dollars
Project Summary	Report		Project Name		vo Ccts on	Birchmount	Rd from RO	W to 14th A	<u>\ve</u>	
	Factors Affectin	ng Timing/Pric	ority		nificant additio	schedule will imponal electrical lo	-			
	Alternative Con Nothing" Altern factors if applic	nparison, incl native (includ	uding "Do-	impact Powers Capacity A few data cer existing feede The "do nothin The impact ser Reliability There are two customers wit currently supp main supplies	Stream distributer projects and the projects and the second the second terms of term	o nothing" and c ution system in t re underway and ufficient capacit vill reduce Powe ng will depend c uth side of 14th ty needs on both sting two ccts or len Ave. There h	wo following asy I the peak dema y for the new loa rStream's ability n the schedule o Ave between W I sides of 14th Av I 14th Ave. Thes nave been pole I	pects: and is expected and and new fee to supply new of the ramping- arden Ave and we between Wa e two ccts are o ne failure incid	to increase ders are req customers up of custor Kennedy. A arden Ave ar on the same dents in the	by 20MVA. The uired. along 14th Ave. ners on 14th Ave. number of nd Kennedy Rd pole line and t
						werStream to pro				do nothing" ay to customers
	2011	2012	2013	alternative wil						-
xpenditures Historical/Planned	<b>2011</b> \$ - \$	2012	<b>2013</b> \$ -	alternative wil the area.	ll not allow Pov	werStream to pro	ovide the high re	liability and su	ipply diversi	to customers
penditures Historical/Planned	2011 \$ - \$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$600,000 \$400,000 \$200,000		2013 \$ -	alternative wil the area.	ll not allow Pov	verStream to pro	2017	liability and su	2019	zozo

	Pi	roject Code		Report Start Year	Number of Years	Scale
Power	5	102	2548	2015	6	Dollars
Sneum	Pi	roject Name				
Project Summar			Two	o Ccts on Birchmount F	Rd from ROW to Enterp	rise
	[					
Major Category Project Overview	System Service					
1. Additional Information	Service Territory		PowerStream S	South		
	Location			from ROW to Enterprise in Ma		
	Scope		To extend two Install two swit	feeders 26M17 and 26M18 alc chgears at the end of 1000 M0	(ROW) underground to Enterp ong Birchmount Rd to Downtov CM Cu cable so that new 1/0 lo ar requirement with Subdivisio	wn Markham area. ops can be created from
	Justification		This project is r	necessary to increase supply ca	pacity and reliability to downt	own Markham
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2015			
	Parent WO#					
3. General Information on the	Job Number Risks to Completion and Risk N	lanagement	This project will	luse existing ductbanks on Dir	chmount Rd. The existing one	may not meet PowerStroam's
Project/Activity (OEB)		nanagement		ductbanks will be installed if	-	may not meet rowerstreams
	Comparative Information on E Historical Projects (if any)	Equivalent			Center (VMC) has been design ment and 1/0 loops will used t	
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		Birchmount Rd	to Enterprise Blvd to provide	26M18 from Hydro One right o supply capacity to downtown I d south of Enterprise to supply	Markham. Two 27.6kV
	1a. Main Driver		Support Capaci area.	ty Delivery. The main driver fo	or this project is to support cap	bacity delivery in the Markham
			Downtown Ma both located of and large numl	rkham(30MW). New capacity i n Warden Ave. If a pole is hit b per of residential and commen ne pole is replaced. Alternate s	ficient capacity to supply futur s required. The two pole riser y a vehicle or a pole on file wil cial customers in downtown M upply path is required to redu	s for the existing 1/0 loop are I cause outage to the 1/0 loop arkham will have prolonged
	1b. Priority and Reasons for Pr	iority	350,000 sq.ft o existing loop.	ffice building now under const There are total of 10 MVA con	action and additional capacity i ruction, and it is expected to a nected transformers on the ex ged outages to the customers	dd 2500 kW load to the isting loop. Pole failure on
	1c. Qualitative and Quantitativ Project and Project Alternative		reliability since		existing 1/0 loop. Taking supp	
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabili	ty	Not Applicable			
	5. Economic Development 6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Proje in terms of Cost Impact, where		Not Applicable Not Applicable			
	Regional Electricity Infrastructo Requirements which affect Pro applicable		Not Applicable			
						Pg

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		102	2548	20	15		6	Do	llars
			Project Name							
Project Summary	Report			<u>Tw</u>	vo Ccts on B	irchmount F	Rd from RO	W to Enterp	<u>orise</u>	
	Description of I Technology, if a Identify any reli	pplicable								
	coordination be		iency, salety of							
	Factors Affectin Analysis of Proje			-	stomer projects					
	Alternative Con Nothing" Altern factors if applic	nparison, incl native (includi	luding "Do-	also increases from another nothing" and is not a viable	supply reliability	since it is a diff feasible option. bly existing and I not allow Pow	erent route tha The ma new loads fron	an the existing a nin alternative to n existing distri	1/0 loop. Provie to this project is bution circuits.	ding a supp to "do However,
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
enditures Historical/Planned	<b>2011</b> \$ - \$	2012	<b>2013</b> \$ -	<b>2014</b> \$ -	<b>2015</b> \$ 1,201,150		<b>2017</b> \$ -	<b>2018</b> \$ -	<b>2019</b> \$ -	<b>2020</b> \$
enditures Historical/Planned		-	<b>2013</b> \$ -							
enditures Historical/Planned	\$ - \$	-	<b>2013</b> \$ -							
enditures Historical/Planned	\$ - \$	-	<b>2013</b> \$ -							
enditures Historical/Planned	\$ - \$ \$1,400,000 \$1,200,000	-	<b>2013</b> \$ -							
enditures Historical/Planned	\$ - \$ \$1,400,000 \$1,200,000 \$1,000,000	- ) )	<b>2013</b> \$ -							
penditures Historical/Planned	\$ - \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000	- )	<b>2013</b> \$ -							
enditures Historical/Planned	\$ - \$ \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000	- ) - ,	<b>2013</b> \$ -							

Fiscal Year       2017         Parent WO#       Job Number         3. General Information on the       Risks to Completion and Risk Management         Project/Activity (OEB)       Risks to Completion and Risk Management         Comparative Information on Equivalent       Historical Projects (if any)         Total Capital and OM&A Costs for       0         Projects (if any)       0		Project Cod	le	Report Start Year	Number of Years	Scale
Project Summary Legort         Valuation TS44 Ecoder Integration - Part 1           Number Congregory         System Sanda           Project Ownwise	Power Stream	-	100336	2015	6	Dollars
Project Summary Legort         Valuation TS44 Ecoder Integration - Part 1           Number Congregory         System Sanda           Project Ownwise	Sircum	Project Nar	me			
Project Overview     Server Territory     Preversioner South       L additional Information     Server Territory     On Kinsy from TS Kinging Ave to Wetch Ridin Valuption - approx 4 km on Vectorin Rid Form King Valid to Tesore Kins King Valid To Tesore King Kinging Ave to Wetch Ridin Valuption - approx 4 km on Vectorin Rid Form King Valid To Tesore King Kinging Ave to Wetch Ridin Valuption - Adving Ave 112 Wester Riding	Project Summa	-		Vaughan TS#4 Feed	ler Integration - Part 1	
Project Overview     Server Territory     Preversioner South       L additional Information     Server Territory     On Kinsy from TS Kinging Ave to Wetch Ridin Valuption - approx 4 km on Vectorin Rid Form King Valid to Tesore Kins King Valid To Tesore King Kinging Ave to Wetch Ridin Valuption - approx 4 km on Vectorin Rid Form King Valid To Tesore King Kinging Ave to Wetch Ridin Valuption - Adving Ave 112 Wester Riding	Maior Category	System Service				
2. defering Information       Societ       Freedings and the second of a single avery to weeters of in single avery to weeters of in single avery to weeters of in single avery to weeter in single avery single aveeter in single avery single avery to weeter						
1. backson     On Gröger more T44 (Egling Ave) to Meson B41 in Wagher - argenz 4. Im enviewend P41 methods Misagher - argenz 4. Im enviewend P41 methods Set (Magher - argenz 4. Im enviewed P41 methods Set (Magher - Argenz 4. Impertance)       2. beneral Project Information of B1     Database set (Magher - argenz 4. Im enviewed P41 methods Set (Magher - argenz 4. Impertance)       2. beneral Project Information of B1     Database set (Magher - argenz 4. Impertance)       3. beneral Project Information of B1     Database set (Magher - argenz 4. Impertance)       4. beaks and pathoger Argenz 4. Impertance     Database set (Magher - argenz 4. Impertance)       5. beneral Project Information of B1     Database set (Magher - argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Impertance     Database set (Magher - argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Impertance     Database set (Magher - argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Impertance     Database set (Magher - argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Impertance     Database set (Magher Argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Impertance     Database set (Magher Argenz 4. Impertance)       5. beaks and pathoger Argenz 4. Imperance     Database set (Magher Argenz 4. Impertance)		Service Territory	PowerStream	South		
2. General Project Information (Giff)     Commutated Capital     Subject State			On Kirby fron	n TS4 (Kipling Ave) to Weston Re		
Part lare: - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the new VTS4 into Power-Stream's distribution system. - 10 integrate federals from the New VTS4 into Power-Stream's distribution system. - 10 integrate federals from the New VTS4 into Power-Stream's distribution system. - 10 integrate federals from the New VTS4 into Power-Stream's distribution system. - 10 integrate federals from VTS4 into Power-Stream's distribution system. - 10 integrate federals from VTS4 into Power-Stream's distribution system. - 10 integrate federals from VTS4 into Power-Stream's distribution system. - 10 integrate federals from VTS4 into Power-Stream's distribution system. - 10 integrate federals from VTS4 into Power-Stream's distribution system. - 10 integrate f		Scope	<ul><li>build 4 ccts</li><li>build 4 ccts</li></ul>	pole line on Kirby from VTS4 (K pole line on Weston Rd from Ki	rby Sdrd to Teston Rd - 2 km	
Fiscal Year       2017         Parent WO#       Job Number         3. General Information on the       Risks to Completion and Risk Management         Project/Activity (OEB)       Risks to Completion and Risk Management         Comparative Information on Equivalent       He risk is to get approval from the City of Vaughan and York Region in time. Capital design will start the design of the project in advance and should get the approvals in place in time.         Comparative Information on Equivalent       Not Applicable.         Historical Projects (if any)       Not Applicable.         Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         4. Evaluation Criteria (OEB)       Project Summary       This project is to build 4 feeders from Vaughan TS#4 to the distribution system. It is Vaughan TS4 Feedel Integration Plan Part 1. It includes: <ul> <li>build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km.</li> <li>build 4 ccts pole line on Kirby from Kirby Sdrd to Teston Rd - 2 km.</li> <li>install manual or Scada-mate switches as necessary to meet PowerStream's design standards.</li> </ul> 1a. Main Driver       Support Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and Comparison of the project is to support the capacity delivery on York region.		Justification	Part 1 are: -To integrate -To increases -To off load W -To increases The major de <u>West Vaugha</u> The West Vau opportunity f accommodat be 50MW to of this develo TS and they of transfer from <u>Hwy 400 Nor</u> The lands of I Vaughan bout to the west a (2,000 acres). built out, butt <u>Vaughan Mer</u> It establishes estimates fro to 80 MW. <u>Vaughan New</u> The Mackenz north side of	4 feeders from the new VTS4 in supply capacity to Vaughan nort TS2,VTS1, RH-TS1 and RH-TS2. Supply reliability to Vaughan and velopments in the area that are <b>in Employment Area</b> ughan Employment Area Second for York Region. With over 500 h e approximately 20,120 employ 80 MW when fully built out, but opment and Kleinburg TS is near an supply up to 40 MVA load. V VTS3 to VTS4 is required to allo <b>th Future Development Areas</b> Hwy 400 North Development ar nded by Teston Road to the sound Jane Street to the east. The a The peak demand for this deve no time line is available at this <b>tro Center (VMC)</b> growth targets for the VMC of a m one of the consultants for the <b>V Hospital</b> ie Vaughan Hospital Precinct Pla Major Mackenzie Drive betwee	to Power-Stream's distributio th and Richmond Hill North. d Richmond Hill. e intended to be supplied by the dary Plan sets out detailed pol nectares of employment design ees. The peak demand for this t no time line is available at th by too. PowerStream has two TS3 has approx. 10 MVA capa- bow VTS3 to supply new load in e located adjacent to Highway uth, the King-Vaughan bounda area of the subject lands is app lopment is estimated to be 80 time. 12,000 residential units and 6, e VMC, the peak demand for t an has an area of 32.8 ha (82 a n Highway 400 and Jane Stree	n system. his project include: icies to create a large economic nated lands, it is planned to is development is estimated to is time. VTS3 is in the center 27.6kV feeders from Kleinburg city left as of 2014 and load Vaughan West area. v 400 within the City of ry to the north, Weston Road proximately 800 hectares MW to 100 MW when fully 500 new jobs by 2031. As per he VMC will be approx. 60MW acres) and is located on the
Parent WO# Job NumberParent WO# Job Number3. General Information on the Project/Activity (OEB)Risks to Completion and Risk ManagementThe risk is to get approval from the City of Vaughan and York Region in time. Capital design will start the design of the project in advance and should get the approvals in place in time.Project/Activity (OEB)Comparative Information on Equivalent Historical Projects (if any)Not Applicable.4. Evaluation Criteria (OEB)Total Capital and OM&A Costs for Project Summary04. Evaluation Criteria (OEB)Project SummaryThis project is to build 4 feeders from Vaughan TS#4 to the distribution system. It is Vaughan TS4 Feed Integration Plan Part 1. It includes: - build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km. - build 4 ccts pole line on Weston Rd from Kirby Sdrd to Teston Rd - 2 km. - install manual or Scada-mate switches as necessary to meet PowerStream's design standards.1a. Main DriverSupport Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and	2. General Project Information (OEB)	Contributed Capital	Contributed (	Capital 0%		
3. General Information on the Project/Activity (OEB)       Risks to Completion and Risk Management Comparative Information on Equivalent Historical Projects (if any)       The risk is to get approval from the City of Vaughan and York Region in time. Capital design will start the design of the project in advance and should get the approvals in place in time.         4. Evaluation Criteria (OEB)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         4. Evaluation Criteria (OEB)       Project Summary       This project is to build 4 feeders from Vaughan TS#4 to the distribution system. It is Vaughan TS4 Feede Integration Plan Part 1. It includes: - build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km. - build 4 ccts pole line on Weston Rd from Kirby Sdrd to Teston Rd - 2 km. - install manual or Scada-mate switches as necessary to meet PowerStream's design standards.         1a. Main Driver       Support Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and		Parent WO#	2017			
Historical Projects (if any)       Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         4. Evaluation Criteria (OEB)       Project Summary       This project is to build 4 feeders from Vaughan TS#4 to the distribution system. It is Vaughan TS4 Feeder Integration Plan Part 1. It includes: - build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km. - build 4 ccts pole line on Weston Rd from Kirby Sdrd to Teston Rd - 2 km. - install manual or Scada-mate switches as necessary to meet PowerStream's design standards.         1a. Main Driver       Support Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and	3. General Information on the Project/Activity (OEB)					
Renewable Energy Generation portion of Projects (if any)4. Evaluation Criteria (OEB)Project SummaryThis project is to build 4 feeders from Vaughan TS#4 to the distribution system. It is Vaughan TS4 Feeder Integration Plan Part 1. It includes: - build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km. - build 4 ccts pole line on Weston Rd from Kirby Sdrd to Teston Rd - 2 km. - install manual or Scada-mate switches as necessary to meet PowerStream's design standards.1a. Main DriverSupport Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and			Not Applicab	le.		
Integration Plan Part 1. It includes: - build 4 ccts pole line on Kirby from TS4 (Kipling Ave) to Weston Rd - 4 km. - build 4 ccts pole line on Weston Rd from Kirby Sdrd to Teston Rd - 2 km. - install manual or Scada-mate switches as necessary to meet PowerStream's design standards.1a. Main DriverSupport Capacity Delivery. The main driver for this project is to support the capacity delivery in York region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and		Renewable Energy Generation portion o Projects (if any)	of			
region. Load growth in the Maple area, new hospital development, Vaughan Metropolitan Center and	4. Evaluation Criteria (OEB)	Project Summary	Integration P - build 4 ccts - build 4 ccts	lan Part 1. It includes: pole line on Kirby from TS4 (Kip pole line on Weston Rd from Kin	ling Ave) to Weston Rd - 4 km rby Sdrd to Teston Rd - 2 km.	
		1a. Main Driver	region. Load	growth in the Maple area, new		

	Proj	ject Code		Report Start Year	Number of Years	Scale
Power Stream	-	10033	6	2015	6	Dollars
	Proj	ject Name				
Project Summar	y Report			Vaughan TS#4 Feed	ler Integration - Part 1	
	1b. Priority and Reasons for Prior			existing feeders are at their ca ow voltage issue during summ		
	1c. Qualitative and Quantitative A Project and Project Alternatives	M V sc	IVA. This pr TS4 will be su ome custome	necessary to extend four feede roject will also significantly imp pplied from 230kV Minden Lir rs will be maintained even the or viable way to supply the ne	prove power supply diversity ne. No existing stations are fro Parkway transmission lines a	to the customers in the area. om the Minden Line. Supply
	2. Safety	N	ot Applicable			
	3. Cyber-Security, Privacy	N	ot Applicable			
	4. Coordination, Interoperability	N	ot Applicable			
	5. Economic Development	N	ot Applicable			
	6. Environmental Benefits	N	ot Applicable			
Category-Specific Requirements for ach Project/Activity (OEB)	Benefits to Customers of Project in terms of Cost Impact, where p		ot Applicable			
	Regional Electricity Infrastructure Requirements which affect Proje applicable		ot Applicable			
	Description of Incorporation of A Technology, if applicable	Advanced N	ot Applicable			
	Identify any reliability , efficiency coordination benefits		his project wil n the existing		to existing customers in Va	ughan. It will reduce line lo
	Factors Affecting Timing/Priority		ustomers load riority.	d ramping up schedule in VMC	and other areas in Vaughan	will impact the timing and
	Analysis of Project Benefits and C Alternative Comparison, includin Nothing" Alternative (including q factors if applicable)	ng "Do- Th qualitative in	he main alteri	native is to "do nothing" and o	continue to supply load growt	
		D 50 51 20 20	ufferin St and 20A in the sur 12A on 20M2 20M22 has 4,0	e-east area is supplied by two f I Center St. Feeder 20M22 is 1 mmer and exceeded PowerStr 2. In terms of the number of 05 customers. There are no ot t. Therefore, new feeders are	8.5km and 20M21 is 14km. Bo eam's feeder loading guide lin customers, feeder 20M21 has her existing feeders available	oth feeders had a peak of o ne of 400A: 547A on 20M21 s 9,761 customers in 2014 a in the area to off load
		Va its Va	aughan north s 10 day Limit aughan New I	is supplied by VTS1/VTS1E. The ced Time Rating (LTR) of 306 M Hospital development (approv native to "do nothing" will cau	IW. It does not have extra cap 10MW).	pacity to supply new loads
		10 OI	0 weather (ex	treme summer temperatures) nt in Vaughan north and the se	in the long term. The impact	severity and timing will de
		-	he "do nothin	g" approach is not a viable op	tion as it will not allow Bowo	

			Project Code		Report Start	Year	Number of Ye	ars	Scale	
Power Stream	5		100	)336		2015		6	D	ollars
Project Summary Report			Project Name		<u>Vaugha</u>	<u>n TS#4 Fee</u>	der Integrati	<u>on - Part 1</u>		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ -	\$ -	\$ -	\$ -	\$-	\$ -	\$ 7,341,955	\$ -	\$ -	\$
	\$8,000,0 \$7,000,0 \$6,000,0 \$5,000,0 \$4,000,0 \$3,000,0 \$2,000,0 \$1,000,0	000 000 000								

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		102	2352	2015	6	Dollars
		Project Name				
Project Summa		,		Vaughan TS#4 Feed	er Integration - Part 2	
Major Category	System Service					
Project Overview						
1. Additional Information	Service Territory		PowerStream S	South		
	Location		North-west cor	ner of Kipling & Kirby, Vaugha	n	
	Scope		and Vaughan V	his project is to build 2 feeders Vest areas. It includes following I cct on Kirby Sdrd from VTS4 t le line to 4 ccts.	g constructions:	acity and backup to Kleinburg - Rebuilc
	Justification			necessary to provide supply ne ty to VTS3 and Kleinburg TS	eded load capacity to Vaughar	n west area, and to provide
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	pital 0%		
	Fiscal Year		2018			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk	Management	-	et approval from the City of Va nce and should get the approv		will start the design of the
	Comparative Information on Historical Projects (if any)	Equivalent	Not Applicable			
	Total Capital and OM&A Cost Renewable Energy Generatio Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		West areas. It i -One additiona	II build 2 feeders 25M11/25M: ncludes following construction I cct on Kirby Sdrd from VTS4 t I cct on Hwy 27 from Teston Re	s: o Hwy 27 – 2 km	kup to Kleinburg and Vaughar
	1a. Main Driver		Support Capaci area. This will	ity Delivery. The main driver for provide needed capacity to m onal backup for VTS3 and Klein	or investment is to support cap eet the load growth in the Vau	
	1b. Priority and Reasons for P	Priority	High. All existi	ng feeders are at their capacity	and have no capacity for futu	re development.
	1c. Qualitative and Quantitati Project and Project Alternativ		also significant supplied from 2 provide the ad	ll extend four feeders into the ly improve power supply diver 230kV Minden Line. No existing ditional benefits to allow supp smission lines are out of service	sity to the customers in the Va g stations are from the Minder ly to some customers to be ma	ughan west area. VTS4 will be n Line. This project will
	2 Safaty		Not Applicable			
	2. Safety 2. Cuber Security, Brivacy		Not Applicable			
	3. Cyber-Security, Privacy	lity	Not Applicable			
	4. Coordination, Interoperabi	nty	Not Applicable			
	<ol> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> </ol>		Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Proj in terms of Cost Impact, when					
	Regional Electricity Infrastruc Requirements which affect Pr applicable		Not Applicable			
	Description of Incorporation Technology, if applicable	of Advanced	Not Applicable			
	Identify any reliability , efficie coordination benefits	ency, safety or	This project wil losses on the e	ll also improve supply reliabilit xisting feeders.	y to existing customers in Vau	ghan West. It will reduce line
	Factors Affecting Timing/Prio	rity	Customers load	d ramping up schedule will imp	act the timing and priority.	
	Alternative Comparison, inclu	iding "Do-	options have b The main alter	fits of this project is to increase een explored, but none are ec native to this project is to "do i ircuits. However, this is not a	onomically viable or practical. nothing" and continue to supp	ly the existing and new loads
			supply the new	load growth forecasted for th	at area.	Pg

			Project Code		Report Sta	rt Year		Number of Yea	ars	Scale	
Power Stream			102	2352		2015			6	D	ollars
		Project Name		<u>Vaugh</u>	an TS#4	Feed	er Integratio	<u>on - Part 2</u>			
	2011	2012	2013	2014	2015	201	16	2017	2018	2019	2020
Expenditures Historical/Planned	\$ - 5	\$-	\$ -	\$ -	\$	- \$	-	\$-	\$ 3,176,402	\$-	\$ -
	\$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000 \$1,500,000 \$1,000,000 \$500,000	0 0 0									
	\$-		2012	2013	2014	2015	2010	5 2017	2018	2019	2020

	Pro	oject Code		Report Start Year	Number of Years	Scale
Power Stream		100	340	2015	6	Dollars
oncum	Pro	oject Name				
Project Summar				Vaughan TS#4 Feed	er Integration - Part 3	
,	<i>,</i> .					
Major Category	System Service					
Project Overview	а. т. т. н.		<b>D</b>			
1. Additional Information	Service Territory Location		PowerStream S Vaughan	South		
	Scope		-	ope includes following construc	ctions:	
				le line from VTS4 to Teston Rd		km
				le line on Teston Rd from Kipli e line on Teston Rd from Pine '	-	
			– 2 km			
				le line on Pine Valley Drive from on existing pole line on MMD f		
			-	on existing pole line on Teston		
			-Adding 2 ccts to Rutherford I	on existing pole line or rebuild Rd – 2km	pole into 4 ccts where necessa	ary on Weston Rd from MMD
	Justification			necessary to integrate VTS4 fe		
				y to Vaughan north and Richmo y reliability to Vaughan and Ric		I, RH-TS1 and RH-TS2, and to
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2019			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Ma	anagement	-	et approval from the City of Va ince and should get the approv	• • •	will start the design of the
	Comparative Information on Ec Historical Projects (if any)	quivalent	Not Applicable			
	Total Capital and OM&A Costs f Renewable Energy Generation p		0			
4. Evaluation Criteria (OEB)	Projects (if any) Project Summary			necessary to bring four 27.6kV ne distribution system.	feeders 25M5/25M6/25M7/25	5M8) out from VTS4 and
	1a. Main Driver		Support Capac	ity Delivery. The main driver fo	or this project is to support cap	pacity delivery in the Vaughan
	1b. Priority and Reasons for Pric	ority	area. Very High. All	existing feeders are at their ca	pacity and have no capacity for	r future development. Some
			existing feeder distance.	s have low voltage issue during	g summer peak time due to hig	gh loading and long supply
	1c. Qualitative and Quantitative	e Analysis of	This project wi	ll extend four feeders into the	area and increase capacity by	80 MVA. This project will also
	Project and Project Alternatives		significantly im	prove power supply diversity t	to the customers in the area. V	TS4 will be supplied from
				transmission line. None of Pownssion line. This will allow sup		
				mission lines are out of service.		
	2 Safety		Not Applicable			
	<ol> <li>Safety</li> <li>Cyber-Security, Privacy</li> </ol>		Not Applicable Not Applicable			
	4. Coordination, Interoperability	y	Not Applicable			
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Projec in terms of Cost Impact, where		Not Applicable			
	Regional Electricity Infrastructur Requirements which affect Proj applicable		Not Applicable			
	Description of Incorporation of Technology, if applicable	Advanced	Not Applicable			
	Identify any reliability, efficienc coordination benefits	cy, safety or	This project wi on the existing		y to existing customers in Vaug	ghan. It will reduce line losses
			0			Pa

			Project Code		Report Start	Year	Number of Yea	rs	Scale	
Power Stream	5		10	0340	2	2015		5	Do	lars
			Project Name					_		
Project Summary	Report				Vaughar	n TS#4 Feed	er Integratio	<u>on - Part 3</u>		
	Alternative Co	oject Benefits omparison, in rnative (inclu	and Costs with	priority. The main bene load capacity b The main alter from existing o	efits of this pro by 80 MVA. mative to this p distribution fac	schedule in VMC oject will be to ex project is to "do cilities. However upply the new loa	tend four feede nothing" and co , the "do nothin	rs into the sub ntinue to supp g" alternative i	ject area and in ly existing and r s not a viable op	crease nee
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
enditures Historical/Planned	\$-	\$ -	\$-	\$ -	\$-	\$-	\$-	\$-	\$ 9,630,000	\$
penditures Historical/Planned	\$ - \$12,000,		\$ -	\$-	\$-	\$ -	\$ -	\$ -	\$ 9,630,000	\$
penditures Historical/Planned		000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,630,000	\$
enditures Historical/Planned	\$12,000,	000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,630,000	\$
enditures Historical/Planned	\$12,000,	000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,630,000	\$
penditures Historical/Planned	\$12,000, \$10,000, \$8,000,	000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,630,000	\$
penditures Historical/Planned	\$12,000,0 \$10,000,0 \$8,000,0 \$6,000,0	000 000 000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,630,000	\$

	Pro	oject Code		Report Start Year	Number of Years	Scale
Power Stream		100632	2	2015	6	Dollars
Project Summar	Prc	oject Name	<u>27.</u> 6	6 kV Pole Line on 14t	h Ave from Hwy 48 to 9	th Line
Major Category	System Service					
Project Overview						
1. Additional Information	Service Territory	Po	werStream	South		
	Location	14	th Ave from	Hwy 48 to 9th Line in Mark	ham, approx. 2km.	
	Scope				our 27.6 kV ccts on 14th Ave be as per PowerStream's design s	tween Hwy 48 and 9th Line, and standard.
	Justification	of	Cornell and	Box Grove both in the shor	supply capacity to Markham ea t and long term. This project w sult of the long and rural feede	
2. General Project Information (OEB)	Contributed Capital	Co	ontributed C	apital 0%		
	Fiscal Year	20	16			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Ma		-	et approval from the City of oprovals should be in place i		sign has started the design of the
	Comparative Information on Eq Historical Projects (if any)	juivalent No	ot Applicable	2.		
	Total Capital and OM&A Costs fo Renewable Energy Generation p Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary	COI	nnect to the		24M6) on 14th Ave from Hwy 4 east of 9th Line so that feeder	8 to 9th Line. 24M3/24M6 will 24M3/24M6 can be rerouted to
		ea: ap tot	st, Hwy 7 to proximately tal load is es	the south, and 9th Line to t 16,000 dwelling units with		l, it will accommodate
		ha	s 2,600 dwe	elling units and will have an a	lopment, is the Box Grove (OP/ additional 10,000 residents whe be fully developed within the r	en completed. This development
		fee	eder integra	tion plan for Markham Tran	e sufficient capacity to supply fi sformer Station Four (MTS4) w apacity for developments in Con	as to reroute two new feeders

	Project Code	Report Start Year	Number of Years	Scale
Power Stream	100632	2015	6	Dollars
Project Summary Report	Project Name <u>2</u>	7.6 kV Pole Line on 14th /	Ave from Hwy 48 to 9th	Line
	cause large area and ar to be suppl In the long beyond the rerouting t This projec step of the new feeder ccts. The project have all the Section 1: I Section 2: I Section 3: n 24M3 and Section 4: I Section 5: I	supplies to Cornell are radial from e scale and prolonged outages to the void blackout situation by supplyin lied from both the east and west. term, 46MW of load is expected in e capacity of the 24M2 and 24M7. wo existing MTS2 feeders (24M3/f t (Extend two 27.6kV circuits 24M2 ultimate supply plan for the Cornel rs 24M3 and 24M6 once pole line of t was first proposed in 2010 and w e sections complete by year 2018. puild 2 feeders overhead on 14th A puild 2 feeders overhead on Reeso re-build existing pole line on 14th A 24M6 from Hwy 48 to 9th Line in 2 puild 2 feeders overhead on Reeso puild 2 feeders overhead on 16th A	he customers. This project will g Cornell from Reesor Rd. The h the Cornell area when it is fu The future incremental capacit M6) via 14th Ave and Reesor Rd 2/24M7 on Reesor Rd from 14t ell area and Box Grove areas. T on 14th Ave between Hwy 48 a as divided into multiple section Ave from 9th Line to Reesor Rd r Rd from 14th Ave to Hwy 7 in Ave into 4 ccts from 9th Line to 1016. r Rd from Hwy 7 Ave to 16th A Ave from 9th Line to Reesor Rd	increase reliability of Cornell se two feeders will allow loads Ily developed. This will be ty needs will be addressed by d. th Ave to Hwy 7) is a interim these two circuits will become and 9th Line is rebuilt into 4 ns. The ultimate plan is to in 2014. n 2015. D Reesor Rd to reroute feeder ave in 2017. d in 2018. This project
1a. Main Driver	reliability. Support Ca reliability. The peaks 24M4 38: 24M5 39: 24M7 340 24M8 138 Feeder 24M 24M7 has e	1A 5A	er for this Investment is to supplied by feeder 24M4, 24 e supplied by feeder 24M4, 24 s and have no extra capacity to s additional 7MW capacity. In	oort capacity delivery and M5, 24M7 and 24M8. o supply new loads. Feeder the long term, 46MW of load
1b. Priority and Reasons for	24M3/24M Markham S Cornell are prolonged blackout si from both Priority High. Insta 1. Address 2. Provide a	by rerouting two existing MTS2 fee 16 will also provide backup in alter Stouffville Hospital and other futur radial from 9th Line, meaning tha outages to the customers. This pro- tuation by supplying Cornell from the east and west. alling two additional 27.6kV circuit the loading issue of Cornell and Bo alternate supply route for Cornell nt with the original Markham TS4	hate route for feeders that sup e high rise buildings in the are t any pole failure on 9th Line v oject will increase reliability of Reesor Rd. These two feeders s on 14th Ave will: ox Grove both in the short and development to increase reliab	pplies Cornell including a. All existing supplies to vill cause large scale and Cornell area and avoid will allow loads to be supplied long term. pility.

	Pi	roject Code		Report Start Year	Number of Years	Scale				
Power Stream	-	100	632	2015	6	Dollars				
	Pi	roject Name								
Project Summar	y Report		27.6 kV Pole Line on 14th Ave from Hwy 48 to 9th Line							
	1c. Qualitative and Quantitative Project and Project Alternative	25	24M5, 24M7 at 24M4 413A 24M5 423A 24M7 372A 24M8 140A Feeders 24M4 (400A). They have redirected to a redirected to a redirected load A significant ne Hospital Comp the expansion Feeder 24M7 s on Reesor Rd b incremental ca addition, feeder urban feeder la To continue to reliability (long drop issues as In summary, th feeder capacity	and 24M8. The peaks of these the and 24M5 are over planning li ave no extra capacity to supply lternate supplies. Feeder 24M I. Feeders 24M4/24M7/24M8 ew load in the Cornell area is the lex expansion is under constru- is complete. upplies customers on the east between Steeles Ave and Majo pacity remaining in the feeder er 24M7 is a rural feeder with a ength average is 10km to 16 km	reeders in July 2013 were: mits and feeder 24M7 is approvention of the second s	roaching the planning limit r planning limits should be upply new load or to take on capacity for future load growth. ion. The Markham Stouffville pected to be 7MW (180A) when y 7 and Steeles Ave, and load of 24M7 was 372A in 2013. The ite future growth in the area. In 40 km. PowerStream's typical d, will result in decreased irmal interruptions) and voltage rove areas after 2015. New 5. Several sections need to be				
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ul> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> <li>4. Coordination, Interoperabilities</li> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> <li>Benefits to Customers of Projetic in terms of Cost Impact, where</li> <li>Regional Electricity Infrastructure</li> <li>Requirements which affect Procapplicable</li> <li>Description of Incorporation of Technology, if applicable</li> <li>Identify any reliability, efficient coordination benefits</li> </ul>	ity ect Expressed e practicable ure bject, if f Advanced ncy, safety or	Not Applicable Not Applicable These two feeo supply reliabili failure on 9th L increase reliab	· · ·	Cornell are radial from 9th Li prolonged outages to the cus plackout situation by supplyir	ne, meaning that any pole tomers. This project will ng Cornell from Reesor Rd.				
	Factors Affecting Timing/Priori		-	r of residential and commercia ted in the years to come.	l projects are under construc	tion now. New customers and				

		Pro	oject Code		Report Start Y	/ear	Number of Year	S	Scale	
Power Stream			100	0632	2	015	6		D	ollars
Project Summar	y Report	Pro	oject Name	<u>27.6</u>	6 kV Pole L	ine on 14th /	Ave from Hw	<u>y 48 to 9th</u>	Line	
	Analysis of Project Alternative Compa Nothing" Alternati factors if applicabl	arison, includii ive (including (	ng "Do-	<ol> <li>Addresses t</li> <li>Provide alter</li> <li>Provide alter</li> <li>The main alter</li> <li>a) Does not m</li> <li>open grid netw</li> <li>b) Negative im</li> <li>developments</li> <li>c) PowerStreat</li> <li>have negative</li> <li>be 30MW.</li> </ol>	the loading issue ernate supply ro rnative is to "do eet short term work philosoph npacts on Powe s will be supplie m will be at risk impacts on ou	e of Cornell and oute for Cornell of o nothing", howe and long term so ry. erStream reliabili ed by a long, rura k of compromisin r corporate repu	Box Grove. development ever that is not vi upply needs of th ty indices since c I feeder 24M7 w ng supply to new tation and missio	te Cornell and sustomers in B ith above aver loads in the N on. The load to	Box Grove de ox Grove and rage exposure Markham east o be impacted	velopments a future area that ma is estimated
				storms, tree c	ontacts, lightni	ng and line hard	ware on feeder 2	4M7 due to it	s nature as a l	n outages due ong rural
	2011	2012	2013	storms, tree c	ontacts, lightni		ware on feeder 2	4M7 due to it	s nature as a l	-
penditures Historical/Planned	2011 \$ - \$	2012 \$	2013	storms, tree co feeder. As load	ontacts, lightnin d in the area gr	ng and line hard	ware on feeder 2 gatively impact S 2017	4M7 due to it AIDI and SAIFI	s nature as a l	ong rural
penditures Historical/Planned	2011 \$ \$ - \$ \$2,500,∪∪		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard rows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural
penditures Historical/Planned	\$ - \$		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard rows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural
penditures Historical/Planned	\$ - \$		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard rows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural
penditures Historical/Planned	\$ - \$ \$2,500,000 \$2,000,000		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard rows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural
penditures Historical/Planned	\$ - \$ \$2,500,000 \$2,000,000 \$1,500,000		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard rows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural
penditures Historical/Planned	\$       -       \$         \$2,500,000       \$2,000,000         \$2,000,000       \$1,500,000         \$1,000,000       \$1,000,000		2013	storms, tree co feeder. As load	ontacts, lightni d in the area gr 2015	ng and line hard ows, this will ne <b>2016</b>	ware on feeder 2 gatively impact S 2017	24M7 due to it AIDI and SAIFI 2018	s nature as a l	ong rural 2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		100	)405	2015	6	Dollars
Project Summar	ry Report	Project Name	<u>27.6</u>	kV Pole Line on Reeso	r Rd from Hwy 7 to 14tl	<u>h Ave</u>
Major Category	System Service					
Project Overview 1. Additional Information	Service Territory Location Scope Justification		To build double To increase sup areas; one of th Reesor Road an	om Hwy 7 to 14th e Circuits on Reesor Rd from H oply capacity and reliability to I ne fastest growing areas in Pov re small capacity 3/0 three Pha	wy 7 to 14th Ave in Markham - Markham East developments o werStream's service territory. Ise feeder. This project will inc ix Grove/Cornell, and improve	f Cornell and Box Grove The existing feeders on rease capacity to those two
2. General Project Information (OEB)	Contributed Capital		Contributed Ca			
3. General Information on the Project/Activity (OEB)	Fiscal Year Parent WO# Job Number Risks to Completion and Ris	k Management	-	et approval from the City of Ma buld get the approvals in place	arkham in time. Capital design in 2015.	has started the design of the
	Comparative Information o Historical Projects (if any) Total Capital and OM&A Co Renewable Energy Generati Projects (if any)	sts for	Not Applicable			
4. Evaluation Criteria (OEB)	Project Summary 1a. Main Driver		to Cornell area Support Capac	ity Delivery. The main driver fo	eesor Rd from 14th Ave to Hwy or this project is to support cap pplied by feeder 24M4, 24M5,	acity delivery in the Markham
			24M4 381A 24M5 391A 24M7 346A 24M8 138A	nese feeders in 2013 were:	s and have no extra capacity to	supply new loads Feeder
			24M7 has extra in order to sup Feeder 24M2 h project will pro	a 2 MW capacity and 24M8 has ply the anticipated future load ad a peak of 150A in 2013. It h	additional 7MW capacity. Ac	dditional feeders are required
				vill also provide backup in alter oital and other future high rise	rnate route for feeder 24M8 th buildings in the area.	at supplies Markham
			cause large sca area and avoid	le and prolonged outages to the	n 9th Line, meaning that any po ne customers. This project will ng Cornell from Reesor Rd. The	increase reliability of Cornell
			beyond the cap	pacity of the 24M2 and 24M7.	n the Cornell area when it is ful The future incremental capacit VI6) via 14th Ave and Reesor Ro	y needs will be addressed by
	1b. Priority and Reasons for	Priority	1. Address the		r Rd will: ox Grove both in the short and development to increase reliab	

	Project Co	de	Report Start Year	Number of Years	Scale
Power Stream	-	100405	2015	6	Dollars
	Project Na	me		•	
Project Summar	y Report	<u>27.</u>	6 kV Pole Line on Reeso	or Rd from Hwy 7 to 14	4th Ave
	1c. Qualitative and Quantitative Analys Project and Project Alternatives	24M4, 24M5, 24M4 413 24M5 423 24M5 423 24M7 372/ 24M8 140A Feeders 24M (400A). They redirected to redirected to redirected to redirected to redirected to redirected to redirected to redirected to feeder 24M7 on Reesor RC incremental addition, fee urban feeder To continue to reliability (loo drop issues a In summary, feeder capac	A 24M7 and 24M8. The peaks of A A A A A A A A A A A A A A A A A A A	these feeders in July 2013 w mits and feeder 24M7 is app y new loads. Existing load ov 8 has additional capacity to 3 combined have only 10 MVA he Markham Hospital expans oction and peak demand is ex- side of 9th Line between Hv r Mack Dr. The peak demand is insufficient to accommod a total trunk feeder length of n. from the 24M7, as configure s customers to higher than ne service the Cornell and Box G powth in the area beyond 2014	vere: proaching the planning limit er planning limits should be supply new load or to take on A capacity for future load growth sion. The Markham Stouffville kpected to be 7MW (180A) when vy 7 and Steeles Ave, and load d of 24M7 was 372A in 2013. The ate future growth in the area. Ir f 40 km. PowerStream's typical ed, will result in decreased ormal interruptions) and voltage Grove areas after 2015. New 4. Several sections need to be
5. Category-Specific Requirements for Each Project/Activity (OEB)	<ul> <li>2. Safety</li> <li>3. Cyber-Security, Privacy</li> <li>4. Coordination, Interoperability</li> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> <li>Benefits to Customers of Project Express in terms of Cost Impact, where practical</li> <li>Regional Electricity Infrastructure Requirements which affect Project, if applicable</li> <li>Description of Incorporation of Advance Technology, if applicable</li> <li>Identify any reliability , efficiency, safet coordination benefits</li> </ul>	ed Not Applicab red Not Applicab y or This project i reliability. Al Line will caus Cornell area	le. le. le. le. le. s to increase supply capacity to l existing supplies to Cornell are	radial from 9th Line, meanir ages to the customers. This p supplying Cornell from Reeso	ng that any pole failure on 9th project will increase reliability of
	Factors Affecting Timing/Priority	-	per of residential and commercia casted in the near future.	al projects are under constru	ction now. New customers and

		F	Project Code		Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			100	0405	20	015		6	Do	llars
		F	Project Name							
Project Summary	Report	-		<u>27.6</u>	kV Pole Lir	<u>ne on Reeso</u>	r Rd from H	lwy 7 to 14th	<u>n Ave</u>	
	Analysis of Proje Alternative Com Nothing" Alterna factors if applica	nparison, inclu ative (includin	ding "Do-	1. Address the 2. Provide alte The only altern a) The status q developments b) Negatively i developments c) PowerStream impacted is est d) Customers v	loading issue of rnate supply ro native to "do no uo does not m and open grid mpacts on Pow will be supplie m will be const timated to be a will be at risk of	of Cornell and Bo bute for Cornell of othing" is not a w eet short term a network philoso verStream reliab d by a long, rura rained to supply	ox Grove both in development viable option fo nd long term so ophy. ility indices sind I feeder 24M7 new loads in th ges, should an o	n the short and or the following upply needs of t ce customers in with above aver he Markham ea butage occur. Th	long term. reasons: the Cornell and Box Grove and rage exposure. st area. The loa tere have been	Box Grove future nd to be outages de
						ows, this will neg				ing rurai
	2011	2012	2013							
enditures Historical/Planned	<b>2011</b> \$			feeder. As load	d in the area gr	ows, this will ne	gatively impact 2017	SAIDI and SAIFI		2020 \$
enditures Historical/Planned	\$	-		feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned		-		feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$1,600,000	)		feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$ \$1,600,000 \$1,400,000			feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$ \$1,600,000 \$1,400,000 \$1,200,000	- ) - 		feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000	- ) - 		feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000			feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020
penditures Historical/Planned	\$ \$1,600,000 \$1,400,000 \$1,200,000 \$1,000,000 \$800,000 \$600,000			feeder. As load	d in the area gr 2015	ows, this will neg 2016	gatively impact 2017	SAIDI and SAIFI	2019	2020

		Project Code		Report Start Year	Number of Years	Scale
Power Stream	<u> </u>	10157	72	2015	6	Dollars
Direan		Project Name			1	
Project Summar	ry Report	Double	Circuit exi	sting 23M8 Circuit fr	om Bayfield & Livingston	e to Little Lake MS.
Major Category	System Service					
Project Overview	Comico Tomitom			1 auto		
1. Additional Information	Service Territory Location		owerStream I arrie	NORTH		
	Scope	TI Li Li st	he project en ivingstone to 3M28. The ne ivingstone to	Cundles & Duckworth (app w circuit will require rebui Cundles, and along Cundle pleted by summer 2019. T	existing 23M21 (formerly 23M8) w rox. 4.5km's) and transferring Lit lding the existing pole line from I s to Little Lake MS. Double circuit ne project includes engineering d	tle Lake MS from 23M21 to Bayfield/Livingstone along ting the 23M21 with the 23M28
	Justification	ol th pr no ex pl tc La	btained from nat a number roposed Cunc ew 20MVA 44 xisting 23M21 lanning limit o o exceed the 6 ake MS from 2	the City of Barrie on propo of commercial developme lles and Little Lake Comme L/13.8kV 4 feeder substatio (formerly 23M8) experier of 400A. Given the propose 500A thermal limit in 2019 23M21 will ensure that the	pacity relief to the existing 23M2 seed developments in the Cundle nts will result in new load growth rcial Developments will total 8.8 on (Little Lake MS#2) is proposed ced a 2013 summer loading of 42 ed developments and new substa Double circuiting the 23M21 wit area can be supplied to accomm nd thermal limits of the 44kV fee	s and Duckworth area indicates that needs to be serviced. The MVA over the next five years. A to be in-service by 2018. The 20A, which exceeded the tion, the 23M21 is forecasted h the 23M28 to offload Little nodate the anticipated load
2. General Project Information (OEB)	Contributed Capital	Ca	ontributed Ca	ipital 0%		
	Fiscal Year Parent WO# Job Number	20	019			
3. General Information on the Project/Activity (OEB)		TI	-		g the required approvals from th cial developments in the area wi	
	Comparative Information or Historical Projects (if any)	n Equivalent So	ome past proj	jects for new circuits have h construction.	taken 6-8 months to obtain the n	ecessary approvals before
	Total Capital and OM&A Cos Renewable Energy Generatio Projects (if any)					
4. Evaluation Criteria (OEB)	Project Summary	Li 2: Li sł	ivingstone to 3M28. The ne ivingstone to	Cundles & Duckworth (app w circuit will require rebui Cundles, and along Cundle pleted by summer 2019. Th	existing 23M21 (formerly 23M8) w rox. 4.5km's) and transferring Lit Iding the existing pole line from I s to Little Lake MS. Double circuit ne project includes engineering d	tle Lake MS from 23M21 to Bayfield/Livingstone along ting the 23M21 with the 23M28
	1a. Main Driver	23 8. pr lo su 23 ad	3M21 (former .8MVA over the roposed to be bading of 420/ ubstation, the 3M21 with the	rly 23M8). Two proposed C he next five years. A new 2 e in-service by 2018. The ex A, which exceeded the plan 23M21 is forecasted to ex e 23M28 to offload Little L	er of the project is to provide cap undles and Little Lake Commerci 0MVA 44/13.8kV 4 feeder substa disting 23M21 (formerly 23M8) ex uning limit of 400A. Given the pro ceed the 600A thermal limit in 20 ake MS from 23M21 will ensure t h without exceeding the plannin	al Developments will total tion (Little Lake MS#2) is sperienced a 2013 summer posed developments and new D19. Double circuiting the shat the area can be supplied to
	1b. Priority and Reasons for	be	eyond 2019 u	pon completion of the new	mal limits will be exceeded in the v Little Lake MS#2 and the propo limited due to existing loading.	
	1c. Qualitative and Quantita Project and Project Alternati	ives th	nereby provid		roximately 30MVA of capacity to kisting 23M21 and ensuring supp s.	
		4( 23 a0	00A planning 3M21 feeder ccommodate	limit in 2013 and the 8.8M	le alternative because the 23M2: VA of proposed commercial deve al limit in 2019. The "do nothing" d growth in the area or provide a	elopments will result in the

			Project Code		Report Start Y	'ear	Number of Yea	rs	Scale	
Power Stream			101	1572	2	015	6	5	Dol	lars
			Project Name							
Project Summar	y Report		<u>Doubl</u>	e Circuit ex	isting 23M8	Circuit from	Bayfield &	Livingstone	e to Little Lak	<u>ke MS.</u>
	2. Safety 3. Cyber-Secu	rity Privocy		Not Applicable Not Applicable						
		on, Interoperabi	lity	Not Applicable						
	5. Economic D		шу	Not Applicable						
	6. Environmer			Not Applicable						
Category-Specific Requirements for		stomers of Proj	ect Expressed							
ach Project/Activity (OEB)		st Impact, whe								
		ricity Infrastruc which affect Pi		Not Applicable	2.					
	Technology, if			Not Applicable						
	Identify any re coordination I		ency, safety or			reliability benef transfer option				ne Barrie no
	Factors Affect	ing Timing/Prio	rity	Securing the reference		vals from the city	in the allotted	timeframe ma	y affect the timi	ng of the
	Alternative Co	oject Benefits a omparison, inclu				that the new ci ckworth area, th				
	Nothing" Alter factors if appl	rnative (includiı icable)		ensuring supp The main alter	ly capacity to th rnative to this p	he new Little Lal proposed projec Iternative is not	ke MS#2 and contract the to th	nmercial devel	lopments. e the foreseeabl	e future.
				ensuring supp The main alter However, the planning limit feeder exceed	ly capacity to the second structure to this period on the second structure of the second structure of the second structure str		ke MS#2 and con t would be to "d viable because t posed commerc 019. The "do no	nmercial devel o nothing" for the 23M21 has cial developme thing" alternat	lopments. e the foreseeabl already exceed nts will result in ive would not ad	e future. ed the 400A the 23M21 ccommodat
				ensuring supp The main alter However, the planning limit feeder exceed the future con	ly capacity to the second structure to this period on the second structure of the second structure of the second structure str	proposed projec Iternative is not e 8.8MVA of pro permal limit in 2	ke MS#2 and con t would be to "d viable because t posed commerc 019. The "do no	nmercial devel o nothing" for the 23M21 has cial developme thing" alternat	lopments. e the foreseeabl already exceed nts will result in ive would not ad	e future. ed the 400A the 23M21 ccommodate
xpenditures Historical/Planned	factors if appl	icable) 2012	ng qualitative	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co	ly capacity to the provided reprint the term of the provided reprint the term of term	proposed project Iternative is not e 8.8MVA of pro nermal limit in 20 rowth in the are	ke MS#2 and con t would be to "d viable because to posed commerce 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl	2012 \$ -	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl	2012 \$ -	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl         2011         \$       -         \$3,000,0	2012 \$ -	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
ixpenditures Historical/Planned	factors if appl	2012 \$ -	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400 <i>A</i> the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl         2011         \$       -         \$3,000,0	<b>2012</b> \$ - 00	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400/ the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0	<b>2012</b> \$ - 00	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400 <i>A</i> the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0	<b>2012</b> \$ - 00 00 00 00 00 00 00 00 00 00 00 00 0	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0 \$2,000,0	<b>2012</b> \$ - 00 00 00 00 00 00 00 00 00 00 00 00 0	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0 \$2,000,0	<b>2012</b> \$ - 00 00 00 00	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400A the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0 \$2,000,0 \$1,500,0 \$1,000,0	<b>2012</b> \$ - 00 00 00 00 00 00 00	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400/ the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0 \$2,000,0 \$1,500,0	<b>2012</b> <b>2012</b> <b>\$</b> - 00 - 0 - 0 0	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400/ the 23M21 ccommodat d transfers i <b>2020</b>
xpenditures Historical/Planned	factors if appl 2011 \$ - \$3,000,0 \$2,500,0 \$2,000,0 \$1,500,0 \$1,000,0	<b>2012 \$</b> - 00 00 00 00 00 00 00 00 00 00 00 00 0	2013	ensuring supp The main alter However, the planning limit feeder exceed the future con contingency co 2014	ly capacity to the provided matrix of the pro	eroposed project Iternative is not e 8.8MVA of pro hermal limit in 2 rowth in the are <b>2016</b>	t would be to "d viable because f posed commerc 019. The "do no ea or provide ad	nmercial devel o nothing" for the 23M21 has tial developme thing" alternat equate feeder 2018	lopments. e the foreseeabl already exceed nts will result in ive would not ac capacity for load	le future. ed the 400 <i>A</i> the 23M21 ccommodat d transfers i <b>2020</b>

	Pro	oject Code	Report Start Year	Number of Years	Scale
Power Stream		102460	2015	6	Dollars
Project Summar		oject Name L	lighway Crossing Rem	ediation - Hwy 400/ Broc	<u>k St.</u>
Major Category	System Service				
Project Overview 1. Additional Information	Service Territory Location Scope	This project two pole sti	m North - Highway 400/ Brock is to carryout the engineering	design review and construction rie which currently uses steel sup	
	Justification	conductor of 407/Westor the street li review all h contracted reviewed ar there are tw with two cir joined to th crossing ind by steel cha channels ar have been r Of the two of The older, t four poles.	f feeder 21M9 (27.6kV circuit) a). High winds were reported i ght post at the same location. ghway crossings and impleme an engineering consultant to in a slated for replacement due to existing crossings. The older cuits at the same level. The ne e older structure by a slack spi icates no concerns. Both sets nnel irons that have been drive a attached to the poles with h einforced in this manner sugg existing crossings at this location wo pole structure, was found Based on these findings, the co	lighway crossing flash over cause April 16th, 2012 to the existing in the area at the time. This was a In the light of the above inciden int corrective action for the any i dentify locations in PowerStream to various structure and proximi r of the two is constructed on a f ewer of the two crossings is a sing an. The preliminary pole class an of structures associated with th en into the ground next to the b eavy steel banding. Based on the ests that there was a concern ab on, the newer installation has no to have had additional steel supp onsultant recommended that this pe taken to correct the concerns	Lighting standard (Hwy a second case of contact with it it was decided to proactively ssues identified. PowerStream of sterritory that need to be ty issues. At the 400/ Brock St. two pole/crossarm structure gle circuit installation that is d guying analysis for the newer e older crossing are supported ase of each pole. These e fact that these structures out their strength in the past. o concerns identified with it. ports installed at the base of all s older structure be planned for
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year Parent WO# Job Number	2018			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk M	completion already had addition, in	is the coordination effort and discussions with Hydro One ir ormation has been forwarded	the Hydro One station yard and t timing required with Hydro One a 2014 to give them time to revie to the municipality to make the a, municipal approvals can be dea	. In response, Engineering has w and settle on a plan. In m aware of any changes
	Comparative Information on Ed Historical Projects (if any)		m has performed several road nation with HONI.	crossings in the past and there s	should be no issue here, other
	Total Capital and OM&A Costs f Renewable Energy Generation Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary	of the two p	oole structures at 400/Brock St	design review and construction . in Barrie which currently uses s dicating a potential strength issu	teel supports installed at the
	1a. Main Driver			older pole structure at this cross oles as reinforcements indicating	
	1b. Priority and Reasons for Prio	of Brock St.		najor safety issue to vehicles driv o coordinate with Hydro One, th	
	1c. Qualitative and Quantitative Project and Project Alternatives	Engineering potential co consultant's alternative	has estimated the cost to reb sts to rebuild the line in an en findings and therefore the 'do to delay action however the le	s identified this crossing as a con uild at \$1,030,215. This cost is si hergency. PowerStream has an co nothing' alternative is not a via ad time for this project has alrea is planned for 2018 or sooner.	gnifcantly less than the obligation to act on the ble option. There is an

		Project Code	5	Report Start Ye	ear	Number of Ye	ars	Scale	
Power Stream 🕇	-	1	.02460	20	15		6	D	ollars
Durington	Descent	Project Nam			ing Pomod	iation - Hw	/ 400/ Brock	Ct	
Project Summar	y Report			Inway Cluss	sing Kemeu		/ 400/ DIUCK	<u> </u>	
	2. Safety		Any failure of t of Brock St.	his crossing wo	uld pose a majo	or safety issue t	o vehicles drivir	ig on Hwy#40	0 in the vicir
	3. Cyber-Security, P	Privacy	Not Applicable						
	4. Coordination, Int	teroperability	Not Applicable						
	5. Economic Develo	opment	Not Applicable						
	6. Environmental B	enefits	Not Applicable						
Category-Specific Requirements for ich Project/Activity (OEB)		ers of Project Express pact, where practicab							
	Regional Electricity Requirements whic applicable		Not Applicable						
	Description of Inco Technology, if appli	rporation of Advanced icable	Not Applicable						
	Identify any reliabil	lity, efficiency, safety	or Not Applicable						
				•					
	coordination benef							c	
	Factors Affecting Ti	iming/Priority	additional time	of this Hwy cros e for coordination	on. The project	has therefore	tion yard and th been prioritized	for 2018 or s	ooner.
	Factors Affecting Ti Analysis of Project I Alternative Compar	iming/Priority Benefits and Costs wit rison, including "Do- ve (including qualitativ	additional time h The benefits of PowerStream's e There are few,	of this Hwy cros of this project are this project are s engineering co if any, alternat	on. The project e mainly to rem onsultant. ves to this prop	has therefore edy a public sa posed project.	been prioritized fety concern tha	for 2018 or s at has been id g" alternative	ooner. entified by is not viable
	Factors Affecting Ti Analysis of Project I Alternative Compar Nothing" Alternativ factors if applicable	iming/Priority Benefits and Costs wit rison, including "Do- ve (including qualitativ	additional time h The benefits of PowerStream's e There are few,	of this Hwy cros of this project are this project are s engineering co if any, alternat	on. The project e mainly to rem onsultant. ves to this prop	has therefore edy a public sa posed project.	been prioritized fety concern tha The "do nothing	for 2018 or s at has been id g" alternative	ooner. entified by is not viable es in this an
xpenditures Historical/Planned	Factors Affecting Ti Analysis of Project I Alternative Compar Nothing" Alternativ factors if applicable	iming/Priority Benefits and Costs wit rison, including "Do- ve (including qualitativ e)	additional time h The benefits of PowerStream's e There are few, it does nothing	of this Hwy cros e for coordination f this project and s engineering co if any, alternat g to correct the	on. The project e mainly to rem onsultant. ves to this prop public safety co	has therefore edy a public sa posed project. oncerns of Powe	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viabl es in this ar
xpenditures Historical/Planned	Factors Affecting Ti Analysis of Project I Alternative Compar Nothing" Alternativ factors if applicable	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viables in this ar <b>2020</b>
ixpenditures Historical/Planned	Factors Affecting Ti         Analysis of Project I         Alternative Compar         Nothing" Alternative         factors if applicable         2011         \$       -	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viables in this ar <b>2020</b>
Expenditures Historical/Planned	Factors Affecting Ti         Analysis of Project I         Alternative Compar         Nothing" Alternative         factors if applicable         \$       -         \$       -         \$1,200,000       -	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viables in this ar <b>2020</b>
xpenditures Historical/Planned	Factors Affecting Till         Analysis of Project I         Alternative Comparing Alternative factors if applicable         2011       2         \$       -       \$         \$1,200,000       -         \$1,000,000       -         \$800,000       -	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viable es in this ar <b>2020</b>
xpenditures Historical/Planned	Factors Affecting Ti   Analysis of Project I   Alternative Company   Nothing" Alternative   factors if applicable   \$1,200,000   \$1,000,000   \$800,000   \$600,000	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viable es in this ard 2020
xpenditures Historical/Planned	Factors Affecting TiAnalysis of Project IAlternative ComparNothing" Alternative factors if applicable $$2011$ $$$$ $$$$ $$$1,200,000$ $$$1,000,000$ $$$800,000$ $$$600,000$ $$$400,000$	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viable es in this ard 2020
xpenditures Historical/Planned	Factors Affecting Ti   Analysis of Project I   Alternative Company   Nothing" Alternative   factors if applicable   \$1,200,000   \$1,000,000   \$800,000   \$600,000	iming/Priority Benefits and Costs wit rison, including "Do- /e (including qualitativ e) 2012 2013	additional time h The benefits of PowerStream's e There are few, it does nothing 2014	of this Hwy cros of this project and this project and engineering co if any, alternat to correct the 2015	on. The project e mainly to rem onsultant. ves to this prop public safety co 2016	has therefore edy a public sa posed project. oncerns of Powe 2017	been prioritized fety concern tha The "do nothin erStream's distri	for 2018 or s at has been id g" alternative bution faciliti <b>2019</b>	ooner. entified by is not viables in this ar <b>2020</b>

	Project Code	2	Report Start Year	Number of Years	Scale
Power Stream		.02459	2015	6	Dollars
Project Summar	Project Nam		way Crossing Remediat		of Dufferin
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory	PowerStream			
	Location Scope	Carryout the	ed at the 407/ East of Dufferin	construction necessary to	remediate the structure/tension dings of PowerStream's
	Justification	conductor of 407/Weston) the street lig review all hig PowerStream reviewed and Dufferin high structures. Th installation. pre-loading is highway are addition to b pole deeper t weakened by meters (10') the cracks wa several of the sag of the coo guying be rev should be coo the loads car engineering of	feeder 21M9 (27.6kV circuit) A h High winds were reported in t ht post at the same location. I ghway crossings and implement of sengineering consultant ident d slated for replacement due to tway crossing carries four 27.6k he pole on the south side of the As a result, the guy wires are ex- s difficult to determine. The co- hanging against the pole and it eing not connected, the commu- than normal. This might indicat is the vertical cracking. The pole above grade. These cracks were as significant. The rough guying e guy strands may be overloade inductors be field measured to co- viewed and modifications be ma- rrected immediately and the bu- n be factored into the guying an	pril 16th, 2012 to the existi he area at the time. This we n the light of the above inco corrective action for the ar- ified locations in PowerStro- various structure and prox / circuits, which is more that 407ETR is bowed due to the theremely tight under normal mmunication guys that wore is not evident if they were unication guy wire attachm e a significant amount of te was found to have several at least 75mm-100mm (3" review of the south pole of d under maximum condition letermine the expected man ade as required. The broke undle information be obtain alysis. Given that this cross nat this work be made a highting the source of the sourc	as a second case of contact with ident it was decided to proactivel by issues identified. eam's territory that need to be imity issues. The 407/East of an any of the other crossings he pre-loading of the guy wires at I conditions and the amount of ald support the span over the broken or never connected. In ents at the pole are dug into the nsion is present or that the pole i large vertical cracks within the 3. -4" deep) and the ant activity in this crossing indicates that wins. It is recommended that the ximum design tension and the n/missing communications guying the from the third parties so that
2. General Project Information (OEB)	Contributed Capital	Contributed	Capital 0%		
	Fiscal Year	2015			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemen	MTO. The re complication	built crossing is planned to mov	ve closer to the bridge and nges on Highway 7. Negoti	
	Comparative Information on Equivalent Historical Projects (if any)		n has performed several road cr rom the necessary approvals fro		re should be no unexpected issue managed.
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary		s to carryout the engineering dension concerns.	esign review and constructi	on necessary to remediate the
	1a. Main Driver	PowerStream	nain driver for this project is to n's engineering consultant noten nsion concerns that need to be a	d the 407/ East of Dufferin	d maintain the system integrity. highway crossing has
	1b. Priority and Reasons for Priority	of Dufferin St	f this crossing would pose a ma t. Based on the weighting given take place in 2015.		driving on Hwy#407 in the vicinity report, this project has been

		Project C	ode	Report Start Y	ear	Number of Yea	ars	Scale	
Power Stream			102459	20	15		6	Do	llars
		Project N	ame						
Project Summar	y Report		<u>High</u>	way Crossing	<mark>Remedia</mark>	ation - Hwy 40	07/ East of E	<u>Dufferin</u>	
		Quantitative Analy							
	Project and Project	t Alternatives	potential cos PowerStrear nothing' alte	sts to rebuild the n has an obligatic rnative is not a vi	line in an em n to act on tl able option.	ld at \$1,099,072. ergency. ne engineering co There is an alterr roject to start ASA	nsultant's findiı native to delay a	ngs and therefo	re the 'do
	2. Safety		Any failure o of Dufferin S	-	uld pose a m	ajor safety issue t	o vehicles drivi	ng on Hwy#407	in the vicin
	3. Cyber-Security, F	Privacy	Not Applicat	ole.					
	4. Coordination, In	teroperability	Not Applicat	ole.					
	5. Economic Develo	opment	Not Applicat	ole.					
	6. Environmental B	Benefits	Not Applicat	ole.					
5. Category-Specific Requirements for Each Project/Activity (OEB)		ners of Project Expre apact, where practic		ole.					
			Not Applicat	ble.					
Requirements which af applicable Description of Incorpor Technology, if applicab Identify any reliability,			<mark>ced</mark> Not Applicab	ole.					
		licable							
		ility, efficiency, safe	<mark>ty or</mark> Not Applicat	ole.					
	Identify any reliabi	ility , efficiency, safe fits	The significa		concerns hav	e resulted in this	project being p	roposed as soo	n as possible
	Identify any reliabi coordination benef Factors Affecting Ti	ility , efficiency, safe fits ïming/Priority	The significa 2015.	nce of the safety					
	Identify any reliabi coordination benef Factors Affecting Ti Analysis of Project	ility , efficiency, safe fits "iming/Priority Benefits and Costs	The significa 2015. with The benefits	nce of the safety of this project ar	e mainly to re				
	Identify any reliabi coordination benef Factors Affecting Ti Analysis of Project Alternative Compa	ility , efficiency, safe fits iming/Priority Benefits and Costs irison, including "Do ve (including qualita	The significa 2015. with The benefits PowerStrear tive There are fer	nce of the safety of this project ar n's engineering co w, if any, alternat	e mainly to ro onsultant. ives to this p	emedy a public sa	fety concern th The "do nothin	at has been ide ng" alternative i	ntified by s not viable
	Identify any reliabi coordination benef Factors Affecting Ti Analysis of Project Alternative Compa Nothing" Alternativ factors if applicable	ility , efficiency, safe fits iming/Priority Benefits and Costs irison, including "Do ve (including qualita	The significa 2015. with The benefits PowerStrear tive There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat	e mainly to ro onsultant. ives to this p	emedy a public sa roposed project.	fety concern th The "do nothin	at has been ide ng" alternative i	ntified by s not viable
xpenditures Historical/Planned	Identify any reliabi coordination benef Factors Affecting Ti Analysis of Project Alternative Compa Nothing" Alternativ factors if applicable	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. with The benefits PowerStrear tive There are fea it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr	at has been ide ng" alternative i ibution facilitie	ntified by s not viable s in this area
Expenditures Historical/Planned	Identify any reliabil coordination benefi Factors Affecting Tri Analysis of Project Alternative Compa Nothing" Alternativ factors if applicable \$ - \$	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area 2020
Expenditures Historical/Planned	Identify any reliabi coordination benef Factors Affecting Ti Analysis of Project Alternative Compa Nothing" Alternativ factors if applicable	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area <b>2020</b>
Expenditures Historical/Planned	Identify any reliabil coordination benefi Factors Affecting Tri Analysis of Project Alternative Compa Nothing" Alternativ factors if applicable \$ - \$	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area <b>2020</b>
Expenditures Historical/Planned	Identify any reliabil coordination benef Factors Affecting Tri Analysis of Project Alternative Compa Nothing" Alternative factors if applicable \$ - \$ \$1,200,000	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area 2020
Expenditures Historical/Planned	Identify any reliabil         coordination beneficitors         Factors Affecting Trians         Analysis of Project         Alternative Compa         Nothing" Alternative         factors if applicable         \$       -         \$       -         \$1,200,000       \$         \$1,000,000       \$	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area 2020
Expenditures Historical/Planned	Identify any reliabil         coordination beneficitors         Factors Affecting Trians         Analysis of Project         Alternative Compa         Nothing" Alternative         factors if applicable         \$       -         \$       -         \$1,200,000       \$         \$800,000       \$	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area 2020
Expenditures Historical/Planned	Identify any reliabil         coordination beneficitors         Factors Affecting Trianal strength         Analysis of Project         Alternative Company         Nothing" Alternative         factors if applicable         \$       -         \$       -         \$1,200,000       \$         \$8800,000       \$         \$600,000       \$	ility , efficiency, safe fits "iming/Priority Benefits and Costs irison, including "Do ve (including qualita e)	The significa 2015. With The benefits PowerStrear There are fer it does nothi	nce of the safety of this project ar n's engineering co w, if any, alternat ng to correct the <b>2015</b>	e mainly to ro onsultant. ives to this p public safety <b>2016</b>	emedy a public sa roposed project. concerns of Powe	fety concern th The "do nothin erStream's distr 2018	at has been iden iden iden iden iden iden iden i	ntified by s not viable s in this area 2020

	Proj	ect Code	Report Start Year	Number of Years	Scale
Power	5	100886	2015	6	Dollars
Project Summary Report Major Category System Service		ect Name	Distribution Automatio	n Switches / Reclosers	
Major Category	System Service				
Project Overview					
1. Additional Information	Service Territory Location	Various locati	North & South ons in PowerStream North and rith the Control Room.	South. The locations will be de	etermined by Planning in
	Scope	various location	volves the installation of Distrik ons. This has been an annual pr I units, with approximately the	ogram for the past 6 years. In	2015 it is proposed to install
	Justification	satisfaction in rapid transfer flexibility to re real time syste distribution a "Distribution a that automati - Reduce fee - Reduce the To determine the FAIDI, FAI Planning also switches to id beneficial in C Finally, autor and Lines by s - Customer S - Feeder load	eliability and rapid response to supplying electricity. RTU cor of loads in emergencies, reduce econfigure the system to avoid f em readings, reduce the risk of utomation system. Engineerin Automation Report ", which wa c switches be installed at strate der down time in case of outage number of customers affected potential switch candidates, Pe FI and SAIFI contributions to the reviews the outage causes, feed entify and determine the locatio MI reduction and operational n matic switch locations are jointly electing potential switch candid ervice reliability needs ling emergency back-up and load of operations needs on outage	Atrolled switches (predominant e restoration time which impro- feeder and station over loads of personnel injury and are the p g Planning released a strategy s subsequently updated in 201 gic locations over a number of es by outages. owerStream planning departm e systems and determines Wor der load balancing plan and loo on for additional switches and needs. of determined among System Pl dates to address the following and transfer needs	tly SCADA-Mates) provide oves reliability, provide during summer peak, provide latform for the complete report in 2005 titled L2. The report recommended f years to: nent ranks Feeders based on rst Performing Feeders. cation of existing automatic re-closers wherein it is most lanning, System Operations, requirements:
2. General Project Information (OEB)	Contributed Capital Fiscal Year	Contributed C	apital 0%		
	Parent WO# Job Number	2015			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Mar		lays from municipal road widen selected in this circumstance an		
	Comparative Information on Equ Historical Projects (if any)	ivalent This program	has been on-going for the past	6 years.	
	Total Capital and OM&A Costs for Renewable Energy Generation pc Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary		Distribution Automation Scada al program for the past 6 years.		
	1a. Main Driver	controlled sw improves relia during summe	e main driver of the Investmen itches provide rapid transfer of ibility, provide flexibility to reco er peak, provide real time syster he complete distribution autom	loads in emergencies, reduce I nfigure the system to avoid fe m readings, reduce the risk of	restoration time which eder and station over loads
	1b. Priority and Reasons for Prior	lacking autom outages, and	authored a Distribution Autom ated devices thereby affecting to reduce the number of custon crease PowerStream's overall re	PowerStreams ability to reduce ners affected by outages. This	e feeder down time in case of

		Project Code		Report Start Year	Number of Years	Scale
Power Stream		100	886	2015	6	Dollars
Project Summary	Report	Project Name		Distribution Automation	n Switches / Reclosers	
	1c. Qualitative and Quantita Project and Project Alternat		represent the b [%improvement In 2014, on ave feeder: Markha Between 2008- to meet it's Lev increased to 23 the 2012 DA re sectionalize fee The alternative alternative will	am=1.23, RichmondHill =0.77, V 2011, PowerStream had been vel 1 automation targets. In 20 8 units/year (14 Scada-Mates a port within 6 years, where the eders, and 67 N.O. switches to s is to continue to utilize manual require Lines crews to operate petween feeders. This will incre-	ved reliability improvement, us ving number of normally open Vaughan=0.98, North area=1.3 installing an average of 8-10 so P13, the Distribution Automatic nd 9 Reclosers) in order to men report called for 70 N.C. Switc build ties between feeders. al LIS (Load Interrupting Switch e a significant number of manu	sing the following equation R.T.U. controlled Switches per 5. witches per year in an attempt on Capital Program was et the DA targets identified in thes or reclosers to n) switches. However, this ial switches to isolate faults or
	2. Safety		switching to oc or visa versa. 2. Allowing swi	ated to safety for this project i ccur without staff in contact wi tching to occur during an eme ical injury, fire or explosion.	th the equipment during chang	
	<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interoperat</li> <li>Economic Development</li> </ol>	bility	Not Applicable		cate back to the control room	via private network.
	<ol> <li>5. Economic Development</li> <li>6. Environmental Benefits</li> </ol>		Not Applicable Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Customers of Pro in terms of Cost Impact, who		Automation sw - Frequency of - Duration of in switching in co - Number of cu - Customer Inte - Customer Inte - Delivery Char, <u>Cost to Custom</u> - Customer Inte - Customer Inte <u>Cost Comparise</u> - Total Cost to C	interruption: 2/year interruption: 30 minutes (0.5 ho mparison to remote automatic istomers affected in an outage d affected in an outage: 2000 k erruption Cost (Frequency): \$2 erruption Cost (Duration): \$20. ge, etc. for loss of revenue calc hers: erruption Cost (Frequency) = N erruption Cost (Duration) = 200	ours). This is the estimated incr c switching : 500 customers cW 0.00/kW (mixed Residential , C 00/kWh (mixed Residential, C culation: \$0.0179/kWh Not Applicable 00 kW x 0.5 hrs x \$20/kWh x 2 f	emental time for manual commercial & Industrial) ommercial & Industrial) failures/year= \$40,000
	Regional Electricity Infrastru Requirements which affect I applicable		Not Applicable			
	Description of Incorporation Technology, if applicable Identify any reliability , effic coordination benefits		loops) if requir RTU controlled - rapid transfer - reduce restor 2-5min) - provide flexib - provide real t - reduce the ris - more efficient	switches are capable to partic ed for future Smart Grid strate switches provide the following of loads in emergencies, ation time which improves reli ility to reconfigure the system ime system readings, sk of personnel injury t planned outages ipation in the complete distribu	gies. g benefits: ability, (without automation = to avoid feeder and station ov	
	Alternative Comparison, inc	and Costs with luding "Do-	automation sw	native to this project would be	ever, "doing nothing" would no	ot allow PowerStream to make

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		100886 2015				6		Dollars	
Project Summary	Report		Project Name		<u>Distributior</u>	<u>n Automatio</u>	n Switches	/ Reclosers		
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ 530,166	\$ 1,085,802	\$ 1,184,597	\$ 671,797	\$ 1,850,276	\$ 1,530,249	\$ 2,080,457	\$ 2,283,805	\$ 2,354,895	\$ 2,409,740
	\$3,000	,000								
	\$2,500	,000								
	\$2,000	,000								
	\$1,500	,000								
	\$1,000	,000								
	\$500,	,000								
		\$- 2011	2012	2013	2014	2015 20	16 2017	2018	2019	2020
	L									

	Ρ	Project Code		Report Start Year	Number of Years	Scale
Power Stream	-	102	851	2015	6	Dollars
	P	Project Name				
Project Summar	ry Report			Purchase of a M	obile Unit Station	
Major Category	System Service					
Project Overview	•					
1. Additional Information	Service Territory		PowerStream I	North & South		
	Location		All MS Stations	5		
	Scope		Purchase of a S	5MVA dual primary and multip	le secondary Mobile Unit Stati	on (MES) complete with 3
			outgoing feede			
	Justification		causes an outa customers to r Powerstream h We had to pay from the neigh because a MES the feeders has stations, a rent locations when when an emerg	number of stations that have n ge. Also, PowerStream has rer emain with power while critica has been fortunate that the ne a rental charge for the use of bouring utility. The MS station is has to be obtained and the st ve to be reconnected to the M cal unit has to be rented and in e loading is an issue, while equ gency occurs and portable pov ing an extended outage.	Ited a unit from a neighbourin al station equipment is either of ighbouring utility had the unit the unit and had to arrange fo s that are "islanded" are not n ation has to be comlpetely dis ES. In order to install monitori stalled. It is expected that the upment that fails in high load	g utility in order to allow changed out or repaired. available when we required it. r the transportation to and maintained as they should be connected from the grid and ng equipment on these unit would be used at many season can be repaired and
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2020			
	Parent WO#					
	Job Number					
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk N		The componen	will be purchased as a turnkey ts are off the shelf equipment manufacturers mobile station	that is assembled on a flat be	
	Comparative Information on I Historical Projects (if any)	Equivalent	No Comparativ	ve Projects		
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		outgoing feede			
	1a. Main Driver		damage that ca allow custome PowerStream I We had to pay from the neigh because a MES the feeders has stations, a rent locations when when an emerg	rs to remain with power while	tream has rented a unit from a critical station equipment is e ighboring utility had the unit a the unit and had to arrange fo that are "islanded" are not ma ation has to be completely dis ES. In order to install monitori stalled. It is expected that the ipment that fails in high load	a neighboring utility in order to ither changed out or repaired. available when we required it. r the transportation to and aintained as they should be connected from the grid and ng equipment on these unit would be used at many season can be repaired and
	1b. Priority and Reasons for Pr		there is no cho stations that has cannot be prop mobile unit co	storation of customers would b ice but to have an extended o ave no redundancy available. T perly diagnosed because the ef uld also serve to provide powe I load arrangements are easier	r forced outage. The exists son hese stations can not be easili fort and the customer disrupt r when a station is disconnect	ne MS stations and Customer y maintained and equipment ion is unacceptable. The ed for scheduled service.
	1c. Qualitative and Quantitative Project and Project Alternative	es	failure of eithe unit can be use used to keep fe	e used for the following purpose r the utilities equipment or the ed to offload a station that is ir eeders energized while a station to neighboring LDCs when not	e customers equipment (e.g. d an overload state (during hig on is maintained (all year long)	ata centre or hospital). The h peak time). the unit can be

			Project Code		Report Start	Year	Number of Yea	rs	Scale				
Power Stream 🚽			102	2851		2015	e	5	D	ollars			
			Project Name										
Project Summary	/ Report				<u>Pu</u>	rchase of a M	lobile Unit St	tation					
	2. Safety			The mobile u	nit provides ad	dded safety to sta	tions that are ou	it for repair or	maintenance.	The perman			
				equipment ca its condition.	n be properly	tested and not ru	ished to comple	te. The equipn	nent can be be	tter assessed			
	3. Cyber-Security	, Privacy		There is no cy	ber security p	rivacy issues with	the purchase of	a mobile subs	tation.				
	4. Coordination, I	nteroperab	ility										
	5. Economic Deve			Not Applicable The environmental benefits for having a mobile substation is that a piece of equipment that is leaking									
	6. Environmental	Benefits		one of the star repaired/repl	tions that can aced. The amo t repaired wit	s for having a mot inot be totally isol ount of contamina thout having to fir	ated without a dation is minimize	customer prolo d as the outag	onged outage o e can easily be	an be prope scheduled a			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Benefits to Custo in terms of Cost I			It is expected	that custome some location	ns cannot be mair							
	Regional Electrici Requirements wh applicable			Not Applicabl									
	Description of Inc Technology, if ap		of Advanced	Not Applicabl	е.								
	Identify any relial coordination ben		ency, safety or	critical custor backup would	ners if require be significan	e used to provide o d. Without a mo t. An extended o pment failed cata	bile unit station utage would res	, the impact of	a station failu	re without			
	Factors Affecting	Timing/Pric	rity	PowerStream presently relies on other utilities to be able to supply it with a mobile station under planned maintenance conditions. If the condition is an emergency, there is no guarantee that a mobile station will be available. This increases significantly the duration of the outage. If an islanded station he a failure that requires extensive repairs (eg. transformer or switchgear replacement), then the amount of time to restore the customer(s) will be significant.									
	Analysis of Projec Alternative Comp Nothing" Alterna factors if applicat	arison, incli tive (includi	uding "Do-	have the nece that the mobi be subjected serve to main PowerStream	ssary mobile le unit station to PowerStrea tain power to 's Reactive an	equipment to pro	vide service in a a number of ver bidding process. maintenance or iir costs will be r	n emergency s ndors. The pro By having a i repairs are ree	ituation. It sho ocurement of t mobile station quired at a stat	ould be note he unit woul available, it tion.			
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020			
Expenditures Historical/Planned	\$ - \$	-	\$ -	\$ -	\$-	\$ -	\$-	\$-	\$ -	\$ 885,			
	\$1,000,000	Τ											
	\$900,000	-											
	\$800,000												
	\$700,000	-											
	\$600,000	-											
	\$500,000												
	\$500,000	\$400,000											
	\$400,000												
	\$400,000 \$300,000												

	Project Code		Report Start Year	Number of Years	Scale
Power Stream	102	2180	2015	6	Dollars
	Project Name				
Project Summary	/ Report		CIS Mod	lifications	
Major Category	General Plant				
Project Overview	Consider Touritory	Devestoreen	Nanth & Cauth		
1. Additional Information	Service Territory	PowerStream I	North and South		
	Location			D.t	
	Scope	CIS Enhanceme Hardware Upg CIS Interfaces	ents - Regulatory and Business rade	Driven Version Upgrade	
	Justification	efficiently and	vital dollars to ensure PowerStr meet the regulatory requirem em that meets regulatory requ	ents. The enhancements repre	esent normal capital upgrade
2. General Project Information (OEB)	Contributed Capital	Contributed Ca	apital 0%		
	Fiscal Year	2015			
	Parent WO#	2015			
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Management		project management and solit commitee, vendor manageme		-
	Comparative Information on Equivalent Historical Projects (if any)		s CCB target go-live date is Apr PowerStream expects the sam		f continuous changes in the
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary		to application to support proce e version of software. ograde	ess improvement and regulato	ry requirements.
	1a. Main Driver	Customer Serv	ice. Improve processes, custor	mer experience and regulatory	compliance.
	1b. Priority and Reasons for Priority	Not Applicable	•		
	1c. Qualitative and Quantitative Analysis of Project and Project Alternatives	Not Applicable			
	2. Safety	Not Applicable			
	3. Cyber-Security, Privacy	Not Applicable			
	4. Coordination, Interoperability	Not Applicable			
	5. Economic Development	Not Applicable			
	6. Environmental Benefits	Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothing" Option	Not Applicable			
	Net Benefits of Project in Monetary Terms (where practicable)	Not Applicable			

			Project Code		Report Start Ye	ear	Number of Yea	ars	Scale	
Power Stream	5		102	2180	20	)15		6	Do	llars
Project Summary			Project Name			CIS Mod	lifications			
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$ 654,419	\$ 423,082	\$ 220,853	\$ 107,203	\$ 1,403,400	\$ 3,884,100	\$ 6,708,900	\$ 2,996,000	\$ 2,996,000	\$ 2,996,000
	\$8,000,0	00								
	\$7,000,0	00 -								
	\$6,000,0	00								
	\$5,000,0	00								
	\$4,000,0	00 -					1	·		
	\$3,000,0	00								
	\$2,000,0	00								
	\$1,000,0	00								
	\$	2011	2012	2013	2014	2015 201	16 2017	2018	2019	2020
	L									]

Project Summary Report Major Category Gene Project Overview	Project Name	1991	2015	6	Dollars
Major Category Gene	ort				
Major Category Gene					
			CIS Replace	ment Project	
Project Overview	ral Plant				
4 Additional Information	- Toullon	Description	death 0 Ceath		
	ce Territory	PowerStream N		ad at Davies Chus anala Jana Chus	at Maushan la satian
Locat	ion	-	l be developed and implement implemented, the CC&B syste		-
Scope	-	Billing ("CC&B" the integration over 30 years of PowerStream H system and the The CIS System supports the Co evolving custor scalable system harness techno leverage techn operational exe A description of Electricity Distr anticipated pro CIS replacemer Board ("Board"	Information System ("CIS") Rep () software to replace the forme of approximately 20 existing a old, utilized outdated technolog had no viable option but to rep e critical nature of the CIS in bill replacement is one of several ompany in addressing key busin mer needs and market consolid h, based on leading technologie ology as a strategic enterprise a ology solutions in order to stre cellence. If work related to the CIS Repla ibution Rate Application, EB-20 oject cost was \$34,495K, with a ant project was included in the c d') Decision and Order related to is scheduled to be in-service in	er T&W Info-Systems Ltd. ("T& ncillary systems linked to the o gy, was difficult to maintain an lace the T&W System due age ling and supporting customers initiatives outlined in Powerst ness drivers such as providing lation. Modernizing the CIS Sy es, allows PowerStream to app sset. The Oracle CC&B solution amline and automate core bus cement Project was included i D12-0161 (Exhibit B1, Tab 1, Sc projected in-service date in th apital funding envelope appro that proceeding, dated Dece	W") CIS System along with CIS. The T&W CIS System was d was no longer sustainable. and obsolescence of the ream's IS Strategy and efficient service, meeting rstem by replacing it with a ly innovation in order to n allows PowerStream to siness processes and achieve n PowerStream's 2013 hedule 5). At that time, the re second quarter of 2014. The wed in the Ontario Energy
Justif	ication	<ul> <li>was essential</li> <li>System</li> <li>provides Power</li> <li>allows Powers</li> <li>requirements i</li> <li>utilizes out-of</li> <li>(SOW)) to stand</li> <li>re-engineers I</li> <li>the new system</li> <li>provides scala</li> <li>effectively int</li> <li>and</li> <li>implements a</li> </ul>	n of the new Oracle CC&B syste given the technological age, ur erStream with the flexibility to Stream to meet regulatory and n a cost effective manner; f-the-box CC&B Software funct dardize business process where PowerStream's business proces n; ability to meet future customer egrates the CC&B System with documented data model that id functionality.	nsustainability and limited flex meet its current and future bu industry changes along with c ionalities (as defined in the Im e possible sses to align with industry best growth; PowerStream's technology, ar	usiness requirements; lata management uplementation Scope of Work r practices, as established by rchitecture and infrastructure;
2. General Project Information (OEB) Contr	ributed Capital	Contributed Ca	ipital 0%		
Job N	nt WO# lumber	2015			
3. General Information on the Risks Project/Activity (OEB)	to Completion and Risk Management	<ul> <li>structured pr</li> <li>a core project</li> <li>timely monitient</li> <li>to PowerStream</li> <li>a communication</li> <li>scope change</li> <li>organization</li> <li>well defined f</li> <li>minimizing communication</li> <li>ensuring accommunication</li> </ul>	ere managed through the follo roject governance with strong e t team with best resources oring and reporting of project s m senior management and Boa ation plan for various stakehold e management and control pro al change management, linking functional requirements omplex product customisations uracy of data migration reporting of benefits	executive support status (e.g. scope, schedule, co rd of Directors lers cess human resources to best prac	
	parative Information on Equivalent rical Projects (if any)	Not Applicable			

		Project Code	Report Start Year	Number of Years	Scale
Power Stream		101991	2015	6	Dollars
		Project Name			
Project Summar	y Report		<u>CIS Repla</u>	cement Project	
Project Summar	y Report Total Capital and OM&A Cos Renewable Energy Generatio Projects (if any) Project Summary 1a. Main Driver 1b. Priority and Reasons for 1c. Qualitative and Quantitar Project Alternati	tts for 0 on portion of The CIS is a years old, c past norma the core pr limited doc application manageme system pro both intern through the Richmond I System pro the Compa The Legacy technologic In 2011, Po existing T& needs, func considering PowerStreat system solu the largest The CC&B S Custom Col under a sep Discovery P the future of facilitated v designated these session to be application The Discover SPriority Not Application	critical and comprehensive bus wned by PowerStream and sup l retirement age and continued ogramming. The Legacy CIS Sys umentation related to these cu is required to meet a core busin nt, billing, collections, payment viding inbound and outbound in al and external to PowerStream e series of amalgamations, merg till Hydro, Aurora Hydro and Ba mpted by government initiative ny at too great a risk for system T&W CIS System served Power? al support and further develop werStream purchased an Oracle N System that was no longer vi tionality and a formal evaluatio replacing their CIS were consu m. Oracle was chosen as the si tion. Subsequently, an RFP was single cost of the overall project olution is comprised of Oracle? Ile for the Ontario Market (CCO arate contract with the System hase identified gaps between t or desired state represented by vorking sessions that focused o system area such as Billing, Cree ons were used to establish busin d to the future state system. T ary nhase manned all functional ervice ble.	Stream well, however it had read ment. e Customer Care and Billing (CC& able. This purchase was based o in process. Other LDC's that had lted in order to determine the bu uccessful vendor after an evaluat i issued to select a vendor to inte	W. The principal of T&W was m and retain the knowledge of d over the years with very wided the full meter-to-cash es related to account r reading. It was also a hub enty other interface systems S System had further evolved ham Hydro, Hydro Vaughan, t changes to the Legacy CIS were putting customers and ched its limits in terms of B) System to replace the n a review and assessment of recently replaced or were est system solution for tion alongside a SAP customer egrate the system which was em Version 2.3.1 and Oracle's into two phases each governed phase was "Discovery". The the legacy T&W System and was executed in a series of ple each session addressed a Care, etc. The outputs from ameters and design decisions k months.
	2. Safety 3. Cyber-Security, Privacy	Not Applica Not Applica			
	4. Coordination, Interoperab				
	5. Economic Development	Not Applica			
	6. Environmental Benefits	Not Applica			

			Project Code		Report Start Ye	ear	Number of Years		Scale		
Power Stream			101	1991	20	15	6	i	C	ollars	
			Project Name								
Project Summar	y Report				<u>(</u>	CIS Replace	ement Projec	<u>t</u>			
Category-Specific Requirements for ach Project/Activity (OEB)	Impact of De	ferral/"Do Nothi	ing" Option	principle and I continue to m opportunities. and developm at risk for supp with no easy w (3) The system Toronto Hydro to sustain any technology wr and integratio available toda PowerStream' deterioration w the art system PowerStream' are required to approach is at replacement of Any capital cos ultimately req	ong-time staff of ake the necessa Specific T&W si ent of these and oort from a sma vay of fixing this has reached its with ~450,000 further substan itten in Basic with n of new technol y. s customer satis when compared s with more cus s annual maintee o be made to ar tractive in the ir olution. It can b cls to stay abrea sts incurred to r	of T&W. The los ry modification taff have some d other staff is in ll single vendor s without pulling capacity. From customers. The tial growth. (4) hich makes it co- ologies compare sfaction can be to other large stomer care and enance and cap n already highly mmediate time e expected tho st of current ar nodify the exist ance costs for th	W programming s of this individu s for regulatory knowledge of co required to mitig (2) Compoundi g key knowledge a pure number system, though Being 1970's vir onsiderably more ed to the newer Expected to rem LDCs who have I self-serve funct tal costs can be customized system rame as it avoid ugh that PowerS d emerging CIS ing CIS will be w he existing system	al would seried or business re- re program fu- gate this risk. E- ng this matter able staff off of of customers , is overly cust tage, the T&V e cumbersome table driven a ain as is (at be implemented ionality than of expected to ir em. The adop s the capital co itream will evo- needs and to s asted if a repl- m will also inco	usly impede t quirements or inctionality bu even with this, is the lack of of normal mai perspective, it tomized makin V product is a to enhance find configurab est) but will be more compretent exists in T&W. Increase as new tion of the stat ost of implement entually have is support its gro acement CIS s	he ability to r future M&A it further train PowerStrear documentation tenance dut t was used at ng it unrealist "green screen or automation le software e at risk to hensive state w modification tus quo enting a CIS to adopt a swth aspiratico olution is	
	Net Benefits (where pract	of Project in Mo icable)	netary Terms	they are implet achieve chang The new syster reports compa- to conduct cus improvement vendor T&W v Although not p	mented and pu es in more cost m offers a numl red to the exist stom analytics th and cost savings which is often a proven, this syst	t into production effective ways our of predefine ing system. This hat will be used s. Currently this lengthy and explore the pottern the pottern the pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store		ce on propose evel of influer the organizat ne ability to cc bility to drill d ivisions efforts requires custo the need to in	nce presents o ion and our cu onduct more e leeper into pro s towards cont om programm ncrease future	pportunities ustomers. ffective had l ocesses in oro tinuous uing by our	
			netary Terms	they are implet achieve chang The new syster reports compa- to conduct cus improvement vendor T&W v Although not p	mented and pu es in more cost m offers a numl red to the exist stom analytics th and cost savings which is often a proven, this syst	t into production effective ways our of predefine ing system. This hat will be used s. Currently this lengthy and explore the pottern the pottern the pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store pottern the store	greater influent on. This greater l to the benefit of ed reports and th s will allow the a as part of the d type of analysis pensive process. ential to reduce	ce on propose evel of influer the organizat ne ability to cc bility to drill d ivisions efforts requires custo the need to in	nce presents o ion and our cu onduct more e leeper into pro s towards cont om programm ncrease future	pportunities ustomers. ffective had h ocesses in orc tinuous uing by our	
xpenditures Historical/Planned	(where pract	icable)	2013	they are implet achieve chang The new syste reports compa- to conduct cus improvement vendor T&W v Although not p due to the inh	mented and pu es in more cost m offers a numl ared to the exist stom analytics th and cost saving which is often a proven, this syst erent efficiencie	t into productio effective ways per of predefine ing system. Thi hat will be used s. Currently this lengthy and exp eem has the pot es and improve	greater influent on. This greater l to the benefit of ed reports and th s will allow the a as part of the d type of analysis pensive process. ential to reduce d functionality b	ce on propose evel of influer the organizat ne ability to cc bility to drill d ivisions efforts requires custo the need to ir uilt into the sy	nce presents o ion and our cu onduct more e leeper into pro s towards cont om programm ncrease future /stem.	pportunities ustomers. ffective had l occesses in oro tinuous ing by our	
penditures Historical/Planned	(where pract 2011) \$ - \$18,000, \$14,000, \$12,000, \$8,000, \$4,000, \$2,000,	2012 \$ 6,651,576 ,000 ,000 ,000 ,000 ,000 ,000 ,000 ,000	2013	they are implet achieve chang The new syste reports compa- to conduct cus improvement vendor T&W v Although not p due to the inh	mented and pu es in more cost m offers a numl ared to the exist stom analytics th and cost saving which is often a proven, this syst erent efficiencie	t into productio effective ways per of predefine ing system. Thi hat will be used s. Currently this lengthy and exp eem has the pot es and improve	greater influence on. This greater l to the benefit of ed reports and the swill allow the a as part of the d type of analysis bensive process. ential to reduce d functionality b	ce on propose evel of influer the organizat ne ability to cc bility to drill d ivisions efforts requires custo the need to in uilt into the sy 2018	to presents o ion and our cu onduct more e leeper into pro s towards cont om programm increase future stem.	pportunities ustomers. ffective had ocesses in ord tinuous ing by our staff resource 2020	

	Ρ	roject Code		Report Start Year	Number of Years	Scale
Power Stream	-	102	968	2015	6	Dollars
	P	roject Name				
Project Summar	ry Report			JD Edwards App	lication Upgrade	
Major Category	General Plant					
Project Overview 1. Additional Information	Convice Territory		PowerStream I	North & Courth		
1. Additional information	Service Territory					
	Location		161 Cityview B	ivu PowerStream's Enterprise Envii	conment System The score of	f this project is to PED to
	Scope			for to assist in the upgrade, an		
	Justification		Gain benefit of	f new features within the version of the second s		
2. General Project Information (OEB)	Contributed Capital		Contributed Ca			
	Fiscal Year		2019			
	Parent WO#		311281			
	Job Number		C14051			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk N	Management	timing on this	project is to dovetail into the e ars of supportability. By not mo	nd of support for the current v	version, into the latest version
	Comparative Information on E Historical Projects (if any)	Equivalent	Keeping softwa of interoperab	are current is a best practice so ility.	enario, allowing for current re	lease benefits, as well as ease
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
4. Evaluation Criteria (OEB)	Project Summary		result in a long	RFP to either upgrade or repla er term project than planned. tion of upgrades.		
	1a. Main Driver		intention of th version of the	nent Support. The supportabil is project timing is to dovetail i software, regaining 5 years of s logy changes in the system fro lication.	nto the end of support on the supportability. Subsequent fac	old, and introduce the latest tors include taking advantage
	1b. Priority and Reasons for Pr	riority	-	are past its supportability is not go past the date, the harder it		to mitigate this risk, however
	1c. Qualitative and Quantitative Project and Project Alternative		Detailed reviev planned upgra		rall project will be handled the	e year prior to the actual
	2. Safety		There is no per	ceived benefit or degradation	to safety.	
	3. Cyber-Security, Privacy		Implementatio	n of the newer system may re- he existing system.		limiting exposures that may
	4. Coordination, Interoperabili	ity	Having newer	systems results in smoother int tougher it is to work with other		ems. The further out of sync a
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		No perceived e	environmental impacts, positive	e or negative.	
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothin	ng" Option	Increased risk	of issues as a result of system f	ailure, or regulatory changes.	
	Net Benefits of Project in Mon (where practicable)	netary Terms	vendor. This a	software updated, issues with allows PowerStream to avoid h em is no longer supported by th	aving to contract a 3rd party c	

			Project Code	•	Report	Start Yea <b>r</b>		Number of Ye	ars	Scale	
Stream	-		102968 2015						6	Dollars	
			Project Nam	е							
Project Summar	ry Report					JD Edwa	ards App	lication Up	<u>grade</u>		
	2011	2012	2013	2014	20:	15	2016	2017	2018	2019	2020
xpenditures Historical/Planned	\$ -	\$-	\$-	\$	\$	- \$	-	\$-	\$-	\$ 2,396,800	\$
	\$3,000,000										
	\$3,000,000										
	\$2,500,000										
	\$2,000,000										
	\$1,500,000										
	\$1,000,000										
	\$500,000										
	\$ -	-	2012	2013	2014	2015	2016	2017	2018		

	103	204	2015	6	Dollars
Proj	ject Name				-
r Report		<u> </u>	MSBPI Microsoft Busine	ess Productivity softwar	<u>e</u>
General Plant					
Service Territory		PowerStream	North & South		
				Droductivity coffuero (Mord	Tural Arrans Dowornaint
		Project, Visio,	SharePoint, etc.)		
Justification		· ·			rity with current security
Contributed Capital		Contributed C	apital 0%		
Fiscal Year		2016			
Parent WO#					
Job Number					
Risks to Completion and Risk Ma	nagement	Risks to compl	letion include resourcing and p	riority.	
Comparative Information on Equ Historical Projects (if any)	uivalent	PowerStream	last did a MSBPI upgrade in 201	1 - cost and improved function	nality documented.
		0			
Project Summary		· ·			rity with current security
1a. Main Driver					f processing information.
1b. Priority and Reasons for Prior	rity	Ensure that se	curity is current as well as take	advantage of new technology	to improve productivity.
1c. Qualitative and Quantitative Project and Project Alternatives	Analysis of	remaining stat	tus quo is unacceptable as tech		
2. Safety		Not Applicable	2.		
3. Cyber-Security, Privacy		Upgrade end u	user tools to current technology	/ standards.	
4. Coordination, Interoperability		require that th	nese systems are upgraded to c	urrent standards in order to w	-
5. Economic Development		Not Applicable	2.		
6. Environmental Benefits		Not Applicable	2.		
Impact of Deferral/"Do Nothing"	Option		-		
Net Benefits of Project in Monet (where practicable)	ary Terms				
	Report   General Plant   Service Territory   Location   Scope   Justification   Contributed Capital   Fiscal Year   Parent WO#   Job Number   Risks to Completion and Risk Math   Comparative Information on Eq   Historical Projects (if any)   Project Summary   1a. Main Driver   1b. Priority and Reasons for Prio   1c. Qualitative and Quantitative   Project and Project Alternatives   2. Safety   3. Cyber-Security, Privacy   4. Coordination, Interoperability   S. Economic Development   6. Environmental Benefits   Impact of Deferral/"Do Nothing"	General Plant         Service Territory         Location         Scope         Justification         Contributed Capital         Fiscal Year         Parent WO#         Job Number         Risks to Completion and Risk Management         Comparative Information on Equivalent         Historical Projects (if any)         Project Summary         1a. Main Driver         1b. Priority and Reasons for Priority         1c. Qualitative and Quantitative Analysis of Project and Project Alternatives         2. Safety         3. Cyber-Security, Privacy         4. Coordination, Interoperability         S. Economic Development         6. Environmental Benefits         Impact of Deferral/"Do Nothing" Option	Report       General Plant         Service Territory       PowerStream         Location       PowerStream         Scope       This project is Project, Visio,         Justification       Improve produstandards, and         Contributed Capital       Contributed C         Fiscal Year       2016         Parent WO#       Job Number         Risks to Completion and Risk Management       Risks to completion and Risk Management         Comparative Information on Equivalent       PowerStream         Historical Projects (if any)       PowerStream         Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)       0         Project Summary       Improve produstandrds, and standards, and ta. Main Driver       Capital Investream         1b. Priority and Reasons for Priority       Ensure that set remaining statinteroperabiliti       Standards, and standards, and taiteroperabiliti         2. Safety       Not Applicable       Not Applicable         3. Cyber-Security, Privacy       Upgrade syst require that th (introduced of the interoperability       Upgrade syst require that th (introduced of the alternative         5. Economic Development       Not Applicable       Not Applicable         6. Environmental Benefits       Not Applicable         Impact of Deferral/"Do Nothing" Option       The	Report       MSBPI Microsoft Busines         General Plant       Fervice Territory       PowerStream North & South         Location       PowerStream North and South         Scope       This project is to upgrade Microsoft Business Project, Visio, SharePoint, etc.)         Justification       Improve productivity of end user with up to or standards, and improve/provision compatibil         Contributed Capital       Contributed Capital 0%         Fiscal Year       2016         Parent WO#       Job Number         Risks to Completion and Risk Management       Risks to completion include resourcing and prove productivity of end user with up to or standards, and improve/provision compatibil         Total Capital and OM&A Costs for       PowerStream last did a MSBPI upgrade in 202         Renewable Energy Generation portion of Projects (if any)       Improve productivity of end user with up to or standards, and improve/provision compatibil         1a. Main Driver       Capital Investment Support. Improved end u         1b. Priority and Reasons for Priority       Ensure that security is current as well as take         1c. Qualitative and Quantitative Analysis of Projects (in any)       Realistically, technical project alternatives with up to current as well as take         1c. Qualitative and Project Alternatives       Improve productivity of end user with up to current as current as well as take         1b. Priority and Reasons for Priority       Ensure	Report         MSBPI Microsoft Business Productivity software           General Plant         Former Stream North & South           Scrvice Territory         PowerStream North & South           Location         PowerStream North and South           Scope         This project is to upgrade Microsoft Business Productivity software (Word, I Project, Visio, SharePoint, etc.)           Justification         Improve productivity of end user with up to date technology, increase secu standards, and improve/provision compatibility with new technologies.           Contributed Capital         Contributed Capital 0%           Fiscal Year         2016           Parent WOH         Job Number           Risks to Completion and Risk Management         Risks to completion include resourcing and priority.           Comparative Information on Equivalent Historical Projects (if any)         PowerStream last did a MSBPI upgrade in 2011 - cost and improved function Projects Summary           Total Capital and OM&A Costs for Project Summary         0           In Main Driver         Capital Investment Support. Improve dend user productivity and security of standards, and improve/provision compatibility with new technology.           1. Qualitative and Quantitative Analysis of Project and Project Alternatives         Ensure that security is current as well as take advantage of new technology interoperability of existing systems.           2. Safety         Not Applicable.           3. Cyber-Securit


			Project Code		Report Star	t Year		Number of Ye	ars	Scale	
Power Stream			10	3204		2015			6	Do	llars
Project Summary	Project Summary Report		Project Name		<u>MSBPI M</u>	icrosoft	Busine	ess Product	ivity softwa	<u>re</u>	
	2011	2012	2013	2014	2015	2	2016	2017	2018	2019	2020
Expenditures Historical/Planned	\$-	\$ -	\$ -	\$ -	\$ -	- \$	10,000	\$ 60,000	\$ 899,999	\$ 50,000	\$ 10,00
	\$1,000,00 \$900,00 \$800,00 \$700,00 \$600,00 \$500,00 \$400,00 \$300,00 \$200,00 \$100,00	00									
	ې. بې	2011	2012	2013	2014	2015	201	6 2017	2018	2019	2020

	Pr	roject Code		Report Start Year	Number of Years	Scale
Power Stream	7	102	2169	2015	6	Dollars
Project Summar		roject Name		Phone System Enh	ancement Upgrade	
Major Category	General Plant					
Project Overview						
1. Additional Information	Service Territory		PowerStream	North & South		
	Location		PS North and S	South		
	Scope		The scope of the	nis project is to implement a co	omplete Phone System Enhanc	ement Upgrade.
	Justification			lity is required to support busi		
				ching 5 years old at the time th	e new system is implemented	
2. General Project Information (OEB)	Contributed Capital		Contributed Ca	apital 0%		
	Fiscal Year		2019			
	Parent WO#					
	Job Number					
<ol> <li>General Information on the Project/Activity (OEB)</li> </ol>	Risks to Completion and Risk M	lanagement		cidents. Full Implementation		
	Comparative Information on E Historical Projects (if any)	quivalent	A similar system handsets.	m upgrade was completed in 2	013 at a cost of \$380,000 but o	lid not include phone
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0			
1. Evaluation Criteria (OEB)	Project Summary		recommendati	compasses the hardware and sons for 2018 telecommunication of additional phore	ons planned review. This will	
	1a. Main Driver		supportability PowerStream's Management. PowerStream is support the bu	ice. At time of implementation (purchased and rolled out in 20 s business as it provides the ma Any downtime would effect th needs to ensure the system is o isiness. Also needs to be able to work from home solution.	013) - 5 years in production. T ain contact center for custome ne way PowerStream commun current, supportable and main	he phone system is central to rs as well as Outage icate with them. tains enough capacity to
	1b. Priority and Reasons for Pri	iority	it goes down, I	rates this as a high priority for a PowerStream would have to ac eam would have no choice but	tivate external support. If the	system couldn't be internally
	1c. Qualitative and Quantitative Project and Project Alternative			ernatives exist to allow for an o n fails, but would run the risk o		_
	2. Safety		Not Applicable			
	3. Cyber-Security, Privacy		Not Applicable			
	4. Coordination, Interoperabilit	ty		ll ensure the new system is abl rStream will need to ensure sca		
	5. Economic Development		Not Applicable			
	6. Environmental Benefits		Not Applicable			
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothing	g" Option	system. Howe	is not a feasible option as the c ver, if PowerStream did not up of phone system outage.		
	Net Benefits of Project in Mone (where practicable)	etary Terms				

_ Power			Project Code		Report Sta		I	Number of Yea		Scale			
Stream 📹			102	2169		2015			5	Do	llars		
Project Summary Report			Project Name	Project Name Phone System Enhancement Upgrade									
	2011	2012	2013	2014	2015	20	016	2017	2018	2019	2020		
Expenditures Historical/Planned	\$ - \$	\$-	\$ -	\$-	\$	- \$	-	\$-	\$-	\$ 50,500	\$ 908,9		
	\$1,000,00	0											
	\$900,00												
	\$800,00	0											
	\$700,00	0											
	\$600,00	0											
	\$500,00												
	\$400,00												
	\$300,00												
	\$200,00												
	\$100,00	0											
	\$ -	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020		

	Project Code	2	Report Start Year	Number of Years	Scale
Power Stream	1	02009	2015	6	Dollars
Project Summar	Project Nam	e	Storage Exp	ansion (Data)	
Major Category	General Plant				
Project Overview					
1. Additional Information	Service Territory Location Scope	Cityview & Ad	North & South discott or data storage growth (in Prod	uction and DR environment	:s)
	Justification	PowerStream data and new PowerStream technology an PowerStream Beyond simple data writes an data growth, I easy means for With that, the 1. Provide app in the near fut Force Manage 2. Provide app of the existing 3. Provide a so planned and u 4. Continue to SAN and their 5. Provide SAN Data growth. Moore's Law s accurate since PowerStream each year to r every 2 years drops by roug	systems is in line with industry IS must provision data storage d pricing of technology change IS plans and expands this data y providing storage space, other ad retrieval, Tools to manage the High level of uptime and available or Business Continuity. primary objectives of Storage I propriate SAN data storage capa ture (i.e. Customer Information ement System, to highlight the to propriate SAN data storage capa systems currently on the SAN calable disk storage system to su implanned Systems o provide Disaster Recovery and respective Corporate data that N specific monitoring and mana states that computer technolog e 1975. Based upon that comput purchased a SAN (in 2013) that neet business data growth require with the price remaining the sa	te data. PowerStream's dat average of 50% per year, th infrastructure to meet this is a drastically from year to ye as required - as opposed to factors are required, such e data effectively, minimizin ility, minimize impact in a D expansion are; acty and performance for th System, Asset and Inventor op four items) actiy and performance to act (i.e. email, GIS, OMS) apport PowerStream's annu Business Continuity of all k these systems contain. gement tools to manage the y will double every 2 years, ter hardware is a very perist was scalable with plans to irements. Historically, comp me, the year over year price	a growth rate through additional his entails that each year growing demand. Because ar, it is most effective it provisioning for future years. as; Optimum performance of ng excessive and unnecessary Disaster scenario, and provide an the key Strategic initiatives coming by Management System & Work commodate organic data growth hal growth rate, as well as new ey systems on the e SAN System and specifically this was stated and has proven hable commodity, therefore purchase required hardware buter hardware has doubled
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year	2015			
	Parent WO#	309881			
	Job Number	C13056			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemen		e completion of this project hav	e been identified.	
	Comparative Information on Equivalent Historical Projects (if any)	Not Applicable	e.		
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			

	Project Code		Report Start Year	Number of Years	Scale
Power	10	02009	2015	6	Dollars
Stream	Project Name	2			
Project Summar		-	<u>Storage Exp</u>	ansion (Data)	
4. Evaluation Criteria (OEB)	Project Summary	Every compo	nent of PowerStream's Corpora	te Infrastructure has at leas	t one touch point to the SAN
		allocated stor Operating Sys space on the logs generate From an Infor systems can o saved for futu point to the S System is allo Operating Sys	hange but customer data, mete ire use. Every component of Po AN (Storage Area Network - a c cated storage space on the SAN stem (OS) files and the data. Eve are allocated storage space on	r the "data" only, or as well ery user within PowerStream any system, emails that ar ed in the SAN. corporate data is our most er data, grid data, once colle werStream's Corporate Infr entralized system of Storag , either for the "data" only, ery user within PowerStream	as including the Server n is allocated and uses storage e sent and received, as well as valuable and irreplaceable asset ected must be safeguarded and astructure has at least one touch e devices, i.e. Hard Drives). Each or as well as including the Serve n (including contractors, summer
		curve. The ind volume of da are following increase this PowerStream 2013. This SA organic growt in 2013 it was meet busines	s initially sized to successfully m s growth through 2018 based u l is to purchase data storage sp	s listed at 50% year on year seeable future. PowerStread e. Other factors, such as ne new state-of-the-art SAN in able to serve PowerStream past associated data growt eet business growth throug pon IS adding the necessary	r; This translates into a large m data metrics show that they w initiatives or mergers could n 2013 robust SAN solution in for 5 years based upon current h rate. When purchasing the SAN h 2014, to have the scalability to
	1a. Main Driver		ment Support.		
	1b. Priority and Reasons for Priority	Not Applicabl	e.		
	1c. Qualitative and Quantitative Analysis of Project and Project Alternatives	of Not Applicabl	e.		
	2. Safety	Not Applicabl	e.		
	3. Cyber-Security, Privacy	Not Available			
	4. Coordination, Interoperability	Not Applicabl	e.		
	5. Economic Development	Not Applicabl	e.		
5. Category-Specific Requirements for Each Project/Activity (OEB)	6. Environmental Benefits Impact of Deferral/"Do Nothing" Option	hampered. As		conflict with regulatory con	
	Net Benefits of Project in Monetary Terms (where practicable)	obligations as	s well as maintain or improve its oft Financial Benefits 00 00 82 47		
		to having suff accesses and critical to the	icient access to system data du created business data ever wor daily operation of the business help perform their daily job fu	e to Storage Expansion. Eve king day. Many of the syste , and the above estimate is	



		Project Code	Report Start Year	Number of Years	Scale
Pov Strea	ver	102263	2015	6	Dollars
Project Su	mmary Report	Project Name	Work Force Mana	agement / Mobile Dispato	<u>h</u>
Major Category	General Plant				
Project Overview 1. Additional Information	Convice Territory	Doworftroo	m North & Couth		
1. Additional information	Service Territory Location		m North & South m North & South		
	Scope			g AM/Mobile/WFM/AA&PO Solu	tion Powerstream does not have
		an enterpris to house sp multitude o Executive C This informa scheduling t Field/Trade day. There information that is occu optimal reso new Custon	se workforce or work flow m ecific project information an f ways including Access Data onsole is used to provide pro ation is used upon project cl that is done is completed usi s Supervisor's desk and they is little communication or in i is limited and difficult to pu rring. Productivity is lost thr ource allocation. It was ide	anagement solution. JDE in com d work instructions. Work proce base, JDE, CIS, Excel and FileNex oject costing and resource usage osing but reviewed minimally the ng Excel and/or Microsoft Project manually sort through and decide formation available while a project t together to get insight and cor ough unnecessary extra field trip ntified during the discovery pha oftware cannot support the wor	abination with FileNexus is used ess flow is managed through a sus. JDE in combination with information on specific projects rough project execution. Any ct. Much of the work lands on t de which projects go on which ect is executing and resource strol around much of the work os, scheduling errors and less the se of the New CIS project that the
		Services. Th place. Wit a mobile we solution use Mobile GIS; books or lap receives the FileNexus a information time spent a installations computer b being recor- are then bro spreadshee information	his is planned to be a short to the respect to mobile dispatch preforce solution and has use as handheld field devices. Or Mobile DigSmart; Mobile Re ptops. Since PowerStream d bir work instructions through and have to be printed out. To a on projects may or may not and vehicles used on the pro- s and replacements is done to ased in put of the required in ded. Staff report findings or bught into the office and entit ts. The information, once entities the solution of the required in the solution of the sol	p a portion of the T&W running erm (2-3 years) solution until a p and reporting, PowerStream has ed the solution for implementing ther uses of mobile have been o esponder. These implementation oes not have a mobile workforce paper. Work instructions are en the paper is taken to the field for e be available depending upon to jects using paper time sheets. In hrough the AEx, which is a new in formation. There are still a nur inspections or outages etc. on to ered by various staff into JDE, G intered into the systems, is somet a difficult to find, difficult to pull	ermanent solution can be put in as made an initial investment int as made an initial investment int as mart meter deployment. The r are being implemented - e.g. hs are through the use of tough e solution, most of the workforce netered into JDE and /or filed in r staff to review. Additional what was printed. Staff report information about material in-house designed tool to allow mber of installations that are no various paper forms. The forms IS, Responder or Excel times entered incorrectly. The
	Justification	identified fo Asset Mana Optimizatio and process the predece Database, p manageable With increa Second - the the executio workforce r efficiencies regulatory o levels. In ou	bur solutions to be considered gement; Mobile Workforce; n. There are three main dr ses in place are combined systems assor utilities well. As smalled aper, etc. to manage assets a and the number of people sed staff, assets, projects, are e regulatory environment are on of the work. Specific targ nanagement and processes/ can be gained through the in- environment is placing increa- rder to provide sophisticated	trategy. It was updated in 2012 d for implementation over 2014 Workforce Management; and As ivers for changing the status quo stems and practices from predec r utilities using programs such as and work, it was easier as the vo involved in the process needing d geography those tools are no d customers demand that utilities ets are set by the regulator for in systems for data capture and an nplementation of new systems as ased demands for solid analytics I analytics, new tools and process ble, and to aid in the efficient ar	& 2015. These solutions were seet Analytics and Project b. First - the current systems ressor utilities. They have served s Excel, Microsoft Project, Access alume of data and work was more access to the data were fewer. longer viable to be used. es continue to gain efficiencies i mproved efficiencies. Improved alytics is an area where and processes. Third - the in defending appropriate spend ses are required to ensure

	Project	Code	Report Start Year	Number of Years	Scale
Power	5	102263	2015	6	Dollars
Sircum	Project	Name			
Project Summary	/ Report		Work Force Manager	<u>ment / Mobile Dispatch</u>	
		subsequently there is a nee Management, the current sy FileNexus, Exc information c multiple of wa information m with one sour times, and op be defined as allocate, sche crew/individu solution that solution woul emails upon s System to aut	estems in these areas are largely cel and Access Databases for W an be entered in multiple syste ays through the implementatio nultiple times, reduced number ce for project information; incr	entation plan. As a result of the sware and implement new pro- bile Dispatch and Mobile Repor- y paper based. There is some of orkflow Management. The sys- ms. It is believed that efficien n of new technology. These in of process steps and wait time eased efficiency in crew sched small gaps of time with approp- technology solution that enable s. The solution would include on of the work. Workflow M project through various stage or project information & allow t WFM The ability to interface w lution includes the ability to vi	his work it was identified that cesses for Workforce rting. This work is of priority as use systems of JDEdwards, items are not integrated and encies can be gained in a clude: reduced input of es in the execution of work uling with optimized drive oriate work. These pieces can es resource managers to the ability to report on anagement A technology s, milestones & triggers. The he sending of automatic with the Work Management iew work instructions
2. General Project Information (OEB)	Contributed Capital	Contributed C	Capital 0%		
	Fiscal Year Parent WO#	2015 311271			
	Job Number	C14042			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manage	implemented and Customer OMS. Change required to su PowerStream phased in ove undertaken in company, has to assist the P and benefits. team to unde as well as less with clearly de documented i management		everal Departments, particular to integrate with other enterpre- for employees to adapt to the prudent approach to this proje- tation commencing in 2015. Pl ct Team, comprising key stake Governance model is in place. tion and analysis of needs, opp t matter expert in the WFM fie d weaknesses of various solut implementations. A detailed p d timelines. Existing business p treamlining and automation w	y Lines, Metering, Engineering, rise systems, such as JDE and new tool. IS resources will be ect. The WFM tool will be anning activities are being holders from across the A consultant will be engaged bortunities for improvement, hd, and will also assist the ions available on the market, roject plan will be prepared brocesses are being vill be explored. A change
		project, as it e Mobile techno part of the Wi initiatives. IS r	FM Project Team. This ensures	unication with field resources. WFM project, and key leaders of that there is alignment of goal roject Team, which will ensure	The implementation of of the Mobile initiative are also s and activities of the two that IS resources are available
	Comparative Information on Equival Historical Projects (if any)	including SCA	has successfully managed the i DA, Outage Management Syste ertaking an upgrade to its ente	m, GIS, and the C55 Optimiser	system. PowerStream is
	Total Capital and OM&A Costs for Renewable Energy Generation portic Projects (if any)	0 on of			

	Project C	Code	Report Start Year	Number of Years	Scale
Power Stream		102263	2015	6	Dollars
	Project N	Jame			•
Project Summary	/ Report		Work Force Manage	ment / Mobile Dispatch	
4. Evaluation Criteria (OEB)	Droject Summery		Project will include the following	functionality	
4. Evaluation Chiena (GEB)	Project Summary	•©ompute •Electronic •Real-time •Tracking c •Electronic	rised tool to schedule jobs and al c dispatch of jobs to field crews; tracking of jobs while in progress of crew schedules and performan c recording and transmission of fie on of processes such as timekeep	ocate resources, with the ability ;; ce; eld data;	v to automate some functions
	1a. Main Driver		estment Support. Process impro resource allocation and job sched s.		
	1b. Priority and Reasons for Priority	at PowerSt with resou workflow p computeri allow jobs provide ins	t is ranked as high priority becau tream has reached levels where a rce allocation, job scheduling, an processes are primarily manual, la sed tool will facilitate process aut to be scheduled (or rescheduled) sight into how work is carried out nalysis into how productivity can	computerised tool is required t d dispatch. At present, these act bour-intensive, and paper-base omation, streamlining, and imp and dispatched more efficiently into the field and provide data	o assist resource managers civities and associated d. The implementation of a rovement. The new tool will y. The WFM system will also
	1c. Qualitative and Quantitative Analy Project and Project Alternatives	intensive v work woul	ative to this project is to maintair vorkflow, resource allocation, and d continue to be not readily avail owerStream would forego the op	scheduling processes. Data on able. Maintaining the status que	how field crews carry out o is not considered acceptabl
	2. Safety	throughou computers wellness. I	t will not have an adverse impact t the project, and particularly for will be mounted in vehicles in a n addition, technical options are while the vehicle is in motion.	the Mobile aspects of the proje manner that is not detrimental	ct. For example, field to employee safety or
	3. Cyber-Security, Privacy	The WFM sand CIS. Is	system will be a critical system th sues of cyber-security and privacy ly with IS and the successful venc	are therefore of critical import	ance. The Project Team will
	4. Coordination, Interoperability	Not Applic	able.		
	5. Economic Development	Not Applic			
	6. Environmental Benefits		ental benefits are anticipated, in t ue to route optimisation. Specific		
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothing" Opti	on Continue t	o rely on existing manual, labour and forego the opportunity to rea		
	Net Benefits of Project in Monetary To (where practicable)	quantified - reduced t - productiv	t is expected to yield net benefits as part of the 2014 Planning pha time spent on allocating resource vity gains in the execution of field fuel costs due to route optimisati	se. Expected benefits include: s and scheduling jobs; work;	ficiency. These benefits will b

			Project Coo	le	Report Start Y	ear	Number of Yea	ars	Scale			
Power Stream				102263	20	015		6	Do	lars		
Project Summary Report			Project Nai	Project Name Work Force Management / Mobile Dispatch								
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020		
Expenditures Historical/Planned	\$-	\$ -	\$	- \$ -	\$ 1,605,000	\$ 2,675,000	\$ 802,500	\$ 802,500	\$ 535,000	\$ 535,000		
	\$3,000,0	000										
	\$2,500,0						<b>.</b>					
	\$2,000,0	000										
	\$1,500,0	000										
	\$1,000,0	000										
	\$500,0	000										
	\$		1									
		201	1 201	2 2013	2014	2015 20	16 2017	2018	2019	2020		

<b></b>			Doport Start Voor	Number of Verse	Scale
<b>D</b>	Project Code	2	Report Start Year	Number of Years	Scale
Stream 📹	1	04022	2015	6	Dollars
Project Summary	Project Nam	e	Barrie Building Ren	ovation Project 2015	
Major Category	General Plant				
Project Overview		PowerStream			
	Service Territory Location Scope	Patterson faci became part of building, cons square feet of make up of th The interior sy office spaces a Offices and w locations. Fu	his project is to implement a re lity in Barrie. The Patterson Ro of PowerStream's facility portfo tructed approximately 20 years two-story office space togethe e Addiscott-Markham facility. baces require a reconfiguration as well as the quality of the inte orkstations at Patterson are not rniture is general older, with so	ad facility operates as the Nor lio as a result of the 2009 merg ago on a 15.8 acre site, compr r with 41,000 square feet of ind and a "facelift" to improve the rior environment. constructed to the same stand me being hand-me-downs for	th Operations Centre. It ger with Barrie Hydro. The rises an estimated 40,832 dustrial space. similar to the e overall functionality of the dards as other PowerStream other facilities. This should
		those in other Technology ar Meeting room In updating th South Operati are aligned th that all teams renovation pla	to provide uniformity, and ensu PowerStream buildings. Ind connectivity in the Barrie off as are not fully equipped and th e Patterson building, it will creat ons Centre at Addiscott - Markl rough the facility portfolio. Th are working within a defined sp ace also provides for future gro to a 3rd party which will allow f	ice is considered to be below P ere are no formal hotelling sta ate an environment that is com nam. This will ensure all Powe e goal is to improve the space bace and not dispersed through wth. The renovation will allow	PowerStream standards. tions in the building. nparable in quality to the erStream work environments utilization and efficiency so hout the building. This v for the leasing of space on
	Justification	estimated 40, space, and is s engaged to pr Business Case would assist in Construction	building was constructed appressed 832 square feet of two-story of similar in make up to PowerStre epare the high level construction. A formal tender was conduct in the design and overall project Resources was the successful bi rawings and confirm PowerStre	fice space together with 41,000 am's Addiscott Court, Markhar on estimate documents that we ed to obtain a Construction Ma management of the renovatio dder. Part of Compass's Scope	D square feet of industrial m facility. CRESA was ere submitted in the original anagement company that on project. Compass
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year Parent WO# Job Number	2015			
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemen		mpletion have been identified. actor is in place. All work requi		
	Comparative Information on Equivalent Historical Projects (if any)	Not Applicabl	e. No other PowerStream own	ed building has been renovate	d to this extent.
	Total Capital and OM&A Costs for Renewable Energy Generation portion of Projects (if any)	0			
4. Evaluation Criteria (OEB)	Project Summary	Not Applicabl			
	1a. Main Driver	Capital Invest	ment Support		

			Project Code		Report Start Y	ear	Number of Yea	rs	Scale	
Power Stream	-		10	4022	20	)15	e	5	Do	llars
Project Summary	y Report		Project Name		<u>Barrie E</u>	uilding Ren	ovation Proj	ect 2015		
	1b. Priority and	1 Reasons for F	'riority	are not constru- with some han ensure that sta secondary acti conditions of t complete the a mechanical up This would min would also brin	ucted to the sa ad-me-downs fr aff in this buildivity was also un he current med analysis and ma grades require himize rework in ng forward rep	me standards as om other facilit ng is being treat ndertaken along hanical and ele- ke recommend d that should be n the years to co airs and upgrade	other PowerStr ies. This is bein ted the same as with the renov ctrical systems of ations. It was de made in conne ome after the or es that would ha	ream locations g addressed to those in other ations, to revie of the building. etermined tha ction with the riginal renovat ave been requi	nd workstations Furniture is ge provide unifor PowerStream k wand determin MMM Group v at there were sig current building ion has been co red as stand-alc n completed an	enerally old mity, and puildings. A ne the exist vas retained prificant g renovatio mpleted, ar one projects
	1c. Qualitative Project and Pro 2. Safety			f Not Applicable New updated		ation systems a	re being added a	and security sy	stems being up	graded, wh
<ol> <li>Cyber-Security, Privacy</li> <li>Coordination, Interope</li> <li>Economic Development</li> </ol>		n, Interoperab	ility	should improv Not Applicable Not Applicable Not Applicable	 	y.				
	6. Environment Impact of Defe		ng" Option	The main alter the building.	native to this p This will impac	roject is to "do PowerStream's		would result i Excellence) as	ion. n no renovation s not all work loo	
				There is a pote utilization.	ential opportun	ity to lease extra	a space to a 3rd	party tenant a	is a result of bet	ter space
		able)								
		2012	2013	2014	2015	2016	2017	2018	2019	2020
xpenditures Historical/Planned	(where practica		<b>2013</b> \$ -		<b>2015</b> \$ 3,149,489		<b>2017</b> \$ -	<b>2018</b> \$ -	<b>2019</b> \$ -	<b>2020</b> \$
xpenditures Historical/Planned	(where practica	<b>2012</b>	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practical       2011       \$     -	<b>2012</b> \$ -	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practical 2011 \$ - \$ \$3,500,000	<b>2012</b> \$ -	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practical 2011 \$ - \$ \$3,500,000 \$3,000,000	<b>2012</b> \$ - 0 -	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practical 2011 \$ - \$ \$3,500,000 \$3,000,000 \$2,500,000	<b>2012</b> \$ - 0	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practice 2011 \$ - \$ \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000	<b>2012</b> \$ - 0	<b>2013</b> \$ -							
xpenditures Historical/Planned	(where practical 2011 \$ - \$ \$3,500,000 \$3,000,000 \$2,500,000 \$2,000,000 \$1,500,000	<b>2012</b> \$ -	2013							


	Project Code		Report Start Year	Number of Years	Scale
Power Stream	10	)3358	2015	6	Dollars
Project Summar	Project Name		rious Light Duty and Me	dium Duty Vehicles ar	nd Equipment
Major Category	General Plant				
Project Overview					
1. Additional Information	Service Territory	PowerStream	North & South		
	Location	North and Sou	th Various Departments.		
	Scope		rious Light and Medium Duty ve rious Light and Medium Duty V		9.
	Justification	Vehicles are ex	xpected to meet PowerStream'	s replacement guidlines.	
2. General Project Information (OEB)	Contributed Capital	Contributed C	apital 0%		
	Fiscal Year	2019			
	Parent WO#				
	Job Number				
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Managemen				
	Comparative Information on Equivalent Historical Projects (if any)		ts are based on historical costs hicles are usually procured thro		sal) and after a thorough
	Total Capital and OM&A Costs for Renewable Energy Generation portion of	-	the bids, the contract is awarde		isal, and alter a thorough
	Projects (if any)				
4. Evaluation Criteria (OEB)	Project Summary 1a. Main Driver		of light duty vehicles. nent Support. Present vehicles Ids.	to be replaced have exceede	d either their mileage, hours,
	1b. Priority and Reasons for Priority	Not Applicable			
	1c. Qualitative and Quantitative Analysis of Project and Project Alternatives 2 Safety	1. Cars, SUV's Due for replac Maintenance of cost based on 2. Pick-Up Tru Due for replac Maintenance of cost based on 3. Miscellaneo Pole Trailers 2 Tension Mach Reel Trailer 15 Forklift 15 Yea Traffic Signals Loaders - Tech	and Passenger Vans: ement when vehicle reaches 24 cost for last three years. Also ta technical assessment. cks: ement when vehicle reaches 2' cost for last three years. Also ta technical assessment. us Class: 0 Years ine 15 Years Years rs – Technical Assessment on con inical Assessment on condition	iken into account is the project 75,000KM and shows an upwa iken into account is the project dition and estimated repairs.	cted Unscheduled Maintenanc
	2. Safety	Not Applicable			
	3. Cyber-Security, Privacy	Not Applicable			
	4. Coordination, Interoperability	Not Applicable			
	5. Economic Development 6. Environmental Benefits		e. y viable, the replacement vehic wards Environmental Benefits.		ergy saving technologies, whic
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothing" Option	While it is pos	sible to keep older vehicles in s of key components, eventually t	ervice almost perpetually wit	
	Net Benefits of Project in Monetary Terms	Not Applicable			

			Project Code		Report Start	t Yea <b>r</b>	Number of Ye	ars	Scale			
Stream			103	358		2015		6	Do	llars		
Project Summary Report			Project Name	Project Name Replace various Light Duty and Medium Duty Vehicles and Equipment								
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020		
Expenditures Historical/Planned	\$ -	\$-	\$ -	\$-	\$ -	\$-	\$ -	\$-	\$ 829,250	\$ 888,10		
	\$1,000,0	00										
	\$900,0	00										
	\$800,0	00										
	\$700,0	00										
	\$600,0											
	\$500,0											
	\$400,0											
	\$300,0											
	\$200,0											
	\$100,0 \$											
	د ا	201	1 2012	2013	2014	2015 2	016 2017	2018	2019	2020		

	Project C	Code	Report Start Year	Number of Years	Scale				
Stream	-	103357	2015	6	Dollars				
Shican	Project N	Name							
Project Summary	Report	<u>Repl</u>	ace various Single Buc	ket and Double Bucket	Line Trucks				
Major Category	General Plant								
Project Overview									
1. Additional Information	Service Territory	PowerStre	eam North & South						
	Location	North and	South Lines Dept						
	Scope	Replace 1	Replace 1 single bucket and 3 double bucket trucks in 2018. Replace 1 single bucket and 2 double bucket trucks in 2019. Replace 1 single bucket and 2 double bucket trucks in 2020.						
	Justification		re expected to meet our replace	cement guidlines.					
2. General Project Information (OEB)	Contributed Capital	Contribut	ed Capital 0%						
	Fiscal Year	2020							
	Parent WO#								
	Job Number								
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Manage	ment Not Appli	cable.						
	Comparative Information on Equivale Historical Projects (if any)		Estimated costs are based on historical costs of similar vehicles. High-dollar vehicles are usually procured through RFP's (Request for Proposal), and after a thorough						
		evaluation		varded to the preferred bidder.					
	Total Capital and OM&A Costs for Renewable Energy Generation portio Projects (if any)	0 n of							
4. Evaluation Criteria (OEB)	Project Summary	Replacem	ent of single-bucket and doubl	e-bucket line trucks.					
	1a. Main Driver	Capital Inv or age thr		hicles to be replaced have exce	eded either their mileage, hours				
	1b. Priority and Reasons for Priority	Not Applie	cable.						
	1c. Qualitative and Quantitative Analy	vsis of Replacem	ent Guideline						
	Project and Project Alternatives	Heavy Dut and show	Heavy Duty Vehicle: Due for replacement when the vehicle reaches 250,000KM or 12000 Engine Hours and shows an upward trend in Unscheduled Maintenance cost for last three years. Also taken into account is the projected Unscheduled Maintenance cost based on technical assessment.						
	2. Safety	Not Appli	cable.						
	3. Cyber-Security, Privacy	Not Applie	Not Applicable.						
	4. Coordination, Interoperability	Not Applie	Not Applicable.						
	5. Economic Development	Not Applie	Not Applicable.						
	6. Environmental Benefits		If economically viable, the replacement vehicle may incorporate hybrid energy saving technologies, whic could count toward Environmental Benefits.						
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothing" Opti			s in service almost perpetually v ally the cost to do so becomes e	vith additional maintenance and excessive.				
	Net Benefits of Project in Monetary T (where practicable)	erms Not Applie	cable.						

			Project Code		Report Star	t Yea <b>r</b>	Nu	umber of Yea	ars	Scale	
Stream		103357		2015			6		Dollars		
			Project Name <u>Replace various Single Bucket and Double Bucket Line Trucks</u>								
	2011	2012	2013	2014	2015	201	.6	2017	2018	2019	2020
Expenditures Historical/Planned	\$-	\$-	\$ -	\$-	\$-	\$	- \$	-	\$ 2,193,500	\$ 1,605,000	\$ 1,391,000
	\$2,500,00 \$2,000,00 \$1,500,00	00									
	\$1,000,00										
	\$500,00	00									
	\$ -	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020

	Ρ	roject Code		Report Start Year	Number of Years	Scale			
Power Stream	-	102	2247	2015	6	Dollars			
	P	roject Name							
Project Summar	y Report			Interest Ca	apitalization				
Major Category	General Plant								
Project Overview	General Flant								
1. Additional Information	Service Territory		PowerStream I	North & South					
	Location		PowerStream						
	Scope		As per IFRS Interest Capitalization is a requirement. This expenditure is to capture interest expense on capital spending that is in the work-in-progress stage before it finally put into production. Interest Capitalization - 2012 capitalized interest is based on capital spending of \$60,000,000.00, at interest rate of 4.0%.						
	Justification		According to accounting rules and OEB regulation, LDCs are allowed to capitalize interest expenses on work-in-progress projects before they are complete. Once the projects are complete interest capitalization ceases and depreciation commences.						
2. General Project Information (OEB)			Contributed Capital 0%						
	Fiscal Year		2015						
	Parent WO#								
	Job Number								
3. General Information on the Project/Activity (OEB)	Risks to Completion and Risk Management		Not Applicable.						
	Comparative Information on Equivalent Historical Projects (if any)		Not Applicable.						
	Total Capital and OM&A Costs Renewable Energy Generation Projects (if any)		0						
4. Evaluation Criteria (OEB)			As per IFRS Interest Capitalization is a requirement. This expenditure is to capture interest expense on capital spending that is in the work-in-progress stage before it finally put into production. Interest Capitalization - 2012 capitalized interest is based on capital spending of \$60,000,000.00, at interest rate of 4.0%.						
	1a. Main Driver		Capital Investn	nent Support					
	1b. Priority and Reasons for Pr	riority	Not Applicable						
	1c. Qualitative and Quantitative Project and Project Alternative		Not Applicable						
	2. Safety		Not Applicable						
	3. Cyber-Security, Privacy		Not Applicable.						
	4. Coordination, Interoperability		Not Applicable.						
	5. Economic Development		Not Applicable.						
	6. Environmental Benefits		Not Applicable.						
5. Category-Specific Requirements for Each Project/Activity (OEB)	Impact of Deferral/"Do Nothin	ig" Option	Not Applicable						
	Net Benefits of Project in Mon (where practicable)	letary Terms	Not Applicable						



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix B: OPA Letters Delivered: February 24, 2015



# Appendix B

## **OPA Letters**

Delivered: February 24, 2015

**Distribution System Plan** 



120 Adelaide Street West Suite 1600 Toronto, Ontario M5H 1T1

T 416-967-7474 F 416-967-1947 www.powerauthority.on.ca

June 14, 2013

Mr. Bing Young Director, Transmission System Development Hydro One Networks, Inc. 483 Bay Street Toronto, Ontario M5G 2P5

Initiating a Regional Infrastructure Planning Process for Near-Term\_Transmission Projects in York Region

Dear Bing:

The purpose of this letter is to:

- Request that Hydro One initiate a Regional Infrastructure Planning (RIP) process to develop and implement the near-term transmission component of the integrated plan to meet the near- and medium-term reliability needs of York Region.
- Hand off from the Ontario Power Authority (OPA) the lead responsibility for the planning process associated with the near-term transmission component of the York Region Integrated Regional Resource Planning (IRRP) process to Hydro One to initiate the RIP process.

This is consistent with the regional planning process endorsed by the Ontario Energy Board (OEB) as part of its Renewed Regulatory Framework for Electricity.

The York Region Working Group (Working Group), consisting of staff from the OPA, the Independent Electricity System Operator (IESO), Hydro One and the York Region local distribution companies, has been conducting an IRRP process for York Region. In combination with conservation and local generation options, the Working Group has identified two transmission projects for meeting the reliability needs of the area for the near and medium term. These projects are located at Holland TS, and along the Parkway Belt transmission corridor.

The Working Group has identified these projects for near-term implementation and has discussed preliminary options. However, more detailed study and development work is required before these projects can be implemented. Continued development of both projects is best accomplished through Hydro One's RIP process, guided by the information and requirements provided below from the IRRP process.

The objectives and scope of these two projects are provided in Attachment 1.

1

To facilitate the transition to the RIP process, the OPA will provide Hydro One with the following information:

- Relevant system base cases
- Demand forecasts
- Conservation and distributed generation forecasts
- Any other relevant information

We look forward to information, results and deliverables from the York Region near-term transmission projects, as part of the York Region Working Group activities, and to continuing to work with and support Hydro One on the implementation of these projects.

Best Regards,

Bob Chow Director, Transmission Integration Power System Planning Division Ontario Power Authority

CC York Region Working Group members:

**PowerStream** Irv Klajman Richard Wang Riaz Shaikh

Newmarket-Tay Power Larry Herod IESO Peter Drury

Paul Cook

Hydro One Networks

Farooq Qureshy

E. Warren King

Peter

Hydro One Distribution Charlie Lee OPA Nicole Hopper Bernice Chan Alexandra Barrett Kun Xiong Joe Toneguzzo

### Attachment 1 – Project Objectives and Scope

#### Holland TS Project Objectives:

The objectives of the Holland TS project are as follows:

- To increase the load-meeting capability of the Claireville-to-Brown Hill transmission line (B82V/B83V) to accommodate forecast load growth in northwest Vaughan and northern York Region in the near and medium term, and the connection of Vaughan #4 MTS, a new load supply station planned to be in service in spring 2017.
- To improve the capability to restore customer loads in northern York Region following a major outage affecting the main B82V/B83V transmission line, in accordance with the IESO's Ontario Resource and Transmission Assessment Criteria (ORTAC).

#### Holland TS Project Scope:

The Working Group has discussed options for meeting the above objectives and recommends proceeding with the following measures:

- Installation of two in-line breakers and associated motorized disconnect switches on the B82V/B83V circuits at, or near, the Holland TS property.
- Design and implementation of a Load Rejection (L/R) scheme for the stations connected to the B82V/B83V transmission line, or have available operational measures adequate for providing similar relief, as permitted by ORTAC.

Based on technical studies by the Working Group, with the addition of the in-line breakers and implementation of the L/R scheme described above, a load-meeting capability of 750 MW can be achieved for the system consisting of the B82V/B83V circuits and local generation (York Energy Centre). The switching facilities will also enable fast isolation of faulted line sections and allow restoration of customer loads, with York Energy Centre as a local supply source, following a major outage on the main transmission line, in accordance with ORTAC.

Hydro One will confirm the scope and cost of the above facilities to meet the identified reliability needs and to optimize their specifications and configuration.

Initiating these measures through the RIP process will allow restoration criteria to be met and provide sufficient capacity to supply forecast net load growth in Vaughan and northern York Region for the near and medium term. In the longer term (2020-2025 based on current load forecasts), the Working Group recognizes that a solution will be needed to support continued load growth in York Region and is planning engagement with affected communities, Aboriginal communities, and stakeholders on a long-term York Region Integrated Regional Resource Plan (IRRP).

The Holland TS project is needed in northern York Region to meet ORTAC restoration criteria today. In addition, it will be necessary to coordinate the development of this project with the connection of Vaughan #4 MTS to ensure there is sufficient capacity to supply this station when it connects in spring 2017. Therefore, the Holland TS project should be targeted to be in service by spring 2017.

#### Parkway Belt Project Objectives:

The objective of the Parkway Belt project is to improve the reliability of supply to customers supplied from the 230 kV "Parkway Belt" circuits (V71P/V75P), specifically in the following areas:

- To enable the Parkway Belt to meet ORTAC's 600 MW load security limit. Currently, the amount of load that could be lost by configuration in a double-circuit contingency exceeds 700 MW during peak demand conditions.
- To enable customer loads supplied from the Parkway Belt circuits to be restored following a major outage affecting the V71P/V75P circuits in accordance with ORTAC.

#### Parkway Belt Project Scope:

There are a number of options for meeting the above objectives, including a new switching station or line option, and the optimal solution has not been determined at this time. Development work, as part of the RIP, is required to assess the feasibility, cost and development timelines of the various options before the project can be fully scoped. There may be potential for a coordinated transmission and distribution solution.

This project is needed to meet ORTAC load security and restoration criteria today. As the project scope has yet to be defined, the in-service date will be established in accordance with the development timeline for the selected option.



120 Adelaide Street West Suite 1600 Toronto, Ontario M5H 1T1

T 416-967-7474 F 416-967-1947 www.powerauthority.on.ca

December 14, 2012

Mark Henderson EVP Asset Management and Chief Operating Officer PowerStream Inc. 161 Cityview Boulevard Vaughan, Ontario L4H 0A9

Dear Mr. Henderson:

#### RE: Siting Vaughan #4 MTS for connecting to the Claireville-Minden line

The purpose of this letter is to support the York Region Working Group's ("Working Group") choice of the option to connect PowerStream's next transformer station in Vaughan ("Vaughan #4 MTS") to the Claireville-to-Minden line (B82/83V).

In early 2011, a Working Group, consisting of representatives of the Ontario Power Authority (OPA), the Independent Electricity System Operator (IESO), Hydro One Networks, Hydro One Distribution, PowerStream and Newmarket-Tay Power, was established to assess electricity reliability in York Region over a 20-year period. The Working Group has confirmed the need for a new transformer station in the Vaughan area to supply load growth in southern York Region.

While planned conservation and distributed generation are expected to offset over 30% of forecast load growth in this area, the remaining net load growth is expected to exceed the combined capacity of the existing stations in and around Vaughan by 2017. An acceptable transmission supply point must be determined as soon as possible.

Based on the existing system configuration, the Working Group identified three potential transmission supply points for Vaughan #4 MTS: the Parkway-to-Claireville line, the Kleinburg Tap, and the Clairevilleto-Minden line, as shown in Figure 1.

From a distribution perspective, the Claireville-to-Minden supply point is preferred because the centre of forecast load growth to be supplied by the new station is near the northern boundary of the City of Vaughan. The Claireville-to-Minden line passes directly through this area, allowing the station to be ideally located to




Figure 1. Potential Supply Points for Vaughan #4 MTS

minimize distribution system expansion. PowerStream's staffs have indicated that suitable sites for the new transformer station near the Claireville-to-Minden corridor have been identified. The Parkway-to-Claireville line and the Kleinburg Tap are respectively located approximately 10 km to the south and 6 km to the west of this area of growth. Siting Vaughan #4 MTS near these supply points would require extensive and costly distribution expansion in areas with limited available road allowances.

All three of the potential supply points have limitations that would prevent them from supplying a new station without transmission system reinforcement. With this understanding, the Working Group considered the connection of Vaughan #4 MTS in the context of the long-term integrated plan for York Region. In addition to Vaughan #4 MTS, a new transformer station is forecast to be needed in Northern York Region around 2020, and two additional stations in Markham and Vaughan are forecast for the longer-term (after 2020). Planning, stakeholder engagement and development of a long-term solution to meet these combined capacity needs will require several years' lead time, so to respect the expected in-service date of Vaughan #4 MTS the Working Group considered means to leverage the existing system to meet the near-to-medium term needs of the area.

In the near-to-mcdium term, York Energy Centre (a new single-cycle peaking generation plant identified as part of a 2005 Integrated Plan for Northern York Region, which came into service in Spring 2012) will provide additional supply capacity on the Claireville-to Minden line and improve the reliability of supply to customers in Northern York Region. In order to fully realize the capacity and reliability benefits of York Energy Centre, additional station facilities, including switching facilities at Holland TS, would need to be installed. These proposed facilities would need to be in service in time for the connection of Vaughan #4 MTS on the Claireville-to-Minden line in 2017.

The Working Group also understands that a longer term solution will be needed to support continued load growth in York Region and the intention to move ahead with stakeholder engagement on a long-term York Region Integrated Electricity Plan.

Best Regards,

Spole

Amir Shalaby Vice President, Power System Planning Ontario Power Authority

CC Kristin Jenkins, Mike Lyle, Bob Chow, and Nicole Hopper, OPA Bing Young and Farooq Qureshy, Hydro One Networks Barbara Constantinescu and Peter Drury, IESO Larry Herod, Newmarket-Tay Power Charlie Lee, Hydro One Distribution

EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix C: Distribution System plan Review - Residential Delivered: February 24, 2015



# Appendix C

## Distribution System Plan Review - Residential

Delivered: February 24, 2015

## DISTRIBUTION SYSTEM PLAN REVIEW PRIMER



PowerStream is a community-owned energy company providing power and related services to more than 370,000 customers residing or owning a business in Alliston, Aurora, Barrie, Beeton, Bradford West Gwillimbury, Markham, Penetanguishene, Richmond Hill, Thornton, Tottenham and Vaughan as well as Collingwood, Stayner, Creemore and Thornbury through a partnership with the Town of Collingwood in the ownership of Collus PowerStream.

## Table of Contents

Why Are We Here? Electricity Grid 101 PowerStream's Grid Today Challenges and Solutions What this Plan Means for You Final Thoughts Glossary



## Planning for Future Energy Needs

This primer and consultation concentrates on the short-term plan for PowerStream's distribution system over the next five years. The graphic below shows the various planning initiatives ongoing within the Province. In addition to the short-term distribution plan being discussed in this primer, there are other planning initiatives undertaken to ensure that the electricity system maintains reliability and works efficiently for the benefit of customers.

Energy planning occurs at the provincial level (by the Ministry of Energy and government agencies such as the Ontario Power Authority) and at the regional and municipal level as well as by each electricity distributor for their service territory and relevant agencies.

If you're interested in broader medium and long term electricity issues such as Ontario's Long-Term Energy Plan, regional planning, conservation planning and general energy policy in the province, there are other opportunities to provide your feedback.


#### **Ontario's Long Term Energy Plan:**

The Ontario Government's plan details how electricity will be generated and the longer-term conservation strategy for the province. It can be found at this website: <a href="http://www.energy.gov.on.ca/en/ltep/">http://www.energy.gov.on.ca/en/ltep/</a>

#### **Regional Planning:**

The Ontario Power Authority (OPA) looks ahead to the future electricity needs of your region and how those needs can be addressed through Conservation and Demand Management (CDM), local generation, and electricity from outside the region. You can follow the OPA's regional planning process at this website: http://www.powerauthority.on.ca/power-planning/regional-planning

### **Ontario's Energy Planning Diagram**



local generation options have been

considered, in addition to core

infrastructure ("wires") solutions

## Why Are We Here?

The electricity industry in Ontario is regulated by the Ontario Energy Board (OEB), which requires distribution companies, such as PowerStream, to prepare and submit a distribution system plan to show how it will sustain the area's electricity distribution system over the next five years.

The OEB recently developed a new regulatory requirement for distribution system plans that requires distribution companies, to gather information about customer needs and preferences on distribution system investments and report on how they responded. PowerStream needs your participation to ensure its plan addresses your needs and expectations.

## You don't have to be an electricity expert to participate

This consultation is not about technical issues. The OEB hearing process will allow experts representing various consumer and interest groups (called intervenors) to challenge the detailed engineering and business decisions within PowerStream's plan. This consultation focuses on the goals of the system. Should PowerStream focus more on reducing the number of outages or the lengths of outages? Should reliability be increased even if rates go higher, or should PowerStream maintain the current level of reliability and keep rate increases lower?

This primer has been developed to guide you through PowerStream's plan. As you proceed, it asks questions designed to collect your feedback. In order to facilitate this, the primer is divided into several sections that explain the distribution system, the challenges it faces and, more importantly, how PowerStream will be responding to those challenges.

Your input, and PowerStream's response to your input, will be presented to the OEB and intervenors when PowerStream files its rate application for 2016 to 2020 in the spring of 2015.

**Innovative Research Group Inc.** has been engaged by PowerStream to collect participant feedback and will deliver it to PowerStream to assist them in shaping their plans.

forecasting

design

Interconnections and grid

### PowerStream's Rate Application Process

PowerStream assesses system needs

## Collects customers needs and preferences

Refines plan (where necessary)

Reports on how plan responds to customer input

Files plan with OEB

Interrogatories and OEB rate hearing process

OEB sets PowerStream's distribution rates

## Your Electricity Bill

Every item and charge on the bill is mandated by the provincial government or regulated by the OEB. There are two distinct cost areas that make up the "Delivery" charge on your bill: distribution and transmission. While PowerStream collects both, it remits the transmission charge to Hydro One. The distribution charges are what PowerStream uses to fund its utility needs.

Distribution charges are one of several charges on your bill. Current monthly distribution charges are approximately \$27 for a typical PowerStream residential customer who consumes 800 kWh in a month. The amount you pay varies depending on the amount of electricity you use.

PowerStream's distribution rates are subject to the review and approval of the OEB. The rate revenue covers PowerStream's capital investments and operating expenses.

### **Sample Electricity Bill**

UR CURRENT COM	UCTION .	Custom	4 30 p M (Mo	1-877-963-6990			Hill # 300000093		RESIDENTIAL
			a o h a tana				PLEASE DETACH AND YOUR PAYMENT, PLE WHEN PAYING AT OUR	ASE BRING EN	S PORTION WITH IT RUBILL
ACC	OUNT NUI	MBER 50-15-55	5555-501	SERVICE A			IE CRT	BILLIN	DATE
					MR C	LIÉNT			10, 2014
PLE/	ASE RETU	RN THIS POR	TION				AMOUNT_PAID		
									NI DUE
								*	
	LIENT AVENUE C	RT							EDITE
VAU	GHAN ON	1 L4L9O9						Sep	30, 2014
			4043	47-900	:		9	6	
ACCO	OUNTINUM	BER 50-15-5555	55-501	SERVICE AT		5501 A	VENUE CRT	P.C.	
SERVICE	FROM	BILLING PBRI		DAYS   RATECO	DE	Mr Cl		BI	LLING DATE
Elect.	Jul 23, 14	Aug 2	2 14	30 RI	-	SMAR	Г		Sep 10. 2014
			_				100 million (1990)	RES	SIDENTIAL
METER NUMBER	PREVIOUS RI			ULT CONSUMPTION			DESCRIPTION		AMOUNT
P500555 EI	1. 10000	10800	1	800.00	kWh		Previous Bill		
							TELE-PAYMENTS Jul 2	0	129 49 129.49 CR
							Balance Forward		0.00
							Your Electricity Charges		
							On-Peak kWh 144.17@		1946 *#
							Off-Peak kWh 558.03 @		41.85 *#
							Mid-Peak kWh 125 40 @	0.112	14 05 *#
							Regulatory Charges		33.29 *#
							Debt Retirement Charge		4.97 *#
									5.60 *#
							* H.S.T. (Reg # 857 503 ) #Ontario Clean Energy Ber		15.50 # 13.47CR
3,000 kwh/mon see Ontario.ca/ Ontario is build Ontario.ca/ener ***Visit Powe Energy provi	th of electrici OCEB OR I- ling strong,clo rgyplan erStream.ca ided through	fit takes 10% off t ty use. Some exce 888-668-4636 To can electricity sys for New rates In STANDARD SE oplied to kWh. Ad	eptions apply, p b learn more al dem visit. nplemented I ERVICE SUP	olease bout how May 1 <sup>21</sup> PLY					
		UNPTION HISTORY	ujusted kvvit	021.00	WATE	CONSU	PTION MISTORY	ACCO	UNT BALANCE
	DAYS 30	CONSUMPTION 800.00	1 NWh (DAY 10.28	READ DATE		DAYS	CONSUMPTION   mº DAY		\$121.25
READ DATE	31	850.00	27.41						
Aug 22,14 Jul 23 14			27.33					D	UE DATE
Aug 22,14	30	820.00						Las	
Aug 22,14 Jul 23 14 Jun 23,14 May23 14	31	840.00	27 10						
Aug 22,14 Jul 23 14 Jun 23,14			27 10 27.00					Sep	30, 2014
Aug 22,14 Jul 23 14 Jun 23,14 May23 14	31 30 Cu	840.00	27.00 ce 1-877-963-	6900		PLEAS PLEAS E&OE	E RETAIN THIS PORTION OF E BRING ENTIRE BILL WHEN	YOUR BILL FO	OR YOUR RECORD:

#### **DISTRIBUTION SYSTEM PLAN REVIEW**

## Feedback


1. How familiar are you with the electricity system in Ontario, and the services PowerStream is responsible for?

- Very familiar
- Somewhat familiar
- Not very familiar
- Not at all familiar
- Don't know

The plan PowerStream is proposing will maintain reliability at or above its current level. The resulting levels of capital investment and operational spending over the next five years will result in an increase of **\$2.14** per month or 7.7 per cent annually on the distribution rates charged by PowerStream. At the end of the plan in 2020, the average residential household will be paying an estimated **\$10.72** more per month on the distribution portion of their electricity bill. Other items on your bill may also increase.

	SU, RESIDENT
RIPTION	AMOUN
Previous Bill	129.49
TELE-PAYMENTS Jul 20 Balance Forward	129.49CR 0.00
Your Electricity Charges On-Peak kWh 144.17 @ 0.135	19.46 *#
Off-Peak kWh 558.03 @0.075 Mid-Peak kWh 125.40 @0.112	41.85 *# 14.05 *#
Delivery Regulatory Charges	<u> </u>
Debt Retirement Charge H.S.T. (Reg # 857 503 346)	5.60 *# 15.50
tario Clean Energy Benefit-10%	13.470

### About 20 per cent of the average residential electricity bill goes to PowerStream



## Electricity Grid 101

## Who Does What in Ontario's Electricity System?

Ontario's electricity system is owned and operated by public, private and municipal corporations across the province. It is made up of three components: generation, transmission and distribution.



## GENERATION Generating facilities co

forms of energy into el



### TRANSMISSIC Transmission lines (hig

connect the power profacilities to transformer



PowerStream is funded by the distribution rates paid by its customers. Periodically, PowerStream is required to file an application with the OEB to determine the funding available to operate and maintain the distribution system. PowerStream must submit evidence to justify the amount of funding it needs to safely and reliably distribute electricity.

### Who Protects Consumer Interests?

PowerStream's evidence is assessed in an open and transparent public process known as a rate hearing. A number of public intervenors with electricity industry expertise submit their own evidence challenging PowerStream's plans and assumptions. At the end of the process, the OEB weighs the evidence and decides on the rates PowerStream can charge for distribution.



### DISTRIBUTION Distribution lines (at m carry electricity to hom

businesses.



CONSUMERS Electricity is delivered and businesses.

√ onvert various lectric power.	<b>EXAMPLES</b> Ontario Power Generation TransCanada Energy Ltd Bruce Power Samsung Renewable
DN gh voltage lines) oduced at generating er stations.	EXAMPLE Hydro One
N nedium voltages) nes and	EXAMPLES Stream Toronto Hydro Newmarket Hydro
to homes	<b>EXAMPLES</b> Residential Commercial Industrial


## How is Ontario's Electricity System Regulated?

The Ontario Ministry of Energy sets energy policy. It sets the rules and establishes key planning and regulatory agencies through legislation.

The mission of the Ontario Energy Board (OEB) is to promote a viable, sustainable and efficient energy sector that serves the public interest and assists consumers to obtain reliable energy services at reasonable cost. It is an independent body established by legislation that sets the rules and regulations for the provincial electricity sector. One of the OEB's roles is to review the distribution plans of all electricity distributors and set their rates.

The **Ontario Power Authority** (OPA) is responsible for medium and long-term electricity planning to ensure an adequate supply of electricity is available for Ontario residents and businesses. The OPA receives directives from the Ministry of Energy (i.e. energy supply mix, Green Energy Act), but otherwise works at arm's-length from the government.

The Independent Electricity System Operator (IESO) is responsible for electricity supply over the shortterm. It operates the grid in real-time to ensure that Ontario has the electricity it needs, where and when it needs it.



COMMERCIAL

RESIDENTIAL

#### INDUSTRIAL

## PowerStream's Grid Today

This section describes the construction of PowerStream's distribution grid including its overhead, underground and secondary systems. It also explains the corporation's historical growth and current electrical infrastructure.

## The Background of PowerStream's Distribution Grid

PowerStream owns and operates \$1.17 billion in capital assets and is the second largest municipally- owned electricity distribution utility in Ontario. It distributes about eight per cent of Ontario's electricity demand. PowerStream's electrical grid is comprised of overhead, underground and secondary systems of various voltages. PowerStream was formed in 2004 from the amalgamation of Hydro Vaughan, Markham Hydro, and Richmond Hill Hydro. Aurora Hydro was purchased in 2005, and in 2009, Barrie Hydro merged with PowerStream.

Each original utility operated independent distribution systems, and as a result, the infrastructure varies from region to region. PowerStream has been working to gradually standardize this equipment, which will help improve reliability and safety across the regions, and make maintaining the system more efficient.

PowerStream is owned by three municipalities and regulated by the OEB. As such, any profits obtained by the utility are provided to the municipalities as a dividend, or reinvested into the distribution system.

## A Look at PowerStream's Growth

PowerStream has been serving York Region since 2004 and Simcoe County since 2009, and has seen remarkable change and innovation through the years. Although PowerStream as an entity dates back to 2004, the first electric system and street lights in the service territory were installed in Barrie in 1888, Markham in 1890-1891, and in neighbouring areas soon after.

PowerStream has a mix of older and newer distribution systems across all of its service territory. PowerStream is systematically and prudently upgrading older areas. Of course, even as this work is completed, the overall system continues to age.

PowerStream is a product of the largest voluntary consolidation of local distributors and is an organization committed to becoming an innovative and socially responsible leader in power distribution and related services. Growth is a key performance driver for PowerStream, and is achieved through increases to its residential and commercial customer bases.


Large projects currently underway include the new Vaughan Metropolitan Centre project at Hwy 7 and Jane Street, the new Vaughan Campus of Mackenzie Health, and the expansion of the Toronto Transit Commission subway into York Region. All of these projects highlight the expansion and growth occurring in PowerStream's service territory.

## PowerStream's Distribution System

Every system is unique with its own history and challenges. In order to better understand the current PowerStream system, we first have to understand all of the different components and how they impact the way in which you receive electricity when you need it. The image below and following terms and definitions will help guide you through the system from when you turn a switch on to when you receive your bill.

PowerStream's distribution system is made up of a number of components which work together to transport electricity to your house or business.

### **Distribution System Diagram**



### **Transformer Stations and Municipal Substa**

PowerStream owns 11 of the 25 Transformer Stations (TSs) that connect PowerStream's distribution system to the 230 Kilovolt (kV) provincial transmission grid owned by Hydro O and operated by the IESO. In fact, the very firs municipally-owned transformer station in Ontar was built in PowerStream's service territory (Markham) back in 1985.

Municipal Substations (MSs), 54 in total, also p an important role in PowerStream's distribution system, further transforming higher voltage electricity to a lower voltage that is suitable for distribution to customers.

**Transformers** – Important pieces of equiprent that reduce the voltage of electricity from a level to a level that can be safely distributed your area, or to your residence/business.

**Breakers** – Devices that protect the distribution system by interrupting a circuit if a higher the normal amount of power flow is detected.

**Switches** – Control the flow of electricity an steer the current to the correct circuits.

**Feeder Circuits** – Are the wires that connective stations to the broader distribution system order to deliver electricity to customers.

r One first tario	<b>PowerStream's Overhead System</b> The overhead system is made up of distribution lines that operate at various voltages depending on their purpose and destination. PowerStream has 2,535 km of overhead distribution lines in its service territory. These distribution lines are attached to the top of hydro poles.
o play on or local	Along the distribution line, pole-top transformers step the voltage down to useable levels of 120V-600V. From there, the electricity is delivered to customers through a secondary line that runs from the transformer to an individual home or business.
pment a high ed to	PowerStream has 3,500 switches, and over 330 pole-mounted remote-controlled switches located throughout its distribution system. These switches, which are controlled from PowerStream's Main System Control Centre, greatly improve operating efficiencies, and reduce restoration times whenever a power interruption occurs.
bution than and nect stem in	<b>PowerStream's Underground System</b> PowerStream's underground system consists of high and low voltage cables, metal enclosed switchgear and transformers situated on concrete pads. In residential areas, underground cables distribute electricity from the TSs or MSs to padmount transformers located on the municipal boulevards. Like the overhead system, these transformers step the electricity down to useable voltages of 120V-600V, and the power is then delivered to customers through over 5,000 km of buried low voltage wires.
	When distributing electricity to urban areas or larger customers, larger transformers are used.

PowerStream has 1,800 gears, and over 40 padmounted switchgears that are controlled remotely from its System Control Centre. These remote-controlled switches are critical for improving operating efficiencies and power restoration times in the underground distribution system.

## Feedback


**2.** How well do you feel you understand the important parts of the electricity system, how they work together, and which services PowerStream is responsible for?

- Very well
- Somewhat well
- Not very well
- I don't understand at all

3. Generally speaking, how satisfied are you with the service you are receiving from PowerStream? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

4. Is there is anything in particular that PowerStream can do to improve its service to you?



## Reliability

Delivering reliable power safely is PowerStream fundamental purpose. Three key standard indu measures are used to track system reliability. include:

#### SAIFI

System Average Interruption Frequency Ind This measure shows the number of outages an average PowerStream customer experiences i year.

#### SAIDI


System Average Interruption Duration Index This measure shows the amount of time an ave PowerStream customer is without power in a year.

#### CAIDI

**Customer Average Interruption Duration Index** This measure indicates on average how long it takes for PowerStream to restore power to a customer after a power outage.

All planned and unplanned sustained interruptions are used to calculate these indices.

### PowerStream SAIDI [minutes] Comparison to Other CEA (Canadian Electricity Association) Urban Utilities for All Outages



m's lustry They	How is PowerStream Performing: For reliability performance, the OEB expects that the distributor's current reliability performance (SAIDI, SAIFI, CAIDI) should, at minimum, remain within the range of its historical previous three year performance. PowerStream's plan aims to meet this
dex	requirement.
n	
in a	As seen in the chart below, PowerStream's SAIDI performance has been at par or better than average of the other comparable Canadian urban utilities with the exception of 2013 when PowerStream was
<b>x</b> verage	hit hard by an unusual weather event (December Ice Storm).



### **Controllable vs. Uncontrollable Factors**


Electricity outages can be caused by factors that PowerStream can and cannot control.

Uncontrollable events include lightning, adverse weather, adverse environment (e.g. salt contamination) and third party created events.

Controllable events include scheduled outages in order to perform work on the distribution system, tree contacts, defective equipment and errors caused by people.


The chart below shows that more than half of the outages PowerStream customers experience are caused by controllable events.

### **Total SAIFI, Controllable & Uncontrollable** SAIFI [2008-2013]



As the breakdown in the chart below illustrates, defective equipment is far and away the largest contributor of controllable outages.

### **Breakdown of Controllable SAIFI** Excluding Loss of Supply and Major Event Days [2008-2013]



### **Capital Expenditure and Outages**

Managing equipment failure is a never-ending race. Each year PowerStream invests in replacement or rehabilitation of its oldest assets and systems. The assets in the poorest condition are identified through an annual inspection programs. However with each passing year the rest of the assets get older and a new set of assets falls into poor condition.

Outages are also targeted as a result of poor performing feeders identified through reliability statistics each year. As these feeders are worked on and reliability improves, a new set of feeders falls to the bottom of the performance ratings.

As you will see in the following pages, over the next five years, PowerStream is planning investments in new equipment and the rehabilitation of existing equipment, such as underground cables, to reduce the number of outages due to equipment failure.

While outages are to some degree chance ev the investment in new equipment matches the profile of the system and is expected to sustai current level of reliability and to achieve reliab improvement in the worst performing areas.

#### **Capital Expenditure and Restoration Times**

Restoration time is an area where PowerStea actively pursues improvement. Restoration tir depend on three things - the physical capacity work around a problem, the speed at which the utility can re-route electricity through that phys network, and the speed by which the broken can be repaired.

As PowerStream expands the system through system service updates such as higher voltage

vents, le aging ain the bility	lines, new stations and feeder lines or similar system improvements, the utility is building more capacity to work around outages.
es am imes ty to he	As PowerStream adds remote monitors to pin- point where faults are occurring and add remote or automated switches to avoid the need to send a crew to manually flip a switch, the utility is increasing the speed by which power can be restored.
vsical parts	Finally, investments in areas such as equipment standardization, GPS devices and improved scheduling tools all contribute to our ability to replace broken equipment more quickly.
h	

## Feedback


5. As far as you know, in the past year, did you experience any outages due to unusual weather such as the ice storm, microbursts or tornados?

- Yes
- No
- Don't know

6. Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

7. Is there is anything in particular PowerStream can do to improve its service to you during these extreme weather events?



the past year?

- Zero One Two Three
- Four
- Five or more

the longest you experienced?

- Less than 15 minutes
- 15 to less than 30 minutes
- 30 minutes to less than 1 hour
- 1 hour to less than 3 hours
- 3 hours to less than 6 hours
- 6 hours to less than 12 hours
- 12 to less than 24 hours
- More than 24 hours
- Don't know

the outage? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

outages?

of reliability is ...

Very good
Good
Acceptable
Poor
Very poor
Don't know

### 8. Other than outages during unusual weather events, how many outages did you experience in


9. Aside from unusual weather events, if you experienced an outage in the past year, what was

**10.** If you experienced an outage, how satisfied are you with the way PowerStream responded to

**11.** Is there is anything in particular PowerStream can do to improve its service to you during

**12.** Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level

#### Capacity Constrained Areas of PowerStream's Service Territory



## Challenges and Solutions

## Pressure: Growth

Fueled by increased economic development and demand for new housing in York Region and Simcoe County, PowerStream adds over 8,000 new customers to its existing customer base every year. This growth in customers and load puts increasing pressure on PowerStream's distribution system, which requires extending power lines, upgrading capacity to existing power lines, and adding new capacity to load constrained areas.

## Challenges

Lines and equipment that cannot carry the increased load and maintain the increased reliability expected by customers.

**Development of new subdivisions** resulting from increased demand for new homes, which requires expansion of the distribution system lines and stations.

The map on the previous page shows the capacity constrained areas of PowerStream's service territory. Red highlighting indicates areas that require increased investment to provide additional capacity in the near term to ensure system reliability.

## Solutions

- New substations, transformer stations, and power lines • where needed to increase supply capacity.
- Voltage Conversion Projects: existing 8kV and 13.8kV power lines converted to 27.6kV to increase load capacity.
- Station Investments: intended to ensure stations have peak loadings maintained at or below their 10 day Limited Term Rating to prevent damage to station equipment and avoid brownouts and blackouts.

Need investments to increase station and power line capacity to maintain the loading of existing municipal substations and to ensure sufficient space capacity exists such that if there is a loss of one substation, the neighbouring **substations** can accommodate the lost capacity.

## Pressure: Aging Equipment

PowerStream's distribution system consists of various equipment (**poles, transformers, cables**, etc.) with different installation date profiles. While the majority of the distribution system was installed or rebuilt after 1980, a significant amount of distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in service today. While that old equipment continues to operate for the time being, it is well past its intended service life, and much of it will need to be replaced soon.

Equipment that is still operating beyond its intended service life is more likely to fail, and cause long power interruptions. As time goes on, more and more of the distribution system assets will be operating past end-of-life, unless replaced. This requires investment in system renewal projects and programs.

Asset Summary Chart – main assets by quantity

While PowerStream and its predecessor utilities have historically managed asset replacement programs efficiently with moderate levels of investment, the growing number of old assets needing replacement requires a higher level of investment than ever before.

PowerStream plans to proactively replace the oldest and worst condition equipment before it fails. Generally, proactive equipment replacement is less expensive than replacing equipment after an unexpected failure.

Some distribution assets such as pole mounted transformers and residential padmounted transformers, as well as secondary cables, are not proactively replaced. These assets are replaced once they fail. This "run to failure" approach is considered normal utility practice in the industry.

Asset Types	Asset Count (approx)	Average Life (approx)	Oldest Assets (approx)
Wood Poles	46,500	35-75	1940
Distribution Transformers	44,000	25-60	1956
Underground Primary Cable	7900 km	20-55	1965
Distribution Switchgear	1800	30-85	1978
Station Circuit Breakers	399	35-65	1958
Municipal Station Primary Switches	66	30-60	1956
Municipal Station Transformers	65	30-60	1958
Station Reactors	34	25-60	1986
Transformer Station Transformers	22	30-60	1986
Transformer Station 230kV High-Voltage Switches	22	30-60	1986
Station Capacitors	5	25-40	1990

**Note:** Above data and figures provided from PowerStream Asset Condition Assessment, Rev. 2, November 27, 2012.

## Challenges

The need to replace poles that are at or nearing end-of-life.

Underground primary cables that are at, or near, end-of-life, and the resulting high negative impact this has on reliability for affected customers.

Aging padmounted switchgear cubicles.

The need to replace padmounted transformers, where concerns about condition have been reported.

Automated/remote-controlled switches, switches that are at, or near, end-of-life and therefore likely to fail compromising the ability to prevent feeder and station overloa during the summer peak.

	Solutions
	• Proactive replacement: PowerStream plans to replace or reinforce approximately 400 of the worst condition poles per year in order to minimize risk.
	<ul> <li>PowerStream proposes to replace approximately 52 km/year of the worst condition underground cables, and use silicon injection to extend the life of another estimated 47 km/year of underground cables.</li> <li>PowerStream's approach for cable replacement is determined by prioritizing the cable sections that have the worst reliability and the highest customer impact.</li> </ul>
	<ul> <li>Proactive replacement: PowerStream plans to replace approximately 31 of the poorest condition switchgear units in 2015, rising to 36 per year in 2016-2020.</li> </ul>
	<ul> <li>PowerStream commenced a proactive replacement program in 2013.</li> <li>PowerStream proposes to proactively replace approximately 60 padmounted transformers per year.</li> </ul>
d ads	<ul> <li>PowerStream proposes to replace five per year.</li> <li>These are important for a number of reasons, including preventing station overloads during summer peaks, as well as improving reliability and restoration times.</li> </ul>

## Pressure: New Technology

PowerStream is finding that in general, customers have increased expectations. They want to communicate with us around the clock and in new ways, such as through social media. Some customers are seeking a detailed understanding of their electricity consumption, and how their bill is calculated. PowerStream information systems must support these customer needs.

The delivery model of the distribution system is changing. Renewable or other forms of generation have changed power flow from unidirectional to multidirectional. Managing this fundamental change requires increased technological investments.

	Challenges	Solutions
35 years old, that cannot support a growing number of customers, has limited ability for interactive features, and no longer has vendor support.       as required, to provide a more efficient platform for customers with increased linteractive support and customer information security. A new modern billing system will also provide increased efficiencies by integrating with other systems, and produce long-term cost savings.         The replacement of end-of-life remote-controlled switches to ensure rapid and automatic transfer of loads in emergencies and reduce restoration times.       • Installation of new smart remote-controlled power line switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.       • Installation of new smart remote-controlled power line switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.       • Installation of new smart remote-controlled power line switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.       • Installation of new smart remote-controlled power line switches and reduce restoration times.         The need to replace old and difficult to operate "min-rupter" (high capacity isolating switches in commercial/ isolating) switches in commercial/ industrial locations.       • Installation of new high-capacity isolating switches that increase operational efficiencies and reduce the need for costly power interruptions when performing routine maintenance.       • Ris         New OEB regulations that require higher intelligence metering equipment for all commercial/industrial customers over       • Replace 4400 meters with new smart technology meters in a pre-planned efficient multi-year program.	support smart grid technology to meet the high reliability demands of today's	<ul> <li>growing numbers of Electric Vehicles.</li> <li>Improvements to the distribution system to support increased renewable generation and energy storage initiatives.</li> <li>Develop and promote consumer energy management</li> </ul>
controlled switches to ensure rapid and automatic transfer of loads in emergencies and reduce restoration times.switches and reclosers.A formal decision-making process for determining the most cost effective quantity of switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.• A formal decision-making process for determining the most cost effective quantity of switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.• Installation of new high-capacity isolating switches that increase operational efficiencies and reduce the need for costly power interruptions when performing routine maintenance.• Replace 4400 meters with new smart technology meters in a pre-planned efficient multi-year program.• Replace 4400 meters	35 years old, that cannot support a growing number of customers, has limited ability for interactive features,	as required, to provide a more efficient platform for customers with increased interactive support and customer information security. A new modern billing system will also provide increased efficiencies by integrating with other
operate "mini-rupter" (high capacity isolating) switches in commercial/ industrial locations.increase operational efficiencies and reduce the need for costly power interruptions when performing routine maintenance.Ris builtNew OEB regulations that require higher intelligence metering equipment for all commercial/industrial customers over• Replace 4400 meters with new smart technology meters in a pre-planned efficient multi-year program.• New State 100 meters output to the state 100 meters 	controlled switches to ensure rapid and automatic transfer of loads in emergencies and reduce restoration	<ul> <li>switches and reclosers.</li> <li>A formal decision-making process for determining the most cost effective quantity of switches, and the optimal locations, for providing the maximum benefit to the largest</li> </ul>
industrial locations.       maintenance.       Ris         New OEB regulations that require higher intelligence metering equipment for all commercial/industrial customers over       • Replace 4400 meters with new smart technology meters in a pre-planned efficient multi-year program.       • New Smart technology meters in a pre-planned efficient multi-year program.	operate "mini-rupter" (high capacity	increase operational efficiencies and reduce the need
intelligence metering equipment for all in a pre-planned efficient multi-year program.		
	intelligence metering equipment for all commercial/industrial customers over	

## Pressure: Security

As technology continues to be utilized in every aspect of the utility's business, there is an increasing risk of cyber security attacks that could potentially affect confidential customer or corporate information, customer privacy, power delivery, and even the safety of employees or customers through the unauthorized use of

## nges

ks to cyber security information and grid and unsecure IT

dalism to substation nd equipment.

•

PowerStream technology. One incident could do serious damage to the corporation and to its corporate image. In addition, there is the on-going risk of physical security; the physical protection of buildings and stations, and the monitoring of critical equipment to protect from impending failure.

## Solutions

- Firewall/Intrusion Detection System/Intrusion Protection System—this is a security checkpoint between the trusted and untrusted network/device/users and is also used to continuously monitor for any malicious activity and can automatically take action in certain instances.
- Network Access Control—this dynamically monitors and controls devices, applications and users to deny unauthorized external access to the network.
- Identity and Access Management—this manages user access and privileges granted throughout the PowerStream environment • Security Information and Event Management—this is real-time logging and analysis of security alerts.
- Vulnerability Assessment Tool—this scans, identifies, quantifies and prioritizes vulnerabilities in the PowerStream environment and suggests remediation solutions.
- Mobile Device Management—this controls mobile devices connected to our network and can authorize, wipe, secure and encrypt corporate information as required.
- Enterprise Change Management—this process and associated technology allows PowerStream to effectively deal with constant change through a structured approach to transitioning systems, applications and technologies from current to desired future states.

• Install equipment monitoring Infrared cameras at 16 additional stations over the next 6 years.

 Install perimeter video surveillance cameras at 17 additional stations over the next 6 years.

## Pressure: Obsolescence

Despite an ever increasing number of weatherrelated interruptions each year, PowerStream has worked hard to stay within the boundary of its average historical reliability performance targets of one outage totalling 60 minutes per customer, per year.

While PowerStream continues to demonstrate strong reliability performance in the operation of its distribution network, it is not without its challenges. There are areas and pockets within the PowerStream distribution system that suffer poor reliability due to the type of legacy construction that was once considered acceptable or even preferable. An example of this would be older houses connected to overhead power lines located in the back lot (rear lot) of those properties. The reliability of rear lot supply connections is worse under severe weather conditions than the current standard front lot connections. In addition, the cost to maintain these rear-lot connections is much higher than the cost to maintain front lot connections.

## Challenges

Rear Lot Conversion program: Capital work required to address reliability, safety, operations and customer service concerns on rear lot supply connections.

## Solutions

- There are 49 areas of rear lot construction scattered among eight of the municipalities of PowerStream.
   Most of those areas were constructed in the 1950's, 1960's and 1970's. The oldest dates back to 1948.
- PowerStream proposes to replace the worst areas of rear lot connections on an annual basis over many years until all areas are converted.
- The average cost of this conversion work is estimated to be \$1.2M per rear lot area.
- Elimination of rear lot supply connections will result in long-term operational efficiencies and reduced maintenance costs.

## Pressure: Major Events

PowerStream's system is built to quickly restor power after the loss of one or two key elements the electricity grid. But what happens when the a major disruption to the system?

PowerStream has been severely impacted by weather-related events over the past year. The December 2013 ice storm, microbursts in York region and tornados in the North service area h all highlighted the risk to the grid from major ev Major events are rare events that have a major impact. The Insurance Bureau of Canada report that severe weather is likely to increase over the 40 years.

The December 2013 Ice Storm in Ontario sever tested the emergency preparedness of electric utilities in Southern Ontario including the Great Toronto Area where hundreds of thousands of

## Challenges

The need for emergency preparedness d unplanned events and expenses.

The need to improve the supply to those customers who are more vulnerable to outages and duration of outages, specific rear lot supply.

The need to make changes to key distrib lines to withstand increased severity of weather events.

The investments discussed earlier in the primer are focused on minimizing day-to-day outages and increasing the speed by which electricity is restored. Additional investments could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

re ts in iere is	customers were left without power, some for as long as a week, or even longer. An independent assessment of PowerStream's response to that storm highlighted a number of areas where improvements are required at PowerStream to be better prepared for future severe storms
ne K have	and emergency events. Key areas identified for improvement include:
vents. or	1. Improve external communications with customers.
orts he next	<ol> <li>Improvements to Customer Care systems and staffing.</li> <li>Improve Outage Management Systems and utilize outage reporting via existing Smart</li> </ol>
erely cal iter	<ul><li>Meters.</li><li>4. Improve vegetation management.</li><li>5. Elimination of rear lot services, and convert to front lot.</li></ul>
	6. Upgrade or underground key distribution lines.
	Solutions
luring	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e. poles, transformers, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and materials are available for emergencies.</li> </ul>
luring	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e. <b>poles, transformers</b>, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and</li> </ul>
	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e. <b>poles, transformers</b>, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and materials are available for emergencies.</li> <li>Plan to replace rear lot supplies on an annual basis</li> </ul>

**13.** A significant amount of PowerStream's distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in-service today. PowerStream works hard to extend the life of our existing equipment because it helps to keep rates down, but as equipment gets older it becomes more likely to fail. PowerStream has two approaches to older equipment.

- If the failure of a piece of equipment will impact a large number of people, result in a long outage or if an inspection shows the equipment is in poor condition, PowerStream does initiate equipment replacement before failure.
- When an equipment failure has only a limited impact and can be quickly replaced, PowerStream's policy is to leave the equipment in place until it breaks down to get all the value possible from that equipment.

### What do you think of this policy?

- I am willing to pay more to replace all equipment before it fails.
- I support the current approach of allowing equipment to run to failure when that failure impacts only a few customers for a limited period of time.
- Don't Know

14. When it comes to replacing aging equipment, which of the following points of view is closest to your own?

- PowerStream should invest what it takes to replace the system's aging infrastructure to reduce the risk of power outages; even if that means my electricity bill will increase by a few dollars per month.
- PowerStream should scale back their investment in renewing the system's aging infrastructure to reduce the size of any bill increase; even if that means more or longer power service interruptions
- Don't Know

15. While there are clear benefits from new technology, there are also costs. The system functions well on the old technology. Do we want to pay more to secure the benefits new technology can deliver?

When it comes to investing in new technology, which of the following points of view is closest to your own?

- Investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream.
- I think the benefits of new technology are important and investments in new technology should be a priority for PowerStream.
- Don't know

**16.** The investments discussed earlier in the primer are focused on minimizing the day-to-day outages and increasing the speed by which electricity is restored. There are additional investments could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average residential customer pays \$27 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather?

What this Plan Means for You

It all comes down to what you pay and what you receive in return.

What will you get? PowerStream's plan for 20 to 2020 deals with the challenges outlined in the primer to deliver a system that will maintain or achieve modest improvements in reliability and service.

What will it cost? Residential customers with average monthly consumption of 800 kWh may an increase of \$2.14 per month or 7.7 per cent annually on the distribution portion of their bill of the next five years. As such by 2020, the avera residential household will be paying an estimat **\$10.72** more per month on the distribution port of their electricity bill. It is important to note that other increases on the bill by other entities are possible.

There are two main elements in that increase:

- An increase of approximately 2.4 per cent 66 cents per month in operating costs which reflects inflation and new costs which are o in part by efficiency savings;
- An increase of approximately **5.3 per cent** \$1.48 per month for new capital investmen deal with the issues discussed earlier such as growth, aging infrastructure and new technology.

In addition, in the first year of the plan there is a "catch-up" increase to deal with expenses that were not properly covered under the existing rate adjustment formula. The next section explains the need for that catch-up.


\$

## Current Revenue Shortfall

2016 his d	The formula for setting PowerStream's rates in 2014 and 2015 is not keeping up with the need for new investment. PowerStream's rates were set in 2013 using the cost of service method where the OEB sets rates at the level needed to fund the operation of the utility. That worked well in 2013.
n an ly see <b>it</b> over age ited tion	However, in 2014 and 2015, rates were not based on actual costs. Instead, a formula was applied which adjusted rates for inflation less an adjustment for efficiency, referred to as a price cap index (PCI) adjustment. This formula does not provide enough revenue in rates to fund the actual capital investments being made in these years.
at e also t or ich offset	The OEB recognized that problem and created the new Custom Incentive Regulation rate setting method which PowerStream will be using in this rate filing. This method will alleviate this issue going forward but there is still a need to deal with 2014 and 2015 investments.
<b>t</b> or nts to	

The chart below compares the revenue from rates using the PCI to the revenue needed to fund utility operations on a cost of service basis. Over 2014 and 2015, there will be a revenue shortfall of approximately \$13.2 million. This shortfall is being funded by PowerStream's municipal shareholders from past earnings retained in the company. However, using savings to make up for the missing revenue will restrict PowerStream's ability to make the necessary future investments to maintain its system and the level of service provided to its customers. The catch-up will enable PowerStream to fund those needed investments.

#### **Revenue Shortfall (\$millions)**



Most of the rate increase in 2016 is to provide funding for capital investments in 2014 and 2015. This will result in an increase of \$3.86 a month for the average residential customer consuming 800 kWh a month.

One of these major capital investments is a new billing system. PowerStream made the second largest investment in its 10 year history when it decided to bring in a new billing system in 2014/2015. PowerStream is committed to providing customers with accurate billing information from meter to payment. However, the old system was implemented 30 years ago and just wasn't keeping up with new demands such as mobile access and self-service options customers have said that they expect today. Changing to a modern system requires both a significant capital investment and an increased operating budget. Not only will it provide much better access for customers and staff, it will do so with a much higher level of security for personal

information, a key concern in these times. This system will be fully implemented in 2015.

## Increased Capital Spending

PowerStream has developed a list of capital investment drivers and proposes capital investment programs based on these key drivers. The definitions of the key drivers are below.

### **Service Requests**

PowerStream has an obligation to connect a customer to its distribution system. This includes both traditional demand customers and distributed generation customers. Requests also can include system modifications to support infrastructure development by government agencies, road authorities and developers. Normal connection costs are recovered through the revenue from new customers. Unusual connection costs are paid by the customer being connected.

### **Increased Delivery Capacity**

As new customers are connected, PowerStream needs to expand the core elements of its distribution system, including expanded or new distribution stations and enhanced or new feeder lines. This is the fundamental infrastructure that allows new customers to be hooked up to the distribution system and is paid for by the extra revenue from new customers served over time.

### System Efficiency

To provide customers with the best service possible, there is always a need to improve restoration capability. As the population in PowerStream's service territory continues to grow, the system also needs to grow in order to be able to handle new connections.

### Mandated Compliance

Environmental, reliability and safety standards are updated on a regular basis and PowerStream's system must be updated to keep up with these standards. Agencies that impact PowerStream include the Ministry of Energy, Measurement Canada, the OEB, the IESO and/or other regulators.

#### **Obsolescence**

Improvements in technology can require PowerStream to replace equipment that is still functional but no longer meets current operating practices or current standards. Reasons for

- them:
- safety-related risks.

PowerStream is not just the local electricity grid replacement include: the equipment is no longer manufactured; itself, it is the business that operates that grid. there are no spare parts; The utility needs storage facilities for equipment, are unable to have maintenance performed on workshops to maintain and repair equipment and offices for people who manage your accounts there are operational constraints or conflicts, and the electricity system. PowerStream needs which can result in increased reliability and/or vehicles for its crews, as well as computer systems to manage customer accounts, track equipment and operate the grid. While this is a relatively small slice Aging or Poor Performing Equipment of the capital spending over the next several years, it is just as critical to have IT systems identify where Where there is the imminent risk of failure due to an outage is and where the needed parts are stored age or condition deterioration, and these potential as to have the replacement parts themselves. failures will result in severe reliability impacts

	Capital Investment Drivers	Primary Driver	Source
System Access	Subdivisions and New Connections Road Authority Metering Other Customer Initiated Work	Service Requests	Developers, Customers, Road Authorities
System Service	Reliability including Distribution Automation Additional Capacity - Lines Additional Capacity - Stations (TS and MS) Security Smart Grid Safety	Reliability Support Capacity Delivery System Efficiency Safety	PowerStream
System Renewal	Distribution Lines - Emergency/Reactive Replacement Overhead Lines and Assets Planned Replacement Underground Cable and Asset Planned Replacement Rear Lot Conversion Program Stations/Protection & Control Asset Replacement (Planned & Emergency)	Mandated Compliance Obsolescence Mitigate Failure Risks Safety	Regulator Safety Authority PowerStream
General Plant	Interest Capitalization Customer Service Information Service and Communication Systems Buildings/Facilities Fleet Tools	Capital Investment Support Customer Service	PowerStream

to customers as well as potential safety risks to crew workers or to the public, refurbishment or replacement is required.

**Business Support Costs** 

Looking ahead at the next five years and all the categories identified above, PowerStream is proposing to spend \$641 million on new capital investments. This will result in an annual increase of about 6 per cent on the distribution portion of your bill which is about three quarters of the proposed rate increase.

#### 2016 - 2020 Forecasted Capital Expenditures (\$ millions)



With the proposed levels of capital and operating budgets for 2016 to 2020, in 2020 PowerStream will continue to operate on less revenue per customer than the average Ontario local distribution company.

## Fe

## Feedback


**17.** Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream system and what they are planning to do to meet those challenges?

- Very well
- Somewhat well
- Not very well
- I don't understand at all

**18.** From what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction?

- Right direction
- Wrong direction
- Don't know


### **19.** And why do you feel that way?



## The Impact on Your Bill

Residential customers with an average monthly consumption of 800 kWh will see an increase of **\$2.14** per month or **7.7 per cent** annually on the distribution portion of their bill over the next five years. As such by 2020, the average residential household will be paying an estimated **\$10.72** more per month on the distribution portion of their electricity bill.

### Estimated Typical Residential Annual Increase in Monthly Bill



## Feedback

**20.** Considering what you know abo represents your point of view:

- The rate increase is reasonable and I support it
- I don't like it, but I think the rate increase is necessary
- The rate increase is unreasonable and I oppose.
- Don't know

#### **21.** And why do you feel that way?

•••••	 	 		 	 	 	 	 	 	 ••••	••••	 ••••	••••	
•••••	 	 		 	••••	 	••••							
<b>.</b>	 	 		 		 								
•••••	 	 	••••	 		 								

20. Considering what you know about the local distribution system, which of the following best

and I support it ncrease is necessary le and I oppose.

## Final Thoughts

PowerStream values your feedback. This outreach is a new requirement, so this is the first time that the utility has conducted a review about its upcoming investment plan in this type of format.

General Impression - Overall, what did you think about this primer?

**Volume of Information**: Did PowerStream provide too much information, not enough, or just the right amount?

**Content Covered**: Was there any content missing that you would have liked to have seen included?

**Outstanding Questions**: Is there anything that you would still like answered?

Suggestions for Future Consultations: How would you prefer to participate in these consultations?

## Glossary

**Breakers:** Devices that protect the distribution system by interrupting a circuit if a higher than normal amount on power flow is detected.

**Feeder Circuit:** Is a wire that connects stations to the broader distribution system in order to deliver electricity to customers.

**Generation Station:** A facility designed to produce electric energy from another form of energy, such fossil fuel, nuclear, hydroelectric, geothermal, solat thermal, and wind.

Kilowatt (kW): 1000 watts.

**Local Distribution Company (LDC):** In Ontario, these are the companies that take electricity from the transmission grid and distribute it around a community.

OM&A: Operations, Maintenance and Administration

**Stations:** These include tranformer stations and distribution stations. They are used to switch generators, equipment, and circuits or lines in and out of a system. It also is used to change AC voltages from one level to another.

**Switches:** These control the flow of electricity—the direct which supply of electricity is used and which circuits are energized. Distribution systems have switches installed at strategic locations to redirect power flows for load balancing or sectionalizing.

**System Access:** Projects required to respond to customer requests for new connections or new infrastructure development. These are usually a regulatory requirement to complete.

**System Renewal:** Projects to replace aging infrastructure in poor condition.

	<b>System Service:</b> Primarily projects that improve reliability.
to r	<b>General Plant:</b> Investments in things like tools, vehicles, buildings and information technology (IT) equipment that are needed to support the distribution system.
uce h as lar	<b>Transmission lines:</b> Transmit high-voltage electricity from the generation source or station to another station in the electricity grid.
, n	<b>Transformer:</b> A piece of equipment that reduces the voltage of electricity from a high level to a level that can be safely distributed to your area or to your residence/business.
ation	<b>Underground Cable:</b> A conductor with insulation, or a stranded conductor with or without insulation and other coverings (single-conductor cable), or a combination of conductors insulated from one another (multiple-conductor cable).
2	<b>Volt (V):</b> A unit of measure of the force, or 'push,' given the electrons in an electric circuit. One volt produces one ampere of current when acting on a resistance of one ohm.
they ch e ct	<b>Watt (W):</b> The unit of electric power, or amount of work (J), done in a unit of time. One ampere of current flowing at a potential of one volt produces one watt of power.
)	<b>Wire:</b> A conductor wire or combination of wires not insulated from one another, suitable for carrying electric current.



If you have any additional questions or comments about PowerStream's Distribution System Plan Review please email:

CustomerFocus@powerstream.ca

or send your questions or comments to:

PowerStream Attn: DSP Review 161 Cityview Boulevard, Vaughan, Ontario L4H 0A9



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix D: Distribution System plan Review – General Service Over 50 Delivered: February 24, 2015



# Appendix D

## Distribution System Plan Review – General Service Over 50

Delivered: February 24, 2015

## DISTRIBUTION SYSTEM PLAN REVIEW PRIMER

1201



PowerStream is a community-owned energy company providing power and related services to more than 370,000 customers residing or owning a business in Alliston, Aurora, Barrie, Beeton, Bradford West Gwillimbury, Markham, Penetanguishene, Richmond Hill, Thornton, Tottenham and Vaughan as well as Collingwood, Stayner, Creemore and Thornbury through a partnership with the Town of Collingwood in the ownership of Collus PowerStream.



128

## Table of Contents

Why Are We Here?	05
Electricity Grid 101	09
PowerStream's Grid Today	11
Challenges and Solutions	21
What this Plan Means for You	29
Final Thoughts	34
Glossary	35

## Planning for Future Energy Needs

This primer and consultation concentrates on the short-term plan for PowerStream's distribution system over the next five years. The graphic below shows the various planning initiatives ongoing within the Province. In addition to the short-term distribution plan being discussed in this primer, there are other planning initiatives undertaken to ensure that the electricity system maintains reliability and works efficiently for the benefit of customers.

Energy planning occurs at the provincial level (by the Ministry of Energy and government agencies such as the Ontario Power Authority) and at the regional and municipal level as well as by each electricity distributor for their service territory and relevant agencies.

If you're interested in broader medium and long term electricity issues such as Ontario's Long-Term Energy Plan, regional planning, conservation planning and general energy policy in the province, there are other opportunities to provide your feedback.


#### **Ontario's Long Term Energy Plan:**

The Ontario Government's plan details how electricity will be generated and the longer-term conservation strategy for the province. It can be found at this website: <a href="http://www.energy.gov.on.ca/en/ltep/">http://www.energy.gov.on.ca/en/ltep/</a>

#### **Regional Planning:**

The Ontario Power Authority (OPA) looks ahead to the future electricity needs of your region and how those needs can be addressed through Conservation and Demand Management (CDM), local generation, and electricity from outside the region. You can follow the OPA's regional planning process at this website: http://www.powerauthority.on.ca/power-planning/regional-planning

#### **Ontario's Energy Planning Diagram**



## Why Are We Here?

The electricity industry in Ontario is regulated by the Ontario Energy Board (OEB), which requires distribution companies, such as PowerStream, to prepare and submit a distribution system plan to show how it will sustain the area's electricity distribution system over the next five years.


The OEB recently developed a new regulatory requirement for distribution system plans that requires distribution companies, to gather information about customer needs and preferences on distribution system investments and report on how they responded. PowerStream needs your participation to ensure its plan addresses your needs and expectations.

## You don't have to be an electricity expert to participate

This consultation is not about technical issues. The OEB hearing process will allow experts representing various consumer and interest groups (called intervenors) to challenge the detailed engineering and business decisions within PowerStream's plan. This consultation focuses on the goals of the system. Should PowerStream focus more on reducing the number of outages or the lengths of outages? Should reliability be increased even if rates go higher, or should PowerStream maintain the current level of reliability and keep rate increases lower?

This primer has been developed to guide you through PowerStream's plan. As you proceed, it asks questions designed to collect your feedback. In order to facilitate this, the primer is divided into several sections that explain the distribution system, the challenges it faces and, more importantly, how PowerStream will be responding to those challenges.

Your input, and PowerStream's response to your input, will be presented to the OEB and intervenors when PowerStream files its rate application for 2016 to 2020 in the spring of 2015.



**Innovative Research Group Inc.** has been engaged by PowerStream to collect participant feedback and will deliver it to PowerStream to assist them in shaping their plans.



## Feedback

**1.** How familiar are you with the electricity system in Ontario, and the services PowerStream is responsible for?

Very familiar

- Somewhat familiar
- Not very familiar
- Not at all familiar
- Don't know


## Your Electricity Bill

Every item and charge on the bill is mandated by the provincial government or regulated by the OEB. There are two distinct cost areas that make up the "Delivery" charge on your bill: distribution and transmission. While PowerStream collects both, it remits the transmission charge to Hydro One. The distribution charges are what PowerStream uses to fund its utility needs.


Distribution charges are one of several charges on your bill. Current monthly distribution charges are approximately \$963 for a typical PowerStream general service customer with a peak monthly demand of 250 kWh. The amount you pay varies depending on your peak demand.

PowerStream's distribution rates are subject to the review and approval of the OEB. The rate revenue covers PowerStream's capital investments and operating expenses.


#### **Sample Electricity Bill**



The plan PowerStream is proposing will maintain reliability at or above its current level. The resulting levels of capital investment and operational spending over the next five years will result in an increase of **\$74.60** per month or **6.7 per cent** annually on the distribution rates charged by PowerStream. At the end of the plan in 2020, the average GS > 50 kW customer will be paying an estimated **\$373.00** more per month on the distribution portion of their electricity bill. Other items on your bill may also increase.



### About eight per cent of the average electricity bill goes to PowerStream for general service customers with a peak demand over 50 kW.



### How are Electricity Rates Determined?

PowerStream is funded by the distribution rates paid by its customers. Periodically, PowerStream is required to file an application with the OEB to determine the funding available to operate and maintain the distribution system. PowerStream must submit evidence to justify the amount of funding it needs to safely and reliably distribute electricity.

### Who Protects Consumer Interests?

PowerStream's evidence is assessed in an open and transparent public process known as a rate hearing. A number of public intervenors with electricity industry expertise submit their own evidence challenging PowerStream's plans and assumptions. At the end of the process, the <u>OEB weighs the evidence and decides on the rates PowerStream can charge for distribution</u>.

## Electricity Grid 101

## Who Does What in Ontario's Electricity System?

Ontario's electricity system is owned and operated by public, private and municipal corporations across the province. It is made up of three components: **generation**, **transmission** and **distribution**.

	GENERATION Generating facilities convert various forms of energy into electric power.	<b>EXAMPLES</b> Ontario Power Generation TransCanada Energy Ltd Bruce Power Samsung Renewable
<b>*</b> **	TRANSMISSION Transmission lines (high voltage lines) connect the power produced at generating facilities to transformer stations.	<b>EXAMPLE</b> Hydro One
11	DISTRIBUTION Distribution lines (at medium voltages) carry electricity to homes and businesses.	EXAMPLES Stream Toronto Hydro Newmarket Hydro
	CONSUMERS Electricity is delivered to homes and businesses.	<b>EXAMPLES</b> Residential Commercial Industrial


## How is Ontario's Electricity System Regulated?

The **Ontario Ministry of Energy** sets energy policy. It sets the rules and establishes key planning and regulatory agencies through legislation.

The mission of the **Ontario Energy Board** (OEB) is to promote a viable, sustainable and efficient energy sector that serves the public interest and assists consumers to obtain reliable energy services at reasonable cost. It is an independent body established by legislation that sets the rules and regulations for the provincial electricity sector. One of the OEB's roles is to review the distribution plans of all electricity distributors and set their rates.

The **Ontario Power Authority** (OPA) is responsible for medium and long-term electricity planning to ensure an adequate supply of electricity is available for Ontario residents and businesses. The OPA receives directives from the Ministry of Energy (i.e. energy supply mix, Green Energy Act), but otherwise works at arm's-length from the government.

The **Independent Electricity System Operator** (IESO) is responsible for electricity supply over the shortterm. It operates the grid in real-time to ensure that Ontario has the electricity it needs, where and when it needs it.



## PowerStream's Grid Today

This section describes the construction of PowerStream's distribution grid including its overhead, underground and secondary systems. It also explains the corporation's historical growth and current electrical infrastructure.

## The Background of PowerStream's Distribution Grid

PowerStream owns and operates \$1.17 billion in capital assets and is the second largest municipally- owned electricity distribution utility in Ontario. It distributes about eight per cent of Ontario's electricity demand. PowerStream's electrical grid is comprised of overhead, underground and secondary systems of various voltages. PowerStream was formed in 2004 from the amalgamation of Hydro Vaughan, Markham Hydro, and Richmond Hill Hydro. Aurora Hydro was purchased in 2005, and in 2009, Barrie Hydro merged with PowerStream.

Each original utility operated independent distribution systems, and as a result, the infrastructure varies from region to region. PowerStream has been working to gradually standardize this equipment, which will help improve reliability and safety across the regions, and make maintaining the system more efficient.

PowerStream is owned by three municipalities and regulated by the OEB. As such, any profits obtained by the utility are provided to the municipalities as a dividend, or reinvested into the distribution system.

## A Look at PowerStream's Growth

PowerStream has been serving York Region since 2004 and Simcoe County since 2009, and has seen remarkable change and innovation through the years. Although PowerStream as an entity dates back to 2004, the first electric system and street lights in the service territory were installed in Barrie in 1888, Markham in 1890-1891, and in neighbouring areas soon after.

PowerStream has a mix of older and newer distribution systems across all of its service territory. PowerStream is systematically and prudently upgrading older areas. Of course, even as this work is completed, the overall system continues to age.

PowerStream is a product of the largest voluntary consolidation of local distributors and is an organization committed to becoming an innovative and socially responsible leader in power distribution and related services. Growth is a key performance driver for PowerStream, and is achieved through increases to its residential and commercial customer bases.


Large projects currently underway include the new Vaughan Metropolitan Centre project at Hwy 7 and Jane Street, the new Vaughan Campus of Mackenzie Health, and the expansion of the Toronto Transit Commission subway into York Region. All of these projects highlight the expansion and growth occurring in PowerStream's service territory.

## PowerStream's Distribution System

Every system is unique with its own history and challenges. In order to better understand the current PowerStream system, we first have to understand all of the different components and how they impact the way in which you receive electricity when you need it. The image below and following terms and definitions will help guide you through the system from when you turn a switch on to when you receive your bill.

PowerStream's distribution system is made up of a number of components which work together to transport electricity to your house or business.

### **Distribution System Diagram**



#### **Transformer Stations and Municipal Substations**

PowerStream owns 11 of the 25 Transformer Stations (TSs) that connect PowerStream's distribution system to the 230 Kilovolt (kV) provincial transmission grid owned by Hydro One and operated by the IESO. In fact, the very first municipally-owned transformer station in Ontario was built in PowerStream's service territory (Markham) back in 1985.

Municipal Substations (MSs), 54 in total, also play an important role in PowerStream's distribution system, further transforming higher voltage electricity to a lower voltage that is suitable for local distribution to customers.

**Transformers** – Important pieces of equipment that reduce the voltage of electricity from a high level to a level that can be safely distributed to your area, or to your residence/business.

**Breakers** – Devices that protect the distribution system by interrupting a circuit if a higher than normal amount of power flow is detected.

**Switches** – Control the flow of electricity and steer the current to the correct circuits.

**Feeder Circuits** – Are the wires that connect the stations to the broader distribution system in order to deliver electricity to customers.

### PowerStream's Overhead System

The overhead system is made up of distribution lines that operate at various voltages depending on their purpose and destination. PowerStream has 2,535 km of overhead distribution lines in its service territory. These distribution lines are attached to the top of hydro poles.

Along the distribution line, pole-top transformers step the voltage down to useable levels of 120V-600V. From there, the electricity is delivered to customers through a secondary line that runs from the transformer to an individual home or business.

PowerStream has 3,500 switches, and over 330 pole-mounted remote-controlled switches located throughout its distribution system. These switches, which are controlled from PowerStream's Main System Control Centre, greatly improve operating efficiencies, and reduce restoration times whenever a power interruption occurs.

#### PowerStream's Underground System

PowerStream's underground system consists of high and low voltage cables, metal enclosed switchgear and transformers situated on concrete pads. In residential areas, underground cables distribute electricity from the TSs or MSs to padmount transformers located on the municipal boulevards. Like the overhead system, these transformers step the electricity down to useable voltages of 120V-600V, and the power is then delivered to customers through over 5,000 km of buried low voltage wires.

When distributing electricity to urban areas or larger customers, larger transformers are used.

PowerStream has 1,800 gears, and over 40 padmounted switchgears that are controlled remotely from its System Control Centre. These remote-controlled switches are critical for improving operating efficiencies and power restoration times in the underground distribution system. ?

## Feedback

**2.** How well do you feel you understand the important parts of the electricity system, how they work together, and which services PowerStream is responsible for?

- Very well
- Somewhat well
- Not very well
- I don't understand at all

**3.** Generally speaking, how satisfied are you with the service you are receiving from PowerStream? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

4. Is there anything in particular that PowerStream can do to improve its service to you?

## Reliability

Delivering reliable power safely is PowerStream's fundamental purpose. Three key standard industry measures are used to track system reliability. They include:

### SAIFI

#### System Average Interruption Frequency Index

This measure shows the number of outages an average PowerStream customer experiences in a year.

#### SAIDI

#### System Average Interruption Duration Index

This measure shows the amount of time an average PowerStream customer is without power in a year.

#### CAIDI

#### **Customer Average Interruption Duration Index**

This measure indicates on average how long it takes for PowerStream to restore power to a customer after a power outage.


All planned and unplanned sustained interruptions are used to calculate these indices.

#### How is PowerStream Performing:

For reliability performance, the OEB expects that the distributor's current reliability performance (SAIDI, SAIFI, CAIDI) should, at minimum, remain within the range of its historical previous three year performance. PowerStream's plan aims to meet this requirement.

As seen in the chart below, PowerStream's SAIDI performance has been at par or better than average of the other comparable Canadian urban utilities with the exception of 2013 when PowerStream was hit hard by an unusual weather event (December Ice Storm).

### PowerStream SAIDI [minutes] Comparison to Other CEA (Canadian Electricity Association) Urban Utilities for All Outages



### **Controllable vs. Uncontrollable Factors**


Electricity outages can be caused by factors that PowerStream can and cannot control.

Uncontrollable events include lightning, adverse weather, adverse environment (e.g. salt contamination) and third party created events.

Controllable events include scheduled outages in order to perform work on the distribution system, tree contacts, defective equipment and errors caused by people.


The chart below shows that more than half of the outages PowerStream customers experience are caused by controllable events.

# Total SAIFI, Controllable & Uncontrollable SAIFI [2008-2013]



As the breakdown in the chart below illustrates, defective equipment is far and away the largest contributor of controllable outages.





### **Capital Expenditure and Outages**

Managing equipment failure is a never-ending race. Each year PowerStream invests in replacement or rehabilitation of its oldest assets and systems. The assets in the poorest condition are identified through an annual inspection programs. However with each passing year the rest of the assets get older and a new set of assets falls into poor condition.

Outages are also targeted as a result of poor performing feeders identified through reliability statistics each year. As these feeders are worked on and reliability improves, a new set of feeders falls to the bottom of the performance ratings.

As you will see in the following pages, over the next five years, PowerStream is planning investments in new equipment and the rehabilitation of existing equipment, such as underground cables, to reduce the number of outages due to equipment failure. While outages are to some degree chance events, the investment in new equipment matches the aging profile of the system and is expected to sustain the current level of reliability and to achieve reliability improvement in the worst performing areas.

#### **Capital Expenditure and Restoration Times**

Restoration time is an area where PowerSteam actively pursues improvement. Restoration times depend on three things - the physical capacity to work around a problem, the speed at which the utility can re-route electricity through that physical network, and the speed by which the broken parts can be repaired.

As PowerStream expands the system through system service updates such as higher voltage

lines, new stations and feeder lines or similar system improvements, the utility is building more capacity to work around outages.

As PowerStream adds remote monitors to pinpoint where faults are occurring and add remote or automated switches to avoid the need to send a crew to manually flip a switch, the utility is increasing the speed by which power can be restored.

Finally, investments in areas such as equipment standardization, GPS devices and improved scheduling tools all contribute to our ability to replace broken equipment more quickly. ?

# Feedback

**5.** As far as you know, in the past year, did you experience any outages due to unusual weather such as the ice storm, microbursts or tornados?

- Yes
- No
- Don't know

**6.** Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

**7.** Is there anything in particular that PowerStream can do to improve its service to you during these extreme weather events?

?

**8.** Other than outages during unusual weather events, how many outages did you experience in the past year?

- Zero
- One
- Two
- Three
- Four
- Five or more

**9.** Aside from unusual weather events, if you experienced an outage in the past year, what was the longest you experienced?

- Less than 15 minutes
- 15 to less than 30 minutes
- 30 minutes to less than 1 hour
- 1 hour to less than 3 hours
- 3 hours to less than 6 hours
- 6 hours to less than 12 hours
- 12 to less than 24 hours
- More than 24 hours
- Don't know


**10.** If you experienced an outage, how satisfied are you with the way PowerStream responded to the outage? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

**11.** Is there anything in particular that PowerStream can do to improve its service to you during outages?

**12.** Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level of reliability is ...

- Very good
- Good
- Acceptable
- Poor
- Very poor
- Don't know



### Capacity Constrained Areas of PowerStream's Service Territory

# Challenges and Solutions

# Pressure: Growth

Fueled by increased economic development and demand for new housing in York Region and Simcoe County, PowerStream adds over 8,000 new customers to its existing customer base every year. This growth in customers and load puts increasing pressure on PowerStream's distribution system, which requires extending power lines, upgrading capacity to existing power lines, and adding new capacity to load constrained areas. The map on the previous page shows the capacity constrained areas of PowerStream's service territory. Red highlighting indicates areas that require increased investment to provide additional capacity in the near term to ensure system reliability.

# Challenges

carry the increased load and

expected by customers.

maintain the increased reliability

# Solutions

Voltage Conversion Projects: existing 8kV and 13.8kV power lines converted to 27.6kV to increase load capacity.
 Station Investments: intended to ensure stations have peak

•

loadings maintained at or below their 10 day Limited Term Rating to prevent damage to station equipment and avoid brownouts and blackouts.

where needed to increase supply capacity.

New substations, transformer stations, and power lines

Development of new subdivisions resulting from increased demand for new homes, which requires expansion of the distribution system lines and stations. Need investments to increase station and power line capacity to maintain the loading of existing municipal substations and to ensure sufficient space capacity exists such that if there is a loss of one substation, the neighbouring substations can accommodate the lost capacity.

### Pressure: Aging Equipment

PowerStream's distribution system consists of various equipment (**poles, transformers, cables**, etc.) with different installation date profiles. While the majority of the distribution system was installed or rebuilt after 1980, a significant amount of distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in service today. While that old equipment continues to operate for the time being, it is well past its intended service life, and much of it will need to be replaced soon.

Equipment that is still operating beyond its intended service life is more likely to fail, and cause long power interruptions. As time goes on, more and more of the distribution system assets will be operating past end-of-life, unless replaced. This requires investment in system renewal projects and programs. While PowerStream and its predecessor utilities have historically managed asset replacement programs efficiently with moderate levels of investment, the growing number of old assets needing replacement requires a higher level of investment than ever before.

PowerStream plans to proactively replace the oldest and worst condition equipment before it fails. Generally, proactive equipment replacement is less expensive than replacing equipment after an unexpected failure.

Some distribution assets such as pole mounted transformers and residential padmounted transformers, as well as secondary cables, are not proactively replaced. These assets are replaced once they fail. This "run to failure" approach is considered normal utility practice in the industry.

Asset Types	Asset Count (approx)	Average Life (approx)	Oldest Assets (approx)
Wood Poles	46,500	35-75	1940
Distribution Transformers	44,000	25-60	1956
Underground Primary Cable	7900 km	20-55	1965
Distribution Switchgear	1800	30-85	1978
Station Circuit Breakers	399	35-65	1958
Municipal Station Primary Switches	66	30-60	1956
Municipal Station Transformers	65	30-60	1958
Station Reactors	34	25-60	1986
Transformer Station Transformers	22	30-60	1986
Transformer Station 230kV High-Voltage Switches	22	30-60	1986
Station Capacitors	5	25-40	1990

### Asset Summary Chart – main assets by quantity

**Note:** Above data and figures provided from PowerStream Asset Condition Assessment, Rev. 2, November 27, 2012.

Challenges	Solutions
The need to replace poles that are at or nearing end-of-life.	• Proactive replacement: PowerStream plans to replace or reinforce approximately 400 of the worst condition poles per year in order to minimize risk.
Underground primary cables that are at, or near, end-of-life, and the resulting high negative impact this has on reliability for affected customers.	<ul> <li>PowerStream proposes to replace approximately 52 km/year of the worst condition underground cables, and use silicon injection to extend the life of another estimated 47 km/year of underground cables.</li> <li>PowerStream's approach for cable replacement is determined by prioritizing the cable sections that have the worst reliability and the highest customer impact.</li> </ul>
Aging padmounted switchgear cubicles.	<ul> <li>Proactive replacement: PowerStream plans to replace approximately 31 of the poorest condition switchgear units in 2015, rising to 36 per year in 2016-2020.</li> </ul>
The need to replace padmounted transformers, where concerns about condition have been reported.	<ul> <li>PowerStream commenced a proactive replacement program in 2013.</li> <li>PowerStream proposes to proactively replace approximately 60 padmounted transformers per year.</li> </ul>
Automated/remote-controlled switches, switches that are at, or near, end-of-life and therefore likely to fail compromising the ability to prevent feeder and station overloads during the summer peak.	<ul> <li>PowerStream proposes to replace five per year.</li> <li>These are important for a number of reasons, including preventing station overloads during summer peaks, as well as improving reliability and restoration times.</li> </ul>

# Pressure: New Technology

PowerStream is finding that in general, customers have increased expectations. They want to communicate with us around the clock and in new ways, such as through social media. Some customers are seeking a detailed understanding of their electricity consumption, and how their bill is calculated. PowerStream information systems must support these customer needs.

The delivery model of the distribution system is changing. Renewable or other forms of generation have changed power flow from unidirectional to multidirectional. Managing this fundamental change requires increased technological investments.

Challenges	Solutions
The requirement to develop and support smart grid technology to meet the high reliability demands of today's electricity consumers.	<ul> <li>Improvements to the distribution system to support growing numbers of Electric Vehicles.</li> <li>Improvements to the distribution system to support increased renewable generation and energy storage initiatives.</li> <li>Develop and promote consumer energy management initiatives to reduce energy demand.</li> </ul>
An outdated billing system, over 35 years old, that cannot support a growing number of customers, has limited ability for interactive features, and no longer has vendor support.	• A new modern <b>billing system</b> , expandable in the future as required, to provide a more efficient platform for customers with increased interactive support and customer information security. A new modern billing system will also provide increased efficiencies by integrating with other systems, and produce long-term cost savings.
The replacement of end-of-life remote- controlled switches to ensure rapid and automatic transfer of loads in emergencies and reduce restoration times.	<ul> <li>Installation of new smart remote-controlled power line switches and reclosers.</li> <li>A formal decision-making process for determining the most cost effective quantity of switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.</li> </ul>
The need to replace old and difficult to operate "mini-rupter" (high capacity isolating) switches in commercial/ industrial locations.	• Installation of new high-capacity isolating <b>switches</b> that increase operational efficiencies and reduce the need for costly power interruptions when performing routine maintenance.
New OEB regulations that require higher intelligence metering equipment for all commercial/industrial customers over 50kW by 2020.	• Replace 4400 meters with new <b>smart technology</b> meters in a pre-planned efficient multi-year program.

# Pressure: Security

As technology continues to be utilized in every aspect of the utility's business, there is an increasing risk of cyber security attacks that could potentially affect confidential customer or corporate information, customer privacy, power delivery, and even the safety of employees or customers through the unauthorized use of PowerStream technology. One incident could do serious damage to the corporation and to its corporate image. In addition, there is the on-going risk of physical security; the physical protection of buildings and stations, and the monitoring of critical equipment to protect from impending failure.

Challenges	Solutions
Evolving risks to cyber security of customer information and grid due to aging and unsecure IT equipment.	<ul> <li>Firewall/Intrusion Detection System/Intrusion Protection System—this is a security checkpoint between the trusted and untrusted network/device/users and is also used to continuously monitor for any malicious activity and can automatically take action in certain instances.</li> <li>Network Access Control—this dynamically monitors and controls devices, applications and users to deny unauthorized external access to the network.</li> <li>Identity and Access Management—this manages user access and privileges granted throughout the PowerStream environment</li> <li>Security Information and Event Management—this is real-time logging and analysis of security alerts.</li> <li>Vulnerability Assessment Tool—this scans, identifies, quantifies and prioritizes vulnerabilities in the PowerStream environment and suggests remediation solutions.</li> <li>Mobile Device Management—this controls mobile devices connected to our network and can authorize, wipe, secure and encrypt corporate information as required.</li> <li>Enterprise Change Management—this process and associated technology allows PowerStream to effectively deal with constant change through a structured approach to transitioning systems, applications and technologies from current to desired future states.</li> </ul>
Risk of vandalism to substation buildings and equipment.	<ul> <li>Install equipment monitoring Infrared cameras at 16 additional stations over the next 6 years.</li> <li>Install perimeter video surveillance cameras at 17 additional stations over the next 6 years.</li> </ul>

### Pressure: Obsolescence

Despite an ever increasing number of weatherrelated interruptions each year, PowerStream has worked hard to stay within the boundary of its average historical reliability performance targets of one outage totalling 60 minutes per customer, per year.

While PowerStream continues to demonstrate strong reliability performance in the operation of its distribution network, it is not without its challenges. There are areas and pockets within the PowerStream distribution system that suffer poor reliability due to the type of legacy construction that was once considered acceptable or even preferable. An example of this would be older houses connected to overhead power lines located in the back lot (rear lot) of those properties. The reliability of rear lot supply connections is worse under severe weather conditions than the current standard front lot connections. In addition, the cost to maintain these rear-lot connections is much higher than the cost to maintain front lot connections.

# Challenges

Rear Lot Conversion program: Capital work required to address reliability, safety, operations and customer service concerns on rear lot supply connections.

# Solutions

- There are 49 areas of rear lot construction scattered among eight of the municipalities of PowerStream.Most of those areas were constructed in the 1950's, 1960's and 1970's. The oldest dates back to 1948.
- PowerStream proposes to replace the worst areas of rear lot connections on an annual basis over many years until all areas are converted.
- The average cost of this conversion work is estimated to be \$1.2M per rear lot area.
- Elimination of rear lot supply connections will result in long-term operational efficiencies and reduced maintenance costs.

### Pressure: Major Events

PowerStream's system is built to quickly restore power after the loss of one or two key elements in the electricity grid. But what happens when there is a major disruption to the system?

PowerStream has been severely impacted by weather-related events over the past year. The December 2013 ice storm, microbursts in York region and tornados in the North service area have all highlighted the risk to the grid from major events. Major events are rare events that have a major impact. The Insurance Bureau of Canada reports that severe weather is likely to increase over the next 40 years.

The December 2013 Ice Storm in Ontario severely tested the emergency preparedness of electrical utilities in Southern Ontario including the Greater Toronto Area where hundreds of thousands of customers were left without power, some for as long as a week, or even longer. An independent assessment of PowerStream's response to that storm highlighted a number of areas where improvements are required at PowerStream to be better prepared for future severe storms and emergency events. Key areas identified for improvement include:

- 1. Improve external communications with customers.
- 2. Improvements to Customer Care systems and staffing.
- Improve Outage Management Systems and utilize outage reporting via existing Smart Meters.
- 4. Improve vegetation management.
- 5. Elimination of rear lot services, and convert to front lot.
- 6. Upgrade or underground key distribution lines.

Challenges	Solutions
The need for emergency preparedness during unplanned events and expenses.	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e. <b>poles, transformers</b>, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and materials are available for emergencies.</li> </ul>
The need to improve the supply to those customers who are more vulnerable to outages and duration of outages, specifically rear lot supply.	<ul> <li>Plan to replace rear lot supplies on an annual basis until all are remediated.</li> </ul>
The need to make changes to key distribution lines to withstand increased severity of weather events.	<ul> <li>Plan to increase structural integrity of key assets (i.e. tension cables designed to add stability to poles).</li> <li>Upgrade or underground key wires.</li> </ul>

The investments discussed earlier in the primer are focused on minimizing day-to-day outages and increasing the speed by which electricity is restored. Additional investments could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

**13.** A significant amount of PowerStream's distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in-service today. PowerStream works hard to extend the life of our existing equipment because it helps to keep rates down, but as equipment gets older it becomes more likely to fail. PowerStream has two approaches to older equipment.

- If the failure of a piece of equipment will impact a large number of people, result in a long outage or if an
  inspection shows the equipment is in poor condition, PowerStream does initiate equipment replacement
  before failure.
- When an equipment failure has only a limited impact and can be quickly replaced, PowerStream's policy is to leave the equipment in place until it breaks down to get all the value possible from that equipment.

### What do you think of this policy?

- I am willing to pay more to replace all equipment before it fails.
- I support the current approach of allowing equipment to run to failure when that failure impacts only a few customers for a limited period of time.
- Don't Know

**14.** When it comes to replacing aging equipment, which of the following points of view is closest to your own?

- PowerStream should invest what it takes to replace the system's aging infrastructure to reduce the risk of power outages; even if that means my electricity bill will increase by a few dollars per month.
- PowerStream should scale back their investment in renewing the system's aging infrastructure to reduce the size of any bill increase; even if that means more or longer power service interruptions.
- Don't Know

**15.** While there are clear benefits from new technology, there are also costs. The system functions well on the old technology. Do we want to pay more to secure the benefits new technology can deliver?

When it comes to investing in new technology, which of the following points of view is closest to your own?

- Investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream.
- I think the benefits of new technology are important and investments in new technology should be a priority for PowerStream.
- Don't know

**16.** The investments discussed earlier in the primer are focused on minimizing the day-to-day outages and increasing the speed by which electricity is restored. There are additional investments could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average GS > 50 kW customer pays \$963 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather?

\$

# What this Plan Means for You

### It all comes down to what you pay and what you receive in return.

What will you get? PowerStream's plan for 2016 to 2020 deals with the challenges outlined in this primer to deliver a system that will maintain or achieve modest improvements in reliability and service.

What will it cost? GS > 50 kW customers with peak montly demand of 250 kWh may see an increase of **\$74.60** per month or **6.7 per cent** annually on the distribution portion of their bill over the next five years. As such by 2020, the average GS > 50 kW customer will be paying an estimated **\$373.00** more per month on the distribution portion of their electricity bill. It is important to note that other increases on the bill by other entities are also possible.

There are two main elements in that increase:

- An increase of approximately 2.1 per cent or \$23.38 per month in operating costs which reflects inflation and new costs which are offset in part by efficiency savings;
- An increase of approximately 4.6 per cent or \$51.22 per month for new capital investments to deal with the issues discussed earlier such as growth, aging infrastructure and new technology.

In addition, in the first year of the plan there is a "catch-up" increase to deal with expenses that were not properly covered under the existing rate adjustment formula. The next section explains the need for that catch-up.

### Current Revenue Shortfall


The formula for setting PowerStream's rates in 2014 and 2015 is not keeping up with the need for new investment.

PowerStream's rates were set in 2013 using the cost of service method where the OEB sets rates at the level needed to fund the operation of the utility. That worked well in 2013.

However, in 2014 and 2015, rates were not based on actual costs. Instead, a formula was applied which adjusted rates for inflation less an adjustment for efficiency, referred to as a price cap index (PCI) adjustment. This formula does not provide enough revenue in rates to fund the actual capital investments being made in these years.

The OEB recognized that problem and created the new Custom Incentive Regulation rate setting method which PowerStream will be using in this rate filing. This method will alleviate this issue going forward but there is still a need to deal with 2014 and 2015 investments. The chart below compares the revenue from rates using the PCI to the revenue needed to fund utility operations on a cost of service basis. Over 2014 and 2015, there will be a revenue shortfall of approximately \$13.2 million. This shortfall is being funded by PowerStream's municipal shareholders from past earnings retained in the company. However, using savings to make up for the missing revenue will restrict PowerStream's ability to make the necessary future investments to maintain its system and the level of service provided to its customers. The catch-up will enable PowerStream to fund those needed investments.

### **Revenue Shortfall (\$millions)**



Most of the rate increase in 2016 is to provide funding for capital investments in 2014 and 2015. This will result in an increase of **\$76.35** a month for the average GS > 50 kW customer with peak monthly demand of 250 kW.

One of these major capital investments is a new billing system. PowerStream made the second largest investment in its 10 year history when it decided to bring in a new billing system in 2014/2015. PowerStream is committed to providing customers with accurate billing information from meter to payment. However, the old system was implemented 30 years ago and just wasn't keeping up with new demands such as mobile access and self-service options customers have said that they expect today. Changing to a modern system requires both a significant capital investment and an increased operating budget. Not only will it provide much better access for customers and staff, it will do so with a much higher level of security for personal information, a key concern in these times. This system will be fully implemented in 2015.

### Increased Capital Spending

PowerStream has developed a list of capital investment drivers and proposes capital investment programs based on these key drivers. The definitions of the key drivers are below.

#### **Service Requests**

PowerStream has an obligation to connect a customer to its distribution system. This includes both traditional demand customers and distributed generation customers. Requests also can include system modifications to support infrastructure development by government agencies, road authorities and developers. Normal connection costs are recovered through the revenue from new customers. Unusual connection costs are paid by the customer being connected.

### **Increased Delivery Capacity**

As new customers are connected, PowerStream needs to expand the core elements of its distribution system, including expanded or new distribution stations and enhanced or new feeder lines. This is the fundamental infrastructure that allows new customers to be hooked up to the distribution system and is paid for by the extra revenue from new customers served over time.

#### **System Efficiency**

To provide customers with the best service possible, there is always a need to improve restoration capability. As the population in PowerStream's service territory continues to grow, the system also needs to grow in order to be able to handle new connections.

#### **Mandated Compliance**

Environmental, reliability and safety standards are updated on a regular basis and PowerStream's system must be updated to keep up with these standards. Agencies that impact PowerStream include the Ministry of Energy, Measurement Canada, the OEB, the IESO and/or other regulators.

#### **Obsolescence**

Improvements in technology can require PowerStream to replace equipment that is still functional but no longer meets current operating practices or current standards. Reasons for replacement include:

- the equipment is no longer manufactured;
- there are no spare parts;
- are unable to have maintenance performed on them;
- there are operational constraints or conflicts, which can result in increased reliability and/or safety-related risks.

#### **Aging or Poor Performing Equipment**

Where there is the imminent risk of failure due to age or condition deterioration, and these potential failures will result in severe reliability impacts to customers as well as potential safety risks to crew workers or to the public, refurbishment or replacement is required.

### **Business Support Costs**

PowerStream is not just the local electricity grid itself, it is the business that operates that grid. The utility needs storage facilities for equipment, workshops to maintain and repair equipment and offices for people who manage your accounts and the electricity system. PowerStream needs vehicles for its crews, as well as computer systems to manage customer accounts, track equipment and operate the grid. While this is a relatively small slice of the capital spending over the next several years, it is just as critical to have IT systems identify where an outage is and where the needed parts are stored as to have the replacement parts themselves.

	Capital Investment Drivers	Primary Driver	Source
System Access	Subdivisions and New Connections Road Authority Metering Other Customer Initiated Work	Service Requests	Developers, Customers, Road Authorities
System Service	Reliability including Distribution Automation Additional Capacity - Lines Additional Capacity - Stations (TS and MS) Security Smart Grid Safety	Reliability Support Capacity Delivery System Efficiency Safety	PowerStream
System Renewal	Distribution Lines - Emergency/Reactive Replacement Overhead Lines and Assets Planned Replacement Underground Cable and Asset Planned Replacement Rear Lot Conversion Program Stations/Protection & Control Asset Replacement (Planned & Emergency)	Mandated Compliance Obsolescence Mitigate Failure Risks Safety	Regulator Safety Authority PowerStream
General Plant	Interest Capitalization Customer Service Information Service and Communication Systems Buildings/Facilities Fleet Tools	Capital Investment Support Customer Service	PowerStream

Looking ahead at the next five years and all the categories identified above, PowerStream is proposing to spend \$641 million on new capital investments. This will result in an annual increase of about 6 per cent on the distribution portion of your bill which is about three quarters of the proposed rate increase.



### 2016 - 2020 Forecasted Capital Expenditures (\$ millions)

With the proposed levels of capital and operating budgets for 2016 to 2020, in 2020 PowerStream will continue to operate on less revenue per customer than the average Ontario local distribution company.

Feedback

**17.** Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream system and what they are planning to do to meet those challenges?

Very well

- Somewhat well
- Not very well
- I don't understand at all

**18.** From what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction?


Right direction

- Wrong direction
- Don't know

19. And why do you feel that way?

### The Impact on Your Bill

GS > 50 kW customers with an average peak monthly demand of 250 kW will see an increase of **\$74.60** per month or **6.7 per cent** annually on the distribution portion of their bill over the next five years. As such by 2020, the average GS > 50 kW customer will be paying an estimated **\$373.00** more per month on the distribution portion of their electricity bill.



#### Estimated Typical GS > 50 kW Annual Increase In Monthly Bill

Feedback

**20.** Considering what you know about the local distribution system, which of the following best represents your point of view:

- The rate increase is reasonable and I support it
- I don't like it, but I think the rate increase is necessary
- The rate increase is unreasonable and I oppose.
- Don't know

21. And why do you feel that way?

# Final Thoughts

PowerStream values your feedback. This outreach is a new requirement, so this is the first time that the utility has conducted a review about its upcoming investment plan in this type of format.

General Impression - Overall, what did you think about this primer?

**Volume of Information**: Did PowerStream provide too much information, not enough, or just the right amount?

Content Covered: Was there any content missing that you would have liked to have seen included?

Outstanding Questions: Is there anything that you would still like answered?

Suggestions for Future Consultations: How would you prefer to participate in these consultations?

# Glossary

**Breakers:** Devices that protect the distribution system by interrupting a circuit if a higher than normal amount on power flow is detected.

**Feeder Circuit:** Is a wire that connects stations to the broader distribution system in order to deliver electricity to customers.

**Generation Station:** A facility designed to produce electric energy from another form of energy, such as fossil fuel, nuclear, hydroelectric, geothermal, solar thermal, and wind.

Kilowatt (kW): 1000 watts.

**Local Distribution Company (LDC):** In Ontario, these are the companies that take electricity from the transmission grid and distribute it around a community.

OM&A: Operations, Maintenance and Administration

**Stations:** These include tranformer stations and distribution stations. They are used to switch generators, equipment, and circuits or lines in and out of a system. It also is used to change AC voltages from one level to another.

**Switches:** These control the flow of electricity—they direct which supply of electricity is used and which circuits are energized. Distribution systems have switches installed at strategic locations to redirect power flows for load balancing or sectionalizing.

**System Access:** Projects required to respond to customer requests for new connections or new infrastructure development. These are usually a regulatory requirement to complete.

**System Renewal:** Projects to replace aging infrastructure in poor condition.

**System Service:** Primarily projects that improve reliability.

**General Plant:** Investments in things like tools, vehicles, buildings and information technology (IT) equipment that are needed to support the distribution system.

**Transmission lines:** Transmit high-voltage electricity from the generation source or station to another station in the electricity grid.

**Transformer:** A piece of equipment that reduces the voltage of electricity from a high level to a level that can be safely distributed to your area or to your residence/business.

**Underground Cable:** A conductor with insulation, or a stranded conductor with or without insulation and other coverings (single-conductor cable), or a combination of conductors insulated from one another (multiple-conductor cable).

**Volt (V):** A unit of measure of the force, or 'push,' given the electrons in an electric circuit. One volt produces one ampere of current when acting on a resistance of one ohm.

Watt (W): The unit of electric power, or amount of work (J), done in a unit of time. One ampere of current flowing at a potential of one volt produces one watt of power.

**Wire:** A conductor wire or combination of wires not insulated from one another, suitable for carrying electric current.



If you have any additional questions or comments about PowerStream's Distribution System Plan Review please email:

CustomerFocus@powerstream.ca

or send your questions or comments to:

PowerStream Attn: DSP Review 161 Cityview Boulevard, Vaughan, Ontario L4H 0A9



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix E: PowerStream Work Book Delivered: February 24, 2015



# Appendix E

# **PowerStream Work Book**

Delivered: February 24, 2015

**Distribution System Plan** 

# DISTRIBUTION SYSTEM PLAN REVIEW PRIMER



PowerStream is a community-owned energy company providing power and related services to more than 370,000 customers residing or owning a business in Alliston, Aurora, Barrie, Beeton, Bradford West Gwillimbury, Markham, Penetanguishene, Richmond Hill, Thornton, Tottenham and Vaughan as well as Collingwood, Stayner, Creemore and Thornbury through a partnership with the Town of Collingwood in the ownership of Collus PowerStream.

# Table of Contents

Why Are We Here? Electricity Grid 101 PowerStream's Grid Today Challenges and Solutions What this Plan Means for You Final Thoughts Glossary



# Planning for Future Energy Needs

This primer and consultation concentrates on the short-term plan for PowerStream's distribution system over the next five years. The graphic below shows the various planning initiatives ongoing within the Province. In addition to the short-term distribution plan being discussed in this primer, there are other planning initiatives undertaken to ensure that the electricity system maintains reliability and works efficiently for the benefit of customers.

Energy planning occurs at the provincial level (by the Ministry of Energy and government agencies such as the Ontario Power Authority) and at the regional and municipal level as well as by each electricity distributor for their service territory and relevant agencies.

If you're interested in broader medium and long term electricity issues such as Ontario's Long-Term Energy Plan, regional planning, conservation planning and general energy policy in the province, there are other opportunities to provide your feedback.


#### **Ontario's Long Term Energy Plan:**

The Ontario Government's plan details how electricity will be generated and the longer-term conservation strategy for the province. It can be found at this website: <a href="http://www.energy.gov.on.ca/en/ltep/">http://www.energy.gov.on.ca/en/ltep/</a>

#### **Regional Planning:**

The Ontario Power Authority (OPA) looks ahead to the future electricity needs of your region and how those needs can be addressed through Conservation and Demand Management (CDM), local generation, and electricity from outside the region. You can follow the OPA's regional planning process at this website: http://www.powerauthority.on.ca/power-planning/regional-planning

### **Ontario's Energy Planning Diagram**



local generation options have been

considered, in addition to core

infrastructure ("wires") solutions

# Why Are We Here?

The electricity industry in Ontario is regulated by the Ontario Energy Board (OEB), which requires distribution companies, such as PowerStream, to prepare and submit a distribution system plan to show how it will sustain the area's electricity distribution system over the next five years.

The OEB recently developed a new regulatory requirement for distribution system plans that requires distribution companies, such as PowerStream, to gather information about customer needs and preferences on distribution system investments and report on how they responded. PowerStream needs your participation to ensure its plan addresses your needs and expectations.

# You don't have to be an electricity expert to participate

This consultation is not about technical issues. The OEB hearing process will allow experts representing various consumer and interest groups (called intervenors) to challenge the detailed engineering and business decisions within PowerStream's plan. This consultation focuses on the goals of the system. Should PowerStream focus more on reducing the number of outages or the lengths of outages? Should reliability be increased even if rates go higher, or should PowerStream maintain the current level of reliability and keep rate increases lower.

This primer has been developed to guide you through PowerStream's plan. As you proceed, it asks questions designed to collect your feedback. In order to facilitate this, the primer is divided into several sections that explain the distribution system, the challenges it faces and, more importantly, how PowerStream will be responding to those challenges.

Your input, and PowerStream's response to your input, will be presented to the OEB and intervenors when PowerStream files its rate application for 2016 to 2020 in the spring of 2015.

**Innovative Research Group Inc.** has been engaged by PowerStream to collect participant feedback and will deliver it to PowerStream to assist them in shaping their plans.

forecasting

design

Interconnections and grid

### PowerStream's Rate Application Process

PowerStream assesses system needs

# Collect customers needs and preferences

Refine plan (where necessary)

Reports on how plan responds to customer input

Files plan with OEB

Interrogatories and OEB rate hearing process

OEB sets PowerStream's distribution rates

### Your Electricity Bill

Every item and charge on the bill is mandated by the provincial government or regulated by the OEB. There are two distinct cost areas that make up the "Delivery" charge on your bill: distribution and transmission. While PowerStream collects both, it remits the transmission charge to Hydro One. The distribution charges are what PowerStream uses to fund its utility needs.

Distribution charges are one of several charges on your bill. Current monthly distribution charges are approximately \$61 for a typical PowerStream general service customer who consumes 2000 kWh in a month. The amount you pay varies depending on the amount of electricity you use.

PowerStream's distribution rates are subject to the review and approval of the OEB. The rate revenue covers PowerStream's capital investments and operating expenses.

### **Sample Electricity Bill**

	<u>Customer Service</u> )-87 808n m to 4 30 pm (Mm Fn)	7 963-6900		Bill # 3000000 PLEASE DETACH YOUR, PAYMENT WHUN PAYING A	AND ENCLOSE THIS PC PLEASE BRING ENTIR
ACCOUNT NUT	MBER 60-16-66666-601 SI	ERVICE AT 6	502 AVEN		BILLING I Sep 10,
PLEASE RETU	RN THIS PORTION			AMOUNT PAID	AM RUNT \$174
REGIONAL LTL 6602 AVENUE C VAUGHAN ON	RT				DUE D Sep 30
	1:0434	7-900:			96
ACCOUNT NUM		RVICE AT	6602	AVENUE CRT	P.C
SERVICE FROM Elect. Jul 23, 14	BILLING PIRIOD TO DAYS Aug 22, 14 30		REG	IONAL LTD ID TYPE ART	BILLI
METER NUMBER PREVIOUS R		CONSUMPTION U		DESCRIPTION	COMP
3,000 kwh/month of electric see Ontario.ca/OCEB OR 1 Ontario is building strong,c Ontario.ca/energyplan	efit takes 10% off the cast of up to 20 use. Some exceptions apply glea 388-663-6150 To last more about an electronicy system visu cast electronicy system visu.	ut how		Previous Bill TELE-PAYMENTS Billing Forward On-Presk KWin 336 OF-Preak KWin 336 OF-Preak KWin 236 OF-Preak KWin 236 OF-Preak KWin 246 Mid Preik KWin 22 Delivery Deli	arges 9 75 @ 0.135 7.170.075 7.58 @0.112 ts Tharge 7 603 646
Loss Factor of 3.45 % a	pplied to kWh. Adjusted kWh 10.	34.50	NATER CON	SU PTICN HISTORY	ACCOUR
Aug 22,14 30	CONSUMPTION ( KWh DAY 1000.00 33.33	READ DATE	DAY		DAY \$1
Jul 23 14 31 Jun 23,14 30 May23 14 31	1050 00 33 87 980.00 32.66 1070 00 34 51	-			DUI
Apr 23,14 30	990.00 33.00				Sep 3
Power Stream	Customer Service 1-877-96 8:00 a.m. to 4:30 p.m. (Mon – Fri)	3-6908	PLE E&	ASE RETAIN THIS PORTJ ASE BRING ENTIRE BILL DE 16-66666-601	

#### **DISTRIBUTION SYSTEM PLAN REVIEW**


# Feedback

1. How familiar are you with the electricity system in Ontario, and the services PowerStream is responsible for?


- Very familiar
- Somewhat familiar
- Not very familiar
- Not at all familiar
- Don't know

COMMERCIAL PORTION WITH IRF BILL DATE DUE DATE 2014 LING DATE p 10, 2014 IMERCIAL AMOUNT 181.35 181.35CR 0.00 47.22 \*# 33.54 \*# 26.60 \*# 51.17 \*# 6 14 \*# 7.00 \*# 22.32 # 19.40CR NT BALANCE 174.59

E DATE 30, 2014 LYOUR RECORDS. The plan PowerStream is proposing will maintain reliability at or above its current level. The resulting levels of capital investment and operational spending over the next 5 years will result in an average annual increase of **\$5.25** per month or **8.2 per cent** on the distribution rates charged by PowerStream. At the end of the plan in 2020, the average general service business will be paying an estimated **\$26.24** more per month on the distribution portion of their electricity bill. Other items on your bill may also increase.



### About 20 per cent of the average general service electricity bill goes to PowerStream



# Electricity Grid 101

# Who Does What in Ontario's Electricity System?

Ontario's electricity system is owned and operated by public, private and municipal corporations across the province. It is made up of three components: generation, transmission and distribution.



### GENERATION Generating facilities co

forms of energy into el



### TRANSMISSIC Transmission lines (hig

connect the power profacilities to transformer



PowerStream is funded by the distribution rates paid by its customers. Periodically, PowerStream is required to file an application with the OEB to determine the funding available to operate and maintain the distribution system. PowerStream must submit evidence to justify the amount of funding it needs to safely and reliably distribute electricity.

### Who Protects Consumer Interests?

PowerStream's evidence is assessed in an open and transparent public process known as a rate hearing. A number of public intervenors with electricity industry expertise submit their own evidence challenging PowerStream's plans and assumptions. At the end of the process, the OEB weighs the evidence and decides on the rates PowerStream can charge for distribution.



### DISTRIBUTION Distribution lines (at m carry electricity to hom

businesses.



CONSUMERS Electricity is delivered and businesses.

V onvert various lectric power.	<b>EXAMPLES</b> Ontario Power Generation TransCanada Energy Ltd Bruce Power Samsung Renewable
DN gh voltage lines) oduced at generating er stations.	EXAMPLE Hydro One
N nedium voltages) nes and	EXAMPLES Stream Toronto Hydro Newmarket Hydro
to homes	<b>EXAMPLES</b> Residential Commercial Industrial


# How is Ontario's Electricity System Regulated?

The Ontario Ministry of Energy sets energy policy. It sets the rules and establishes key planning and regulatory agencies through legislation.

The mission of the Ontario Energy Board (OEB) is to promote a viable, sustainable and efficient energy sector that serves the public interest and assists consumers to obtain reliable energy services at reasonable cost. It is an independent body established by legislation that sets the rules and regulations for the provincial electricity sector. One of the OEB's roles is to review the distribution plans of all electricity distributors and set their rates.

The **Ontario Power Authority** (OPA) is responsible for medium and long-term electricity planning to ensure an adequate supply of electricity is available for Ontario residents and businesses. The OPA receives directives from the Ministry of Energy (i.e. energy supply mix, Green Energy Act), but otherwise works at arm's-length from the government.

The Independent Electricity System Operator (IESO) is responsible for electricity supply over the shortterm. It operates the grid in real-time to ensure that Ontario has the electricity it needs, where and when it needs it.



COMMERCIAL

RESIDENTIAL

#### INDUSTRIAL

# PowerStream's Grid Today

This section describes the construction of PowerStream's distribution grid including its overhead, underground and secondary systems. It also explains the corporation's historical growth and current electrical infrastructure.

### The Background of PowerStream's Distribution Grid

PowerStream owns and operates \$1.17 billion in capital assets and is the second largest municipally- owned electricity distribution utility in Ontario. It distributes about eight per cent of Ontario's electricity demand. PowerStream's electrical grid is comprised of overhead, underground and secondary systems of various voltages. PowerStream was formed in 2004 from the amalgamation of Hydro Vaughan, Markham Hydro, and Richmond Hill Hydro. Aurora Hydro was purchased in 2005, and in 2009, Barrie Hydro merged with PowerStream.

Each original utility operated independent distribution systems, and as a result, the infrastructure varies from region to region. PowerStream has been working to gradually standardize this equipment, which will help improve reliability and safety across the regions, and make maintaining the system more efficient.

PowerStream is owned by three municipalities and regulated by the OEB. As such, any profits obtained by the utility are provided to the municipalities as a dividend, or reinvested into the distribution system.

# A Look at PowerStream's Growth

PowerStream has been serving York Region since 2004 and Simcoe County since 2009, and has seen remarkable change and innovation through the years. Although PowerStream as an entity dates back to 2004, the first electric system and street lights in the service territory were installed in Barrie in 1888, Markham in 1890-1891, and in neighbouring areas soon after.

PowerStream has a mix of older and newer distribution systems across all of its service territory. PowerStream is systematically and prudently upgrading older areas. Of course, even as this work is completed, the overall system continues to age.

PowerStream is a product of the largest voluntary consolidation of local distributors and is an organization committed to becoming an innovative and socially responsible leader in power distribution and related services. Growth is a key performance driver for PowerStream, and is achieved through increases to its residential and commercial customer bases.


Large projects currently underway include the new Vaughan Metropolitan Centre project at Hwy 7 and Jane Street, the new Vaughan Campus of Mackenzie Health, and the expansion of the Toronto Transit Comission subway into York Region. All of these projects highlight the expansion and growth occurring in PowerStream's service territory.

# PowerStream's Distribution System

Every system is unique with its own history and challenges. In order to better understand the current PowerStream system, we first have to understand all of the different components and how they impact the way in which you receive electricity when you need it. The image below and following terms and definitions will help guide you through the system from when you turn a switch on to when you receive your bill.

PowerStream's distribution system is made up of a number of components which work together to transport electricity to your house or business.

### **Distribution System Diagram**



### **Transformer Stations and Municipal Substa**

PowerStream owns 11 of the 25 Transformer Stations (TSs) that connect PowerStream's distribution system to the 230 Kilovolt (kV) provincial transmission grid owned by Hydro O and operated by the IESO. In fact, the very firs municipally-owned transformer station in Ontar was built in PowerStream's service territory (Markham) back in 1985.

Municipal Substations (MSs), 54 in total, also p an important role in PowerStream's distribution system, further transforming higher voltage electricity to a lower voltage that is suitable for distribution to customers.

**Transformers** – Important pieces of equiprent that reduce the voltage of electricity from a level to a level that can be safely distributed your area, or to your residence/business.

**Breakers** – Devices that protect the distribution system by interrupting a circuit if a higher the normal amount of power flow is detected.

**Switches** – Control the flow of electricity an steer the current to the correct circuits.

**Feeder Circuits** – Are the wires that connective stations to the broader distribution system order to deliver electricity to customers.

r One first tario	<b>PowerStream's Overhead System</b> The overhead system is made up of distribution lines that operate at various voltages depending on their purpose and destination. PowerStream has 2,535 km of overhead distribution lines in its service territory. These distribution lines are attached to the top of hydro poles.
o play ion ior local	Along the distribution line, pole-top transformers step the voltage down to useable levels of 120V-600V. From there, the electricity is delivered to customers through a secondary line that runs from the transformer to an individual home or business.
pment a high ed to	PowerStream has 3500 switches, and over 330 pole-mounted remote-controlled switches located throughout its distribution system. These switches, which are controlled from PowerStream's Main System Control Centre, greatly improve operating efficiencies, and reduce restoration times whenever a power interruption occurs.
bution than and	<b>PowerStream's Underground System</b> PowerStream's underground system consists of high and low voltage cables, metal enclosed switchgear and transformers situated on concrete pads. In residential areas, underground cables distribute electricity from the TSs or MSs to
nect stem in	padmount transformers located on the municipal boulevards. Like the overhead system, these transformers step the electricity down to useable voltages of 120V-600V, and the power is then delivered to customers through over 5000 km of buried low voltage wires.
	When distributing electricity to urban areas or larger customers, larger transformers are used.

PowerStream has 1800 gears, and over 40 padmounted switchgears that are controlled remotely from its System Control Centre. These remote-controlled switches are critical for improving operating efficiencies and power restoration times in the underground distribution system.

# Feedback

**2.** How well do you feel you understand the important parts of the electricity system, how they work together, and which services PowerStream is responsible for?

- Very well
- Somewhat well
- Not very well
- I don't understand at all

3. Generally speaking, how satisfied are you with the service you are receiving from PowerStream? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

4. Is there is anything in particular that PowerStream can do to improve its service to you?



### Reliability

Delivering reliable power safely is PowerStream fundamental purpose. Three key standard indu measures are used to track system reliability. include:

#### SAIFI

System Average Interruption Frequency Ind This measure shows the number of outages an

average PowerStream customer experiences in year.

### SAIDI


System Average Interruption Duration Index This measure shows the amount of time an ave PowerStream customer is without power in a year.

### CAIDI

**Customer Average Interruption Duration Index** This measure indicates on average how long it takes for PowerStream to restore power to a customer after a power outage.

All planned and unplanned sustained interruptions are used to calculate these indices.

### PowerStream SAIDI [minutes] Comparison to Other CEA (Canadian Electricity Association) Urban Utilities for All Outages



m's lustry They	How is PowerStream Performing: For reliability performance, the OEB expects that the distributor's current reliability performance (SAIDI, SAIFI, CAIDI) should, at minimum, remain within the range of its historical previous 3 year performance. PowerStream's plan aims to meet this
dex n	requirement.
in a	As seen in the chart below, PowerStream's SAIDI performance has been at par or better than average of the other comparable Canadian urban utilities with the exception of 2013 when PowerStream was
x	hit hard by an unusual weather event (December
/erage	Ice Storm).
(oor	



### **Controllable vs. Uncontrollable Factors**


Electricity outages can be caused by factors that PowerStream can and cannot control.

Uncontrollable events include lightning, adverse weather, adverse environment (e.g. salt contamination) and 3rd party created events.

Controllable events include scheduled outages in order to perform work on the distribution system, tree contacts, defective equipment and errors caused by people.


The chart below shows that more than half of the outages PowerStream customers experience are caused by controllable events.

### Total SAIFI, Controllable & UnControllable SAIFI [2008-2013]



As the breakdown in the chart below illustrates, defective equipment is far and away the largest contributor of controllable outages.

### **Breakdown of Controllable SAIFI** Excluding Loss of Supply and Major Event Days [2008-2013]



### **Capital Expenditure and Outages**

Managing equipment failure is a never-ending race. Each year PowerStream invests in replacement or rehabilitation of its oldest assets and systems. The assets in the poorest condition are identified through an annual inspection program. However with each passing year the rest of the assets get older and a new set of assets falls into poor condition.

Outages are also targeted as a result of poor performing feeders identified through reliability statistics each year. As these feeders are worked on and reliability improves, a new set of feeders falls to the bottom of the performance ratings.

As you will see in the following pages, over the next five years, PowerStream is planning investments in new equipment and the rehabilitation of existing equipment, such as underground cables, to reduce the number of outages due to equipment failure.

While outages are to some degree chance ev the investment in new equipment matches the profile of the system and is expected to sustai current level of reliability and to achieve reliab improvement in the worst performing areas.

### **Capital Expenditure and Restoration Times**

Restoration time is an area where PowerStea actively pursues improvement. Restoration tir depend on three things - the physical capacity work around a problem, the speed at which the utility can re-route electricity through that phys network, and the speed by which the broken can be repaired.

As PowerStream expands the system through system service updates such as higher voltage

vents, le aging ain the bility	lines, new stations and feeder lines or similar system improvements, the utility is building more capacity to work around outages.
es am imes ty to he	As PowerStream adds remote monitors to pin- point where faults are occurring and add remote or automated switches to avoid the need to send a crew to manually flip a switch, the utility is increasing the speed by which power can be restored.
vsical parts	Finally, investments in areas such as equipment standardization, GPS devices and improved scheduling tools all contribute to our ability to replace broken equipment more quickly.
h	

# Feedback


5. As far as you know, in the past year, did you experience any outages due to unusual weather such as the ice storm, microbursts or tornados?

- Yes
- No
- Don't know

6. Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

7. Is there is anything in particular PowerStream can do to improve its service to you during these extreme weather events?



the past year?

- Zero One Two Three
- Four
- Five or more

the longest you experienced?

- Less than 15 minutes
- 15 to less than 30 minutes
- 30 minutes to less than 1 hour
- 1 hour to less than 3 hours
- 3 hours to less than 6 hours
- 6 hours to less than 12 hours
- 12 to less than 24 hours
- More than 24 hours
- Don't know

the outage? Would you say ...

- Very satisfied
- Somewhat satisfied
- Somewhat dissatisfied
- Very dissatisfied
- Don't know

outages?

of reliability is ...

Very good
Good
Acceptable
Poor
Very poor
Don't know

### 8. Other than outages during unusual weather events, how many outages did you experience in


9. Aside from unusual weather events, if you experienced an outage in the past year, what was

**10.** If you experienced an outage, how satisfied are you with the way PowerStream responded to

**11.** Is there is anything in particular PowerStream can do to improve its service to you during

**12.** Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level

### Capacity Constrained Areas of PowerStream's Service Territory



# Challenges and Solutions

### Pressure: Growth

Fueled by increased economic development and demand for new housing in York Region and Simcoe County, PowerStream adds over 8,000 new customers to its existing customer base every year. This growth in customers and load puts increasing pressure on PowerStream's distribution system, which requires extending power lines, upgrading capacity to existing power lines, and adding new capacity to load constrained area.

# Challenges

Lines and equipment that cannot carry the increased load and maintain the increased reliability expected by customers.

**Development of new subdivisions** resulting from increased demand for new homes, which requires expansion of the distribution system lines and stations.

The map on the previous page shows the capacity constrained areas of PowerStream's service territory. Red highlighting indicates areas that require increased investment to provide additional capacity in the near term to ensure system reliability.

# Solutions

- New substations, transformer stations, and power lines • where needed to increase supply capacity.
- Voltage Conversion Projects: existing 8kV and 13.8kV power lines converted to 27.6kV to increase load capacity.
- Station Investments: intended to ensure stations have peak loadings maintained at or below their 10 day Limited Term Rating to prevent damage to station equipment and avoid brownouts and blackouts.

Need investments to increase station and power line capacity to maintain the loading of existing municipal substations and to ensure sufficient space capacity exists such that if there is a loss of one substation, the neighbouring **substations** can accommodate the lost capacity.

# Pressure: Aging Equipment

PowerStream's distribution system consists of various equipment (**poles, transformers, cables**, etc.) with different installation date profiles. While the majority of the distribution system was installed or rebuilt after 1980, a significant amount of distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in service today. While that old equipment continues to operate for the time being, it is well past its intended service life, and much of it will need to be replaced soon.

Equipment that is still operating beyond its intended service life is more likely to fail, and cause long power interruptions. As time goes on, more and more of the distribution system assets will be operating past end-of-life, unless replaced. This requires investment in system renewal projects and programs.

Asset Summary Chart – main assets by quantity

While PowerStream and its predecessor utilities have historically managed asset replacement programs efficiently with moderate levels of investment, the growing number of old assets needing replacement requires a higher level of investment than ever before.

PowerStream plans to proactively replace the oldest and worst condition equipment before it fails. Generally, proactive equipment replacement is less expensive than replacing equipment after an unexpected failure.

Some distribution assets such as pole mounted transformers and residential padmounted transformers, as well as secondary cables, are not proactively replaced. These assets are replaced once they fail. This "run to failure" approach is considered normal utility practice is the industry.

Asset Types	Asset Count (approx)	Average Life (approx)	Oldest Assets (approx)
Wood Poles	46,500	35-75	1940
Distribution Transformers	44,000	25-60	1956
Underground Primary Cable	7900 km	20-55	1965
Distribution Switchgear	1800	30-85	1978
Station Circuit Breakers	399	35-65	1958
Municipal Station Primary Switches	66	30-60	1956
Municipal Station Transformers	65	30-60	1958
Station Reactors	34	25-60	1986
Transformer Station Transformers	22	30-60	1986
Transformer Station 230kV High-Voltage Switches	22	30-60	1986
Station Capacitors	5	25-40	1990

**Note:** Above data and figures provided from PowerStream Asset Condition Assessment, Rev. 2, November 27, 2012.

# Challenges

The need to replace poles that are at or nearing end-of-life.

Underground primary cables that are at, or near, end-of-life, and the resulting high negative impact this has on reliability for affected customers.

Aging padmounted switchgear cubicles.

The need to replace padmounted transformers, where concerns about condition have been reported.

Automated/remote-controlled switches, switches that are at, or near, end-of-life and therefore likely to fail compromising the ability to prevent feeder and station overloa during the summer peak.

	Solutions
	• Proactive replacement: PowerStream plans to replace or reinforce approximately 400 of the worst condition poles per year in order to minimize risk.
	<ul> <li>PowerStream proposes to replace approximately 52 km/year of the worst condition underground cables, and use silicon injection to extend the life of another estimated 47 km/year of underground cables.</li> <li>PowerStream's approach for cable replacement is determined by prioritizing the cable sections that have the worst reliability and the highest customer impact.</li> </ul>
	<ul> <li>Proactive replacement: PowerStream plans to replace approximately 31 of the poorest condition switchgear units in 2015, rising to 36 per year in 2016-2020.</li> </ul>
	<ul> <li>PowerStream commenced a proactive replacement program in 2013.</li> <li>PowerStream proposes to proactively replace approximately 60 padmounted transformers per year.</li> </ul>
d ads	<ul> <li>PowerStream proposes to replace five per year.</li> <li>These are important for a number of reasons, including preventing station overloads during summer peaks, as well as improving reliability and restoration times.</li> </ul>

### Pressure: New Technology

PowerStream is finding that in general, customers have increased expectations. They want to communicate with us around the clock and in new ways, such as through social media. Some customers are seeking a detailed understanding of their electricity consumption, and how their bill is calculated. PowerStream information systems must support these customer needs.

The delivery model of the distribution system is changing. Renewable or other forms of generation have changed power flow from unidirectional to multidirectional. To manage this fundamental change requires increased technological investments.

Challenges	Solutions	Challenges
The requirement to develop and support smart grid technology to meet the high reliability demands of today's electricity consumers.	<ul> <li>Improvements to the distribution system to support growing numbers of Electric Vehicles.</li> <li>Improvements to the distribution system to support increased renewable generation and energy storage initiatives.</li> <li>Develop and promote consumer energy management initiatives to reduce energy demand.</li> </ul>	Evolving risks to cyber security of customer information and grid due to aging and unsecure IT equipment.
An outdated billing system, over 35 years old, that cannot support a growing number of customers, has limited ability for interactive features, and no longer has vendor support.	<ul> <li>A new modern billing system, expandable in the future as required, to provide a more efficient platform for customers with increased interactive support and customer information security. A new modern billing system will also provide increased efficiencies by integrating with other systems, and produce long-term cost savings.</li> </ul>	
The replacement of end-of-life remote- controlled switches to ensure rapid and automatic transfer of loads in emergencies and reduce restoration times.	<ul> <li>Installation of new smart remote-controlled power line switches and reclosers.</li> <li>A formal decision-making process for determining the most cost effective quantity of switches, and the optimal locations, for providing the maximum benefit to the largest number of customers.</li> </ul>	
The need to replace old and difficult to operate "mini-rupter" (high capacity isolating) switches in commercial/ industrial locations.	• Installation of new high-capacity isolating <b>switches</b> that increase operational efficiencies and reduce the need for costly power interruptions when performing routine maintenance.	Risk of vandalism to substation buildings and equipment.
New OEB regulations that require higher intelligence metering equipment for all commercial/industrial customers over 50kW by 2020.	<ul> <li>Replace 4400 meters with new smart technology meters in a pre-planned efficient multi-year program.</li> </ul>	

# Pressure: Security

As technology continues to be utilized in every aspect of the utility's business, there is an increasing risk of cyber security attacks that could potentially affect confidential customer or corporate information, customer privacy, power delivery, and even the safety of employees or customers through the unauthorized use of

# lenges

•

•

PowerStream technology. One incident could do serious damage to the corporation and to its corporate image. In addition, there is the on-going risk of physical security; the physical protection of buildings and stations, and the monitoring of critical equipment to protect from impending failure.

# Solutions

- Firewall/Intrusion Detection System/Intrusion Protection System—this is a security checkpoint between the trusted and untrusted network/device/users and is also used to continuously monitor for any malicious activity and can automatically take action in certain instances.
- Network Access Control—this dynamically monitors and controls devices, applications and users to deny unauthorized external access to the network.
- Identity and Access Management—this manages user access and privileges granted throughout the PowerStream environment • Security Information and Event Management—this is real-time logging and analysis of security alerts.
- Vulnerability Assessment Tool—this scans, identifies, quantifies and prioritizes vulnerabilities in the PowerStream environment and suggests remediation solutions.
- Mobile Device Management—this controls mobile devices connected to our network and can authorize, wipe, secure and encrypt corporate information as required.
- Enterprise Change Management—this process and associated technology allows PowerStream to effectively deal with constant change through a structured approach to transitioning systems, applications and technologies from current to desired future states.

Install equipment monitoring Infrared cameras at 16 additional stations over the next 6 years.

 Install perimeter video surveillance cameras at 17 additional stations over the next 6 years.

### Pressure: Obsolescence

Despite an ever increasing number of weatherrelated interruptions each year, PowerStream has worked hard to stay within the boundary of its average historical reliability performance targets of one outage totalling 60 minutes per customer, per year.

While PowerStream continues to demonstrate strong reliability performance in the operation of its distribution network, it is not without its challenges. There are areas and pockets within the PowerStream distribution system that suffer poor reliability due to the type of legacy construction that was once considered acceptable or even preferable. An example of this would be older houses connected to overhead power lines located in the back lot (rear lot) of those properties. The reliability of rear lot supply connections is worse under severe weather conditions than the current standard front lot connections. In addition, the cost to maintain these rear-lot connections is much higher than the cost to maintain front lot connections.

# Challenges

Rear Lot Conversion program: Capital work required to address reliability, safety, operations and customer service concerns on rear lot supply connections.

# Solutions

- There are 49 areas of rear lot construction scattered among eight of the municipalities of PowerStream.
   Most of those areas were constructed in the 1950's, 1960's and 1970's. The oldest dates back to 1948.
- PowerStream proposes to replace the worst areas of rear lot connections on an annual basis over many years until all areas are converted.
- The average cost of this conversion work is estimated to be \$1.2M per rear lot area.
- Elimination of rear lot supply connections will result in long-term operational efficiencies and reduced maintenance costs.

### Pressure: Major Events

PowerStream's system is built to quickly restore power after the loss of one or two key elements the electricity grid. But what happens when the a major disruption to the system?

PowerStream has been severely impacted by weather-related events over the past year. The December 2013 ice storm, microbursts in York region and tornados in the North service area h all highlighted the risk to the grid from major ev Major events are rare events that have a major impact. The Insurance Bureau of Canada report that severe weather is likely to increase over the 40 years.

The December 2013 Ice Storm in Ontario seve tested the emergency preparedness of electrica utilities in Southern Ontario including the Great Toronto Area where hundreds of thousands of

# Challenges

The need for emergency preparedness d unplanned events and expenses.

The need to improve the supply to those customers who are more vulnerable to outages and duration of outages, specific rear lot supply.

The need to make changes to key distribution lines to withstand increased severity of weather events.

The investments discussed earlier in the primer are focused on minimizing the day-to-day outages and increasing the speed by which electricity is restored. Additional investments could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

re ts in here is ne	customers were left without power, some for as long as a week, or even longer. An independent assessment of PowerStream's response to that storm highlighted a number of areas where improvements are required at PowerStream to be better prepared for future severe storms and emergency events. Key areas identified for
have	improvement include:
vents.	<ol> <li>Improve external communications with customers.</li> </ol>
orts he next	2. Improvements to Customer Care systems and staffing.
	<ol> <li>Improve Outage Management Systems and utilize outage reporting via existing Smart</li> </ol>
erely cal iter	<ul><li>Meters.</li><li>4. Improve vegetation management.</li><li>5. Elimination of rear lot services, and convert to front lot.</li></ul>
	6. Upgrade our underground key distribution lines.
	Solutions
luring	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e.: poles, transformers, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and materials that are available for emergencies.</li> </ul>
luring	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e.: <b>poles, transformers</b>, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and</li> </ul>
	<ul> <li>Prepare contingency plans for the immediate replacement of assets (i.e.: poles, transformers, etc.) due to unanticipated failure, storms, motor vehicle accidents, vandalism, etc.</li> <li>Ensure adequate levels of spare equipment and materials that are available for emergencies.</li> <li>Plan to replace rear lot supplies on an annual basis</li> </ul>

13. A significant amount of PowerStream's distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in-service today. PowerStream works hard to extend the life of our existing equipment because it helps to keep rates down, but as equipment gets older it becomes more likely to fail. PowerStream has two approaches to older equipment.

- If the failure of a piece of equipment will impact a large number of people, result in a long outage or if an inspection shows the equipment is in poor condition, PowerStream does initiate equipment replacement before failure.
- When an equipment failure has only a limited impact and can be quickly replaced, PowerStream's policy is to leave the equipment in place until it breaks down to get all the value possible from that equipment.

What do you think of this policy?

- I am willing to pay more to replace all equipment before it fails
- I support the current approach of allowing equipment to run to failure when that failure impacts only a few customers for a limited period of time.
- Don't Know

14. When it comes to replacing aging equipment, which of the following points of view is closest to your own?

- PowerStream should invest what it takes to replace the system's aging infrastructure to reduce the risk of power outages; even if that means my electricity bill will increase by a few dollars per month.
- PowerStream should scale back their investment in renewing the system's aging infrastructure to reduce the size of any bill increase; even if that means more or longer power service interruptions.
- Don't Know

**15.** When it comes to investing in new technology, which of the following points of view is closest to vour own?

- Investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream.
- I think the benefits of new technology are important and investments in new technology should be a priority for PowerStream.
- Don't know

**16.** Currently, the average general service customer pays \$61 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather?

\$

# What this Plan Means for You

It all comes down to what you pay and what you receive in return.

What will you get? PowerStream's plan for 2016 to 2020 deals with the challenges outlines in this primer to deliver a system that will maintain or achieve modest improvements in reliability and service.

What will it cost? General service customers with an average monthly consumption of 2000 kWh may see an average annual increase of **\$5.25** per month or **8.2 per cent** on the distribution portion of their bill over the next five years. As such by 2020, the average general service customer will be paying an estimated **\$26.24** more per month on the distribution portion of their electricity bill. It is important to note that other increases on the bill by other entities are also possible.

There are two main elements in that increase:

- An increase of approximately **2.5 per cent** or **1.60 cents** per month per year in operating costs which reflects inflation and new costs which are offset in part by efficiency savings;
- An increase of approximately **5.7 per cent** or **\$3.65** per month per year new capital investments to deal with the issues discussed earlier such as growth, aging infrastructure and new technology.

In addition, in the first year of the plan there is a "catch-up" increase to deal with expenses that were not properly covered under the existing formula. The next section explains the need for that catch-up. \$160


### Current Revenue Shortfall

The formula setting PowerStream's rates in 2014 and 2015 is not keeping up with the need for new investment.

PowerStream's rates were set in 2013 using the cost of service method where the OEB sets rates at the level needed to fund the operation of the utility. That worked well in 2013.

**Revenue Shortfall (\$millions)** 

**Revenue Deficiency** 



However, in 2014 and 2015, rates were not based on actual costs. Instead, a formula was applied which adjusted rates for inflation less an adjustment for efficiency, referred to as a price cap index (PCI) adjustment. This formula does not provide enough revenue in rates to fund the actual capital investments being made in these years.

For instance, PowerStream made the second largest investment in its 10 year history when it brought in a new billing system. PowerStream is committed to providing customers with accurate billing information from meter to payment. However, the old system was implemented 30 years ago and just wasn't keep up with new demands such as mobile access and self-service options customers told us they expect today. Changing to a modern system required both a significant capital investment and an increased operating budget, but not only does it provides much better access for customers and staff, it does so with a much higher level of security for personal information, a key concern in these times.

(\$13.2)

(\$7.8)

(\$5.4)

The OEB recognized that problem and created the new Custom Incentive Rate rate setting method which PowerStream will be using in this rate filing. This method will alleviate this issue going forward but there is still a need to deal with 2014 and 2015 investments.

The chart on page 29 compares the revenue from rates using the PCI to the revenue needed to fund utility operations on a cost of service basis. Over 2014 and 2015, there will be a revenue shortfall of approximately \$13.2 million. This shortfall is being funded by PowerStream's municipal shareholders from past earnings retained in the company. However, using savings to make up for the missing revenue will restrict PowerStream's ability to make the necessary future investments to maintain its system and the level of service provided to its customers. The catch-up will enable PowerStream to fund those needed investments.

Most of the rate increase in 2016 is to provide funding for capital investments in 2014 and 2015. This will result in an increase of \$8.53 a month for the average general service customer consuming 2000 kWh a month.

#### Increased Capital Spending

PowerStream has developed a list of capital investment drivers and proposes capital investment programs based on these key drivers. The definitions of the key drivers are below.

#### **Service Requests**

PowerStream has an obligation to connect a customer to its distribution system. This includes both traditional demand customers and distributed generation customers. Requests also can include system modifications to support infrastructure development by government agencies, road authorities and developers. Normal connection costs are recouped through the revenue from new customers. Unusual connection costs are paid by the customer being connected.

#### **Increased Delivery Capacity**

As new customers are connected, PowerStream needs to expand the core elements of its distribution system, including expanded or new distribution stations and enhanced or new feeder lines. This is the fundamental infrastructure that allows new customers to be hooked up to the distribution system and is paid for by the extra revenue from new customers served over time.

#### System Efficiency

To provide customers with the best service possible, there is always a need to improve restoration capability. As the population in PowerStream's service territory continues to grow, the system also needs to grow in order to be able to handle new connections.

#### Mandated Compliance

Environmental, reliability and safety standards are updated on a regular basis and PowerStream's system must be updated to keep up with these standards. Agencies that impact PowerStream include the Ministry of Energy, Measurement Canada, the OEB, the IESO and/or other regulators.

#### **Obsolescence**

Improvements in technology can require PowerStream to replace equipment that is still functional but no longer meets current operating practices or current standards. Reasons for replacement include:

- them:
- safety-related risks.

PowerStream is not just the local electricity grid the equipment is no longer manufactured; itself, it is the business that operates that grid. there are no spare parts; The utility needs storage facilities for equipment, are unable to have maintenance performed on workshops to maintain and repair equipment and offices for people who manage your accounts there are operational constraints or conflicts, and the electricity system. PowerStream needs which can result in increased reliability and/or vehicles for its crews, as well as computer systems to manage customer accounts, track equipment and operate the grid. While this is a relatively small slice of the capital spending over the next several years, Aging or Poor Performing Equipment Where there is the imminent risk of failure due to it is just as critical to have IT systems identify where an outage is and where the needed parts are stored age or condition deterioration, and these potential as to have the replacement parts themselves. failures will result in severe reliability impacts

	Capital Investment Drivers	Primary Driver	Source
System Access	Subdivisions and New Connections Road Authority Metering Other Customer Initiated Work	Service Requests	Developers, Customers, Road Authorities
System Service	Reliability including Distribution Automation Additional Capacity - Lines Additional Capacity - Stations (TS and MS) Security Smart Grid Safety	Reliability Support Capacity Delivery System Efficiency Safety	PowerStream
System Renewal	Distribution Lines - Emergency/Reactive Replacement Overhead Lines and Assets Planned Replacement Underground Cable and Asset Planned Replacement Rear Lot Conversion Program Stations/Protection & Control Asset Replacement (Planned & Emergency)	Mandated Compliance Obsolescence Mitigate Failure Risks Safety	Regulator Safety Authority PowerStream
General Plant	Interest Capitalization Customer Service Information Service and Communication Systems Buildings/Facilities Fleet Tools	Capital investment Support Customer service	PowerStream

to customers as well as potential safety risks to crew workers or to the public, refurbishment or replacement is required.

**Business Support Costs** 

Looking ahead at the next five years and all the categories identified above, PowerStream is proposing to spend \$641 million on new capital investments. This will result in an annual increase of about 6% on the distribution portion of your bill which is about three quarters of the proposed rate increase.

#### 2016 - 2020 Forecasted Capital Expenditures (\$ millions)



With the proposed levels of capital and operating budgets for 2016 to 2020, in 2020 PowerStream will continue to operate on less revenue per customer than the average Ontario local distribution company.

# Feedback

17. Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream system and what they are planning to do to meet those challenges?

- Very well
- Somewhat well
- Not very well
- I don't understand at all

18. From what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction?

- Right direction
- Wrong direction
- Don't know


#### **19.** And why do you feel that way?



#### The Impact on Your Bill

General service customers with an average monthly consumption of 2000 kWh may see an average annual increase of \$5.25 per month or 8.2 per cent on the distribution portion of their bill over the next five years. As such by 2020, the average general service customer will be paying an estimated **\$26.24** more per month on the distribution portion of their electricity bill.

#### Estimated Typical GS<50 KW Annual Increase in Monthly Bill



# Feedback

represents your point of view:

- The rate increase is reasonable and I support it
- I don't like it, but I think the rate increase is necessary
- The rate increase is unreasonable and I oppose.
- Don't know

#### 21. And why do you feel that way?

••••	 	 ••••	••••	 	 	••••	 	 	••••	 ••••	• • • •	••••	••••	 ••••	 ••••	• • • •	••••
••••	 	 		 	 		 	 		 				 	 ••••		
<b>.</b>	 	 		 	 		 	 		 				 	 		
<b>.</b>	 	 		 	 		 	 		 				 	 		

20. Considering what you know about the local distribution system, which of the following best

# Final Thoughts

PowerStream values your feedback. This outreach is a new requirement, so this is the first time that the utility has conducted a review about its upcoming investment plan in this type of format.

General Impression - Overall, what did you think about this primer?

**Volume of Information**: Did PowerStream provide too much information, not enough, or just the right amount?

**Content Covered**: Was there any content missing that you would have liked to have seen included?

**Outstanding Questions**: Is there anything that you would still like answered?

Suggestions for Future Consultations: How would you prefer to participate in these consultations?

# Glossary

**Breakers:** Devices that protect the distribution system by interrupting a circuit if a higher than normal amount on power flow is detected.

**Feeder Circuit:** Is a wire that connects stations to the broader distribution system in order to deliver electricity to customers.

**Generation Station:** A facility designed to produce electric energy from another form of energy, such fossil fuel, nuclear, hydroelectric, geothermal, solat thermal, and wind.

Kilowatt (kW): 1000 watts.

**Local Distribution Company (LDC):** In Ontario, these are the companies that take electricity from the transmission grid and distribute it around a community.

OM&A: Operations, Maintenance and Administration

**Stations:** These include tranformer stations and distribution stations. They are used to switch generators, equipment, and circuits or lines in and out of a system. It also is used to change AC voltages from one level to another.

**Switches:** These control the flow of electricity—the direct which supply of electricity is used and which circuits are energized. Distribution systems have switches installed at strategic locations to redirect power flows for load balancing or sectionalizing.

**System Access:** Projects required to respond to customer requests for new connections or new infrastructure development. These are usually a regulatory requirement to complete.

**System Renewal:** Projects to replace aging infrastructure in poor condition.

	<b>System Service:</b> Primarily projects that improve reliability.
to r	<b>General Plant:</b> Investments in things like tools, vehicles, buildings and information technology (IT) equipment that are needed to support the distribution system.
uce h as lar	<b>Transmission lines:</b> Transmit high-voltage electricity from the generation source or station to another station in the electricity grid.
, n	<b>Transformer:</b> A piece of equipment that reduces the voltage of electricity from a high level to a level that can be safely distributed to your area or to your residence/business.
ation	<b>Underground Cable:</b> A conductor with insulation, or a stranded conductor with or without insulation and other coverings (single-conductor cable), or a combination of conductors insulated from one another (multiple-conductor cable).
2	<b>Volt (V):</b> A unit of measure of the force, or 'push,' given the electrons in an electric circuit. One volt produces one ampere of current when acting on a resistance of one ohm.
they ch e ct	<b>Watt (W):</b> The unit of electric power, or amount of work (J), done in a unit of time. One ampere of current flowing at a potential of one volt produces one watt of power.
)	<b>Wire:</b> A conductor wire or combination of wires not insulated from one another, suitable for carrying electric current.



If you have any additional questions or comments about PowerStream's Distribution System Plan Review please email:

CustomerFocus@powerstream.ca

or send your questions or comments to:

PowerStream Attn: DSP Review 161 Cityview Boulevard, Vaughan, Ontario L4H 0A9



EB-2015-0003 PowerStream Inc. Rate Proposal Exhibit G Tab 2 Appendix F: Customer Consultation Report Delivered: February 24, 2015



# Appendix F

# **Customer Consultation Report**

Delivered: February 24, 2015

**Distribution System Plan** 



Innovative Research Group, Inc. Toronto • Vancouver

# **Customer Consultation Report**

# **Distribution System Plan**

February 2015

Prepared for:

PowerStream Inc. 161 Cityview Blvd, Vaughan, ON L4H 0A9



# **Customer Consultation Report**

# **Distribution System Plan**

### February 2015

This report has been prepared by Innovative Research Group Inc. (INNOVATIVE) for PowerStream.

The conclusions drawn and opinions expressed are those of the authors.

Innovative Research Group Inc.

56 The Esplanade, Suite 310 Toronto ON | M5E 1A7 Tel: 416.642.6340 Fax: 416.640.5988 www.innovativeresearch.ca

# **Table of Contents**

Introduction1
About this Consultation1
Customer Consultation Overview2
Primer Development5
Executive Summary7
Customer Needs7
Customer Preferences9
Customer Reaction to Rate Impacts
Online Primer
Summary
Methodology
About the Online Primer13
Figure A: Online Primer Progress Rates15
Respondent Profile16
Figure B1: Residential Consumer Profile16
Figure B2: Residential Consumer Profile17
Figure C: Sample Regional Profile18
Respondent Feedback
Familiarity, Satisfaction and System Reliability19
Figure 1: Familiarity with Electricity Distribution System20
Figure 2: Understanding of How Electricity System Works21
Figure 3: General Satisfaction with PowerStream22
Figure 4: Open-ended on How to Improve Service23
Figure 5: Outages in the Past Year during Unusual Weather
Figure 6: Satisfaction with Response to Unusual Weather Outages
Figure 6: Open-ended on How to Improve Service in Unusual Weather
Figure 7: Number of Outages in Past Year other than Unusual Weather
Figure 8: Outage Length in Past Year during Normal Weather
Figure 9: Satisfaction with Response to Normal Weather Outages
Figure 10: Open-ended on How to Improve Service during Outages
Figure 11: Level of Reliability
Long-term Challenges and Investment Solutions

Figure 12: Willingness to Pay for Infrastructure Development
Figure 12a: Smith and Jones on Investment in Infrastructure
Figure 12b: Smith and Jones on Investment in New Technologies
Figure 12c: Municipalities on Investment in Infrastructure and Technology
Figure 13: Open-ended on Amount Willing to Pay for Infrastructure Investment
Figure 14: Consumer Understanding of Challenges
Figure 16: Direction of Investment Plan39
Figure 17a: Open-ended on Direction of Investment Plan40
Figure 17b: Open-ended on Direction of Investment Plan41
Figure 18a: Permission Question42
Figure 18b: Explanation of Permission Response43
Appendix: Feedback on the Primer45
General Service and Residential Consultations
Summary
Methodology
About the General Service and Residential Customer Consultation
Participant Feedback
General Service under 50kW Rate Class (Barrie)53
Residential Rate Class (Barrie)
General Service under 50kW Rate Class (Markham)57
Residential Rate Class (Markham)60
General Service under 50kW Rate Class (Vaughan)61
Residential Rate Class (Markham)63
Questionnaire Results
Mid-Market General Service Workshops
Summary74
Methodology75
About the Mid-Market GS Workshop Consultation75
Participant Feedback77
Simcoe County Consultation Session (Tuesday December 9 <sup>th</sup> , 2014)
York Region Consultation Session (Wednesday December 10 <sup>th</sup> , 2014)81
Questionnaire Results
Key Accounts Consultations
Summary

Methodology	
About the Key Accounts Workshop Consultation	
Participant Feedback	
Key Accounts Consultation Session (Wednesday December 10 <sup>th</sup> , 2014)	94
Residential and General Service Telephone Survey	100
Summary	100
Methodology	104
About the Residential and General Service Telephone Survey	104
Questionnaire Design	
Fielding the Survey	
Sample Design	
Demographic Profile	
Respondent Feedback	108
Familiarity and Satisfaction: Residential and General Service Customers	108
Familiarity, Satisfaction Summary	108
Preamble for Familiarity and Satisfaction Section	
Figure 1.0 RS: Familiarity with the Local Distribution System	
Figure 1.1 GS: Familiarity with the Local Distribution System	110
Figure 1.2 RS: Satisfaction with PowerStream	
Figure 1.3 GS: Satisfaction with PowerStream	
Figure 1.4 RS/GS: How to Improve Service	113
Figure 1.5 RS: Knowledge of PowerStream ownership	
Figure 1.6 GS: Knowledge of PowerStream ownership	
Electricity Bill Knowledge	116
Electricity Bill Knowledge Summary	116
Preamble for Bill Knowledge Section	
Figure 2.0 RS: Familiarity with Share of Bill Going to PowerStream	
Figure 2.1 GS: Familiarity with Share of Bill Going to PowerStream	
System Reliability	119
System Reliability Summary	
Figure 3.0 RS: Extreme Weather Outages	
Figure 3.1 GS: Extreme Weather Outages	
Figure 3.2 RS: Satisfaction with Response to Events	
Figure 3.3 GS: Satisfaction with Response to Events	
Figure 3.4 RS/GS: How to improve service during Extreme Weather	

	Figure 3.5 RS: Number of Outages during Extreme Weather Events	126
	Figure 3.6 GS: Number of Outages during Extreme Weather Events	127
	Figure 3.7 RS: Satisfaction with PowerStream Response	128
	Figure 3.8 GS: Satisfaction with PowerStream Response	129
	Figure 3.9 RS: Open-ended on Improvement to Service	130
	Figure 3.10 GS: Open-ended on Improvement to Service	131
	Figure 3.11 RS: Number of Power Outages	132
	Figure 3.12 GS: Number of Power Outages	133
	Figure 3.13 RS: Aided Number of Power Outages	134
	Figure 3.14 GS: Aided Number of Power Outages	134
9	System Challenges & Priorities	. 136
	System Challenges & Priorities Summary	136
	Preamble for System Challenges & Priorities Section	137
	Figure 4.0 RS: Investment in Aging Infrastructure	137
	Figure 4.1 GS: Investment in Aging Infrastructure	138
	Figure 4.2 RS: Open-ended on Extreme Weather Infrastructure Investment	139
	Figure 4.3 GS: Open-ended on Extreme Weather Infrastructure Investment	140
	Preamble for Investment in Equipment and Tools	140
	Figure 4.4 RS: Investment in New Technology	141
	Figure 4.5 GS: Investment in New Technology	142
	Preamble for Investment in New Technology	142
	Figure 4.6 RS: Investment in New Buildings, Equipment and IT	143
	Figure 4.7 GS: Investment in New Buildings, Equipment and IT	144
4	Assessment of Plan	. 145
	Assessment of Plan Summary	145
	RS/GS- Preamble for Assessment of Plan Section	145
	Figure 5.0 RS - Permission for Rate Increase	146
	Figure 5.1 GS - Permission for Rate Increase	147
	Figure 5.2 RS – Residential Financial Strain	148
	Figure 5.3 GS – General Service Financial Strain	148
	Figure 5.4 RS – Opinion on Proposed Rate Increase	149
	Figure 5.5 GS – Opinion on Proposed Rate Increase	150
Su	rvey Instruments	. 151
	Residential Survey Instrument	151
	General Service Survey Instrument	

<b>Primer Appendices: PowerStream's Distribution S</b>	System Plan 1	177

# Introduction

# About this Consultation

Innovative Research Group Inc. (INNOVATIVE) has been commission by PowerStream to help the utility design, collect feedback and document its customer engagement and consultation process as part of the development of PowerStream's Distribution System Plan (DSP).

PowerStream's Distribution System Plan is a key element of its next distribution rates application. The outcome of this application will determine PowerStream's electricity distribution rates for the next five years.

The OEB's new "consumer-centric" approach to rate applications contained in the *Renewed Regulatory Framework for Electricity (RRFE)* requires LDCs to demonstrate that services are provided in a manner that responds to identified customer <u>needs</u> and <u>preferences<sup>1</sup></u>. Distributors are required to provide an overview of the customer engagement activities that that they have undertaken with respect to their plans and how customer needs and preferences have been reflected in their application. While PowerStream engages customers in a number of ways to explore their needs, it has not done so in the context of its capital plan or rate implications. This initiative sought to bring customers directly into the process of finding the right balance between cost and reliability in PowerStream's Distribution System Plan.

This process of identifying and reacting to customer needs and preferences as it pertains to their DSP development and execution is new to Ontario's LDCs. There are no established practices and there are a number of options available to engage with customers. The following section explains how INNOVATIVE approached this engagement.

#### Approach to Meaningful Customer Engagement

It is our experience at INNOVATIVE that engaging customers in meaningful consultation can be a challenge. The reality of most consultation processes is that they start out aiming to collect the views of the average person, but end up collecting the views of organized advocacy groups.

Many customers feel they don't know enough to contribute to a public consultation. Others fear the combative nature of some public processes or prefer not to risk offending friends and neighbours by taking firm positions on issues that are sometimes controversial. Moreover, many customers simply do not pay attention and remain unaware of particular consultations that they would participate in if they had been aware.

Running a consultation on a Distribution System Plan presents an additional challenge – the lack of awareness of the distribution system including how it is funded, regulated and the nature of its challenges. This is well documented in Ontario Energy Board research and in INNOVATIVE's own experience.

<sup>&</sup>lt;sup>1</sup> OEB Renewed Regulatory Framework for Electricity Sections 2.4.2, 5.0, and 5.0.4.

Considering both the challenge of engaging a representative group of customers and a general lack of knowledge, we have created a process built on six key principles:

- 1. Ensure customers from across PowerStream's customer-base have an opportunity to be heard.
- 2. Use random-sampling research elements to ensure a representative sample of customers are engaged.
- 3. Create open voluntary processes to allow anyone who wants to be heard to be heard.
- 4. Focus on fundamental value choices. Look for questions that ask people to choose between key outcomes rather than focus on the technical questions of how to reach those outcomes.
- 5. Create an opportunity for the public to learn the basics of the distribution system so they can provide a more informed point of view.
- 6. Test the consultation material in advance for clarity of language, appropriateness of questions, ability to respond to questions, and the right balance between comprehensiveness and simplicity.

Since this was the first time PowerStream so explicitly engaged customers in the development of their DSP, a specific effort was made to collect participant comments on the process itself. While most customers felt this approach to engagement was effective at soliciting their feedback on PowerStream's DSP, other ideas on how to improve upon the process were collected throughout the consultation. This is discussed in detail throughout the body of this report.

# **Customer Consultation Overview**

Based on the principles outlined above, INNOVATIVE worked with PowerStream staff to design a multifaceted customer engagement program which included a combination of traditional consultation services as well as qualitative and quantitative research elements. This comprehensive consultation was designed to engage various rate classes and collect feedback on preferences and priorities as they relate PowerStream's 5 Year DSP.


The consultation encompassed **five** core elements of customer engagement:

- 1. **Online Primer**: The online primer was promoted through traditional print advertising and social media as well as PowerStream's website. This first phase of the consultation was available to any PowerStream customer who wanted to participate.
- 2. General Service and Residential Consultation Groups: The General Service and Residential Customer phase of PowerStream's multi-faceted customer consultation was used as an engagement tool to educate customers, access customer preferences and priorities, gauge customer permission of rate increases, as well as to inform subsequent phases of the consultation. The groups were randomly recruited and held in different locations across PowerStream's service area. A primer was used to provide the participants with core information about Ontario's electricity system and PowerStream's Distribution System Plan. They were provided incentives in recognition of their time commitment.

- Mid-Market General Service Workshops: General Service customers over 50 kW (GS > 50kW) were engaged through a series of randomly recruited workshops. They were provided incentives in recognition of their time commitment.
- Key Accounts Workshop: Key Accounts customers were engaged in an interactive workshop, including a presentation from PowerStream staff, as well as a Focus Group component lead by INNOVATIVE. Key Accounts customers were randomly recruited from lists provided by PowerStream.
- Random Telephone Surveys: INNOVATIVE conducted telephone surveys with residential and general service (GS < 50kW) customers to provide a quantitative assessment of key aspects of the plan. Customer lists for both respondent groups were provided by PowerStream and the sample was randomly-selected by INNOVATIVE.

There were **four** stages in developing and implementing this consultation:

- **Think**: The first step was developing the core background material and key questions for the primer. INNOVATIVE and PowerStream worked together to review the Distribution System Plan to identify potential questions that would allow customers to share their needs and preferences and then to develop a primer that would provide the information needed to allow customers with different levels of initial knowledge to find answers to those questions.
- **Test**: The second step was to refine the primer and determine what were the best ways to present the narrative. INNOVATIVE conducted Focus Groups to understand whether the primer was comprehensible and whether challenges, solutions and options were presented in as clear a manor as possible.
- Identify: The third step was to find out the range of views held by the public regarding the Distribution System Plan through the more qualitative elements of the process. This included an online primer using a voluntary sample and a series of customer discussion groups and workshops using randomly recruited samples of residential and GS customers, including PowerStream Key Accounts customers.
- **Quantify**: The final step was quantitative randomly recruited telephone surveys of residential and GS customers. Randomly recruited surveys allow us to draw generalizable conclusions that can be applied to the broader population of PowerStream customers. The surveys were developed based on the feedback from the qualitative research.



The consultation was designed so that anyone who is interested would have an opportunity to participate in the process through the online primer. However, in our approach, we distinguish between responses from the opinion research discipline (random recruits and scientific polls) and responses from an "open invitation" consultation discipline.

The small group results are presented as numeric counts to help readers remember that qualitative research only identifies points of view, it does not project the incidence of that point of view in the broader public.

The results from the primer and random telephone surveys are presented as percentages due to the larger numbers involved.

- Readers are cautioned that the online primer results represent the views of volunteers. The online primer sample is not randomly selected and cannot be generalised to the broader public.
- The telephone surveys are based on random samples so we can reliably project the incidence to the broader population of PowerStream customers.
- In some instances, the quantitative total may be greater than 100% due to rounding. This is in keeping with standard research practice.

It is important to note that these consultations occurred as PowerStream was developing its plan.

#### **Primer Development**

As we noted earlier, a key challenge in getting public feedback on PowerStream's DSP is the lack of customer knowledge about the Ontario electricity system, PowerStream's role in the system and the local distribution system as a whole. The DSP itself is a very detailed and extensive document that uses technical language. Our challenge was to briefly cover these key issues and to frame meaningful questions to determine customer needs and preferences.

The process of developing the consultation primer began in the fall of 2014. INNOVATIVE and PowerStream staff began the process of reviewing PowerStream's Distribution System Plan while INNOVATIVE conducted three nights of exploratory groups on June 17<sup>th</sup> in Barrie, June 18<sup>th</sup> in Vaughan and June 19<sup>th</sup> in Markham with randomly selected Residential and General Service customers to determine what they were looking for in the consultation process and what they needed to know to determine if PowerStream's DSP was reasonable.

Based on the initial review of the plan, exploratory groups, and feedback from testing, the primer was divided into key sections that explained PowerStream's electric system, the challenges facing the system, and how PowerStream intended to meet those challenges over time.

The final consultation primer had six distinct chapters:

- 1. Why Are We Here?: the purpose of the discussion, where the discussion fits in the bigger picture.
- 2. **Electricity Grid 101**: how the overall system works and the players involved in operating and regulating the system.
- 3. **PowerStream's Grid Today**: a discussion of the structure and key elements of PowerStream's distribution system, including current and past reliability.
- 4. **Challenges and Solutions**: a discussion of the various challenges facing the grid and an overview of the initiatives being undertaken to manage these challenges.
- 5. What this Plan Means for You: how PowerStream customers will be affected by the proposed Distribution System Plan, including rate impacts.
- 6. **Final Thoughts**: an opportunity for customers to provide feedback on general aspects of the consultation process, including what they enjoyed and where improvements could be made.

Although the knowledge base of customers varied, the same basic primer was used in all qualitative customer engagements – the online primer, the residential and small GS discussion groups and the midsized GS and Key Accounts workshops. The key change in the material between audiences is that the bill references varied to reflect the details of that specific rate class. As the customer went through the consultation primer – either independently or through a facilitated session – they were prompted with questions related to system reliability, system challenges, and preferences on the direction of PowerStream's proposed Distribution System Plan.

The questions themselves were another key element of the primer. In developing them, we looked for questions that could also be applicable over the telephone, and without all the information in the primer.

The needs questions were the easiest to develop. We started with a basic satisfaction question and then asked an open-ended question about how PowerStream could improve its services. Without imposing boundaries, we let customers illustrate whatever topics they wanted to cover. Later in the primer we probed satisfaction with the number and duration of routine outages and probed the impacts of those outages. We also zeroed in on major events by asking customers if they had experienced an outage during the ice storm, microbursts or tornadoes, how satisfied they were with PowerStream's response, as well as how PowerStream could improve its services during those events.

Questions ascertaining preferences required more tact. We were looking for value choices rather than technical issues. Key topics for preferences included:

- What approach should be taken with regards to replacing aging infrastructure?
- Should the utility continue to follow a run-to-failure approach or implement a pro-active replacement strategy?
- Given the other major needs for investment, how important is it to invest in modernizing technology?
- How much more are you willing to pay for investments that would help the system better withstand major events such as extreme weather?
- Whether the overall Distribution System Plan was heading in the right or wrong direction and why?

The final substantive question asked about the cost of the DSP. Sometimes this question is asked with a simple *support or oppose* response scale, but we found that type of scale didn't effectively capture the scope of customer responses. Instead, we gave customers three options as well as a *not sure* opt out:

- The rate increase is reasonable and I support it.
- I don't like it, but I think the rate increase is necessary.
- The rate increase is unreasonable and I oppose.

The primer concluded with a final set of five questions to assess the primer and process itself.

The primers can be found in the **Appendix** of this report.

# **Executive Summary**

The following section provides a detailed summary of the findings of PowerStream's Distribution System Plan Customer Consultation. In this section we provide a high level overview of PowerStream's Residential and General Service customers' needs and preferences as they relate to the DSP.

More than 1,600 customers participated in the qualitative stages of the consultation, which included both Focus Groups and an Online Primer. In these stages we explored the range of issues related to PowerStream's rate application. Another 1,202 customers participated in the quantitative stage where we documented the incidence of needs and preferences across the customer population.

#### **Customer Needs**

From the start of the consultation focus groups, and throughout the online primer and telephone survey, customers are extremely satisfied with the job PowerStream is doing running the electricity distribution system. The format of the consultation process is intended to build on ideas and questions from stage to stage, and satisfaction was positive throughout. Below is a chart indicating customers overall satisfaction with PowerStream and the services they provide.

_		Direc Focus Groups 8	Generalizable (Telephone Surveys)			
Response	Residential Groups	GS under 50 kw Groups	Mid-Market Groups	Online Primer	General Service	Residential
Very satisfied	16	9	8	46%	25%	34%
Somewhat satisfied	6	13	8	45%	58%	52%
Somewhat dissatisfied	1	1	1	5%	6%	5%
Very dissatisfied	0	0	0	2%	4%	4%
Don't know / Refused	0	0	0	2%	6%	0%
TOTAL	n=23	n=23	n=17	n=1,553	n=201	n=1,001

Overall Satisfaction with PowerStream Service

While satisfaction is overwhelmingly positive, there are areas that customers believe PowerStream can improve upon. The main threads that ran throughout the stages were rate reductions and communication. When asked how PowerStream could improve service during both normal and usual weather outages, the overwhelming response in the telephone survey was tied to rate reductions. 33% of Residential and 32% of General Service customers saw reducing rates as key was PowerStream could improve service.

Improving communication was also seen as a priority in each stage of the consultation. Disseminating information regarding estimated recovery times was a key priority mentioned in each stage of the consultation. Business customers are affected by outages of any length, and improving communication can help them determine whether or not to remain open.

Generally, customers expect an increased online presence during outages and throughout the focus groups and online primer requested further online alerts through both social and television media.

Beyond rate reductions and communication, customers commonly asked that PowerStream provide clearer bill breakdowns. Upon gathering this feedback in the earlier consultation stages, customers in the telephone survey were asked about their familiarity with the amount of their electricity bill that went to PowerStream – of which, 67% of Residential and 55% of General Service customers were

unfamiliar. These three responses were common through every stage of the consultation process. This paradox of *lower prices* while seeking *service improvements* is the key dilemma the consultation sought to explore and better understand.

All stages of the consultation focused deeply on the question of outages, both under normal circumstances and due to unusual weather. In both cases PowerStream customers were extremely satisfied with the utilities response. The tables below depict customer satisfaction with both types of outages across both the qualitative and quantitative stages of the consultation.

		Direc	Generalizable			
Descrete		Focus Groups 8	(Telephone Surveys)			
Response	Residential Groups	GS under 50 kw Groups	Mid-Market Groups	Online Primer	General Service	Residential
Very satisfied	11	11	8	41%	25%	33%
Somewhat satisfied	7	13	8	41%	41%	40%
Somewhat dissatisfied	3	0	0	8%	4%	7%
Very dissatisfied	0	0	0	3%	3%	5%
Don't know / Refused	0	0	1	7%	25%	13%
TOTAL	n=21	n=23	n=17	n=1,553	n=201	n=1,001

#### Satisfaction with Response to Unusual Weather Outages

#### Satisfaction with Response to Normal Outages

		Direc	Generalizable (Telephone Surveys)			
Demonst		(Focus Groups &				
Response	Residential Groups	GS under 50 kw Groups	Mid-Market Groups	Online Primer	General Service	Residential
Very satisfied	11	12	5	42%	38%	42%
Somewhat satisfied	9	12	8	42%	43%	44%
Somewhat dissatisfied	0	0	1	8%	8%	5%
Very dissatisfied	0	0	0	3%	5%	4%
Don't know / Refused	1	1	2	5%	6%	6%
TOTAL	n=21	n=25	n=16	n=1,012	n=81	n=462

As with general satisfaction, PowerStream is seen extremely positively with regards to response to outages; yet improving communication during outages continues to be a central concern. If outages are going to be prolonged, customers want to know so they can plan accordingly. Customers understand that outages caused by usual weather are out of PowerStream's control, but they still request clear communication regarding recovery times.

Again, when asked how PowerStream could improve response to outages, customers in all stages pointed to recovery time and speed. In essence, they want faster response time from line crews, and the overall duration of outages to be reduced.

The customer needs feedback gathered in the qualitative stages of the consultation helped to shape the telephone survey and questions about customer preferences on the trade-off between cost and reliability. The feedback gathered in this phase of the consultation is summarized in the section below.

#### **Customer Preferences**

#### **Outage Preferences**

Building on the reliability performance feedback gathered in the qualitative stages of the consultation, the telephone survey asked customers to choose between three options with regards to how PowerStream should address the number of outages.

- 32% of Residential and 38% of General Service customers said PowerStream should spend what is needed to *reduce* the number of outages.
- 40% of Residential and 34% of General Service customers said PowerStream should spend what is needed to *maintain* the current level of outages.
- 13% of Residential and 14% of General Service customers said PowerStream accept more power outages in order to help keep customers costs from rising.

Similarly, when customers were asked about the length of time they were without power, both Residential and General Service customers gave almost the same responses to the previous question.

These findings from the telephone survey are consistent with much of the data and feedback gathered throughout the qualitative stages of the consultation. In fact, in the focus groups, many business customers said that reliability is often more important (and a cost savings) than the proposed rate increase. For these customers, any length of outage can be extremely costly and investment is seen to be the better option.

#### System Challenges and Priorities

There are a number of system challenges and priorities that PowerStream must address in the next five years, and customers voiced their preferences throughout the consultation process. With regards to replacing aging infrastructure, customers in all phases generally understand the need to invest in either improving or maintaining the current system. Below is a chart illustrating customer preference regarding investment in the infrastructure projects outlined in PowerStream's DSP.

Demonso		Direc Focus Groups 8	Generalizable (Telephone Surveys)			
Response	Residential Groups	GS under 50 kw Groups	Mid-Market Groups	Online Primer	General Service	Residential
PowerStream should invest what it takes to replace the system's aging infrastructure	13	13	9	55%	54%	54%
PowerStream should lower its estimated investment in renewing the system's aging infrastructure	8	6	2	27%	32%	30%
Don't know	2	4	4	18%	8%	10%
TOTAL	n=23	n=23	n=15	n=1,553	n=201	n=1,001

#### Investment in Aging Infrastructure

Investments in new technology were seen as an important priority throughout the consultation stages. In the telephone survey, 61% of GS and 58% of residential customers think that the benefits of new technology are important and investments in new technology should be a priority for PowerStream.

### **Customer Reaction to Rate Impacts**

Customers are generally conflicted when it comes to PowerStream's Distribution System Plan and the proposed rate impacts. While customers throughout the consultation understand that there is a need to invest in PowerStream's system, which they understand is facing numerous types of pressures, few customers welcome the idea of a rate increase.

Many customers, both business and residential are feeling a financial pinch. For residential customers, they feel as if they are continuously falling behind, and businesses are not able to charge more for products. In a sense, they have their hands tied.

Reliable electricity remains a priority for many customers; most do not *want* or *like* a rate increase, but are often not opposed. Referring to the results of the telephone survey, 63% of Residential and 43% of General Service customer support the proposed rate increase, numbers that fall slightly behind the direction observed in the qualitative phase of the consultation.

Response	Directional (Focus Groups & Online Primer)				Generalizable (Telephone Surveys)	
	The rate increase is reasonable and I support it	3	1	1	19%	15%
I don't like it, but I think the rate increase is necessary	15	16	9	48%	28%	42%
The rate increase is unreasonable and I oppose it	5	4	6	26%	54%	33%
Don't know/ Refused	0	0	0	7%	1%	3%
TOTAL	n=23	n=21	n=16	n=1,553	n=201	n=1,001

#### **Customer Permission Regarding Proposed Rate Increase**

After further analysis of the telephone survey data, financial strain is a determining factor in permission towards the proposed rate increase. Nearly 8-10 (76%) of Residential customers whose electricity bill does not majorly affect their finances accept the proposed rate increase. Almost 6-10 (58%) of General Service customers who electricity bill does not have a major impact on their organization's bottom line accept the proposed rate increase.

The majority (57%) of Residential customers whose bill majorly affects their finances also accept the proposed rate increase. 37% of General Service customers with the same financial strain accept the increase. That being said, in the directional stage of the consultation, many business customers expressed the financial strain that any length of outage causes their organization.

As seen throughout PowerStream's customer consultation, there is no simple answer to electricity utility spending and investing from the customer's perspective. Rate increases are undesirable, but lower

reliability is unacceptable and the need to invest in renewal and spend on maintenance of the distribution system is understood and accepted.

As a result, PowerStream customers reluctantly accept the proposed Distribution System Plan and its accompanying rate increase as an unfortunate necessity.

# **Online Primer**

Online Primer with Volunteered customers **PURPOSE:** To inform customers on the details of PowerStream's DSP and obtain feedback on the proposed options.

## Summary

#### Satisfaction is extremely high, despite luke-warm familiarity with PowerStream.

- Consumers are quite happy with PowerStream: 91% (including 30 out of 32 business consumers) say they are satisfied with their service. Familiarity with the electricity system and PowerStream services is mixed (48% familiar vs. the same not familiar), but overall consumers feel they have a good understanding of the important parts of the system and PowerStream's responsibilities.
- Satisfaction with how PowerStream handled both unusual and normal weather outages is also extremely high: 82% are satisfied with PowerStream's response to unusual weather outages in the past year and 84% feel the same regarding normal weather outages.

#### Most have experienced outages, but consumers think current reliability is "good".

- Nearly seven-in-ten (70%) say they experienced an outage during unusual weather and six-in-ten (57%) say they experienced an outage not including extreme weather in the past year.
- That being said, the average outage described is quite short: six-in-ten (60%) outages in normal weather are less than an hour and three-in-ten (29%) are less than 15 minutes.
- Although a majority have experienced outages, two-thirds (57%) say that PowerStream's level of reliability is "good" and just 6% say "poor".

#### Communication during outages is a key concern.

- When asked how PowerStream can improve their service during both unusual and normal weather outages, "improved communication" is consistently a top mention.
- Consumers seem to appreciate an increased online presence during outages and asked for further online alerts through social media such as Twitter, the website, email and via apps or SMS on their phone.

#### Aurora, Markham and Richmond Hill self-report more issues with reliability.

- Respondents from Aurora, Markham and Richmond Hill generally report a bit less reliable service than the rest of the municipalities.
- They say they experienced more outages during unusual weather (Aurora (78%) and Richmond Hill (76%)) and in normal conditions (Aurora: just 25% "no outages; Markham: 29%; Richmond Hill, 41%).
- Outages are a bit longer in Aurora and Markham (55% and 54% "less than an hour").

• And all three, although still a majority, are less likely to say that PowerStream's level of reliability is "good" (Aurora: 65%; Markham 58%; Richmond Hill 66%).

#### Consumers support investment in infrastructure and new technologies.

- When asked which they prefer, ramping up infrastructure development to reduce outages or scaling back to reduce costs, consumers prefer "investing to reduce in power outages" by a two-to-one margin (55% to 27%).
- By a smaller margin, consumers also prefer investing in new technologies over the idea that new technologies are a "luxury, not a necessity" (48% to 34%).

#### Consumers understand challenges ahead, like the plan and are willing to pay.

- A strong majority (87%) feel they understand the challenges facing the PowerStream system.
- Six-in-ten (58%) think PowerStream's investment plan, from what they know so far, is on the right track.
- Those that think PowerStream is on the right track think that the "proposed solutions are reasonable and balanced", (26%) they're satisfied overall with PowerStream (10%) and they value increased reliability (26%). A plurality of those who think PowerStream's plan is going in the wrong direction just "don't want to cover the cost" (n=22/64 for "wrong direction").
- Overall, across all municipalities, a majority of business respondents and all demographics, twothirds (67%) of consumers support the rate increase.
- Those who think the increase is reasonable support it to "prevent future disruptions" in service (n=45) and think the amount is also reasonable (n=31). Of those who oppose it, a quarter (n=55 out of 220) say they would not accept any increase at all. "Oppose" verbatim also talk about the operating efficiencies of PowerStream (n=37) and executive accountability (n=31). Those who "don't like the increase, but think it's necessary" also cite reliability (n=31) and don't necessarily see an alternative (n=23).

# Methodology

#### About the Online Primer

PowerStream commissioned INNOVATIVE in 2014 to help create an online consumer primer for its consumers. This 21-question primer would inform consumers of current challenges facing the distribution system and explore opinion on the plan to deal with it, including a potential rate increase.

The PowerStream Primer is divided into five key sections:

- "Why are we Here?"
- "Electricity Grid 101"
- "PowerStream's Grid Today"
- "Challenges and Solutions"
- "What this Plan Means for You"

The first section, "Why are we Here?" briefly explains the Ontario Energy Board (OEB)'s regulatory requirements to consumers and the importance of consumer's opinions, whatever their level of expertise, to the rate application process. Respondents are asked to rate their familiarity with both the

electricity system and PowerStream's role. A detailed explanation is provided of consumer bills and how electricity rates are determined.

In the second section, "Electricity Grid 101", PowerStream outlines the three components of Ontario's electricity system – "generation, transmission and distribution"- as well as examples of some of the regional companies in each category. With visual aids, the primer further explains how Ontario's electricity system is regulated and the roles of the OEB, the Ontario Power Authority (OPA) and the Independent Electricity System Operator (IESO).

The third section outlines the key parts of PowerStream's distribution system and provides an in-depth analysis on outages and an outline of how PowerStream plans to reduce outages through capital expenditure. Respondents are asked about their understanding of the system, their satisfaction with PowerStream and a number of detailed questions on outages, both during usual and unusual weather events.

"Challenges and Solutions", the fourth section, is precisely that: an outline of the challenges PowerStream faces to providing reliable distribution with aging equipment and technology, potential security concerns and reaction times during major events such as the December 2013 ice storm. For each of these topics, specific solutions are given. Then consumer opinion is gaged on investing in new infrastructure and technology.

The final section, "What this Plan Means for You" explains the current revenue shortfall to meet these challenges, forecasted capital expenditures from 2016-2020 and specifically how consumers' bills will be impacted. The final questions ask the consumer whether they think this investment plan is on the right track and whether they would be willing to support a rate increase to meet the challenges ahead.

#### Field Dates:

The Online Primer was accessible to PowerStream consumers from November, 17<sup>th</sup> 2014 to December, 29<sup>th</sup> 2014.

#### Promoting the Online Primer:

PowerStream promoted the Distribution System Plan primer in a number of ways:

- The PowerStream Call Centre and other Front line staff
- A two week digital advertising campaign that included ads on radio station websites (JewelRadio.com and 1059TheRegion.com) and three newspaper websites: TheBarrieExaminer.com (leaderboard ad, 100,000 impressions/week), Simcoe.com (run of site, 25,000 impressions/week) and YorkRegion.com (run of site, 40,000 impressions/week)
- The PowerStream website which included a survey "pop-up" modal with options to take the survey as well as reminders. Promotion on the website also included a home-page carousel banner.
- Social media such as Twitter, including a carousel banner image and link to the survey.

#### Publishing the Primer Online

INNOVATIVE hosted the primer at the following URL: powerstreamcustomerfocus.ca

The website prevented consumers from completing questions repeatedly and saved their progress as they answered each question. They could therefore complete the primer in more than one sitting. Upon completion, the site was no longer accessible at the web address given. After the website was taken down, consumers could still access an "offline" version of the primer.

Note that INNOVATIVE does not ever link to the personal information submitted on the website. All responses were kept anonymous and confidential.

#### Validating Consumer Responses:

Consumers who filled out the primer were tagged with an identification number based on their postal code and their response as a residential or business consumer of PowerStream. Postal codes were checked against a list provided by PowerStream for validity and those deemed invalid were removed from the final sample.


#### Sample Characteristics:


The breakdown of Online Primer responses are as follows:

- 5,130 unique visitors came to the landing page.
- 2,643 unique visitors answered at least a few questions.
- 1,553 consumers (including 32 business respondents) completed the entire Online Primer.

The information provided by consumers were grouped together anonymously and used only for exploratory analysis in this report.

#### **Figure A: Online Primer Progress Rates**






#### **Business Respondents:**


Since only 32 business consumers finished the primer out of a total of 1,553 respondents, the focus of this report will primarily be on the total sample with a close look at municipality and household size.

Responses provided by business consumers are included in most of the following charts as footnotes and for key questions on satisfaction and permission.

#### **Respondent Profile**

The following charts display a breakdown of the residential respondents by gender, age, responsibility for electricity bill, type of residence, living situation, and number of people in household. The sample is also divided up geographically in two ways: by region into York and Simcoe County; and by municipality, including Aurora, Barrie, Markham, Richmond, Vaughan and "Other". (This last category includes respondents from Bradford as well as respondents from 18 other FSAs that did not fit precisely into the other 5 regions).





#### **Residential Demographics**


#### Figure B2: Residential Consumer Profile




#### **Residential Demographics**


Note: "Other" (2%) such as "living with parents" not shown.








#### Figure C: Sample Regional Profile



#### Sample Demographics

Municipality



# **Respondent Feedback**

In total, 1,553 respondents answered questions to the end of the primer (including 32 business respondents). Note that the number of responses will vary from question to question, particularly on the open-ended questions.

# Familiarity, Satisfaction and System Reliability


The first section of respondent feedback focuses on familiarity with the system and PowerStream, satisfaction with their level of service in the past year and perceived system reliability in both unusual and normal weather.

#### Familiarity and Understanding of the System

 PowerStream consumers say they have a good understanding of the electricity system and PowerStream's role (80% well vs. 20% not well). There's room to grow though on familiarity: half of consumers are not familiar with the system or where PowerStream fits in (49% familiar vs. 49% not familiar).

#### Satisfaction and System Reliability

- While consumers might not be the most familiar with the day-to-day track record of PowerStream, they sure are happy about what they've heard. Nearly all (91%) of the respondents say they are satisfied with PowerStream service. Similarly, 30 out of 32 of the business consumers who responded are satisfied with PowerStream.
- The best way consumers feel PowerStream could improve its service is to reduce rates (26%). Reliable service (9%) and improved communication (8%) are also key concerns. Still, even when asked for constructive criticism nearly two-in-ten (17%) say there's nothing wrong with their PowerStream service.
- Nearly seven-in-ten (70%) say they experienced an outage during unusual weather with the municipalities of Richmond Hill (78%) and Aurora (76%) and larger households (3+: 70-71% vs. 1 person: 57%) the hardest hit. Even so, a strong majority of consumers feel satisfied with PowerStream's response (82% satisfied).
- When asked how to deliver better service during both extreme weather and normal outages, "improved communication" (23%) is voiced as a key topic of concern.
- Not including unusual weather events, nearly six-in-ten (57%) respondents say they experienced an outage in the past year. Three-in-ten (29%) experienced at least two. The volume of outages varies across municipalities- Aurora (25% no outages), Markham (29%) and Richmond Hill (41%) were the hardest hit. And larger households experienced far more outages during normal weather than one-person households (42% to 58% no outages).
- These normal weather outages tended to be quite short: six-in-ten (60%) are less than hour. Aurora (55% less than an hour) and Markham (54%) experienced outages a bit longer.
- Consumers are just as happy with PowerStream's response during "normal" weather outages (84% satisfied).
- Two-thirds (67%) of consumers think PowerStream's level of reliability is "good". Aurora (65%), Markham (58%) and Richmond Hill (66%), the three municipalities who claim the most outages, are a bit less inclined to agree.



#### Figure 1: Familiarity with Electricity Distribution System

How familiar are you with the electricity system in Ontario and

the services PowerStream is responsible for? [n=1,553]




Note: "Don't know" (2%) not shown. Business respondents included in chart.

pusiness respondents included in chart.

About half (49%) of PowerStream consumers are familiar with the electricity system in Ontario. One-inten (9%) are "very familiar" with the system and four-in-ten (40%) are "somewhat familiar". Roughly the same number are not familiar with the Ontario system: nearly four-in-ten (36%) are "not very familiar" and 13% are "not familiar at all".

- In the region, Aurora (54%) is just a bit more aware than other municipalities of the electricity system.
- Men (55%) say they are much more familiar with the system than women (37%).
- Older consumers are more familiar with the system than younger ones (55+: 55% vs. 18-34: 42%).



#### Figure 2: Understanding of How Electricity System Works


How well do you feel you understand the important parts of the electricity system, how they work together and which services

Business respondents included in chart.

Eight-in-ten (80%) consumers say that they have a good understanding for both how the electricity system works and PowerStream's role in that system. More than two-in-ten (22%) think that they understand the system "very well" while almost six-in-ten (58%) understand it "somewhat well". Just two-in-ten (20%) do not understand the system (19%: "not very well"; 1%: "don't understand at all").

- Respondents in Richmond Hill (85%) feel that they have the greatest understanding of the • electricity system, while just three-in-four (75%) consumers in Vaughan feel the same.
- Men are much more likely than women to say they understand the important parts of the • electricity system, how they work together and PowerStream's role (84% vs. 71%).

Sample Breakdown **>>** 



#### Figure 3: General Satisfaction with PowerStream

Note: Don't know (2%) not shown.

Business respondents included in chart.


From the northern tip of Simcoe County to the Markham-Toronto county line, consumers are pleased with their PowerStream service. Nine out of every ten (91%) consumers say they are satisfied with their service and nearly half (46%) are "very satisfied". Just seven percent of PowerStream consumers say they are dissatisfied with current service.

Over a very small sample of business consumers (n=32), nearly all say they are satisfied with their PowerStream service (n=19: "very satisfied"; n=11: "somewhat satisfied").

#### Figure 4: Open-ended on How to Improve Service

Q

Is there is anything in particular that PowerStream can do to improve its service to you? [n=609, open-ended]




Business respondents included in chart.

Cost appears to be a major concern for PowerStream consumers. When asked precisely how PowerStream could improve its service, a quarter of respondents said "reduce rates and charges" (26%).

Still, satisfaction is clear among consumers even when asking for constructive criticism: nearly two-inten say "no improvements needed"- they are satisfied with the service.

Improvements to billing ("clear breakdown, more options to pay" (11%)), "home conservation incentives" (10%), "more consistent service, less power outages" (9%) and "improved communication" (8%) are also key issues that concern PowerStream consumers. Some issues brought up by a handful of consumers include "keeping the powerlines clear" (3%), "alerts through social media, site, SMS, email and apps" (3%), "improved infrastructure" (2%), "renewable energy programs" (2%), "faster emergency response time" (2%), "better financial management" (1%) and "prioritize the at-risk population such as elderly and infirmed consumers" (1%).




### Figure 5: Outages in the Past Year during Unusual Weather

Business respondents included in chart.

In the previous question "consistent service" (9%) was a leading mention. Here, one can see why: in the past year, nearly seven-in-ten (70%) respondents experienced a power outage during unusual weather. Just a third (32%) did not experience any power outage during weather "such as the ice storm, microbursts or tornados".

- Some striking differences emerge in the regional breakdown: roughly three quarters of
  respondents in Richmond Hill (78%), Aurora (76%), Markham and Vaughan (73%) experienced a
  power outage during this unusual weather. Barrie, on the other hand, appears to have avoided
  the brunt of the unusual weather: less than half (49%) of respondents in that area say they
  experienced such an outage.
- The larger households seem to have the worst luck on outages: just 57% of single-person households and less than two-thirds (64%) of two-person households experienced an outage during unusual weather, whereas seven-in-ten (70%-71%) households with three-or-more people experienced the same. This could be explained by a spurious factor: the age and type of residence. Respondents with large families may be more likely to live in large, old homes vulnerable to the elements, whereas single respondents and couples might more likely live in smaller, more modern condo or apartment units with greater protection against unusual weather.



### Figure 6: Satisfaction with Response to Unusual Weather Outages

Note: Don't know (7%) not shown. Business respondents included in chart.

Business respondents included in chart.

Despite the fact that 70% of respondents suffered outages in the past year, consumers are extremely satisfied with PowerStream's response to these unusual weather events. (Note that all consumers were asked, "whether they were personally affected or not".)


More than eight-in-ten (82%) consumers say they are satisfied with PowerStream's response to the outages and four-in-ten (41%) are "very satisfied". Just one-in-ten (11%) consumers are not satisfied with how PowerStream handled these events.

Of the 32 business consumers who responded, nearly all say they are satisfied with PowerStream's handling of the outages during unusual weather (n=17: "very satisfied"; n=11: "somewhat satisfied").

- Although satisfaction is high across municipalities, Richmond Hill (77%) is a bit less satisfied than the rest.
- Single-person households (86%) are the most satisfied with PowerStream's response in the past year to power outages.

### Figure 6: Open-ended on How to Improve Service in Unusual Weather


Is there is anything in particular that PowerStream can do to improve its service to you during these extreme weather events?



#### Business respondents included in chart.

Communication during an outage is paramount to consumers. About a quarter (23%) of the 544 respondents say "improved communication" is needed and almost two-in-ten (16%) say "online alerts through social media, site, SMS, email or apps". Even when prompted to provide criticism though, about two-in-ten say "no, they are satisfied" (21%).

Other mentions on how to improve service during extreme weather outages include "faster emergency response time" (8%), "improved infrastructure" (6%), "keep powerlines clear" (6%), "consistent service" (4%), "improved employee training and preparation" (3%), "reduce rates and changes" (2%), "better service maps" (1%) and "prioritize at-risk population" (1%).



### Figure 7: Number of Outages in Past Year other than Unusual Weather


Other than outages during unusual weather events, how many outages did you experience

Business respondents included in chart.

in the past year?

Not including unusual weather events, nearly six-in-ten (57%) respondents experienced an outage in the past year. Of those, almost three-in-ten (28%) experienced just one outage, 14% experienced two and 15% experienced 3-4 outages. A large minority (43%) of respondents did not experience an outage.

- Looking at municipalities, some major differences emerge on number of outages. Aurora and Markham are much more likely to have been hit by power outages during normal weather than other PowerStream municipalities (No outages: Aurora, 25%; Markham, 29% vs. Vaughan, 60%).
- One-person households (No outages: 58%) are far less likely –by a fifteen point margin- to have suffered power outages in the last year compared with larger households (No outages: 2+, 42-43%).




### Figure 8: Outage Length in Past Year during Normal Weather

Aside from unusual weather events, if you experienced an

Don't know (6%) not shown. Business respondents included in chart.

During normal weather, most outages for consumers are quite short. Six-in-ten (60%) outages for respondents are less than an hour; a third (29%) are less than fifteen minutes. Just three percent of outages for respondents are more than twenty four hours.

• Breaking it down by municipality, respondents Barrie, Richmond Hill and Vaughan (63%) experienced the shortest outages, with more than six-in-ten outages less than an hour. Consumers in Aurora (55%) and Markham (54%) are a bit more likely to say they experience longer outages.



### Figure 9: Satisfaction with Response to Normal Weather Outages


Don't know (5%) not shown. Business respondents included in chart

Again, even though a majority (57%) of respondents experienced an outage in normal weather, they are happy with how PowerStream handled it. Of those who had such an outage, more than eight-in-ten (84%) are satisfied with PowerStream's response to the outage and four-in-ten (42%) are "very satisfied". Only one-in-ten (11%) consumers who experienced an outage are dissatisfied with how PowerStream response to the power loss.

Almost all of the 20 business consumers left are satisfied with the way PowerStream responded to normal weather outages (n=10, very satisfied; n=9, somewhat satisfied).

• In the municipalities, satisfaction during normal weather outages is high across the board; Barrie (91%) appears the most satisfied.

### Figure 10: Open-ended on How to Improve Service during Outages



Business respondents included in chart.


When asked for an open-ended response to how PowerStream can improve their service during these outages, three-in-ten (29%) respondents said "nothing, they were satisfied" with how PowerStream handled it. Communication surfaces again as a major issue: nearly four-in-ten (39%) say PowerStream needs "improved communication" (23%) –such as faster and more accurate updates- and "alters through social media, site, SMS, email and apps" (16%).

Other key mentions include "faster emergency response time" (8%), "consistent service" (3%), "improved infrastructure" (3%) and "reduced rate and charges" (3%).

### Figure 11: Level of Reliability

Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level of reliability is ... [n=1,553]





Don't know (1%) not shown. Business respondents included in chart.

Respondents think PowerStream is reliable. When told that PowerStream consumers lose about 100 minutes of power a year due to outages and that this is at or below the industry average, more than two-thirds (67%) see that as a good level of reliability. About a quarter (26%) think it is "acceptable" and only 6% think the level of reliability is "poor".

- Of all the municipalities, Barrie (79%) is the most likely to say PowerStream is at a "good" level of reliability. There is a twenty-one point gap between Barrie and Markham (58%) on the level of reliability.
- One-person households (77%) are more likely than larger ones (64-67%) to say that the company is operating at a "good" level of reliability.

## Long-term Challenges and Investment Solutions

The second and final section examines consumer opinion on aging infrastructure and investment in new technology and gages consumer "permission" to increase rates to address these challenges.


### Aging Infrastructure and Investment in New Technology

- When asked if they are willing to pay for infrastructure, first respondents say instead "we should stay the course" of running equipment to failure if it impacts only a few consumers. However, when compared with scaling back on investments, respondents are mostly supportive: "investing to reduce in power outages" beats "scale back infrastructure investment" by a twoto-one margin (55% to 27%).
- Respondents also agree PowerStream should invest in new technologies (48%); just a third (34%) say these new technologies are a "luxury, not a necessity".

#### The Investment Plan, Consumer "Permission" for Increase

- In the open-ended question on how much more they would be willing to pay each month to support infrastructure investment, about forty percent said less than \$10. There's a hard opposition here: 23% say they would not be willing to pay any additional fees.
- A strong majority (87%) feel they understand the challenges facing the PowerStream system.
- Six-in-ten (58%) think PowerStream's investment plan, from what they know so far, is on the right track. Those that think PowerStream is on the right track think that the "proposed solutions are reasonable and balanced", (26%) they're satisfied overall with PowerStream (10%) and they value increased reliability (26%). Those who aren't quite sure what to think of the investment plan and those who think PowerStream's plan is going in the wrong direction are likely to say "consumers shouldn't cover the additional cost" (31% not sure, n=22/64 for "wrong direction).
- Overall, two-thirds of consumers support the rate increase (19% "reasonable"; 48% "necessary"). Support is consistently high across the municipalities and for the 32 business consumers (n=21 support).
- Those who think the increase is reasonable support it to "prevent future disruptions" in service (n=45) and think the amount is also reasonable (n=31). Those who oppose it include the "hard opposition" mentioned above: 55 out of 220 say they would not accept any increase at all.
   "Oppose" verbatim also talk about the operating efficiencies of PowerStream (n=37) and executive accountability (n=31). Those who "don't like the increase, but think it's necessary" also cite reliability (n=31) and don't necessarily see an alternative (n=23).

### Figure 12: Willingness to Pay for Infrastructure Development



Business respondents included in chart.

The next question, a measure of how willing consumers are to invest in infrastructure, includes the following pre-amble:

A significant amount of PowerStream's distribution system equipment was installed in the 1970s, 1960s or even earlier, and is still in service today. PowerStream works hard to extend the life of existing equipment because it helps to keep rates down, but as equipment gets older it becomes more likely to fail. PowerStream has two approaches to older equipment.

- If the failure of a piece of equipment will impact a large number of people, result in a long outage or if an inspection shows the equipment is in poor condition, PowerStream does its best to replace the equipment before it fails.
- When an equipment failure has only a limited impact and can be quickly replaced, PowerStream's policy is to leave the equipment in place until it breaks down to get all of the value possible from that equipment.

When asked what they think of this policy, just 17% of respondents say they are willing to pay more to replace equipment before it fails. Nearly seven-in-ten (68%) respondents "support the current approach" of running equipment to failure when it impacts "only a few consumers for a limited amount of time".

 No municipality in particular is more willing to pay to improve their infrastructure, despite the fact that some municipalities are far more likely to report outages this year than others (Aurora and Markham: 75% and 71% experienced an outage this year, respectively compared with just 40% in Vaughan).

Another planning issue is the pace of replacing aging equipment. This can have an impact on both the cost and the reliability of system. Replacing equipment sooner rather than later will result in higher rates but also should provide fewer outages due

#### When it comes to replacing aging equipment, which of the following points of view is closest to your own? [n=1,553] Jones says: Smith says: PowerStream should scale back PowerStream should invest their investment in renewing the what it takes to replace the system's aging infrastructure to system's aging infrastructure to reduce the size of any bill increase; reduce the risk of power even if that means more or longer outages; even if that means my power service interruptions. electricity bill will increase by a few dollars per month. 27% 27% Agree with 55% Jones 18% 55% Agree with 18% Don't Know Smith

### Figure 12a: Smith and Jones on Investment in Infrastructure

Business respondents included in chart.

to equipment failures.

The previous question compared increased infrastructure investment to "the current approach" of running equipment until it fails. This next question asks: how does added infrastructure investment fare vs. *reduced* investment, considering the cost to consumers?


Consumers favor infrastructure investment a lot more in this comparison. More than half (55%) agree that PowerStream should invest in aging infrastructure whereas more than a quarter (27%) say PowerStream should "scale back" its investment to "reduce the size of any bill increase". Less than two-in-ten (18%) do not know the answer.

• Men are a bit more likely than women to want PowerStream to invest in infrastructure (58% vs. 50%).

### Figure 12b: Smith and Jones on Investment in New Technologies

Of course, while there are clear benefits from new technology, there are also costs. The system functions well on the old technology. Do we want to pay more to secure the benefits new technology can deliver?

When it comes to investing in new technology, which of the following points of view is closest to your own? [n=1,553]



Business respondents included in chart.

When asked about investment in new *technology*, almost half (48%) agree that "the benefits of new technology are important" and investing in it should be a priority. Just over a third (34%) agree with the opposite view, that investing in new technology is a "luxury" and should be a "low priority for PowerStream". Again, less than two-in-ten (17%), do not know the answer.

• Men are also more likely than women to think the benefits of new technology are important and investments in it should be a priority (51% vs. 43%).

	Aurora	Barrie	Markham	Richmond Hill	Vaughan	Other
Invest in Infrastructure	56%	55%	59%	55%	51%	58%
Scale back investment	22%	29%	25%	27%	28%	26%
Invest in technology	45%	47%	54%	48%	46%	42%
Technology luxury, not necessity	36%	37%	30%	35%	35%	40%

### Figure 12c: Municipalities on Investment in Infrastructure and Technology


A majority of all the municipalities favor an investment in aging infrastructure over scaling back on investment with respondents from Markham (59%) the most likely to prefer investment.

Markham is also a bit more likely to want to invest in technology than other municipalities (54% vs. 42-48%) and also a bit less likely to say that technology investment is a luxury, not a necessity (30% vs. 35-40%).

### Figure 13: Open-ended on Amount Willing to Pay for Infrastructure Investment

The investments discussed earlier in the primer are focused on minimizing the day-to-day outages and increasing the speed by which electricity is restored. There are additional investments that could help "harden" the system and speed up power restoration during a major event. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.


Currently, the average residential customer pays \$27 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather? [n=1542, open-ended]



"Don't know" (1%), "Refused" (1%) not shown. Business respondents included in open-ends.

This next open-ended question informs consumers that the "average residential consumer pays \$27 a month to PowerStream" and asks them how much more they are willing to pay each month.

Around a quarter (23%) of consumers would not pay any more each month to invest in system improvement. Another quarter (25%) would pay less than \$5 and 16% would pay between 5 and 10 dollars. About one-in-ten would pay \$10 to \$20 (10%), \$20 to \$30 (9%) or \$30 to \$40 (11%) and almost no respondents would pay more than that (3%).



### Figure 14: Consumer Understanding of Challenges

system and what they are planning to do to meet those

Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream


Business respondents included in chart.

A very strong majority of consumers (87%) feel that they understand the system challenges and also how PowerStream is addressing those challenges. Just 12% say they do not understand these system challenges and how PowerStream plans to address those problems.

Sample Breakdown >>

### Figure 16: Direction of Investment Plan

Prom what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction? [n=1,553]



Sample Breakdown >>

Those who say "right direction"

Business respondents included in chart.

PowerStream's investment strategy is on the right track, according to consumers. Nearly six-in-ten (58%) respondents feel that PowerStream's investment plan is moving in the right direction with just six percent who feel the opposite. There is a lot of uncertainty here: more than a third (35%) are "not sure".


- Other municipalities (including Bradford) are the most likely to think that PowerStream's investment plan is going in the right direction (68%). That being said, there is strong majority support across all municipalities.
- Men are slightly more likely than women to think PowerStream's investment plan is going in the right direction (61% vs. 53%).

### Figure 17a: Open-ended on Direction of Investment Plan



And why do you feel that way?


[n=663, open-ended]



Business respondents included in chart.

In this follow-up open-ended question, responses are categorized in two ways: the overall sample, and a breakdown of those who think PowerStream's investment plan is moving in the right direction vs. those who are unsure how to answer. (With only 64 responses, "Wrong direction" is only included as a footnote on the following chart.)

Out of the 663 total respondents, the main reasons respondents the key reasons are cost ("the consumers shouldn't cover the additional cost", 17%), reliability ("prevent future disruptions", 16%) and "proposed solutions are reasonable and balanced" (15%). Other key mentions include "find operating efficiencies, reduce expenses" (8%), "satisfied with PowerStream service so far" (6%), "executive accountability" (5%), "more details needed, not enough info" (5%), "saves money in the long run" (4%), "skeptical of information" (3%), "cost increase not too much if service improves" (3%), "renewable energy solutions" (2%) and "too much detail, too complicated" (1%).



### Figure 17b: Open-ended on Direction of Investment Plan

And why do you feel that way?

[n=664, open-ended]

Wrong direction not shown [n=64].

Top mentions are "customers shouldn't cover additional costs" [n=22], "find operating efficiencies, reduce expenses" [n=16] and "executive accountability" [n=9]


For those 387 respondents who feel PowerStream's investment plan is moving in the right direction, "reliability" (26%) and "proposed solutions are reasonable and balanced" (26%) are the key reasons for their support. Other reasons include "satisfied with PowerStream service so far" (10%), "consumers shouldn't cover additional cost" (7%), "saves money in the long run" (6%), "find operating efficiencies, reduce expenses" (5%), "cost increase not too much if service improves" (4%), "executive accountability" (2%) and "renewable energy solutions".

For the 212 PowerStream consumers who "aren't sure" about the company's direction, roughly threein-ten (31%) say "consumers shouldn't cover the additional cost" (31%). These unsure consumers feel the details of what's going on are either not sufficient ("need more info" (15%)), not reliable ("skeptical of information", 6%) or too complicated (4%). Some other mentions for the unsure consumers are "executive accountability" (8%), "find operating efficiencies" (7%), "renewable energy solutions" (3%), "difficult to predict future needs" (1%) or reliability (1%). Not surprisingly for this group, 13% of them "don't know".

(Top mentions for "wrong direction" consumers are also cost ("consumers shouldn't cover additional costs", n=22), "find operating efficiencies, reduce expenses" (n=16) and "executive accountability" (n=9)).

### **Figure 18a: Permission Question**

Considering what you know about the local distribution system, which of the following best represents your point of view: [n=1,553]




Don't know (7%) not included.

Two out of every three PowerStream consumers support the rate increase (67% support). Around twoin-ten think it is "reasonable and support it" while almost half (48%) say they "don't like it", but understand the rate increase is necessary. A quarter (26%) of respondents oppose it, saying the rate increase is "unreasonable".


- In the region, support is high across the board for the rate increase. Vaughan (63%) is slightly less supportive of it than the rest of the municipalities.
- Older Canadians (72%) are a bit more likely than younger ones to give permission (18-34: 67%; 35-54: 64%).

Of the 32 business consumers who responded to this question, 21 "don't like it, but think it's necessary" and nine think it is "unreasonable" and oppose it.


### Figure 18b: Explanation of Permission Response



Business respondents included in chart.



[n=620, open-ended]



The final question of the primer asks consumers to explain their opinion on the rate increase. Responses are divided into those who support it, those who "don't like it, but think it's necessary", and those who oppose it.

8

5 5

5

7

3

Other

Don't know

Refused

8

15

18

Increased amount is too much

Saves money in the long run Renewable energy infrastructure

Skeptical of information (real cost, source) Spread out increase evenly, too much in 2016

More details needed, not enough info

Respondents who support the rate increase do so because they want reliable service (n=45 out of 120). They also think the increase is a reasonable amount (n=31). Other reasons include "don't see an alternative" (n=12), "saves money in the long run" (n=9), "executive accountability" (n=3), "renewable energy infrastructure" (n=3), and "cost of living increases" (n=2).


A quarter (n=55 out of 220) of consumers who oppose the rate increase would not accept any increase at all, no matter the size: it already "costs too much". Some think that PowerStream should look from within first to reduce expenses (n=37) while others mention "executive accountability" (n=31) or the rising cost of living (n=25) as their key concern. Other reasons by consumers who oppose the rate increase are "increased amount is too much" (n=13), "spread it out more evenly" (12), "skeptical of information (9), "elderly and infirmed concerns" (8), "renewable energy infrastructure" (3) and "not enough info" to decide (2).


For those who don't like the increase but think it's necessary, "cost" and "reliability" are the top concerns (n=31). The cost is already too much, but, if it prevents future disruptions, they consider it worth it. Other top mentions include "they don't see an alternative" (n=23), "executive accountability" (n=22), "cost of living increases" (n=19), "the increase is a reasonable amount" (n=17), "find operating efficiencies, reduce expenses" (n=16), "elderly and infirmed concerns" (n=16) and "the amount is too much" (n=15).


## **Appendix: Feedback on the Primer**

In the appendix, respondents were asked a series of questions to give feedback on the primer; their impression of the primer itself, the volume of information, the depth of coverage, and suggestions for future consultations.


- General impression of the primer overall was quite positive (+62): overall respondents found it "very good" or "good (37%), informative (26%) and clear and easy to use (11%).
- The primer had just the right amount of information according to a majority of respondents (60% "just the right amount"; 30% "too much"; "4% not enough").
- For a majority, the primer covered everything relevant and did not leave anything out (57% "no, didn't miss anything"; 62% "no, no other questions to answer").
- A strong minority (43%) would prefer to participate in a similar format, online, in the future.








**Outstanding Questions:** is there anything that you would still like answered? [n=592, open-ended]





**Suggestions for Future Consultations:** how would you prefer to participate in these consultations? [n=620, open-ended]



## **General Service and Residential Consultations**

Customer Consultation Groups with Residential and General Service customers

**PURPOSE:** To gain qualitative input on PowerStream's DSP from residential and GS < 50 kW customers and to obtain feedback into survey design.

### Summary

The following summary highlights key findings from the General Service and Residential consultation sessions held in Barrie, Markham, and Vaughan.

## PowerStream's service is seen positively by both General Service and Residential customers.

Both rate classes are generally satisfied with the service they receive from PowerStream. Residential customers see the utility as being well run and visible in the community and General Service customers see PowerStream as helpful and responsive. PowerStream is also generally held in high regard when compared to other utilities, including Toronto Hydro.

### Improved communication would help increase customer satisfaction.

Both General Service and Residential customers generally believe that communications could be improved, especially during outages. Communicating the estimated length of outages is important for both rate classes, primarily General Service customers, as prolonged outages can effect productivity and therefore, profitability.

### Given high reliability, certain investments are seen as unnecessary.

The majority of customers feel PowerStream is highly reliable. They generally buy into the argument on pro-active replacement, but look to that as a business case, and want to know that the investment will yield not only reliability benefits, but also cost savings for customers down the line.

Both General Service and Residential customers often focused on the billing system as a point of disconnect. Many participants questioned the need for such an expenditure, and also the benefit to them as they saw no issue in their experience.

### Preparing for extreme weather is not seen as a priority for many customers.

Because reliability is generally seen positively, many participants, both General Service and Residential, did not see preparing for extreme weather as a priority. These types of events are seen as 'unpredictable' and do not provide value to the overall system's reliability.

## There is a desire to know that both internal and external cost savings have been considered.

Before agreeing to a rate increase, many customers, both General Service and Residential, felt that every possible avenue of cost savings needs to be looked at. They felt that the magnitude of the rate

increase would require significant sacrifice on the part of customers – they wanted to see that the sacrifices were shared by PowerStream, even among management.

General Service customers were particularly interested in internal efficiencies related to employee salaries and managing assets. Many GS customers argued that they could not increase costs so dramatically at their own businesses, and PowerStream shouldn't either.

### Opinions are formed at a higher level, in the context of overall energy bills.

Both General Service and Residential customers look at this proposed rate increase in terms of their overall energy bill. Again, both groups believe increases to other elements are also on the horizon, bringing the net customer 'ask' on bills much higher. Many customers point out that the 'stacking' of rate increases is making it increasingly difficult to afford electricity. While for many, this proposed rate increase is manageable, there is a general uncertainty as to what will happen in the future should these increases continue.

## The rate increase is seen as symptomatic of a broader disconnect between public and private economies.

Many business customers point out that they have faced increasing costs, technology shifts, and other pressures for several years that they are unable to pass on to customers. They ask why PowerStream is unable to operate under the same conditions that they face.

Residential customers point out that they have for the most part not been receiving raises or bonuses for several years, while their costs continue to escalate. They ask why PowerStream is unable to operate in the same economic world they are forced to operate in.

### The Primer was informative, but was seen to have gaps that created 'push back'.

Many customers zeroed in on the rate increase. They generally did not find the information they needed to justify it, and although they understood the plan and the underlying needs, they could not find the information to truly validate it. This caused the Primer to invoke some 'push back' as to motive, most feeling it was simply a tool to get a rate increase across.

Some customers, both General Service and Residential, wanted a business case that included full financial information, presented in a simple, clear manner. They specifically wanted financial information that showed costs on a comparative basis, particularly salary costs and overheads. They wanted information on what many called "profit", or any surpluses.

### Permission was obtained, but somewhat grudgingly.

Ultimately, participants in the customer consultation sessions give PowerStream social permission for a rate increase (35 of 47), although, somewhat grudgingly. Many customers want to be sure that all alternative avenues have been explored and that PowerStream is making the prudent spending and investment decisions. While most customers feel that PowerStream's rate increase is necessary, many want to be reassured that rates do not continue to increase indefinitely at such a significant level.

Response	Sum Total
The rate increase is reasonable and I support it	4
I don't like it, but I think the rate increase is necessary	31
The rate increase is unreasonable and I oppose	9
Don't know	0
Total	47

## Methodology

### About the General Service and Residential Customer Consultation

Innovative Research Group (INNOVATIVE) was engaged by PowerStream to conduct a series of General Service and residential customer consultation sessions designed to identify the needs and preferences of consumers as they relate to the Distribution System Plan.

The consultation sessions were held in Barrie on November 17, 2014, Markham on November 17, 2014, and Vaughan on November 19, 2014. A total of 49 General service and residential customers participated in these consultation sessions.

Barrie: November 17, 2014						
	General Service under 50 kW Rate Class Residential Rate Class	10 participants 7 participants				
Markham: November 18, 2014						
	General Service under 50 kW Rate Class Residential Rate Class	10 participants 10 participants				
Vaughan: November 19, 2014						
	General Service under 50 kW Rate Class Residential Rate Class	6 participants 6 participants				

### **Recruiting Consultation Participants:**

General Service customers in the under 50 kW rate class were randomly selected by telephone from customer lists and screened for appropriateness as session participants. General Service customers qualified for the consultation if they managed or oversaw their businesses' electricity bill. This was to ensure they were at least somewhat knowledgeable of their electricity costs and could have an informed discussion on the impact of the proposed rate increases.

Customer recruitment lists were randomly generated and provided to INNOVATIVE by PowerStream.

An incentive of \$100 was provided to General Service customers, while residential customers received \$80 to participate in the consultation sessions.

All consultation sessions were video recorded to verify participant feedback and quotes.

### **Consultation Session Structure:**

The consultation sessions were structured around the themes contained in the primer, which was developed by INNOVATIVE and PowerStream in Fall 2014.

The primer themes included the following:

- 1. Why Are We Here?
- 2. Electricity Grid 101
- 3. PowerStream's Grid Today
- 4. Challenges and Solutions
- 5. What This Plan Means for You
- 6. Final Thoughts

At the start of the sessions, the facilitator gave an overview explaining the purpose of the consultation and why PowerStream is seeking feedback from General Service and residential customers.

After explaining the purpose of the consultation, hardcopy primers were distributed to act as a session guide for participants to record their answers to the question contained within.

Participants were then provided roughly 45-minutes to read and complete the questions within the primer. When it came to the questions within the primer, participants were asked to fill in their answers independently.

The facilitator then went through the primer section by section and facilitated a discussion on what the details meant for the individual or their business.

Hardcopy primers were collected from the participants at the conclusion of each consultation session.

Each consultation sessions ran for approximately two hours.

### Informing the Consultation Process:

In addition to identifying customer needs and preferences as they relate to the proposed Distribution System Plan, feedback collected from this phase of the consultation was used to inform the next phases of the process.

**NOTE:** Results contained within this report are based on a limited sample and should be interpreted as directional only.

## **Participant Feedback**

The following section highlights the general feedback from General Service and Residential customers.

### General Service under 50kW Rate Class (Barrie)

### Customers were generally satisfied with PowerStream's service.

Overall, General Service customers were happy with the service they were receiving from PowerStream. That being said, many participants noted a high (and increasing) bills as a reason for displeasure with the service they are receiving.

What can they improve on? For me, nothing.

Been in business for 6 years and never had a power outage.

The cost could come down.

PowerStream does a really good job, but I think we pay for it.

## Some participants provided 'push back' to this process and PowerStream in general.

There was some 'push back' regarding where PowerStream fits in to the larger energy sector. Discussion focused on the rate increase being passed regardless of customer opinions. For several participants, PowerStream was seen as a bureaucratic monopoly that can just about do whatever it pleases.

Part of a Hydro bureaucracy. Looks like this is just to justify rate increases. They don't talk about the profit portion of it. We don't have an option, we're in a monopoly.

### System reliability was generally seen positively by participants.

Overall, participants in this group were pleased with the reliability they received. Outside of outages caused by extreme weather, participants noted very few power interruptions.

From a customer point of view, you can't complain, the power works.

*Our system's pretty reliable. We're competing on a global basis.* 

*I'm very satisfied, they can't do anything better.* 

#### Some participants reported varying consequences during shorter outages.

Smaller outages that do not register in formal statistics were a concern for some participants. The consequences of these minor outages varied within the group, however, can be seen as a substantial problem for some businesses. For instance, one participant noted the machinery recovery time following these types of outages. Again, equipment damage is a concern for some businesses.

It's flickering, maybe there's a surge. I'm worried about my equipment.

We had a padmount blow up and they were on it like white on rice.

Just a flicker. Not a huge issue.

We had five incidents. I can't afford battery backups for machines.

An overarching concern in this group was related to improving communication during outages.

The central concern in this group was related to improved communication during outages. Many participants in this group found that communication during outages, particularly during the Ice Storm, could be improved. For many small businesses, understanding the duration of an outage affects how they will respond, including; sending employees home and closing their business altogether. Many participants pointed to using media, both paid and unpaid, to disseminate information to the general public. While some participants pointed to using social media, others said radio and television would be more effective.

Is there any way to communicate a timeline [for restoration]?

Most people have smartphones, there's always Twitter and Facebook.

Sometimes I'm informing [PowerStream] of the outage.

When the power goes out, people are thinking; what, what? The best way now would be through a smartphone.

Go through the media and give out information [during outages].

I don't see why the utilities can't be more proactive in media.

They need to use something to show that everything is good. Maybe Twitter?

## Despite a desire for improved communication, several participants do not believe investing in a new billing system is important.

While proactive communication during outages was seen as important, improvements to the billing system were generally not seen as a priority for many. Many participants had a difficult time seeing why a new billing system would be a priority. It is not seen as helping to increase reliability or offset bill increases, and therefore, not a priority for many. Some participants noted receiving this bills on time, and not wanting to pay more to receive a bill they already get.

If they were doing something completely new that was saving money, that's a different story.

I think they should invest what's necessary.

Billing system doesn't support reliability.

# Several participants suggested coordinating future infrastructure projects with city plans.

Several participants in this group believe that there should be more effort made to coordinate infrastructure projects with other city projects. These participants believe that efficiencies could be found if this coordination occurs, as roads would not need to be 'torn up' more than once to accommodate for these projects.

These companies need to be more forward-thinking. Integrate [infrastructure projects] with construction.

When they decide they're going to tear up the road, plan it together.

## Many participants believe that PowerStream should find internal efficiencies to reduce the proposed rate increase.

Internal efficiencies are seen to be an important factor in reducing the proposed rate increase. Again, these participants point to how PowerStream operates as an area that requires further attention.

Find [the money] in the company.

Find it from within.

If it's being run really efficiently inside. Are there a lot of efficiencies at PowerStream?

# Participants were generally split regarding preparing for extreme weather, however, most do not believe it should be a priority.

The majority of participants in this group do not believe it is necessary to invest in preparing for extreme weather. Because future weather is seen as unpredictable, and past experience is generally positive, this is seen as an area of investment that is not necessary, and does not directly affect day-to-day reliability.

What happens is going to happen, I don't buy that as a reason to raise rates.

It's like planning for shit happening when you can't.

This company should be planning a systematic upgrade.

### There is a general desire for further information and education regarding the plan and PowerStream billing in general.

Many customers in this group believe that the public needs further information regarding the rate increase. That being said, several participants point to not fully understanding the bills, and this being a barrier to understanding the plan in its entirety. A few participants had a difficult time understanding where PowerStream fit in the larger energy market.

I get three bills. I pay for those three meters, send me one bill.

As consumers, we know little about this, it's just PowerStream on the letterhead. This is information that the public needs.

Explain to me what the benefit is.

In order for me to approve something I need to understand it completely.

# Although the rate increase is generally seen negatively, the majority of participants believe it is necessary.

Seven participants support the rate increase, while only one are opposed to it. Despite receiving support in the primer, further clarity was seen as an important factor. There are some gaps in trust that left some participants feeling uneasy about the increase. Some participants pointed to small businesses being unable to shoulder the proposed increase. Despite this pushback, the majority of participants understood why is was necessary.

This plan shoes a lack of foresight. Based on the last 5 years of government I don't trust them. How are small businesses going to cope [with this increase]? No attempt to address waste and inefficiencies. What will the [new] system do? Why is it such a big priority?

### **Residential Rate Class (Barrie)**

## While several participants were overwhelmingly positive about the consultation process, some provided more 'push back'.

Some participants were positive regarding the consultation process. These participants were specifically satisfied with the opportunity to voice their opinions, as well as getting educated on the broader energy sector. Prior to reading the primer, few participants in this group were very familiar with PowerStream's responsibility. Despite this positivity, some participants felt that the rate increase was inevitable and that the primers intention was to persuade and not to consult.

We get to voice our opinions directly. I feel more educated, I like it. It was driven in one direction to get you to agree. No matter what we say, the rates are going to go up. Corporations should pay more for the delivery costs – they can afford it.

## Several participants believe that PowerStream could improve communication, especially during outages.

While the consequences of outages were not seen as being severe, several participants requested increased communication during outages. Short-term outages were less problematic, however, some more prolonged outages presented more problematic concerns.

If it's going to be out for 16 days, tell us.

Communication would be nice.

## Many participants say that the proposed investments can be justified by long-term savings.

Many participants in this group believed that these proposed infrastructure investments should provide long-term savings on bills. Many in this group found it difficult to justify the investment without savings in the long-term.

If it's an investment in the long-term

They should be making decisions based on what's profitable

Efficiencies can be found by modernizing the system

#### The same long-term savings were also expressed for investments in new technology.

Again, investments in new technology are seen to generate long-term savings. These investments are generally seen to be positive only when providing some long-term benefit, mainly cost savings.

If there's a cost benefits to technology, go for it.

If it increase the system's capacity, go for it.

Several participants believe that planning for extreme weather will not only increase safety, but also help offset bills.

Some participants saw investing in planning for extreme weather as a potential savings, should the system be hit again (like the Ice Storm).

I don't like to see major amount of people without what they need to survive [electricity].

Maybe this will help decrease bills in the long-run.

## Some also see these investments as unnecessary due to the unpredictability of weather.

With regards to extreme weather, the opposite view was also expressed in this group. For a few participants, these investments should not be made because weather is seen as unpreventable, and investments might turn out to be unused and redundant.

We don't know, it's way up in the air.

### All participants approved the rate increase, however, with some reluctance.

Seven out of seven participants supported the proposed rate increase. However, many participants suggested that further information would help solidify their support for the plan. Specifically, several participants expressed interest in further information regarding how the business portion of PowerStream operates, including employee salaries.

I'm never sure [PowerStream] is running effectively on the business side.

You question if the [money] is actually being well spent.

I would rather see a gradual increase.

### General Service under 50kW Rate Class (Markham)

# Participants were generally satisfied with the service being provided by PowerStream.

Generally, participants in this group were satisfied with the service they were receiving from PowerStream. In particular, one participant pointed to the relatively young age of the company as being an 'impressive' factor in their positive service experience.

I think their doing a pretty good job. They're only a ten year old company.

My [service] is exceptional.

# Some participants expressed difficulty in understanding how certain investments would help improve productivity.

Several participants in this group found it difficult to understand how these investments would improve their own reliability. For instance, how will certain investments affect the recovery time during outages? In addition to this, some participants wanted to know how these investments would increase productivity and operations costs as a whole. Specifically, what would be the cost difference between replacing infrastructure proactively versus replacing at time of failure?

Everything that is given is black and white, they should have some middle ground.

If I were to have everything that is proposed, will I have less downtime? We don't have that number.

Know the price difference between sending the crews out and using remote technology.

This is how quickly we'll be able to get power to a number of people, this scenario compared to the other.

## Several participants questioned why there was no information regarding internal efficiencies and PowerStream salaries.

Several participants in this group questioned why the primer and PowerStream's plan in general did not feature any savings or internal efficiencies. PowerStream was generally seen as placing the burden on the customer without looking within to find savings. Specifically, participants pointed to employee salaries as an area that could be examined to find savings and therefore reduce overall bill impacts.

I didn't see one word on spending less money on anything. How much does an executive at PowerStream make? If they want to, [PowerStream] can find out things they can reduce. They don't talk about wage increases.

## Although the majority of participants accept the proposed rate increase, some believe that further savings can be found to reduce rate impacts.

Similarly to the prior point, several participants in this group believe that further efficiencies can be found to reduce the rate impact, including stretching equipment life. The general sentiment in this group was that some rate increase was acceptable, however, the percentage was difficult to justify. Many of these business customers express not being able to pass this rate increase off to their own customers without "a damn good explanation".

I believe they can use the older equipment a bit longer, if they're not broke don't fix them.

8.2 per cent, and I'm assuming that's going to be compounded. I have public companies and I can't tell them were going to have an 8.2 per cent increase without a really damn good explanation.

They want to be proactive, and there's nothing wrong with that.

## When asked about the balance between investment and rate increases, participants were generally divided.

At the end of the session, participants were asked to write down what they thought the appropriate balance was between investments and rate increases. The following are transcribed responses from that question:

The right balance between a rate increase and providing consistent, reliable power needs to be based on the power distributor's ability to maintain as well as improve electricity distribution while still breaking even and being revenue positive one year to the next.

*Try not to spend more than you make, but repair (replace) what is needed.* 

The correct balance for rate inflation should be gradual enough for the consumer to comprehend. 2%. More information should be provided to keep costs low!

*Identify the hazard of failing equipment and prioritize. Charge sufficient development fees to cover future needs plus refurbish old equipment. Reasonable, increase 5%* 

*Increase the rate based on the most urgent needs. To start with, increase the efficiency of operations (overhead), have a longer plan.* 

Inform the consumers what kinds of plan the PowerStream has at the present time so that consumers can use this plan so that they can reduce the bill.

*Replacement needs to be ongoing for aging equipment. Utility needs to be proactive in information supplied to end consumer.* 

### **Residential Rate Class (Markham)**

## PowerStream's service is generally seen positively, including their response during the 2013 Ice Storm.

Residential customers in Markham were generally very positive about PowerStream's service. In fact, in this group, very little time was spent on this subject, because participants generally had nothing negative to say about PowerStream, nor the services it offers.

During the ice storm I think they did a wonderful job communicating with customers when the power was going to be back.

### In addition to service, most participants do not see PowerStream's reliability as an issue.

Similarly to overall service, customers in this group did not see reliability as a major concern. In fact, 6 of 7 participants who responded in the primer express having two or fewer outages in the past year. Again, for these individuals, reliability was of little concern.

There's no reliability problem in my opinion. In the last 12 months I've had no outages.

#### Several participants do not believe the PowerStream is effectively managed.

Despite a general positive perception of PowerStream in this group, there were several participants who believe its financials are not being effectively managed. In fact, a few of these people believe that the current proposed rate increase is a result of mismanagement.

I think they need to justify more why they need an increase.

I believe that they money is not managed properly.

It doesn't strike to the heart of the matter, when you look at the sunshine list in Ontario, how many hundreds of people are working for PowerStream.

## A number of participants believe that further information is needed to make an informed decision regarding the rate increase.

There were certain gaps in the primer that created skepticism regarding the proposed rate increase. For instance, one participant pointed to a lack of information regarding labour costs. This participant believed that there was a lack of information regarding a specific cost breakdown of various proposed infrastructure projects. In addition to this, a few participants requested information regarding current costs compared to proposed costs.

*This whole book did not mention labour costs. They're just not mentioned.* 

In order to make an informed decision on the rates, we need to know what they are doing now.

#### Many participants note using less electricity, however, not seeing a bill decrease.

In a discussion regarding electricity usage, most participants noted using substantially less electricity, yet bills continued to rise. Many of these participants found it difficult to understand how decreasing usage didn't result in savings.

My usage has gone down, my bill has gone up dramatically.

# Most participants questioned what would happen following the five year rate increase.

There was an overarching concern in this group that bill increases would go beyond the proposed five year plan. The general feeling was that the current proposed plan was reasonable, however, not if the same increases occur indefinitely.

It's still not clear. In the five years are they fixing everything?

My expectation is what's going to happen after five years? Is there any promise to the consumer that because all the infrastructure has been repaired we won't see any more rate increases?

I agree with five years. What's going to happen after five years?

For many participants, the proposed rate increase is seen as unreasonable.

I think that with proper planning, why would they need more than an inflation increase.

I agree to a rate increase but not at these rates.

That being said, seven of ten participants accepted the rate increase, despite not 'liking it'.

If you don't invest in the future today, at some point you hit a brick wall and have a huge expense and have to catch up.

Why get opinions from us if they're going to make the changes anyways.

### General Service under 50kW Rate Class (Vaughan)

#### Participants were generally satisfied with PowerStream's service.

Many participants stated their satisfaction with PowerStream's service, particularly when compared to other similar utilities. In fact, a few participants who managed multiple properties noted that PowerStream's service was far superior to that of Toronto Hydro.

Compare PowerStream to Toronto, it's like night and day. PowerStream is way better.

#### Most participants were also generally satisfied with the reliability they receive.

In addition to service, most participants were satisfied with the service reliability they received. Very few had experienced many substantial outages, and this left them feeling positive about the system reliability.

*My office is in Woodbridge and I haven't seen an outage once.* 

The reliability is way better then where I live in Albion.

## Some participants were unclear as to how this plan will directly affect their businesses.

There was a general desire in this group to understand how exactly this plan would affect their own business' service and reliability. For instance, some participants wanted to know how these investments would help guarantee less outages or the time required to regain power. Many participants found these questions to be missing in the primer.

I don't know what I'm gaining in terms of downtime.

#### Many participants questioned PowerStream's plan from a business perspective.

Some participants questioned the validity of the plan as they believe it does not make a "strong business case". Again, some participants wanted more details on PowerStream operations and a more detailed understanding of how the business was run. Until this information was provided, several participants believed that the plan was unreasonable.

It doesn't tell me what their overhead is.

It's all vague, there's no specifics. This is a very generalized document.

Line wages, management wages.

I don't know how they manage their resources.

#### Some participants also believe that alternative sources of funding should be found to help pay for the proposed investments.

A few participants raised the idea of alternative sources of funding, particularly by finding internal efficiencies and government assistance.

This is what we're contributing, what are they contributing?

What funding does PowerStream get from the different levels of government?

### According to some participants, prolonged outages can be financially costly to small businesses.

For many participants in this group, short outages were not overly concerning, however, prolonged outages are costly.

If I have to close for a whole day, that's a problem.

#### A few participants did not understand the need to invest in a new billing system.

A new billing system was seen to not benefit the customer whatsoever. Generally, participants in this group consistently received a bill, and did not see how this investment would improve system reliability.

I love my bills, I can read by bills.

## While the majority approved the proposed rate increase, they did so with certain provisions.

Generally speaking, most participants in this group wanted certain guarantees when approving the proposed rate increase. For instance, they wanted assurance that all efficiencies have been found and that the money would be spent effectively. That being said, most participants understood that these investments are necessary.

It's a burden but we have to do it. I would like to see if they can look internally.

I don't want to see in a year from now that we're doing this again.

There's no option because they have to start doing this.

Are they going to spend the money in the right way?

### **Residential Rate Class (Markham)**

#### Many participants found the consultation to be a valuable education in electricity.

Before I just paid the bill. Now I have a better understanding of what I'm paying, and why I'm paying.

*I learned a little more detail on all the different parts and how much the local utility. It's a smaller part than what I thought.* 

## Generally, participants had a positive perception of PowerStream as a well-run company.

The general sense in this group was that PowerStream was doing an excellent job managing their electricity. Several participants had recently had positive interactions with PowerStream, whether during the Ice Storm or with general Customer Service. Overall, PowerStream was seen to be doing a good job managing the distribution portion of bills.

I really feel PowerStream is a respected utility in many ways. I think the public feels like they're managing well. And they've been manning with the rate increases they've been giving us.

*I see the trucks on the street, I see the efficiency of the ground crews. They're better – their trucks. They spend money on the essential on-street equipment and they're doing a better job.* 

#### Most participants found that system reliability was a strength for PowerStream.

Very few participants in this group were at all concerned with the reliability they were currently experiencing. In fact, the only real instances were outages were noticeable was during the Ice Storm in 2013. Even then, customers in this group experienced outages that were seen to be 'manageable'.

Personally, I think it is very reliable. During last year's ice storm I was sleeping and four hours later - so during the time the power was out - by the time I got up and running it was restored. For me that was great.

I'm satisfied with how we get hydro. The interruptions are minimal. Other than during the ice storm, we were I think three days without power. What was nice in our particular case - we had power maybe for an hour at one point and then it went off or maybe 10 hours. But then we would get it for a little bit so we could recharge.

#### Some participants pushed back as to why they had to fund a rate increase.

In large part, because reliability was seen positively by most, participants in this group did not understand why they were being asked to fund these investments. It was generally believed that PowerStream should be able to find internal and external efficiencies to help mitigate the rate impact.

The question is why are they asking us to pay for it.

We're paying distribution then replacement, new equipment. It's like my business. I don't charge my customers when I have to replace an oven. You know, it's part of my costs. So my question is why do they keep passing it on to us.

#### The proposed rate increase was generally seen as unrealistic.

Some participants in this group found that PowerStream might be asking for too much. Although perceptions of PowerStream were still positive, it was said that this level of investment might not be needed.

I think they might be overreacting a little bit, in terms of this plan – but it's in the right direction. And in my opinion PowerStream is doing a good job.

### Several participants agreed that average households would not be able to afford the proposed rate increase.

When tied to the overall cost of living, many participants believe that this rate increase is too high. All aspects of energy continue to rise, while the average household income stays the same, making it increasingly difficult to 'keep up'. Overall, this increase is seen as too much for the average household.

I don't want to go 7.7%, I think that's too much. I disagree with that, but I also am positive about the future. But the ordinary household can't afford that because everything is going up. Taxes are going up.

A lot of people are working for minimum wage and they're stretching their budget already. They're doing their part and buying these homes. They're mortgaging and stretching a dollar and I think for the average household it's too much.

### **Questionnaire Results**

The following tables are the tabulations of participant feedback to questions in the hardcopy primers which were returned at the end of each consultation session.

Reponses to *open-ended* questions have been coded and examples of those codes are included below the question.

1. How familiar are you with the electricity system in Ontario, and the services PowerStream is responsible for?

Response		Barrie			Markham	1	<u>۱</u>	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	
Very familiar	1	0	1	1	1	2	1	0	1	4
Somewhat familiar	2	2	4	5	2	7	1	2	3	14
Not very familiar	4	2	6	2	4	6	3	3	6	18
Not at all familiar	2	1	3	0	2	2	0	1	1	6
Don't know	1	0	1	0	0	0	0	0	0	1
TOTAL	10	5	15	8	9	17	5	6	11	43

2. How well do you feel you understand the important parts of the electricity system, how they work together, and which services PowerStream is responsible for?

Pochonco	Barrie				Markham	)	V	'aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Very well	1	1	2	3	4	7	2	1	3	12
Somewhat well	8	4	12	6	5	11	3	4	7	30
Not very well	1	2	3	0	1	1	0	1	1	5
I don't understand	0	0	0	0	0	0	0	0	0	0
TOTAL	10	7	17	9	10	19	5	6	11	47

3. Generally speaking, how satisfied are you with the service you are receiving from PowerStream? Would you say...

Response	Barrie				Markham	1	\	/aughan		Grand Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
Very satisfied	4	4	8	4	7	11	1	5	6	25
Somewhat satisfied	6	2	8	3	3	6	4	1	5	19
Somewhat dissatisfied	0	1	1	1	0	1	0	0	0	2
Very dissatistied	0	0	0	0	0	0	0	0	0	0
Don't know	0	0	0	0	0	0	0	0	0	0
TOTAL	10	7	17	8	10	18	5	6	11	46


4. Is there anything in particular that PowerStream can do to improve its service to you? [OPEN-ENDED]

**Reliability** – Improve the reliability in the area north of Highway 7 and west of Woodbine Ave. Blackouts seem to occur at least 1-2 times a year in all or part of this area

**Rate Reduction** – Lower bills, eliminate the GEA and reduce the hydro bureaucracy. Capitalize on efficiencies in the system. Promote/ encourage more power reductions and streamline the system

**Communication** – when undertaking major projects informing customers about the phases of the project would be appreciated

**Other** - not a big fan of the peak mid peak and off peak usage. I think electrical costs should not be based on peak demand



5. As far as you know, in the past year, did you experience any outages due to unusual weather such as the ice storm, microbursts or tornados?

Posponso	Barrie				Markham	<u>ו</u>	\	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Yes	8	2	10	7	8	15	5	6	11	36
No	1	5	6	3	2	5	0	0	0	11
Don't know	1	0	1	0	0	0	0	0	0	1
TOTAL	10	7	17	10	10	20	5	6	11	48

6. Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say...

Response	Barrie				Markham	)	١	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
Very satisfied	6	4	10	3	5	8	2	2	4	22
Somewhat satisfied	3	1	4	7	3	10	3	3	6	20
Somewhat dissatisfied	0	0	0	0	2	2	0	1	1	3
Very dissatistied	0	0	0	0	0	0	0	0	0	0
Don't know	0	0	0	0	0	0	0	0	0	0
TOTAL	9	5	14	10	10	20	5	6	11	45


7. Is there anything in particular that PowerStream can do to improve its service to you during these extreme weather events?

**Increased Manpower** – have on call staff list to increase man power during bad weather.

None – No I find PS to be very proactive they act fast during outages

**Communication** – *it would be great if an email blast would be sent out updating us on the status of the outage. Most of us have email service on our phone and PDA* 

**Other -** *ensure power outages are dealt with as quickly as possible, with as short a duration as possible* 



Pasnansa		Barrie			Markham	1	\ ا	/aughan		Grand Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
Zero	1	4	5	1	3	4	0	0	0	9
One	2	0	2	4	2	6	3	2	5	13
Two	4	0	4	1	1	2	1	3	4	10
Three	0	0	0	0	0	0	0	0	0	0
Four	0	0	0	0	0	0	0	0	0	0
Five or more	2	2	4	1	1	2	0	0	0	6
TOTAL	9	6	15	7	7	14	4	5	9	38

8. Other than outages during unusual events, how many outages did you experience in the past year?

9. Aside from unusual weather events, if you experienced an outage in the past year, what was the longest you experienced?

Desnource		Barrie			Markham	1	١	/aughan		Croud Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Less than 15 min	1	2	3	4	4	8	1	1	2	13
15 to less than 30 min	3	1	4	0	0	0	0	1	1	5
30 min to less than 1 hr	0	1	1	1	1	2	0	1	1	4
1 hr to less than 3 hrs	0	0	0	0	0	0	0	0	0	0
3 hrs to less than 6 hrs	0	0	0	0	0	0	0	0	0	0
6 hrs to less than 12 hrs	0	0	0	0	0	0	0	0	0	0
12 to less than 24 hrs	0	0	0	0	0	0	1	1	2	2
More than 24 hrs	0	0	0	0	0	0	0	0	0	0
Don't know	1	0	1	0	2	2	2	0	2	5
TOTAL	5	4	9	5	7	12	4	4	8	29

10. If you experienced an outage, how satisfied are you with the way PowerStream responded to the outage? Would you say...


Response	Barrie				Markham	າ	\ ا	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Very satisfied	6	4	10	4	5	9	2	2	4	23
Somewhat satisfied	4	1	5	5	4	9	3	4	7	21
Somewhat dissatisfied	0	0	0	0	0	0	0	0	0	0
Very dissatistied	0	0	0	0	0	0	0	0	0	0
Don't know	0	0	0	1	1	2	0	0	0	2
TOTAL	10	5	15	10	10	20	5	6	11	46

11. Is there anything in particular that PowerStream can do to improve its service to you during outages? [OPEN-ENDED]

None – no - speed in my area is adequate

**Communication -** *communicate to the customer via email, message or 1800 number* 

**Other -** maybe design backup power packs. Use text to customers re outages



12. Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level of reliability is...

Pasmansa		Barrie			Markham	1	N	/aughan	•	Grand Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Very good	4	2	6	4	3	7	3	3	6	19
Good	5	5	10	4	3	7	1	1	2	19
Acceptable	0	0	0	2	2	4	1	2	3	7
Poor	0	0	0	0	0	0	0	0	0	0
Very poor	0	0	0	0	0	0	0	0	0	0
Don't know	0	0	0	0	1	1	0	0	0	1
TOTAL	9	7	16	10	9	19	5	6	11	46

#### 13. What do you think of this policy?

Posponso		Barrie			Markham	1	N	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
I am willing to pay more	1	2	3	1	2	3	2	0	2	8
Support current approach	9	5	14	5	7	12	3	6	9	35
Don't know	0	0	0	2	0	2	0	0	0	2
TOTAL	10	7	17	8	9	17	5	6	11	45


14. When it comes to replacing aging equipment, which of the following points of view is closest to your own?

Porponco		Barrie			Markham	1	\ \	/aughan		Grand Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
PowerStream should	4	3	7	6	7	13	3	3	6	26
invest	4	5	/	0	/	15	5	5	0	20
PowerSteam should scale	4	4	8	1	2	3	1	2	3	14
back	4	4	0	1	2	5	1	2	5	14
Don't know	2	0	2	1	1	2	1	1	2	6
TOTAL	10	7	17	8	10	18	5	6	11	46

15. While there are clear benefits from new technology, there are also costs. The system functions well on the old technology. Do we want to pay more to secure the benefits new technology can deliver?

Pornonco		Barrie			Markham	1	N	/aughan	Grand Total	
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
Investments in new	E	3	8	4	3	7	2	0	2	17
technology	5	5	0	4	5	/	2	0	2	17
I think the benfits of new	2	4	6	3	6	9	2	6	9	24
techology	2	4	0	5	0	9	5	0	9	24
Don't know	3	0	3	1	1	2	0	0	0	5
TOTAL	10	7	17	8	10	18	5	6	11	46

16. Currently, the average residential customer pays \$27 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather? [OPEN-ENDED]



17. Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream system and what they are planning to do to meet those challenges?

Response		Barrie		Markham		Vaughan		Grand Total		
	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Totai
Very well	2	3	5	4	3	7	1	1	2	14
Somewhat well	8	4	12	4	6	10	4	3	7	29
Not very well	0	0	0	0	0	0	1	2	3	3
Don't understand at all	0	0	0	0	0	0	0	0	0	0
TOTAL	10	7	17	8	9	17	6	6	12	46

18. From what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction?

Response		Barrie			Markham	1	\ \	/aughan		Grand Total
	GS	Res	Total	GS	Res	Total	GS	Res	Total	Granu Total
Right direction	6	5	11	5	5	10	5	2	7	28
Wrong direction	3	0	3	2	0	2	0	1	1	6
Don't know	1	2	3	0	3	3	1	2	3	9
TOTAL	10	7	17	7	8	15	6	5	11	43


19. And why do you feel that way? [OPEN-ENDED]

Respondents who answered "right direction" to Q18 provided the following responses:

**Long-term savings** – improvements in reliability and efficiency appear to pay returns in the long term

**Need for improvements** – *I see a need for continual system and infrastructure upgrades in the area. Particularly for hardware. Not sure that I agree that a major investment should be identified as a new billing system are consumers expected to pay for investments in order for PS to take our money* 

**Other** - overall I feel PowerStream is a respectful utility managing rate increases while investing prudently in infrastructure but prioritize and focus on essential changes in infrastructure and manage better



#### 19. And why do you feel that way? [OPEN-ENDED]

Respondents who answered "wrong direction" to Q18 provided the following responses:

Only 1 Residential and 5 General Service participants found that PowerStream was moving in the "wrong direction". The general theme of "finding money elsewhere" could be found amongst these responses. Specific responses include the following:

Has PS identified any efficiencies within their system? What waste needs to be addressed/ trimmed. Is PS overstaffed what are they doing to address these?

the investment plan is being funded by the taxpayer or consumer - why aren't taxpayers given incentives and builders to assist in reducing costs by participating in electrical generation i.e. solar panels or new roofing design and technology

Expect us to pay for the repairs. We pay enough the repairs should come out of their profits not put the burden on us. We pay for a service. We are not owners in the company, government needs to be more responsible. Stop building new subdivisions until we can maintain the homes we have now. Use modern technology, solar panels, waterless hot water tanks, etc.

Making "major capital investments" on a new billing system? Come on! The old system is just fine. Focus on the field and not on ancillary aspects

As small businesses will not be able to afford the increase. Developers should be charged for a large portion of providing energy to new areas

20. Considering what you know about the local distribution system, which of the following best represents your point of view?

Decrearce		Barrie			Markham	า	V	/aughan		Grand Total
Response	GS	Res	Total	GS	Res	Total	GS	Res	Total	Grand Total
The rate increase is reasonable and I support it	0	2	2	1	1	2	0	0	0	4
I don't like it, but I think the rate increase is necessary	7	5	12	4	6	10	5	4	9	31
The rate increase is unreasonable and I oppose	2	0	2	2	3	5	0	2	2	9
Don't know	0	0	0	0	0	0	0	0	0	0
TOTAL	9	7	16	7	10	17	5	6	11	44

## Mid-Market General Service Workshops

Workshop Presentations and Discussion Groups with Mid-Market Customers

**PURPOSE:** To gain qualitative input on PowerStream's DSP from Mid-Market customers and to obtain feedback into survey design.

### Summary

The following summary highlights key findings from the mid-market workshop sessions held in Simcoe County (Barrie) on December 9<sup>th</sup>, 2014 and York Region (Richmond Hill) on December 10<sup>th</sup>, 2014.

#### Satisfaction with service is high in both Simcoe County and York Region.

Customers in Simcoe County were overwhelmingly positive about the service they receive from PowerStream. In both groups, PowerStream was often compared to other utilities, and in all cases fared positively. Overall, PowerStream has provided excellent service and is perceived as a well-run business by its customers.

When asked where improvements could be made, customers in both groups pointed to reducing bills. Otherwise, PowerStream is doing an excellent job at being visible in the community.

## Since satisfaction with reliability is high, customers find it difficult to justify the proposed investment plan.

In both regions, customers have experienced very few outages in recent years, including those due to extreme weather. As such, they found it difficult to justify the need for the proposed investments. Customers in both groups provided consistent push-back on infrastructure projects because reliability was not seen as a pressing concern.

In Simcoe County specifically, customers found both customer service and reliability to be adequate, and therefore, could not understand why money was needed to invest in these areas.

#### Certain aspects of communication were seen as a weakness in York Region, but customers believe that investments in new technology should provide cost savings.

Customers in York Region found that PowerStream could improve its communications, especially when outages were planned and could be prepared for. Receiving information regarding projected outage durations helps small businesses decide whether they should shut down, or stay open – a decision that affects them financially.

Many customers believe that any investments in new technology, including communications systems should provide long-term cost savings. Using their own businesses as a point of reference, many participants thought that investments in new technology should reduce bills rather than increase them.

#### Planning for extreme weather is not seen as a priority for most.

Neither group saw investments in planning for extreme weather as a priority. Since overall system reliability was seen positively, most customers did not believe it was necessary to plan for events that would 'happen regardless'. While most, especially in Simcoe County understood that these investments would act as an 'insurance policy' very few were willing to spend the extra money required to harden the system.

Instead of hardening the system as a whole, many customers in both groups, have already or plan to invest in backup generation in case of prolonged outages caused by extreme weather. In fact, some participants in Simcoe County wanted more information on how they could become less reliant on PowerStream.

# Depending on the region, short outages and interruptions can be costly for small businesses.

Short interruptions, including brown-outs and 'blips' are a concern for customers in York Region. While the consequences of outages vary based on sector, most customers in this region report having experienced loss caused by outages. Safety and lost productivity are real concerns for customers. In some cases they have to clear buildings that contain vulnerable populations, notably the elderly. These short outages, which often do not register in formal statistics, can cause serious problems to equipment and electronics.

In Simcoe County, however, customers reported minor inconveniences when outages occurred, even when exceeding a few hours. In most cases, they simply shut down or operated without power. Again, for many of these customers, if the projected duration of these outages are effectively communicated, they are manageable.

## The proposed rate increase generated push-back and was seen as being 'over ambitious'.

Customers in Simcoe County provided a great deal of push-back towards the proposed rate increase. This is seen as an overly ambitious plan. That being said, they realized that these investments are necessary, and most would be willing to agree to some increase, but not at this level. In order to offset the proposed rate increase, the majority believe that PowerStream can find efficiencies.

In York Region, customers were more receptive to the plan and provided less push-back. Although they might not like it, they understand that the pressures to the system require action and the cost of increased outages would most likely outweigh the cost of the proposed rate increase.

### Methodology

### About the Mid-Market GS Workshop Consultation

Innovative Research Group (INNOVATIVE) was engaged by PowerStream to conduct a series of midmarket customer consultation sessions designed to identify the needs and preferences of consumers as they relate to the proposed Distribution System Plan.

The consultation sessions were held in Simcoe County (Barrie) on December 9<sup>th</sup>, 2014 and York Region (Richmond Hill) on December 10<sup>th</sup>, 2014. A total of 18 mid-market customers participated in these consultation sessions.

<b>Simcoe County</b> : December 9 <sup>th</sup> , 2014	
Simcoe County (Barrie)	6 participants
York Region: December 10 <sup>th</sup> , 2014	
York Region (Richmond Hill)	12 participants

#### **Recruiting Consultation Participants:**

Mid-market (GS over 50 kWh) customers were randomly selected by telephone from customer lists and screened for appropriateness as session participants. Users qualified for the consultation if they managed or oversaw their businesses' electricity bill. This was to ensure they were at least somewhat knowledgeable of their electricity costs and could have an informed discussion on the impact of the proposed rate increases.

Mid-market customer lists were randomly generated and provided to INNOVATIVE by PowerStream.

An incentive of \$150 was provided to all mid-market customers who participated in the consultation sessions.

All consultation sessions were video recorded to verify participant feedback and quotes.

#### **Consultation Session Structure:**

The consultation sessions were structured around the themes contained in the primer, which was developed by INNOVATIVE and PowerStream staff in Fall 2014.

The primer themes included the following:

- 1. Why Are We Here?
- 2. Electricity Grid 101
- 3. PowerStream's Grid Today
- 4. Challenges and Solutions
- 5. What this Plan Means for You
- 6. Final Thoughts

All consultation participants were sent electronic copies of the primer via email as part of a pre-read package in advance of the sessions.

At the start of the sessions, the facilitator gave an overview explaining the purpose of consultation and why PowerStream is seeking feedback from mid-market customers.

After explaining the purpose of the consultation, PowerStream staff delivered a detailed presentation outlining key aspects of the DSP, including the challenges faced by the grid, as well as the proposed solutions.

Following the presentation, consultation participants were able to ask PowerStream staff questions. Overall, this portion of the session lasted roughly one and a half hours. PowerStream staff then left and participants were separated into two "breakout" groups. Two facilitators then lead the two groups of participants through the primer section by section to ensure they understood the information and to answer any questions they had about the content.

When it came to the questions within the primer, participants were asked to fill in their answers independently. The facilitator then led a group discussion on the answers participants provided and what this meant for their own businesses.

Hardcopy primers were collected from the participants at the conclusion of each consultation session.

Each consultation sessions ran for approximately 3 hours.

**NOTE:** Results contained within this report are based on a limited sample and should be interpreted as directional only.

### **Participant Feedback**

The following section highlights the general feedback from each Mid-Market General Service consultation group.

### Simcoe County Consultation Session (Tuesday December 9th, 2014)

#### Participants were generally very satisfied with PowerStream's services.

Participants had unanimously positive things to say about PowerStream's current level of service. PowerStream was often compared to other Local Distribution Companies, and is seen very positively. Other than outages occurring during extreme events, participants expressed very few power outages at their businesses. In fact, several participants in the Barrie area did not suffer an outage during the ice storm in 2013.

I'm very satisfied. As I said, from the School Board, we have buildings all across the county and we are in many different utility companies, and PowerStream is the easiest. You can actually talk to real people and answer your questions.

We have regular power, even with the ice storm last year, we didn't have any loss of power, we're satisfied, obviously like to see rates lower.

Very satisfied. We rarely have outages.

### For many respondents, a rate reduction is the sole way PowerStream can improve service.

When probed regarding how PowerStream can improve overall service, many respondents pointed to a rate reduction as a key driver. Again, perceptions were overwhelmingly positive, however, rates were a point of dissatisfaction for many.

Just rates, otherwise, just fine.

# In terms of average reliability, participants were also very satisfied with PowerStream.

Somewhat satisfied, because in the last two weeks we probably had 4 outages. .Good for us, I think we've had one in the last two years, like a half hour or something like that.

Reliability is fine.

Since I've been where I am, 2007, we lost it for two days, that's the only significant power loss in that time.

Compared to Angus they get outages all the time.

*Right now the restoration time is not that high.* 

# Several participants had a difficult time comprehending the difference in cost between replacing and repairing aging infrastructure.

Participants had a difficult time digesting the need to replace aging infrastructure, rather than simply making repairs on an ongoing basis. Several participants wanted further details regarding the cost differential of replacing versus repairing said infrastructure. Generally, participants chose to support the most cost-effective measures that kept rate impacts low.

I'm not sure you need to replace everything before it fails.

What percentage of those totals that they show you is actually aged, and has to be replaced, versus what percent they want to replace as a prevention type thing.

We don't know their priorities. At the school board we have 140 buildings that we manage, we have a system like they do that shows us, we have all of our equipment itemized, based on age, brand and model, it tells us the estimated replacement date and if we followed that we would be spending \$150 million a year replacing equipment, the reality is we've spending \$10 million because it's not always accurate, we can fix it or patch it and make it last another 10 years.

What is the cost of replacing a pole when it fails, as opposed to proactively?

I agree that they need to replace as they go along, I just don't want to spend more money on it.

# Because reliability was generally considered "good" in the area, participants found it difficult to justify further investments.

Since most participants considered PowerStream's reliability to be "good", they found it difficult to understand why large infrastructure investments were needed. Since reliability and customer service are both considered to be adequate, many did not see the need for investments in these areas. Again, some participants compared PowerStream's system reliably to other LDC's where it was often seen as far superior.

My concern is, going around the room, none of us have really experienced many power outages. If we were in a different area, maybe Hydro One, where we had more outages, my answer would be different.

*My power is really reliable so I have a hard time justifying why they need these huge infrastructure increases.* 

Several participants saw planning for extreme weather as an insurance policy that wasn't always necessary.

Overall, since system reliability was positive, participants did not see planning for extreme weather as a priority.

I have to look at and say, the risk of going down is a day of sales which I just have to determine if that's a risk I'm willing to take.

*If it was three days, I could probably live with that.* 

Zero insurance. I've run my business for 20 years and we lost power for two days, we survived, no big loss and the reliability of the product we're getting now is right up there.

If I'm willing to pay 5 per cent, what do you get for that?

If something happens, you shut down your business and go home.

When we have had power outages, we just send the kids home. Big picture, it's not really that big of a deal.

The weather man's never right, their models never right, so it could be we have ten years of great weather, or ten years of bad weather.

*I put zero [percent]. We have a backup generator already.* 

#### Many saw new technology as a cost-saver, rather than an additional cost on bills.

Using their own businesses as a point of reference, many participants thought that investments in new technology should reduce bills rather than increase them. Ultimately, several participants doubted whether new technology should be a priority if, in the end, it doesn't help to reduce the impact of their bills.

New tech should be priority?

It makes it more efficient, so it should be cheaper in the long run for them, so the bills shouldn't be reflected.

I don't think there's enough information on the new technology available.

I find it interesting that costs continue to grow, when typically, you would think, a lot of new technology when you're putting it into plants and manufacturing it's supposed to reduce your costs.

## Some participants saw new technology as an opportunity to invest in reliability outside of PowerStream.

A few participants saw improvements in technology as an opportunity to invest in their businesses own electricity system, and ultimately as a way to separate from PowerStream. Several businesses currently operate generators and are looking to reduce bills by investing in sustainable energy.

I'm looking at it as: How do I get off the grid?

#### Many participants saw this increase as part of a broader series of increases.

This just seems like you've got a lot of cost increases and I see five years from now being in same boat where they're going to do it again.

There's so much pressure, and then to add and say, do we want to spend the money to do this infrastructure?

That's a big hit. For us, our electricity bill is pretty big and we're looking at a 6 percent increase on the commodity, were not getting a 6 percent increase in funding.

### Several participants saw the proposed rate increase as difficult to afford for small businesses and not-for-profits.

We certainly can't increase our capital expenditures by 150%, I don't know who does that. I don't get where that makes sense.

Looking at the type of funding we're given to pay our electricity bill, the rate of inflation is sort of the line I was looking at, I get that they would like to do some big things in years one and two, but maybe they have to look at some other ways to fund it.

*Everything is higher, but our margins aren't any higher, so it's coming out of our bottom line.* 

When you're operating your own business, you have to look at your profitability and what can you afford to do, so it's a different decision when you can just go charge everyone.

#### Most participants believe that the proposed increase is "too ambitious".

I think they're going in the right direction, I just question if they're too aggressive.

I think the increase is very high, and they just need to scale it back.

I think the scale of it is a little too ambitious and what they're asking for from customers.

### Again, the majority of participants do not support the proposed rate increase; however, they would consider a smaller amount.

Four of the five participants who responded to the question found the rate increase to be unreasonable. That being said, they were not generally opposed to *any* rate increase, however, the current proposal was seen as too severe. Finding efficiencies and alternate funding were seen as potential solutions to offset the proposed rate increase.

I understand why they have to do the rate increase and I think it's reasonable that they're asking for a rate increase, but there should be a blend of the rate increase.

They should try to mitigate the rate increase, it's a big punch.

I don't like it, but I think it's necessary. I think it's inevitable. We're going to have to pay for it now or later.

I think the rate increase is unreasonable, I think it's too high.

I think the cost increase they're proposing is too high. I think some increase is reasonable, but not this much because we're a not-for-profit, there's no profit for us to cover this kind of an increase.

Look at if our own business is efficient and could we reduce our own costs internally to offset some of these costs.

I completely understand. They fell behind on their maintenance program, it's really what it comes down to.

#### Some participants were outright unwilling to see any rate increase on their bills.

I don't think there should be any increases.

I understand it. I don't agree with it. Fundamentally [don't agree] with the concept of money, that's the issue.

They [PowerStream] just stick it the guys paying the bill.

### York Region Consultation Session (Wednesday December 10th, 2014)

#### Participants were generally very satisfied with PowerStream's services.

Overall, the participants in this group were satisfied with PowerStream's current services. PowerStream was held in particularly high regard when compared to other urban utilities, including Toronto Hydro.

You're doing an excellent and you're doing very well with the money we give you now.

That's something that surprised me that we're charged exactly what PowerStream pays for the commodity. I would assume that they would mark it up a certain amount.

#### Overall, most participants thought the response to extreme weather was adequate.

With regards to extreme weather, almost all participants found that PowerStream effectively responded to requests and was efficient at restoring power. In fact, many participants have not experienced outages due to extreme weather, and those that have, had power quickly restored.

I was really impressed with how quickly they responded to most of the problematic areas of the ice storm.

They we're better than Toronto.

I thought the communication was good, and the response was great. That really showed me a lot.

Toronto was bad, and they weren't as good as PowerStream at getting it up again.

### Several participants believe that PowerStream could improve certain aspects of communications.

Several participants, including many in the second 'breakout group' found that communication was often lacking. Particularly, participants requested better communication regarding planned outages. These are seen as outages that can be prepared for, however, they are often in adequately informed or entirely unaware.

*I think that the communication and coordination with the clients is an area that can be improved.* 

Lack of notification is the problem.

They don't always tell us they're going to do the work in advance.

They need to improve reaction time from customer calls.

When we put in a request, it goes into a black hole and we don't get a response back.

Mostly you can't get through to anybody, it's an automated voicemail. Nobody actually picks up.

I think our regular meetings with key account reps would be helpful, I know with Entersource we have meetings every two months and it's an opportunity just to talk.

If it's something more than a half an hour up to an hour, it comes down to communication, when will the power come back on?

### For most participants, short outages, including brown-outs and blips can be very costly.

Particularly in manufacturing, any short outage, which is not registered in formal statistics, can force equipment to shut down. Several participants expressed that certain equipment can take several minutes, or even hours, to restart.

Power outages are expensive for us.

At my business, we've had some power surges where it just goes off for a second or two and the impact to us was we had metal-halide fixtures and they take 10 or 15 minutes to re-illuminate.

We have a large number of blips on our feeders, it's a nuisance for us and it happens quite routinely.

Sometimes an outage of a minute requires restarting machinery.

Any sort of power outage requires re-setting equipment, bringing it back on line. Usually we can have stuff back up and running in 15 minutes.

## Safety and lost productivity are serious concerns for many participants during outages.

If the rental we have for 1 hour and the lights are out for 15 minutes, they want their money back or they complain, and it's not our fault.

Last time we went out with the ice storm, a lot of trouble. The reason being, most of our systems are automated, some of the doors failed to close or lock, some systems went down. Because of the time of the year we couldn't even get technicians to look at the systems. So we had a really bad period where we had to get security guards in place. We had to start investing in staff to stay overnight. For 10-15 days it was crazy.

There's a health and safety issue for us. Different times of the day we might have 400-500 people in the building and when the lights are out, especially in the evening, it's a serious issue. Clearing the building, making sure people get out safely.

There's also the impact on revenue, our rentals are typically 55 minutes, so if we lose 10 or 15 minutes because the power went out, it's a significant issue for us.

All the equipment goes off, damage for our refrigerators and computers and the whole facility.

We have to send everyone home, with pay of course.

More of a human resources matter than machines. People go outside and have a fun time and then it's difficult to get them back to work.

It's dangerous in the dark, because we have huge bins all over the warehouse, people can get hurt and fall.

# According to some participants, outages to certain businesses and at certain times of day are not costly.

Participants in the restaurant industry express not suffering significant losses when outages occur during the day. Additionally, certain small trades could operate certain equipment without electricity, or simply resume a project when the outage ends. Ultimately, where outages were not costly, increasing rates were a particular concern.

I have no problem with power, if it's off and we're making a monument, it's not a big rush.

*If the outage is during the day, it's not a big problem, nothing stops. When it's dark outside it's a disaster.* 

We haven't had any complaints other than the rates.

### Many participants have invested in backup generators, which are costly to run during prolonged outages.

It costs us money because we have to run our diesel generators and pay for fuel, plus it effects productivity.

Quite often, a 30 minute outage is longer for us, because once we've transferred to our generators, you have to get a change window to retransfer. That 30 minutes could easily become 12 hours of diesel run time.

# Generally, participants see the ability to plan for outages as more important than the actual number of outages.

We couldn't plan anything. We didn't know if we should close down or cancel events and 90 per cent of our events start after 7, we need everything working.

In our case it makes no difference if it's five minutes or three hours, we get just as many calls.

#### Participants generally did not like it, but supported the proposed rate increase.

9 out of 11 respondents who answered the question in the primer supported the proposed rate increase. Additionally, most participants find that PowerStream's plan is on the right path.

Loss of power costs more than the rate increase.

### **Questionnaire Results**

The following tables are the tabulations of participant feedback to questions in the hardcopy primers which were returned at the end of each consultation session.

1. How familiar are you with the electricity system in Ontario, and the services PowerStream is responsible for?

Response	York Region	Simcoe County	Total
Very familiar	3	2	5
Somewhat familiar	4	3	7
Not very familiar	3	0	3
Not at all familiar	1	0	1
Don't know	1	0	1
TOTAL	12	5	17

2. How well do you feel you understand the important parts of the electricity system, how they work together, and which services PowerStream is responsible for?

Response	York Region	Simcoe County	Total
Very well	5	2	7
Somewhat well	6	4	10
Not very well	0	0	0
I don't understand	0	0	0
TOTAL	11	6	17

3. Generally speaking, how satisfied are you with the service you are receiving from PowerStream? Would you say...

Response	York Region	Simcoe County	Total
Very satisfied	5	3	8
Somewhat satisfied	5	3	8
Somewhat dissatisfied	1	0	1
Very dissatistied	0	0	0
Don't know	0	0	0
TOTAL	11	6	17

5. As far as you know, in the past year, did you experience any outages due to unusual weather such as the ice storm, microbursts or tornados?

Response	York Region	Simcoe County	Total
Yes	10	4	14
No	1	2	3
Don't know	0	0	0
TOTAL	11	6	17

6. Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say...

Response	York Region	Simcoe County	Total
Very satisfied	5	3	8
Somewhat satisfied	5	3	8
Somewhat dissatisfied	0	0	0
Very dissatistied	0	0	0
Don't know	1	0	1
TOTAL	11	6	17

Response	York Region	Simcoe County	Total
Zero	1	2	3
One	2	0	2
Two	2	2	4
Three	3	0	3
Four	1	0	1
Five or more	2	2	4
TOTAL	11	6	17

8. Other than outages during unusual events, how many outages did you experience in the past year?

9. Aside from unusual weather events, if you experienced an outage in the past year, what was the longest you experienced?

Response	York Region	Simcoe County	Total
Less than 15 min	3	2	5
15 to less than 30 min	1	1	2
30 min to less than 1 hr	3	0	3
1 hr to less than 3 hrs	1	0	1
3 hrs to less than 6 hrs	1	1	2
6 hrs to less than 12 hrs	0	0	0
12 to less than 24 hrs	1	0	1
More than 24 hrs	0	0	0
Don't know	0	1	1
TOTAL	10	5	15

10. If you experienced an outage, how satisfied are you with the way PowerStream responded to the outage? Would you say...

Response	York Region	Simcoe County	Total
Very satisfied	3	2	5
Somewhat satisfied	5	3	8
Somewhat dissatisfied	1	0	1
Very dissatistied	0	0	0
Don't know	1	1	2
TOTAL	10	6	16

12. Most years, the average PowerStream customer loses power due to outages for about 100 minutes over the whole year. This is at or below the average for similar utilities. Do you feel this level of reliability is...

Response	York Region	Simcoe County	Total
Very good	2	3	5
Good	6	3	9
Acceptable	2	0	2
Poor	1	0	1
Very poor	0	0	0
Don't know	0	0	0
TOTAL	11	6	17

#### 13. What do you think of this policy?

Response	York Region	Simcoe County	Total
I am willing to pay more	1	0	1
Support current approach	9	6	15
Don't know	1	0	1
TOTAL	11	6	17

14. When it comes to replacing aging equipment, which of the following points of view is closest to your own?

Response	York Region	Simcoe County	Total
PowerStream should	6	3	٥
invest		J	9
PowerSteam should	2	0	ſ
scale back		0	2
Don't know	3	1	4
TOTAL	11	4	15

15. While there are clear benefits from new technology, there are also costs. The system functions well on the old technology. Do we want to pay more to secure the benefits new technology can deliver?

Response	York Region	Simcoe County	Total
Investments in new	2	1	0
technology	2	T	3
I think the benfits of	7	7 3	10
new techology		5	10
Don't know	2	2	4
TOTAL	11	6	17

17. Given what you know and what you have read so far, how well do you feel you understand the challenges facing the PowerStream system and what they are planning to do to meet those challenges?

Response	York Region	Simcoe County	Total
Very well	3	2	5
Somewhat well	8	4	12
Not very well	0	0	0
Don't understand at all	0	0	0
TOTAL	11	6	17

18. From what you have read and what you may have heard elsewhere, does PowerStream's investment plan seem like it is going in the right direction or the wrong direction?

Response	York Region	Simcoe County	Total
Right direction	8	3	11
Wrong direction	0	2	2
Don't know	3	0	3
TOTAL	11	5	16

20. Considering what you know about the local distribution system, which of the following best represents your point of view?

Response	York Region	Simcoe County	Total
The rate increase is reasonable and I support it	1	0	1
I don't like it, but I think the rate increase is necessary	8	1	9
The rate increase is unreasonable and I oppose	2	4	6
Don't know	0	0	0
TOTAL	11	5	16

## **Key Accounts Consultations**

Workshop Presentations and Discussion Groups with Key Accounts

**PURPOSE:** To gain qualitative input on PowerStream's DSP from Key Accounts customers and to obtain feedback into survey design.

### Summary

The following summary highlights key findings from the key accounts workshop session held in the Richmond Hill area on December 10<sup>th</sup>, 2014.

## Participants want to know how this plan will affect their businesses as generally, reliability is more important than cost.

Reliability and cost are closely connected for this group. Participants want to clearly understand how the proposed plan will affect their own reliability and not just the system as a whole. Many participants are willing to spend more if they can be assured that their own reliability will improve.

It was repeated multiple times that the costs related to poor reliability outweigh the costs associated with the proposed rate increase. It is important to demonstrate how individual, case-by-case reliability will improve, rather than the system as a whole.

## When viable, businesses are looking beyond PowerStream to improve individual reliability.

For those who cannot afford *any* outage, customers are turning to alternative sources of energy to help harden their own systems. Although reliability is generally seen positively, many companies are investing in backup systems in order to avoid relying on PowerStream's system.

However, in other cases, where these investments are not possible, customers want to see improvements to the overall system in order to see better reliability.

## Communication is seen as a concern that can be improved through investments in technology.

Communication is generally seen as an area that needs improvement. Participants often found that there was not often a clear stream of information being shared between PowerStream and themselves. A key area of improvement could be seen in projecting outage lengths, particularly for customers with tenants.

Investments in new technology were seen as a potential bridge to help with communication. Again, projecting outage durations was a key driver in this discussion.

#### No matter the length, power interruptions can be very costly.

Short power interruptions, which do not register in system reliability statistics, can cause serious headaches for large customers. These interruptions, which can last from seconds to minutes, cause

robotics to malfunction and force computer systems to reboot, which affects productivity and creates lost production.

For many of these customers, any length of interruption can shut them down; it can take anywhere from minutes to hours to return to working order.

## Investing in extreme weather preparedness is seen as a valuable 'insurance policy'.

As reliability is of such importance for these customers, investing in extreme weather preparedness is seen as a valuable insurance policy that could ultimately pay for itself. For many customers, the costs related to prolonged outages are far greater than that of making these investments.

On the other hand, some customers do not see these investments as a priority, as these weather events will happen regardless and the system cannot be made 'invincible'.

## While the rate increase is understood, efficiencies should be found to reduce overall impact.

While customers generally granted permission for PowerStream's proposed Distribution System Plan, they did so under certain circumstances. The plan as a whole was seen to be overly ambitious and overall rate impact was far too high. Many customers pointed to finding internal efficiencies to help reduce the proposed rate increase.

Generally, there is concern that these rate increases will continue for the foreseeable future (beyond five years), and this is alarming for many customers. When combined with other rising costs, the increases become too much for many businesses to handle, especially for those who own multiple buildings with tenants. While this proposed increase may be manageable, if they continue for 20 years, it becomes unrealistic for many.

### Methodology

### About the Key Accounts Workshop Consultation

Innovative Research Group (INNOVATIVE) was engaged by PowerStream to conduct a series of midmarket customer consultation sessions designed to identify the needs and preferences of consumers as they relate to the proposed Distribution System Plan

The consultation session was held in York Region (Richmond Hill) on December 10<sup>th</sup>, 2014. A total of 8 key accounts customers participated in this consultation session.

York Region: December 10<sup>th</sup>, 2014

York Region (Richmond Hill)

8 participants

#### **Recruiting Consultation Participants:**

Key Accounts customers were selected by telephone from a list generated and provided to INNOVATIVE by PowerStream.

All consultation sessions were video recorded to verify participant feedback and quotes.

#### **Consultation Session Structure:**

The consultation sessions were structured around the themes contained in the primer, which was developed by INNOVATIVE and PowerStream staff in Fall 2014.

The primer themes included the following:

- 1. Why Are We Here?
- 2. Electricity Grid 101
- 3. PowerStream's Grid Today
- 4. Challenges and Solutions
- 5. What this Plan Means for You
- 6. Final Thoughts

All consultation participants were sent electronic copies of the primer via email as part of a pre-read package in advance of the sessions.

At the start of the sessions, the facilitator gave an overview explaining the purpose of consultation and why PowerStream is seeking feedback from mid-market customers.

After explaining the purpose of the consultation, PowerStream staff delivered a detailed presentation outlining key aspects of the DSP, including the challenges faced by the grid, as well as the proposed solutions.

Following the presentation, consultation participants were able to ask PowerStream staff questions. Overall, this portion of the session lasted roughly two hours.

PowerStream staff then left and the facilitator began to lead the participants through the primer section by section to ensure they understood the information and to answer any questions they had about the content.

When it came to the questions within the primer, participants were asked to fill in their answers independently. The facilitator then led a group discussion on the answers participants provided and what this meant for their own businesses.

Hardcopy primers were collected from the participants at the conclusion of each consultation session.

The consultation session ran for approximately four hours.

**NOTE:** Results contained within this report are based on a limited sample and should be interpreted as directional only.

### **Participant Feedback**

The following section highlights the general feedback from the Key Accounts consultation group.

# Key Accounts Consultation Session (Wednesday December 10<sup>th</sup>, 2014)

#### Customers want to know how this plan will affect their business.

Many participants want to know how the proposed DSP will directly affect their business' reliability. Many participants are willing to accept the rate increase, however, they want to be assured that their reliability will be improved, otherwise it is difficult to justify the proposed rate increase.

For us, in manufacturing, reliability is more important than cost, if costs are going to go up a little bit but it's going to give us better reliability, we're okay with it.

We don't know if these capital investments are going to directly affect our area or our production, or our feed or anything like that, so if I'm going to answer, yeah, let's pay more money so we can be more reliable, I don't know if that's going to actually affect my plant.

If you're in an area that won't receive any benefit for 5 years...

We don't know what that asset allocation is. We don't know where we're on the list.

#### For large users, reliability is generally more important than cost.

Participants generally saw reliability as being directly connected to cost. For these customers, the cost of poor reliability greatly outweighs potential rate increases.

*For me, reliability is more important than cost.* 

For us, reliability is a bigger factor than cost.

## Several participants believe that PowerStream should find efficiencies to help reduce the overall rate impact.

### Customers are generally satisfied with PowerStream's service, despite wanting to see bills decrease.

PowerStream is generally positively perceived, however, common complaints were tied to bills. When asked how PowerStream could improve service, most customers pointed to finding ways to help decrease overall bills.

I'm somewhat satisfied. [They can make it better] by reducing the bills.

It's been good, they have been quite accommodating, because in the past we've asked them to adjust some switches.

Things fail, and to be honest with you, they haven't failed very much. We've had two outages in the last 20 years.

# There are, however, isolated incidences of dissatisfaction with PowerStream's service.

Despite the general satisfaction with PowerStream's service, a few customers pointed to poor reliability as a serious concern. As several customers had multiple tenants, poor reliability affected them on multiple levels. In fact, tenants had threatened to deduct costs based on poor reliability and frequent outages.

The tenant has come to us and said, we're going to clock some time and deduct that from our rent, and if you don't like that we'll move out.

Probably have [outages] two or three times a year.

They haven't been doing that well. We had six brown-outs just last year. These are just cutting right into our profitability.

## Many customers are looking beyond PowerStream to improve their company's electricity reliability.

Several participants expressed not being in a position to allow any outages to occur. Reasons varied from loss of business to potential fines. In such cases, most participants have invested in alternative systems to protect against issues related to PowerStream reliability. Again, while outages may be infrequent, these 'backup' systems are seen as an insurance policy that will pay for itself over time.

*PowerStream says "We provide you will as reliable power as we can, and what you need is above standard expectation."* 

We use UPS [electronics], the motor will go down, but the brain still works and knows where it is and where it left off. Everything is UPS with 20 minute backup.

I can't afford to have any outage, that's why I have 12 megawatts of backup power on top of UPS backup, transfer switches.

#### However, in some instances where this is not viable, there is a desire to improve the overall system.

Some participants noted that regardless of the investments they make, the overall system's reliability has to be improved in order to reduce the effect of an outage.

*If there were different classes for different needs of reliability, that's something we would discuss with them.* 

Not everything is [protected by surge], key equipment and key components are, but if you get a hit, your presses will go down.

## Improving communication is a concern for these customers, however, only at the right cost.

A prominent theme that emerged in this discussion group was related to a lack of communication. Several participants found that there was not a clear stream of information between PowerStream and themselves. Projected outage durations were a particular concern for many of the participants who managed several properties or buildings. We've had numerous concerns with reliability, being complete blackouts, brown-outs, switchovers, for any length of time. In many cases later on finding out that many of these switchovers could be communicated but actually were not.

One of our concerns other than rates and reliability would be communication. I'm getting numerous calls and tenants are wanting to know if they should close up shop.

Telephone, they should have a line that gives you a continuous update. A website that you can click on that says this was just updated 15 minutes ago. Is [increased communication] going to cost me \$100,000 or \$1000? If it's \$100,000 I don't want it, but for \$1000, okay.

When it comes to communication, they haven't been that helpful telling us what can they do and what can we do, and how can we work together to get rid of these issues.

It wouldn't bother me if PowerStream contacted me and said it was going to be an hour [to restore an outage].

#### Investment in new technology is generally seen as an important step for PowerStream and will also help with communication.

Beyond general reliability, many participants saw technology as the key to improving communications. Potential improvements in communications technology included telephone services and 'smart phone' accessibility.

We want to have more communication, we want to have more knowledge and be more involved in what's going on and I think new technology would help.

I think the benefits of the new technology, in my particular case, is keeping my customers informed, I think it's an important component. When you let it get too old, we're going to be in this position again.

It's a priority in terms of knowing what is happening at that particular time When is the recovery time?

#### Several participants believe that new technology should bring a positive return.

Cost reductions were often tied to improvements in technology. Participants generally believed that these investments would increase efficiency and ultimately reduce bills.

*If there's a productivity improvement, that should be able to recover some of the costs.* 

Depending on what the investment is, there should be some type of return.

There could be added value to some of the technology, whether it's timer sensors, there could be some benefits to that.

As a general statement, technology has helped us become more effective, more efficient. I would push definitely for that.

## Some participants noted extended wait times while attempting to gather information on outages.

Frustrating. It can take a couple of hours, and with tenants calling me it's just a continuous frustrating experience. Once we get a hold of them they give us an estimated time, and we give that to the client, and when that's not met, you try to contact them again.

### Any power disruption can be very costly.

In terms of both productivity and lost product, any duration of outage can cost large users greatly. While many minor outages do not register in system reliability statistics, they can cause robotics to malfunction and force computer systems to reboot. It can take anywhere from minutes to hours to return to working order.

In certain instances we've had a flicker, and in that process we have something rebooting. You can't just shut it down again, we've lost CPUs, and sensitive equipment, and we've lost multiple items that are our assets.

We have 145 electric robots and when they're in motion, the least power flicker, it stops. You have to recover.

Recovery is the big thing. It's the recovery all the way down the line, and that hurts.

Sometimes we have to scrap the product out - a lot of times we have to scrap it.

Probably [costs] about \$5,000 or \$6,000 each time [there's an outage].

Complete or 50 percent loss of production and our lines take five or six hours to start back up.

Our machinery is expensive- each piece of equipment. The PLCs are designed to be sensitive.

Three outages is worth our total bill for the year.

#### Overall, there is general dissatisfaction with energy policy in Ontario.

PowerStream's DSP was often tied to broader energy policies in Ontario. Many participants saw this rate increase as part of a system that was inherently flawed. One participant pointed to PowerStream not being permitted to save money for future investments as a key policy concern.

I'm upset because of the government. The stupid people become ministers.

They're creating a system that's gauging, and [PowerStream] is part of it.

The process needs to be addressed.

## Some participants believe that in order to keep rates down, the depreciation model should be changed.

The depreciation model of PowerStream assets was seen as a potential weakness by some participants. These participants believed that further efficiencies could be found by making changes to the model.

*If they want to keep this rate down, that means they're going to depreciate it over a longer period of time?* 

#### There is a general concern that these increases will continue beyond five years.

Most participants are concerned that these rate increases will continue beyond the scope of the DSP. Additionally, when combined with other increases in energy costs, participants believe that overall costs are getting 'out of control'.

This 6.7 is being ramped up and will likely continue for longer than that five year period, but then in a couple of years they are going to look at some more stuff, which will make the increases even more.

Is the five years the end, or does it go on for another five, another five, another five?

## Many participants said that their businesses could not afford sustained rate increases, nor could their tenants.

Beyond being unable to afford the increasing rates themselves, several participants were concerned that their tenants would be forced to vacate their properties. Again, several participants noted they could afford this increase, however, not if they continue for the next 20 years and beyond.

No business can afford these kind of increases over the next 20 years.

There's only so much a business can afford, there has to be a median.

## Most participants generally support the current 'run to failure' approach, however, they asked for more information on the policy.

In principal, most participants supported this policy; however, they were unclear as to whether the equipment supporting their buildings were covered. Concerns with this policy occur on an individual basis, not on the system as a whole.

The way I read this, is it a major impact or a minor impact? If it's a minor impact, let it fail because it's not going to affect so much.

It's a tough question because there's one extreme and the other extreme, there's nothing in between.

It all depends on if I'm on that 'run to fail' list.

From our point of view, I don't want them to repair anything in the system; I want everything to go to failure.

## Participants were generally divided regarding investing for extreme weather, however several saw it as a valuable insurance policy.

It's a matter of importance- importance to the system, to the security and the functionality of the system.

You can only design to a certain point. At the end of the day, if an act of god happens, it doesn't matter what you've got in place, you'll go down. It doesn't matter how much money you throw at it.

Up until 3 percent would be a realistic insurance policy.

I do think there needs to be some sort of upgrade to the system, you're going to lose money anyway in a different way.

If you can't predict it, don't spend any money.

A very small percentage increase.

You have to spend something to make sure; the potential costs of a disaster are substantial.

## Participants generally don't like the increase, but think it's necessary; however, they do wish to see the overall bill impact reduced.

While permission was generally granted, many participants expressed a desire for further information and for efficiencies to be found in the plan. The general feeling was that this plan, and rate increase, were unrealistic and further internal efficiencies could be found to reduce the overall percentage. I challenge them to revisit it. We always put our wish list out first and I'm wondering if there's an opportunity for it to be challenged

Overall, I would challenge it.

It's a big increase, I would like to see a bit more planning.

6.7 per cent I would say automatically no.

If it's necessary, spend it. But I would say that the whole process needs to be looked at to even it out in such a way that you don't get hit by 6.7 per cent.

It's the difference between what I'd like to have and what I need to have.

My first impression of the budget is that it was padded. They know they're not going to get it, so if they wanted X they made Y because they know the government is going to cut them down a bit.

You've got all these big fat cats in all these different industries, and they're all making money out of it with no competition.

What's your staff, what's in the office, what's on the road? How many people do you have in your staff?

My point is productivity, what are they doing about productivity?

# Residential and General Service Telephone Survey

Telephone Surveys among Residential and GS customers **PURPOSE:** To obtain statistically significant quantitative customer feedback on PowerStream's Distribution System Plan and assess reaction to customer opinions obtained from the previous research phases.

## Summary

This section summarizes the findings from the two telephone surveys of 1,001 PowerStream residential customers and 201 General Service customers:

#### Familiarity, Satisfaction and Bill Knowledge

## Nearly half of customers are familiar with their local distribution systems, Residents more familiar than GS on PowerStream ownership.

- Just under half of both Residential (45%) and General Service (45%) respondents are familiar with their local distribution system while a majority (54% Residential; 55% General Service) in both groups are unfamiliar.
- "High consumption" residential customers are much more familiar with the system than "low consumption ones (50% vs. 37%).
- When asked if they knew that PowerStream was owned by the cities of Vaughan, Markham and Barrie, less than six-in-ten Residential (57%) respondents confirmed they already knew this information before the survey.
- Less than four-in-ten (36%) GS respondents confirmed they already knew PowerStream's owners before the survey.

## Strong majority of Residential and General Service customers are satisfied with PowerStream's service.

- Nearly nine-in-ten residential customers (87%) are satisfied with PowerStream's service; just one-in-ten say they are "dissatisfied".
- General Service customers are also quite pleased with PowerStream; more than eight-in-ten (83%) say they are satisfied with how PowerStream is running their local distribution system.

#### "Lower rates" is by far the leading concern for PowerStream customers, "communication" and "reduced outages also key mentions.

- For both Residential and General Service customers, a plurality say "lowering rates" is the biggest improvement PowerStream could make to improve service.
- "Better communication" (4% Residential, 3% General Service), "reduced outages" (2%, 2%) and "improved billing" (2%, 4%) are also key ways that, according to respondents, PowerStream could better service its customers.

#### Customers are not familiar with the breakdown of their electricity bill.

- Before the details provided in the survey just a third (33%) of Residential customers say they are familiar with the amount of their electricity bill that went to PowerStream.
- Nearly half (45%) of Residential customers say they are "not familiar at all".
- As for General Service customers, only three-in-ten (29%) are familiar with the amount of their bill owed to PowerStream. More than half (53%) of GS customers are "not familiar at all" with the breakdown of their bill.

#### System Reliability

## Almost half of customers experienced outage during extreme weather, most are satisfied with PowerStream's response.

- This past year, almost half of both Residential (45%) and General Service (44%) customers experienced an outage due to extreme weather. "High consumption" customers were the hardest hit (41% vs. Low: 56% "no, did not experience outage").
- That being said, customers are quite satisfied with PowerStream's response. Nearly threequarters (73%) of Residential and two-thirds (66%) of General Service say they are satisfied with how PowerStream handled the extreme weather service issues.
- When asked in the open-ended question to list something PowerStream could do to improve its services during extreme weather outages, a plurality of both Residential and General Service customers said they did not see anything else PowerStream could do to improve service (49% Residential, 30% GS).

## Again, about half experienced an outage during normal weather, high levels of satisfaction with PowerStream response.

- In the last year, not including extreme weather, almost half (47%) of Residential and four-in-ten (39%) GS customers have experienced an outage.
- A quarter (24%) of Residential customers have experienced one or two outages and also about a quarter (23%) have experienced three or more outages.
- Again, a quarter (25%) of GS customers have experienced one or two outages and roughly the same number (23%) have experienced three or more outages.
- A strong majority (86%) of Residential and GS customers (81%) are satisfied with PowerStream's response to these outages.

## Customers want "better communication" and "improved response time" during outages.

- The two leading improvements during outages mentioned by PowerStream Residential customers are "better communication" (13%) and "improved response and recovery" (8%). Other specific mentions include "reduced outages" (4%), "reduced short outages" (2%) and "reduce rates" (1%).
- General Service customers also bring up "improved communication" and "improved recovery time" as their top two concerns. There is some uncertainty among GS customers: three-in-ten (31%) don't know how to improve PowerStream's response to outages.

## Customers divided on whether to spend to maintain current number of outages or spend more to reduce the number.

- Four-in-ten (40%) Residential customers say PowerStream should "spend what is needed to maintain the current level of outage". Roughly a third (32%) say PowerStream should "spend what is needed to reduce the current length of time customers are without power." Only 13% say PowerStream should "accept longer time without power in order to help minimize customer costs from rising".
- General Service customers are also evenly divided on how PowerStream should approach the number of outages. Nearly four-in-ten (38%) say PowerStream should spend to maintain the current levels while a third (34%) say that it should spend to reduce the number. Again just 14% say they would accept more outages to keep costs from rising.
- Additional knowledge, that the average PowerStream customer loses power "for about 100 minutes per year", does not change the results much for either Residential or GS customers. Still a large minority (43%) of Residential and GS (38%) say "spend to maintain". Nearly the same amount say "spend to reduce" (31% Residential and GS).

#### System Challenges & Priorities

## Generally, both RS and GS customers support increased investment in aging infrastructure despite additional cost.

- A majority (54%) of both Residential and General Service customers choose to maintain the system despite an increase in cost for them personally.
- Three-in-ten (30%) Residential and a third (32%) of General Service customers prefer a reduced investment strategy to minimize any impact on their bill.

## When asked to put a specific dollar amount on it to deal with unusual weather though, roughly half would not pay a dime more.

- A strong minority, nearly half (46%) of Residential customers say they would not pay anything more to strengthen the system to deal with unusual weather. A quarter (24%) would pay less than \$5 and 15% would pay between \$5 and \$10 more. Very few people, just 11% would pay more than \$10 on their monthly bill to prevent outages in unusual weather.
- As for General Service customers, six-in-ten (59%) say they would not pay any more on their monthly bill when asked the same question. Those that would pay are willing to pay slightly more than the Residential customers: roughly a quarter (26%) would pay less than \$10 and 15% would pay more than \$10 a month to help prevent outages during unusual weather.

## Both "new technology" and "buildings, equipment and IT systems" should be an investment priority.

- Most Residential and GS customers think investment in new technology should be a priority for PowerStream. Nearly six-in-ten (58%) Residential and just over six-in-ten (61%) GS feel that investment in new technology should be a priority for PowerStream, while just a third of Residential (33%) and a quarter (24%) of GS customers feel that investment in new technology is a luxury, not a necessity.
- A majority of both Residential and GS customers also think PowerStream should invest in "buildings, equipment and IT systems". Two-thirds (64%) of Residential and over half (51%) OF GS customers prefer to manage the system efficiently with the right equipment and tools

despite the cost, while around three-in-ten (29%) Residential and nearly four-in-ten (37%) GS customers think PowerStream should make do with its current buildings and equipment.

#### **Overall Assessment of Plan**

#### Residential customers give permission, General Service oppose the increase.

Residential					
Q: Considering the cost of PowerStream's plan, would you say?					
The rate increase is reasonable and I support it	21%				
I don't like it, but I think the rate increase is necessary	42%				
The rate increase is unreasonable and I oppose it	33%				

- A majority (63%) of PowerStream Residential customers, when given additional context on the five-year plan, permit PowerStream to increase its rates.
- Two-in-ten (21%) think "the rate increase is reasonable and support it"; more than four-in-ten (42%) say they "don't like it, but think it's necessary"; and a third (33%) say "the rate increase is unreasonable and oppose it".

General Service					
Q: Considering the cost of PowerStream's plan, would you say?					
The rate increase is reasonable and I support it	15%				
I don't like it, but I think the rate increase is necessary	28%				
The rate increase is unreasonable and I oppose it	54%				

• General Service customers generally oppose it with a majority (54%) who say "the rate increase is unreasonable". Just 15% say "the rate increase is reasonable and support it" and less than three-in-ten (28%) say they "don't like it, but think the increase is necessary".

#### Cost is main permission concern for both Residential and General Service.

- When Residential customers were asked an open-ended follow-up on the permission question, the leading concern was cost. Specifically, the increase was "already too high" or "they pay too much currently" (35%).
- For General Service customers, the leading mention is also cost-related. More than a quarter (27%) say that "the rate increase is too much" and "they're paying enough already". Others think PowerStream or the government should shoulder the cost burden (11%).

## Methodology

### About the Residential and General Service Telephone Survey

PowerStream commissioned two surveys by telephone: the "Residential Rate Payer Customer Consultation" for 1,001 Residential customers of PowerStream and 201 organization customers, both conducted between January  $14^{th}$  and January  $29^{th}$ . The sample of Residential customers this size is considered accurate to within ±3.1 percentage points, 19 times out of 20 and the General Service sample is considered accurate to within ±6.9 percentage points 19 times out of 20. Margin of error will vary widely within each sub-grouping of the sample.

### **Questionnaire Design**

This questionnaire is a direct result of the previously-mentioned Online Primer and Primer-led Consultation Sessions conducted in 2014. Feedback, both positive and negative, from these two previous phases helped guide PowerStream and Innovative in the initial question design phase.

The primary goal of this survey was to both consult and inform the customer on their personal (or organizational) experience with the distribution system and gage their opinions on familiarity, satisfaction, bill knowledge, system reliability, the system challenges and priorities and, finally, the assessment of the plan to raise rates to help pay for necessary infrastructure investment.

Note that wording of questions changed slightly between Residential and General Service questionssuch as the amount paid in a bill per month- but otherwise are readily comparable.

The average survey ran approximately 10 minutes. For further information on exact question wording and order, see Appendices A and B at the end of the Telephone Survey Report.

### **Fielding the Survey**

In order to field both surveys, PowerStream provided INNOVATIV E with a confidential list containing the contact information of 316,066 Residential and 315,861 GS customers. PowerStream built this list through randomly selecting among the approximately 312,000 Residential customers and 37,000General Service customers on file in its customer database. The list consisted of customers with a landline contact on file who had been customers of PowerStream since at least December 31<sup>st</sup>, 2012. Information included in this file included customer name, home telephone number, home address, service area, and total annual usage between January 1<sup>st</sup> and December 31<sup>st</sup>, 2013.

Only one customer per household was eligible to complete the residential survey and this member was screened to ensure that they were the resident primarily responsible for paying their PowerStream bill. This screen was used to ensure the customer was the most qualified to answer the questions regarding billing and the proposed rate increase.

Before retiring a randomly selected phone number, 12 attempts were made to reach the customer for each unique telephone number, or until a hard refusal from the customer. Each number was called twice a day for the first half of field and once a day for the remaining half. Each night, INNOVATIVE added new sample to the contact list to replace completed or retired calls.

PowerStream Residential customers were contacted at home by telephone between 4pm and 8pm on weekdays; 10am and 8pm on Saturdays; and 11am to 8pm on Sundays.

General Service customers were contacted during standard work hours: weekdays 9am to 4pm. These customers were also screened to ensure they were the person in-charge of managing the electricity bill at their organization. Only 50kW or less organizations were used in this survey.

All fieldwork was conducted using INNOVATIVE's CATI system.

### Sample Design

The survey followed a stratified random sampling methodology. This is a method of sampling that divides the population into smaller groups known as strata. In stratified random sampling, the strata are formed based on members' shared attributes or characteristics (in this case, customer service area or electricity consumption). A random sample from each stratum is taken in a number proportional to the stratum's size when compared to the customer population. These subsets of the strata are then pooled to form a random sample.

In this survey, residential customers were divided into strata based on service area populations and then again into quartiles based on annual electricity usage to ensure the sample has a proportionate mix of customers from low, medium-low, medium-high, and high electricity usage households.

<b>Residential Customers</b>	Count	% Dist	Sample	Quartile 1	Quartile 2	Quartile 3	Quartile 4
Aurora	16,673	5%	53	13	13	13	13
Barrie	47,194	15%	151	38	38	38	38
Bradford	7,896	3%	25	6	6	6	6
Markham	87,074	28%	279	70	70	70	70
Richmond Hill	54,006	17%	173	43	43	43	43
Vaughan	81,528	26%	262	65	65	65	65
Other	17,285	6%	55	14	14	14	14
Total	311,656	100%	1,000	250	250	250	250

The table below illustrates the strata divisions for the Residential customer survey:


A similar stratified random sample was used for the General Service customers, broken down in the following table:

GS Customers	Count	% Dist	Sample	Quartile 1	Quartile 2	Quartile 3	Quartile 4
Barrie	5,051	14%	28	7	7	7	7
Markham	8,580	23%	47	12	12	12	12
Richmond Hill	4,931	13%	27	7	7	7	7
Vaughan	12,224	33%	67	17	17	17	17
Other	5,836	16%	32	8	8	8	8
Total	36,622	100%	200	50	50	50	50

Both samples were weighted according to the Region and Quartiles breakdown in the two previous tables.


## **Demographic Profile**

The following details the demographic characteristics of respondents who completed the Residential Ratepayer Survey [n=1,001].



The residential ratepayers tend to be older (44% "55+"; 40% "35-54"; 13% "18-34") home-owners (87% own vs. 9% rent) living in fully- (71%) or semi-(16%) detached homes.

Below are the firmographics of respondents who completed the General Service Ratepayer Survey [n=200]:



Note: Refused (3%) not shown

## **Respondent Feedback**

## Familiarity and Satisfaction: Residential and General Service Customers

The first section of respondent feedback examines how familiar both Residential and General Service customers are with the local distribution system and their satisfaction with PowerStream's stewardship of that system.

### Familiarity, Satisfaction Summary

## Nearly half of customers are familiar with their local distribution systems, Residents more familiar with GS on PowerStream ownership.

- Just under half of both Residential (45%) and General Service (45%) respondents are familiar with their local distribution system while a majority (54% Residential; 55% General Service) in both groups are unfamiliar.
- "High consumption" residential customers are much more familiar with the system than "low consumption ones (50% vs. 37%).
- When asked if they knew that PowerStream was owned by the cities of Vaughan, Markham and Barrie, less than six-in-ten Residential (57%) respondents confirmed they already knew this information before the survey.
- Less than four-in-ten (36%) respondents confirmed they already knew PowerStream's owners before the survey.

## Strong majority of Residential and General Service customers are satisfied with PowerStream's service.

- Nearly nine-in-ten residential customers (87%) are satisfied with PowerStream's service; just one-in-ten say they are "dissatisfied".
- General Service customers are also quite pleased with PowerStream; more than eight-in-ten (83%) say they are satisfied with how PowerStream is running their local distribution system.

#### "Lower rates" is by far the leading concern for PowerStream customers, "communication" and "reduced outages also key mentions.

- For both Residential and General Service customers, a plurality say "lowering rates" is the biggest improvement PowerStream could make to improve service.
- "Better communication" (4% Residential, 3% General Service), "reduced outages" (2%, 2%) and "improved billing" (2%, 4%) are also key ways that, according to respondents, PowerStream could better service its customers.
- Still, about a quarter of both Residential and General Service customers have no complaints, even when prompted to give one (26% Residential, 22% General Service).

### Preamble for Familiarity and Satisfaction Section

Before respondents are asked the first question on familiarity, the following preamble describes the components of Ontario's electricity system:


"To start, I'd like to ask you a few questions about the electricity system...

As you may know, Ontario's electricity system has three key components: **generation**, **transmission** and **distribution**.


- Generating stations convert various forms of energy into electric power;
- **Transmission lines** connect the power produced at generating stations to where it is needed across the province; and
- Distribution lines carry electricity to the homes and businesses in our communities.

Today we're going to talk about your **local distribution system** which is maintained and operated by PowerStream in your community."


### Figure 1.0 RS: Familiarity with the Local Distribution System



How familiar are you with the local distribution system which it



Sample Breakdown ▶▶



### Figure 1.1 GS: Familiarity with the Local Distribution System

Sample Breakdown 🕨

How familiar are you with the local distribution system which it

maintained and operated by PowerStream?

Note: 'Refused' (>1%) not shown

Almost half of both Residential (45%) and General Service (45%) respondents are familiar with their local distribution system while a majority (54% Residential; 55% General Service) in both groups are unfamiliar.

#### Residential

- Richmond Hill (39%) and Vaughan (43%) have the lowest level of familiarity with the local system.
- Differences in consumption level are also related to familiarity. High (50%) levels of consumption are associated with more familiarity than low (37%) level consumption.
- Consumers "55+" are more familiar with the system (52%) than consumers age 18-34 (31%).


#### General Service


- More than half (56%) of General Service customers in Simcoe County are familiar, while only 41% of York Region say the same.
- High (36%) consumption organizations are the least familiar with their local distribution system.

### Figure 1.2 RS: Satisfaction with PowerStream

Generally speaking, how satisfied are you with the job PowerStream is doing running your local distribution system? Would you say ...


Sample Breakdown ▶▶ Those who say "satisfied"





Nearly nine-in-ten residential customers (87%) are satisfied with PowerStream's service; just one-in-ten say they are "dissatisfied".

Richmond Hill (90%) and Markham (89%) are a bit more likely to be satisfied with their service • than the rest of the region.



Sample Breakdown


## Figure 1.3 GS: Satisfaction with PowerStream

Generally speaking, how satisfied is your organization with the

job PowerStream is doing running your local distribution system?

Note: 'Don't know' (6%) not shown

General Service customers are also quite pleased with PowerStream; more than eight-in-ten (83%) say they are satisfied with how PowerStream is running their local distribution system.



### **Figure 1.4 RS/GS: How to Improve Service**


For both Residential and General Service customers, the biggest improvement PowerStream could make is to "lower rates" (33% residential; 32% General Service). "Better communication" (4% Residential, 3% General Service), "reduced outages" (2%, 2%) and "improved billing" (2%, 4%) are also key ways that, according to respondents, PowerStream could better service its customers. Still, about a quarter of both Residential and General Service customers have no complaints, even when prompted to give one (26% Residential, 22% General Service).

### Figure 1.5 RS: Knowledge of PowerStream ownership

PowerStream is 100% owned by the cities of Vaughan, Markham and Barrie and is overseen by a board of directors. This board is made up of members of the respective city councils and the community and is responsible for overseeing the operations and management of the utility.

Sample Breakdown

Those who say "yes"




Note: 'Don't know' (1%) not shown

When asked if they knew that PowerStream was owned by the cities of Vaughan, Markham and Barrie, less than six-in-ten Residential (57%) respondents confirmed they already knew this information before the survey.

- Barrie (53%) Residential customers are the most likely to claim knowledge of PowerStream ownership while Residential customers in Richmond Hill (32%) are the least likely.
- Higher consumption customers (46-47%) claim to be a bit more knowledgeable than lower consumption residential customers (Low: 33%; Medium-low: 42%).

### Figure 1.6 GS: Knowledge of PowerStream ownership



Note: 'Don't know/refused' (3%) not shown

Less than four-in-ten (36%) respondents confirmed they already knew PowerStream's owners before the survey.

• Simcoe County is a bit more likely than York Region General Service customers to know PowerStream is owned by the cities of Vaughan, Markham and Barrie (46 vs. 33%).

## **Electricity Bill Knowledge**

This section explores Residential and General Service respondent perceptions and knowledge of their electricity bill. It specifically focuses on the breakdown of the bill and what portion respondents estimate goes to PowerStream.

### **Electricity Bill Knowledge Summary**

#### Customers are not familiar with the breakdown of their electricity bill

- Before the details provided in the survey just a third (33%) of Residential customers say they are familiar with the amount of their electricity bill that went to PowerStream.
- Nearly half (45%) of Residential customers say they are "not familiar at all".
- As for General Service customers, only three-in-ten (29%) are familiar with the amount of their bill owed to PowerStream. More than half (53%) of GS customers are "not familiar at all" with the breakdown of their bill.

### Preamble for Bill Knowledge Section

The question on electricity bill knowledge begins with this preamble:


"I'd now like to talk with you about your electricity bill ...

While some customers pay more and other pay less, the **average residential customer pays about \$135 a month** for electricity of **which \$27 or approximately 20% goes to PowerStream**. The rest of the bill goes to power generation companies, transmission companies, the provincial government and regulatory agencies."

(Note that in the GS survey, the bolded text is replaced with the following: *"the average General Service customer pays about \$305 a month for electricity of which \$61 or approximately 20% goes to PowerStream"*.)


#### Before this survey, how familiar were you with the amount of Sample Breakdown ▶▶ your electricity bill that went to PowerStream? Would you say ... Those who say "familiar" [asked of all respondents; n= 1001] Municipality Aurora 37% 67% Unfamiliar 33% Familiar Barrie 37% 45% Markham 28% **Richmond Hill** 31%

Figure 2.0 RS: Familiarity with Share of Bill Going to PowerStream



The details of billing are fuzzy to Residential consumers: just a third (33%) say they are familiar with the amount of their electricity bill that went to PowerStream. Nearly half (45%) say they are "not familiar at all"

• "High consumption" respondents (37%) are a bit more familiar with the breakdown of their bills than "Low consumption" ones (29%).



### Figure 2.1 GS: Familiarity with Share of Bill Going to PowerStream

Sample Breakdown ▶▶

Before this survey, how familiar were you with the amount of

your electricity bill that went to PowerStream? Would you say ...

Note: 'Don't know/refused' (3%) not shown

Just three-in-ten (29%) General Service customers are familiar with the amount of their bill owed to PowerStream. More than half (53%) say they are "not familiar at all".

• Again, "High consumption" General Service customers (34%) are more familiar than "Low consumption" ones (18%).

## System Reliability

This next section analyzes feedback on power service interruptions in the last 12 months, due to either extreme weather or normal conditions, as well as customer satisfaction with PowerStream's responses to these outages. Then customers were asked to describe in the open-ends specifically how PowerStream could improve its service during these two types of interruptions and also.

### System Reliability Summary

## Almost half of customers experienced outage during extreme weather, most are satisfied with PowerStream's response

- This past year, almost half of both Residential (45%) and General Service (44%) customers experienced an outage due to extreme weather. "High consumption" customers were the hardest hit (41% vs. Low: 56% "no, did not experience outage").
- That being said, customers are quite satisfied with PowerStream's response. Nearly threequarters (73%) of Residential and two-thirds (66%) of General Service say they are satisfied with how PowerStream handled the extreme weather service issues.
- When asked in the open-ended question to list something PowerStream could do to improve its services during extreme weather outages, a plurality of both Residential and General Service customers said they did not see anything else PowerStream could do to improve service (49% Residential, 30% GS).

## Again, about half experienced an outage during normal weather, high levels of satisfaction with PowerStream response

- In the last year, not including extreme weather, almost half (47%) of Residential and four-in-ten (39%) GS customers have experienced an outage.
- A quarter (24%) of Residential customers have experienced one or two outages and also about a quarter (23%) have experienced three or more outages.
- Again, a quarter (25%) of GS customers have experienced one or two outages and roughly the same number (23%) have experienced three or more outages.
- A strong majority (86%) of Residential and GS customers (81%) are satisfied with PowerStream's response to these outages.

## Customers want "better communication" and "improved response time" during outages


- The two leading improvements during outages mentioned by PowerStream Residential customers are "better communication" (13%) and "improved response and recovery" (8%). Other specific mentions include "reduced outages" (4%), "reduced short outages" (2%) and "reduce rates" (1%).
- General Service customers also bring up "improved communication" and "improved recovery time" as their top two concerns. There is some uncertainty among GS customers: three-in-ten (31%) don't know how to improve PowerStream's response to outages.

## Customers divided on whether to spend to maintain current number of outages or spend more to reduce the number

- Four-in-ten (40%) Residential customers say PowerStream should "spend what is needed to maintain the current level of outage". Roughly a third (32%) say PowerStream should "spend what is needed to reduce the current length of time customers are without power." Only 13% say PowerStream should "accept longer time without power in order to help minimize customer costs from rising".
- General Service customers are also evenly divided on how PowerStream should approach the number of outages. Nearly four-in-ten (38%) say PowerStream should spend to maintain the current levels while a third (34%) say that it should spend to reduce the number. Again just 14% say they would accept more outages to keep costs from rising.
- Additional knowledge, that the average PowerStream customer loses power "for about 100 minutes per year", does not change the results much for either Residential or GS customers. Still a large minority (43%) of Residential and GS (38%) say "spend to maintain". Nearly the same amount say "spend to reduce" (31% Residential and GS).

### Figure 3.0 RS: Extreme Weather Outages

In the past year or so, PowerStream customers experienced unusually extreme weather – *microburst and tornados this past summer* and an *ice storm in December 2013*. These major weather events caused power outages for many PowerStream customers.




In the past year, nearly half (45%) of Residential PowerStream customers experienced an outage during an extreme weather event.

- "High consumption" Residential customers are the most likely to have experienced an outage (41% vs. Low: 56% "no").
- Older Residential customers are more likely than younger ones to have experienced an outage due to extreme weather (35+: 42-44% "no"; 18-34: 56% "no).

### Figure 3.1 GS: Extreme Weather Outages


In the past year or so, PowerStream customers experienced unusually extreme weather – *microburst and tornados this past summer* and an *ice storm in December 2013*. These major weather events caused power outages for many PowerStream customers.



Note: 'Refused' (2%) not shown

Nearly half (44%) of General Service customers, over the past year, experienced an outage.

• General Service customers in York Region are more likely to have experienced an outage than those in Simcoe County (59% vs. 45%: "no").




### Figure 3.2 RS: Satisfaction with Response to Events

Whether you were personally affected or not, how satisfied are

0

Nearly three-quarters (73%) of Residential customers are satisfied with PowerStream's response to extreme weather events. Just 12% say they are dissatisfied with the service.



## Figure 3.3 GS: Satisfaction with Response to Events

Whether your organization was directly affected or not, how

Note: 'Refused' (3%) not shown


General Service customers are a bit less positive, but still two-thirds (66%) say they are "satisfied" overall with how PowerStream responded.

• "High consumption" General Service customers are more likely than "Low consumption" ones to feel satisfied with PowerStream's response (55% vs. 36%).

### Figure 3.4 RS/GS: How to improve service during Extreme Weather



Is there is anything in particular that PowerStream can do to improve its service to your organization during these extreme weather events?



Generally, both Residential and General Service customers appear satisfied with PowerStream's response to extreme weather events. Half (49%, includes "general satisfaction") of Residential and three-in-ten (30%) General Service say that there is nothing the organization could do to improve its service during this time.


Criticism focused more on "better communication" (15% Residential, 3% GS) and "improved response and recovery times" (9% Residential, 8% GS). Other specific ways to improve include "better preparation and prevention measures" (3% Residential, 4% GS), "reduce rates" (2%), "reduce outages" (1%) and "move wires underground" (1%).

### Figure 3.5 RS: Number of Outages during Extreme Weather Events

Q

<u>Not</u> including power outages caused by extreme weather events, have you experienced any power outages **in the past 12 months**, and if so, approximately how many? [asked of all respondents; n=1001]

Sample Breakdown ►► Those who say " 0 to 3 outages"




In the past twelve months, excluding extreme weather, nearly half (47%) of Residential customers have experienced an outage. About a quarter of Residential customers have experienced one or two outages (24%), and nearly the same amount (23%) have experienced three or more outages.

### Figure 3.6 GS: Number of Outages during Extreme Weather Events

Q


<u>Not</u> including power outages caused by extreme weather events, has your organization experienced any power outages **in the past 12 months**, and if so, approximately how many? [asked of all respondents; n=201]

Sample Breakdown ►► Those who say " 0 to 3 outages"



Note:'Refused' (3%) not shown

As for General Service customers, nearly four-in-ten (39%) have experienced an outage at their organization in the past year. One-in-four (25%) experienced one or two outages and 14% experienced three or more outages. A slight majority (52%) of General Service customers experienced no outages during normal weather.




Sample Breakdown ▶▶

### Figure 3.7 RS: Satisfaction with PowerStream Response

And how satisfied are you with the way PowerStream responded

Note: 'Don't know' (6%) not shown

A strong majority (86%) of Residential customers are satisfied with PowerStream's response to the outages. Just 9% say they are dissatisfied.




As for the 81 General Service customers who responded, eight-in-ten (81%) say they are satisfied with the way PowerStream handled the outage.

Figure 3.8 GS: Satisfaction with PowerStream Response

### Figure 3.9 RS: Open-ended on Improvement to Service



Is there is anything in particular that PowerStream could do to improve its service to you during your most recent power outages?




When asked an open-ended question on how PowerStream could improve its service during outages, half (49%) of Residential customers say there are no improvements needed- they are satisfied with the response. The two leading improvements mentioned by respondents are "better communication" (13%) and "improved response and recovery" (8%). Other specific mentions include "reduced outages" (4%), "reduced short outages" (2%) and "reduce rates" (1%).


### Figure 3.10 GS: Open-ended on Improvement to Service



Is there is anything in particular that PowerStream could do to improve its service to your organization during your most recent power outages?




Turning to the General Service customers, one-in-three (33%) in the open-ended question said they were satisfied and nothing could improve PowerStream service. Again, concerns about communication (13%) and recovery time (16%) top the list. Three-in-ten (31%) are unsure of how to improve PowerStream's response to outages.



**Figure 3.11 RS: Number of Power Outages** 

When offered a choice between spending what is needed to maintaining the number of outages vs. spending more to reduce them, customers prefer "maintain" by a hair. Four-in-ten (40%) Residential customers say PowerStream should "spend what is needed to maintain the current level of outage". Roughly a third (32%) say PowerStream should "spend what is needed to reduce the current length of time customers are without power" and just 13% say PowerStream should "accept longer time without power in order to help minimize customer costs from rising".


• Aurora (37%) is a bit more likely to say "spend what is needed" than the rest of the municipalities (22-35%).



## **Figure 3.12 GS: Number of Power Outages**

General Service customers are about evenly divided regarding *number* of outages. Nearly four-in-ten (38%) say PowerStream should spend to maintain the current levels while a third (34%) say that it should spend to reduce the number. Only 14% say they would accept more outages to keep costs from rising.

• York Region is slightly more likely than Simcoe County to say PowerStream should spend what is needed to reduce the number of outages (36% vs. 27% "spend what is needed").




## Figure 3.13 RS: Aided Number of Power Outages

The follow-up question explains to customers that the average PowerStream customer loses power "for about 100 minutes per year" and, with this new piece of information, asks them to answer the previous question again.

This new piece of information does not move the dial. Roughly the same breakdown occurs as the previous question: around three-in-ten (31%) say PowerStream should spend to reduce time and a large minority (43%) say to spend what is needed to maintain the length of outages. Again, 14% say they would accept longer times without power if it prevented rising costs.

• High consumption (33%) customers are a bit more likely to prefer "spending to reduce the number of outages" than low consumption ones (25%)

## Figure 3.14 GS: Aided Number of Power Outages



The General Service customers do not, with this new piece of information, change their opinion much. A plurality prefer "spending to maintain" (38%) over "spending to reduce time" (31%) and still the distant third is to "accept longer times to minimize rising costs" (16%).

• "High consumption" (42%) customers are more likely to prefer "spending to reduce the number of outages" than "Low consumption" customers (26%)

# System Challenges & Priorities

The next section outlines challenges to the system -aging infrastructure, outdated technology and older buildings, equipment and IT systems- and gages customer preference on infrastructure investment.

## System Challenges & Priorities Summary

# Generally, both RS and GS customers support increased investment in aging infrastructure despite additional cost

- A majority (54%) of both Residential and General Service customers choose to maintain the system despite an increase in cost for them personally.
- Three-in-ten (30%) Residential and a third (32%) of General Service customers prefer a reduced investment strategy to minimize any impact on their bill.

# When asked to put a specific dollar amount on it to deal with unusual weather though, roughly half would not pay a dime more

- A strong minority, nearly half (46%) of Residential customers say they would not pay anything more to strengthen the system to deal with unusual weather. A quarter (24%) would pay less than \$5 and 15% would pay between \$5 and \$10 more. Very few people, just 11% would pay more than \$10 on their monthly bill to prevent outages in unusual weather.
- As for General Service customers, six-in-ten (59%) say they would not pay any more on their monthly bill when asked the same question. Those that would pay are willing to pay slightly more than the Residential customers: roughly a quarter (26%) would pay less than \$10 and 15% would pay more than \$10 a month to help prevent outages during unusual weather.

# Both "new technology" and "buildings, equipment and IT systems" should be an investment priority

- Most Residential and GS customers think investment in new technology should be a priority for PowerStream. Nearly six-in-ten (58%) Residential and just over six-in-ten (61%) GS feel that investment in new technology should be a priority for PowerStream, while just a third of Residential (33%) and a quarter (24%) of GS customers feel that investment in new technology is a luxury, not a necessity.
- A majority of both Residential and GS customers also think PowerStream should invest in "buildings, equipment and IT systems". Two-thirds (64%) of Residential and over half (51%) OF GS customers prefer to manage the system efficiently with the right equipment and tools despite the cost, while around three-in-ten (29%) Residential and nearly four-in-ten (37%) GS customers think PowerStream should make do with its current buildings and equipment.

## Preamble for System Challenges & Priorities Section


The following pre-amble was read to respondents before they were asked the first question on system challenges and priorities:

"As significant amount of PowerStream's electrical infrastructure was built in the 1960s and 70s, and is still in-service today. While PowerStream believes it has done its best to prolong the life of these assets, today many of these assets are now approaching the end of their useful life and are beginning to pose a threat to system reliability.

As part of its investment plan, PowerStream is proposing a significant infrastructure renewal program. The estimated cost of this system renewal program is \$258 million over the next 5 years.

Although this plan will allow PowerStream to make, what independent studies suggest are, the necessary investments to maintain system reliability, it will have an impact on customer bills."

## **Figure 4.0 RS: Investment in Aging Infrastructure**




Note: Statements randomized

## Figure 4.1 GS: Investment in Aging Infrastructure



Which of the following statements best represents your point of view? [asked of all respondents; n=201]



Note: Statements randomized (Refused (6%) not shown)

Customers were asked to choose between two opposing statements on infrastructure: either to "invest what it takes to replace aging infrastructure and maintain reliability even if it means a bill increase" or "lower its investment in aging infrastructure to lessen the impact of a bill increase".

A majority (54%) of both Residential and General Service customers choose to maintain the system despite an increase in cost for them personally. Three-in-ten (30%) Residential and a third (32%) of General Service customers prefer a reduced investment strategy to minimize any impact on their bill.

#### Residential

• Male residential customers (58%) are a bit more likely than women (50%) to support investment in aging infrastructure despite the cost.


#### General Service

• Among the General Service customers, those in the York Region (56%) are more likely to support aging infrastructure investment than organizations in Simcoe County (46%)

# **Figure 4.2 RS: Open-ended on Extreme Weather Infrastructure Investment**

The investments discussed earlier are focused on day-to-day reliability. There are additional investments that could help "harden" the electrical system and speed up power restoration during rare weather events that have an unusually large impact on the system – such as tornados or ice storms. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average residential customer pays \$27 a month to PowerStream to operate and maintain the local distribution system. How much are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather?




A brief pre-amble to the next question outlines the need for additional infrastructure to deal with unusual weather issues such as ice storms and also reminds them how much they pay PowerStream on their monthly bill. With all this in mind, customers are asked how much more they are willing to pay towards infrastructure to deal with major weather events.

A strong minority, nearly half (46%) say they would not pay one cent more to strengthen the system to deal with unusual weather. A quarter (24%) would pay less than \$5 and 15% would pay between \$5 and \$10 more. Very few people, just 11% would pay more than \$10 on their monthly bill to prevent outages in unusual weather.

# **Figure 4.3 GS: Open-ended on Extreme Weather Infrastructure Investment**

The investments discussed earlier are focused on day-to-day reliability. There are additional investments that could help "harden" the electrical system and speed up power restoration during rare weather events that have an unusually large impact on the system – such as tornados or ice storms. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average General Service customers pays \$61 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather?




As for General Service customers, six-in-ten (59%) say they would not pay any more on their monthly bill when asked the same question. Those that would pay are willing to pay slightly more than the Residential customers: roughly a quarter (26%) would pay less than \$10 and 15% would pay more than \$10 a month to help prevent outages during unusual weather.

## **Preamble for Investment in Equipment and Tools**

On the next question regarding investment in equipment, tools and IT systems, customers were read the following short pre-amble:

"PowerStream is not just the local electricity distribution system itself, but a company that operates the system. As a company, PowerStream needs buildings to house its staff, vehicles and tools to service the power lines and IT systems to manage the electrical system and customer information.



When it comes to investing in new technology, which of the following points of view is closest to your own?


## **Figure 4.4 RS: Investment in New Technology**

Note: Statements randomized

Most customers think investment in new technology should be a priority for PowerStream.

When asked to choose between two competing viewpoints on "new technology investment", nearly sixin-ten (58%) Residential customers agree that "the benefits of new technology are important and investment in new technology should be a priority for PowerStream." One-third (33%) of customers agree with the contrary view, that "investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream."

• Aurora (63%) is a bit more likely to think investment in new technology should be a priority than other municipalities (56-60%).



## **Figure 4.5 GS: Investment in New Technology**

Note: Statements randomized (Refused (7%) not shown)

General Service customers feel roughly the same on new technology investment: six-in-ten (61%) say that new technology should be a priority compared with a quarter (24%) who feel it is more of "a luxury than a necessity".

## Preamble for Investment in New Technology


Before asking customers for their opinion on investment in new technology, callers read respondents this brief pre-amble:

"New technology can have many impacts on electricity distribution systems:

- New computer systems and GPS systems provide pinpointed information about outages to both system controllers and customer in real time.
- Remote monitors and switches allow power to be restored to many customers much more quickly than in the past.

While there are benefits from new technology, there are also costs."

## Figure 4.6 RS: Investment in New Buildings, Equipment and IT




The final "Smith and Jones" question compared viewpoints on investment in buildings, equipment and IT: on the one hand, customers could agree that "PowerStream should find ways to make do with the buildings, equipment and IT systems it already has"; or instead, they could choose "while PowerStream should be wise with its spending, it is important that its staff have the equipment and tools they need to manage the system efficiently and reliably."

Two-thirds (64%) of customers agree with the latter, that it is important to have the right equipment and tools despite the cost. Less than three-in-ten (29%) say that PowerStream should make do with its current buildings, equipment and IT systems.

• "High consumption" Residential customers (71%) are more likely than "Low consumption" (61%) to feel PowerStream should spend as it needs on equipment and tools to manage the system efficiently.

## Figure 4.7 GS: Investment in New Buildings, Equipment and IT



Note: Statements randomized (Refused (5%) not shown)

General Service customers also favor investment in new equipment and tools. Just over half (51%) prefer the option to manage the system efficiently with the right equipment and tools despite cost while nearly four-in-ten (37%) think that PowerStream should make do with its current building, equipment and IT systems.

## Assessment of Plan

In this last section, customers were given additional context on the five-year plan and asked for permission on a possible rate increase. A follow-up open-ended question asked customers to explain their decision to support or oppose the increase.

## **Assessment of Plan Summary**

#### Residential customers give permission, General Service oppose the increase.

- A majority (63%) of PowerStream Residential customers, when given additional context on the five-year plan, permit PowerStream to increase its rates.
- Two-in-ten (21%) think "the rate increase is reasonable and support it"; more than four-in-ten (42%) say they "don't like it, but think it's necessary"; and a third (33%) say "the rate increase is unreasonable and oppose it".
- General Service customers generally oppose it with a majority (54%) who say "the rate increase is unreasonable". Just 15% say "the rate increase is reasonable and support it" and less than three-in-ten (28%) say they "don't like it, but think the increase is necessary".

#### Cost is main permission concern for both Residential and General Service.

- When Residential customers were asked an open-ended follow-up on the permission question, the leading concern was cost. Specifically, the increase was "already too high" or "they pay too much currently" (35%).
- Other reasons for not supporting the increase include "PowerStream should find efficiencies or the money from other sources" (10%), "it's not necessary" (1%), "cost of everything is going up" (1%), "it will happen anyways" (1%) and "need more information" (1%).
- For General Service customers, the leading mention is also cost-related. More than a quarter (27%) say that "the rate increase is too much" and "they're paying enough already". Others think PowerStream or the government should shoulder the cost burden (11%).
- Some other reasons to oppose it mentioned include "they don't like the rate increase or decisions made at PowerStream" (8%), "businesses can't afford it" (5%) and "it's a waste of money and unnecessary" (3%).

## **RS/GS- Preamble for Assessment of Plan Section**

Before customers were asked for permission, a brief explanation of the investment plan was included in the preamble:


"To maintain the reliability of the local electricity system, PowerStream's proposed 5 year plan will spend an estimated **\$641 million** on new capital investments. This includes ...

- **\$258 million** to replace aging infrastructure;
- **\$150 million** for new technologies to make the system more efficient, reliable, safe and to expand system capacity to accommodate future growth;
- **\$147 million** to maintain metering and connect new customers to the electricity system;
- **\$86 million** to invest in tools, computers and software systems, vehicles and facilities needed to manage the electricity system;

To fund this plan, PowerStream is proposing the **average residential customers' rate increase by \$2.14 per month** on the distribution portion of their bill over the next five years. So, by 2020, the average residential household will be paying an **estimated \$10.72** <u>more</u> **per month** on the distribution portion of its electricity bill."

(In the General Service survey, the last two bolded phrases were replaced with "**average General Service customers' rate increase by \$5.25 per month"** and "**estimated \$26.24** <u>more per month"</u>, respectively. Other than the difference in rate impact, the pre-amble is identical in both surveys).


## Figure 5.0 RS - Permission for Rate Increase



Note: 'Not sure'/'Refused' (3%) not shown

A majority (63%) of PowerStream Residential customers, when the breakdown of pricing is explained, permit a rate increase. Two-in-ten (21%) think "the rate increase is reasonable and support it"; more than four-in-ten (42%) say they "don't like it, but think it's necessary"; and a third (33%) say "the rate increase is unreasonable and oppose it".

- Opposition is a bit higher in Aurora (39%) and Vaughan (37%) and lowest in Richmond Hill (27%).
- Residential customers aged 18-34 are a bit more likely to support the rate increase (28% "oppose" vs. 31-38%).



## Figure 5.1 GS - Permission for Rate Increase

Considering the cost of PowerStream's plan, would you say

Note: 'Not sure'/'Refused' (1%) not shown

[asked of all respondents; n=201]

Conversely, a majority (54%) of General Service customers *oppose* the rate increase. Just 15% say "the rate increase is reasonable and support it" and less than three-in-ten (28%) say they "don't like it, but think the increase is necessary".

#### Financial Strain on Level of Acceptance

It is expected that PowerStream's proposed rate increase will have a greater financial impact on some customers more than others, depending on their level of financial strain. As such, all respondents were asked the extent to which the cost of their electricity bill has on the respondents' personal finances or business' bottom line.

For residential respondents whose electricity bill has major impact on their finances and requires them do without some other important priorities, the level of their acceptance for the proposed rate increase (57%) is lower than those whose finances are less impacted by their electricity bill (76%).

## **Figure 5.2 RS – Residential Financial Strain**

	Financially Strained Households	Not Financially Strained Households
The rate increase is reasonable and I support it	16%	32%
I don't like it, but I think the rate increase is necessary	41%	44%
The rate increase is unreasonable and I oppose it	40%	21%
Overall Permission	57%	76%

For GS respondents whose electricity bill has major impact on their organizations' bottom line and requires them to put off some important priorities and investments, the level of their acceptance for the proposed rate increase (37%) is lower than those whose bottom line are less impacted by their electricity bill (58%).

## **Figure 5.3 GS – General Service Financial Strain**

	Financially Strained Business'	Not Financially Strained Business'
The rate increase is reasonable and I support it	14%	16%
I don't like it, but I think the rate increase is necessary	22%	42%
The rate increase is unreasonable and I oppose it	61%	40%
Overall Permission	37%	58%

#### **Open-Ended Opinions Based on PowerStream's Proposed Rate Increase**

When Residential customers were asked an open-ended follow-up on the permission question, 36% of those who chose "the rate increase is reasonable and I support it" did so because they believe the proposed rate increase is "not a lot". Other reasons for this group include "system upgrade needed" (19%) and "it's important/needed" (13%).

For Residential customers who chose "I don't like it, but I think the rate increase is necessary", nearly 1-3 (32%) held this position because the rate increase is seen as too high and "already pay too much".

For Residential customers who chose "the rate increase is unreasonable and I oppose it", a large majority (61%) hold this position because they think the increase is too high and that they "already pay too much". Additionally, 22% of the same group believe that PowerStream can "find efficiencies" or other sources to reduce the rate impact.

## Figure 5.4 RS – Opinion on Proposed Rate Increase



And why do you say that? (Asked of Residential respondents who had an opinion of PowerStreams's proposed rate increase)

ACCEPTANCE: INCREASE REASONABLE	% RS
It's not a lot	36%
System upgrade needed	19%
It's important/needed	13%
Improve/maintain reliability	10%
New technology	7%
Other	13%
Don't Know	1%

n=210

ACCEPTANCE: DON'T LIKE BUT NECESSARY	% RS
Increase too high/ already pay too much	32%
It's important/needed	21%
System upgrade needed	10%
Find efficiencies/ other sources	6%
Improve/maintain reliability	3%
New technology	3%
It's not a lot	2%
Cost of everything is going up	2%
Will happen anyways	2%
Need more information	1%
Not necessary	1%
Other	10%
None	1%
Don't Know	5%
Refused	1%

NO ACCEPTANCE: INCREASE UNREASONABLE	% RS
Increase too high/ already pay too much	61%
Find efficiencies/ other sources	22%
Not necessary	3%
Other	12%
Don't Know	2%
-220	

n=328

For General Service customers who chose "the rate increase is reasonable and I support it", 35% hold that position because the rate increase is seen as "small/ reasonable". The same amount (35%) think it's "the smart thing to do".

For General Service customers who chose "I don't like it, but I think the rate increase is necessary", almost half (43%) hold that position because they think the investments are "necessary".

Almost half (48%) of General Service customers who chose "the rate increase is unreasonable and I oppose it" did so because they believe they "already paying enough" for electricity. 1-5 (20%) of this group hold that position because they believe that PowerStream should find savings elsewhere.

## Figure 5.5 GS – Opinion on Proposed Rate Increase

And why do you say that? (Asked of General Service respondents who had an opinion of PowerStreams's proposed rate increase)

ACCEPTANCE: INCREASE REASONABLE	% GS
The rate increase is small/reasonable	35%
It's the smart thing to do	35%
Investments are necessary	10%
Business depends on reliable electricity	6%
Other	3%
Don't Know	3%
Refused	6%

#### n=31

ACCEPTANCE: DON'T LIKE BUT NECESSARY	% GS
Investments are necessary	43%
Don't like rate increases	19%
Business depends on reliable electricity	16%
If it saves money in the long run	5%
Waste of money/unnecessary	3%
The rate increase is small/reasonable	2%
Cost savings should be found elsewhere	2%
Other	7%
Don't Know	3%

n=58

NO ACCEPTANCE: INCREASE UNREASONABLE	% GS
Already paying enough	48%
Cost savings should be found elsewhere	20%
Businesses can't afford a rate increase	9%
Waste of money/unnecessary	5%
Don't like rate increases	4%
Other	13%
Don't Know	3%

n=111

# **Survey Instruments**

## **Residential Survey Instrument**

#### A. Introduction

Hello, my name is \_\_\_\_\_\_ and I'm calling from **Innovative Research Group** on behalf of **PowerStream**, your electricity distributor.

Innovative Research Group is a national public opinion research firm. We have been commissioned by **PowerStream** to help them better understand the needs and preferences of customers who are responsible for paying their household's electricity bill.

**PowerStream** – which distributes electricity to homes and businesses in your community – is preparing to submit its 5-year investment plan to the Ontario Energy Board for regulatory review. Since this plan will impact your bill, PowerStream wants to hear from you, so your views can help shape its plan.

A1. Would you mind if I had ten minutes of your time to ask you some questions? All your responses will be kept strictly confidential.

Yes No – NOT PRIMARY BILL PAYER No – BAD TIME No – HARD REFUSAL

- 1 [continue]
- 2 [go to TRANSFER-1]
- 3 ARRANGE CALLBACK
- 4 [Terminate]

#### MONIT

This call may be monitored or audio taped for quality control and evaluation purposes. PRESS TO CONTINUE 1

A2. Have I reached you at your home phone number?

**INTERVIEWER NOTE; IF "NO" ASK:** May I speak to someone who does live there?

Yes - SPEAKING, CONTINUE YES - TRANSFERRED – **(GO BACK TO INTRODUCTION)** No - NOT AVAILABLE – **(ARRANGE CALLBACK)** Refused – LOG **(THANK AND TERMINATE)** 

- [continue to A3]
   [back to INTRO]
   [ARRANGE CALLBACK]
- 9 [Terminate]
- A3. Are you the person primarily responsible for paying the electricity bill in your household?

Yes – I pay the bill1[continue to A4]Yes – shared responsibility2[continue to A4]No3[go to TRANSFER-1]Don't know (DNR)98[Terminate]

#### **TRANSFER-1**

Can I speak with the person in your household who usually pays the electricity bill? Yes 1 [BACK TO <u>INTRO</u>]

No – NOT AVAILABLE/BAD TIME – (ARRANGE CALLBACK)	2 [ARRANGE CALLBACK]
No – HARD REFUSAL	3 [Terminate]
Don't know ( <b>DNR</b> )	98 [Terminate]

A4. And can you confirm that your household receives an electricity bill from **PowerStream**?

Yes	1 [continue]
No	2 [Terminate]
Don't know ( <b>DNR</b> )	98 [Terminate]

GENDER	R Note gender by observation:		
	Male	1	
	Female	2	

#### **B. General Satisfaction**

# We need to prime respondents to start thinking about electricity and the part of the system that PowerStream operates.

#### PREAMBLE-1

To start, I'd like to ask you a few questions about the electricity system ...

As you may know, Ontario's electricity system has three key components: **generation**, **transmission** and **distribution**.

- Generating stations convert various forms of energy into electric power;
- **Transmission lines** connect the power produced at generating stations to where it is needed across the province; and
- Distribution lines carry electricity to the homes and businesses in our communities.

Today we're going to talk about your **local distribution system** which is maintained and operated by **PowerStream** in your community.

How familiar are you with the local electricity distribution system? Would you say ... [READ LIST]

Very familiar	1
Somewhat familiar	2
Not very familiar	3
Not familiar at all	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

B6. Generally speaking, how satisfied are you with the job **PowerStream** is doing running your local distribution system? Would you say ... [**READ LIST**]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

B7. Is there anything in particular **PowerStream** can do to improve its service to you? [**OPEN**]

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

**B8. PowerStream** is 100% owned by the cities of Vaughan (*pronounced as "Von"*), Markham and Barrie and is overseen by a board of directors. This board is made up of members of the respective city councils and the community and is responsible for overseeing the operations and management of the utility.

Before this survey, did you know that PowerStream was owned by the cities of Vaughan, Markham and Barrie? [DO NOT READ LIST]

Yes	1
No	2
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### C. Bill Knowledge & Impact

I'd now like to talk with you about your electricity bill ...

C9. While some customers pay more and other pay less, the **average residential customer pays about \$135 a month** for electricity of **which \$27 or approximately 20% goes to PowerStream**. The rest of the bill goes to power generation companies, transmission companies, the provincial government and regulatory agencies.

Before this survey, how familiar were you with the amount of your electricity bill that went to **PowerStream**? Would you say ... [**READ LIST**]

Very familiar	1
Somewhat familiar	2
Not very familiar	3
Not familiar	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### **D. System Reliability**

These questions are about priming the respondent to think about their experience with system reliability and separate adverse weather from failing equipment.

D10. In the past year or so, PowerStream customers experienced unusually extreme weather – *microburst and tornados this past summer* and an *ice storm in December 2013*. These major weather events caused power outages for many PowerStream customers.

As far as you know, in the past year, did your household experience any power outages due to extreme weather events such as the ice storm, microbursts or tornados?

Yes	1
No	2
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

D11. Whether you were personally affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say ... [READ LIST]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

D12. Is there is anything in particular that PowerStream can do to improve its service to you during these extreme weather events? [**OPEN**]

#### [Ask all respondents]

D13. <u>Not</u> including power outages caused by extreme weather events, have you experienced any power outages **in the past 12 months**, and if so, approximately how many? [**DO NOT READ LIST**]

No outages	0	[SKIP to D16]
1 outage	1	[CONTINUE]
2 outages	2	[CONTINUE]
3 outages	3	[CONTINUE]
4 outages	4	[CONTINUE]
5 outages	5	[CONTINUE]
6 outages	6	[CONTINUE]
7 outages	7	[CONTINUE]
8 or more outages	8	[CONTINUE]
Don't know ( <b>DNR</b> )	98	[SKIP to D16]
Refused (DNR)	99	[SKIP to D16]

D14. And how satisfied are you with the way PowerStream responded to the outage? Would you say ... [READ LIST]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused ( <b>DNR</b> )	99

- D15. Is there is anything in particular that PowerStream could do to improve its service to you during your most recent power outages? [**OPEN**]
- D16. In your view, how do you think **PowerStream** should address the <u>number</u> of customer power outages? Would you say ... [**READ LIST**]

#### [Rotate response codes 1 and 3]

Spend what is needed to reduce the number of power outages	1
Spend what is needed to maintain the current level of outages	2
Accept more power outages in order to help keep customer costs from rising	3
Don't Know ( <b>DNR</b> )	98
Refused (DNR)	99

D17. The average **PowerStream** customer is without power for about **100 minutes per year**.

In your view, how do you think PowerStream should address the <u>length of time</u> customers are without power? Would you say ... [READ LIST]

#### [Rotate response codes 1 and 3]

Spend what is needed to <b>reduce</b> the time customers are without power	1
Spend what is needed to maintain the current length of time customers are without power	2
Accept longer time without power in order to help minimize customer costs from rising	3
Don't Know ( <b>DNR</b> )	98
Refused ( <b>DNR</b> )	99

### E. System Challenges & Priorities

#### **System Renewal Question**

E18. [PREAMBLE to E19] As significant amount of PowerStream's electrical infrastructure was built in the 1960s and 70s, and is still in-service today. While PowerStream believes it has done its best to prolong the life of these assets, today many of these assets are now approaching the end of their useful life and are beginning to pose a threat to system reliability.

As part of its investment plan, PowerStream is proposing a significant infrastructure renewal program. The estimated cost of this system renewal program is **<u>\$258 million</u>** over the next 5 years.

Although this plan will allow PowerStream to make, what independent studies suggest are, the necessary investments to maintain system reliability, **<u>it will have an impact on customer bills</u>**.

#### E19. Which of the following statements best represents your point of view? [Read and Rotate statements 1 and 2]

Some customers have said ...

PowerStream should invest what it takes to replace the system's aging infrastructure to maintain system reliability; even if that increases my monthly electricity bill by a few dollars over the next few years.

1

Others have said ...

PowerStream should lower its estimated investment in renewing the system's aging infrastructure to lessen the impact of any bill increase; even if that means more or longer power outages.

	2
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

E20. The investments discussed earlier are focused on day-to-day reliability. There are additional investments that could help "harden" the electrical system and speed up power restoration during **rare weather events that have an unusually large impact on the system** – *such as tornados or ice storms*. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average residential customer pays \$27 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather? \$\_\_\_\_\_

#### **System Service Questions**

[PREAMBLE TO E22] New technology can have many impacts on electricity distribution systems:

- New computer systems and GPS systems provide pinpointed information about outages to both system controllers and customer in real time.
- Remote monitors and switches allow power to be restored to many customers much more quickly than in the past.

While there are benefits from new technology, there are also costs.

E22. When it comes to investing in new technology, which of the following points of view is closest to your own?

#### [Read and Rotate statements 1 and 2]

Some customers have said...

Investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream. 1

Others have said ...

I think the benefits of new technology are important and investments in new technology should be a priority for PowerStream. 2

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### **General Plant Questions**

E23. PowerStream is not just the local electricity distribution system itself, but a company that operates the system. As a company, PowerStream needs buildings to house its staff, vehicles and tools to service the power lines and IT systems to manage the electrical system and customer information.

Again, customers have made number of statements about this sort of investment. Which of the following statements best represents your point of view? [Read and Rotate statements 1 and 2]

Some customers have said ...

PowerStream should find ways to make do with the buildings, equipment and IT systems it already has.

Others have said ...

While PowerStream should be wise with its spending, it is important that its staff have the equipment and tools they need to manage the system efficiently and reliably. 2

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### F. Assessment of Plan

#### PREAMBLE

To maintain the reliability of the local electricity system, PowerStream's proposed 5 year plan will spend an estimated **\$641 million** on new capital investments. This includes ...

- \$258 million to replace aging infrastructure;
- **\$150 million** for new technologies to make the system more efficient, reliable, safe and to expand system capacity to accommodate future growth;
- \$147 million to maintain metering and connect new customers to the electricity system;
- **\$86 million** to invest in tools, computers and software systems, vehicles and facilities needed to manage the electricity system;

To fund this plan, PowerStream is proposing the **average residential customers' rate increase by \$2.14 per month** on the distribution portion of their bill over the next five years. So, by 2020, the average residential household will be paying an **estimated \$10.72** <u>more per month</u> on the distribution portion of its electricity bill.

F25. Considering the cost of PowerStream's plan, would you say [**READ LIST**] ... Rotate response codes "1 "and "3"

The rate increase is reasonable and I support it	1
I don't like it, but I think the rate increase is necessary	2
The rate increase is unreasonable and I oppose it	3
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### Ask only if F25 = 1, 2 or 3

F26. And why do you say that? [**OPEN**]

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

#### **G.** Segmentation

These last few questions are for statistical purposes only and we remind you again that all of your responses are completely confidential.

G27. Please tell me if you strongly agree, somewhat agree, somewhat disagree or strongly disagree with the following statement:

The cost of my electricity bill has a major impact on my finances and requires I do without some other important priorities.

Strongly agree	1
Somewhat agree	2
Neither agree nor disagree (DNR)	3
Somewhat disagree	4
Strongly disagree	5
Don't Know ( <b>DNR</b> )	98
Refused (DNR)	99

#### G28. In which year were you born? [Enter YEAR]

#### INTERVIEWER NOTE: if REFUSE; ask "AGE".

AGE: Can you tell me what age category do you fall into? [READ LIST]

Less than 18	0
18-25	1
25-34	2
35-44	3
45-54	4
55-64	5
65 years or older	6
Refused (DNR)	99

#### G29. Do you own or rent your home?

Own	1
Rent	2
Refused (DNR)	99

#### G30. How would you describe your primary residence? Would you say you live in ... [READ LIST]

A fully-detached home;	1
A semi-detached home;	2
An apartment or condo building <u>less than 5 stories</u> ; or	3
An apartment or condo building <u>5 stories or higher</u> ?	4
Refused (DNR)	99

G31. Counting yourself, how many people live in your household?

1 person	1
Enter number of people	27
8 or more	8
Refused (DNR)	99

### THANK and END SURVEY

Thank you very much for taking the time to complete this survey.

## **General Service Survey Instrument**

#### Introduction

#### INTRO

**INTRO**. Hello, my name is \_\_\_\_\_\_ and I'm calling from **Innovative Research Group**, a national public opinion research firm. We have been hired by **PowerStream** to help them better understand the needs and preferences of its customers.

Can I please speak to the person who is in-charge of managing the electricity bill at your organization?

5) Maybe < <b>may I ask who is calling?</b> >	[skip to GATE]
4) No < <b>busy</b> > "When is a good time to callback?"	[record callback time
3) No <not contact="" person="" right="" the=""></not>	[GO to "NEW"]
2) Yes <transferred contact="" to=""></transferred>	[skip to Q1]
1) Yes, speaking <contact line="" on="" the=""></contact>	[skip to Q1]

NEW. And ... can I have their ... First Name \_\_\_\_\_ Last Name \_\_\_\_\_ Title/Position \_\_\_\_\_

Phone Number \_\_\_\_\_

#### ASK to be transferred ...

- if transferred  $\rightarrow$  go to A1
- if not transferred → Thank & Add to Callback List

**GATE**. My name is \_\_\_\_\_\_ and I'm calling on behalf of your local electricity distributor, **PowerStream**.

**INTERVIEWER NOTE: If gatekeeper asks the purpose of call**  $\rightarrow$  I'd like to ask the person in-charge of managing the electricity bill at your organization a few questions concerning a **PowerStream** customer consultation.

1) Yes <transferred contact="" to=""></transferred>		[skip to A1]
2) No < <b>not available</b> >	"When is a good time to callback?	[record callback time and GO to "NEW"]
3) No <not in="" interested="" talking<="" td=""><td>3&gt;</td><td>[Thank &amp; Terminate]</td></not>	3>	[Thank & Terminate]

#### **A2 QUAL PREAMBLE:**

Innovative Research Group is a national public opinion research firm. We have been commissioned by **PowerStream** to help them better understand the needs and preferences of customers who are responsible for paying their businesses' electricity bill.

**PowerStream** – which distributes electricity to homes and businesses in your area – is preparing to submit its 5-year investment plan to the Ontario Energy Board for regulatory review. Since this plan will impact your bill, PowerStream wants to hear from you, so your views can help shape its plan.

A2. Would you mind if I had ten minutes of your time to ask you some questions? All your responses will be kept strictly confidential.

Yes	1	[continue]
No – NOT PRIMARY BILL PAYER	2	[go to TRANSFER-1]
No – BAD TIME	3	ARRANGE CALLBACK
No – HARD REFUSAL	4	[Terminate]

#### MONIT

This call may be monitored or audio taped for quality control and evaluation purposes. PRESS TO CONTINUE 1

A3. Just to confirm, does your organization receive an electricity bill from PowerStream?

YES	1 [continue]
NO	2 [Terminate]
DK (volunteered)	98 [Terminate]

A4. As part of your job, are you in-charge of <u>managing</u> or <u>overseeing</u> your organization's electricity bill?

Yes	1	[Continue to B5]
No	2	CAN I SPEAK TO THE PERSON WHO MANAGES YOUR
		ORGANIZATION'S ELECTRICITY BILL?[Return to NEW]
DK	3	CAN I SPEAK TO THE PERSON WHO MANAGES YOUR
		ORGANIZATION'S ELECTRICITY BILL?
		[Return to NEW]

#### **TRANSFER-1**

Can I speak with the person at your organization who usually pays the electricity bill?

Yes1[BACK TO INTRO]No - NOT AVAILABLE/BAD TIME - (ARRANGE CALLBACK)2[ARRANGE CALLBACK]No - HARD REFUSAL3[Terminate]Don't know (DNR)98 [Terminate]

#### **B. General Satisfaction**

We need to prime respondents to start thinking about electricity and the part of the system that PowerStream operates.

#### PREAMBLE-1

To start, I'd like to ask you a few questions about the electricity system ...

As you may know, Ontario's electricity system has three key components: **generation, transmission** and **distribution**.

- Generating stations convert various forms of energy into electric power;
- **Transmission lines** connect the power produced at generating stations to where it is needed across the province; and
- Distribution lines carry electricity to the homes and businesses in our communities.

Today we're going to talk about your **local distribution system** which is maintained and operated by **PowerStream**.

How familiar are you with the local electricity distribution system? Would you say ... [READ LIST]

Very familiar	1
Somewhat familiar	2
Not very familiar	3
Not familiar at all	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

B6. Generally speaking, how satisfied are your organization with the job **PowerStream** is doing running your local distribution system? Would you say ... [**READ LIST**]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

B7. Is there anything in particular **PowerStream** can do to improve its service to your organization? [**OPEN**]

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

B8. **PowerStream** is 100% owned by the cities of Vaughan (*pronounced as "Von"*), Markham and Barrie and is overseen by a board of directors. This board is made up of members of the respective city councils and the community and is responsible for overseeing the operations and management of the utility.

Before this survey, did you know that PowerStream was owned by the cities of Vaughan, Markham and Barrie? [DO NOT READ LIST]

Yes	1
No	2
Don't know ( <b>DNR</b> )	98
Refused ( <b>DNR</b> )	99

## C. Bill Knowledge & Impact

I'd now like to talk with you about your electricity bill ...

C9. While some customers pay more and other pay less, the average General Service customer pays about \$305 a month for electricity of which \$61 or approximately 20% goes to PowerStream. The rest of the bill goes to power generation companies, transmission companies, the provincial government and regulatory agencies.

Before this survey, how familiar were you with the amount of your electricity bill that went to **PowerStream**? Would you say ... [**READ LIST**]

Very familiar	1
Somewhat familiar	2
Not very familiar	3
Not familiar	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

## **D. System Reliability**

These questions are about priming the respondent to think about their experience with system reliability and separate adverse weather from failing equipment.

D10. In the past year or so, PowerStream customers experienced unusually extreme weather – microburst and tornados this past summer and an ice storm in December 2013. These major weather events caused power outages for many PowerStream customers.

As far as you know, in the past year, did your organization experience any power outages due to extreme weather events such as the ice storm, microbursts or tornados?

Yes	1
No	2
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

D11. Whether your organization was directly affected or not, how satisfied are you with the way PowerStream responded to these events? Would you say ... [READ LIST]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

D12. Is there is anything in particular that PowerStream can do to improve its service to your organization during these extreme weather events? [**OPEN**]

## [Ask all respondents]

D13. <u>Not</u> including power outages caused by extreme weather events, has your organization experienced any power outages **in the past 12 months**, and if so, approximately how many? [**DO NOT READ LIST**]

No outages	0	[SKIP to D16]
1 outage	1	[CONTINUE]
2 outages	2	[CONTINUE]
3 outages	3	[CONTINUE]
4 outages	4	[CONTINUE]
5 outages	5	[CONTINUE]
6 outages	6	[CONTINUE]
7 outages	7	[CONTINUE]
8 or more outages	8	[CONTINUE]
Don't know ( <b>DNR</b> )	98	[SKIP to D16]
Refused (DNR)	99	[SKIP to D16]

D14. And how satisfied is your organization with the way PowerStream responded to the outage? Would you say ... [READ LIST]

Very satisfied	1
Somewhat satisfied	2
Somewhat dissatisfied	3
Very dissatisfied	4
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

- D15. Is there is anything in particular that PowerStream could do to improve its service to your organization during your most recent power outages? [**OPEN**]
- D16. In your view, how do you think **PowerStream** should address the <u>number</u> of customer power outages? Would you say ... [**READ LIST**]

## [Rotate response codes 1 and 3]

Spend what is needed to reduce the number of power outages	1
Spend what is needed to maintain the current level of outages	2
Accept more power outages in order to help keep customer costs from rising	3
Don't Know ( <b>DNR</b> )	98
Refused (DNR)	99

D17. The average **PowerStream** customer is without power for about **100 minutes per year**.

In your view, how do you think PowerStream should address the <u>length of time</u> customers are without power? Would you say ... [READ LIST]

## [Rotate response codes 1 and 3]

Spend what is needed to reduce the time customers are without power	1
Spend what is needed to maintain the current length of time customers are without power	2
Accept longer time without power in order to help minimize customer costs from rising	3
Don't Know ( <b>DNR</b> )	98
Refused (DNR)	99

## E. System Challenges & Priorities

## **System Renewal Question**

[PREAMBLE to E19] A significant amount of PowerStream's electrical infrastructure was built in the 1960s and 70s, and is still in-service today. While PowerStream believes it has done its best to prolong the life of these assets, today many of these assets are now approaching the end of their useful life and are beginning to pose a threat to system reliability.

As part of its investment plan, PowerStream is proposing a significant infrastructure renewal program. The estimated cost of this system renewal program is \$258 million over the next 5 years.

Although this plan will allow PowerStream to make, what independent studies suggest are, the necessary investments to maintain system reliability, **it will have an impact on customer bills**.

E19. Which of the following statements best represents your point of view? [Read and Rotate statements 1 and 2] Some customers have said ...

PowerStream should invest what it takes to replace the system's aging infrastructure to maintain system reliability; even if that increases my monthly electricity bill by a few dollars over the next few years.

1

Others have said ... PowerStream should lower its estimated investment in renewing the system's aging infrastructure to lessen the impact of any bill increase; even if that means more or longer power outages.

	2
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

E20. The investments discussed earlier are focused on day-to-day reliability. There are additional investments that could help "harden" the electrical system and speed up power restoration during **rare weather events that have an unusually large impact on the system** – *such as tornados or ice storms*. There is no practical limit to potential ways of making the system more resilient in a major event, it is fundamentally a question of money.

Currently, the average General Service customers pays \$61 a month to PowerStream to operate and maintain the local distribution system. How much more are you willing to pay each month for investments that would help the system better withstand major events such as extreme weather? \$\_\_\_\_\_

## **System Service Questions**

[PREAMBLE TO E22] New technology can have many impacts on electricity distribution systems:

- New computer systems and GPS systems provide pinpointed information about outages to both system controllers and customer in real time.
- Remote monitors and switches allow power to be restored to many customers much more quickly than in the past.

While there are benefits from new technology, there are also costs.

E22. When it comes to investing in new technology, which of the following points of view is closest to your own?

## [Read and Rotate statements 1 and 2]

Some customers have said...

Investments in new technologies are more a luxury than a necessity and should be a low priority for PowerStream. 1

Others have said ...

I think the benefits of new technology are important and investments in new technology should be a priority for PowerStream. 2

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

## **General Plant Questions**

E23. PowerStream is not just the local electricity distribution system itself, but a company that operates the system. As a company, PowerStream needs buildings to house its staff, vehicles and tools to service the power lines and IT systems to manage the electrical system and customer information.

Again, customers have made number of statements about this sort of investment. Which of the following statements best represents your point of view? [Read and Rotate statements 1 and 2]

Some customers have said ...

PowerStream should find ways to make do with the buildings, equipment and IT systems it already has.

Others have said ...

While PowerStream should be wise with its spending, it is important that its staff have the equipment and tools they need to manage the system efficiently and reliably. 2

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

## F. Assessment of Plan

## PREAMBLE

To maintain the reliability of the local electricity system, PowerStream's proposed 5 year plan will spend an estimated **\$641 million** on new capital investments. This includes ...

- \$258 million to replace aging infrastructure;
- **\$150 million** for new technologies to make the system more efficient, reliable, safe and to expand system capacity to accommodate future growth;
- \$147 million to maintain metering and connect new customers to the electricity system;
- **\$86 million** to invest in tools, computers and software systems, vehicles and facilities needed to manage the electricity system;

To fund this plan, PowerStream is proposing the **average General Service customers' rate increase by \$5.25 per month** on the distribution portion of their bill over the next five years. So, by 2020, the average General Service customer will be paying an **estimated \$26.24** <u>more</u> per month on the distribution portion of its electricity bill.

F25. Considering the cost of PowerStream's plan, would you say [READ LIST] ... Rotate response codes "1 "and "3"

The rate increase is reasonable and I support it	1
I don't like it, but I think the rate increase is necessary	2
The rate increase is unreasonable and I oppose it	3
Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

## Ask only if F25 = 1, 2 or 3

F26. And why do you say that? [OPEN]

Don't know ( <b>DNR</b> )	98
Refused (DNR)	99

## **G.** Segmentation

These last few questions are for statistical purposes only and we remind you again that all of your responses are completely confidential.

G27. Please tell me if you strongly agree, somewhat agree, somewhat disagree or strongly disagree with the following statement:

The cost of my electricity bill has a major impact on the bottom line of my organization and results in some important priorities and investments being put off.

Strongly agree	1
Somewhat agree	2
Neither agree nor disagree (DNR)	3
Somewhat disagree	4
Strongly disagree	5
Don't Know ( <b>DNR</b> )	98
Refused (DNR)	99

G28. Which of the following best describes the **hours of operation** of your business? Would you say ... [**READ LIST**]

We are open 24/7	1
We operate several shifts each day, but are not open 24/7	2
We operate during regular business hours only	3
We operate outside of regular business hours, but do not have shifts	4
Other (please specify):	88

G29. And, which of the following best describes **when your business operates** through the week? Would you say ... [**READ LIST**]

We operate on weekdays only	1
We operate on weekdays and weekends	2
Other (please specify):	88

## THANK and END SURVEY

Thank you very much for taking the time to complete this survey.

# **Primer Appendices:** PowerStream Distribution System Plan

**Residential Primer General Service Primer** 

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	1 of 9
Date:	February 24,2015

						COST	(000's)		ACC				
CCA			Depreciation		Opening	Additions	Disposals/	Closing	Opening		Disposals/	Closing	Net Book Value
Class	GL account	Detail Asset Class	Rate	Notes	Balance	(3)	Adjustments	Balance	Balance	Additions (3)	Adjustments	Balance	(000's)
								,					
<u>Jistribut</u> 47	ion Assets and	Streetlighting Hydro One TS - Contributed Capital	2.50%	<u> </u>	609	4,363	0	4,972	29	288	0	317	4,65
		Land	2.50%		10.968	4,363	0	4,972	29	200	0	0	4,65
n/a CEC		Land Rights	0		766	31	0	797	0	0	0	0	79
			-			188			-	197	-	388	5.92
1	1000		2.50%		6,120		0	6,308	191		0		
47		Major spare parts	0		9,184	(1,076)	0	8,108	0	0	0	0	8,10
47		Transformer Stations	2.50%	1	94,982	838	0	95,820	4,974	4,280	0	9,254	86,56
47		Distribution Stations	3.33%	1	21,527	219	0	21,746	2,051	1,162	0	3,213	18,53
47		Poles, Towers & Fixtures	2.22%		100,913	13,031	(115)	113,829	2,327	2,606	(4)	4,929	108,900
47		O/H Cond & Devices	2.50%		94,291	8,572	(187)	102,676	2,567	2,996	(10)	5,553	97,123
47		U/G Conduit	1.67%		63,374	7,572	0	70,946	1,081	1,253	0	2,334	68,61
47		U/G Cond & Devices	2.22%		185,286	30,099	(389)	214,996	5,296	5,462	(14)	10,744	204,252
47			2.92%	2	133,046	13,599	(1,665)	144,980	5,823	6,195	(101)	11,917	133,063
47		Services (OH and UG)	3.25%	2	53,933	4,219	0	58,152	4,469	3,239	0	7,708	50,444
47		Meters	5.33%	2	18,058	3,908	1,878	23,844	(777)	1,202	1,945	2,370	21,474
47		Smart Meters	6.67%		46,536	471	(84)	46,923	3,735	3,413	(14)	7,134	39,789
47	1875	Streetlighting	4.00%		1,632	320	0	1,952	54	73	0	127	1,825
		Subtotal Distribution Assets	n/a		841,225	93,471	(562)	934,134	31,820	32,366	1,802	65,988	868,146
General	Plant Assets												
1	1908	Building & Fixtures - Head office	2.00%	1	39,884	354	0	40,238	919	927	0	1,846	38,392
13	1910	Leasehold Improvements	30.00%		0	65	0	65	0	0	0	0	65
8	1915	Office Equipment	10.00%		3,654	1,223	0	4,877	460	556	0	1,016	3,861
10		Computer hardware	20.42%	2	5,100	1.752	0	6,852	1,568	1,390	0	2,958	3,894
12		Computer Software	22.78%	2	8,750	(1.556)	0	7,194	2,159	2,383	0	4,542	2.652
10	1930	Transportation	9.05%	2	9,581	1.947	0	11,528	1,165	1,396	(8)	2,553	8,975
8	1935		10.00%		(4)	7	0	3	(2)	0	0	(2)	÷1+.
8		Tools, Shop & Garage	10.00%		2.528	715	0	3.243	379	419	0	798	2.445
8		Communication Equipment	21.67%	2	1,618	257	0	1.875	398	377	ů 0	775	1.100
8			10.00%	_	0	0	0	0	000	0	0	0	1,100
47			7.78%	2	8.099	782	(7)	8,874	1,491	979	(2)	2.468	6.406
47		Other Tangible property	n/a	-	0,000	0	0	0,014	0	0,0	0	2,400	0,400
	1330	Subtotal General Plant Assets	n/a		79.210	5.546	(7)	84,749	8.537	8.427	(10)	16.954	67.795
Other Ca	nital	Subtotal General Flant Assets	11/a		79,210	3,540	(7)	04,743	0,007	0,427	(10)	10,954	07,795
47		Prop. Under Capital Lease-Addiscott	4.00%		17.549	0	0	17.549	731	733	0	1,464	16.085
47		Non-utility property owned	4.00%		0	0	0	0	0	0	0	1,404	10,000
47	2013	Subtotal Other Capital Assets	4.00%		17.549	0	0	17.549	731	733	0	1.464	16.085
		Total Assets Before Contributed	li/d		17,549	0	0	17,349	731	755	0	1,404	10,005
		Capital	-		007.004	00.017	(500)	1,036,432	44.000	44 500	1 700	04 400	952,026
47	1995/1996	Capital Contributed Capital	n/a		937,984 (244,673)	99,017 (37,923)	(569) 885	(281,711)	41,088 (8,805)	41,526 (8,199)	1,792 45	84,406 (16,959)	(264.752
47	1995/1996		varies		1	1- 11		( = 1 /	(-)/				
	<u> </u>	All PP& E ASSETS	n/a		693,311	61,094	316	754,721	32,282	33,327	1,837	67,447	687,274
		Less Socialized Renewable Energy Generation Investments (input as negative)											
		(5)			(493)	(604)	0	(1,097)	(22)	(50)	0	(72)	(1,025
		Less/plus: Other Non Rate-Regulated			(45)	(07)	_	(00)	07	(4.4)		00	(105
	<u> </u>	Utility Assets (4)	<u> </u>		(45)	(37)	0	(82)	37	(14)	0	23	(105
	1	Net Total PP&E Distribution Assets			692,773	60,453	316	753,542	32,297	33,263	1,837	67,398	686,144

10	Transportation
8	Stores Equipment
8	Tools, Shop & Garage

Less: Fully Allocated Depreciation		
Transportation	\$	1,396
Stores Equipment	\$	-
Tools, Shop & Garage	\$	419
less - Non- distribution	-\$	14
Net Depreciation	\$	31,498

### NOTES:

(1) This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.

(2) This is the average depreciation rate of subclass of assets within the asset group

(3) Work in progress expenditures have been removed
 (4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation Connection Rate Potection (RGCRP) is not applicable to 2012 as the Renewable generation costs were in the Deferral account and not Board approved until a later year

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	2 of 9
-	0
Date:	February 24,2015

						COS	ST (000's)		ACC	1			
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
)istributi	on Assets and S	Streetlighting											
47		Hvdro One TS - Contributed Capital	2.50%	1	4.972	0	0	4.972	317	288	0	605	4.36
/a	1805		2.3078		18.085	146	0	18.231	0		0	000	18,23
CEC		Land Rights	0		797	30	0	827	0	0	0	0	82
1		Building & Fixtures	2.50%		6.308	340	0	6.648	388	202	0	590	6.05
47		Major spare parts	0		8,108	649	0	8,757	000	0	0	000	8,75
47		Transformer Stations	2.50%	1	95,820	4,185	0	100,005	9,254	4,154	0	13,408	86,59
47		Distribution Stations	3.33%	1	21,746	1,365	0	23.111	3,213	1,154	0	4,367	18,74
47		Poles, Towers & Fixtures	2.22%		113,829	15.751	(59)	129,521	4,929	2,858	(3)	7,784	121,73
47		O/H Cond & Devices	2.50%		102,676	11,151	(74)	113,753	5,553	3,181	(6)	8,728	105,02
47		U/G Conduit	1.67%		70,946	8.070	0	79.016	2,334	1,385	0	3,719	75.29
47		U/G Cond & Devices	2.22%		214,996	31,247	(477)	245,766	10,744	6.097	(32)	16.809	228,95
47		Line Transformers	2.92%	2	144,980	9,662	(2.136)	152,506	11,917	6,476	(231)	18,162	134.34
47		Services (OH and UG)	3.25%	2	58,152	4,555	0	62,707	7,708	3,298	0	11,006	51,70
47		Meters	5.33%	2	23,844	5,015	0	28,859	2,370	1,453	0	3,823	25,03
47		Smart Meters	6.67%		46,923	1,448	0	48.371	7,134	3,453	0	10.587	37,78
47		Streetlighting	4.00%		1,952	150	0	2,102	127	88	0	215	
		Subtotal Distribution Assets	n/a		934,134	93,764	(2,746)	1,025,152	65,988	34,087	(272)	99,803	923,462
General F	Plant Assets							11 -					
1	1908	Building & Fixtures - Head office	2.00%	1	40,238	889	0	41,127	1,846	936	0	2,782	38,34
13	1910	Leasehold Improvements	30.00%		65	151	0	216	0	8	0	8	20
8		Office Equipment	10.00%		4.877	17	0	4.894	1.016	594	0	1.610	3.28
50	1920	Computer hardware	20.42%	2	6,852	2,138	0	8,990	2,958	1,194	0	4,152	4,83
12	1611	Computer Software	22.78%	2	7,194	8,097	0	15,291	4,542	2,821	0	7,363	7,92
10	1930	Transportation	9.05%	2	11,528	1,897	(10)	13,415	2,553	1,596	(10)	4,139	9,27
8	1935	Stores Equipment	10.00%		3	0	0	3	(2)	1	0	(1)	
8	1940	Tools, Shop & Garage	10.00%		3,243	510	0	3,753	798	430	0	1,228	2,52
8	1955	Communication Equipment	21.67%	2	1,875	241	0	2,116	775	411	0	1,186	93
8	1960	Miscellaneous equipment	10.00%		0	0	0	0	0	0	0	0	
47	1980	System Supervisory Equip	7.78%	2	8,874	1,310	(5)	10,179	2,468	984	(4)	3,448	6,73
47	1990	Other Tangible property	n/a		0	0	0	0	0	0	0	0	
		Subtotal General Plant Assets	n/a		84,749	15,250	(15)	99,984	16,954	8,975	(14)	25,915	74,06
Other Cap	pital												
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0	0	17,549	1,464	731	0	2,195	15,35
-		Subtotal Other Capital Assets	n/a		17,549	0	0	17,549	1,464	731	0	2,195	15,35
		Total Assets Before Contributed											
		Capital	n/a		1,036,432	109,014	(2,761)	1,142,685	84,406	43,793	(286)	127,913	1,014,77
47	1995/1996	Contributed Capital	varies		(281,711)	(24,442)	1,117	(305,036)	(16,959)	(8,873)	91	(25,741)	(279,295
		NET DISTRIBUTION ASSETS	n/a		754,721	84,572	(1,644)	837,649	67,447	34,920	(195)	102,172	735,47
		Less Socialized Renewable Energy											
		Generation Investments (input as negative)			(1.007)	(7.40)		(1.007)	(70)	(70)	0	(4.45)	(4.000
		(5)			(1,097)	(740)	0	(1,837)	(72)	(73)	0	(145)	(1,692
		Less Other Non Rate-Regulated Utility Assets (input as negative) (4)			(82)	194	0	112	23	(51)	0	(28)	14
		Total PP&E			753.542	84.026	(1.644)	835.924	67.398	34,796	(195)	101.999	733.926
			1	1	700,042	04,020				5-,790	(195)	101,333	100,920
10		Transportation	1					Less: Fully Allocate Transportation	d Depreciation	\$ 1,596			
8		Stores Equipment	1					Stores Equipment		\$ 1			
0		Tools, Shop & Garage						Tools, Shop & Ga		\$ 430			
0								I UUIS, SHUP & Ga	auc	3 430			
8		roolo, onop a carage	1					ess - Non- distrib		-\$ 51			

NOTES:

(1) This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.

(2) This is the average depreciation rate of subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") capital costs for 2010 and 2011 are included in the closing 2013 fixed assets balances above in the amount of \$524k. In 2013 received Board approval for the renewable generation connection rate protection amount of \$493k. This represents 94% of the total RGEN costs to be recovered from all provincial ratepayers through the IESO and not directly from PowerStream ratepayers. Accordingly this amount is removed from the fixed assets along with the associated depreciation as they are not included in revenue requirement. The residual 6%, otherwise known as the RGEN direct benefit, remain in rate base and are recovered from PowerStream rate payers as part of this Custom IR rate application

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	3 of 9
Date:	February 24,2015

			COST (000's)							ACCUMULATIVE DEPRECIATION (000's)				
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's	
istributi	on Assets								-					
47	1610	Hydro One TS - Contributed Capital	2.50%		4.972	0	(19)	4.953	605	288	0	893	4.0	
/a		Land	0		18.231	4.191	0	22,422	0	0	0	0	22.4	
EC		Land Rights	0		827	46	0	873	0	0	0	0	8	
1	1808	Building & Fixtures	2.50%		6,648	70	0	6,718	590	211	0	801	5,9	
47	1810	Major spare parts	0		8,757	1,121	0	9,878	0	0	0	0	9,87	
47	1815	Transformer Stations	2.50%	1	100,005	3,280	0	103,285	13,408	4,004	14	17,426	85,8	
47	1820	Distribution Stations	3.33%	1	23,111	1,205	0	24,316	4,367	1,391	0	5,758	18,5	
47	1830	Poles, Towers & Fixtures	2.22%		129,521	14,911	(154)	144,278	7,784	3,255	(14)	11,025	133,2	
47	1835	O/H Cond & Devices	2.50%		113,753	10,628	(131)	124,250	8,728	3,505	(9)	12,224	112,0	
47	1840	U/G Conduit	1.67%		79,016	18,430	0	97,446	3,719	1,583	0	5,302	92,14	
47	1845	U/G Cond & Devices	2.22%		245,766	34,636	(1,292)	279,110	16,809	7,082	(93)	23,798	255,3	
47	1850	Line Transformers	2.92%	2	152,506	12,218	(1,480)	163,244	18,162	6,673	(215)	24,620	138,62	
47	1855	Services (OH and UG)	3.25%	2	62,707	5,444	0	68,151	11,006	3,394	0	14,400	53,75	
47	1860	Meters	5.33%	2	28,859	2,633	(1,605)	29,887	3,823	1,735	(120)	5,438	24,44	
47	1862	Smart Meters	6.67%		48,371	1,463	0	49,834	10,587	3,559	0	14,146	35,68	
47	1875	Streetlighting	4.00%		2,102	22	0	2,124	215	90	0	305	1,81	
		Subtotal Distribution Assets	n/a		1,025,152	110,298	(4,681)	1,130,769	99,803	36,770	(437)	136,136	994,63	
eneral F	Plant Assets			-										
1	1908	Building & Fixtures - Head office	2.00%	1	41,127	2,425	0	43,552	2,782	962	0	3,744	39,8	
13		Leasehold Improvements	30.00%		216	(25)	0	191	8	17	0	25	1	
8	1915	Office Equipment	10.00%		4,894	44	0	4,938	1,610	594	0	2,204	2,73	
50		Computer hardware	20.42%	2	8,990	2,337	0	11,327	4,152	1,765	3	5,920	5,40	
12		Computer Software	22.78%	2	15,291	1,508	0	16,799	7,363	3,045	12	10,420	6,3	
10		Transportation	9.05%	2	13,415	1,008	(120)	14,303	4,139	1,757	(91)	5,805	8,49	
8		Stores Equipment	10.00%		3	142	0	145	(1)	5	1	5	14	
8		Tools, Shop & Garage	10.00%		3,753	564	0	4,317	1,228	450	0	1,678	2,6	
8	1955	Communication Equipment	21.67%	2	2,116	119	0	2,235	1,186	361	0	1,547	68	
8		Miscellaneous equipment	10.00%		0	0	0	0	0	0	0	0		
47		System Supervisory Equip	7.78%	2	10,179	1,125	0	11,304	3,448	1,016	15	4,479	6,82	
47	1990	Other Tangible property	n/a		0	0	0	0	0	0	0	0		
		Subtotal General Plant Assets	n/a		99,984	9,247	(120)	109,111	25,915	9,972	(60)	35,827	73,28	
ther Cap		-	-						-				·	
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0		17,549	2,195	731	0	2,926	14,62	
		Subtotal Other Capital Assets	n/a		17,549	0	0	17,549	2,195	731	0	2,926	14,62	
		Total Assets Before Contributed												
		Capital	n/a		1,142,685	119,545	(4,801)	1,257,429	127,913	47,473	(497)	174,889	1,082,54	
47	1995/1996	Contributed Capital	varies		(305,036)	(22,608)	798	(326,846)	(25,741)	(9,413)	90	(35,064)	(291,78	
		NET DISTRIBUTION ASSETS	n/a		837,649	96,937	(4,003)	930,583	102,172	38,060	(407)	139,825	790,75	
		Less Socialized Renewable Energy												
		Generation Investments (input as negative)			(1,837)	(1,054)	0	(2,891)	(145)	(105)	0	(250)	(2,64	
		Less Other Non Rate-Regulated Utility			(1,007)	(1,004)	Ŭ	(2,001)	(140)	(100)	Ŭ	(200)	(2,04	
		Assets (input as negative) (4)			112	60	0	172	(28)	(45)	0	(73)	24	
		Total PP&E			835,924	95,943	(4,003)	927,864	101,999	37,910	(407)	139,502	788,35	
							1	Less: Fully Allocate	d Depreciation					
10		Transportation						Transportation		\$ 1,757				
8		Stores Equipment						Stores Equipment		\$ 5				
		Tools, Shop & Garage						Tools, Shop & Ga		\$ 450				
8		· · · · · · · · · · · · · · · · · · ·					1	ess - Non- distribu	ution	-\$ 45				

(1) This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.

(2) This is the average depreciation rate of subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") capital costs for 2012 and 2013 are included in the closing 2014 fixed assets balances above. In 2014 received Board approval for the renewable generation connection rate protection("RGCRP") amount of \$1,344k. This represents 94% of the total RGEN costs to be recovered from all provincial ratepayers through the IESO and not directly from PowerStream ratepayers. Accordingly the RGCRP amount is removed from the fixed assets and depreciation as they are not included in revenue requirement. The residual 6%, otherwise known as the RGEN direct benefit, remain in rate base and therefore are recovered from PowerStream rate payers as part of this Custom IR rate application

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	4 of 9
Date:	February 24,2015

Class         O         Adjustment         Balance         Adjustment							COS	T (000's)		1 ſ	ACC	UMULATIVE DEF	RECIATION (00	0's)	
17     1610 http://bit     1610 http://bit     1181     377       00     1680 lad     0     2242     1125     0     2344     0     0     0     0     0     0     0     0     0     0     0       220     1612 land Rents     0     2242     1125     0     2344     0 </th <th></th> <th>GL account</th> <th>Detail Asset Class</th> <th>•</th> <th>Notes</th> <th></th> <th></th> <th></th> <th>•</th> <th></th> <th></th> <th>Additions (3)</th> <th></th> <th>•</th> <th>Net Book Value (000's</th>		GL account	Detail Asset Class	•	Notes				•			Additions (3)		•	Net Book Value (000's
whi         1980         Lond         0         2,2,22         1,12         0         2,5,07         0         0         0         0         0         0         2,5,5           cir         1000         Balling & Findure         2,000         6,710         21         0         6,501         0 </td <td>Distributi</td> <td>on Assets</td> <td></td>	Distributi	on Assets													
EEC         1412         Lond Squits         0         673         33         0         998         0	47	1610	Hydro One TS - Contributed Capital	2.50%		4,953	0	0	4,953		893	288	0	1,181	3,772
1       1000       Building & Frances       2.50%       6.718       271       0       6.898       601       275       0       1.016       5.93         47       1510       Insight of Marce spars       2.50%       1       1132.25%       0       0.898       0.0       0       0.0       0       0.0       0       0.0       0.0       0       0       0.0       0.0       0       0.0       0.0       0       0.0	n/a	1805	Land	0		22,422		0			0		0	0	23,547
nt     nt<	CEC										-			-	906
47     1815     Transformer Stations     2.506     1     103.286     2.988     0     106.233     17.426     4.005     0     2.141     4.47       47     1815     Transformer Stations     3.338     1     4.238     4.071     0     28.327     5.758     1.444     0     7.2578     1.444     0     7.2578     1.444     0     7.2578     1.444     0     1.269	1			2.50%		-, -		-				-			5,913
arr       isso				0							-			Ŷ	9,878
47         1830         Polies, Towers & Fixtures         2.22%         144.276         165.800         167.71         11.025         3.605         (14)         14.616         146.16           47         1830         Dirto Cod & Breviose         2.50%         174.226         1.28.27         (15)         177.98         0.0         16.0571         5.308         1.798         0.0         7.01         97.98           47         1840         UG Cond & Breviose         2.27.8         2         1.01         7.757         0         105.011         2.5308         2         2.27.8         2         2.01         10.81         2.14         2.0         0.13         10.81         2.14         2.0         0.13         10.81         2.14         2.0         2.14         2.0         2.14         2.0         2.14         2.0         2.14         2.0         2.14         2.0         2.12         2.0         2.12         2.0         2.12         2.0         2.12         2.0         2.12         2.0         2.12         2.0         2.12         2.0         2.12         1.0         0.0         0.0         0.0         1.0         1.0         1.0         1.0         1.0         1.0         1.0 <th1< td=""><td></td><td></td><td></td><td></td><td>1</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>84,762</td></th1<>					1										84,762
47       1438 [OH Cond & Devices       2.26%       112.426       12.827       (130)       136.977       17.224       3.799       (100)       16.013       120.06         47       1446 [UIC Cond & Devices       2.278       2.773       (10)       17.284       3.799       (100)       150.01       8.797         47       1486 [UIC Cond & Devices       2.278       2.773       (10)       17.895       (433)       316.622       2.788       6.659       (212)       31.775       284.82         47       1485 [Device (M and LG)       3.251       2       68.151       3.663       (0)       17.845       14.460       3.467       (3)       17.845       14.460       3.467       (3)       17.845       14.460       3.467       (3)       17.845       14.460       3.467       (3)       17.845       14.460       3.467       (3)       1.77       3.744       1.446       1.77       3.744       1.783       3.74       1.00       4.783       1.77         5       3.900       1.97.89       97.70       3.74       1.72       3.74       1.224       3.79       1.73         6       1.900       1.97.89       97.70       3.741       1.72.726       1.83.89					1										
47       1460 [UC Condit       1.67%       97.446       7.573       0       105.019       5.302       1.799       0       7.101       97.91         47       1485 [UC Condit       2.22%       2.27110       37.686       (433)       31.642       2.2788       8.099       (92)       31.755       248.61         47       1485 [Ur Condit       1490       5.337       2       85.151       35.65       0       0.71.641       14.440       3.467       0       7.768       248.151         47       1480 [Meter       6.538       2       2.857       4.012       (641)       3.328       5.458       1.044       (330)       7.762       28.151         47       1080 [Meter       6.077       4.8324       1.18       0       0.1019       1.13.53       3.648       0       0       1.763       3.264       0       1.763       3.649       0       17.438       1.024.34         660       1010       10.3078       99.798       (3.271)       1.227.285       136.138       93.989       (661)       17.438       1.024.34         6710       1080       10.00%       4.3352       3.761       0       4.7313       3.744       1.024															
47     1145     UG Cond & Devices     2.22%     273,110     37,665     (433)     316,642     23,786     6,693     (92)     31,765     284,847       47     11655     Services (OH and UG)     3.20%     2     68,151     3.653     0     71,884     14,400     3.467     0     17,867     553,84       47     11680     Maters     6.33%     2     2.8817     41,112     (681)     3.154,84     5,438     1,944     0     0     17,867     553,85       47     11680     Interm Maters     6.07%     49,544     1,186     0     1,019     1,41,455     3.644     0     1,7947     353,747       47     11800     Darkt Maters     0.07%     1     45,527     3,71     0     47,71     10,24     0     4,768     42,527       51     1010     Lasehold Improvements     30,00%     101     0     191     25     3     0     2,206     1,4552     3,71     0     4,7313     3,744     1,024     0     4,768     4,252       31     1010     Dashod Improvements     30,00%     114,323     2,702     0     13,368     5,603     1,944     0     7,971     6,44       3															
47         1850 Lene Transformers         2.92%         2         163.244         7.463         (1)(2)(1)         198.806         24.620         6.936         (215)         31.341         197.44           47         1855 Services (D1 and U5)         3.25%         2         6.8151         3.553         0         71.804         14.400         3.467         0         17.787         5.53           47         1860 Meters         6.67%         4.40%         2.124         2         0         2.128         305         91         0         388         1,77           47         1860 Meters         1001 Building & Futures - Head office         2.00%         1         4.352         3.761         0         2.728         136.136         3.040         0         4.788         4.27           1001 Disashed Intravenents         20.00%         1         4.352         3.761         0         4.733         3.744         1,044         0         4.788         4.255           50         1002 Computer foruter andware         20.24%         2         1.6704         4.255         1.333         5.420         1.433         2.263         0         1.538         5.920         1.441         1.774         3.224 <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>															
47       1685       Services (DH and UG)       3.28%       2       66,151       3.683       0       77,1004       14,400       3.467       0       17,867       58.88         47       1680       Meters       6.67%       49.884       1,186       0       67.103       14,146       3.3,042       0       17,747       33.228         47       1380       Status Distribution Assets       1/13       0       2.124       2       0       2.126       136,138       3.9,601       06101       17,458       1.022         50       101       Basebpic Instrumentise       2.00%       1       131       2.4       1.00       3.471       1.024       0       2.498       0       47.313       0       4.788       4.788       4.788       0       1.111       1.024       0       4.788       4.924       4.924       4.925					2										
47         1860         Meters         5.33%         2         29.887         4.012         (661)         3.238         5.438         1.044         (330)         7.052         26.11           47         1860         Start Meters         6.67%         44.834         1.185         0         51.019         14.146         3.048         0         1.724         3.32           47         1875         Streeting Intra- Streeting Intra- Intr															
47         1880         Bmart Meters         6.67%         49.834         1,185         0         51,019         14,146         3,648         0         17,734         33,22           47         1875         Strestelphing         Auxos         1,130,769         99.708         (3,212)         1,227,265         138,138         39,380         0         17,743         33,22           1998         Building & Fixtures         Head office         2,00%         1         43,252         3,761         0         17,313         3,744         1,024         0         4,768         42,56           1         1998         Building & Fixtures         Head office         2,00%         1         43,026         0         1,7134         3,744         1,024         0         4,768         42,56           50         1990         Conceptor         1,030,00%         191         0         0         191         0.25         3         0         2,264         0         7,569         44,36           1910         Computer Sottware         2,278%         2         16,774         44,56         10,470         5,354         0         15,774         45,66           101         100,00%         44,363 <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td><math>\vdash</math></td> <td></td> <td></td> <td></td> <td></td> <td>26,186</td>									1	$\vdash$					26,186
47         1975         Eventshing         4.00%         2.124         2         0         2.126         305         91         0         396         1.77           Subtoal Distribution & Extures - Head office         2.00%         1         435.52         336.138         33.309         (661)         174.435.1         1.022.49         1.35.138         33.30.90         (671)         1.77           General Distribution & Extures - Head office         2.00%         1         43.552         3.761         0         47.313         3.744         1.024         0         4.768         42.55           1         1910         0         0         1.911         0.055         2.204         506         0         2.208         2.41         4.002         50.35         2.204         506         0         2.208         2.41         4.002         50.35         0         2.204         50.66         0         2.206         2.21         1.202.44         0.00         7.75         4.102.44         4.06         1.343         5.920         1.949         0         7.75         4.12         1.137.76         4.733         0         2.2176         2.813         1.201.44         4.266         1.410         1.371.44         1.427.					-					H					33,225
Subtorial Distribution Assets         N/a         1,130,769         99,708         (3,212)         1,227,265         136,136         39,360         (661)         174,835         1,082,435           General Pient Assets         1         1908         Building A Fixtures         2,00%         1         43,552         3,761         0         47,313         3,744         1,024         0         4,768         42,254           8         1915         Office Equipment         10,00%         4,338         97         0         5,035         2,204         596         0         2,800         2,821           10         1915         Office Equipment         10,00%         4,338         97         0         5,035         2,204         596         0         2,800         2,800         2,820         1,430         0         7,698         5,484           10         1930         Timssoriation         6,05%         2         16,799         47,635         0         6,435         10,440         5,554         0         1,410         0         7,619         8,494           10         1930         Timssoriation         6,05%         2         16,709         4,755         1,676         4,771         4,763 <td></td> <td>1 -</td> <td>1.730</td>														1 -	1.730
General Plant Assets         Control         Contro         Control <thcontrol< th=""></thcontrol<>					1										1,052,430
13       1910       0       191       0       191       25       3       0       28       11         8       1915       Office Equipment       10.00%       4.938       97       0       5.035       2.204       596       0       2.800       2.235       50       1920       Computer hardware       20.42%       2       11.327       2.036       0       13.383       5.920       1.949       0       7.869       5.44         10       1930       Transportation       9.05%       2       14.799       47.637       0       64.436       10.420       5.354       0       14.568       5.805       1.814       0       7.619       8.48         8       1940       Todes, Shop & Garage       10.00%       4.4317       5.58       0       4.875       1.678       473       0       2.1547       2.778       4       2.226       3.64       0 <td>General F</td> <td>Plant Assets</td> <td></td> <td></td> <td></td> <td>, ,</td> <td></td> <td></td> <td>, ,</td> <td></td> <td></td> <td></td> <td></td> <td>,</td> <td>1</td>	General F	Plant Assets				, ,			, ,					,	1
8         1915         Office Equipment         10.00%         4.938         97         0         5.035         2.204         596         0         2.800         2.23           50         1320         Computer Software         22.42%         2         1.327         2.036         0         1.3363         5.202         1.949         0         7.868         5.44           12         1611         Computer Software         22.42%         2         1.797         4.436         10.420         5.354         0         15.774         448.66           8         1930         Transportation         9.05%         2.14.303         2.263         0         16.566         5.005         1.814         0         7.619         8.9           8         1950         Communication Equipment         10.00%         4.317         558         0         4.875         1.677         4.73         0         2.151         2.70           8         1950         Microstrov Equip         7.78%         2         1.304         1.301         0         12.055         4.472         1.032         0         5.511         7.05           47         1980         Netbotal General Plant Assets         10a	1	1908	Building & Fixtures - Head office	2.00%	1	43,552	3,761	0	47,313		3,744	1,024	0	4,768	42,545
50         1200         Computer bardware         20.42%         2         11.327         2.036         0         13.383         5.920         1.949         0         7.869         5.45           112         111         Computer Software         22.78%         2         16.799         47.637         0         64.496         10.402         5.354         0         17.774         48.64           113         1133         Dirac Software         10.00%         1.45         553         0         6.805         5.839         0         44         6.9           8         11950         Communication Equipment         21.67%         2         2.235         364         0         2.599         1.547         250         0         1.797         48           8         11960         Mice Targlobe propent         10.00%         0 <td>13</td> <td>1910</td> <td>Leasehold Improvements</td> <td>30.00%</td> <td></td> <td></td> <td></td> <td>0</td> <td>191</td> <td></td> <td>25</td> <td></td> <td>0</td> <td>28</td> <td>163</td>	13	1910	Leasehold Improvements	30.00%				0	191		25		0	28	163
12       1611       Computer Software       22.78%       2       16.799       47.637       0       64.36       10.420       5.354       0       15.774       48.66         10       1300       Tansportation       9.0%       2       14.303       2.863       0       16.566       5.805       1.814       0       7.619       8.84         8       1394       Tools, Shop & Garage       10.00%       4.417       555       0       6.80       5       33       0       4.44       65         8       1940       Tools, Shop & Garage       10.00%       4.317       555       0       4.875       1.678       473       0       2.157%       2.725       3.64       0       2.598       1.447       250       0       1.797       68         8       1960       Miscelianeous equipment       21.67%       2       2.353       3.64       0       2.598       1.447       250       0       1.797       68       6.35       3.527       1.254       0       0       1.700       3.657       1.328       1.656       1.803       1.567       1.328       1.567       1.328       1.567       1.328       1.567       1.328       1.567		1915	Office Equipment	10.00%				0	5,035		2,204			2,800	2,235
10       1300       Transportation       9.05%       2       14,303       22,863       0       16,566       5,805       1,814       0       7,619       8,493         8       1945       Stores Equipment       10.00%       443       558       0       4,875       1,678       473       0       2,151       2,77         8       1950       Communication Equipment       10.00%       2,235       364       0       2,599       1,547       220       10,111       5,552       0       16,763       35,827       12,634       0       43,867       13,86         47       2005       Prop. Under Capital Lease-Addiscott       4,00%		1920	Computer hardware	20.42%	2				13,363		5,920			7,869	5,494
8         1935         Stores Equipment         10.00%         145         535         0         680         5         139         0         144         653           8         1940         Tools, Shop & Garage         10.00%         4.317         555         0         4.475         1.678         473         0         2.157         2.77           8         1955         Communication Equipment         21.67%         2         2.235         364         0         2.598         1.678         473         0         2.151         2.77           8         1960         Miscelineous equipment         10.00%         0															48,662
8         1940         Tools, Shop, & Garage         10.00%         4.317         558         0         4.875         1.678         473         0         2.151         2.72           8         1955         Communication Equipment         21.67%         2         2.235         364         0         2.699         1.547         250         0         1.797         80           47         1980         System Supervisory Equip         7.78%         2         11.304         1.301         0         12.605         4.479         1.032         0         5.511         7.05           47         1980         Other Tangible property         n/a         109,111         58,552         0         167,663         35,827         12,534         0         48,361         119,30           67         Subtoal Ober Capital Lesse-Addiscott         4.00%         17,549         0         0         17,549         2.926         731         0         3.667         13.88           7         1980         Contributed         n/a         1.257,429         158,260         (3.212)         1.412,477         174,889         52,625         (661)         228,83         1.185,65           6         Total Assets Before Contribu					2										8,947
8         1955         Communication Equipment         21.67%         2         2.235         364         0         2.599         1.547         250         0         1.797         86           8         1960         Miscellaneous equipment         10.00%         0 <td></td> <td>636</td>															636
8       1960       Miscelaneous equipment       10.00%       0       <	-														2,724
47         1980         System Supervisory Equip         7.78%         2         11,304         1,301         0         12,605         4,479         1,032         0         5,511         7,05           47         1990         Other Tangble property         n/a         0 <t< td=""><td></td><td></td><td></td><td></td><td>2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>1 -</td><td>802</td></t<>					2									1 -	802
47         1990         Other Tangible property         n/a         0					0	-					-			0	0
Subtotal General Plant Assets         n/a         109,111         58,552         0         167,663         35,827         12,534         0         48,361         119,30           47         2005 Prop. Under Capital Lease-Addiscott         4.00%         17,549         0         0         17,549         2,926         731         0         3,657         13,86           47         2005 Prop. Under Capital Assets         n/a         17,549         0         0         17,549         2,926         731         0         3,657         13,86           47         20,52         Gental         n/a         1,257,429         158,260         (3,212)         1,412,477         174,889         52,625         (661)         226,853         1,85,62           47         1995/1996         Contributed Capital         varies         (326,846)         (18,323)         993         (344,176)         (35,064)         (9,958)         90         (44,932)         (29,924           NET DISTRIBUTION ASSETS         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,32           Generation Investments (input as negative)         (2,891)         (76)         0					2	1			1			1		- 1 -	7,094
Other Capital           47         2005         Prop. Under Capital Lease-Addiscott         4.00%         17,549         0         0         17,549         2,926         731         0         3,657         13,86           4         Subtotal Other Capital Assets         n/a         17,549         0         0         17,549         2,926         731         0         3,657         13,86           4         Total Assets Before Contributed (Capital         n/a         1,257,429         158,260         (3,212)         1,412,477         174,689         52,625         (661)         226,853         1,185,626           47         1995/1996         Contributed Capital         varies         (326,846)         (18,323)         993         (344,176)         (35,064)         (9,958)         90         (44,932)         (299,24           4         NET DISTRIBUTION ASSETS         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,38           6         Generation Investments (nput as negative)         (2,891         (76)         0         (2,297)         (250)         (119)         0         (369)         (2,59)           (5)	47	1990												-	110 202
47       2005       Prop. Under Capital Lesse-Addiscott       4.00%       17,549       0       0       17,549       2,926       731       0       3,657       13,85         Subtoal Other Capital Assets       n/a       17,549       0       0       17,549       2,926       731       0       3,657       13,85         Capital       Subtoal Other Capital Assets       n/a       17,549       0       0       17,549       2,926       731       0       3,657       13,85         Capital       n/a       1,257,429       158,260       (3,212)       1,412,477       174,889       52,625       (661)       226,853       1,185,62         47       1995/1996       Contributed Capital       varies       (326,846)       (18,323)       993       (344,176)       (35,064)       (9,958)       90       (44,932)       (29,246       (31,91,937)       (2,19)       1,068,301       139,825       42,667       (571)       181,921       886,33         Less Other Non Rate-Regulated Utility       (17,2       (2)       0       (76)       0       (2,967)       (250)       (119)       0       (369)       (2,59)         Less Other Non Rate-Regulated Utility       172       (2)       0	Othor Ca	nital	Subiolal General Flant Assets	II/a		109,111	30,332	0	107,003		33,027	12,554	0	40,301	119,302
Subtotal Other Capital Assets         n/a         17,549         0         0         17,549         2,926         731         0         3,657         13,89           Total Assets Before Contributed Capital         n/a         1,257,429         158,260         (3,212)         1,412,477         174,889         52,625         (661)         226,853         1,185,62           47         1995/1996         Contributed Capital         varies         (326,846)         (18,323)         993         (344,176)         (35,064)         (9,958)         90         (44,932)         (299,24           NET DISTRIBUTION ASSETS         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,38           Generation Investments (input as negative) (5)         (2,891)         (76)         0         (2,967)         (250)         (119)         0         (369)         (2,59)           4         Less Other Non Rate-Regulated Utility Assets (input as negative)         1772         (2)         0         170         (73)         (44)         0         (117)         22           10         Transportation         \$ 1,814         Stores Equipment         \$ 39         39         700ls, Shop & G			Prop. Under Capital Lease-Addiscott	4.00%		17 5/19	0	0	17 5/19		2 926	731	0	3 657	13 802
Total Assets Before Contributed Capital         n/a         1,257,429         158,260         (3,212)         1,412,477         174,889         52,625         (661)         226,853         1,185,62           47         1995/1996         Contributed Capital         varies         (326,846)         (18,323)         993         (344,176)         (35,064)         (9,958)         90         (44,932)         (299,24)           NET DISTRIBUTION ASSETS         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,38           Generation Investments (input as negative) (5)         (2,891)         (76)         0         (2,967)         (250)         (119)         0         (369)         (2,59)           Less Other Non Rate-Regulated Utility (5)         172         (2)         0         170         (73)         (44)         0         (117)         22           Total PP&E         927,864         139,859         (2,219)         1,065,504         139,502         42,504         (571)         181,435         884,066           Total PP&E         Less: Fully Allocated Depreciation           Transportation         \$ 1,814           8		2003													13,892
Capital         n/a         1,257,429         158,260         (3,212)         1,412,477         174,889         52,625         (661)         226,853         1,185,62           47         1995/1996         Contributed Capital         varies         (326,846)         (18,323)         993         (344,176)         (35,064)         (9,958)         90         (44,932)         (299,24)           NET DISTRIBUTION ASSETS         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,38           Generation Investments (input as negative)         n/a         930,583         139,937         (2,219)         1,068,301         139,825         42,667         (571)         181,921         886,38           (5)         (2,891)         (76)         0         (2,967)         (250)         (119)         0         (369)         (2,59)           (5)         Less Other Non Rate-Regulated Utility         172         (2)         0         170         (73)         (44)         0         (117)         22           Assets (input as negative) (4)         927,864         139,859         (2,219)         1,065,504         139,504         (571)         181,435         884,				n/a		17,040	0	0	17,040		2,020	101	0	0,007	10,002
47       1995/1996       Contributed Capital       varies       (326,846)       (18,323)       993       (344,176)       (35,064)       (9,958)       90       (44,932)       (299,24         NET DISTRIBUTION ASSETS       n/a       930,583       139,937       (2,219)       1,068,301       139,825       42,667       (571)       181,921       886,38         Generation Investments (input as negative)       (2,891)       (76)       0       (2,967)       (250)       (119)       0       (369)       (2,59)         Less Other Non Rate-Regulated Utility       172       (2)       0       170       (73)       (44)       0       (117)       28         Assets (input as negative)       (4)       172       (2)       0       170       (73)       (44)       0       (117)       28         Mote as negative)       (4)       927,864       139,859       (2,219)       1,065,504       139,502       42,504       (571)       181,435       884,064         Less: Fully Allocated Depreciation         Transportation       \$       1,814       Stores Equipment       \$       39         8       Tools, Shop & Garage       \$       473       less - Non- distribution       -\$				n/a		1.257.429	158,260	(3.212)	1.412.477		174.889	52.625	(661)	226.853	1,185,624
Less Socialized Renewable Energy Generation Investments (input as negative) (5)         Control         Control <thcontrol< th="">         Control         Co</thcontrol<>	47	1995/1996		varies											(299,244)
Generation Investments (input as negative) (5)       (2,891)       (76)       0       (2,967)       (250)       (119)       0       (369)       (2,594)         Less Other Non Rate-Regulated Utility Assets (input as negative) (4)       172       (2)       0       170       (73)       (44)       0       (117)       28         Total PP&E       927,864       139,859       (2,219)       1,065,504       139,502       42,504       (571)       181,435       884,069         Less: Fully Allocated Depreciation         Transportation       \$       1,814         8       Stores Equipment       \$       39         8       Tools, Shop & Garage       \$       473         less - Non- distribution       -\$       44         NoTES:       Net Depreciation       \$			NET DISTRIBUTION ASSETS	n/a		930,583	139,937	(2,219)	1,068,301		139,825	42,667	(571)	181,921	886,380
(5)       (2,891)       (76)       0       (2,967)       (250)       (119)       0       (369)       (2,59)         Less Other Non Rate-Regulated Utility       172       (2)       0       170       (73)       (44)       0       (117)       28         Assets (input as negative) (4)       927,864       139,859       (2,219)       1,065,504       139,502       42,504       (571)       181,435       884,064         Less: Fully Allocated Depreciation         10       Transportation       Transportation       \$ 1,814         8       Stores Equipment       \$ 39         8       Tools, Shop & Garage       \$ 473         less - Non- distribution       - \$ 44         NoTES:       Net Depreciation       \$ 40,297			Less Socialized Renewable Energy												
Less Other Non Rate-Regulated Utility Assets (input as negative) (4)       172       (2)       0       170       (73)       (44)       0       (117)       26         Total PP&E       927,864       139,859       (2,219)       1,065,504       139,502       42,504       (571)       181,435       884,065         10       Transportation       Stores Equipment       \$       39			Generation Investments (input as negative)			(= == .)	()		( )		()			()	()
Assets (input as negative) (4)       172       (2)       0       170       (73)       (44)       0       (117)       28         Total PP&E       927,864       139,859       (2,219)       1,065,504       139,502       42,504       (571)       181,435       884,069         10       Transportation       \$       1,814         8       Stores Equipment       \$       39       39       39       39       39       39       39       39       39       39       39       39       39       39       44       5       44       40,297       40,297       40,297       40,297       40,297       5       40,297       40,297       40,297       5       40,297       40,297       5       40			(5)			(2,891)	(76)	0	(2,967)	$\vdash$	(250)	(119)	0	(369)	(2,598)
Total PP&E         10         927,864         139,859         (2,219)         1,065,504         139,502         42,504         (571)         181,435         884,066           10         Transportation         Transportation         5         1,814           8         Stores Equipment         \$         39           8         Tools, Shop & Garage         \$         473           less - Non- distribution         -\$         44           NOTES:         Net Depreciation         \$         40,297						172	(2)	n	170		(73)	(44)	n	(117)	287
10       Transportation       \$       1,814         8       Stores Equipment       \$       39         8       Tools, Shop & Garage       \$       473         NOTES:       Net Depreciation       \$       40,297										H					884,069
10     Transportation     \$ 1,814       8     Stores Equipment     \$ 39       8     Tools, Shop & Garage     \$ 473       less - Non- distribution     \$ 44       NOTES:				•				(_, 0)	.,	<u> </u>		.2,004	(0.1)		00.,000
10     Transportation     \$ 1,814       8     Stores Equipment     \$ 39       8     Tools, Shop & Garage     \$ 473       less - Non- distribution     \$ 44       NOTES:									Less: Fully Alloca	ated	Depreciation				
8     Stores Equipment     \$     39       8     Tools, Shop & Garage     \$     473       less - Non- distribution     -\$     44       NOTES:	10		Transportation	1								\$ 1,814			
8     Tools, Shop & Garage     \$     473       less - Non- distribution     -\$     44       Not Depreciation     \$     40,297				1						ent					
NOTES: less - Non- distribution -\$ 44 Net Depreciation \$ 40,297	8			1							age	\$ 473			
NOTES: Net Depreciation \$ 40,297			· • • •	-							0				
NOTES:									Net Depreciation	n					
(1) This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.	NOTES:								-						
	(1) This i	s the depreciation	on rate on the largest component within the	e asset class. A	ctual dep	reciation is ca	lculated on the	e specific rate for	each componer	nt w	vithin the class.				

(2) This is the average depreciation rate of 2 subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") capital costs for 2014 and unrecovered costs from prior years are included in the closing 2015 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the above in the amount of \$1,054k. This amount was approved by the OEB and represents the eligible renewable generation connection rate protection total that PowerStream will receive from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, has been included in the above 2015 fixed asset additions and will be added to rate base to be recovered from PowerStream ratepayers.

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	5 of 9
-	
Date:	February 24,2015

				-			T (000's)				JMULATIVE DEP			
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance		Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
Distributi	ion Assets													
47		Hydro One TS - Contributed Capital	2.50%		4,953	0	0	4.953		1,181	288	0	1,469	3,484
n/a		Land	0		23,547	2,889	0	26,436		0	0	0	0	26,436
CEC	1612	Land Rights	0		906	34	0	940		0	0	0	0	940
1	1808	Building & Fixtures	2.50%		6,929	76	0	7,005		1,016	219	0	1,235	5,770
47	1810	Major spare parts	0		9,878	0	0	9,878		0	0	0	0	9,878
47	1815	Transformer Stations	2.50%	1	106,253	2,891	0	109,144		21,491	4,135	0	25,626	83,518
47		Distribution Stations	3.33%	1	28,387	491	0	28,878		7,202	1,484	0	8,686	20,192
47		Poles, Towers & Fixtures	2.22%		160,781	23,545	(87)	184,239		14,616	4,060	(14)	18,662	165,577
47		O/H Cond & Devices	2.50%		136,977	24,397	(130)	161,244		16,013	4,229	(10)	20,232	141,012
47		U/G Conduit	1.67%		105,019	6,333	0	111,352		7,101	1,893	0	8,994	102,358
47		U/G Cond & Devices	2.22%		316,642	38,603	(433)	354,812		31,765	9,056	(92)	40,729	314,083
47		Line Transformers	2.92%	2	168,806	13,235	(1,901)	180,140		31,341	7,274	(215)	38,400	141,740
47		Services (OH and UG)	3.25%	2	71,804	4,118	0	75,922		17,867	3,522	0	21,389	54,533
47		Meters	5.33%	2	33,238	2,924	(1,176)	34,986		7,052	2,165	(588)	8,629	26,357
47		Smart Meters	6.67%		51,019	2,384	0	53,403		17,794	3,767	23	21,584	31,819
47	18/5	Streetlighting	4.00%		2,126	2	0	2,128	_	396	91	0	487	1,641
<b></b>		Subtotal Distribution Assets	n/a		1,227,265	121,922	(3,727)	1,345,460		174,835	42,183	(896)	216,122	1,129,338
General P	Plant Assets	Building & Fixtures - Head office	2.00%	1	47,313	398	0	47,711		4,768	1,068	0	5,836	41,875
13		Leasehold Improvements	30.00%	-	47,313	390	0	47,711	_	4,768	(1)	0	27	164
8		Office Equipment	10.00%		5.035	13	0	5.048	_	2.800	598	0	3.398	1,650
50		Computer hardware	20.42%	2	13,363	2.194	0	15,557	_	7.869	2.161	28	10,058	5,499
12		Computer Software	22.78%	2	64,436	9,413	0	73.849	-	15,774	8.382	20	24,156	49,693
10		Transportation	9.05%	2	16,566	3,124	0	19,690	-	7,619	1,953	0	9,572	10,118
8		Stores Equipment	10.00%		680	0,124	0	680		44	65	0	109	571
8		Tools, Shop & Garage	10.00%		4,875	478	0	5,353		2,151	498	0	2,649	2,704
8		Communication Equipment	21.67%	2	2,599	268	0	2,867		1.797	209	0	2,006	861
8		Miscellaneous equipment	10.00%	_	2,000	0	0	2,001		0	0	0	0	001
47		System Supervisory Equip	7.78%	2	12.605	1.596	0	14.201		5,511	1.044	8	6.563	7,638
47			n/a		0	0	0	0		0	0	0	0	0
			n/a		167,663	17,484	0	185,147		48,361	15,977	36	64,374	120,773
Other Cap	pital									0	- / -			
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0	0	17,549		3,657	733	0	4,390	13,159
		Subtotal Other Capital Assets	n/a		17,549	0	0	17,549		3,657	733	0	4,390	13,159
		Total Assets Before Contributed												
		Capital	n/a		1,412,477	139,406	(3,727)	1,548,156		226,853	58,893	(860)	284,886	1,263,270
47	1995/1996		varies		(344,176)	(22,014)	993	(365,197)		(44,932)	(10,620)	90	(55,462)	(309,734)
			n/a		1,068,301	117,392	(2,734)	1,182,959		181,921	48,273	(770)	229,424	953,536
		Less Socialized Renewable Energy												
		Generation Investments (input as negative)			(2.967)	(67)	0	(3.034)		(369)	(110)	0	(479)	(2.555)
		(5) Less Other Non Rate-Regulated Utility			(2,907)	(67)	0	(3,034)	_	(309)	(110)	0	(479)	(∠,000)
		Assets (input as negative) (4)			170	(2)	0	168		(117)	(44)	0	(161)	329
		Total PP&E			1,065,504	117,323	(2,734)	1,180,093		181,435	48,119	(770)	228,784	951,309
								Less: Fully Alloca	ated D	Depreciation				
10		Transportation						Transportation			\$ 1,953			
8		Stores Equipment						Stores Equipme	ent		\$ 65			
8		Tools, Shop & Garage						Tools, Shop & C	Gara	je	\$ 498			
		· · · · · · · · · · · · · · · · · · ·	•					ess - Non- distr			-\$ 44			
								Net Depreciation		-	\$ 45,713			
NOTES:								•		-				
NUIES:														

(2) This is the average depreciation rate of the subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") capital costs for 2015 are included in the closing 2016 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the RGEN costs and for 2017 the calculated amount is \$76k. Upon approval PowerStream will receive the recoveries from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, has been included in the above 2016 fixed asset additions and therefore added to rate base to be recovered from PowerStream ratepayers.

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	6 of 9
Date:	February 24,2015

						CO	ST (000's)		1 Г	ACC	UMULATIVE DE	PRECIATION (000	)'s)	1
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance		Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
Distributi	on Assets													
47	1610	Hydro One TS - Contributed Capital	2.50%		4,953	0	0	4,953		1,469	288	0	1,757	3,190
ı/a	1805	Land	0		26,436	0	0	26,436		0	0	0	0	26,43
CEC		Land Rights	0		940	34	0	974		0	0		0	97
1		Building & Fixtures	2.50%		7,005	77	0	7,082		1,235	220	0	1,455	5,62
47		Major spare parts	0		9,878	0	0	9,878		0	0	0	0	9,87
47		Transformer Stations	2.50%	1	109,144	24,962	0	134,106		25,626	4,377	0	30,003	104,10
47		Distribution Stations	3.33%	1	28,878	2,886	0	31,764		8,686	1,461	0	10,147	21,61
47		Poles, Towers & Fixtures	2.22%	-	184,239	24,299	(87)	208,451		18,662	4,583	(14)	23,231	185,22
47		O/H Cond & Devices U/G Conduit	2.50% 1.67%		161,244	23,360	(130)	184,474 118,435		20,232	4,778	(10)	25,000	159,47 107.44
47		U/G Cond & Devices	2.22%		111,352 354.812	7,083	(433)	397.815		8,994 40,729	2,001 10.062	(92)	10,995 50.699	347.11
47		Line Transformers	2.22%	2	180,140	43,436	(1,901)	191,825		40,729	7,682	(92)	45,867	145,95
47		Services (OH and UG)	3.25%	2	75,922	4,203	(1,901)	80,125		21,389	3,580	(213)	24,969	55,15
47		Meters	5.33%	2	34,986	3,207	(1,176)	37,017		8,629	2,342	(588)	10,383	26,63
47		Smart Meters	6.67%	~	53,403	1,536	(1,170)	54,939		21,584	3,888	(300)	25,472	29,46
47		Streetlighting	4.00%		2,128	1,000	0	2,130		487	91	0	578	1.55
71	10/0		n/a		1,345,460	148,671	(3,727)	1,490,404		216.122	45,353	(919)	260,556	1,229,848
General F	Plant Assets		170		1,010,100	110,011	(0,121)	1,100,101		210,122	10,000	(010)	200,000	1,220,010
1		Building & Fixtures - Head office	2.00%	1	47,711	403	0	48,114	П	5,836	1,073	0	6,909	41,20
13	1910	Leasehold Improvements	30.00%		191	0	0	191		27	(1)	0	26	16
8	1915	Office Equipment	10.00%		5,048	24	0	5,072		3,398	598	0	3,996	1,07
50	1920	Computer hardware	20.42%	2	15,557	2,954	0	18,511		10,058	2,502	0	12,560	5,95
12	1611	Computer Software	22.78%	2	73,849	10,466	0	84,315		24,156	9,482	0	33,638	50,67
10	1930	Transportation	9.05%	2	19,690	2,686	0	22,376		9,572	2,046	0	11,618	10,75
8		Stores Equipment	10.00%		680	0	0	680		109	66	0	175	50
8	1940	Tools, Shop & Garage	10.00%		5,353	473	0	5,826		2,649	507	0	3,156	2,67
8		Communication Equipment	21.67%	2	2,867	513	0	3,380		2,006	212	0	2,218	1,16
8		Miscellaneous equipment	10.00%		0	0	0	0		0	0	0	0	
47		System Supervisory Equip	7.78%	2	14,201	1,093	0	15,294		6,563	1,064	0	7,627	7,66
47	1990		n/a		0	0	0	0		0	0	0	0	
		Subtotal General Plant Assets	n/a		185,147	18,612	0	203,759		64,374	17,549	0	81,923	121,83
Other Ca			4.000/	r –	17.540	0	<u>^</u>	17.540		1 000	704		5 404	10.10
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0	0	17,549	$\vdash$	4,390	731	0	5,121	12,428
		Subtotal Other Capital Assets Total Assets Before Contributed	n/a		17,549	0	0	17,549		4,390	731	0	5,121	12,428
		Capital	n/a		1,548,156	167,283	(3,727)	1,711,712		284,886	63,633	(919)	347,600	1,364,112
47	1995/1996	Contributed Capital	varies		(365,197)	(22,923)	993	(387,126)		(55,462)	(11.322)	(919)	(66,694)	(320,432
47	1990/1990		n/a		1,182,959	144.360	(2,734)	1.324.586		229,424	52,311	(829)	280,906	1,043,68
		Less Socialized Renewable Energy	11/a		1,102,939	144,300	(2,734)	1,324,300		229,424	52,511	(029)	200,900	1,043,00
		Generation Investments (input as negative)												
		(5)			(3,034)	0	0	(3,034)		(479)	(108)	0	(587)	(2,447
		Less Other Non Rate-Regulated Utility												
		Assets (input as negative) (4)			100	(0)		100		(101)	(4.0)		(005)	
					168	(2)	0	166		(161)	(44)	0	(205)	37
		Total PP&E			1,180,093	144,358	(2,734)	1,321,717		228,784	52,159	(829)	280,114	1,041,602
								L		. D				
10		Transportation						Less: Fully Alloc Transportation	aleu	Depreciation	\$ 2,046			
8									ot					
		Stores Equipment						Stores Equipme			\$ 66			
8		Tools, Shop & Garage						Tools, Shop & C			\$ 507			
NOTES:	a the depression	n rate on the largest component within the	anat daga A	atual daar	registion is go	louisted on th	o openifia rato for	less - Non- distr Net Depreciation	n		-\$ 44 \$ 49,648	-		
2) This i 3) Work	s the average de in progress exp	In rate on the largest component within the epreciation rate of the subclass of assets v enditures have been removed is have been removed. In some years the	vithin the asset	group							t			

(5) Renewable Generation ("RGEN") accumulative capital costs for 2016 are included in the closing 2017 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the RGEN costs and for 2017 the calculated amount is \$67k. Upon approval PowerStream will receive the recoveries from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, has been included in the above 2017 fixed asset additions and is added to rate base to be recovered from PowerStream ratepayers.

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	7 of 9
Date:	February 24,2015

CCA Class Distributi 47	GL account	COST (000's) Depreciation Opening Additions Disposals/ Closing												
	GL account	Detail Asset Class	Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance		Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
	ion Assets													
		Hydro One TS - Contributed Capital	2.50%		4,953	0	0	4,953		1,757	288	0	2,045	2,908
n/a	1805	Land	0		26,436	9	0	26,445		0	0	0	0	26,445
CEC	1612	Land Rights	0		974	35	0	1,009		0	0	0	0	1,009
1	1808	Building & Fixtures	2.50%		7,082	156	0	7,238		1,455	223	0	1,678	5,560
47		Major spare parts	0		9,878	0	0	9,878		0	0	0	0	9,878
47		Transformer Stations	2.50%	1	134,106	4,765	0	138,871		30,003	4,685	0	34,688	104,183
47		Distribution Stations	3.33%	1	31,764	9,507	0	41,271		10,147	1,567	0	11,714	29,557
47		Poles, Towers & Fixtures	2.22%		208,451	22,367	(87)	230,731		23,231	5,102	(14)	28,319	202,412
47		O/H Cond & Devices	2.50%		184,474	22,313	(130)	206,657		25,000	5,310	(10)	30,300	176,357
47		U/G Conduit	1.67%		118,435	7,478	0	125,913		10,995	2,123	0	13,118	112,795
47		U/G Cond & Devices	2.22%	_	397,815	43,414	(433)	440,796		50,699	11,128	(92)	61,735	379,061
47		Line Transformers	2.92%	2	191,825	14,439	(1,901)	204,363		45,867	8,092	(215)	53,744	150,619
47		Services (OH and UG)	3.25%	2	80,125	4,408	0	84,533		24,969	3,643	0	28,612	55,921
47		Meters	5.33%	2	37,017	4,366	(1,176)	40,207		10,383	2,544	(588)	12,339	27,868
47		Smart Meters Streetlighting	6.67% 4.00%		54,939 2.130	1,259	0	56,198 2,132		25,472 578	4,003 91	0	29,475 669	26,723
47	18/5	Subtotal Distribution Assets	4.00% n/a		1,490,404	134,518	(3,727)	1,621,195		260,556	48,799	(919)	308,436	<u>1,463</u> 1,312,759
Conoral (	Plant Assets	Subiolal Distribution Assets	11/d		1,490,404	134,316	(3,727)	1,021,195		200,550	40,799	(919)	306,430	1,312,759
<u>Jeneral r</u> 1		Building & Fixtures - Head office	2.00%	1	48,114	407	0	48,521		6,909	1,082	0	7,991	40,530
13		Leasehold Improvements	30.00%		191	0	0	191		26	(1)	0	25	166
8		Office Equipment	10.00%		5.072	35	0	5.107		3.996	427	0	4.423	684
50		Computer hardware	20.42%	2	18,511	1,355	0	19,866		12,560	2,741	0	15,301	4,565
12		Computer Software	22.78%	2	84,315	6,320	0	90,635		33,638	9,386	0	43,024	47,611
10		Transportation	9.05%	2	22,376	2,910	0	25,286		11,618	2,156	0	13,774	11,512
8		Stores Equipment	10.00%		680	0	0	680		175	66	0	241	439
8	1940	Tools, Shop & Garage	10.00%		5,826	573	0	6,399		3,156	522	0	3,678	2,721
8	1955	Communication Equipment	21.67%	2	3,380	317	0	3,697		2,218	215	0	2,433	1,264
8	1960	Miscellaneous equipment	10.00%		0	0	0	0		0	0	0	0	0
47	1980	System Supervisory Equip	7.78%	2	15,294	816	0	16,110		7,627	1,071	0	8,698	7,412
47	1990	Other Tangible property	n/a		0	0	0	0		0	0	0	0	0
		Subtotal General Plant Assets	n/a		203,759	12,733	0	216,492		81,923	17,665	0	99,588	116,904
Other Ca														
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0	0	17,549		5,121	731	0	5,852	11,697
			n/a		17,549	0	0	17,549		5,121	731	0	5,852	11,697
		Total Assets Before Contributed												
	/	Capital	n/a		1,711,712	147,251	(3,727)	1,855,236		347,600	67,195	(919)	413,876	1,441,360
47	1995/1996	Contributed Capital	varies		(387,126)	(23,833)	993	(409,966)		(66,694)	(12,073)	90	(78,678)	(331,288)
		NET DISTRIBUTION ASSETS	n/a		1,324,586	123,418	(2,734)	1,445,270		280,906	55,122	(829)	335,198	1,110,072
		Less Socialized Renewable Energy Generation Investments (input as negative)												
		(5)			(3,034)	0	0	(3,034)		(587)	(106)	0	(693)	(2,341)
		Less Other Non Rate-Regulated Utility			(0)00.07			(0)00.7		(00.)	()		(***)	(=)••••
		Assets (input as negative) (4)			166	(2)	0	164		(205)	(44)	0	(249)	412
		Total PP&E			1,321,717	123,416	(2,734)	1,442,399		280,114	54,972	(829)	334,256	1,108,144
			1					Less: Fully Alloca	ated	Depreciation				
10		Transportation						Transportation			\$ 2,156			
8		Stores Equipment						Stores Equipme			\$ 66			
8		Tools, Shop & Garage	l					Tools, Shop & C		0	\$ 522			
								less - Non- distr		tion	-\$ 44			
								Net Depreciation	n		\$ 52,334			
NOTES:														
		n rate on the largest component within the preciation rate of the subclass of assets v			reciation is ca	lculated on the	e specific rate for	each componer	nt w	vithin the class.				

(2) This is the average depreciation rate of the subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") accumulative capital costs for 2017 are included in the closing 2018 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the RGEN costs and for 2017 there are no additional costs. Upon approval PowerStream will receive the recoveries from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, is included in the 2017 fixed asset balances and is added to rate base to be recovered from PowerStream ratepayers.

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	8 of 9
Date:	February 24,2015

						COS	6T (000's)		ACC	UMULATIVE DEP	PRECIATION (000	)'s)	
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
istributi	on Assets					( )					· · ·		
47		Hydro One TS - Contributed Capital	2.50%		4.953	0	0	4,953	2.045	288	0	2,333	2,62
/a		Land	2.30%		26,445	758	0	27,203	2,043	200	0	2,333	27,20
EC		Land Rights	0		1.009	35	0	1.044	0	0	0	0	1.04
1		Building & Fixtures	2.50%		7,238	137	0	7,375	1,678	227	0	1.905	5,47
47		Major spare parts	2.30%		9,878	0	0	9.878	0	0	0	1,903	9.87
47		Transformer Stations	2.50%	1	138.871	4.262	0	143,133	34,688	4,771	0	39,459	103,67
47		Distribution Stations	3.33%	1	41.271	13.038	0	54,309	11.714	1,873	0	13,587	40.72
47		Poles, Towers & Fixtures	2.22%	1	230,731	18,249	(87)	248,893	28,319	5,553	(14)	33,858	215,03
47		O/H Cond & Devices	2.22%		206,657	29.344	(130)	246,693	30,300	5,555	(14)	36,207	199.66
47						7.232	( )		,	2,245	( · /		,
47		U/G Conduit	1.67%		125,913	42,793	0	133,145	13,118		0	15,363	117,78
		U/G Cond & Devices	2.22%		440,796	,	(433)	483,156	61,735	12,194	(92)	73,837	409,31
47		Line Transformers	2.92%	2	204,363	14,830	(1,901)	217,292	53,744	8,504	(215)	62,033	155,25
47	1855		3.25%	2	84,533	4,842	0	89,375	28,612	3,737	0	32,349	57,02
47		Meters	5.33%	2	40,207	5,416	(1,176)	44,447	12,339	2,748	(588)	14,499	29,94
47		Smart Meters	6.67%		56,198	1,248	0	57,446	29,475	4,174	0	33,649	23,79
47	1875		4.00%		2,132	2	0	2,134	669	91	0	760	1,37
		Subtotal Distribution Assets	n/a		1,621,195	142,186	(3,727)	1,759,654	308,436	52,322	(919)	359,839	1,399,815
	Plant Assets		0			0							1
1		Building & Fixtures - Head office	2.00%	1	48,521	417	0	48,938	7,991	1,090	0	9,081	39,85
13		Leasehold Improvements	30.00%		191	0	0	191	25	(1)	0	24	16
8		Office Equipment	10.00%		5,107	13	0	5,120	4,423	246	0	4,669	45
50		Computer hardware	20.42%	2	19,866	2,310	0	22,176	15,301	2,559	0	17,860	4,31
12	1611	Computer Software	22.78%	2	90,635	7,880	0	98,515	43,024	9,835	0	52,859	45,65
10	1930	Transportation	9.05%	2	25,286	3,098	0	28,384	13,774	2,362	0	16,136	12,24
8	1935	Stores Equipment	10.00%		680	0	0	680	241	66	0	307	37
8	1940	Tools, Shop & Garage	10.00%		6,399	589	0	6,988	3,678	542	0	4,220	2,76
8	1955	Communication Equipment	21.67%	2	3,697	317	0	4,014	2,433	202	0	2,635	1,37
8	1960	Miscellaneous equipment	10.00%		0	0	0	0	0	0	0	0	
47	1980	System Supervisory Equip	7.78%	2	16,110	1,159	0	17,269	8,698	1,080	0	9,778	7,49
47	1990	Other Tangible property	n/a		0	0	0	0	0	0	0	0	
		Subtotal General Plant Assets	n/a		216,492	15.783	0	232.275	99,588	17.981	0	117.569	114.70
other Ca	pital											1	
47		Prop. Under Capital Lease-Addiscott	4.00%		17.549	0	0	17,549	5,852	731	0	6.583	10,96
		Subtotal Other Capital Assets	n/a		17,549	0	0	17.549	5,852	731	0	6,583	10,96
		Total Assets Before Contributed	i va		11,010	Ū	Ű	11,010	0,002		Ű	0,000	10,00
		Capital	n/a		1,855,236	157,969	(3,727)	2,009,478	413,876	71,034	(919)	483,991	1,525,48
47	1995/1996	Contributed Capital	varies		(409,966)	(23,802)	993	(432,775)	(78.678)	(12.831)	90	(91,419)	(341.357
-11	1000/1000	NET DISTRIBUTION ASSETS	n/a		1,445,270	134,167	(2,734)	1,576,703	335,198	58,203	(829)	392,572	1,184,13
		Less Socialized Renewable Energy	11/4		1,443,270	134,107	(2,734)	1,570,705	555,130	30,203	(023)	552,512	1,104,13
		Generation Investments (input as negative)											
		(5)			(3,034)	0	0	(3,034)	(693)	(105)	0	(798)	(2,236
		Less Other Non Rate-Regulated Utility										x /	
		Assets (input as negative) (4)											
					164	(2)	0	161	(249)	(44)	0	(293)	45
		Total PP&E			1,442,399	134,164	(2,734)	1,573,830	334,256	58,054	(829)	391,481	1,182,348
								ess: Fully Allocate	ad Depressistion				
10		Transportation						Fransportation	ed Depreciation	\$ 2,362			
8		Stores Equipment						Stores Equipmen	+	\$ 66			
-													
		Tools, Shop & Garage						Fools, Shop & Ga		\$ 542			
8								ess - Non- distrib		-\$ 44			

This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.
 This is the average depreciation rate of the subclass of assets within the asset group

(3) Work in progress expenditures have been removed

NOTES:

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") accumulative capital costs for 2018 are included in the closing 2019 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the RGEN costs and for 2018 there are no additional costs. Upon approval PowerStream will receive the recoveries from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, is included in the 2018 fixed asset balances and is added to rate base to be recovered from PowerStream ratepayers.

File Number:	EB-2015-0003
Exhibit:	G
Tab:	2a
Schedule:	1
Page:	9 of 9
Date:	February 24,2015

						COS	ST (000's)		ACC	UMULATIVE DEI	PRECIATION (00	0's)	
CCA Class	GL account	Detail Asset Class	Depreciation Rate	Notes	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Opening Balance	Additions (3)	Disposals/ Adjustments	Closing Balance	Net Book Value (000's
istributio	on Assets								-				
47		Hydro One TS - Contributed Capital	2.50%		4,953	0	0	4,953	2,333	288	0	2,621	2,33
'a	1805		0		27,203	10	0	27.213	0	0	0	0	27.21
EC		Land Rights	0		1,044	36	0	1.080	0	0	0	0	1.08
1		Building & Fixtures	2.50%		7,375	139	0	7,514	1,905	231	0	2,136	5,37
47	1810	Major spare parts	0		9,878	0	0	9,878	0	0	0	0	9,87
47	1815	Transformer Stations	2.50%	1	143,133	3,697	0	146,830	39,459	4,859	0	44,318	102,51
47	1820	Distribution Stations	3.33%	1	54,309	7,656	0	61,965	13,587	2,105	0	15,692	46,27
47	1830	Poles, Towers & Fixtures	2.22%		248,893	18,906	(87)	267,712	33,858	5,974	(14)	39,818	227,89
47	1835	O/H Cond & Devices	2.50%		235,871	21,065	(130)	256,806	36,207	6,556	(10)	42,753	214,05
47	1840	U/G Conduit	1.67%		133,145	7,902	0	141,047	15,363	2,375	0	17,738	123,30
47	1845	U/G Cond & Devices	2.22%		483,156	48,289	(433)	531,012	73,837	13,273	(92)	87,018	443,99
47		Line Transformers	2.92%	2	217,292	14,552	(1,901)	229,943	62,033	8,909	(215)	70,727	159,21
47	1855	Services (OH and UG)	3.25%	2	89,375	4,777	0	94,152	32,349	3,864	0	36,213	57,93
47	1860	Meters	5.33%	2	44,447	2,865	(1,176)	46,136	14,499	2,930	(588)	16,841	29,29
47	1860	Smart Meters	6.67%		57,446	5,655	0	63,101	33,649	4,480	0	38,129	24,97
47	1875	Streetlighting	4.00%		2,134	2		2,136	760	91	0	851	1,28
		Subtotal Distribution Assets	n/a		1,759,654	135,551	(3,727)	1,891,478	359,839	55,935	(919)	414,855	1,476,623
eneral P	lant Assets												
1		Building & Fixtures - Head office	2.00%	1	48,938	417	0	49,355	9,081	1,101	0	10,182	39,17
13		Leasehold Improvements	30.00%		191	0	0	191	24	(1)	0	23	16
8		Office Equipment	10.00%		5,120	286	0	5,406	4,669	175	0	4,844	56
50		Computer hardware	20.42%	2	22,176	2,531	0	24,707	17,860	2,650	0	20,510	4,19
12		Computer Software	22.78%	2	98,515	8,212	0	106,727	52,859	9,975	0	62,834	43,89
10		Transportation	9.05%	2	28,384	2,948	0	31,332	16,136	2,373	0	18,509	12,82
8	1935		10.00%		680	0	0	680	307	66	0	373	30
8		Tools, Shop & Garage	10.00%		6,988	543	0	7,531	4,220	553	0	4,773	2,75
8		Communication Equipment	21.67%	2	4,014	310	0	4,324	2,635	206	0	2,841	1,48
8		Miscellaneous equipment	10.00%		0	0	0	0	0	0	0	0	
47		System Supervisory Equip	7.78%	2	17,269	1,204	0	18,473	9,778	1,120	0	10,898	7,57
47	1990	Other Tangible property	n/a		0	0	0	0	0	0	0	0	
		Subtotal General Plant Assets	n/a		232,275	16,451	0	248,726	117,569	18,218	0	135,787	112,93
ther Cap		-	1						r	-			-
47	2005	Prop. Under Capital Lease-Addiscott	4.00%		17,549	0		17,549	6,583	733	0	7,316	10,23
		Subtotal Other Capital Assets	n/a		17,549	0	0	17,549	6,583	733	0	7,316	10,23
		Total Assets Before Contributed											
		Capital	n/a		2,009,478	152,002	(3,727)	2,157,753	483,991	74,886	(919)	557,958	1,599,79
47	1995/1996	Contributed Capital	varies		(432,775)	(25,323)	993	(457,105)	(91,419)	(13,522)	90	(104,852)	(352,254
		NET DISTRIBUTION ASSETS	n/a		1,576,703	126,679	(2,734)	1,700,648	392,572	61,364	(829)	453,106	1,247,54
		Less Socialized Renewable Energy											
		Generation Investments (input as negative)			(3.034)	0	0	(3.034)	(798)	(104)	0	(902)	(2.13)
		Less Other Non Rate-Regulated Utility			(3,034)	0	0	(3,034)	(130)	(104)	0	(302)	(2,102
		Assets (input as negative) (4)											
		<b>3 7 1</b>			161	(2)	0	159	(293)	(44)	0	(337)	49
		Total PP&E			1,573,830	126,677	(2,734)	1,697,773	391,481	61,216	(829)	451,868	1,245,906
					11			1.5.5			()	. ,	. , ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
							1	ess: Fully Allocat	ed Depreciation				
10		Transportation						Transportation	•	\$ 2,373			
8		Stores Equipment						Stores Equipmer	ıt	\$ 66			
8		Tools, Shop & Garage						Tools, Shop & Ga		\$ 553			
Ũ		·····	I					ess - Non- distrib		-\$ 44			
										+ 44			

(1) This is the depreciation rate on the largest component within the asset class. Actual depreciation is calculated on the specific rate for each component within the class.
 (2) This is the average depreciation rate of the subclass of assets within the asset group

(3) Work in progress expenditures have been removed

(4) Non-distribution assets have been removed. In some years the net impact is adding cost because the removal of the contributed capital on streetlighting exceeded the cost

(5) Renewable Generation ("RGEN") accumulative capital costs for 2020 are included in the closing 2020 fixed assets balances. The renewable generation connection rate protection("RGCRP") additions represents 94% of the RGEN costs and for 2019 and 2020 there are no additional costs. Upon approval PowerStream will receive the recoveries from Ontario ratepayers through the IESO. The residual 6%, otherwise known as the RGEN direct benefit, is included in the 2020 fixed asset balances and is added to rate base to be recovered from PowerStream ratepayers.

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 1 of 17



Note: Drop-down lists are shaded blue; Input cells are shaded green.

This Workbook Model is protected by copyright and is being made available to you solely for the purpose of filing your application. You may use and copy this model for that purpose, and provide a copy of this model to any person that is advising or assisting you in that regard. Except as indicated above, any copying, reproduction, publication, sale, adaptation, translation, modification, reverse engineering or other use or dissemination of this model without the express written consent of the Ontario Energy Board is prohibited. If you provide a copy of this model to a person that is advising or assisting you in preparing the application or reviewing your draft rate order, you must ensure that the person understands and agrees to the restrictions noted above.

While this model has been provided in Excel format and is required to be filed with the applications, the onus remains on the applicant to ensure the accuracy of the data and the results. The use of any models and spreadsheets does not automatically imply Board approval. The onus is on the distributor to prepare, document and support its application. Board-issued Excel models and spreadsheets are offered to assist parties in providing the necessary information so as to facilitate an expeditious review of an application. The onus remains on the applicant to ensure the accuracy of the data and the results.

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 2 of 17

2014

Audited Actual



## ICM True-Up Model for Electricity Distributors

### Sheet 2: ICM Capital Cost Data

Total Underground Cable Rehabilitation

ICP 2.1.

ICP 2.2

ICP 2.3

ICP 2.4 ICP 2.5

ICP 2.6

ICP 2.7

ICP 2.8

ICP 2.9

ICP 2.10

ICP 2 SYSTEM RENEWAL - POLE REPLACEMENTS

### 1 Capital Costs

ICP 1. UNDERGROUND CABLE REHABILITATION ICP 1.1
ICP 1.2
ICP 1.3
ICP 1.4
ICP 1.5
ICP 1.6
ICP 1.7
ICP 1.8
ICP 1.9
ICP 1.10

Asset Type Asset type must be selected to enable calculations	Audited Actual
Poles	24,226
Overhead Conductor	19,823
Underground Conduit	2,305,442
Underground Conductor	723,816
Underground Injected Cable	3,890,145
Underground Transformers	49,234
Overhead Transformers	393
Overhead Services	3,551
	\$ 7,016,630

Asset Type

Poles	Audited Actual 961,466
Overhead Conductor	406,931
Underground Conductor	56,172
Overhead Transformers	117,810
Underground Transformers	12,990
Overhead Services	79,026
Underground Conduit	19,64
System Supervisory Equipment	17
Distribution Station Equipment - Normally Primary below 50 kV	14
Underground Injected Cable	5
	\$ 1,654,412

Asset Type

Total System Renewal - Pole Replacements

### ICP 3 SYSTEM RENEWAL - STATION REPLACEMENTS

10	CP 3.1				
10	CP 3.2				
10	CP 3.3				
10	CP 3.4				
10	CP 3.5				
10	CP 3.6				
10	CP 3.7				
10	CP 3.8				
10	CP 3.9				
10	CP 3.10				

Total System Renewal - Station Replacements

Audited Actual 25,605 Poles Overhead Conductor 79,225 RTU's 79,025 Underground Conductor 3,329 Underground Transformers 74 Overhead Services 509 System Supervisory Equipment 320 Distribution Station Equipment - Normally Primary below 50 kV 9,923 Transformer Station Equipment - Normally Primary above 50 kV 125,164 

Asset Type

Poles

9,421

\$

323,174

ICP 4 SYSTEM RENEWAL - SWITCHGEAR & TRANFORMER REPLACEMENTS

ICP 4.1

### EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 3 of 17

ICP 4.2			
ICP 4.3			
ICP 4.4			
ICP 4.5			
ICP 4.6			
ICP 4.7			
ICP 4.8			
ICP 4.9			
ICP 4.10			

Total System Renewal - Switchgear & Transformer ReplacementS

Overhead Conductor	2,502
Underground Conduit	186,340
Underground Conductor	925,519
Overhead Transformers	12
Underground Transformers	165,200
Overhead Services	23,764
RTU's	-7,819
Distribution Station Equipment - Normally Primary below 50 kV	2,217
Land Rights	19
	\$ 1,307,175

### ICP 5 SYSTEM CAPACITY RELIEF

ICP 5.1		
ICP 5.2		
ICP 5.3		
ICP 5.4		
ICP 5.5		
ICP 5.6		
ICP 5.7		
ICP 5.8		
ICP 5.9		
ICP 5.10		
Total System Capacity Relief		

Asset Type	Audited Actual
Poles	285,853
Overhead Conductor	193,612
Underground Conduit	87,407
Underground Conductor	75,667
Overhead Transformers	10,496
Overhead Services	-470
RTU's	2,324
	\$ 654,890
	\$ 10,956,281

Asset Type

OTHER CAPITAL COST	Audited Actual	
A		
В		
C		
Total Other Capital Costs	\$-	
Total ICM Capital Costs	\$ 10,956,281	

### 2 Aggregated ICM Costs by Category

Total Capital Costs Related to Incremental Capital Projects (ICP)

2.1	Capital	Account	
2.1.1	Poles	1830	\$ 1,306,572
2.1.2	Overhead Conductor	1835	\$ 702,093
2.1.3	Underground Conduit	1840	\$ 2,598,835
2.1.4	Underground Conductor	1845	\$ 1,784,503
2.1.5	Underground Injected Cable	1846	\$ 3,890,196
2.1.6	Overhead Transformers	1849	\$ 128,712
2.1.7	Underground Transformers	1850	\$ 227,498
2.1.8	Overhead Services	1855	\$ 106,380
2.1.9	RTU's	1981	\$ 73,531
2.1.10	System Supervisory Equipment	1980	\$ 494
2.1.11	Distribution Station Equipment - Normally Primary below 50 kV	1820	\$ 12,286
2.1.12	Transformer Station Equipment - Normally Primary above 50 kV	1815	\$ 125,164
2.1.13	Land Rights	1612	\$ 19
2.1.14			

Total Capital Costs

\$ 10,956,281

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 4 of 17



## ICM True-Up Model for **Electricity Distributors**

## **Sheet 3: Parameters and Rates**

	2014
Cost of Capital	
Capital Structure	
Deemed Short-term Debt Capitalization	4.0%
Deemed Long-term Debt Capitalization	56.0%
Deemed Equity Capitalization	40.0%
Preferred Shares	
Total	100.0%
Cost of Capital Parameters	
Deemed Short-term Debt Rate	2.08%
Long-term Debt Rate (actual/embedded/deemed)1	4.15%
Target Return on Equity (ROE)	8.93%
Return on Preferred Shares	0.0070
WACC	5.98%
	0.0070
Working Capital Allowance	
Working Capital Allowance Rate	13.0%
(% of the sum of Cost of Power + controllable expenses)	
Taxes/PILs	
Aggregate Corporate Income Tax Rate	26.00%
Capital Tax (until July 1st, 2010)	0.00%

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 5 of 17

Depreciation Rates	Account	
(expressed as expected useful life in years)		
Poles - years	1830	45
- rate (%)		2.22%
Overhead Conductor - years	1835	40
- rate (%)		2.50%
Underground Conduit - years	<b>1840</b>	60
- rate (%)		1.67%
Underground Conductor - years	1845	45
- rate (%)		2.22%
U/G Injected Cable - years	1846	20
- rate (%)		5.00%
Overhead Transformers - years	1849	40
- rate (%)		2.50%
Underground Transformers - years	<b>1850</b>	30
- rate (%)		3.33%
OH Services - years	1855	40
- rate (%)		2.50%
RTU's - years	1981	15
- rate (%)		6.67%
System Supervisory Equipment - years	<b>1980</b>	15
- rate (%)		6.67%
Distribution Station Equipment - years	<b>1820</b>	30
- rate (%)		3.33%
Transformer Station Equipment - years	1815	40
- rate (%)		2.50%
Land Rights - years	1612	-
- rate (%)		0.00%

no depreciation (ECE)

CCA Rates	
Poles - CCA Class	47
Pole - CCA Rate	8%
Overhead Conductor - CCA Class	47
Overhead Conductor - CCA Rate	8%
Underground Conduit - CCA Class	47
Underground Conduit - CCA Rate	8%
Underground Conductor - CCA Class	47
Underground Conductor - CCA Rate	8%
U/G Injected Cable - CCA Class	47
U/G Injected Cable - CCA Rate	8%
Overhead Transformers - CCA Class	47
Overhead Transformers - CCA Rate	8%
	47
Underground Transformers - CCA Class Underground Transformers - CCA Rate	47 8%
	070
OH Services - CCA Class	47
OH Services - CCA Rate	8%
RTU's - CCA Class	8
RUT's - CCA Rate	20%
System Supervisory Equipment - CCA Class	8
System Supervisory Equipment - CCA Rate	20%
Distribution Station Equipment - CCA Class	47
Distribution Station Equipment - CCA Rate	8%
Transformer Station Equipment - CCA Class	47
Transformer Station Equipment - CCA Rate	8%
Land Rights - CCA Class	
Land Rights - CCA Rate	

## Assumptions

<sup>1</sup> Fiscal calendar year (January 1 to December 31) used.
3 Amortization is done on a striaght line basis and no "half-year" rule applied.

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 7 of 17

2014



## Sheet 4: ICM Assets - Net Book Value

Net Fixed Assets - Poles	2014
Gross Book Value	
Opening Balance	
Capital Additions during year (from ICM Costs)	\$ 1,306,572
Retirements/Removals (if applicable)	φ 1,000,072
Closing Balance	\$ 1,306,572
Closing Balance	φ 1,500,572
Accumulated Depreciation	
Opening Balance	
Amortization expense during year	-\$ 29,035
Retirements/Removals (if applicable)	· · · · · · · · · · · · · · · · · · ·
Closing Balance	-\$ 29,035
J J J J J J J J J J J J J J J J J J J	
Net Book Value	
Opening Balance	\$ -
Closing Balance	\$ 1,277,537
Incremental CAPEX	\$ 1,277,537
Net Fixed Assets - Overhead Conductor	
Gross Book Value	
Opening Balance	
Capital Additions during year (from ICM Costs)	\$ 702,093
Retirements/Removals (if applicable)	
Closing Balance	\$ 702,093
J J J J J J J J J J J J J J J J J J J	
Accumulated Depreciation	
Opening Balance	
Amortization expense during year	-\$ 17,552
Retirements/Removals (if applicable)	
Closing Balance	-\$ 17,552
-	

		EB-2015-00 PowerStream Ir ICM True-Up Moo G-2b	nc. del
Net Deals Value		Page 8 of	
Net Book Value Opening Balance	\$		
Closing Balance	\$	684,541	
Incremental CAPEX	\$	684,541	1
Net Fixed Assets - Underground Conduit		, , , , , , , , , , , , , , , , , , ,	
Gross Book Value			
Opening Balance			
Capital Additions during year (from ICM Costs)	\$	2,598,835	
Retirements/Removals (if applicable)			
Closing Balance	\$	2,598,835	
Accumulated Depreciation			
Opening Balance			
Amortization expense during year	-\$	43,314	
Retirements/Removals (if applicable) Closing Balance	-\$	43,314	
	- <b>\$</b>	43,314	
Net Book Value			
Opening Balance	\$	-	
Closing Balance	\$	2,555,521	
Incremental CAPEX	\$	2,555,521	
<u>Net Fixed Assets - Underground Conductor</u> Gross Book Value			
Opening Balance			
Capital Additions during year (from ICM Costs)	\$	1,784,503	
Retirements/Removals (if applicable)	<u></u>	1 794 502	
Closing Balance	\$	1,784,503	
Accumulated Depreciation			
Opening Balance Amortization expense during year	-\$	39,656	
Retirements/Removals (if applicable)	-φ	39,000	
Closing Balance	-\$	39,656	
		· · ·	
Net Book Value	¢		
Opening Balance Closing Balance	\$ \$	- 1,744,847	
Incremental CAPEX	\$	1,744,847	Т
	Ψ	1,144,041	1
Net Fixed Assets - U/G Injected Cable			
Gross Book Value			
Opening Balance	¢	2 200 406	
Capital Additions during year (from ICM Costs) Retirements/Removals (if applicable)	\$	3,890,196	
Closing Balance	\$	3,890,196	
Accumulated Depreciation			

		EB-2015-000 PowerStream In	
		ICM True-Up Mod	
		G-2b	
Opening Polonee		Page 9 of 7	17
Opening Balance	¢	104 510	
Amortization expense during year	-\$	194,510	
Retirements/Removals (if applicable)			
Closing Balance	-\$	194,510	
Net Deals Value			
Net Book Value	•		
Opening Balance	\$ \$	-	
Closing Balance	\$	3,695,686	
Incremental CAPEX	\$	3,695,686	
et Fixed Assets - OH Transformers			
Gross Book Value			
Opening Balance			
Capital Additions during year (from ICM Costs)	\$	128,712	
Retirements/Removals (if applicable)	Ψ	120,712	
Closing Balance	\$	128,712	
	Ψ	120,712	
Accumulated Depreciation			
Opening Balance			
Amortization expense during year	-\$	3,218	
Retirements/Removals (if applicable)	Ψ	0,210	
Closing Balance	-\$	3,218	
	<u>-Ψ</u>	5,210	
Net Book Value			
Opening Balance	\$	_	
Closing Balance	\$	125,494	
Incremental CAPEX	\$	125,494	1
et Fixed Assets - UG Transformers	_•		1
et Fixed Assets - 00 Transformers			
Gross Book Value			
Opening Balance			
Capital Additions during year (from ICM Costs)	\$	227,498	
Retirements/Removals (if applicable)			
Closing Balance	\$	227,498	
5		,	
Accumulated Depreciation			
Opening Balance			
Amortization expense during year	-\$	7,583	
Retirements/Removals (if applicable)	Ψ	1,000	
Closing Balance	-\$	7,583	
	-Ψ	7,505	
Net Book Value			
Opening Balance	¢	_	
	\$	=	
	¢	210 01/	
Closing Balance Incremental CAPEX	\$ <b>\$</b>	219,914 <b>219,914</b>	÷.

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 10 of 17

## **Net Fixed Assets - OH Services**

Gross Book Value		
Opening Balance		
Capital Additions during year (from ICM Costs)	\$	106,380
Retirements/Removals (if applicable)		
Closing Balance	\$	106,380
Accumulated Depreciation		
Opening Balance		
Amortization expense during year	-\$	2,660
Retirements/Removals (if applicable)	Ψ	2,000
Closing Balance	-\$	2,660
	Ψ	2,000
Net Book Value		
Opening Balance	\$	-
Closing Balance	\$ \$	103,721
Incremental CAPEX	\$	103,721
Net Fixed Assets - RTUs		
Gross Book Value		
Opening Balance		
Capital Additions during year (from ICM Costs)	\$	73,531
Retirements/Removals (if applicable)		
Closing Balance	\$	73,531
Accumulated Depreciation		
Opening Balance		
Amortization expense during year	-\$	4,902
Retirements/Removals (if applicable)	-ψ	4,302
Closing Balance	-\$	4,902
	Ψ	4,502
Net Book Value		
Opening Balance	\$	-
Closing Balance	\$	68,629
Incremental CAPEX	\$	68,629
Net Fixed Assets - System Supervisory Equipment		
Gross Book Value		
Opening Balance		
Capital Additions during year (from ICM Costs)	\$	494
Retirements/Removals (if applicable)		
Closing Balance	\$	494

EB-2015-0003 PowerStream Inc. el -1 17

		ICM True-Up Model
		G-2b-1 Page 11 of 17
Accumulated Depreciation		r age rr or rr
Opening Balance		
Amortization expense during year	-\$	33
Retirements/Removals (if applicable)		
Closing Balance	-\$	33
Net Book Value		
Opening Balance	\$	-
Closing Balance	\$	461
Incremental CAPEX	\$	461
Net Fixed Assets - Distribution Station Equipment		
Gross Book Value		
Opening Balance		
Capital Additions during year (from ICM Costs)	\$	12,286
Retirements/Removals (if applicable)		
Closing Balance	\$	12,286
Accumulated Depreciation		
Opening Balance	<b>^</b>	110
Amortization expense during year	-\$	410
Retirements/Removals (if applicable)		
Closing Balance	-\$	410
Net Book Value		
Opening Balance	\$	-
Closing Balance	\$ \$	11,876
Incremental CAPEX	\$	11,876
Net Fixed Assets - Transformer Station Equipment		
Gross Book Value		
Opening Balance		
Capital Additions during year (from ICM Costs)	\$	125,164
Retirements/Removals (if applicable)		
Closing Balance	\$	125,164
Accumulated Depreciation		
Opening Balance		
Amortization expense during year	-\$	3,129
Retirements/Removals (if applicable)		
Closing Balance	-\$	3,129

**Closing Balance** 

#### Net Book Value **Opening Balance** \$ -Closing Balance \$ 122,034 \$ Incremental CAPEX 122,034

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 12 of 17

## **Net Fixed Assets - Land Rights**

Gross Book Value Opening Balance	
Capital Additions during year (from ICM Costs)	\$ 19
Retirements/Removals (if applicable)	
Closing Balance	\$ 19
Accumulated Depreciation	
Opening Balance	
Amortization expense during year	\$ -
Retirements/Removals (if applicable)	
Closing Balance	\$ -
Net Book Value	
Opening Balance	\$ -
Closing Balance	\$ 19
Incremental CAPEX	\$ 19

Additions	\$	10,956,281	#
Incremental CAPEX	\$	10,610,281	#
Total Amortization	-\$	346,001	#

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 13 of 17



## ICM True-Up Model for Electricity Distributors

## Sheet 6: CCA For PILs Calculation

## UCC/Class 47

Opening UCC Capital Additions Retirements/Removals (if applicable) UCC Before Half Year Rule Half Year Rule (1/2 Additions - Disposals) Reduced UCC CCA Rate Class CCA Rate CCA Closing UCC

## UCC/Class 8

Opening UCC Capital Additions RTU's Retirements/Removals (if applicable) UCC Before Half Year Rule Half Year Rule (1/2 Additions - Disposals) Reduced UCC CCA Rate Class CCA Rate CCA Closing UCC

2014 Audited Actual				
\$ \$	- 10,882,256			
φ	10,882,238			
\$	10,882,256			
\$ \$	5,441,128			
\$	5,441,128			
	47			
	8%			
\$	435,290.24			
\$	10,446,966			

2014 Audited Actual

\$ -
\$ 74,025
\$ 74,025
\$ 37,013
\$ 37,013
8
20%
\$ 7,403
\$ 66,623



ICM True-Up Model for Electricity Distributors

## Sheet 6: Incremental Capital Adjustment

Return on Rate Base				
Incremental Capital CAPEX			\$ 10,956,281	В
Depreciation Expense			\$ 346,001	С
Incremental Capital CAPEX to be included in Rate Base			\$ 10,610,281	D = B - C
Deemed ShortTerm Debt %	4.0%	Е	\$ 424,411	G = D * E
Deemed Long Term Debt %	56.0%	F	\$ 5,941,757	H = D * F
Short Term Interest	2.08%	Т	\$ 8,828	K = G * I
Long Term Interest	4.15%	J	\$ 246,583	L = H * J
Return on Rate Base - Interest			\$ 255,411	M = K + L
Deemed Equity %	40.0%	N	\$ 4,244,112	P = D * N
Return on Rate Base -Equity	8.93%	ο	\$ 378,999	Q = P * O
Return on Rate Base - Total			\$ 634,410	R = M + Q

	С	\$	346,001	S
	0	\$	378 999	т
	•	Ŷ	010,000	•
	s	\$	346,001	U
		\$	442,693	v
		\$	282,307	W = T + U - V
26.0%	х			
		\$	73,400	Y = W * X
		\$	99,189	Z = Y / (1 - X)
		\$	10,956,281	AA
		\$	-	AB
		\$	10,956,281	AC = AA - AB
0.000%	AD			
		\$	-	AE = AC * AD
٦				
	Q	\$	634,410	AF
	s	\$	346,001	AG
	z	\$	99,189	AH
	AE	\$	-	AI
	1	0 S 26.0% X 0.000% AD	O S S S S 26.0% X S S 0.000% AD S Q S	O \$ 378,999 S \$ 346,001 \$ 442,693 \$ 282,307 26.0% X \$ 73,400 \$ 99,189

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 15 of 17



## ICM True-Up Model for Electricity Distributors

This worksheet calculates the funding adder revenues.

### Sheet 7: ICM Funding Adder Revenues

### Account 1511 - Sub-account ICM Funding Adder Revenues

Prescribed Interest Rates	Approved Deferral and Variance Accounts	CWIP	Date	Year	Quarter		ning Balance Principal)	Funding Adder Revenues	Interest Rate	Interest	Principal & Interest (Cumm.)	d Approved I Funding Adder	ICI	rd Approved M Funding Adder Cumm.)
2006 Q1			Jan-14	2014	Q1	\$	-	\$ -	1.47% \$	-	\$ -	\$ -	\$	-
2006 Q2	4.14%	4.68%	Feb-14		Q1	\$	-	\$ -	1.47% \$		\$	\$ -	\$	-
2006 Q3	4.59%	5.05%	Mar-14	2014	Q1	\$	-	\$ 81,633.07	1.47% \$	-	\$ 81,633.07	\$ 83,403.75	\$	83,403.75
2006 Q4	4.59%	4.72%	Apr-14	2014	Q2	\$	81,633.07	\$ 79,489.14	1.47% \$	100.00	\$ 161,222.21	\$ 83,403.75	\$	166,807.50
2007 Q1	4.59%	4.72%	May-14	2014	Q2	\$	161,122.21	\$ 101,852.75	1.47% \$	197.37	\$ 263,272.33	\$ 83,403.75	\$	250,211.24
2007 Q2	4.59%	4.72%	Jun-14	2014	Q2	\$	262,974.96	\$ 88,915.12	1.47% \$	322.14	\$ 352,509.59	\$ 83,403.75	\$	333,614.99
2007 Q3	4.59%	5.18%	Jul-14	2014	Q3	\$	351,890.08	\$ 96,907.28	1.47% \$	431.07	\$ 449,847.94	\$ 83,403.75	\$	417,018.74
2007 Q4	5.14%	5.18%	Aug-14	2014	Q3	\$	448,797.36	\$ 102,961.39	1.47% \$	549.78	\$ 553,359.11	\$ 83,403.75	\$	500,422.49
2008 Q1	5.14%	5.18%	Sep-14		Q3	\$	551,758.75	\$ 98,095.57	1.47% \$	675.90	\$ 652,130.58	\$ 83,403.75	\$	583,826.24
2008 Q2	4.08%	5.18%	Oct-14	2014	Q4	\$	649,854.32	\$ 93,325.99	1.47% \$	796.07	\$ 746,252.64	\$ 83,403.75	\$	667,229.98
2008 Q3	3.35%	5.43%	Nov-14	2014	Q4	\$	743,180.31	\$ 87,338.40	1.47% \$	910.40	\$ 834,501.44	\$ 83,403.75	\$	750,633.73
2008 Q4	3.35%	5.43%	Dec-14	2014	Q4	\$	830,518.71	\$ 96,981.68	1.47% \$	1,017.39	\$ 932,500.51	\$ 83,403.75	\$	834,037.48
2009 Q1	2.45%	6.61%	Jan-15	2015	Q1	\$	927,500.39	\$ 77,333.33	1.47% \$	1,136.19	\$ 1,010,970.03	\$ 69,503.12	\$	903,540.60
2009 Q2	1.00%	6.61%	Feb-15	2015	Q1	\$	1,004,833.72	\$ 77,333.33	1.47% \$	1,230.92	\$ 1,089,534.29	\$ 69,503.12	\$	973,043.73
2009 Q3	0.55%	5.67%	Mar-15	2015	Q1	\$	1,082,167.06	\$ 77,333.33	1.47% \$	1,325.65	\$ 1,168,193.27	\$ 69,503.12	\$ 1	,042,546.85
2009 Q4	0.55%	4.66%	Apr-15	2015	Q2	\$	1,159,500.39	\$ 77,333.33	1.47% \$	1,420.39	\$ 1,246,946.99	\$ 69,503.12	\$ 1	,112,049.97
2010 Q1	0.55%	4.34%	May-15	2015	Q2	\$	1,236,833.72	\$ 77,333.33	1.47% \$	1,515.12	\$ 1,325,795.45	\$ 69,503.12	\$ 1	,181,553.10
2010 Q2	0.55%	4.34%	Jun-15	2015	Q2	\$	1,314,167.06	\$ 77,333.33	1.47% \$	1,609.85	\$ 1,404,738.63	\$ 69,503.12	\$ 1	251,056.22
2010 Q3	0.89%	4.66%	Jul-15	2015	Q3	\$	1,391,500.39	\$ 77,333.33	1.47% \$	1,704.59	\$ 1,483,776.55	\$ 69,503.12	\$ 1	320,559.34
2010 Q4	1.20%	4.01%	Aug-15	2015	Q3	\$	1,468,833.72	\$ 77,333.33	1.47% \$	1,799.32	\$ 1,562,909.21	\$ 69,503.12	\$ 1	390,062.47
2011 Q1	1.47%	4.29%	Sep-15	2015	Q3	\$	1,546,167.06	\$ 77,333.33	1.47% \$	1,894.05	\$ 1,642,136.59	\$ 69,503.12	\$ 1	459,565.59
2011 Q2	1.47%	4.29%	Oct-15	2015	Q4	\$	1,623,500.39	\$ 77,333.33	1.47% \$	1,988.79	\$ 1,721,458.71	\$ 69,503.12	\$ 1	529,068.71
2011 Q3	1.47%	4.29%	Nov-15	2015	Q4	\$	1,700,833.72	\$ 77,333.33	1.47% \$	2,083.52	\$ 1,800,875.57	\$ 69,503.12	\$ 1	598,571.84
2011 Q4	1.47%	3.92%	Dec-15	2015	Q4	\$	1,778,167.06	\$ 77,333.33	1.47% \$	2,178.25	\$ 1,880,387.15	\$ 69,503.12	\$ 1	668,074.96
2012 Q1	1.47%	3.92%												
2012 Q2	1.47%	3.23%												
2012 Q3	1.47%	3.23%												
2012 Q4	1.47%	3.70%												
2013 Q1	1.47%	3.70%												
2013 Q2	1.47%	3.17%												
2013 Q3	1.47%	3.17%												
2013 Q4	1.47%	3.17%												
2014 Q1	1.47% 1.47%	2.89%												
2014 Q2 2014 Q3	1.47%	2.89% 2.89%												
2014 Q3	1.47%	2.89%												
2014 Q4	1.47%	2.89%												
2015 Q1 2015 Q2	1.47%	2.89%												
2015 Q2 2015 Q3	1.47%	2.89%												
2015 Q3 2015 Q4	1.47%	2.89%												
2010 04	1.4770	2.0378	Total Fund	ing Ad	der Reve	enues C	ollected	\$ 1,855,500.39	\$	24,886.76	\$ 1,880,387.15			

NOTE: Funding adder revenues are up to December 2014 actuals

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 16 of 17



## ICM True-Up Model for Electricity Distributors

This worksheet calculates the interest on amortization/depreciation expense, in the absence of monthly data.

## Sheet 8: Interest on Amortization (Annual Data)

Year	OM&A		Amor Expei	tization 1se	 ulative OM&A Amortization nse	 ulative OM&A Amortization	Average Annual Prescribed Interest Rate for Deferral and Variance Accounts (from Sheets 8A and 8B)	OM&A	ization
			(from	Sheet 6)					
2014	\$	-	\$	346,000.76	\$ 346,000.76	\$ 173,000.38	1.47%	\$	2,543.11
2015	\$	-	\$	346,000.76	\$ 692,001.53	\$ 519,001.15	1.47%	\$	7,629.32
Cumulati	ive Interest to 2014							\$	2,543.11
Cumulati	ive Interest to 2015							\$	10,172.42

EB-2015-0003 PowerStream Inc. ICM True-Up Model G-2b-1 Page 17 of 17



## ICM True-Up Model for Electricity Distributors

This worksheet calculates the ICM Incremental Revenue Requirement.

## Sheet 9: ICM Incremental Revenue Requirement True-up

	2014	2015	Total
Deferred and forecasted ICM Incremental Revenue Requirement (from Sheet 6)	\$ 1,079,600	\$ 1,079,600	\$ 2,159,199
Interest on Deferred and forecasted Amortization Expense (Sheet 8)	\$ 2,543	\$ 7,629	\$ 10,172
ICM Funding Adder Revenues (from Sheet 7)	\$ 927,500	\$ 928,000	\$ 1,855,500
ICM Funding Adder Interest (from Sheet 7)	\$ 5,000	\$ 19,887	\$ 24,887
Net Deferred Revenue Requirement	\$ 149,642	\$ 139,342	\$ 288,985

### Appendix G-4: Cost of Power Historic and Forecast by Account

Account		2010 Actual	2011 Actual	2012 Actual	2013 Actual	2014 Actual	2015 Bridge Year	2016 Test Year	2017 Test Year	2018 Test Year	2019 Test Year	2020 Test Year
4705	Commodity	566,291,804	623,332,033	667,399,795	741,502,767	527,616,463	489,025,785	573,465,911	609,945,760	645,172,167	676,835,947	683,003,777
4707	Global Adjustment Non-RPP					253,334,229	353,503,551	373,730,754	343,702,034	354,927,915	350,057,342	361,558,775
4708	WMS including RRRP	47,590,790	48,080,106	45,115,072	45,789,416	48,291,356	50,187,908	50,281,293	50,142,785	50,007,538	49,842,037	49,705,534
4714	Transmission Network	51,006,312	52,534,019	58,748,678	62,280,620	63,647,721	66,371,567	67,622,986	68,583,522	69,564,627	70,519,365	71,531,065
4716	Transmission Connection	24,847,123	25,559,804	26,233,013	26,199,446	26,908,153	29,417,591	30,021,199	30,502,104	30,998,668	31,490,271	32,014,411
4750	Low Voltage	1,582,384	1,951,377	1,986,409	2,301,273	2,303,704	4,182,723	4,654,991	4,882,065	5,103,784	5,334,655	5,320,773
4751	SME				2,149,419	3,178,054	3,250,964	3,440,602	3,507,875	2,979,432	-	-
Total	Cost of Power	691,318,413	751,457,339	799,482,967	880,222,940	925,279,679	995,940,089	1,103,217,737	1,111,266,145	1,158,754,131	1,184,079,615	1,203,134,336

### EB-2015-0003 PowerStream Inc. G-4-1 Page 2 of 7

### Appendix G-4: 2015 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
VOLUMES													
Energy Purchased PS South (kWh)													
Energy Purchased PS North(kWh)													
Total Purchases (kWh)1	761,018,584	720,482,683	721,054,626	658,815,876	680,701,941	777,724,538	871,881,404	826, 166, 538	693,029,962	656,082,058	667,212,098	770,725,828	8,804,896,137
· · /													
RPP Customer Base	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	
Non-RPP Customer Base <sup>2</sup>	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	
RPP kWh	352,982,125	334,180,417	334,445,701	305,577,594	315,728,975	360,730,823	404,403,463	383,199,604	321,447,063	304,309,571	309,472,001	357,484,621	4,083,961,957
Non-RPP kWh	408,036,459	386,302,265	386,608,925	353,238,283	364,972,966	416,993,716	467,477,942	442,966,934	371,582,899	351,772,487	357,740,097	413,241,207	4,720,934,180
		,.,,	,	,,				,,.		,		-, , .	, .,,
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	
System Line/System kW - IESO	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	
System Transformer/System kW - IESO	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	
System kW/Energy Purchased kWh - HONI	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
-3													
kW Quantities													
Transmission Network - IESO	1,316,143	1,246,038	1,247,027	1,139,389	1,177,240	1,345,035	1,507,875	1,428,813	1,198,560	1,134,661	1,153,910	1,332,931	15,227,622
Transmission Line Connection - IESO	1,404,138	1.329.346	1.330.401	1,215,566	1.255.947	1,434,962	1,608,688	1,524,341	1,278,694	1.210.522	1,231.058	1,422,048	16.245.710
Transmission Transformation Connection - IES	386,793	366,190	366,481	334,847	345,971	395,284	443,139	419,905	352,237	333,458	339,115	391,726	4,475,146
Transmission Network - HONI	220,857	209,093	209,259	191,197	197,548	225,705	253,031	239,764	201,126	190,403	193,633	223,674	2,555,291
Transmission Line Connection - HONI	220,007	209,685	209,259	191,738	198,107	226,344	253,747	240,442	201,695	190,942	194,181	224,307	2,562,520
LV Charges - HONI	303,158	287,010	287,238	262,445	271,163	309,813	347,321	329,110	276,074	261,356	265,789	307,025	3,507,501
EV Charges - HON	303,130	207,010	207,230	202,445	271,103	309,013	347,321	323,110	270,074	201,330	203,703	307,023	3,307,301
RATES													
Commodity (RPP)	0.09496	0.09496	0.09496	0.09496	0.09496	0.09496	0.09496	0.09496	0.09496	0.09496	0.09930	0.09930	0.09568
Commodity (Non-RPP)	0.02548	0.02059	0.02059	0.02059	0.01951	0.01951	0.01951	0.01696	0.01696	0.01696	0.02669	0.02669	0.02084
Global Adjustment Rate/kWh	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488	0.07488
Transmission Network - IESO	3.78000	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800	3.7800
Transmission Line Connection - IESO	0.86000	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600	0.8600
Transmission Transformation Connection- IESO	2.00000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000	2.0000
Transmission Network - HONI	3.448	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
Transmission Line Connection - HONI	0.751	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
Transmission Transformation Connection - HONI	1.784	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
LV Charges - HONI	1.123	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227	1.1227
Wholesale Market Charge (per kWh)	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057
Monthly Service charges (fixed per account)	453.7000	453.70	453.70	453.70	453.70	453.70	453.70	453.70	453.70	453.70	453.70	453.70	453.70
LVDS (per kW)	2.0247	2.02	2.02	2.02	2.02	2.02	2.02	2.02	2.02	2.02	2.02	2.02	2.0247
Specific ST Lines (per km)	960.9097	960.91	960.91	960.91	960.91	960.91	960.91	960.91	960.91	960.91	960.91	960.91	960.91
COP EXPENSE													
Commodity (RPP)	\$ 33,519,183 \$	31,733,772 \$	31,758,964 \$	29,017,648 \$	29,981,623 \$	34,254,999 \$	38,402,153 \$	36,388,634 \$	30,524,613 \$	28,897,237 \$	30,730,104 \$	35,497,685 \$	390,706,616
Commodity (Non-RPP)	10,396,769	7,953,964	7,960,278	7,273,176	7,120,623	8,135,547	9,120,495	7,512,719	6,302,046	5,966,061	9,548,083	11,029,408 \$	98,319,169
Commodity Global Adjustment (Non-RPP)	30,553,770	28,926,314	28,949,276	26,450,483	27,329,176	31,224,489	35,004,748	33,169,364	27,824,128	26,340,724	26,787,578	30,943,502 \$	353,503,551
Transmission Network - IESO	4,975,021	4,710,025	4,713,764	4,306,889	4,449,965	5,084,233	5,699,767	5,400,914	4,530,558	4,289,017	4,361,778	5,038,480 \$	57,560,411
Transmission Line Connection - IESO	1,207,558	1,143,237	1,144,145	1,045,387	1,080,115	1,234,067	1,383,472	1,310,933	1,099,676	1,041,049	1,058,710	1,222,962 \$	13,971,311
Transmission Transformation Connection- IESO	773,585	732,380	732,961	669,695	691,942	790,567	886,279	839,809	704,474	666,916	678,230	783,453 \$	8,950,292
Transmission Network - HONI	761,560	720,995	721,567	659,284	681,186	778,277	872,501	826,754	693,523	656,548	667,686	771,274 \$	8,811,155
Transmission Line Connection - HONI	166,377	157,515	157,640	144,033	148,818	170,030	190,615	180,620	151,513	143,436	145,869	168,499 \$	1,924,965
Transmission Transformation Connection - HONI	395,079	374,035	374,332	342,021	353,383	403,752	452,633	428,901	359,783	340,602	346,380	400,119 \$	4,571,023
LV Charges - HONI	340,355	322.226	322.482	294,647	304,435	347,827	389,937	369,492	309,948	293.424	298,402	344,697 \$	3.937.871
Wholesale Market Charge	4,337,806	4,106,751	4,110,011	3,755,250	3.880.001	4,433,030	4,969,724	4,709,149	3.950.271	3,739,668	3.803.109	4,393,137 \$	50,187,908
Monthly Service charges (26 accounts)	11,796	11,796	11,796	11,796	11,796	11,796	11,796	11,796	11,796	11,796	11,796	11,796 \$	141,554
LVDS (on average 1500 kW)	3,037	3,873	3,873	3,873	3,873	3,873	3,873	3,873	3,873	3,873	3,873	3,873 \$	45,643
Specific ST Lines (5km)	4,805	4,805	4,805	4,805	4,805	4,805	4,805	4,805	4,805	4,805	4,805	4,805 \$	57,655
SME	270,914	270,914	270,914	270,914	270,914	270,914	270,914	270,914	270,914	270,914	270,914	270,914 \$	3,250,964
	\$ 87,717,615 \$		81,236,809 \$	74,249,902 \$	76,312,655 \$	87,148,207 \$	97,663,711 \$	91,428,677 \$	76,741,921 \$	72,666,070 \$	78,717,317 \$	90,884,603 \$	995,940,089
	- σ.,,σ.σ φ	.,	, <b>_</b> οο,οοο ψ	,		J.,,20. V	,000, V	,	,	. 1,000,010 W	,	- 3,00 .,000 W	000,010,000

### Appendix G-4: 2016 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
/OLUMES Energy Purchased PS South (kWh)													
nergy Purchased PS North(kWh) otal Purchases (kWh) <sup>1</sup>	761,541,737	731,221,172	721,978,612	659,600,164	681,639,924	778,711,763	872,775,976	826,771,265	693,464,178	656,288,778	667,139,807	770, 146, 110	8,821,279,486
PP Customer Base	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	
on-RPP Customer Base2	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	
PP kWh	353,224,778	339,161,235	334,874,272	305,941,369	316,164,038	361,188,726	404,818,391	383,480,094	321,648,464	304,405,454	309,438,470	357,215,731	4,091,561,022
on-RPP kWh	408,316,959	392,059,937	387,104,340	353,658,795	365,475,886	417,523,037	467,957,586	443,291,172	371,815,713	351,883,324	357,701,337	412,930,378	4,729,718,465
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO System Line/System kW - IESO	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	0.17% 106.69%	
System Transformer/System kW - IESO	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	
System kW/Energy Purchased kWh - HONI	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
kW Quantities													
Transmission Network - IESO	1,317,048	1,264,610	1,248,625	1,140,745	1,178,862	1,346,743	1,509,422	1,429,859	1,199,311	1,135,018	1,153,785	1,331,929	15,255,956
Transmission Line Connection - IESO	1,405,103	1,349,159	1,332,106	1,217,013	1,257,678	1,436,783	1,610,339	1,525,457	1,279,495	1,210,903	1,230,924	1,420,979	16,275,939
Transmission Transformation Connection - IESO	387,059	371,648	366,950	335,246	346,448	395,785	443,594	420,212	352,458	333,563	339,078	391,432	4,483,473
Transmission Network - HONI	221,009 221,634	212,210 212,810	209,527 210,120	191,424	197,820 198,380	225,992 226,631	253,291 254,007	239,939	201,252	190,463	193,612 194,160	223,506	2,560,046 2,567,288
Transmission Line Connection - HONI LV Charges - HONI	303,366	291,288	287,606	191,966 262,757	271,537	310,206	347,677	240,618 329,351	201,821 276,247	191,002 261,438	265,760	224,138 306,794	2,567,268 3,514,027
ATES													
Commodity (RPP)	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888	0.10888
Commodity (Non-RPP)	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706	0.02706
lobal Adjustment Rate/kWh	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902	0.07902
ransmission Network - IESO	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539	3.8539
ransmission Line Connection - IESO	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725	0.8725
ransmission Transformation Connection- IESO	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772	2.0772
ransmission Network - HONI	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
ransmission Line Connection - HONI	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
ransmission Transformation Connection - HONI	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
V Charges - HONI Vholesale Market Charge (per kWh)	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057	1.2500 0.0057
Inthly Service charges (fixed per account)	441.7000	441.70	441.70	441.70	441.70	441.70	441.70	441.70	441.70	441.70	441.70	441.70	441.70
VDS (per kW)	1.5666	1.57	1.57	1.57	1.57	1.57	1.57	1.57	1.57	1.57	1.57	1.57	1.5666
Specific ST Lines (per km)	821.1486	821.15	821.15	821.15	821.15	821.15	821.15	821.15	821.15	821.15	821.15	821.15	821.15
OP EXPENSE													
	\$ 38,457,971 \$		36,460,027 \$	33,309,906 \$	34,422,918 \$	39,325,060 \$	44,075,317 \$	41,752,072 \$	35,020,044 \$	33,142,681 \$	33,690,660 \$	38,892,493 \$	445,475,927
Commodity (Non-RPP)	11,049,385	10,609,457	10,475,355	9,570,291	9,890,071	11,298,509	12,663,309	11,995,816	10,061,632	9,522,246	9,679,686	11,174,228 \$	127,989,984
Commodity Global Adjustment (Non-RPP)	32,264,205	30,979,615	30,588,036	27,945,251	28,879,008	32,991,647	36,976,861	35,027,781	29,379,966	27,804,957	28,264,682	32,628,746 \$	373,730,754
Transmission Network - IESO	5,075,814	4,873,722	4,812,119	4,396,355	4,543,254	5,190,256	5,817,211	5,510,581	4,622,065	4,374,284	4,446,608	5,133,164 \$	58,795,435
Transmission Line Connection - IESO	1,225,907 803,983	1,177,098 771,973	1,162,219 762,215	1,061,804 696,360	1,097,283 719,628	1,253,547 822,110	1,404,968 921,416	1,330,911 872,848	1,116,318 732,111	1,056,474 692,864	1,073,941 704,320	1,239,758 \$ 813,067 \$	14,200,229 9,312,895
ransmission Network - HONI	762.083	731.741	702,215	660.069	682.124	779.265	873.396	827.359	693.957	656.755	667.614	770.694 \$	8.827.550
ransmission Line Connection - HONI	166,492	159,863	157,842	144,205	149,023	170,245	190,810	180,752	151,608	143,481	145,853	168,373 \$	1,928,547
ransmission Transformation Connection - HONI	395,351	379,610	374,812	342,429	353,870	404,265	453,098	429,215	360,009	340,709	346,343	399,818 \$	4,579,529
V Charges - HONI	379,208	364,110	359,507	328,446	339,421	387,758	434,597	411,689	345,309	326,797	332,201	383,492 \$	4,392,534
Wholesale Market Charge	4,340,788	4,167,961	4,115,278	3,759,721	3,885,348	4,438,657	4,974,823	4,712,596	3,952,746	3,740,846	3,802,697	4,389,833 \$	50,281,293
Monthly Service charges (26 accounts)	11,484	11,484	11,484	11,484	11,484	11,484	11,484	11,484	11,484	11,484	11,484	11,484 \$	137,810
VDS (on average 1500 kW)	2,997	2,997	2,997	2,997	2,997	2,997	2,997	2,997	2,997	2,997	2,997	2,997 \$	35,963
Specific ST Lines (5km)	7,390	7,390	7,390	7,390	7,390	7,390	7,390	7,390	7,390	7,390	7,390	7,390 \$	88,684
SME	286,717 \$ 95,229,775 \$	286,717 91,450,515 \$	286,717 90,298,491 \$	286,717 82,523,426 \$	286,717 85,270,538 \$	286,717 97,369,906 \$	286,717 109,094,394 \$	286,717 103,360,208 \$	286,717 86,744,353 \$	286,717 82,110,683 \$	286,717 83,463,193 \$	286,717 \$ 96,302,254 \$	3,440,602 1,103,217,737
Total Cost of Power	\$ 90,229,115 \$	51,400,010 \$	30,290,491 <b>\$</b>	02,323,420 \$	03,210,330 \$	31,303,300 \$	103,034,334 \$	103,300,200 \$	00,144,303 \$	02,110,003 \$	03,403,193 \$	30,302,234 \$	1,103,217,737

### EB-2015-0003 PowerStream Inc. G-4-1 Page 4 of 7

### Appendix G-4: 2017 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
VOLUMES													
Energy Purchased PS South (kWh)													
Energy Purchased PS North(kWh)													
Total Purchases (kWh) <sup>1</sup>	761,071,123	720,642,992	721,384,111	658,725,413	680,785,221	777,853,858	871,768,040	825,419,033	691,937,471	654,530,295	665,105,381	767,756,965	8,796,979,903
RPP Customer Base	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	
Non-RPP Customer Base2	40.38 % 53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	40.38 % 53.62%	53.62%	
	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	00.0270	
RPP kWh	353,006,494	334,254,773	334,598,526	305,535,634	315,767,603	360,790,805	404,350,881	382,852,890	320,940,334	303,589,819	308,494,846	356,107,578	4,080,290,182
Non-RPP kWh	408,064,629	386,388,218	386,785,585	353,189,778	365,017,619	417,063,053	467,417,159	442,566,143	370,997,137	350,940,476	356,610,536	411,649,387	4,716,689,721
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	
System Line/System kW - IESO	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	
System Transformer/System kW - IESO	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	
System kW/Energy Purchased kWh - HONI	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
kW Quantities													
Transmission Network - IESO	1,316,234	1,246,316	1,247,597	1,139,232	1,177,384	1,345,259	1,507,679	1,427,520	1,196,671	1,131,977	1,150,266	1,327,797	15,213,931
Transmission Line Connection - IESO	1.404.235	1,329,642	1.331.009	1,215,399	1.256.101	1,435,200	1,608,479	1,522,962	1,276,678	1,207,659	1,227,171	1,416,571	16.231.104
Transmission Transformation Connection - IESO	386,819	366,272	366,648	334,802	346,014	395,349	443,082	419,525	351,682	332,669	338,044	390,218	4,471,123
Transmission Network - HONI	220,872	209,140	209,355	191,170	197,572	225,743	252,998	239,547	200,809	189,953	193,022	222,813	2,552,994
Transmission Line Connection - HONI	221,497	209,731	209,947	191,711	198,131	226,382	253,714	240,225	201,377	190,490	193,568	223,443	2,560,216
LV Charges - HONI	303,179	287,074	287,369	262,409	271,196	309,864	347,276	328,812	275,639	260,737	264,950	305,842	3,504,347
RATES													
Commodity (RPP)	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992	0.10992
Commodity (Non-RPP)	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423	0.03423
Global Adjustment Rate/kWh	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287	0.07287
Transmission Network - IESO	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293	3.9293
Transmission Line Connection - IESO	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851	0.8851
Fransmission Transformation Connection- IESO	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573	2.1573
Transmission Network - HONI	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
Transmission Line Connection - HONI	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
Transmission Transformation Connection - HONI	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
LV Charges - HONI	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182	1.3182
Wholesale Market Charge (per kWh)	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057
Monthly Service charges (fixed per account)	424.8700	424.87	424.87	424.87	424.87	424.87	424.87	424.87	424.87	424.87	424.87	424.87	424.87
LVDS (per kW)	1.5967	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.5967
Specific ST Lines (per km)	865.0076	865.01	865.01	865.01	865.01	865.01	865.01	865.01	865.01	865.01	865.01	865.01	865.01
OP EXPENSE													
Commodity (RPP)	\$ 38,802,860 \$	36,741,650 \$	36,779,436 \$	33,584,811 \$	34,709,520 \$	39,658,520 \$	44,446,691 \$	42,083,608 \$	35,278,112 \$	33,370,925 \$	33,910,091 \$	39,143,734 \$	448,509,956
Commodity (Non-RPP)	13,966,626	13,224,718	13,238,319	12,088,452	12,493,277	14,274,611	15,998,056	15,147,492	12,697,935	12,011,466	12,205,532	14,089,320 \$	161,435,804
Commodity Global Adjustment (Non-RPP)	29,735,397	28,155,852	28,184,808	25,736,704	26,598,590	30,391,106	34,060,377	32,249,500	27,034,314	25,572,798	25,985,972	29,996,616 \$	343,702,034
Transmission Network - IESO	5,171,894	4,897,163	4,902,199	4,476,399	4,626,308	5,285,942	5,924,141	5,609,174	4,702,093	4,447,891	4,519,755	5,217,328 \$	59,780,289
Transmission Line Connection - IESO	1,242,910	1,176,887	1,178,097	1,075,769	1,111,795	1,270,318	1,423,690	1,347,997	1,130,008	1,068,918	1,086,188	1,253,829 \$	14,366,408
Transmission Transformation Connection- IESO	834,485	790,157	790,970	722,267	746,455	852,887	955,860	905,040	758,683	717,667	729,262	841,816 \$	9,645,547
Transmission Network - HONI	761,612	721,155	721,897	659,194	681,269	778,407	872,388	826,006	692,429	654,996	665,578	768,303 \$	8,803,234
Transmission Line Connection - HONI	166,389	157,550	157,712	144,013	148,836	170,058	190,590	180,457	151,274	143,096	145,408	167,850 \$	1,923,234
Transmission Transformation Connection - HONI	395,107	374,119	374,503	341,974	353,427	403,819	452,575	428,513	359,216	339,797	345,287	398,578 \$	4,566,913
LV Charges - HONI	399,650	378,421	378,810	345,907	357,491	408,463	457,779	433,440	363,347	343,704	349,257	403,161 \$	4,619,430
Wholesale Market Charge	4,338,105	4,107,665	4,111,889	3,754,735	3,880,476	4,433,767	4,969,078	4,704,888	3,944,044	3,730,823	3,791,101	4,376,215 \$	50,142,785 132,559
Monthly Service charges (26 accounts) LVDS (on average 1500 kW)	11,047 3.054	11,047 3,054	11,047 \$ 3,054 \$	132,559 36.654									
Specific ST Lines (5km)	3,054	3,054	3,054	3,054	3,054	3,054	3,054	3,054	3,054	3,054	3,054	3,054 \$ 7,785 \$	36,654
SME	292.323	292,323	292,323	292,323	292,323	292,323	292,323	292,323	292,323	292,323	292,323	292,323 \$	3,507,875
Total Cost of Power	\$ 96.129.245 \$	91.039.546 \$	91.132.850 \$	83.244.434 \$	86.021.653 \$	98.242.107 \$	110.065.432 \$	104,230,324 \$	87.425.665 \$	82.716.289 \$	84.047.640 \$	96.970.959 \$	1.111.266.145

### Appendix G-4: 2018 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
OLUMES													
Energy Purchased PS South (kWh) Energy Purchased PS North(kWh)													
Fotal Purchases (kWh) <sup>1</sup>	760, 127, 229	719,559,056	720,247,196	657,226,532	679,237,312	776,242,708	869,942,017	823,176,492	689,463,342	651,765,641	662,004,601	764,260,123	8,773,252,250
	700,127,220	110,000,000	720,217,100	007,220,002	010,201,012	110,212,100	000,012,017	020,770,702	000, 100,012	001,700,011	002,001,001	101,200,120	0,110,202,200
PP Customer Base	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	
Ion-RPP Customer Base2	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	
PP kWh	352,568,689	333,752,013	334,071,192	304,840,411	315,049,638	360,043,508	403,503,920	381,812,735	319,792,763	302,307,493	307,056,615	354,485,643	4,069,284,620
Ion-RPP kWh	407,558,540	385,807,043	386,176,004	352,386,121	364,187,674	416,199,201	466,438,098	441,363,757	369,670,580	349,458,147	354,947,986	409,774,480	4,703,967,630
	,,					,	,	,		,,			.,,,
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	
System Line/System kW - IESO System Transformer/System kW - IESO	106.69% 29.39%												
System kW/Energy Purchased kWh - HONI	29.39%	0.03%	0.03%	29.39%	29.39%	0.03%	0.03%	0.03%	0.03%	29.39%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
kW Quantities													
Transmission Network - IESO	1,314,602	1,244,441	1,245,631	1,136,640	1,174,707	1,342,472	1,504,521	1,423,642	1,192,392	1,127,196	1,144,903	1,321,749	15,172,895
Transmission Line Connection - IESO	1,402,493	1,327,642	1,328,911	1,212,633	1,253,245 345,227	1,432,227	1,605,110	1,518,824	1,272,113	1,202,558	1,221,449	1,410,119	16,187,325 4,459,063
Transmission Transformation Connection - IESO Transmission Network - HONI	386,340 220,598	365,721 208,825	366,070 209,025	334,040 190,735	345,227 197,123	394,530 225,275	442,154 252,468	418,385 238,896	350,424 200,091	331,264 189,151	336,468 192,122	388,440 221,798	4,459,063 2,546,108
Transmission Line Connection - HONI	221,223	209,416	209,616	191,275	197,681	225,913	253,182	239,572	200,657	189,686	192,666	222,425	2,553,311
LV Charges - HONI	302,803	286,642	286,916	261,811	270,580	309,222	346,548	327,919	274,653	259,636	263,715	304,449	3,494,895
ATES													
Commodity (RPP)	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559	0.11559
commodity (Non-RPP)	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716	0.03716
ilobal Adjustment Rate/kWh iransmission Network - IESO	0.07545 4.006	0.07545 4.0062	0.07545 4.0062										
ransmission Line Connection - IESO	0.898	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979	0.8979
ransmission Transformation Connection- IESO	2.241	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405	2.2405
Fransmission Network - HONI	3.448	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
Fransmission Line Connection - HONI	0.751	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
ransmission Transformation Connection - HONI	1.784	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
V Charges - HONI	1.385	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849	1.3849
Wholesale Market Charge (per kWh)	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057 427.79
Monthly Service charges (fixed per account) _VDS (per kW)	427.7900 1.6319	427.79 1.63	427.79										
Specific ST Lines (per km)	858.9937	858.99	858.99	858.99	858.99	858.99	858.99	858.99	858.99	858.99	858.99	858.99	858.99
,													
COP EXPENSE													
	\$ 40,752,402 \$	38,577,437 \$	38,614,330 \$	35,235,628 \$	36,415,683 \$	41,616,395 \$	46,639,859 \$	44,132,638 \$	36,963,927 \$	34,942,855 \$	35,491,793 \$	40,973,978 \$	470,356,925
Commodity (Non-RPP) Commodity Global Adjustment (Non-RPP)	15,146,245 30,751,466	14,337,886 29,110,253	14,351,598 29,138,093	13,095,852 26,588,548	13,534,438 27,479,010	15,467,361 31,403,429	17,334,407 35,194,099	16,402,560 33,302,167	13,738,201 27,892,711	12,987,039 26,367,624	13,191,060 26,781,849	15,228,596 \$ 30,918,666 \$	174,815,242 354,927,915
Fransmission Network - IESO	5,266,512	4,985,437	4,990,205	4,553,569	4,706,069	5,378,167	6,027,359	5,703,346	4,776,920	4,515,733	4,586,673	5,295,147 \$	60,785,138
Fransmission Line Connection - IESO	1,259,365	1,192,153	1,193,293	1,088,881	1,125,348	1,286,065	1,441,305	1,363,824	1,142,291	1,079,834	1,096,798	1,266,213 \$	14,535,369
Fransmission Transformation Connection- IESO	865,605	819,407	820,191	748,425	773,490	883,957	990,658	937,403	785,135	742,207	753,866	870,311 \$	9,990,657
Fransmission Network - HONI	760,668	720,071	720,759	657,694	679,720	776,795	870,560	823,762	689,953	652,229	662,475	764,803 \$	8,779,489
Fransmission Line Connection - HONI	166,182	157,313	157,464	143,686	148,498	169,706	190,191	179,966	150,734	142,492	144,730	167,086 \$	1,918,047
Transmission Transformation Connection - HONI	394,617	373,556	373,913	341,196	352,623	402,983	451,627	427,348	357,932	338,361	343,677	396,762 \$	4,554,595
V Charges - HONI	419,352 4,332,725	396,971 4.101.487	397,350 4,105,409	362,583	374,726 3.871.653	428,242 4.424,583	479,935 4,958,669	454,135 4,692,106	380,367	359,570 3,715,064	365,219 3.773.426	421,632 \$ 4.356,283 \$	4,840,080 50,007,538
Vholesale Market Charge Monthly Service charges (26 accounts)	4,332,725 11,123	4,101,487 11,123	4,105,409 11,123	3,746,191 11,123	3,871,653	4,424,583 11,123	4,958,669	4,692,106 11,123	3,929,941 11,123	3,715,064 11,123	3,773,426 11,123	4,356,283 \$ 11,123 \$	50,007,538 133,470
VDS (on average 1500 kW)	3,122	3,122	3,122	3,122	3,122	3,122	3,122	3,122	3,122	3,122	3,122	3,122 \$	37,462
pecific ST Lines (5km)	7,731	7,731	7,731	7,731	7,731	7,731	7,731	7,731	7,731	7,731	7,731	7,731 \$	92,771
SME	297,943	297,943	297,943	297,943	297,943	297,943	297,943	297,943	297,943	297,943		\$	2,979,432
	\$ 100,435,058 \$	95,091,889 \$	95,182,523 \$	86,882,172 \$	89,781,176 \$	102,557,602 \$	114,898,588 \$	108,739,175 \$	91,128,030 \$	86,162,927 \$	87,213,540 \$	100,681,451 \$	1,158,754,131

### Appendix G-4: 2019 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
/OLUMES													
Energy Purchased PS South (kWh)													
Energy Purchased PS North(kWh)													
Total Purchases (kWh) <sup>1</sup>	757,994,447	717,375,329	718,021,843	654,938,171	676,903,543	773,861,529	867,504,492	820,673,715	686,907,308	649,158,348	659,334,268	761,543,944	8,744,216,936
200 0	10.000/	10.000/	40.000/	10.000/	10.000/	40.000/	10.000/	10.000/	10.000/	10.000/	10.000/	10.000/	
RPP Customer Base Non-RPP Customer Base2	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	46.38% 53.62%	
NOI-RPP Customer Basez	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.02%	53.02%	53.02%	53.62%	
RPP kWh	351,579,443	332,739,138	333.039.010	303,779,004	313.967.169	358,939,049	402.373.326	380,651,876	318.607.201	301,098,157	305.818.039	353,225,802	4,055,817,213
Non-RPP kWh	406,415,003	384,636,191	384,982,833	351,159,167	362,936,373	414,922,480	465,131,166	440,021,839	368,300,107	348,060,191	353,516,230	408,318,142	4,688,399,723
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	
System Line/System kW - IESO	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	
System Transformer/System kW - IESO	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	
System kW/Energy Purchased kWh - HONI	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
kW Quantities													
Transmission Network - IESO	1,310,913	1,240,664	1,241,782	1,132,682	1,170,670	1,338,354	1,500,305	1,419,314	1,187,971	1,122,686	1,140,285	1,317,052	15,122,680
Transmission Line Connection - IESO	1,310,913	1,240,664	1,241,782	1,132,662	1,248,939	1,336,354	1,600,612	1,419,314	1,187,971	1,122,000	1,140,265	1,405.107	16,133,752
Transmission Transformation Connection - IESO	385,256	364,611	364,939	332,877	344,041	393,320	440,915	417,113	349,125	329,939	335,111	387,060	4,444,306
Transmission Network - HONI	219,979	208,191	208,379	190,071	196,446	224,584	251,761	238,170	199,349	188,394	191,347	221,010	2,537,681
Transmission Line Connection - HONI	220,602	208,780	208,968	190,609	197,002	225,220	252,473	238,844	199,913	188,927	191,888	221,635	2,544,860
LV Charges - HONI	301,953	285,772	286,030	260,900	269,650	308,274	345,577	326,922	273,635	258,597	262,651	303,367	3,483,329
ATES													
Commodity (RPP)	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908	0.11908
Commodity (Non-RPP)	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135	0.04135
ilobal Adjustment Rate/kWh	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466	0.07466
ransmission Network - IESO	4.085	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845	4.0845
ransmission Line Connection - IESO	0.911	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110	0.9110
ransmission Transformation Connection- IESO	2.327	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270	2.3270
ransmission Network - HONI	3.448	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
ransmission Line Connection - HONI	0.751	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
ransmission Transformation Connection - HONI	1.784	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
V Charges - HONI	1.455	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552
/holesale Market Charge (per kWh)	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057
Ionthly Service charges (fixed per account)	430.1000	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10
VDS (per kW)	1.6430	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.6430
pecific ST Lines (per km)	868.5871	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59
OP EXPENSE													
	\$ 41,865,328 \$	39,621,864 \$	39,657,573 \$	36,173,354 \$	37,386,539 \$	42,741,694 \$	47,913,755 \$	45,327,211 \$	37,939,064 \$	35,854,124 \$	36,416,158 \$	42,061,373 \$	482,958,034
ommodity (Non-RPP)	16,806,351	15,905,739	15,920,073	14,521,374	15,008,393	17,158,158	19,234,422	18,196,084	15,230,198	14,393,223	14,618,845	16,885,051 \$	193,877,912
ommodity Global Adjustment (Non-RPP)	30,344,801	28,718,695	28,744,577	26,219,148	27,098,488	30,980,008	34,728,818	32,854,041	27,498,969	25,987,764	26,395,137	30,486,898 \$	350,057,342
ransmission Network - IESO	5,354,454	5,067,522	5,072,089	4,626,467	4,781,630	5,466,539	6,128,030	5,797,219	4,852,296	4,585,638	4,657,521	5,379,528 \$	61,768,932
ransmission Line Connection - IESO	1,274,038	1,205,765	1,206,852	1,100,821	1,137,740	1,300,707	1,458,102	1,379,389	1,154,554	1,091,106	1,108,210	1,280,004 \$	14,697,289
ransmission Transformation Connection- IESO	896,478	848,438	849,202	774,594	800,572	915,244	1.025.995	970,609	812,403	767.758	779,793	900,676 \$	10,341,761
ransmission Network - HONI	758,533	717,885	718,532	655,404	677,385	774,412	868,121	821,257	687,396	649,620	659,803	762,085 \$	8,750,433
ransmission Line Connection - HONI	165,716	156,836	156,977	143,185	147,988	169,185	189,658	179,419	150,175	141,922	144,147	166,492 \$	1,911,699
ransmission Transformation Connection - HONI	393,509	372,422	372,758	340,008	351,412	401,747	450,361	426,049	356,605	337,008	342,290	395,352 \$	4,539,522
V Charges - HONI	439,402	415,856	416,230	379,661	392,395	448,600	502,884	475,737	398,194	376,311	382,210	441,460 \$	5,068,940
holesale Market Charge	4,320,568	4,089,039	4,092,725	3,733,148	3,858,350	4,411,011	4,944,776	4,677,840	3,915,372	3,700,203	3,758,205	4,340,800 \$	49,842,037
Ionthly Service charges (26 accounts)	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183 \$	134,191
VDS (on average 1500 kW)	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143 \$	37,717
Specific ST Lines (5km)	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817 \$	93,807
SME Fotal Cost of Power	·		07.000.701		01 000 000 0	101 700 117	447 407 005 4	444 400 000 +	00.017.000	07.000.010		\$	-
	\$ 102,641,322 \$	97,142,204 \$	97,229,731 \$	88,689,306 \$	91,663,033 \$	104,789,447 \$	117,467,065 \$	111,126,998 \$	93,017,368 \$	87,906,819 \$	89,284,461 \$	103,121,862 \$	1,184,079,615

### Appendix G-4: 2020 Cost of Power Forecast by Month

Components	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	ост	NOV	DEC	Total
/OLUMES													
nergy Purchased PS South (kWh)													
nergy Purchased PS North(kWh)	755 101 000	70 / 77 / 707	745 050 000	050 00 / 007	074 404 005	774 0 40 057	004 040 050	0.17 700 070	000 050 440	0.00.474.404	050 007 070	750 (50 (00	
otal Purchases (kWh)1	755,464,290	724,774,797	715,359,690	652,204,907	674, 121, 985	771,048,057	864,649,853	817,762,276	683,959,440	646, 174, 421	656,297,278	758,452,139	8,720,269,134
PP Customer Base	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	46.38%	
on-RPP Customer Base2	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	53.62%	
	33.0270	33.02 /0	55.02 /0	33.0270	33.0270	33.0270	33.0270	55.62 /6	33.0270	33.0270	33.0276	33.0270	
PP kWh	350,405,885	336,171,223	331,804,227	302,511,238	312,677,004	357,634,080	401,049,263	379,301,467	317,239,896	299,714,126	304,409,396	351,791,734	4,044,709,539
on-RPP kWh	405,058,405	388,603,575	383,555,463	349,693,669	361,444,982	413,413,977	463,600,590	438,460,808	366,719,544	346,460,295	351,887,882	406,660,404	4,675,559,594
Historic Ratios (kW) <sup>3</sup>													
System kW/Energy Purchased kWh - IESO	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	0.17%	
System Line/System kW - IESO	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	106.69%	
System Transformer/System kW - IESO	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	29.39%	
System kW/Energy Purchased kWh - HONI	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	0.03%	
System Line/System kW - HONI	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	100.28%	
Low Voltage/System kW - HONI	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	137.26%	
kW Quantities													
Transmission Network - IESO	1,306,537	1,253,461	1,237,178	1,127,955	1,165,860	1,333,489	1,495,368	1,414,278	1,182,873	1,117,526	1,135,033	1,311,705	15,081,264
Transmission Line Connection - IESO	1,393,890	1,337,265	1,319,894	1,203,368	1,243,807	1,422,643	1,595,345	1,508,834	1,261,958	1,192,241	1,210,919	1,399,402	16,089,567
Transmission Transformation Connection - IESO	383,970	368,372	363,586	331,487	342,627	391,890	439,464	415,633	347,627	328,422	333,567	385,488	4,432,134
Transmission Network - HONI	219,245	210,339	207,606	189,278	195,639	223,768	250,932	237,325	198,494	187,528	190,466	220,112	2,530,731
Transmission Line Connection - HONI	219,865	210,934	208,194	189,813	196,192	224,401	251,642	237,996	199,055	188,058	191,005	220,735	2,537,891
LV Charges - HONI	300,945	288,720	284,969	259,811	268,542	307,153	344,440	325,762	272,461	257,409	261,441	302,135	3,473,789
ATES													
ommodity (RPP)	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146	0.12146
Commodity (Non-RPP)	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101	0.04101
lobal Adjustment Rate/kWh	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733	0.07733
ransmission Network - IESO	4.164	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644	4.1644
ransmission Line Connection - IESO	0.924	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242	0.9242
ransmission Transformation Connection- IESO	2.417	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167	2.4167
ransmission Network - HONI	3.448	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482	3.4482
ransmission Line Connection - HONI	0.751	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512	0.7512
ransmission Transformation Connection - HONI	1.784	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838	1.7838
V Charges - HONI	1.455	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552	1.4552
/holesale Market Charge (per kWh)	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057
onthly Service charges (fixed per account)	430.1000	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10	430.10
VDS (per kW)	1.6430	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.64	1.6430
pecific ST Lines (per km)	868.5871	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59	868.59
OP EXPENSE													
Commodity (RPP)	\$ 42,560,095 \$	40,831,161 \$	40,300,748 \$	36,742,839 \$	37,977,567 \$	43.438.027 \$	48,711,210 \$	46,069,735 \$	38,531,773 \$	36,403,103 \$	36,973,388 \$	42,728,419 \$	491,268,063
commodity (Non-RPP)	16.610.667	15.935.886	15,728,872	14,340,265	14,822,164	16.953.313	19,011,369	17,980,435	15,038,464	14,207,671	14,430,246	16,676,362 \$	191,735,714
Commodity Global Adjustment (Non-RPP)	31,322,972	30,050,528	29,660,159	27,041,643	27,950,367	31,969,104	35,850,011	33,905,963	28,358,246	26,791,608	27,211,321	31,446,854 \$	361,558,775
ransmission Network - IESO	5,440,959	5,219,929	5,152,120	4,697,271	4,855,121	5,553,196	6,227,329	5,889,638	4,925,971	4,653,839	4,726,745	5,462,478 \$	62,804,597
ransmission Line Connection - IESO	1,288,193	1,235,863	1,219,808	1,112,119	1,149,491	1,314,766	1,474,373	1,394,422	1,166,266	1,101,836	1,119,097	1,293,288 \$	14,869,523
ransmission Transformation Connection- IESO	927,957	890,260	878,695	801,120	828,042	947,099	1,062,072	1,004,479	840,125	793,713	806,147	931,627 \$	10.711.335
ransmission Network - HONI	756,001	725,290	715,868	652,669	674,601	771,596	865,265	818,344	684,446	646,634	656,764	758,991 \$	8,726,468
ransmission Line Connection - HONI	165,163	158,453	156,395	142,588	147,380	168,570	189,034	178,783	149,530	141,269	143,483	165,816 \$	1,906,463
ransmission Transformation Connection - HONI	392,196	376,264	371,376	338,589	349,967	400,286	448,879	424,538	355,075	335,459	340,714	393,747 \$	4,527,089
V Charges - HONI	437,936	420,145	414,687	378,077	390,782	446,969	501,229	474,049	396,485	374,581	380,449	439,668 \$	5,055,058
holesale Market Charge	4,306,146	4,131,216	4,077,550	3,717,568	3,842,495	4,394,974	4,928,504	4,661,245	3,898,569	3,683,194	3,740,894	4,323,177 \$	49,705,534
lonthly Service charges (26 accounts)	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183	11,183 \$	134,191
/DS (on average 1500 kW)	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143	3,143 \$	37,717
pecific ST Lines (5km)	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817	7,817 \$	93,807
SME	A 101 000 107 1					100 000 010 -			0 / 007 000 ÷			\$	-
Total Cost of Power	\$ 104,230,428 \$	99,997,138 \$	98,698,424 \$	89,986,891 \$	93,010,120 \$	106,380,043 \$	119,291,418 \$	112,823,774 \$	94,367,092 \$	89,155,050 \$	90,551,390 \$	104,642,570 \$	1,203,134,336