


1       **3.3.2    Asset Strategy**

2    Hydro One’s strategy for steel structures is to manage the fleet through a combination of  
3    planned structure replacements, component refurbishments and tower coating in order to  
4    maintain reliability of the system. Structure replacements and component refurbishments  
5    are usually part of line refurbishment and are described earlier in this section. This  
6    investment category focuses on preserving structures through a tower coating program.

7  
8    Based on International Organization for Standardization (ISO) the environment is divided  
9    into six atmospheric corrosivity categories. In accordance with ISO 12944 and a study  
10    completed by EPRI, the province of Ontario is divided into four corrosion zones ranging  
11    from C2 to C5. Each of these corrosion zones has a range of corrosion rates which can be  
12    used to estimate the service life of HDG steel based on its location. C2 and C3 zones are  
13    defined as light corrosion zones and the towers located in these two zones will likely  
14    have the original galvanizing protection layer for at least 140 years. This means towers  
15    will be protected and maintained in good condition for minimum of 115 years without  
16    requiring any coating. Based on Hydro One asset records, there are approximately  
17    39,000 steel structures in these light corrosion zones and 2,200 of them are older than 100  
18    years. However, none of them are older than 115 years and there is no immediate tower  
19    coating needs for structures within these zones.

20  
21    C4 & C5 zones are defined as heavy corrosion zones which have very high corrosion  
22    rates for zinc and carbon steel (See Figure 32 below). Based on EPRI study, the towers  
23    will lose their protective zinc in 35-65 years after installation. Furthermore they would  
24    lose 10% of their metal in the following 30-60 years. At this stage, structures are no  
25    longer able to withstand the original design loads and either a major refurbishment or  
26    complete tower replacement would be required.

27  
Witness: Chong Kiat Ng



1  
2 **Figure 32: C4 & C5 corrosion regions in Ontario (courtesy of EPRI).**

3  
4 An effective tower coating program can maintain a steel tower structure at its design  
5 capacity indefinitely by re-application of the coating approximately every 35 to 65 years.

6  
7 If towers are not re-coated prior to corrosion and metal loss, the opportunity is lost and  
8 the tower will ultimately have to be replaced.

9  
10 **3.3.3 Asset Assessment Details**


11 Demographics

12 Hydro One has approximately 52,000 steel structures; the demographic of the steel  
13 structure population is outlined in Figure 33. There are approximately 13,000 steel  
14 structures are located in heavy corrosion zones such as Windsor, Sarnia, Hamilton and  
15 GTA. 7,500 of them currently meet tower coating criteria and approximately an  
16 additional 4,700 steel structures will meet this tower coating criteria over the next 10  
17 years if the historical coating rate is maintained. The demographic of the steel structures  
18 in heavy corrosion zones are outlined in Figure 34.

Witness: Chong Kiat Ng

1 Hydro One uses an average expected service life (“ESL”) of 80 years for steel structures  
2 if the structures are not re-coated. Currently 2,100 structures in high corrosion zones are  
3 beyond ESL and exceed the coating criteria. These structures will need detailed  
4 engineering assessment and potentially require heavy refurbishment or even complete  
5 replacement.


6



7

8


**Figure 33: Demographics of Steel Structure Fleet province wide**



1  
2  
3  
4  
5  
6  
7  
8

**Figure 34: Demographics of Steel Structure Fleet in Heavy Corrosion Zones**

Based on the historical data, the average rate for structure renewal is about 200 towers per year. As outlined in Figure 35, at historic tower coating rates, the steel structures requiring coating in high corrosion zones will increase by 34% in 10 years. However, with planned coating plan, all structures requiring coating will be coated in the next 10 years.




1  
2 **Figure 35: Projection of Steel Structures requiring Coating**

3  
4 Performance

5 Forced outages for steel structures represent the number of times an outage is caused by  
6 steel structure failure such as complete tower collapse, or a broken (or bent) tower  
7 member. It excludes forced outages caused by external interferences such as animal  
8 contact and weather related incidents.

9  
10 The number of forced outages due to steel structure failures has shown slight decrease  
11 over the past 10 years as outlined in Figure 36. With the current condition of the steel  
12 structures and the demographics of the fleet, it is expected that increased capital programs  
13 will be required to prevent future increases in forced outages due to steel structure  
14 failures.


Witness: Chong Kiat Ng



1  
2  
3  
4  
5  
6  
7  
8  
9

**Figure 36: Forced Outages due to Steel Structure Failures**

The forced outage duration due to steel structure failures, displayed in Figure 37, demonstrates a stable outage duration trend over the last 10 years, except for the spike in 2011. This type of spike is not unexpected given the very remote locations of some of the circuits with difficult access. This can place considerable strain on the system as it may result in loss of supply to large customers including local distribution companies and generation connections.




**Figure 37: Forced Outage Duration due to Steel Structure Failures**

Condition

Transmission steel structure condition assessment is initiated based on demographics, geographic zone and result of study conducted by industry experts over the past several years. The initial assessment results will be verified by the established Hydro One maintenance program which includes inspections, patrols and detail corrosion assessment. Towers are visually inspected in accordance with NACE (“Nation Association of Corrosion Engineers”) guidelines on the degree of corrosion. Detailed corrosion assessment includes climbing towers and measuring the remaining thickness of protective coating, loss of metal if any and assessment of bolts and fittings.

Based on the current assessment, 4% of Hydro One’s steel structures require major refurbishment or replacement as outlined in Figure 38. 14% of the steel structures require coating and will be addressed in the steel structure coating program. This assessment is continuously reviewed and updated as more structures meet the coating criteria every year.

Witness: Chong Kiat Ng



**Figure 38: Steel Structure Fleet Condition Assessment**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14

In order to maintain the condition of the fleet, the rate of refurbishment/coating will need to be increased as per Hydro One's investment plan.

Other Influencing Factors

- Innovation - Hydro One is continuing to investigate the use of alternative coating products in order to reduce the cycle time involved in the re-coating process by potentially reducing the amount of steel surface preparation and decreasing the drying time which is coating product dependent. This will reduce outage time, when required, and permit a higher number of towers to be coated each year.
- Work Method – A revised work method has been established that allows for tower coating in live line conditions. This live line work method will minimize the outage constraints and maximize the quantity of towers to be coated.

Witness: Chong Kiat Ng



1

**Table 11: Steel Structure Replacement**

Steel Structure Portfolio	Historic				Bridge	Test	
	2012	2013	2014	2015	2016	2017	2018
# of Renewal	228	235	121	300	462	1250	1600
% of Fleet	0.4	0.5%	0.2%	0.6%	0.9%	2.4%	3.1%

2

3 The capital investment in the test years is an increase over historic levels. The strategy to  
 4 manage the fleet of steel towers is a combination of planned replacements, component  
 5 refurbishment and tower coating. The number of towers that have been refurbished,  
 6 coated, or replaced over the past 10 years has been very low. As a result of recent  
 7 condition inspections and tower coating studies the rapid deterioration of steel structures  
 8 in highly corrosive areas needs to be addressed with an increase in the fleet renewal rate.  
 9 Hydro One plans to undertake an aggressive tower coating program to sustain these  
 10 assets. Tower coating has been identified as the preferred alternative as it has a  
 11 significant life cycle cost advantage and has less impact to the system as circuit outages  
 12 required for coating are minimal.

13

14 **3.4 Transmission Lines Insulators**

15 **3.4.1 Asset Overview**

16 Transmission line insulators are an integral component of the transmission system. They  
 17 mechanically support and electrically insulate the conductor from the structure and must  
 18 provide sufficient dielectric strength to prevent short circuits to ground. There are  
 19 approximately 420,000 insulator strings in Hydro One’s overhead transmission network.  
 20 They are assessed through visual inspection, infrared thermography and in-situ live-line  
 21 electrical testing. Insulators are categorized into three types; porcelain, glass and polymer  
 22 as described below and depicted in Figure 40.

23

Witness: Chong Kiat Ng

1 Steel Structure Coating

2 Hydro One's transmission system includes about 50,000 steel structures. Steel structures  
3 are manufactured with a zinc-based galvanized coating that protects the underlying steel  
4 against corrosion. The coating will generally last from 30 to 60 years, with the more  
5 corrosive environments depleting the galvanizing at a quicker rate. Assessment of the  
6 steel structure condition is carried out on an annual basis as part of the maintenance  
7 program, with a focus on transmission line sections that are greater than 30 years and are  
8 located in highly corrosive areas or in locations where known problems exist. The  
9 assessments determine the amount of galvanizing that remains on the structure, or in the  
10 case where the coating is depleted, the amount of metal loss that has occurred. This  
11 program focuses on coating steel tower structures that the assessment has deemed in need  
12 of corrosion protection due to loss of galvanized coating.

13  
14 Additional details for this program are provided in the Investment Summary Document  
15 S45 in Exhibit D2, Tab 2, Schedule 3.

16  
17 Steel Structure Replacements

18 Once the galvanized coating on a steel structure has been depleted, the bare steel becomes  
19 exposed to the environment and begins to corrode at a much faster rate. If the tower is not  
20 re-coated and corrosion is allowed to continue, components of the steel structures will  
21 begin to lose strength and eventually fall below Hydro One Transmission's design  
22 standards. Once a structure is identified as being in poor condition through visual  
23 inspection and measurement of the zinc coating, a detailed corrosion assessment is  
24 conducted to determine whether it is possible to replace a portion of the steel structure  
25 and coat the remaining structure to protect it from corrosion or whether it is more  
26 economical to replace the entire structure. This program addresses the replacement of  
27 steel structures where the corrosion assessment has deemed the structure to be at end of  
28 life.

1 Additional details for this program are provided in the Investment Summary Document  
2 S46 in Exhibit D2, Tab 2, Schedule 3.

3

4 Steel Structure Foundation Refurbishments

5 The foundations of the transmission structures are integral to the strength of the steel  
6 structure. One of the earlier vintages of steel structures is the lattice steel structures  
7 which are constructed with a grillage (buried steel) foundation. These particular structure  
8 foundations are prone to deterioration of the protective zinc coating and/or corrosion at or  
9 below the groundline depending on the ground conditions. About 60% of lattice type  
10 steel towers on the Hydro One transmission system have grillage footings. The  
11 transmission lines foundation refurbishment program is focused on assessing the  
12 condition of the foundations and anchors and repairing or replacing foundations and  
13 anchors that have been deemed not to satisfy the original installed design requirements.  
14 The assessment of foundation uses a pre-specified rating system and the decision to coat,  
15 repair or replace depends on the severity of corrosion or metal loss found.

16

17 Additional details for this program are provided in the Investment Summary Document  
18 S47 in Exhibit D2, Tab 2, Schedule 3.

19

20 Shieldwire Replacements

21 The shieldwire in Hydro One's transmission system is primarily made up of galvanized  
22 steel wire that is positioned above the conductors to protect a circuit against lightning  
23 related outages and to provide continuity of the grounding system. When the zinc  
24 galvanizing has depleted, the underlying steel begins to corrode, resulting in pitting and  
25 loss of metal and eventual failure if not replaced in time. Hydro One Transmission  
26 maintains an on-going shieldwire testing program where a sample of wire is removed  
27 from a line section and tested in a laboratory to determine the condition of the wire and  
28 the need for replacement. This program focuses on the replacement of shieldwire that

- 1 • The condition of the steel structure fleet, determined through industry standard  
2 maintenance practices, is such that 3% present fair or high condition risks that need to  
3 be mitigated.
- 4 • The number of forced outages for steel structure has shown slight deterioration over  
5 the last 10 years; although the duration of forced outages for steel structures has  
6 remained stable.

7  
8 Given the current demographics of the steel structure population, condition trend and the  
9 risks associated with steel structure failures, an increase in the fleet renewal is required to  
10 maintain current levels of performance and risk.

## 11 12 **Asset Strategy**


13  
14 Hydro One Transmission's strategy for steel structures is to manage the aging fleet of  
15 steel structures through a combination of planned replacements, component  
16 refurbishments and tower coating in order to maintain reliability of the system while  
17 minimizing rate impacts.

18  
19 Effective tower coating can maintain a steel tower structure indefinitely by re-application  
20 of the coating approximately every 20 to 25 years depending on the installed environment  
21 of the structure. However tower replacement is a requirement once the structure has  
22 degraded to a point where recoating cannot stop the corrosion process. Hydro One  
23 Transmission strives to recoat before this point is reached; as the life cycle costs of  
24 regular coating programs are estimated to be less than half of a replacement strategy.

1 **Asset Assessment Details**


2  
3 Demographics

4 Hydro One Transmission uses a normal expected service life (“ESL”) of between 80 to  
5 100 years for steel structures if the structures are not re-coated. The average age of the  
6 steel structure fleet is currently 56 years of age and 21% are currently beyond their ESL;  
7 for which 4% of these are beyond 100 years. The demographics of the steel structure  
8 population is outlined in Figure 36.



10  
11 **Figure 36: Demographics of Steel Structure Fleet**

12  
13 As can be seen in Figure 37, continuing at the historic fleet renewal rate would result in  
14 the percentage of steel structures beyond their expected service life increasing to 24% by  
15 2024. However under the proposed plan, the percentage of steel structures beyond their  
16 expected service life will decrease from 21% to 18% over the next 10 years.




1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15

**Figure 37: Projection of Steel Structures Beyond Expected Service Life**

Performance


Forced outages for steel structures represents the number of times an outage is caused due to a steel structure failure such as failed, broken or bent tower member. It excludes forced outages caused by external interferences (animal contact, weather, etc.). Although single circuit tower outages typically do not result in delivery point interruptions, a multiple circuit tower failure can result in customer outages.

The number of forced outages due to steel structure failures has shown slight increase over the past 10 years, as outlined in Figure 38. With the current condition of the steel structures and the demographics of the fleet, it is expected that an increase in the capital programs will be required to prevent future increases in forced outages due to steel structures.



1  
2 **Figure 38: Forced Outages due to Steel Structure Failures**

3  
4 The forced outage duration due to steel structure failures, displayed in Figure 39,  
5 demonstrates a stable outage duration trend over the last 10 years, except for the extreme  
6 spikes in 2004 and 2005. These type of spikes are not unexpected given the very remote  
7 locations of some of the circuits, with difficult access. This can place considerable strain  
8 on the system as it may result in loss of supply to large customers including local  
9 distribution companies and generation connections.



10  
11  
12 **Figure 39: Forced Outage Duration due to Steel Structure Failures**


1 Condition

2 The condition of the steel structures is determined through inspections, patrols and  
3 detailed corrosion assessment. Towers are visually inspected in accordance with NACE  
4 (“Nation Association of Corrosion Engineers”) guidelines on the degree of corrosion.  
5 Detailed corrosion assessment includes climbing towers and measuring the remaining  
6 thickness of protective coating, loss of metal if any and assessment of bolts and fittings.

7

8 Based on the current assessment of condition, 3% of Hydro One Transmission steel  
9 structures have condition in the fair or high risk category, as outlined in Figure 40, and  
10 meet the current refurbishment/coating criteria. This assessment is continuously reviewed  
11 and adjusted as new conditions are reported or factors are considered. An additional 14%  
12 of steel structures need to be assessed in order to determine their condition.

13



14

15 **Figure 40: Steel Structure Fleet Condition Assessment**

16

17 In order to maintain the condition of the fleet, the rate of refurbishment/coating will need  
18 to be increased. Towers in fair and high condition will require coating within the next 5



1 years. Should they exceed this optimum time to coat, the structures will eventually  
 2 require either partial or full replacement.

3

4 Other Influencing Factors

- 5 • Innovation - Hydro One Transmission is continuing to investigate using alternative  
 6 recoating products in order to reduce the amount of steel surface preparation and  
 7 increase the drying process. This should reduce outage time and therefore permit a  
 8 higher number of towers to be coated within the limited outage windows. Hydro One  
 9 Transmission also continues to explore new steel tower coatings that are longer  
 10 lasting than those that are currently commercially available.

11

12 **Cost Trends and Impacts**

13

Steel Structure Portfolio	Historic			Bridge	Test	
	2011	2012	2013	2014	2015	2016
# of Refurbishments	0	226	218	350	350	400
# of Replacements	0	0	17	4	4	12
% of Fleet	0%	0.5%	0.5%	0.7%	0.7%	0.8%
Capital (\$M)	0.6	8.7	13.3	11.1	10.7	16.0
OM&A (\$M)	4.7	4.8	3.1	4.4	4.1	4.2

14

15 The capital investment in the test years is an increase over historic levels. The strategy to  
 16 manage the aging fleet of steel towers is a combination of planned replacements,  
 17 component refurbishment and tower coating. The number of towers that have been  
 18 refurbished, coated or replaced over the past 10 years has been very low. The result of  
 19 recent condition inspections has pointed to rapid deterioration of steel structures in highly  
 20 corrosive areas, which demonstrates a need to increase the fleet renewal. Hydro One  
 21 Transmission plans to undertake an aggressive tower coating program to sustain these  
 22 assets. Tower coating has been identified as the preferred alternative as it has a life cycle

1 cost of roughly half that of tower replacement and is less impactful to the system as  
2 circuit outages required for coating are minimal.

3  
4 OM&A expenditures are relatively stable with assessment activities performed frequently  
5 to assess zinc coating thickness and member condition.

6  
7 4.2.4 Transmission Underground Cables

8  
9 **Asset Overview**

10  
11 Hydro One's transmission system consists of approximately 290 km of underground  
12 cables that supply city centres in Toronto, Ottawa and Hamilton with short sections in  
13 London, Sarnia, Picton, Windsor and Thunder Bay. Transmission underground cables are  
14 typically extensions to, or links between, portions of the overhead transmission system  
15 operating at 230 kV and 115 kV. Underground cables are mainly used in urban areas  
16 where it is either impossible, or extremely difficult to build overhead transmission lines  
17 due to legal, environmental and safety reasons.

18  
19 Depending on the cable design the three phase conductors may be contained together  
20 within a steel pipe or each phase conductor self-contained in its own sheath and installed  
21 separately underground. Transmission underground cables are systems, similar to  
22 transmission lines, made up of numerous components all of which need to integrate and  
23 function properly in order to deliver power with the reliability that is demanded.

24  
25 There are three different types of high voltage underground cables in use on the  
26 transmission system: Low-Pressure Oil-Filled ("LPOF") cables, High-Pressure Oil-Filled  
27 Pipe-Type ("HPOF") cables, and Extruded Cross Linked Polyethylene ("XLPE") cables.

**UNDERTAKING – TCJ2.3**

**Undertaking**

To provide calculations behind the tower coating evaluations.

**Response**

**Part 1: Net Present Value Calculation**

The Net Present Value (NPV) of a tower coating investment for 2 scenarios is presented below. The first scenario assumes an individual tower needs replacement and the second scenario assumes a group of more than 20 towers located in close vicinity needs replacement.

**Information and Assumptions**

- a. Tower replacement age: 75 year-old
- b. Average age of eligible towers is 45 year-old
- c. Expected new coating life: 35 years
- d. Straight line depreciation with ½ year rule in the first year
- e. Inflation rate equal to 2%.
- f. Study period of 60 years.
- g. Start time for the study is 2017.
- h. Unit costs for tower coating and replacement as provided below.

**Table 1: Tower Coating and Replacement Costs**

<b>Single Tower Replacement</b>		<b>Multiple Towers Replacement</b>	
<b>115 kV Tower</b>		<b>115 kV Tower</b>	
Replacement Cost (\$k)	400	Replacement Cost (\$k)	250
Coating Cost (\$k)	30	Coating Cost (\$k)	30
<b>230 kV Tower</b>		<b>230 kV Tower</b>	
Replacement Cost (\$k)	450	Replacement Cost (\$k)	350
Coating Cost (\$k)	37	Coating Cost (\$k)	37

Notes:

- 1. Tower replacement costs for replacing only one tower and a group of more than 20 towers in similar areas are presented. The lower unit cost for the latter case is due to economies of scale and savings from access, mobilization and demobilization.

Witness: Chong Kiat Ng



1 Total capital cost saving resulted from 2017 and 2018 tower coating investment is shown  
 2 below. Total towers expected to be coated in 2017 and 2018 is 2850. Fifteen percent of  
 3 coating candidates are 115kV and 85% are 230kV towers.  
 4

5 **Table 3: Unit and Total Cost Savings**

<b>Single Tower Replacement</b>		<b>Multiple Towers Replacement</b>	
<b>115 kV Tower</b>		<b>115 kV Tower</b>	
Unit Cost Saving	\$62k	Unit Cost Saving	\$27k
Total Cost Saving: \$62K*2850*0.15	\$26.50M	Total Cost Saving: \$27K*2850*0.15	\$11.54M
<b>230 kV Tower</b>		<b>230 kV Tower</b>	
Unit Cost Saving	\$65k	Unit Cost Saving	\$42k
Total Cost Saving: \$65K*2850*0.85	\$157.46M	Total Cost Saving: \$42K*2850*0.85	\$101.75M
<b>Total NPV Capital Cost Saving Resulted from Test Years Tower Coating</b>	<b>\$184.0M</b>	<b>Total NPV Capital Cost Saving Resulted from Test Years Tower Coating</b>	<b>\$113.3M</b>

6  
 7 **Additional Information**

8 There are 2 new developments since 2014 that have significantly improved the NPV  
 9 analysis of this investment, which is the basis to support increasing investment for tower  
 10 coating.  
 11

12 **A. Engineering Study to Determine Corrosion Zones, Corrosion Rates, Tower Condition**  
 13 **Assessment; and End of Life Criteria and Coating Opportunity**

- 14
- 15 i) Corrosion Zones, Corrosion Rates and Tower Condition Assessment:  
 16 Hydro One and Electric Power Research Institute (EPRI) conducted an  
 17 engineering study to define corrosion zones and corrosion rates in the  
 18 province of Ontario and assess impact of corrosion to Hydro One's  
 19 transmission tower. The study includes condition assessment of towers  
 20 located in various corrosion zones. The study concludes that a significant  
 21 portion of towers located in high corrosive zones are in need of coating to  
 22 arrest further deterioration and prevent eventual replacements. Refer to  
 23 Exhibit B1, Tab 2, Schedule 6, Section 3.3 and Exhibit I, Tab 9, Schedule 6,  
 24 Attachment 2.  
 25
- 26 ii) Tower End of Life Criteria and Coating Opportunity:  
 27 A transmission tower is deemed to have reached end of life when it has lost  
 28 10% of steel thickness, rendering it incapable to withstand design load. A new

Witness: Chong Kiat Ng

1 tower comes with a layer of protective zinc applied over bare steel via hot-dip  
2 galvanizing process. This layer varies in thickness. The American Society of  
3 Testing and Materials (ASTM) specifies a minimum thickness of 100 microns  
4 for tower steel. It is common for fabricator to deliver steels with an average  
5 zinc thickness of 150 microns.

6  
7 The most common steel member thickness for 115 and 230kV towers is 8mm  
8 ie, 8000 microns. In high corrosive areas, the average annual zinc corrosion  
9 rate is 3.3 microns and bare steel is 27.5 microns.

- 10  
11
- 12 • Most common steel member thickness = 8mm.
  - 13 • End of Life Criteria = 10% loss of steel thickness, 800 microns
  - 14 • Opportunity to coat = in the time interval between when the zinc layer is  
nearly depleted and before end of life.

15 New steel members come with 150 microns zinc layer and the annual zinc  
16 corrosion rate is 3.3 microns. Hence, it takes 45 years ( $150/3.3=45$ ) to deplete  
17 the zinc layer.

18  
19 Once zinc layer is depleted, the exposed bare steel will corrode at an annual  
20 rate of 27.5 microns. Hence, it takes 29 years ( $800/27.5=29$ ) to lose 800  
21 microns of thickness.

22  
23 A tower in high corrosive area will reach end of life in 74 years (45+29)

24  
25 Therefore, the opportunity to economically extend life of towers located in  
26 high corrosive area via coating is around 45 year-old and before 74 year-old.  
27 As the towers exceed 75 year-old, various level of refurbishment effort will be  
28 required to restore strength before coating can be applied. Eventually, costly  
29 tower replacement becomes the only feasible option.

30  
31 **B. Galvatech**

32 Galvatech is a zinc rich coating product manufactured by Rust-Anode. Hydro One  
33 became aware of this product in recent years and completed a detailed assessment  
34 of its performance. Refer to Exhibit I, Tab 9, Schedule 6, Attachment 3. The  
35 unique and desirable performance characteristics of this product are:

- 36  
37 i) Does not require extensive surface preparation;  
38 ii) Rapid curing, approximately 2 hours as opposed to 24 hours;

- 1       iii)    Less dripping, less likely to contaminate other line components such as
- 2            insulators, which enables live-working technique;
- 3       iv)    High performance, quality of coating comparable to hot-dip galvanizing
- 4            process; and
- 5       v)    Durability, coating is expected to last 30 to 35 years in the high corrosive
- 6            zones.

7  
8       These 2 new developments described in (A) and (B) have improved significantly the  
9       productivity and efficiency of tower coating investment, which makes it an attractive and  
10       prudence asset management undertaking as discussed in Part 1.

11  
12       **Tower Coating Investment Pacing**

13       The Hydro One transmission system consists almost exclusively of overhead  
14       transmission lines and owns approximately 52,000 steel structures. Hydro One is  
15       planning to coat 1,250 and 1,600 towers in 2017 and 2018 respectively. The total count of  
16       2,850 towers eligible for coating in the test years represents approximately 5.5% of the  
17       tower population.

18  
19       There are approximately 13,000 towers located within high corrosive zones, which is the  
20       focal point of the tower coating investment. Currently 7,550 of these 13,000 towers have  
21       met coating criteria and are within the window of opportunity for coating. Sixty percent  
22       of these 7,550 towers are currently experiencing corrosion and metal loss. As these  
23       towers approach 75 years old, the ability to extend their service life by coating  
24       diminishes.

25  
26       Hydro One intends to complete coating these 7,550 towers between 2017 and 2021 to  
27       extend the service life of these towers and maximize capital cost savings by minimizing  
28       tower replacements. 2017 is intended to be a ramp up year operations with 1,250 towers.  
29       Subsequent years from 2018 to 2021 will see an average of 1,600 towers coated per year.  
30       The tower coating program will be adjusted after 2021 based on the condition of the  
31       remaining towers in high corrosive zones that meet the tower coating criteria and lessons  
32       learned from the test years.