

Hydro One Networks Inc.

7th Floor, South Tower
483 Bay Street
Toronto, Ontario M5G 2P5
www.HydroOne.com

Tel: (416) 345-5393
Fax: (416) 345-6833
Joanne.Richardson@HydroOne.com

Joanne Richardson

Director – Major Projects and Partnerships
Regulatory Affairs



BY COURIER

February 21, 2017

Ms. Kirsten Walli
Secretary
Ontario Energy Board
Suite 2700, 2300 Yonge Street
P.O. Box 2319
Toronto, ON.
M4P 1E4

Dear Ms. Walli:

EB-2016-0322 – Union Gas Limited Application for Approval of the 2017 Storage Enhancement Project – Hydro One Networks' Correspondence Regarding Written Submissions

Hydro One Networks Inc. ("Hydro One") applied to be an intervenor in Union Gas Ltd.'s ("Union Gas") Storage Enhancement Project as it had concerns with respect to maintaining an adequate separation between Hydro One's distribution poles and Union Gas' proposed facility expansions near the Dawn plant in Lambton County.

Union Gas, in response to Hydro One's interrogatories has ensured that the "the minimum separation between any of Union's Proposed Facilities and Hydro One's wooden distribution poles is approximately 40 meters." Union also replied that with a minimum separation distance of approximately 40 meters, relocation of any Hydro One poles is not required.

Hydro One is satisfied with these responses and maintains that the minimum separation distance of 40 meters must be kept. As such, Hydro One will not be providing a submission to this Application.

Sincerely,

ORIGINAL SIGNED BY JOANNE RICHARDSON

Joanne Richardson