

October 30, 2017

BY COURIER & RESS

Ms. Kirsten Walli
Board Secretary
Ontario Energy Board
2300 Yonge Street, 27th Floor
Toronto, ON M4P 1E4

Dear Ms. Walli:

**Re: Union Gas Limited (“Union”)
Sudbury Maley Replacement Project
EB-2016-0222 - Change Request #2**

Enclosed please find written confirmation from the TSSA in relation to the above noted Change Request. TSSA in a letter dated October 26, 2017 confirms that Union’s pipeline design is in compliance with appropriate codes and regulations.

In the event that you have any questions on the above or would like to discuss in more detail, please do not hesitate to contact me.

Yours truly,

[original signed by]

W.T. (Bill) Wachsmuth, RPF
Senior Administrator, Regulatory Projects
:sb
Attach.

cc: N. Marconi
Z. Crnojacki
R. Murray



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

October 26, 2017

Mr. Tom O'Malley,
Union Gas Limited,
50 Keil Drive North,
Chatham, ON N7M 5M1

Re: Union Gas Limited Sudbury Expansion Project (OEB File No. EB-2016-0222).

Dear Mr. O'Malley.

We reviewed the documentation related to the referenced project, including the design and pipe specifications and recent increase to the wall thickness from 6.4mm to 7.1mm. Proposed project meets the Ontario Regulation on Oil and Gas Pipeline Systems (O. Reg. 210/01) and Code Adoption Documents FS-220-16.

If you have any further questions, please call me.

Yours truly,

Kourosh Manouchehri, P. Eng.
Fuels Safety Engineer
Tel.: 416 734 3539
Fax. 416 231 7525
e-mail: kmanouchehri@tssa.org

c: Mr. Guy Castagne, TSSA

Zora Crnojacki,
Ontario Energy Board,
2300 Yonge Street, 26th. Floor,
Toronto, ON M4P 1E4