

Application No.: A.16-09-  
Exhibit No.: SCE-09, Vol. 03  
Witnesses: P. Joseph  
A. Varvis  
R. White



(U 338-E)

***Results of Operations***  
***Volume 03 – Depreciation Study***

Before the  
**Public Utilities Commission of the State of California**

Rosemead, California  
September 1, 2016

# SCE-09: Results of Operation Volume 03 - Depreciation Study

## Table Of Contents

Section		Page	Witness
I.	INTRODUCTION .....	1	A. Varvis
A.	Organization of Testimony .....	2	
B.	SCE’s Depreciation Proposals .....	3	
C.	Application of Gradualism Principle to SCE’s Proposal .....	5	
D.	Summary Tables .....	8	
II.	COMMISSION DIRECTIVES FROM SCE’S 2015 GRC DECISION .....	11	
A.	The Four Directives Established in the 2015 GRC Decision .....	11	
B.	SCE’s Approach to Addressing the Compliance Directives from the 2015 GRC Decision .....	12	
1.	The First Directive – Per Unit Net Salvage Analysis .....	14	
a)	Traditional Approaches to Analyzing Historical and Future Net Salvage .....	15	
b)	Comparing the Differences Between Calculating Net Salvage Ratios Using a Traditional Analysis Versus Per-Unit Analysis.....	16	
2.	The Second Directive – Retirement Mix .....	18	
3.	The Third Directive – The Age of Retirements and Integration of Salvage and Life Analyses .....	19	
4.	The Fourth Directive – Process for Assigning Costs.....	20	
C.	Process for Assigning Costs to Installation and Removal (The Fourth Directive) .....	20	
1.	Project-Specific Estimating (Bulk-Power Transmission, Substation, and Generation/Other) .....	21	
a)	Bulk Power Transmission and Substation (Accounts 350-359) .....	21	

# SCE-09: Results of Operation Volume 03 - Depreciation Study

## Table Of Contents (Continued)

	Section	Page	Witness
	b) Generation and Other (Accounts 301-348, and 390-398) .....	21	
2.	Design Manager (DM) Estimating (Distribution/Sub-Transmission Assets) .....	22	
	a) Building a Project Estimate in DM Using Compatible Units (CUs) .....	22	
	b) Cost Allocation in PowerPlan .....	23	
3.	Substantiating SCE's Standard Rates Table Allocation Factors .....	25	
	a) 2004 Study .....	26	
	b) 2006 Study .....	27	
	c) 2016 Study .....	28	
	(1) Background of Development of Compatible Units (CUs). .....	28	
	(2) 2009-2010 Labor Study .....	28	P. Joseph
	(3) 2016 Comparison of Standard Rates Table and CUs.....	30	A. Varvis
D.	SCE's Experience with Increasingly Negative Net Salvage Rates.....	30	
1.	The Average Age of Retirements is Increasing .....	31	
	a) Age and Inflation Impacts on Recorded Net Salvage Ratios.....	31	
	b) SCE's Aging Retirements .....	32	
2.	Total Cost Increases Affect Cost of Removal.....	33	
3.	SCE's Per-Unit Analysis is Indifferent to the Realized Net Salvage Ratios .....	34	
III.	DEPRECIATION STUDY .....	36	

# SCE-09: Results of Operation

## Volume 03 - Depreciation Study

### Table Of Contents (Continued)

Section		Page	Witness
A.	T&D - Average Service Life and Net Salvage Proposals.....	37	R. White
1.	Development of Depreciation Rates .....	37	
2.	2016 Service-Life Study.....	39	
3.	2016 Net Salvage Study.....	43	
a)	Directive No. 1 .....	45	
b)	Directive No. 2.....	49	
c)	Directive No. 3.....	49	
d)	Directive No. 4.....	50	
B.	Generation and G&I - Average Service Life and Net Salvage Proposals .....	51	A. Varvis
1.	Purpose and Scope .....	51	
2.	Generation-Related Property .....	51	
a)	Average Service Lives for Generation Assets .....	51	
(1)	Palo Verde Nuclear Generating Station (PVNGS) .....	53	
(2)	Hydro Generation.....	53	
(3)	Pebbly Beach .....	54	
(4)	Mountainview .....	55	
(5)	Peakers .....	55	
(6)	Solar Photovoltaic.....	55	
(7)	Fuel Cells .....	56	
(8)	Energy Storage.....	56	
b)	Net Salvage Rates for Generation Assets .....	56	



# SCE-09: Results of Operation Volume 03 - Depreciation Study

## Table Of Contents (Continued)

	Section	Page	Witness
	(1) Palo Verde Net Salvage .....	58	
	(2) Hydro Net Salvage .....	58	
	(3) Pebbly Beach Net Salvage .....	59	
	(4) Mountainview Net Salvage .....	59	
	(5) Peakers Net Salvage .....	59	
	(6) Solar Photovoltaic Net Salvage .....	60	
	(7) Fuel Cell Net Salvage .....	60	
	(8) Energy Storage Net Salvage .....	61	
3.	Forecast Service Lives for G&I Assets .....	61	
4.	Forecast Service Lives – Account-By-Account .....	63	
	a) General Plant .....	63	
	(1) Account 391.1 – Office Furniture .....	63	
	(2) Account 391.2 And 391.3 – Computer Equipment .....	63	
	(3) Account 391.4 – Power Management System .....	63	
	(4) Account 391.5 and 391.6 – Office Equipment; Duplicating Equipment .....	66	
	(5) Account 393 – Stores Equipment .....	66	
	(6) Account 394 – Tools & Work Equipment .....	66	
	(7) Account 395 – Laboratory Equipment .....	66	
	(8) Account 397 – Telecommunication Equipment .....	66	
	(9) Account 398 – Miscellaneous .....	68	

# SCE-09: Results of Operation Volume 03 - Depreciation Study

## Table Of Contents (Continued)

	Section	Page	Witness
b)	Intangibles.....	68	
	(1) Miscellaneous Intangibles.....	68	
	(2) Capitalized Software.....	68	
	(3) Easements .....	68	

Appendix A 2016 Service-Life and Net Salvage Study

Appendix B Formulation of Per Unit Net Salvage Rates

I.

**INTRODUCTION**

Depreciation is the means by which SCE's investors recover the costs of the fixed capital investments they have made to provide electric service to SCE's customers. Depreciation provides a mechanism for recovery of the original cost of the investment and the future cost to retire the investment over its useful life. In each GRC, SCE submits a depreciation study that presents analyses of service lives and retirement costs. In Volume 2 of SCE-09, SCE set forth its proposed depreciation expense accruals for 2018-2020. This Volume 3 of SCE-09 describes the depreciation study undertaken by SCE's in-house and outside experts.

In this rate case, unlike prior ones, SCE undertook an *actuarial* analysis to estimate life parameters for its transmission and distribution (T&D) assets. Actuarial analyses rely on aged data, not on the unaged plant records that SCE used in the past to derive its proposed depreciation expense. SCE's actuarial analysis revealed that for 18 of 20 T&D accounts, the forecast service life of many assets is the same or longer than what had been authorized in the past. When service lives are extended, depreciation expense will decrease, all other things being equal.

However, a large driver impacting depreciation expense is cost of removal. As assets age, the effect of inflation increases cost of removal. Indeed, depreciation is a major expense in large part because it includes an allocation of the original cost of fixed capital and its estimated future cost of removal. This future removal cost, called net salvage, is defined as gross salvage minus cost of removal. When cost of removal is higher than gross salvage, as is commonly experienced in the utility industry, the value is negative and results in an increase to total depreciation expense. When that increasing cost to remove is expressed as a percentage of the original cost—a computation known as the net salvage ratio, or NSR—it becomes more negative as SCE's infrastructure ages.

In the 2015 GRC, the Commission directed SCE to conduct a more detailed analysis of its cost of removal for at least five of SCE's largest plant accounts as measured by proposed depreciation expense. That rigorous analysis, known as a "per-unit" analysis, differs from the traditional way in which SCE forecasts net salvage. Section C of Chapter II describes these differences in detail, but the main point is that under a per-unit analysis, SCE divides each plant account into "sub-populations" of similar assets, determines the historical cost to remove each unit in the sub-populations, and then applies the per-unit cost to the quantities identified in the surviving plant balance. SCE uses the surviving plant balance (*i.e.*, the mix of assets on SCE's books *today*) as the "window" into what future costs of removal will be,

1 given the projected timing of the assets' retirement. This work is detailed and rigorous, and meets the  
2 Commission's compliance directives described in Chapter II. A traditional cost of removal analysis,  
3 applied to the balance of accounts, takes a more aggregated approach and generally assumes that future  
4 removal costs and activity will mimic what SCE experienced in the past. Both are accepted methods of  
5 forecasting the cost of removal, but the per-unit analysis is more detailed and labor-intensive.

6 The study results confirmed that SCE's NSRs are increasingly negative. That fact is not  
7 surprising given SCE's recorded history and the many other drivers SCE discusses in Section D of  
8 Chapter II. In fact, applying the results of the study would result in an estimated increase in depreciation  
9 expense of \$963 million. However, SCE is not requesting to recover that sum over this GRC cycle given  
10 the resulting impact it would have on customers' retail rates. Rather, for reasons described in Section B  
11 of Chapter II, SCE elects to moderate its proposal in service of a public policy principle on which the  
12 Commission has relied before in the depreciation context—"gradualism." The idea is to spread the  
13 increases in depreciation expense over time to mitigate the immediate rate impact on customers. Thus,  
14 for T&D accounts where SCE's depreciation study results in an increase greater than 25% of currently  
15 authorized NSRs, SCE proposes to cap the increase at 25%. The result of applying this cap is to reduce  
16 SCE's proposal to \$71 million above currently authorized, \$892 million less than what the study results  
17 justify, as shown in Figure I-1 below.

#### 18 **A. Organization of Testimony**

19 This chapter summarizes SCE's depreciation proposal comparing the "full" (un-tempered)  
20 empirical study results with SCE's moderated proposal. Section D of this chapter shows average life and  
21 NSR values for all accounts.

22 Sections A through C of Chapter II address the Commission's four compliance directives from  
23 SCE's 2015 GRC, which required additional quantitative detail to support SCE's net salvage proposals.<sup>1</sup>  
24 Section D of the same chapter offers qualitative reasons for SCE's increasingly negative net salvage  
25 rates.

26 Chapter III sets forth the results of SCE's depreciation study, based on plant assets as of  
27 December 31, 2015, separated into: (1) a life and net salvage analysis of Transmission and Distribution  
28 (T&D) assets, undertaken by SCE's outside expert (Section A of Chapter III); and (2) a life and net

---

<sup>1</sup> The compliance directives are also addressed in Chapter III, Section A.3.

1 salvage analysis of Generation assets, plus General and Intangible (G&I) assets, undertaken by SCE's  
2 in-house expert (Section B of Chapter III).

3 **B. SCE's Depreciation Proposals**

4 As shown in Table I-1, SCE's total proposed depreciation expense resulting from the study's  
5 revised parameters (using the moderated approach) is approximately five percent higher than recorded  
6 2015 depreciation expense using the 2015 GRC-authorized depreciation rates.

***Table I-1<sup>2</sup>***  
***Depreciation Expense Proposal***


Line No.	Item	Depreciation Expense (Nominal \$M)	% Change from 2015 Recorded (Line 1)
1.	Recorded 2015 Depreciation Expense at Authorized Depreciation Rates (from 2015 GRC)	\$1,656	
2.	Change due to 2016-2018 Plant Growth at Authorized Depreciation Rates	\$266	16.1%
3a.	Change due to proposed Depreciation Rates applied to Year-End 2015 Recorded Plant	\$71	4.3%
3b.	Change due to Proposed Depreciation Rates applied to 2018 Forecast Plant	\$10	0.6%
3.	Total Change due to Depreciation Study (Sum of 3a and 3b)	<b>\$81</b>	<b>4.9%</b>
4.	Proposed Test Year 2018 Depreciation Expense (Sum of Lines 1,2, and 3)	\$2,003	21.0%

7 SCE's depreciation rate proposals (Line 3a above) can be separated into major functional  
8 categories as shown in Figure I-1 below.

---

<sup>2</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 1-20 (Depreciation Rate Proposals).

**Figure I-1<sup>3</sup>**  
**Impact of Proposed Depreciation Rates by Class of Plant**  
*(Based on Year-End 2015 CPUC-Jurisdictional Plant Balances, \$M)*



Note: The far left bar in the figure above shows a different number (\$1,521M) from Table I-1 (\$1,656) for two reasons: (1) It is calculated using only year-end 2015 plant balance instead of the full year 2015 recorded plant balances; and (2) it represents CPUC-jurisdictional depreciation expense only.

The increase in generation accruals is due primarily to shorter life proposals for hydro and solar facilities (See Section B of Chapter III). For T&D, SCE proposes to extend or retain average service lives for 18 of 20 accounts, and proposes more negative NSRs for 13 of 20 T&D accounts. The small change in General & Intangible accruals is the result of SCE's proposal to recover recorded reserve deficits.

As shown in Figure I-1 above, the results of SCE's net salvage analysis support a total increase in the annual accruals for net salvage of \$976 million (assuming 2.72% inflation) consisting of SCE's requested \$84 million plus an additional \$892 million not requested in this rate case. Section C below

<sup>3</sup> Because this figure is based on CPUC-jurisdictional plant balances as of Year-End 2015, it does not include the impact of forecast plant additions from 2016-2018. The estimated impact of these forecast additions is shown in Line 2 of Table I-1 above.

discusses SCE's approach to moderating its T&D net salvage expense proposals to the requested \$84 million.

**C. Application of Gradualism Principle to SCE's Proposal**

The results of the more rigorous per-unit net salvage analysis required as part of the Commission's directives from the 2015 GRC (see Chapter II), together with a forecast of the timing of retirements,<sup>4</sup> supports increasing SCE's annual accruals for T&D net salvage by \$976 million above currently authorized levels. This depreciation proposal "as is" would translate into a large revenue requirement increase if the Commission were to adopt it. Given the magnitude of the impact this proposal would have on retail rates, SCE requests only \$84 million for T&D net salvage accruals.

SCE chooses to "temper" its depreciation request in light of the Commission's recognition that while a utility could substantiate large depreciation expense requests through "empirical analysis of cost trends,"<sup>5</sup> more moderated rates may be in the public interest for reasons unrelated to empirical analyses. The Commission discussed this principle—known as "gradualism"—relatively recently in its Decision Authorizing Pacific Gas and Electric Company's (PG&E's) General Rate Case Revenue Requirement for 2014-2016, D.14-08-032, where it approved increased negative net salvage rates relative to PG&E's then-current rates "but at a reduced level relative to PG&E's forecasts to mitigate ratepayer impacts and to reflect the principle of gradualism."<sup>6</sup>

Specifically, the Commission concluded that for all asset accounts in which net salvage amounts were contested, it would adopt no more than 25% of the estimated net increase from current rates that would otherwise result from applying PG&E's net negative salvage rates (*e.g.*, if the previously approved NSR was -50% and PG&E requested -100%, the Commission adopted an NSR no more negative than -62.5%). The Commission concluded that 25% of the difference between then-current rates and proposed rates "gives some credence to the empirical methods used by PG&E while declining

---

<sup>4</sup> To estimate the timing of retirements, SCE used the average retirement life and dispersion curves determined through its actuarial analyses, and then applied a 2.72% capital escalation assumption to determine forecast net salvage. For an explanation about the basis of the inflation assumption, refer to WP SCE-09 Vol. 03, Book A, p. 24 (Capital Escalation).

<sup>5</sup> D.14-08-032, p. 596.

<sup>6</sup> *Id.*, p. 11.

1 to pass along the full amount of PG&E's forecasted increase in negative salvage rates to current  
2 ratepayers."<sup>7</sup>

3 SCE's gradualism proposal in this proceeding uses a different formula than the one the  
4 Commission applied in PG&E's 2014 GRC Decision because SCE proposes to cap increases at 25%  
5 more than currently authorized NSRs rather than proposing an increase equal to 25% of the difference  
6 between proposed and authorized NSRs.<sup>8</sup> See Table I-2, below, for a summary of SCE's capping  
7 proposal (which was applied only to the accounts with gray highlights given that the study results would  
8 have increased the NSRs by more than 25% from authorized rates).

---

<sup>7</sup> *Id.*, p. 602. In SCE's 2015 GRC, the Commission relied on its rationale from the PG&E case, stating that "[c]onsistent with the logic of gradualism that we applied to PG&E," it adopted a negative net salvage rate for Account 364 of -210% instead of the -225% that SCE had requested. D.15-11-021, p. 421. Similarly, for Account 369, SCE proposed an increase from -85% to -125%. "Consistent with gradualism," and for other reasons, the Commission adopted an increase to -100%. *Id.*, p. 425. In SCE's 2009 GRC, the Commission did not refer to "gradualism" as a doctrine but nonetheless tempered SCE's otherwise reasonable removal cost estimates "because of economic difficulties facing ratepayers." D.14-08-032, p. 599 (citing D.09-03-025, pp. 179-180).

<sup>8</sup> SCE's proposal, using the same calculation method as the Commission applied in the 2014 PG&E Decision, is equal to roughly 10% of the difference between currently authorized NSRs T&D accounts and what SCE's study results would justify.



**Table I-2**  
***SCE's Proposed Net Salvage Ratios for T&D Accounts***

FERC Acct	Description	2015 GRC Authorized	Study Results	25% Above Authorized	SCE's NSR Proposals
A	B	C	D	E=C*1.25	G=Lesser of D or E
<b>Transmission Plant</b>					
352	Structures and Improvements	35%	35%	44%	35%
353	Station Equipment	15%	10%	19%	10%
354*	Towers and Fixtures	60%	185%	75%	75%
355*	Poles and Fixtures	72%	499%	90%	90%
356*	Overhead Conductors and Devices	80%	210%	100%	100%
357	Underground Conduit	0%	0%	0%	0%
358	Underground Conductor and Devices	15%	25%	19%	19%
359	Roads and Trails	0%	0%	0%	0%
<b>Distribution Plant</b>					
361	Structures and Improvements	25%	30%	31%	30%
362	Station Equipment	25%	50%	31%	31%
364*	Poles, Towers and Fixtures	210%	488%	263%	263%
365*	Overhead Conductors and Devices	115%	538%	144%	144%
366*	Underground Conduit	30%	401%	38%	38%
367*	Underground Conductor and Devices	60%	261%	75%	75%
368*	Line Transformers	20%	47%	25%	25%
369*	Services	100%	387%	125%	125%
370	Meters	5%	0%	6%	0%
373	Streetlights	30%	100%	38%	38%

\* Used a per-unit analysis to arrive at proposed net salvage rates

The moderated NSRs, taken together with the balance of SCE's depreciation proposal, result in a total depreciation request that is less than 5 percent above what the Commission authorized for SCE in the 2015 GRC Decision.

SCE has weighed the balance between setting rates in this GRC based on cost-of-service principles, on the one hand, and being mindful of customer rate impacts, on the other. SCE also acknowledges errors inherent in any forecast of lives and removal costs of long-lived assets given the many variables that will eventually bear on the final costs. SCE recognizes the Commission's statement that one must "be cautious in making large changes in estimates of service lives and net salvage for property that will be in service for many decades, as future experience may show the current estimates to be incorrect."<sup>2</sup> Indeed, the premise of SCE's per-unit analysis is that one can take the per-unit historical

<sup>2</sup> D.14-08-032, p. 598.

1 cost to remove assets, and apply that per-unit cost to the *quantities* of assets in the surviving plant  
2 balance to obtain a reasonable forecast of the cost to remove the assets given projections about the  
3 timing of the assets' retirements. A key assumption in this analysis is the per-unit cost to retire each  
4 asset. While the proposals presented in SCE's depreciation study substantiate sound estimates of the  
5 future costs to retire, SCE does not overlook that future rate cases will provide updates to SCE's  
6 recorded experience that will further refine the expectations of future net salvage. That is, in future rate  
7 cases, SCE will have the ability to take its then-surviving plant balances to even better refine its  
8 projections about the future in light of then-available conclusions about historical costs-per-unit. By  
9 moderating SCE's depreciation expense, the Commission will make progress towards SCE's current  
10 estimate of forecast net salvage while permitting the Company in future rate cases to rely on additional  
11 data to refine its forecasts.

12 **D. Summary Tables**

13 Table I-3, Table I-4, and Table I-5 below summarize the life and net salvage parameters resulting  
14 from the analyses described in the chapters below.

**Table I-3<sup>10</sup>**  
**Summary of SCE's Request for Depreciation Parameters -**  
**Transmission and Distribution**

FERC Account	Description	Net Salvage Rates			Curves and Lives			Depreciation Rates		
		Auth.	Prop.	Change	Auth.	Prop.	Change	Auth.	Prop.	Change
A	B	C	D	E=D-C	F	G	H=G-F	I	J	K=J-I
<b>Transmission</b>										
352	Structures and Improvements	-35%	-35%		S 3.0 55	L 1.0 55		2.53%	2.40%	-0.13%
353	Station Equipment	-15%	-10%	5%	R 0.5 45	L 0.5 40	-5	2.66%	2.84%	0.18%
354	Towers and Fixtures	-60%	-75%	-15%	R 5.0 65	R 5.0 65		2.30%	2.73%	0.43%
355	Poles and Fixtures	-72%	-90%	-18%	R 0.5 50	SC 65	15	3.43%	2.84%	-0.59%
356	Overhead Conductors & Devices	-80%	-100%	-20%	R 3.0 61	R 3.0 61		2.63%	3.24%	0.61%
357	Underground Conduit	0%	0%		R 3.0 55	R 3.0 55		1.73%	1.73%	0.00%
358	Underground Conductors & Devices	-15%	-19%	-4%	R 2.5 40	S 1.0 45	5	2.65%	2.41%	-0.24%
359	Roads and Trails	0%	0%		SQ 60	R 5.0 60		1.52%	1.65%	0.13%
<b>Distribution</b>										
361	Structures and Improvements	-25%	-30%	-5%	R 2.5 42	L 0.5 50	8	3.04%	2.39%	-0.65%
362	Station Equipment	-25%	-31%	-6%	R 1.5 45	L 0.5 65	20	3.13%	2.01%	-1.12%
364	Poles, Towers and Fixtures	-210%	-263%	-53%	L 0.5 47	R 1.0 55	8	7.04%	7.09%	0.05%
365	Overhead Conductors & Devices	-115%	-144%	-29%	R 0.5 45	R 0.5 55	10	4.87%	4.49%	-0.38%
366	Underground Conduit	-30%	-38%	-8%	R 3.0 59	R 3.0 59		2.22%	2.27%	0.05%
367	Underground Conductors & Devices	-60%	-75%	-15%	R 0.5 45	R 1.5 43	-2	2.98%	3.94%	0.96%
368	Line Transformers	-20%	-25%	-5%	R 1.0 33	S 1.5 33		3.93%	4.57%	0.64%
369	Services	-100%	-125%	-25%	R 1.5 45	R 1.5 45		4.34%	5.04%	0.70%
370	Meters	-5%	0%	5%	R 3.0 20	R 3.0 20		5.30%	5.61%	0.31%
373	Street Lighting & Signal Systems	-30%	-38%	-8%	L 0.5 40	L 1.0 48	8	3.10%	3.00%	-0.10%
<b>General Buildings</b>										
390	Structures & Improvements	-10%	-10%	0%	R 3.0 38	R 0.5 45	7	2.74%	2.08%	-0.66%
Used a Per-Unit Analysis to analyze Net Salvage										
Moderated as discussed in Chapter 1, Section C										
Proposed Retention of Currently Authorized Lives										

<sup>10</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 5-20 (Rate Determination Schedule).

**Table I-4<sup>11</sup>**  
**Summary of SCE's Request for Book Depreciation**  
**Generation Plant**

Generation Facility	Life Spans		Net Salvage	
	Auth.	Prop.	Auth.	Prop.
A	B	C	D	E
Nuclear Production - Palo Verde	30.5 yrs.	28.0 yrs.	Covered under NDCTP	
Hydro Production	26.0 yrs.	19.9 yrs.	\$79.3 M	\$95.3 M
<b>Other Production</b>				
Pebbly Beach	45 yrs.	25 yrs.	\$6.6 M	-
Mountainview	35 yrs.	35 yrs.	\$16.3 M	\$18.5 M
Peakers	35 yrs.	35 yrs.	\$12.1 M	\$15.1 M
Solar Photovoltaic	25 yrs.	20 yrs.	\$81.9 M	\$80.9 M
Fuel Cells	10 yrs.	10 yrs.	-	-
Energy Storage	N/A	10 yrs.	N/A	-

**Table I-5<sup>12</sup>**  
**Summary of SCE's Request for Book Depreciation**  
**General and Intangible Plant**

FERC Account	Description	Lives		Depreciation Rates	
		Auth.	Prop.	Auth.	Prop.
A	B	C	D	E	F
<b>General Plant</b>					
389.2	Easements	60	60	1.67%	1.67%
391.1	Office Furniture	20	20	5.00%	5.00%
391.2	Personal Computers	5	5	20.00%	20.00%
391.3	Mainframe Computers	5	5	20.00%	20.00%
391.4	DDSMS-Security Monitoring System	Various	Various	12.90%	9.84%
391.5	Office Equipment	5	5	20.00%	20.00%
391.6	Duplicating Equipment	5	5	20.00%	20.00%
391.7	PC Software	5	5	20.00%	20.00%
393	Stores Equipment	20	20	5.00%	5.00%
394	Tools & Work Equipment	10	10	10.00%	10.00%
395	Laboratory Equipment	15	15	6.67%	6.67%
397	Telecommunication Equipment	Various	Various	9.77%	11.65%
398	Misc. Power Plant Equipment	20	20	5.00%	5.00%
<b>Intangible Plant</b>					
302.020	Hydro Relicensing	Various	Various	2.52%	2.47%
303.640	Radio Frequency	40	40	2.50%	2.50%
302.050	Miscellaneous Intangibles	20	20	5.00%	5.00%
303.105	Capitalized Software - 5 year	5	5	20.00%	20.00%
303.707	Capitalized Software - 7 year	7	7	14.29%	14.29%
303.210	Capitalized Software - 10 year	10	10	10.00%	10.00%
303.315	Capitalized Software - 15 year	15	15	6.67%	6.67%

<sup>11</sup> *Id.*, pp. 5-7.

<sup>12</sup> *Id.*, pp. 9-12.

## II.

### **COMMISSION DIRECTIVES FROM SCE'S 2015 GRC DECISION**

In the 2015 GRC Decision, the Commission gave four directives for SCE's net salvage proposals in this 2018 GRC proceeding. Most of the remainder of this chapter explains SCE's approach to meeting each of the directives. Section D addresses SCE's experience with increasingly negative net salvage rates (this testimony refers to "higher" net salvage rates, for simplicity's sake) and demonstrates how the advancing age of SCE's infrastructure and the increasing urbanization within its service territory has contributed to more negative NSRs.

#### **A. The Four Directives Established in the 2015 GRC Decision**

Ordering Paragraph 9 of the 2015 GRC Decision required SCE to "provide considerably more detail in support of its net salvage proposals for at least five of the largest accounts, as measured by proposed annual depreciation expense" including at least the following:<sup>13</sup>

##### The First Directive

"A quantitative discussion of historical and anticipated future Cost of Removal (COR) on a per unit basis for the large (greater than 15% as measured by portion of plant balance) asset classes in the account. This discussion should identify and explain the key factors in changing or maintaining the per-unit COR."

##### The Second Directive

"A quantitative discussion of historical and anticipated future retirement mix (i.e., retirements among different asset classes), identifying and explaining the key factors in changing or maintaining this mix."

##### The Third Directive

"A quantitative discussion of the life of assets and original cost of assets being retired, in relation to the COR, on both a historical and anticipated future basis. This discussion should be integrated with and/or cross-reference the proposal for life characteristics."

##### The Fourth Directive

"An account-specific discussion of the process for allocating costs to COR."<sup>14</sup>

The per-unit analysis required by the Commission involves substantially more work than a "traditional" net salvage analysis that is typically performed by the industry (as described in Standard Practice U-4).<sup>15</sup>

---

<sup>13</sup> D.15-11-021, Ordering Paragraph 9, p. 554.

<sup>14</sup> *Id.*, pp. 554-555.

<sup>15</sup> For the purpose of this testimony, the term "traditional approach" will be used to describe Standard U-4.

Table II-6, below, summarizes the differences at a high level, and Sections B and C of this chapter goes into more detail.

**Table II-6**  
**Summary of Difference Between Per-Unit Analysis and Traditional Approach**

Compliance Directive from 2015 GRC	Per-Unit Analysis (Required by 2015 GRC Decision)	Traditional Approach (As Established in Standard Practice U-4)
1. <b>Perform a per-unit COR analysis</b>	Separate account into sub-populations (e.g., account 365 conductor vs. account 365 switches) and calculate a per-unit COR. Math: Historical cost to retire assets divided by <i>quantities</i> of property units being retired within each subpopulation.	Calculate NSR at the account level of detail (e.g., account 365). Math: Historical cost to retire assets divided by <i>original cost</i> of assets retiring.
2. <b>Discuss Whether Retirement Mix Will Change Or Stay The Same</b>	Apply the per-unit cost estimate results to surviving plant balance assuming that the future retirement mix will be consistent with the current plant balance.	Assumes that the future retirement mix will mimic SCE's recorded experience.
3. <b>Integrate Salvage Analysis with Life Analysis</b>	Utilize original cost of current plant-in-service and results of the life analysis to estimate timing and cost of future retirements.	Assume that the future average age of retirements, and the inflation embedded in the cost of removal, will both mimic recorded activity.
4. <b>Discuss COR Allocation</b>	Provide account-specific discussion for the process for assigning costs to cost of removal (versus install).	

## **B. SCE's Approach to Addressing the Compliance Directives from the 2015 GRC Decision**

To comply with the directives from the 2015 GRC Decision, SCE performed a per-unit analysis for “at least five of the largest accounts, as measured by [the] proposed annual depreciation expense.” As shown in Table II-7, below, the five largest accounts under that definition are distribution accounts 364, 365, 367, 368, and 369.<sup>16</sup>

SCE performed a per-unit analysis on nine T&D accounts, which comprise 85% of the total COR expense proposed. Apart from the five largest accounts, SCE performed a per-unit analysis on another distribution line account, Account 366, which is the only remaining account in the series 364-369 (covering distribution line circuits). In addition, SCE performed a per-unit analysis for Account 354 (Transmission Towers) because a traditional analysis produced anomalous estimates of future net salvage rates (upwards of -800%) resulting from the removal of very old towers with a high cost to retire. SCE also selected accounts 355, 356, and 366 (Transmission Poles, Transmission Overhead

<sup>16</sup> The same five T&D accounts represented the top five accounts (measured by proposed depreciation expense) in the 2015 GRC.

1 Conductor, and Distribution Underground Conduit respectively) given their similarity to corresponding  
2 distribution account assets for which SCE conducted a per-unit analysis.

3 The Commission's directives from the 2015 GRC Decision stand alone. However, in the course  
4 of complying with those directives, SCE is indirectly addressing related directives from SCE's 2012  
5 GRC Decision (D.12-11-051, pp. 683-686). In the 2012 GRC decision, the Commission asked SCE to:  
6 (1) provide more information about its cost of removal estimates; and (2) to "review its allocation  
7 practices to be sure that all installation-related costs are booked to Plant-in-Service," instead of to cost of  
8 removal.<sup>17</sup> Both decisions request additional information substantiating removal costs and reviewing  
9 SCE's cost allocation. The primary distinction is that the 2015 GRC Decision required SCE to analyze  
10 its largest accounts by the proposed depreciation expense, whereas the 2012 GRC Decision instead  
11 required that SCE select its largest accounts using industry comparisons.

---

<sup>17</sup> D.12-11-051, p. 683.

**Table II-7**  
**T&D Accounts Ranked by Proposed Annual Depreciation Expense**  
*(Based on CPUC-Jurisdictional Depreciation Expense (\$M))*

FERC Account	Description	Proposed Depr. Exp.	Rank
<b>Transmission Plant</b>			
352	Structures and Improvements	5,101	15
353	Station Equipment	62,978	6
354	Towers and Fixtures	2,603	16
355	Poles and Fixtures	19,820	11
356	Overhead Conductors & Devices	7,856	13
357	Underground Conduit	1,053	17
358	Underground Conductors & Devices	6,160	14
359	Roads and Trails	114	18
<b>Distribution Plant</b>			
361	Structures and Improvements	13,783	12
362	Station Equipment	45,110	8
364	Poles, Towers and Fixtures	174,654	2
365	Overhead Conductors & Devices	64,341	5
366	Underground Conduit	44,209	9
367	Underground Conductors & Devices	218,724	1
368	Line Transformers	160,345	3
369	Services	65,591	4
370	Meters	50,205	7
373	Streetlights	26,163	10
Total		968,810	
<i>Proposals based on results of Per-Unit Analysis (\$758M or 78% of Total Expense)</i>			

## 1. The First Directive – Per Unit Net Salvage Analysis

The per-unit net salvage analysis segments each FERC plant account into large subpopulations (*i.e.*, dollar value of assets representing more than 15% of the total account balance).<sup>18</sup> To calculate the average per-unit cost to remove, SCE divided the net salvage dollars incurred by the quantity of units retired for each of the identified subpopulations. For example, Account 368—

<sup>18</sup> In the first compliance directive from the 2015 GRC Decision, the Commission referred to “large . . . asset classes in the account” as measured by 15% or more of the portion of plant balance. D.15-11-021, p. 398. SCE uses the term “subpopulation” to refer to those large asset classes within each FERC account.



1 Distribution Line Transformers—consists of three major subpopulations; overhead (OH) transformers,  
2 underground (UG) transformers, and fuseholders. For each subpopulation, SCE divided the net salvage  
3 incurred from 2009-2015<sup>19</sup> by the quantity of units retired, as shown in Figure II-3, below. This per-unit  
4 cost to remove each asset formed one part of the basis for forecasting SCE’s expected future net salvage  
5 proposals presented in this GRC.

6 a) Traditional Approaches to Analyzing Historical and Future Net Salvage  
7 Standard Practice U-4, Determination of Straight-Line Remaining Life  
8 Depreciation Accruals (“U-4,” or “Standard Practice U-4”), “sets forth various factors influencing the  
9 determination of depreciation accruals and describes methods of calculating these accruals”<sup>20</sup> with the  
10 purpose of assisting “the Commission staff in determining proper depreciation expenses.”<sup>21</sup> Although  
11 over 50 years old, Standard Practice U-4 represents conventional utility depreciation practices. The  
12 depreciation rates proposed in this study are consistent with the standard practices described in U-4. In  
13 addition, SCE conducted a more rigorous per-unit analysis for nine T&D accounts in response to the  
14 Commission’s directives from the 2015 GRC.

15 To meet requirements set forth in U-4, SCE uses different approaches to estimate  
16 NSRs based on the plant’s retirement characteristics and recorded experience. Broadly speaking, SCE’s  
17 net salvage study analyzes mass property differently than life-span property and other non-mass plant  
18 accounts. Mass property accounts (*e.g.*, transmission and distribution plant accounts) are those that have  
19 a significant number of property units which are generally retired separately. Life-span property refers to  
20 accounts which are comprised of a few major units which individually are expected to retire at a single  
21 point in time (*e.g.*, generating plants).

22 Mass property plant accounts, such as T&D, can contain a significant number of  
23 components and generally experience large numbers of retirement transactions under a diverse number  
24 of retirement circumstances. The large number of retirement units and retirement occurrences for mass  
25 property generally necessitate an analysis of *aggregate* historical NSRs and per-unit costs. To  
26 accomplish this, Standard Practice U-4 describes how to estimate future net salvage rates using the

---

<sup>19</sup> This period contains detailed net salvage data by CPR, available in PowerPlan, SCE’s capital system of record. Net salvage data prior to this period is maintained at the FERC prime account level only.

<sup>20</sup> Standard Practice U-4 is available at <http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M042/K177/42177433.PDF> and includes methods to analyze net salvage.

<sup>21</sup> *Id.*, p. 6.

experienced ratios of net salvage, gross salvage, and removal cost (in today’s dollars) as a percent of the original installed costs (in older dollars) of retirements. The average net salvage rate by FERC account is then applied to the total plant balance to determine the estimated future net salvage amount, barring any adjustments. Understanding the inputs involved in the calculation and the calculation itself is important to interpreting the resulting NSRs. The calculations are as follows:

**Figure II-2**  
**Computing NSRs Under the Traditional Approach**

$$\text{Net Salvage \%} = \text{Gross Salvage \%} - \text{Removal Cost \%}$$

$$\frac{\text{Net Salvage (\$)}}{\text{Retirements (\$)}} = \frac{\text{Gross Salvage (\$)}}{\text{Retirements (\$)}} - \frac{\text{Removal Cost (\$)}}{\text{Retirements (\$)}}$$


---

b) Comparing the Differences Between Calculating Net Salvage Ratios Using a Traditional Analysis Versus Per-Unit Analysis

The first and most important way that a per-unit analysis differs from the traditional analysis is that the NSRs are computed using the original cost of the *surviving* plant balance (*i.e.*, the current plant balance), as opposed to a traditional analysis’ use of the original cost of the plant that has already *retired*. That is, a traditional net salvage analysis examines the *historical* NSRs as the principal factor used to estimate *future* NSRs. By contrast, the per-unit analysis takes historical per unit costs and applies them to surviving plant *quantities* to project future removal costs given projections (from the life analysis) of when assets are expected to retire. The traditional approach implicitly assumes that factors such as the age of retirements, changes in SCE’s operating environment, levels of inflation and other factors will, in the future, be the same as they were in the past. By contrast, a per-unit analysis develops forward-looking estimates of net salvage by relying on recorded costs, surviving plant balances, and assumptions about the timing of future retirements.

An illustration of SCE’s approach to the per-unit analysis computation is instructive, especially compared to the calculation in Figure II-2, above. First, the net salvage cost per-unit is calculated by summing seven years’ worth of recorded history—in both dollars used to remove assets, and quantities of assets removed—to arrive at a per-unit net salvage value by sub-population:

**Figure II-3**  
**Calculation of Per-Unit Net Salvage Costs**  
*(Recorded 2009-2015 values for Account 368 – Line Transformers)*

Per-Unit Net Salvage	=	$\frac{\text{Net Salvage (\$)}}{\text{Quantity Retired}}$			
		Overhead <u>Transformer</u>	Underground <u>Transformer</u>	<u>Fuseholder</u>	<u>Others</u>
Per-Unit Net Salvage	=	<u>\$79,500,742</u> 141,838	<u>\$78,642,058</u> 53,904	<u>\$44,409,667</u> 275,472	<u>\$19,071,340</u> 19,862
	=	\$560.50	\$1,458.93	\$161.21	\$960.19

Next, the per-unit cost derived above is applied to a forecast using anticipated rates of inflation, as opposed to inflation experienced in the past. A simplified (no-inflation) calculation of future net salvage is shown in Figure II-4, as it shows the per-unit net salvage from Figure II-3 multiplied by the year-end 2015 surviving quantities (the study date). The resulting value is equivalent to an estimate of the cost to remove all of the assets in Account 368 as of the study date.

**Figure II-4 <sup>22</sup>**  
**Calculation of Future Net Salvage Using a Per-Unit Methodology**  
*(for Account 368 – Line Transformers; excluding future inflation)*

Future Net Salvage	=	$\frac{\text{Per-Unit NS}}{\text{Per-Unit Surviving Quantity}}$			
		Overhead <u>Transformer</u>	Underground <u>Transformer</u>	<u>Fuseholder</u>	<u>Others</u>
Future Net Salvage	=	<u>\$560.50</u> x 456,611	<u>\$1,458.93</u> x 259,299	<u>\$161.21</u> x 1,400,640	<u>\$960.19</u> x 62,788
\$920,320,858	=	\$255,932,428	\$378,298,499	\$225,801,375	\$60,288,556

This forecast of future net salvage can be divided by the costs of assets currently serving customers (the denominator, or surviving plant balance) to arrive at an estimated future NSR. This no-inflation estimate of the future NSR is shown in Figure II-5 below.

<sup>22</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 21-24 (Per-Unit Calculations).

**Figure II-5<sup>23</sup>**  
**Derivation of Future Net Salvage Rate Under a Per-Unit Analysis**  
*(for Account 368 – Line Transformers; excluding future inflation)*

$$\begin{array}{rcl} \text{Future Net} & = & \frac{\text{Future Net Salvage}}{\text{Surviving Plant}} \\ \text{Salvage Rate} & & \\ \\ 26.7\% & = & \frac{\$920,320,858}{\$3,450,870,284} \end{array}$$


---

To summarize, a per-unit analysis estimates future net salvage by: 1) establishing a per-unit cost to retire each asset, 2) applying results of the life analysis to estimate when these costs will be incurred, and 3) dividing this forecast net salvage by the surviving plant balance. See Figure II-6 below for a simplified comparison of the differences.

**Figure II-6**  
**Simplified Comparison of Traditional Analysis vs. Per-Unit Analysis**

<u>Traditional Analysis</u>	<u>Per-Unit Analysis</u>
$\text{Future Net Salvage Rate} = \frac{\text{Net Salvage Incurred}}{\text{Cost Retired}}$	$\text{Per-Unit Net Salvage} = \frac{\text{Net Salvage Incurred}}{\text{Quantity Retired}}$
	<div style="display: flex; align-items: center; justify-content: center;"> <div style="text-align: center;"> <math display="block">\text{Future Net Salvage} =</math> </div> <div style="text-align: center;"> <math display="block">\text{Per-Unit Net Salvage} \times \text{Surviving Quantity}^1</math> </div> </div>
	<div style="display: flex; align-items: center; justify-content: center;"> <div style="text-align: center;"> <math display="block">\text{Future Net Salvage Rate} =</math> </div> <div style="text-align: center;"> <math display="block">\frac{\text{Future Net Salvage}}{\text{Surviving Plant}}^2</math> </div> </div>

1. Multiplying by surviving quantity produces forward-looking estimates of net salvage (in more complex examples, the timing of removal and level of inflation will change the per unit net salvage value).

2. Using the surviving plant balance is representative of the future retirement mix.

## 2. The Second Directive – Retirement Mix

The second directive, requiring a discussion of the historical and future retirement mix, has been addressed by separating the original directive into two sub-directives (1) an analysis and

---

<sup>23</sup> *Id.*

discussion of the historical retirements, and (2) a discussion of the expected future retirement mix. The per-unit analysis described above complies with the first sub-directive because it requires review of the historical mix of retirements to determine an average per-unit cost to retire. To address the second sub-directive, SCE assumes that the future retirement mix will be consistent with the asset mix in the surviving plant balance as of year-end 2015. (In future rate cases, when the retirement mix changes, the forecast NSR will change accordingly.)

Analyzing the account by subpopulation achieves a more detailed “weighting” than looking at the account-based retirement mix in the aggregate. That is, the traditional approach focuses solely on the backward-looking ratios, which are used to estimate *future* net salvage. The blunt assumption underlying this approach is that the mixture of asset retirements in the past is representative of what one could expect in the future without regard to the composition of the then-current plant balance. Under the per-unit approach, by contrast, one focus is on the *surviving* plant balance, which offers a “snapshot” in real time that forms the basis for estimating the future mix of retirements. In determining its proposed depreciation expense, SCE did not identify or rely on factors that would cause it to modify the future retirement mix relative to the mix that currently exists in its plant accounts. Should factors in the future modify the retirement mix, the surviving plant balances examined at the relevant time will integrate and reflect those changes.

### **3. The Third Directive – The Age of Retirements and Integration of Salvage and Life Analyses**

The third directive requires SCE to provide a quantitative discussion of the life of assets and original cost of assets being retired in relation to the cost of removal. This directive has been addressed by separating the original directive into two sub-directives requiring (1) a discussion of the age of retirements *experienced* and (2) a forecast of the *future* age of retirements given the results of the life analysis. The Commission intended this directive to “integrate” the life analysis with the COR analysis: “This [COR] discussion should be integrated with and/or cross-reference the proposal for life characteristics.”<sup>24</sup> The only way to properly integrate both prongs of the analysis is to factor in the impact of the *passage of time*, or inflation, on the per-unit costs. To address this directive, SCE has provided the average age and original cost of assets retired, together with a forecast of future retirements

---

<sup>24</sup> D.15-11-021, p. 398 (see also Ordering Paragraph 9.i., pp. 554-555).

1 using the results of the life analysis. SCE’s forecasts are derived by integrating the historical (per-unit)  
2 cost to remove each asset with the forecast retirements from the life analysis.

#### 3 **4. The Fourth Directive – Process for Assigning Costs**

4 In compliance with the fourth directive from the 2015 GRC Decision—requiring SCE to  
5 provide an “account-specific discussion of the process for allocating costs to COR” for at least five of  
6 the largest accounts<sup>25</sup> — Section C below describes in detail SCE’s process for allocating a portion of  
7 total work order costs to cost of removal.

#### 8 **C. Process for Assigning Costs to Installation and Removal (The Fourth Directive)**

9 The 2015 GRC Decision requested an “account-specific” discussion of the process for allocating  
10 costs to removal. For every capital project SCE undertakes, one or more work orders is created and  
11 populated with a Unit Estimate (UE) in PowerPlan, which is SCE’s fixed asset accounting software  
12 system. UEs are comprised of *property* descriptions, otherwise known as continuous property records  
13 (CPRs), and *activity* descriptions. An example of a CPR is 364.330 for a distribution wood pole the  
14 “364” refers to FERC plant account 364 Distribution Poles, and the “.330” suffix refers to an SCE-  
15 specific retirement unit, in this case, a solely-owned wood pole.

16 The activity description of a UE is used to denote whether the activity undertaken within each  
17 work order involves: Installation of a new asset, Removal of an existing asset, or related Expense  
18 (I/R/E).<sup>26</sup> For each project, SCE personnel will populate a UE with the CPR and activity types that are  
19 specific to the project that they are estimating. (Note that capital material costs are assigned to Install,  
20 whereas, labor costs are assigned to I/R/E.)

21 UEs originate from two different “categories” of capital projects, each of which broadly uses a  
22 different cost assignment methodology. The first category is relevant to bulk-power transmission,  
23 substation, and generation-related projects, which combined account for approximately 15% of SCE’s  
24 total 2016-2020 forecast cost of removal in this rate case. In general, the assets in this category are  
25 booked to all plant accounts other than Accounts 364-373, and the process for allocating costs is  
26 described in subsection II.C.1, “Project-Specific Estimating” below.

27 The second category is relevant to distribution and sub-transmission line assets (*e.g.*, poles,  
28 conductors, streetlights, etc.), which together account for the majority (approximately 85%) of SCE’s

---

<sup>25</sup> *Id.*

<sup>26</sup> For this cost assignment description, the “expense” category is considered a non-capitalized activity but is included here for completeness.

total 2016-2020 forecast COR in this rate case. At a high level, the assets in this second category (sometimes referred to as “mass plant” assets) are booked to Accounts 364 to 373, and the process for assigning costs is described in subsection II.C.2., “Design Manager (DM) Estimating” below.

**1. Project-Specific Estimating (Bulk-Power Transmission, Substation, and Generation/Other)**

For project-specific estimating, SCE personnel create a detailed cost estimate for each of the activities required at the outset of each job. The cost estimate reflects the total estimated costs of *installation* separate from the total estimated costs of *removal*.

a) Bulk Power Transmission and Substation (Accounts 350-359 and 362)

For bulk power transmission and substation estimates,<sup>27</sup> engineers and technical experts use the Scope and Cost Management Tool (SCMT) to document, track, and communicate the scope for each project. Cost estimators then complete the costs for each project identifying and separating the installation, removal and expense activities. They assign CPR accounts that serve as the basis for creating the UEs that will ultimately be uploaded into the PowerPlan system.

For example, a capital project to replace a bulk power (*e.g.*, 500/220 kV) transformer begins when the estimator develops a specific cost estimate by itemizing the scope of major activities (*e.g.*, removing the old transformer, trench cover, power/control cable, conduits, etc. and then installing the new equipment).<sup>28</sup> The installation and removal activities are separately identified by hours required to install and/or remove the particular assets. In other words, there is a specific estimate of the labor, equipment, and associated overheads required to remove assets, and it is not a template-based “allocation” of *total* hours required for the job. The work is also broken out by the specific classification of employee who will be performing the task and also whether or not SCE crews or contract crews will be performing the work. The details of this estimate are compiled and used to create the UE in PowerPlan that will assign the ultimate costs recorded as “installation” costs versus “removal” costs.

b) Generation and Other (Accounts 301-348, and 390-398) <sup>29</sup>

Generation, Information Technology, and Operational Services also use project-specific estimating. That is, a detailed scope of work is set by engineers and other technical experts. The

---

<sup>27</sup> Examples of accounts with related assets are Accounts 350 to 359 and 362.

<sup>28</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 25-41 (Project-Specific Estimating) for an example of a project-specific estimate.

<sup>29</sup> Examples of some of these accounts are: Accounts 301 to 348 and 390 to 398.



scope of work is separated into installation and removal activities and becomes the foundation for building the UEs that are put in the PowerPlan System.

## **2. Design Manager (DM) Estimating (Distribution/Sub-Transmission Assets)**

For the large majority of capital assets, such as distribution and some sub-transmission line assets (*e.g.*, poles, conductors, streetlights, etc.), it is impractical for SCE to use project-specific estimating every time a new capital project is undertaken. That is because in any given year, SCE will install and replace thousands of these units of property. For example, in 2015 alone, SCE replaced over 40,000 wood poles, 25,000 transformers, and 3,000 miles of conductor.<sup>30</sup>

To manage the high volume of work, SCE uses a template-based estimating approach to assign a capital project's total costs to Installation, Removal, and Related Expense (I/R/E). Since 2010, SCE's planners have been using Design Manager to estimate labor hours, schedule work, and price distribution and sub-transmission projects. The DM estimating approach is commonly used for emergency work, planned/routine work, and customer-driven projects including relocations, overhead/underground conversions, new service connections and meter installations. A subset of data from DM is sent to PowerPlan, and that is where SCE's allocation methodology is applied for fixed asset accounting purposes, as explained in more detail below.

### **a) Building a Project Estimate in DM Using Compatible Units (CUs)**

A planner tasked with initiating a project (*e.g.*, a pole replacement) will open a work order and, based on the project scope (including site visits, where applicable), begin identifying Compatible Units (CUs) required to complete the job. CUs are building blocks of material and labor used to develop the distribution design and work order cost estimates. They eliminate the need for planners to manually identify and select every material component for frequently installed equipment and structures on SCE's electrical system. CUs identify the quantity and type of property needed for a project (*e.g.*, wood poles, transformers, conductors, etc.) and associated estimates of labor hours and costs. DM contains legend codes to indicate the type of activity to be performed for each asset (*i.e.*, installation vs. removal). DM incorporates the use of over 4,500 distribution CUs, to help planners build cost estimates and schedule work depending on the requirements of the job.

---

<sup>30</sup> Refer to WP SCE-09 Vol. 03, Book D, pp. 2-40 (Per-Unit Net Salvage Analysis). Estimates are taken from per-unit analysis quantity.



1                   b)       Cost Allocation in PowerPlan

2                   For purposes of fixed asset accounting, the CUs and legend codes from DM work  
3 orders are migrated to PowerPlan. CUs are paired with—and converted to—one of over 100 CPR  
4 accounts.<sup>31</sup> At this point, the CPR account consists only of quantities and types of property to be  
5 installed and, if applicable, quantities and types of property to be removed. The estimated costs and  
6 labor hours from DM are not carried over to PowerPlan. For fixed asset accounting purposes, SCE uses  
7 a “Standard Rates Table”<sup>32</sup> to allocate installation and removal costs relative to total project costs of  
8 individual work orders. The Standard Rates Table is also used to allocate costs among the appropriate  
9 FERC accounts.

10                   Each CU relates to a specific, individual piece of property. For example, different  
11 CUs are used to reflect the various height, class, material, and treatment status<sup>33</sup> of poles. Likewise,  
12 different CUs are used to reflect the various size, voltage and even manufacturer of transformers. The  
13 number of CUs that planners use to build a UE is many times greater than the number of CPRs to which  
14 the CUs are paired in PowerPlan. The Standard Rates Table allocation is therefore performed at an  
15 aggregated level that accounts for the various types of property the CPRs encompass. The table has been  
16 in continuous use since approximately the 1970s and it sets forth allocation factors that have been  
17 studied but that have not been materially modified over the years. However, in Chapter II.C.2.c., SCE  
18 describes three studies validating that the Standard Rates Table’s general allocations continue to be  
19 reasonable, if not more conservative in assigning costs to removal versus installation.

20                   An example of how the Standard Rates Table works in PowerPlan is illustrated in  
21 the three tables below, Table II-8, Table II-9, and Table II-10. Assume that a project to replace a wood  
22 pole also requires replacing an attached streetlight fixture. The table below lists the CPRs and the  
23 associated allocation factors by activity:<sup>34</sup>

---

<sup>31</sup> A CPR account is defined as the combination of a FERC plant account and a retirement unit subaccount.

<sup>32</sup> In prior rate cases, this “Standard Rates Table” has sometimes been referred to as “Table 34.”

<sup>33</sup> Treatment processes vary and are used to minimize pole decay (*e.g.*, through-boring, treatments, etc.).

<sup>34</sup> Note that the numbers are neither dollars nor hours; they are allocation factors from the Standard Rates Table. Refer to WP SCE-09 Vol. 03, Book A, pp. 47-51 (Standard Rates Table).

**Table II-8**  
**Standard Rates Table Values**

CPR Account	Description	Standard Rates Table Values			
		Install		Removal	Total
364.330	Distribution Wood Pole	1,286	+	600	= 1,886
		+		+	
373.390	Streetlight fixture	105	+	74	= 179
		=		=	
	Total	1,391	+	674	= <b>2,065</b>

The Standard Rates Table values are not important as absolute values; they are only meaningful in relation to each other. In the example above, the value assigned to removing the pole (600) is—appropriately—much larger than the value assigned to removing the fixture (74).

Table II-9 below converts the values in the rows and columns above to percentages of the total. Comparing the values across columns shows the allocation between install and removal. Comparing the values between rows shows the allocation between CPR accounts.

**Table II-9**  
**Percent of Sum of Standard Rates**

CPR Account	Description	Percent of Sum of Standard Rates Values			
		Install		Removal	Total
364.330	Distribution Wood Pole	62%	+	29%	= 91%
		+		+	
373.390	Streetlight fixture	5%	+	4%	= 9%
		=		=	
	Total	67%	+	33%	= <b>100%</b>

Allocation  
between CPR  
Accounts

Allocation between Install and Removal  
for replacement project

For fixed asset accounting purposes, the percentages from the table above are applied to the allocable dollars<sup>35</sup> in the project's work order, as shown in Table II-10 below.

<sup>35</sup> Material costs are generally allocated to installation, not removal.

**Table II-10**  
**Application of Standard Rates to \$1,000 of Labor**

CPR Account	Description	Application of Standard Rates to \$1,000 of Labor			
		Install		Removal	Total
364.330	Distribution Wood Pole	\$623	+	\$290	= \$913
		+		+	
373.390	Streetlight fixture	\$51	+	\$36	= \$87
		=		=	
	Total	\$674	+	\$326	= <b>\$1,000</b>

As illustrated in Table II-8, Table II-9, and Table II-10 above, while the Standard Rates Table uses a template approach to setting allocation factors, the resulting cost assignment for each project is “customized” in several ways. First, by virtue of the planner’s initial designation of CU legend codes, the *activity* for each CPR is appropriately designated as “installation” versus “removal,” and these splits are specific to each project depending on the properties and quantities that are installed or removed. Second, the *quantities* of property estimated by planners are drawn into PowerPlan and trued up by the end of every project to reflect what was actually removed and installed. Third, and most importantly, as units of property and quantities change with each work order, the matrix of cost assignment becomes more complex and reflective of the work performed in that project. For example, if another CPR account were added to the illustration above, the resulting allocations would be modified to reflect the weight of each CPR account relative to the total.

### **3. Substantiating SCE’s Standard Rates Table Allocation Factors**

SCE has conducted three studies substantiating the results of the Standard Rates Table’s installation and removal allocation factors—in 2004, 2006, and 2016. The results of these three studies are summarized in Table II-11, which shows the CORs as a percentage of total costs under the Standard Rates Table compared to the COR percentages from the 2004, 2006 and 2016 Studies. The table demonstrates that SCE’s allocation practice continues to be reasonable and appropriate. In fact, the Standard Rates Table COR allocations (on which the proposals for depreciation expense are based) are the most conservative with respect to removal costs given that the study results indicate that more dollars *could* be assigned to removal using cost assignment data from field experts.

**Table II-11<sup>36</sup>**  
**Comparison of Cost Assignment Ratios Across Three Studies Relative to the Standard Rates Table**  
*(Stated as Percentage of Total Cost)*

FERC Account	Description	Standard Rates Table	2004 Study	2006 Study	2016 Study
<b>Transmission Plant</b>					
354	Towers and Fixtures		Not Applicable - Non-Mass Plant		
355	Poles and Fixtures	27.2%	30.2%	31.4%	Not Studied
356	Overhead Conductors & Devices	42.1%	56.1%	56.7%	Not Studied
<b>Distribution Plant</b>					
364	Poles, Towers and Fixtures	36.6%	43.0%	39.4%	46.1%
365	Overhead Conductors & Devices	34.7%	38.6%	37.1%	35.6%
366	Underground Conduit	20.0%	42.3%	41.9%	41.7%
367	Underground Conductors & Devices	34.7%	32.1%	33.7%	35.7%
368	Line Transformers	27.3%	47.4%	48.8%	41.6%
369	Services	35.5%	44.2%	44.5%	33.8%
	Weighted Average*	33.0%	38.8%	38.3%	37.5%

\*Weighted by 2009-2015 Recorded Net Salvage

a) 2004 Study<sup>37</sup>

In the 2004 Study, performed for the 2006 GRC, SCE assembled field operations experts who compiled and analyzed work requirements for replacement projects of various assets under many different scenarios. The 2004 Study approached replacement costs from the perspective of SCE operations and maintenance personnel who had an average of 21 years of experience working with T&D assets. These subject matter experts, who had experience performing and supervising work activities, reviewed and assessed the time and work requirements for each of several scenarios including total time spent on the project, equipment requirements, and crew size requirements. The work activities were evaluated and separated into installation and removal activities. The experts compared the results from the study to the existing allocations in the Standard Rates Table and determined that no update to the Standard Rates Table was required because the estimated costs of removal were not overstated using the existing process.

<sup>36</sup> The nine accounts listed on this table are the same ones for which SCE performed a per-unit analysis. Refer to WP SCE-09 Vol. 03, Book A, pp. 42-46 (Summary of Study Results).

<sup>37</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 52-172 (2004 Study Results).

1 In preparing this testimony, SCE revisited the rebuttal testimony of its outside  
2 depreciation expert from the 2015 GRC. Appendix A of the witness's rebuttal testimony was a copy of  
3 the 2004 study, and, in response to a question about the "historical documentation describing . . . the  
4 development of allocation factors used by SCE," the witness referred to the 2004 study in Appendix A  
5 (among other things) as evidence that "SCE used a very robust and detailed process to develop its  
6 allocation factors."<sup>38</sup> As a point of clarification, the allocation factors to which the witness referred in his  
7 testimony are not the Standard Rates Table allocations that formed the basis of SCE's depreciation  
8 request in the 2015 GRC and this 2018 GRC.<sup>39</sup> Rather, the witness testified to the allocation process and  
9 results from the 2004 Study together with his own observations and discussions with field personnel  
10 about cost assignment. Any lack of clarity in distinguishing between the Standard Rates Table  
11 allocations and the 2004 Study's allocations is not material as demonstrated in Table II-11, above. In  
12 fact, the results of the 2004 Study would have assigned a larger percentage of costs to removal than does  
13 the Standard Rates Table (by approximately 5%), as shown in that table.

14 b) 2006 Study <sup>40</sup>

15 In 2006, SCE updated the 2004 Study in preparation for the 2009 GRC. Using a  
16 similar approach to the one utilized for the 2004 Study, SCE assembled a team of field operations  
17 experts to gather consensus estimates for labor hours for the job configuration scenarios used in the 2004  
18 Study. The panel of study participants included overhead and underground experts from metropolitan  
19 and rural areas of SCE's service territory and others who reviewed job conditions, crew sizes, and labor  
20 hour estimates. In addition, as an enhancement to the 2004 Study, the field experts weighted the  
21 installation and removal activities by the likelihood of the scenarios' occurrence in the field. The results  
22 from the analysis were compared to the Standard Rates Table allocations, and the experts determined  
23 that if they were to update the Standard Rates Table allocations to incorporate the results of the 2006  
24 Study, the cost of removal allocations would increase by over 5%. For this reason, and because SCE  
25 planned to implement new work planning and accounting software in 2010, SCE elected to continue  
26 using the Standard Rates Table.

---

<sup>38</sup> 2015 GRC, SCE-26, Volume 3, p. 13. Later in the same volume, SCE's witness testified that the study in Appendix A shows that "the allocation factor will change based on more complex installations." *Id.*, p. 115 (emphasis in original). This was a reference to the study results, not to the way in which the Standard Rates Table allocations are applied today.

<sup>39</sup> The Standard Rates Table was used to assign costs for several GRCs even prior to 2015.

<sup>40</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 173-188 (2006 Study Results).

1                   c)       2016 Study

2                           (1)       Background of Development of Compatible Units (CUs).

3                               Before explaining the results of the 2016 Study, it is important to  
4 understand the development beginning in 2009 of the CUs that T&D employees use to plan, estimate,  
5 schedule and bill work. As explained in section II.C.2, above, DM incorporates the use of over 4,500  
6 distribution CUs to assist planners with building cost estimates and scheduling work depending on the  
7 specific requirements of the job. When CUs are migrated to PowerPlan, they are mapped to CPRs and,  
8 for fixed asset accounting purposes only, the Standard Rates Table is used to allocate costs between  
9 removal and installation. The labor hours embedded in the CUs in DM are not used in the cost allocation  
10 process, but are important to facilitating the planning, scheduling, execution and closure of work orders  
11 for the T&D Operating Unit.

12                           (2)       2009-2010 Labor Study

13                               In 2009-2010, SCE undertook a year-long process to review and update  
14 the precursors to CUs, called “assembly kits,” in preparation for integration into DM and SAP. This  
15 effort to examine CU hours was internally referred to as the “Labor Study,” and it leveraged the results  
16 of the 2004 and 2006 Studies described above. The participants in the Labor Study—including  
17 construction managers and supervisors, foremen, trouble men, and standards and engineering teams  
18 from across SCE’s service territory<sup>41</sup> — examined over 4,500 CUs of distribution assets and modified  
19 1,800 of them.<sup>42</sup> The purpose was not to modify CUs for depreciation plant accounting purposes; rather,  
20 the intent of the study was to refine the “building blocks” of SCE’s thousands of work orders (CUs) to  
21 improve planning, crew scheduling, estimating and pricing jobs and work order closure processes.

22                               For three to four months of eight-hour days, the teams went line-by-line  
23 through SCE’s old Material Management System (the old mainframe system in which the assembly kits  
24 resided) to remove obsolete items.<sup>43</sup> The initial part of the Labor Study was devoted to just clearing  
25 SCE’s planning system of obsolete assembly kits. In the latter phase, the teams updated the labor hours

---

<sup>41</sup> Specifically, the experts came from the Metro West, Metro East, North Cost, Desert and Orange areas of SCE’s service territory.

<sup>42</sup> Separately, approximately 3,900 CUs for substation and sub-transmission assets were reviewed and migrated into SAP.

<sup>43</sup> For example, if the Material Management System referred to a transformer with certain voltage requirements that were no longer applicable, that assembly kit was removed.

1 of the most commonly used CUs—transformers, switches and poles. The goal was to approximate labor  
2 hours as precisely as possible in order to improve crew scheduling times and cost estimates.<sup>44</sup> The team  
3 based labor hour estimates on the expert judgment and analysis of T&D employees, taking into  
4 consideration factors such as crew size, whether the work is performed energized, and whether the crews  
5 would have vehicle access. The work also involved examining individual CUs to assign updated  
6 removal and installation hours. The end result of the panel of experts' process was to review—and, if  
7 necessary, revise—the installation and removal hours (the removal hours assigned in the old assembly  
8 kits had been set at roughly half of installation hours). The updated labor values were developed using  
9 an average of the best, typical and worst case scenario specific to the installation and removal of a CU.

10 By 2010, the update process for the CUs had been completed, but SCE  
11 uses an ongoing governance structure to further update CUs on an ad hoc basis when required. There are  
12 three full-time employees whose job is focused on maintaining and updating CUs so that  
13 proposed/required changes flow through a standard process. The CU team receives an average of 22  
14 requests each year to create new CUs (from planning, engineering, apparatus and meter services). The  
15 team also receives approximately 60 requests each year to review the accuracy of specific CUs  
16 (requesting review of hours or material components). Of the approximately one thousand field requests  
17 that have come through to examine CUs since 2010, less than a handful of requests actually resulted in  
18 changes to the installation/removal hours. This is due both to the comprehensiveness of the 2009-2010  
19 Labor Study and the reality that work processes/practices do not change so significantly over time as to  
20 impact cost of removal ratios.

21 When planners use CUs to design and estimate particular jobs, they may—  
22 based on their own experience or through discussions with field personnel—supplement the labor  
23 estimates with additional Install, Removal or Expense labor hours on a work order-by-work-order basis.  
24 Any changes made to the project based on job complexity, additional crew tailboards, additional traffic  
25 control requirements, travel time, etc. are used for that specific work order only, and do not result in  
26 updating the master CU in the CU library. Updates to the CUs in the CU library occur occasionally. For  
27 example, in August 2012, a manager within the Street and Outdoor Lighting Organization requested that  
28 the CU team review the installation hours for street light photocells given his assessment that the 0.5

---

<sup>44</sup> Work under Rules 2, 15, 16 and 20 benefit from accurate cost estimates built into CUs because those estimates form the basis for how customers are billed.



1 man hours for installation of this CU appeared high. The CU team pulled together a team of subject  
2 matter experts to assess and recommend a revision to the hours and determined that it should be reduced  
3 to 0.1 hours. Upon approval, the update was made in DM.

4 (3) 2016 Comparison of Standard Rates Table and CUs

5 In 2016, SCE undertook a study comparing the Standard Rates Table  
6 allocations with what the allocations would be if SCE's fixed asset accounting process mapped the CU  
7 process described above. The scope of the study included a review of over 70,000 individually planned  
8 distribution orders developed in Design Manager in 2015, which collectively amounted to \$1.7 billion,  
9 or approximately 84% of that year's capital expenditures. The review included comparing the  
10 installation and removal cost allocation from DM against the Standard Rates Table allocation for all  
11 70,000 orders. The results indicate that the planners' CU-based approach, which is more detailed than  
12 the higher-level aggregation of the CPR-based allocations in the Standard Rates Table, results in cost  
13 assignments substantially similar to the Standard Rates Table (validated by the 2004 and 2006 Study  
14 results based on the panels of T&D experts).<sup>45</sup>

15 **D. SCE's Experience with Increasingly Negative Net Salvage Rates**


16 NSRs are typically negative because gross salvage is largely negligible compared to the cost of  
17 removal. The main reason for more negative NSRs can be attributed to the results of this mathematical  
18 formula: (1) costs to retire assets (numerator) in today's dollars divided by (2) the age and original cost  
19 of assets retired (denominator). Since 2002, SCE's 5-year rolling average NSR has more than tripled for  
20 distribution infrastructure, from -66% to -283% as shown in Figure II-7 below.

---

<sup>45</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 189-197 (2016 Study Results).



**Figure II-7**  
**Realized Net Salvage Ratios**  
**Distribution Plant 2002-2015**



For the last twenty years, SCE has experienced increasingly negative net salvage ratios for reasons explained in the next sections.

**1. The Average Age of Retirements is Increasing**

a) Age and Inflation Impacts on Recorded Net Salvage Ratios

An important consideration for the net salvage ratio calculation is that the numerator (net salvage cost) and the denominator (original cost) are stated in dollars spent at different points in time. The original cost retired in the denominator are measured in dollars from the time the plant was first placed in service (*i.e.*, older dollars) and the net salvage amounts in the numerator are measured when the plant is retired from service (*i.e.*, using more recent dollars). For example, a distribution pole placed into service in 1970 and retired in 2015 will have an original cost stated in 1970 dollars, but the removal costs will be incurred using 2015 dollars. Consequently, the temporal distance between installation and removal can have a significant effect on net salvage ratios primarily due to the effects of inflation. The effects of inflation are most apparent in the removal cost ratio, as the cost to retire (*i.e.*, labor) is what is subject to the forces of inflation.<sup>46</sup>

<sup>46</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 198-201 (Experienced Net Salvage Rates) - *Depreciation Systems*, Frank K. Wolf and W. Chester Fitch, Iowa State University Press, pp. 53-55.

To illustrate the impact of inflation using a real life example, Table II-12, below, shows that the removal cost ratio increases with the age of the pole retired. Column C reflects the original cost of the pole being retired, while column D represents the removal cost in current dollars.

**Table II-12**  
**Plant Retirement and Removal Cost**  
*(As Experienced for Distribution Poles – Account 364)*  
*Data based on averages from 2009 to 2015*


Vintage	Age of Pole Retired	Original Cost of Pole Retired	Per Pole Removal Cost	Removal Cost Ratio
A	B	C	D	E=D/C
2010	2.5	\$7,599	\$2,862	38%
2000	12.5	\$3,547	\$2,862	81%
1990	22.5	\$1,413	\$2,862	203%
1980	32.5	\$622	\$2,862	460%
1970	42.5	\$369	\$2,862	775%
1960	52.5	\$167	\$2,862	1717%

The table above demonstrates that as the age of the asset retired grows, the effects of inflation have an increasingly large impact on the realized removal cost ratio. This occurs because the average cost to install a pole in 1960 (Column C) would be significantly lower than the average cost to install a pole today, while the cost to remove each pole (Column D) is the same regardless of the age of the pole retired.

b) SCE's Aging Retirements

For multiple GRCs, T&D experts have testified about the advancing age of SCE's infrastructure. As the system matures, the average age of any retirement can be expected to be older than what was experienced in the past. As the system ages, the incidence of age related failures will increase. In fact, as shown in Figure II-8, below, this has been SCE's experience with distribution infrastructure for the past 13-years.

**Figure II-8**  
**Average Age Of Distribution Infrastructure Retired**



As the age of T&D retirements increases, the original cost of the retirements has remained low, resulting in an increase in the experienced net salvage ratios.

## 2. Total Cost Increases Affect Cost of Removal

Over the last several rate cases, T&D experts have testified to the increasing need for capital to replace aging T&D infrastructure. This capital (including both the cost to remove and install) has been discussed by multiple witnesses over more than a decade of rate cases. In each case, witnesses have testified to cost pressures from the effects of: increasingly urban environments, increasing labor and contractor rates, increased permitting costs, more stringent environmental regulations, disposal fees, and system complexity.

For example, in the 2006 GRC the T&D Infrastructure Replacement witness provided the following still-relevant discussion on why the cost to retire assets in urban environments is higher than in rural areas:<sup>47</sup>

- 1) Permitting: Pole contractors are almost always required to obtain a city permit before initiating the work. In rural areas, permits are almost never required.

<sup>47</sup> 2006 GRC SCE-03 Vol 03 Part III pp. 14-15 and 2009 GRC SCE-03 Vol 03 Part III pp. 20-21.

- 2) Accessibility: Urban areas are frequently inaccessible by trucks and require that a crane be rented or that the pole be carried into the back yard and set manually. Rural areas are typically truck-accessible.
- 3) Congestion: Higher customers per circuit in urban areas contribute to higher congestion per pole than in rural areas. For example, an urban pole can be expected to be taller, as well as have more conductors, transformers, and cross-arms than a rural pole. In addition, the work may be performed on energized lines requiring specially trained crews and safety requirements.
- 4) Repairs: Urban areas frequently require that repairs are made to the concrete sidewalks, a requirement not typically necessary in rural areas.

Los Angeles County's population experienced significant growth<sup>48</sup> in the post-World War II period through the 1970s. This post-war population growth has increased the level of urbanization across SCE's service territory, putting upward pressure on costs. As a result of this, when assets originally installed in a rural environment are removed, the net salvage ratio reflects a very low original install cost for these assets. But these same assets are likely being replaced in a now more urban environment, adding to the upward pressure on removal cost. This experience can have a significant effect on the net salvage ratios—lower original cost (denominator) and higher cost of removal (numerator).

Given the increasing age of this infrastructure and the increasing urbanization associated with the post-war population growth, increases in the realized net salvage ratios is not surprising. As a result, however, the conditions present in SCE's service territory over this period of time may not be a realistic expectation of the future. In this case, and as further discussed immediately below, a per-unit analysis controls for this variation, and better represents SCE's expectation about the future levels of net salvage.

### **3. SCE's Per-Unit Analysis is Indifferent to the Realized Net Salvage Ratios**

As described in Section B.1 of Chapter II, a per-unit analysis takes a different approach than Standard Practice U-4 in analyzing the expected levels of future net salvage. Rather than reviewing the relationship between historical costs of assets and the net salvage experienced in the past, the per-unit analysis uses the recorded average cost to retire each unit of property, and then applies per-unit

---

<sup>48</sup> 2009 GRC SCE-03 Vol 03 Part 3 p. 15 (SCE Territory – Population and System Demand).

1 costs to existing plant balances to forecast future net salvage given the anticipated timing of retirements.  
2 This approach to estimating future net salvage helps ensure that the results of the analysis are applicable  
3 to the mixture of plant that is serving customers today. Over time, as this mix of plant balances change,  
4 SCE will have the opportunity to reflect these changes in future per-unit analyses presented in its rate  
5 cases.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

### III.

#### **DEPRECIATION STUDY**

Chapter II, above, explained how SCE complied with the Commission’s compliance directives and addressed the difference between traditional and per-unit analyses. The depreciation study addressing T&D assets, presented in Section A in Q&A format, was undertaken by an external consultant, Ronald E. White Ph.D. of Foster Associates Consultants, LLC. Dr. White provided SCE with life and net salvage parameters that SCE then used to calculate the proposed depreciation rates. SCE also conducted an in-house depreciation study of its Generation and G&I depreciable plant assets, discussed by an in-house SCE expert witness in Section B, below.

Unlike the Simulated Plant Record (SPR) procedure used in prior SCE rate cases, Dr. White performed an *actuarial* service life analysis using aged data from 2002 to 2015. In the 2012 GRC, the Commission stated that aged data is likely to be more reliable than SPR data, and it ordered SCE to “inform the Commission whether it used any aged data, and if not, when sufficient data is expected to be available.”<sup>49</sup> In its 2015 GRC testimony, SCE stated that it began collecting aged data in 2008 and that it did not have sufficient aged data to perform an effective actuarial life analysis for the 2015 GRC.<sup>50</sup> This statement was based on an incorrect assumption that the Company began collecting aged data in 2008 when it implemented PowerPlan as its capital system of record.<sup>51</sup> In preparing its showing for this proceeding, SCE discovered that PowerPlan contains reconciled aged plant activity from 2002 forward. Thus, for this GRC, Foster Associates LLC performed an actuarial life analysis using the aged data from 2002 to 2015.<sup>52</sup>

Section A of Chapter III, below, which is in Q&A format, is the direct testimony of Dr. Ronald E. White of Foster Associates LLC.

---

<sup>49</sup> D.12-11-051 p. 685.

<sup>50</sup> See Testimony in 2015 GRC, SCE-10, Vol. 02, Revision 1A, p. 33. SCE stated that it expected that aged data may become useful “in 10 years or so.” *Id.*

<sup>51</sup> PowerPlan was used only as the depreciation system of record prior to 2008.

<sup>52</sup> SCE possesses some aged retirement data from 1994 through 2001 in Excel format outside of SCE’s current capital system of record (PowerPlan). Neither SCE nor its outside expert evaluated or relied on the aged data in the 1994-2001 Excel sheets.

1 **A. T&D - Average Service Life and Net Salvage Proposals**

2 **1. Development of Depreciation Rates**

3 **Q. PLEASE EXPLAIN WHY DEPRECIATION STUDIES ARE NEEDED FOR**  
4 **ACCOUNTING AND RATEMAKING PURPOSES.**

5 A. The goal of depreciation accounting is to charge to operations a reasonable estimate of the cost  
6 of the service potential of an asset (or group of assets) consumed during an accounting interval.<sup>53</sup>  
7 A number of depreciation systems have been developed to achieve this objective, most of which  
8 employ time as the apportionment base.

9 Implementation of a time-based (or age-life) system of depreciation accounting requires the  
10 estimation of several parameters or statistics related to a plant account. The average service life  
11 of a vintage, for example, is a statistic that will not be known with certainty until all units from  
12 the original placement have been retired from service. A vintage average service life, therefore,  
13 must be estimated initially and periodically revised as indications of the eventual average service  
14 life becomes more certain. Future net salvage rates and projection curves, which describe the  
15 expected distribution of retirements over time, are also estimated parameters of a depreciation  
16 system that are subject to future revisions. Depreciation studies should be conducted periodically  
17 to assess the continuing reasonableness of parameters and accrual rates derived from prior  
18 estimates.

19 The need for periodic depreciation studies is also a derivative of the ratemaking process  
20 which establishes prices for utility services based on costs. Absent regulation, deficient or  
21 excessive depreciation rates will produce no adverse consequence other than a systematic over or  
22 understatement of the accounting measurement of earnings. While a continuance of such  
23 practices may not comport with the goals of depreciation accounting, the achievement of capital  
24 recovery is not dependent upon either the amount or the timing of depreciation expense for an  
25 unregulated firm. In the case of a regulated utility, however, recovery of investor-supplied  
26 capital is dependent upon allowed revenues, which are in turn dependent upon approved levels of  
27 depreciation expense. Periodic reviews of depreciation rates are, therefore, essential to the

---

<sup>53</sup> The service potential of an asset is the present value of future net revenue (*i.e.*, revenue less expenses exclusive of depreciation and other non-cash expenses) or cash inflows attributable to the use of that asset alone.

achievement of timely capital recovery for a regulated utility.

It is also important to recognize that revenue associated with depreciation is a significant source of internally generated funds used to finance plant replacements and new capacity additions. This is not to suggest that internal cash generation should be substituted for the goals of depreciation accounting. However, the potential for realizing a reduction in the marginal cost of external financing provides an added incentive for conducting periodic depreciation studies and adopting proper depreciation rates.

**Q. PLEASE DESCRIBE THE PRINCIPAL STEPS INVOLVED IN  
CONDUCTING A DEPRECIATION STUDY.**

A. The first step in conducting a depreciation study is the collection of plant accounting data needed to conduct a statistical analysis of past retirement experience. Data are also collected to permit an analysis of the relationship between retirements and realized gross salvage and cost of removal. The data collection phase should include a verification of the accuracy of the plant accounting records and a reconciliation of the assembled data to the official plant records of the Company.

The next step in a depreciation study is the estimation of service life statistics from an analysis of past retirement experience. The term *life analysis* is used to describe the activities undertaken in this step to obtain a mathematical description of the forces of retirement acting upon a plant category. The mathematical expressions used to describe these forces are known as survival functions or survivor curves.

Life indications obtained from an analysis of past retirement experience are blended with expectations about the future to obtain an appropriate projection life curve. This step, called *life estimation*, is concerned with predicting the expected remaining life of property units still exposed to the forces of retirement. The amount of weight given to the analysis of historical data will depend upon the extent to which past retirement experience is considered descriptive of the future.

Average and future net salvage rates are ideally estimated from a historical analysis of the cost per unit to install and the net cost per unit to retire major retirement units. A per unit analysis explicitly recognizes that the cost per unit to retire an asset is independent of the age of the asset when it is retired from service. The cost to retire a foot of conductor today, for example, is no different for a conductor that was installed yesterday or a conductor that was installed many years ago. As a result, percentage rate required to accrue for \$5 per foot of removal expense on a



conductor costing \$10 per foot to install is twice the rate required to accrue the same amount of removal expense on a conductor costing \$20 per foot to install.

Although a per unit analysis of installation and retirement costs is the most desirable treatment of net salvage, time and cost considerations (as well as the availability of the required data) often dictate a less rigorous analysis. Net salvage rates are frequently developed from a historical analysis using a three to ten-year moving average of the ratio of realized salvage and cost of removal to associated retirements. Net salvage estimates are also obtained from engineering studies of the cost to dismantle or abandon existing facilities.

## **2. 2016 Service-Life Study**

### **Q. DID SCE PROVIDE FOSTER ASSOCIATES PLANT ACCOUNTING DATA FOR ESTIMATING SERVICE LIFE PARAMETERS?**

A. Yes. Service life statistics estimated in the 2016 study were derived from plant accounting transactions recorded over the period 2002 through 2015. Detailed accounting transactions were extracted from the Continuing Property Record (CPR) system and assigned transaction codes which describe the nature of the accounting activity. Transaction codes for plant additions, for example, were used to distinguish normal additions from acquisitions, purchases, reimbursements and adjustments. Similar transaction codes were used to distinguish normal retirements from sales, reimbursements, abnormal retirements and adjustments. Transaction codes were also assigned to transfers, capital leases, gross salvage, cost of removal and other accounting activity that should be considered in a depreciation study.

The accuracy and completeness of the assembled database was verified for activity years 2002 through 2015 by comparing the beginning plant balance, additions, retirements, transfers and adjustments, and the ending plant balance derived for each activity year to the official plant records of the Company. Age distributions of surviving plant at December 31, 2015 were reconciled to the CPR.

### **Q. HOW WERE SERVICE-LIFE ESTIMATES DERIVED FOR SCE PLANT AND EQUIPMENT?**

A. As noted above, the first step in estimating service lives is called *life analysis*. All transmission, distribution and general depreciable plant accounts were analyzed using a technique in which first, second and third degree polynomials were fitted to a set of observed retirement ratios. The

1 resulting function was expressed as a survivorship function, which was numerically integrated to  
2 obtain an estimate of the average service life. The smoothed survivorship function was then  
3 fitted by a weighted least-squares procedure to the Iowa-curve family to obtain a mathematical  
4 description or classification of the dispersion characteristics of the data. Service life indications  
5 derived from the statistical analyses were blended with informed judgment and expectations  
6 about the future to obtain an appropriate projection life curve for each plant category. The  
7 analysis of each plant account is contained in Appendix A.

8 **Q. PLEASE EXPLAIN IN GREATER DETAIL HOW LIFE ANALYSES WERE**  
9 **CONDUCTED IN THE 2016 STUDY.**

10 A. The fundamental probability distribution of interest in estimating the service life of industrial  
11 property is called a *hazard function*. This function, which is also used in reliability theory, is an  
12 equation that describes the conditional probability of retirement (called a *hazard rate*) during an  
13 age interval given survival to the beginning of the interval. So, for example, the probability that  
14 plant that has been in service, say for 5 years, will be retired during the 6<sup>th</sup> year is a conditional  
15 probability of retirement. In other words, the probability is conditioned upon having achieved an  
16 age of 5 years.

17 Graduating or smoothing observed hazard rates is an application of inferential statistics  
18 which draws inferences and predictions about a population based on samples of data taken from  
19 the population of interest. Projection lives and projection curves are population parameters  
20 “inferred” from a statistical analysis of the underlying forces of retirement described by  
21 probability distributions.

22 The object of a statistical analysis of plant retirements is to find the form of an equation that  
23 best describes the conditional probabilities of retirement, where the form of the equation is  
24 driven by the underlying forces of retirement. Any number of equations can be considered as  
25 candidates for selection. The so-called Iowa curves are a family of distributions most often used  
26 in conducting depreciation studies.

27 Each Iowa curve has a unique hazard function derived from the ratio of its retirement  
28 frequency distribution to its survivor distribution. Unfortunately, however, Iowa hazard functions  
29 cannot be written as explicit equations. It is for this reason that polynomials of the form  
30  $y = a + bx + cx^2 + dx^3$  are used to estimate hazard functions. The variable  $y$  is the hazard rate

and  $x$  is the age interval of the rate.<sup>54</sup> A polynomial can be transformed into a survivor function and plotted against an Iowa curve to visually observe the derived survivor curve expressed as an Iowa curve.

The problem, therefore, is to estimate the coefficients (*i.e.*,  $a$ ,  $b$ ,  $c$  and  $d$ ) of the polynomial from an estimate of hazard rates derived from a sampling of historical retirements recorded for a plant category. Different estimators of the hazard rate can be used depending upon the desired statistical properties of the estimator. The ratio of retirements to exposures is most often used for depreciation studies.

Coefficients were estimated in the 2016 study using *Orthogonal Polynomials*. An orthogonal polynomial is not a special form of a polynomial. It is a procedure developed by Tchebysheff to estimate the coefficients of a polynomial (using regression) without rewriting the normal equations for each successive power of the polynomial. The coefficients of a second degree equation, for example, can be derived from a first degree equation without rewriting the equations used in a normal least squares regression.

Coefficients and polynomials were estimated for numerous trials or samples of retirements recorded over various bands of activity years. An activity year is the calendar year in which retirements were recorded. Retirements from vintages of like ages are combined to increase the size of the samples from which hazard rates are estimated. The motivation for examining various bands of activity years is to observe service–life trends to the extent they may be detectable.

Each polynomial was transformed or converted to a survivor function (or survivor curve when plotted) from which an estimate of the projection life was derived. The polynomial form of the hazard functions were also plotted and visually inspected as an aid to better understanding the forces of retirement acting upon a plant category.

Polynomials transformed to survivor functions were then fitted to Iowa–type curves with projection lives set equal to those derived from the polynomials. The purpose of fitting to Iowa curves is to obtain service–life descriptors more familiar to users of Iowa curves. It would be more obscure and less informative to describe survivor curves by the coefficients of a polynomial.

---

<sup>54</sup> The reason polynomials are limited to a third degree term (*i.e.*, a polynomial having an  $x^3$  term) is that some low modal Iowa curves exhibit two inflection points in a plot of the hazard function.

1 **Q. WERE FACTORS OTHER THAN SERVICE–LIFE INDICATIONS DERIVED**  
2 **FROM THE STATISTICAL STUDIES CONSIDERED IN ESTIMATING**  
3 **SERVICE–LIVES FOR SCE?**

4 A. Yes. As discussed earlier, estimating service lives is a two–step procedure. The first step (life  
5 analysis) is largely mechanical and primarily concerned with history. Statistical techniques are  
6 used in this step to obtain a mathematical description of past forces of retirement acting upon a  
7 plant category and an estimate of the projection life implied from observed historical experience.

8 The second step (life estimation) is concerned with predicting the expected remaining life of  
9 property units still exposed to forces of retirement and the service life of future plant additions. It  
10 is a process of blending the results of a life analysis with information (mostly qualitative) and  
11 informed judgment to obtain an appropriate projection life and curve descriptive of future  
12 expectations. The amount of weight given to a life analysis will depend upon the extent to which  
13 past retirement experience is considered descriptive of the future. Both life analysis and life  
14 estimation require an understanding of the limitations of statistical studies and the need for  
15 reasonable and informed judgment.

16 **Q. ARE FACTORS YOU CONSIDERED IN LIFE ESTIMATION DESCRIBED**  
17 **IN THE 2016 STUDY?**

18 A. Yes. Appendix A contains a narrative explanation of both quantifiable factors (life analyses) and  
19 non–quantifiable factors (largely life estimation) considered by Foster Associates in  
20 recommending appropriate projection lives and curves for SCE. In those instances in which  
21 statistical indications could not be derived and/or observed indications were adjusted for  
22 operational, financial or ratemaking reasons, Foster Associates deferred to SCE in the selection  
23 of appropriate service lives.

24 **Q. IS A PROJECTION LIFE THE SAME AS AN AVERAGE SERVICE LIFE?**

25 A. No. A projection life is an estimate of the mean service–life of the population from which  
26 retirements are a random sample. The *average* service life of a plant category is a function of the  
27 age distribution of surviving plant (*i.e.*, plant currently in service by vintage–year of installation)  
28 and a selected level of asset grouping such as broad–group, vintage–group or equal-life group. If  
29 retirements are distributed over varying ages, the broad–group procedure (which assumes that

each vintage has the same average service life) is the only grouping of assets that will produce an average service life equal to the projection life estimated for a plant category.

**Q. PLEASE SUMMARIZE THE FINDINGS OF YOUR SERVICE-LIFE STUDY.**

A. Current and recommended projection lives and dispersions are summarized in Table III-13 below.

**Table III-13**  
**Service Life Statistics**

Account Description A	Current		Recommended	
	P-Life C	Dispersion D	P-Life E	Dispersion F
<b>Transmission Plant</b>				
352.00 Structures and Improvements	55.00	S3	55.00	L1
353.00 Station Equipment	45.00	R0.5	40.00	L0.5
354.00 Towers and Fixtures	65.00	R5	65.00	R5
355.00 Poles and Fixtures	50.00	R0.5	65.00	SC
356.00 Overhead Conductors and Devices	61.00	R3	61.00	R3
357.00 Underground Conduit	55.00	R3	55.00	R3
358.00 Underground Conductors and Devices	40.00	R2.5	45.00	S1
359.00 Roads and Trails	60.00	SQ	60.00	R5
<b>Distribution Plant</b>				
361.00 Structures and Improvements	42.00	R2.5	50.00	L0.5
362.00 Station Equipment	45.00	R1.5	65.00	L0.5
364.00 Poles, Towers and Fixtures	47.00	L0.5	55.00	R1
365.00 Overhead Conductors and Devices	45.00	R0.5	55.00	R0.5
366.00 Underground Conduit	59.00	R3	59.00	R3
367.00 Underground Conductors and Devices	45.00	R0.5	43.00	R1.5
368.00 Line Transformers	33.00	R1	33.00	S1.5
369.00 Services	45.00	R1.5	45.00	R1.5
370.00 Meters	20.00	R3	20.00	R3
373.00 Street Lighting and Signal Systems	40.00	L0.5	48.00	L1
<b>General Plant</b>				
390.00 Structures and Improvements	38.00	R3	45.00	R0.5

**Table 1. Service Life Statistics**

**3. 2016 Net Salvage Study**

**Q. WHY IS NET SALVAGE RECOGNIZED IN THE COMPUTATION OF DEPRECIATION ACCRUAL RATES?**

A. Depreciation is a measurement of the service potential of an asset that is consumed during an accounting interval. The cost of obtaining a bundle of service units (*i.e.*, a future net revenue stream) is represented by an initial capital expenditure which creates a revenue requirement for return and depreciation, and a future expenditure which creates a revenue requirement for cost of

removal reduced by salvage proceeds. The matching principle of accounting provides that both the initial and future expenditures should be allocated to the accounting periods in which the service potential of an asset is consumed. The standard or criterion that should be used to determine a proper net salvage rate is, therefore, cost allocation over economic life in proportion to the consumption of service potential. If some other standard (such as cash flow or revenue requirements) is considered more important in setting depreciation rates, then cost allocation theory must be abandoned as the foundation for depreciation accounting.

The need to include net salvage in the development of depreciation rates is widely recognized and accepted by a substantial majority of state regulatory commissions as a standard ratemaking principle. The FERC Uniform System of Accounts (USoA), for example, describes depreciation as the "... loss in service value" where service value is defined as "... the difference between original cost and net salvage value of gas plant." Net salvage value means "the salvage value of property retired less the cost of removal."

The economic principle underlying both the accounting and ratemaking treatment of net salvage is that in addition to return *of* and return *on* invested capital and taxes, a revenue requirement for removal expense (or a reduction in the revenue requirement attributable to gross salvage) is created when an asset is placed in service. It is customary and appropriate for regulated utilities, therefore, to include a net salvage component in its depreciation rates to more nearly achieve the goals of depreciation accounting and to equitably distribute the revenue requirement for removal expense over the period in which the assets that created the requirement are used to provide utility service.

**Q. WHAT IS A FUTURE NET SALVAGE RATE?**

A. Future net salvage (in percent) is the sum of future net salvage (*i.e.*, gross salvage less cost of removal) at a given observation age divided by the surviving plant investment at that age.

**Q. WHAT IS AN AVERAGE NET SALVAGE RATE?**

A. Average net salvage (in percent) is the sum of realized and future net salvage divided by the plant investment at age zero. Stated differently, average net salvage is the total estimated salvage less cost of removal for a vintage (or group of vintages) expressed as a percent of the original vintage additions. Future net salvage is related to the surviving plant of a vintage (or group of vintages) whereas average net salvage is associated with the original vintage addition.

1 **Q. ARE YOU FAMILIAR WITH THE COMMISSION’S DECISION IN SCE’S**  
2 **2015 GRC (D.15-11-021) REGARDING NET SALVAGE PROPOSALS?**

3 A. Yes. In the 2015 GRC Decision, the Commission directed SCE to provide more detail in support  
4 of its net salvage proposals for at least five of the largest accounts, as measured by proposed  
5 annual depreciation expense. At a minimum, this detail shall include:

- 6 1. “A quantitative discussion of historical and anticipated future Cost of Removal  
7 (COR) on a per unit basis for the large (greater than 15% as measured by the  
8 portion of plant balance) asset classes in the account. This discussion should  
9 identify and explain the key factors in changing or maintaining the per-unit  
10 COR.”
- 11 2. “A quantitative discussion of historical and anticipated future retirement mix  
12 (i.e., retirements among different asset classes), identifying and explaining the  
13 key factors in changing or maintaining this mix.”
- 14 3. “A quantitative discussion of the life of assets and original cost of assets being  
15 retired, in relation to the COR, on both a historical and anticipated future basis.  
16 This discussion should be integrated with and/or cross-reference the proposal  
17 for life characteristics.”
- 18 4. “An account-specific discussion of the process for allocating costs to COR.”<sup>55</sup>

19 a) Directive No. 1

20 **Q. WERE HISTORICAL AND FUTURE NET SALVAGE COSTS DERIVED ON**  
21 **A PER UNIT BASIS IN COMPLIANCE WITH THE COMMISSION’S FIRST**  
22 **DIRECTIVE?**

23 A. Yes. Per unit net salvage analyses were conducted for the nine (9) plant accounts listed in Table  
24 III-14, below.

---

<sup>55</sup> D.15-11-021, pp. 554-555.



**Table III-14**  
**Per Unit Net Salvage Accounts**

Account Description
354.00 Towers and Fixtures
355.00 Poles and Fixtures
356.00 Overhead Conductors and Devices
364.00 Poles, Towers and Fixtures
365.00 Overhead Conductors and Devices
366.00 Underground Conduit
367.00 Underground Conductors and Devices
368.00 Line Transformers
369.00 Services

**Table 2. Per Unit Net Salvage Accounts**

Each of the nine plant accounts was grouped into one or more subpopulations of major equipment categories. Historical per unit ratios (defined as net cost per unit to retire divided by the cost per unit to install) were used in both the historical and future per unit analyses. Net costs to retire (or net salvage) were used in the analysis to maintain consistency with future net salvage parameters used in the formulation of remaining-life accrual rates. Gross salvage is generally small in relation to cost of removal.

Historical per unit ratios were examined and compared with the ratio of realized net salvage to the associated retirements. In most instances, the ratio of net salvage to retirements is greater than historical per unit ratios observed over the period 2009–2014. This is predictable since net salvage is recorded in current dollars and retirements are recorded in historical dollars.

Future per unit ratios were derived using a weighted average of the subpopulation net salvage per unit values recorded over the period 2009–2015. These values appear in the numerator of future per unit ratios. This treatment was decided after multiple meetings and discussions with SCE engineers and subject matter experts who reported that SCE has no planned or expected changes in retirement activities that would measurably change average net salvage per unit values recorded in recent activity years. Other than recognizing future inflation, historical net salvage per unit values were therefore retained in the forecast of future net salvage rates. Subpopulations and average historical per unit net salvage costs are summarized in Table III-15 below.



**Table III-15**  
**Average Net Salvage Per Unit to Retire**

Account and Subpopulation	12/31/2015		Avg. Add Per Unit*	Avg. NS Per Unit*
	Plant	Percent		
A	B	C	D	E
354.00 Towers and Fixtures				
A. Towers Solely Owned >= 230 kV	\$ 1,139,621,027	91.8%	\$ 610,475	\$ 57,365
B. Towers < 230 kV, Common and Other	101,453,733	8.2%	321,711	6,628
	1,241,074,760	100.0%		
355.00 Poles and Fixtures				
A. Wood, Fiber Glass and Composite	375,781,560	47.2%	14,939	4,517
B. Light Duty Steel	419,049,403	52.6%	18,775	10,281
C. Retaining Walls	1,261,756	0.2%	145,988	(36,480)
	796,092,719	100.0%		
356.00 Overhead Conductors and Devices				
A. Conductor < 220 kV	202,769,129	18.7%	11	5
B. Conductor >= 220 kV	739,015,019	68.3%	38	6
C. Disconnect Switches	27,761,688	2.6%	42,650	11,921
D. Ground Wire	113,151,541	10.5%	20	(46)
	1,082,697,377	100.0%		
364.00 Poles, Towers and Fixtures				
A. Wood, Fiberglass and Steel Poles	2,191,572,261	100.0%	6,882	2,700
	2,191,572,261	100.0%		
365.00 Overhead Conductors and Devices				
A. Overhead Conductor	946,696,334	68.6%	8	3
B. Switches	347,104,388	25.1%	12,828	3,384
C. Breakers, Reclosures and Other	87,013,183	6.3%	2,404	358
	1,380,813,905	100.0%		
366.00 Underground Conduit				
A. Pull and Slab Boxes	447,741,061	13.0%	949	1,305
B. Below Ground Conduit	789,932,796	22.9%	23	1
C. Vaults	324,651,530	9.4%	7,584	23,101
D. Excavation Trenches	16,836,983	0.5%	(77)	
E. Manholes and Other	157,068,859	4.6%	1,258	462
	1,736,231,229	50.3%		
367.00 Underground Conductors and Devices				
A. Underground Cable	4,452,641,073	84.6%	25	10
B. Breakers, Switches, Reclosures	809,879,908	15.4%	8,567	4,896
	5,262,520,981	100.0%		
368.00 Line Transformers				
A. Overhead Transformers	1,045,618,106	30.3%	2,655	561
B. Underground Transformers	1,262,937,734	36.6%	5,899	1,459
C. Lightning Arresters and Fuse Holders	749,306,101	21.7%	924	161
D. Switches, Breakers, Capacitors, etc.	393,008,343	11.4%	5,658	960
	3,450,870,284	100.0%		
369.00 Services				
A. Underground Conductor	783,834,596	61.2%	301	221
B. Overhead Conductor	387,892,896	30.3%	236	123
C. Risers	63,694,659	5.0%	881	450
D. Underground Conduit and Other	44,872,497	3.5%	12	0
	1,280,294,648	100.0%		
*2009 - 2015				

**Table 3. Average Net Salvage Per Unit to Retire**

The per unit cost of plant additions used in forecasting future net salvage rates was obtained by dividing vintaged plant in service at December 31, 2015 (*i.e.*, age distributions of surviving plant) by vintaged units in service within each subpopulation. The ratio of average net salvage per unit experienced over the period 2009–2015 (adjusted for inflation) to the per unit cost of plant in service is the ratio that was applied to forecasted retirements to estimate future net

salvage for each vintage. The sum of future net salvage over all vintages divided by current plant account balances produces an estimated future net salvage rate for each primary account. The formulation of per-unit net salvage rates is contained in Appendix B.

**Q. PLEASE SUMMARIZE THE FINDINGS OF YOUR PER UNIT NET SALVAGE ANALYSIS.**

A. Future net salvage rates derived with inflation rates ranging between zero (0) and three (3) percent are summarized in below.

**Table III-16**  
**Future Net Salvage Rates**

Account Description	Projection Curve	Inflation Rate			
		0%	1%	2%	2.72%
A	B	C	D	E	F
354.00 Towers and Fixtures	65-R5	104%	125%	155%	185%
355.00 Poles and Fixtures	65-SC	90%	155%	295%	499%
356.00 Overhead Conductors and Devices	61-R3	114%	141%	178%	210%
364.00 Poles, Towers and Fixtures	55-R1	180%	249%	361%	488%
365.00 Overhead Conductors and Devices	55-R0.5	195%	272%	397%	538%
366.00 Underground Conduit	59-R3	108%	170%	276%	401%
367.00 Underground Conductors and Devices	43-R1.5	112%	150%	205%	261%
368.00 Line Transformers	33-S1.5	27%	33%	40%	47%
369.00 Services	45-R1.5	178%	231%	309%	387%

**Table 4. Future Net Salvage Rates**

**Q. HOW WERE NET SALVAGE RATES ESTIMATED FOR ACCOUNTS NOT INCLUDED IN THE PER UNIT NET SALVAGE ANALYSIS?**

A. A five-year moving average analysis of the ratio of realized salvage and removal expense to the associated retirements was used to: a) estimate a realized net salvage rate; b) detect the emergence of historical trends; and c) establish a basis for estimating a future net salvage rate. Cost of removal and salvage opinions obtained from Company personnel were blended with judgment and historical net salvage indications in developing estimates of the future. The analysis of net salvage is contained in Appendix A.

Although future per unit ratios applied to a forecast of future retirements provides a more rigorous estimate of future net salvage rates, it is the opinion of Foster Associates that the ratio of realized net salvage to retirements provides reasonable estimates of future net salvage rates to the extent that future inflation is similar to the past. Estimating depreciation rates, however, is not an exact science; errors of estimate in both service lives and nets salvage rates will always remain.

b) Directive No. 2

**Q. WERE HISTORICAL AND FUTURE RETIREMENT MIXES EVALUATED  
IN COMPLIANCE WITH THE COMMISSION'S SECOND DIRECTIVE?**

A. Yes. As noted above, each of the nine plant accounts was divided into one or more subpopulations of major equipment categories. The mix of equipment classified in each subpopulation and the size of each subpopulation as a percent of the current investment in each related plant account were reviewed by SCE engineering and plant accounting personnel. No key factors were identified from this review that would suggest the future retirement mix or relative size of each subpopulation will be significantly different from the current composition and grouping of subpopulations.

c) Directive No. 3

**Q. WERE RECOMMENDED LIFE CHARACTERISTICS AND NET COST OF  
REMOVAL INTEGRATED IN COMPLIANCE WITH THE COMMISSION'S  
THIRD DIRECTIVE?**

A. Yes. The directive to provide a quantitative discussion of asset life and original cost of assets being retired, in relation to the COR on a historical basis, was interpreted to mean an examination of the average age of retirements associated with the recording of COR. Work papers supporting Appendix A provide a summary (Schedule E) of the average age of retirements and recorded COR for each of the per unit accounts. Although net salvage is often recorded subsequent to the recording of retirements, it can be observed that COR as a percent of retirements is a function of the age of retirements and generally increases with increases in the average age.

As noted earlier, a prospective per-unit analysis should be designed to produce estimates of future net salvage rates respecting the principle that the net cost per unit to retire an asset is independent of the age of the asset when it is retired from service. The percentage rate applied to the cost of an old asset to accrue the same cost per unit to retire a newer asset, however, depends upon the relative difference in the cost per unit incurred to install the assets. Integration of per unit ratios with life characteristics necessitates forecasting vintaged retirements using projection lives and curves estimated for each plant account.

Estimates of the amount and timing of future net salvage were derived from an application of

1 the ratio of per unit net costs to retire and per unit installed costs of each vintage within a  
2 subpopulation, to future retirements (forecasted by vintage) using the projection lives and curves  
3 estimated in the statistical life studies. Inflation rates ranging between zero and three percent  
4 were employed in the analysis to recognize the likelihood of increasing net salvage solely  
5 attributable to inflation.

6 Other than a range of assumed inflation rates and parameters estimated in the service-life  
7 studies, no elements of qualitative judgment were required or exercised in estimating future net  
8 salvage rates from the per unit analysis.

9 d) Directive No. 4

10 **Q. THE COMMISSION'S FOURTH DIRECTIVE IN APPLICATION A.13-11-**  
11 **003 WAS TO PROVIDE AN ACCOUNT-SPECIFIC DISCUSSION OF THE**  
12 **PROCESS FOR ALLOCATING COSTS TO COR. HAS SCE COMPLIED**  
13 **WITH THIS DIRECTIVE?**

14 A. Yes. The process for allocating costs is described in the direct testimony of SCE witness Alan  
15 Varvis in this Exhibit.

16 **Q. DOES THIS CONCLUDE YOUR DIRECT TESTIMONY?**

17 A. Yes, it does.

## **B. Generation and G&I - Average Service Life and Net Salvage Proposals**

### **1. Purpose and Scope**

This chapter covers the average service lives and net salvage proposals for SCE's Generation and General & Intangible (G&I) assets. For G&I assets, SCE proposes to retain the same service lives and net salvage rates as authorized in the 2015 GRC Decision.


### **2. Generation-Related Property**

#### **a) Average Service Lives for Generation Assets**

Generating facilities are life span assets that consist of large plant assets expected to retire all at one time, with some smaller components retiring earlier during the service life of the plant (called "interim retirements"). To determine the *average* life of the plant asset, SCE adjusts the life span downward to take into account the shorter-lived interim retirements. The life span for a generating facility as a whole depends on the factors affecting the final shutdown: operating license, fuel and resource availability, contractual obligations, the relative efficiency of the generating units, and so forth. The total life span is determined largely as an engineering judgment based on the factors previously mentioned.

Interim retirements consist of such items as pumps, motors, and other individual generating components that retire depending on the factors specifically affecting them—wear and tear, reliability, obsolescence, and so forth. The impacts of the life span and the interim retirements on the overall average service life of the plant asset are determined separately. SCE considered the interim retirement adjustment first by estimating the future level of annual interim retirements as a percent of the plant balance (*i.e.*, an interim retirement rate or IR rate). The estimate of an IR rate is made by analyzing the historical levels of interim retirements. The determined annual IR rate is applied to the current plant balance over the remaining life of the plant to determine the necessary adjustment to the overall remaining life of the generating station. For example, if a generating plant has a 10-year remaining life and an IR rate of 1.4 percent per year, then about 14 percent of the current plant balance would retire as interim retirements (10 years times 1.4 percent year) and the remaining 86 percent would retire as a final retirement. The resulting survivor curve is shown in Figure III-9.

**Figure III-9**  
**Life Span Survivor Curve\***



\* Remaining Life Span = 10 years; IR Rate = 1.4%.

As Figure III-10 demonstrates, the average life is equal to the life span adjusted for the shorter life of the interim retirements. The remaining life adjustment is calculated as follows:

**Figure III-10**  
**Life Span: Remaining Life Adjustment**

$$\begin{aligned} \text{Remaining Life Adjustment} &= \frac{\text{Rem. Life Span} \times \text{IR Rate}}{2} \times \text{Rem. Life Span} \\ 0.7 \text{ Years} &= \frac{10 \text{ Years} \times 1.4\%}{2} \times 10 \text{ Years} \end{aligned}$$

Table III-17 summarizes SCE's proposed generation average service lives as compared to those authorized in the 2015 GRC. What follows is a plant-by-plant discussion of the proposed average service lives.

**Table III-17**  
**Generation Service Life Spans**

Generation Facility	Life Spans	
	Authorized	Proposed
A	B	C
Nuclear Production - Palo Verde	30.5 yrs	28.0 yrs
Hydro Production	26 yrs	19.9 yrs
<b>Other Production</b>		
Pebbly Beach	45 yrs	25 yrs
Mountainview	35 yrs	35 yrs
Peakers	35 yrs	35 yrs
Solar Photovoltaic	25 yrs	20 yrs
Fuel Cells	10 yrs	10 yrs
Energy Storage	N/A	10 yrs

(1) Palo Verde Nuclear Generating Station (PVNGS)

The Nuclear Regulatory Committee (NRC) licenses for PVNGS Units 1, 2, and 3 end June 1, 2045, April 24, 2046, and November 25, 2047, respectively, resulting in an average 30.5 year remaining life span for the station as of December 31, 2015. In addition, recent retirement activity supports adjusting the average remaining life down by 2.5 years to 28 years to account for the effect of interim retirements.

(2) Hydro Generation

SCE's hydro generation system consists of 76 generating units and associated facilities accounted for in 60 different accounting locations. Nearly all of SCE's hydro facilities (99 percent) is covered by FERC licenses. The licenses have a variety of termination dates—from expired (either in the process of being relicensed or decommissioned) to 2046. The total life span of SCE's current license periods for those plants without expired licenses range between 5 and 30 years. Recently, FERC has issued renewals with license periods averaging 40 years.

Prior license renewal does not guarantee that the generating plant will last indefinitely. There are no guarantees that the FERC will continue to grant the company licenses or that the generating units will continue to be economic. Moreover, the individual components making up a generating station will continue to wear out, be retired, and need to be replaced. Consequently, SCE proposes that the hydro generation plant be depreciated over the remaining life spans associated with the

individual FERC licenses.<sup>56</sup> For generating stations with already expired, or within five years of license termination, SCE proposes that the life spans be extended by the estimated license life in its current FERC license applications.<sup>57</sup>

(3) Pebbly Beach

The Pebbly Beach generating station consists of six diesel generating units, ranging in capacity from 1.0 MW to 2.8 MW. In its last GRC, SCE was authorized a 45-year average service life for this account on the basis that each of the six units would experience increasing risk of obsolescence and failure after two overhaul cycles (approximately 22 years between overhauls). Because of the difficulty in sourcing alternative supply of generation for Catalina Island, SCE engineers expect these units to remain in-service for the foreseeable future. However, to help ensure continued operations, SCE engineers state that the units require a zero-time overhaul<sup>58</sup> after approximately 100 to 120 thousand operating hours. Based on SCE's actual experience with the operations of these units, the time between overhauls is approximately 25 years.

For example, the SCE is proposing to reduce the average service life for this account from the currently authorized 45 years to 25 years. This change is concurrent with moving the start of the amortization period from the vintage year to the date of the last overhaul. This 25-year life allows SCE to recover the cost of each zero-time overhaul over its useful life with little impact to the remaining life as shown in Table III-18 below.

---

<sup>56</sup> In the case of the 1 percent of hydro plant not covered by a FERC license, SCE applies the average life determined for the plant that is covered by FERC license.

<sup>57</sup> The average application license period is 44 years. The exception to this life span extension is the amortization period for the hydro relicensing costs. These relicensing costs are only amortized over the associated license period for which they were spent.

<sup>58</sup> A zero-time overhaul restores operations of the unit to like-new operating conditions.



**Table III-18 <sup>59</sup>**  
**Comparison of SCE's 2015 Authorized and 2018 Proposed Lives for**  
**Pebble Beach Generating Station**

Line No.	Item	2015 GRC Authorized	2018 GRC Proposed
1.	Average Start Date	1986	2006
2.	Proposed ASL	45	25
3. = 1.+2.	Estimated Ret. Date	2031	2031
4. = 3. - 2015	Rem. Life a/o 1/1/2016	15.7	15.5

There have been insufficient interim retirements to estimate an IR rate for this plant; consequently both the remaining life span and the average remaining life are 15.5 years for this account.

(4) Mountainview

SCE is proposing to retain Mountainview's currently authorized 35-year life span as established in the 2015 GRC Decision. There have been insufficient interim retirements to estimate an IR rate for this plant; consequently both the remaining life span and the average remaining life are 25 years for this account.

(5) Peakers

SCE is proposing to retain the currently authorized 35-year average service life for Peaker. There have been insufficient interim retirements to estimate an IR rate for this plant; consequently both the remaining life span and the average remaining life are 28 years for this account.

(6) Solar Photovoltaic

The currently authorized average service life for Solar Photovoltaic (PV) equipment is 25 years. SCE is proposing to return to the previously authorized 20-year average service life. Based on discussions with SCE engineers<sup>60</sup> the major components of this account will have significantly shorter service lives than the currently authorized 25-year life. Engineers indicate that the

<sup>59</sup> Refer to WP SCE-09 Vol. 03, Book A, p. 203 (Generation Life Spans).

<sup>60</sup> Refer to WP SCE-09 Vol. 03, Book A, p. 204 (Generation Life Spans).

equipment in this account is expected to fail significantly sooner than the currently authorized 25-year authorized life. For example, the three main components<sup>61</sup> include:

- Solar Panels – 10-12 years
- Inverters – 5-8 years (warranted for 5 years)
- Control System – 6-8 years for obsolescence to set in.

In addition, the rooftop leases granting SCE the rights to use the rooftop facilities is currently 20-years. Given the uncertainty of lease renewal and short expectations about the life of the equipment, a 20-year life proposal is reasonable for this account. There have been insufficient interim retirements to estimate an IR rate for this plant; consequently both the remaining life span and the average remaining life are 16 years for this account.

(7) Fuel Cells

SCE owns and operates two fuel cell demonstration facilities. The plants, located at California State University, San Bernardino (CSUSB) and University of California Santa Barbara (UCSB) were installed in September 2012 and October 2013 respectively. SCE is proposing to retain the currently authorized 10-year average service life. This proposal is consistent with our expectations that title to the demonstration facilities will be transferred to the site owners at the end of their 10-year lease.

(8) Energy Storage

The Commission has required SCE to procure and install 580 MW of energy storage facilities in its service territory by 2020. These facilities represent emerging technology and face significant risk of technological obsolescence in the future. SCE estimates the life of Energy Storage by the design life, cycle times of the proposed facilities, discussion with engineers, reviewing of reputable engineering studies and benchmarking with industry peers. SCE proposes a 10-year average service life for the Energy Storage and this represents a reasonable estimate of the expected life of these facilities when they are deployed.

b) Net Salvage Rates for Generation Assets

As discussed above, generation properties are retirement units that will retire in full at a specific time. Although there are interim additions and retirements that occur over the service life of the plant, the plant as a whole is subject to final retirement. SCE's generating plants—Palo Verde,

---

<sup>61</sup> *Id.*

Hydro, Pebbly Beach, Mountainview, Peakers, Solar Photovoltaic, Fuel Cell—fit these characteristics. The net salvage for SCE’s generation plants is considered using two basic elements—interim retirement net salvage and final retirement net salvage (*i.e.*, “decommissioning”)—which are estimated separately. The final retirement net salvage entails an engineering estimate of the cost to remove and dispose of the plant and equipment existing at the time of the station’s final shutdown.

In contrast to final retirements, interim retirement net salvage is the removal cost associated with the numerous small retirements occurring over the life of the generating station. This net salvage is estimated based upon an analysis of recorded interim net salvage ratios similar to the approach followed for mass property. Finally, the interim and final net salvage amounts are combined based upon the associated plant dollars to determine a total weighted average net salvage for the generating station. The estimated decommissioning costs at retirement are shown in the Table III-19 below. Interim retirement net salvage is relatively small with only a minor impact to amortization levels.

**Table III-19**  
**Generation Removal Cost**

Plant	Decommissioning		Interim Retirement NS	
	Auth.	Prop.	Auth.	Prop.
A	B	C	D	E
Nuclear Production - Palo Verde	Covered Under NDCTP		-	\$2.1 M
Hydro Production	-	-	\$1.9 M	\$4.5 M
<b>Other Production</b>				
Pebble Beach	\$6.6 M	-	-	-
Mountainview	\$16.3 M	\$16.2 M	-	-
Peakers	\$12.1 M	\$14.9 M	-	-
Solar Photovoltaic	\$81.9 M	\$80.8 M	-	-
Fuel Cells	-	-	-	-
Energy Storage	N/A	-	-	-

The net salvage estimates for generating stations will differ significantly depending upon a variety of factors. Although the net salvage consists of both interim retirement net salvage and final decommissioning costs, the scale of the decommissioning costs will generally drive the overall net salvage levels requested. In the case of Palo Verde, only interim retirement net salvage is included in the filing and is estimated to be zero percent at this time. The Commission will address the final decommissioning costs of Palo Verde in the Nuclear Decommissioning Cost Triennial Proceedings. The following sections discuss the decommissioning estimates for the respective generation facilities.

1 (1) Palo Verde Net Salvage

2 As previously mentioned, only interim retirements are addressed in this  
3 filing. While SCE did not request for interim retirement net salvage cost in its prior rate cases, recent  
4 retirement activity supports a modest increase. As such, SCE is proposing to include the interim  
5 retirement net salvage rates as shown in Table III-20, below.

***Table III-20<sup>62</sup>***  
***Palo Verde Interim Retirement Net Salvage***

	Net Salvage Ratio (% of IRs)	Net Salvage Ratio (% of Plant)
Land and Land Rights	0.0%	0.0%
Structures and Improvements	-0.15%	0.0%
Reactor Plant Equipment	-20.0%	-3.7%
Turbogenerator Units	-16.0%	-5.9%
Accessory Electric Equipment	-13.0%	-0.6%
Misc. Power Plant Equipment	-16.0%	-2.0%

6 (2) Hydro Net Salvage

7 With the exception of San Geronio Unit 2, which is an active state of  
8 decommissioning, SCE is not requesting net salvage for decommissioning at this time. SCE is  
9 continuing to remove/retire San Geronio Unit 2 and is requesting \$6.4M for the capital expenditures  
10 expected to be incurred from 2016 to 2019.

11 Interim retirement net salvage ratios for interim retirements are calculated  
12 by analyzing the recent retirement history for the level of net salvage incurred during interim  
13 retirements. The ratio of net salvage (gross salvage less cost of removal) divided by the retirement  
14 values is used to arrive at the net salvage ratios shown in Table III-21, below.

---

<sup>62</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 205-214 (Palo Verde Interim Retirements).

**Table III-21<sup>63</sup>**  
**Hydro Interim Retirement Net Salvage**

	Net Salvage Ratio (% of IRs)	Net Salvage Ratio (% of Plant)
Structures and Improvements	-150%	-10.9%
Reservoirs, Dams and Waterways	-250%	-5.6%
Water Wheels, Turbines & Generators	-50%	-9.5%
Accessory Electric Equipment	-150%	-10.6%
Misc. Power Plant Equipment	-20%	-1.9%
Roads, Railroads & Bridges	-100%	-11.5%

(3) Pebbly Beach Net Salvage

Due to the expectations that the diesel generators will continue to operate in the foreseeable future, SCE is not proposing to recover any decommissioning costs in this rate case. Because of limited retirement history, SCE is not proposing recovery of interim retirement net salvage at this time.

(4) Mountainview Net Salvage

SCE compiled a list of equipment and facilities to be installed as part of the new generation facilities and itemized them by FERC plant account.<sup>64</sup> SCE then developed demolition costs for each component. The estimated decommissioning costs for Mountainview is \$8.9 million (2012 dollars). SCE escalated the \$8.9 million out to the end of the remaining life of the station, resulting in \$16.2<sup>65</sup> million. Because of limited retirement history, SCE is not proposing recovery of interim retirement net salvage at this time.

(5) Peakers Net Salvage

In 2007, SCE commissioned Arcadis to perform decommissioning cost studies for each of its five Peaker units. Table III-22 below shows the current cost for each unit, totaling \$7.7M. Escalated to the estimated year of final retirement produces a total future decommissioning cost of \$14.9M.<sup>66</sup> Because of limited retirement history, SCE is not proposing recovery of interim retirement net salvage at this time.

<sup>63</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 215-223 (Hydro Interim Retirements).

<sup>64</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 308-313 (Mountainview Decomm).

<sup>65</sup> *Id.*

<sup>66</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 225-291 (Peakers Decomm).

**Table III-22**  
**Peaker Decommissioning Costs (\$000's)**

Line No.	Peaker Unit	2015 (\$) Decomm	Retirement Year	Retirement Year Decomm (\$)
1.	Barre	\$1,427	2042	\$2,676
2.	Center	\$1,414	2042	\$2,652
3.	Grapeland	\$1,593	2042	\$2,987
4.	McGrath	\$1,683	2042	\$3,155
5.	MiraLoma	\$1,604	2047	\$3,407
		<u>\$7,722</u>		<u>\$14,877</u>

(6) Solar Photovoltaic Net Salvage

In 2011, SCE commissioned Worley Parsons to conduct a decommissioning study of its Solar Photovoltaic Equipment. The study resulted in a range of estimates between \$300,000 and \$547,000 per megawatt in 2011 dollars based on the type of facility installed. Lower cost estimates are associated with ground mount installations characterized by ease of access and fewer equipment requirements, while the higher cost facilities are rooftop mounted that increase the complexity of removal activities. Escalating the estimates to the end of the proposed 20-year average service life results in a total decommissioning estimate of \$81 million as shown in Table III-23. Because of limited retirement history, SCE is not proposing recovery of interim retirement net salvage at this time.

**Table III-23**  
**Solar Decommissioning Costs by Panel Type (\$000's)**

Installation Type	2015 \$ Megawatt	Installed MW	Total Decomm 2015 (\$)	Total Decomm Retirement Year (\$)
A	B	C	D=B*C	E
Rooftop - Floating	\$614	54	\$32,890	\$47,959
Rooftop - Anchored	\$645	31	\$20,071	\$29,486
Ground Mount	\$354	7	\$2,395	\$3,410
			<u>\$55,355</u>	<u>\$80,855</u>

(7) Fuel Cell Net Salvage

SCE is not proposing to recover decommissioning costs for Fuel Cells at this time because of the expectation to transfer ownership to site hosts at the end of their 10-year life.

1 While SCE is not proposing decommissioning at this time, it is not unreasonable to expect that if  
2 circumstances change, there will be future costs to retire these plants.

3 (8) Energy Storage Net Salvage

4 SCE is proposing to install lithium-ion battery units in a rack  
5 configuration. Engineers indicate that the removal activities to retire these assets include driving to the  
6 facility, removing the battery modules the rack, and shipping to recycling centers for disposal. Engineers  
7 also indicate that there may be a small amount of gross salvage associated with the recycling of the  
8 units. Although it is not unreasonable to assume that there may be increasing costs to retire these assets  
9 in the future (*e.g.*, if recycling salvage becomes disposal fees) SCE is not proposing decommissioning  
10 costs for energy storage assets at this time.

11 **3. Forecast Service Lives for G&I Assets**

12 Some categories of plant do not lend themselves to statistical analysis, but do not belong  
13 in the life span category. These plant assets include most general plant (*i.e.*, FERC Accounts 391-397),  
14 intangible plant (*e.g.*, software, radio frequencies, etc.), and easements. SCE determined average service  
15 lives through conducting discussions with SCE engineers familiar with the assets, considering prior  
16 company procedure, and being familiar with industry practice.

17 Table III-24, below, shows the forecast depreciation service lives for general and  
18 intangible plant accounts. The table compares SCE's proposed depreciation rates to authorized service  
19 lives from D.15-11-021 (the 2015 GRC Decision). As discussed in the sections below, because Power  
20 Management Systems (Account 391.4) and Telecommunications Equipment (Account 397) consist of  
21 sub-accounts of fairly disparate service lives, the subaccounts have been categorized based upon the  
22 equipment lives. For example, in the case of Telecommunication Equipment, SCE grouped Telephone  
23 Systems with Videoconferencing Equipment in a 7-year category separate from the infrastructure  
24 equipment such as open wire communication conductor and antenna support structures that belong in a  
25 40-year category.

**Table III-24<sup>67</sup>**  
**General and Intangible Plant Service Life Proposals**

Account No.	Account Description	2015-2017 Authorized (Years)	2018-2020 Proposed (Years)
<u>General Plant</u>			
391.1	Office Furniture	20	20
391.2	Personal Computers	5	5
391.3	Mainframe Computers	5	5
391.4	DDSMS-Power Management System	7.8	10.2
391.5	Office Equipment	5	5
391.6	Duplicating Equipment	5	5
391.7	PC Software	5	5
393	Stores Equipment	20	20
394	Tools & Work Equipment	10	10
395	Laboratory Equipment	15	15
397	Telecommunication Equipment	10.3	8.6
398	Misc Power Plant Equipment	20	20
<u>Intangibles</u>			
302.020	Hydro Relicensing	Various	Various
303.640	Radio Frequency	40	40
302.050	Miscellaneous Intangibles	20	20
303.105	Capitalized Software - 5 year	5	5
303.707	Capitalized Software - 7 year	7	7
303.210	Capitalized Software - 10 year	10	10
303.315	Capitalized Software - 15 year	15	15
<u>Easements</u>			
350	Transmission Easements	60	60
360	Distribution Easements	60	60
389	General Easements	60	60

<sup>67</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 5-12 (Rate Determination Schedule).



#### 4. Forecast Service Lives – Account-By-Account

##### a) General Plant

Most general and intangible plant accounts contain many low value individual items. Following FERC guidelines, non-structural items in these accounts are amortized by vintage group over the specified service life and retired at the end of the life span.<sup>68</sup> For example, personal computers are amortized over a 5-year period (*i.e.*, a 20 percent annual depreciation rate) and when a vintage group reaches five years of age, the vintage group of computers will be fully depreciated and retired off the books. Following this approach eliminates costly plant record keeping and continuous physical tracking of the equipment. Over time, imbalances in the accumulated depreciation can occur if there are depreciation life or rate changes and if net salvage is recorded to the books but not reflected in the depreciation rate. These accumulated depreciation surpluses (deficits) are amortized over this GRC cycle (2018-2020).

##### (1) Account 391.1 – Office Furniture

Account 391.1 contains all costs incurred to acquire office furniture. It includes such items as modular furniture, desks, cabinets, and files used for general utility service that are not permanently attached to buildings. A 20-year average service life is reasonable for both modular and free standing furniture.

##### (2) Account 391.2 And 391.3 – Computer Equipment

The assets in Account 391.2 can include Central Processing Units and associated components (*e.g.*, monitors, printers, etc.) when purchased as a bundled unit, or when any of these items are purchased individually and meet the capitalization threshold. Account 391.3 is where SCE records all investment related to mainframe computer and file server equipment. SCE information technology personnel state that the average life for this equipment should be five years or less. Retention of the five-year life is reasonable.

##### (3) Account 391.4 – Power Management System

Account 391.4 contains Supervisory Control and Data Acquisition (SCADA) equipment for controlling and monitoring the SCE electrical system. Contained within this

---

<sup>68</sup> FERC Accounting Release Number AR15 provided for the vintage year accounting method allowing companies to amortize vintage groups of assets over their designated service life and subsequently retire them. The FERC accounting release states that “[a]doption- of vintage year accounting will relieve companies from maintaining extensive plant records and will generate efficiencies and costs savings without degrading the quality of plant records and the associated financial reporting.”

account are the components making up the Power Management System specifically, computer and data gathering equipment, man-machine interface, analog and digital telemetry devices, and data center facility infrastructure. The account consists of components with very different lives depending upon the technical sophistication and other retirement factors affecting the equipment. SCE's power management personnel have assessed this equipment as having service lives in categories of 5, 7, 10, 15 or 20 years. A dollar weighting of these equipment lives yields a combined average service life of about 10 years. Each of these equipment life categories are summarized in Table III-25 and addressed in the following discussions.

**Table III-25**  
***Power Management System Service Life Proposals***

CPR Account	Description	2015-2017 Authorized (Years)	2018-2020 Proposed (Years)
<b>Five-Year Power Management System Equipment</b>			
391.417	Firewall	7	5
391.422	TACACS/Sniffer	10	5
391.405	EMS Web Server	20	5
391.406	EMS Workstation	20	5
391.43	External Tape Drive	20	5
<b>Seven-Year Power Management System Equipment</b>			
391.401	Bulk Storage	7	7
391.416	USAT Hub	7	7
<b>Ten-Year Power Management System Equipment</b>			
391.402	Communications Network Processor	10	10
391.404	Server Cabinet	10	10
391.411	Large Screen Display System	10	10
391.419	Dynamic Map Board	25	10
391.42	Data Acquisition Controller	10	10
391.429	Digital Wall Chart Recorded	10	10
391.435	Dial-Up Remote Terminal Unit	10	10
<b>Fifteen-Year Power Management System Equipment</b>			
391.436	Uninterruptible Power Supply	15	15
391.438	Battery System	15	15
<b>Twenty-Year Power Management System Equipment</b>			
391.421	Remote Terminal Unit (RTU)	20	20

1 (a) Five-Year Power Management System Equipment

2 Equipment in the 5-year category is typically modern, digital  
3 electronic computer and microprocessor-based equipment which is subject to discontinued support by  
4 the manufacturer or replaced with newer equipment within a short period of time. Due to these changing  
5 needs, the hardware asset portfolio will become obsolete if not actively refreshed, which can  
6 significantly affect operations. Furthermore, these devices contain components like processors, memory,  
7 and rotating disks that become obsolete and/or worn out after five years of continuous use.

8 (b) Seven-Year Power Management System Equipment

9 Equipment in the 7-year category is typically modern, digital  
10 electronic computer and microprocessor-based equipment which is subject to discontinued support by  
11 the manufacturer or replaced with newer equipment within a short period of time. Furthermore, these  
12 devices contain rotating disk, printers and CRTs that become obsolete and/or worn out after seven years  
13 of continuous use.

14 (c) Ten-Year Power Management System Equipment

15 SCE's power management personnel indicate that the ten-year  
16 lived equipment is less sophisticated than the typical 7-year items. They contain digital electronics as  
17 well as some electromechanical devices. Most of this equipment is specialized, proprietary and generally  
18 supported by the vendor for 10 years. Past experience indicates this equipment will be replaced after  
19 about 10 years.

20 (d) Fifteen-Year Power Management System Equipment

21 Telemetry equipment is analog devices with mostly repairable  
22 parts. They do not contain a high degree of sophistication and with proper maintenance, these devices  
23 should last approximately 15 years. The Uninterruptible Power System is an electromechanical device  
24 with a rated life of about 15 years. Beyond 15 years both of these devices require high levels of  
25 maintenance due to passive component failures and electromechanical malfunction.

26 (e) Twenty-Year Power Management System Equipment

27 Twenty-year power management system equipment contains  
28 hardened substation field equipment used for data gathering. The equipment is highly fault-tolerant and  
29 is typically supported by the vendor for approximately 20 years. Also included here are Wall Strip Chart  
30 Recorders and Backup Control Systems. These are robust analog devices containing some passive  
31 electronics typically rated for 20 years of service.

1 (4) Account 391.5 and 391.6 – Office Equipment; Duplicating Equipment

2 These accounts represent a \$7.4 million net investment in miscellaneous  
3 office equipment such as video projection equipment, public address equipment, plotters, duplicating  
4 equipment, and so forth. The current service life of five years is reasonable.

5 (5) Account 393 – Stores Equipment

6 Account 393 represents a \$7.6 million net investment in equipment used  
7 for the receiving, shipping, handling, and storage of materials and supplies for warehouses. It includes  
8 electric pallet jacks, lifting tables, stretch wrapping machine, racking rotobins/storage bins, battery  
9 chargers, transformer trays, hand-held scanners, lockers, picking carts, awnings, barrel grabbers,  
10 warehouse heaters, screen netting, cable cutting machines, and so forth. Based on historical Stores  
11 Equipment usage and knowledge of warehouse equipment, the operational personnel state that this  
12 equipment has a useful service life of 20 years or less. Retaining the current 20-year service life is  
13 reasonable for this account.

14 (6) Account 394 – Tools & Work Equipment

15 Account 394 represents a \$49.2 million net investment in tools and  
16 equipment for construction, repair, maintenance, general shop, and garage, but not specifically  
17 includable in other accounts. SCE proposes retaining the current service life of 10 years.

18 (7) Account 395 – Laboratory Equipment

19 Account 395 represents a \$63.8 million net investment in laboratory and  
20 field test equipment. The account has a wide variety of equipment. It includes, for example, calibrators,  
21 baths, furnaces, current shunts, dew point meters, gauge calibrators, insulation testers, gas leak detectors,  
22 mass comparator, micrometers, multimeters, oscilloscopes, phase meters, watthour meter testing power  
23 source, power system analyzers, self-contained portable calibration carts, sound meters, metrology  
24 standards, thermometer, vibration analysis data pack, and volt meters. The expected average service life  
25 of lab and test equipment is impacted by two major retirement factors: technological obsolescence and  
26 normal “wear and tear” from usage in both the field and lab environments. SCE proposes to retain the  
27 currently authorized 15-year average service life for this account.

28 (8) Account 397 – Telecommunication Equipment

29 Account 397 represents SCE’s investment in communication equipment  
30 for the company’s system. Contained within this account are the electronic and computer-based  
31 equipment (such as transmission equipment, dynamic network multiplexers, data network

1 interconnection system, and radio equipment), as well as communication infrastructure (such as the  
2 copper and fiber optic cable, conduit, microwave equipment, and the electrical power generator system).  
3 SCE telecommunication engineers have assessed this equipment as having service lives of 5, 7, 10, 15,  
4 25, or 40 years depending on the type of equipment.<sup>69</sup> These are the same service lives the Commission  
5 authorized in the prior rate case. The equipment lives are addressed in the following discussions.

6 (a) Five-Year Communication Equipment

7 Equipment falling into the 5-year category experiences shorter  
8 lives from lack of vendor support, facility relocations, and insufficient capacity to meet current demand.

9 (b) Seven-Year Communication Equipment

10 Equipment in the 7-year category is typically modern, state-of-the  
11 art, electronic and/or computer-based equipment which is subject to being discontinued by manufacturer  
12 or replaced with newer equipment within a short period of years.

13 (c) Ten-Year Communication Equipment

14 NetComm radio equipment is not as sophisticated as the other  
15 electronic equipment and warrants a 10-year service life. SCE is replacing NetComm radios after about  
16 10 years.

17 (d) Fifteen-Year Communication Equipment

18 Equipment in this group of assets is typically subject to  
19 environmental wear and has an average life of about 15 years. The equipment fails or is replaced as a  
20 result of unreliability and/or high maintenance due to failure of passive components or  
21 electromechanical failure. In the case of electronic components included in this category, the  
22 telecommunication engineers state that these are relatively basic and not the state-of-the art- electronics  
23 reflected in the seven-year life category.

24 (e) Twenty-Five Year Communication Equipment

25 Although SCE has not yet had fiber optic cable as long as 25 years,  
26 SCE telecommunication engineers believe that it may be subject to greater level of degradation than the  
27 copper cable. They estimate that 25 years is a reasonable life for the fiber optic cable.

---

<sup>69</sup> Refer to WP SCE-09 Vol. 03, Book A, pp. 314-318 (Telecomm. Engineering Data).

1 (f) Forty-Year Communication Equipment

2 The balance of the communication infrastructure includes such  
3 equipment as overhead and underground communication cable, the communication conduit system, and  
4 antenna support structures. This equipment has an average 40-year service life. The items are subject to  
5 physical or mechanical deterioration since they are subject to outdoor environments.

6 (9) Account 398 – Miscellaneous

7 Account 398 represents a \$21.8 million net investment in miscellaneous  
8 utility equipment that does not fit other plant accounts. Examples can include such diverse items as  
9 kitchen and infirmary equipment. The current service life of 20 years is a reasonable depreciation period  
10 for this account.

11 b) Intangibles

12 SCE has investments in a number of intangible assets, including hydro  
13 relicensing, radio frequencies, long term franchise fees, capitalized software, and land easements and  
14 rights-of-way. As previously discussed, the hydro relicensing costs are amortized over the remaining life  
15 of the FERC project license period. SCE proposes to continue amortizing the radio frequency  
16 investments over the 40-year service life and land easements and rights-of-way over the 60 year service  
17 life determined in prior rate case proceedings. The other categories are discussed below.

18 (1) Miscellaneous Intangibles

19 The year-end 2015 net investment for miscellaneous intangibles is  
20 approximately \$431 thousand, which is largely made up of long-term franchise costs (~\$300 thousand).  
21 SCE proposes to allocate these costs over 20 years.

22 (2) Capitalized Software

23 The depreciable life of capitalized software reflects the estimated life prior  
24 to investments required to replace or optimize the software as a result of technology, vendor, or business  
25 obsolescence. SCE proposes to continue the four existing service life categories of five, seven, ten, and  
26 fifteen years determined in prior proceedings.

27 (3) Easements

28 SCE proposes to retain the authorized amortization period of 60 years for  
29 its easements and rights-of-way.

## **Appendix A**

### **2016 Service-Life and Net Salvage Study**

# 2016 Service-life and Net Salvage Study



SOUTHERN CALIFORNIA  
**EDISON**

An *EDISON INTERNATIONAL* Company

SCE is a registered trademark of Edison International. © 2016 Edison International. All rights reserved.





# CONTENTS

<b>EXECUTIVE SUMMARY</b>	<b>SECTION I</b>
INTRODUCTION .....	1
SCOPE OF STUDY .....	1
<b>STUDY PROCEDURE</b>	<b>SECTION II</b>
INTRODUCTION .....	2
SCOPE .....	2
DATA COLLECTION .....	3
LIFE ANALYSIS AND ESTIMATION .....	4
NET SALVAGE ANALYSIS .....	6
<b>RECOMMENDATIONS AND ANALYSIS</b>	<b>SECTION III</b>
RECOMMENDATIONS .....	9
ANALYSIS .....	9
<b>TRANSMISSION PLANT</b>	
ACCOUNT 352.00 – STRUCTURES AND IMPROVEMENTS .....	10
ACCOUNT 353.00 – STATION EQUIPMENT .....	12
ACCOUNT 354.00 – TOWERS AND FIXTURES .....	15
ACCOUNT 355.00 – POLES AND FIXTURES .....	17
ACCOUNT 356.00 – OVERHEAD CONDUCTORS AND DEVICES .....	19
ACCOUNT 357.00 – UNDERGROUND CONDUIT .....	21
ACCOUNT 358.00 – UNDERGROUND CONDUCTORS AND DEVICES .....	23
ACCOUNT 359.00 – ROADS AND TRAILS .....	25
<b>DISTRIBUTION PLANT</b>	
ACCOUNT 361.00 – STRUCTURES AND IMPROVEMENTS .....	26
ACCOUNT 362.00 – STATION EQUIPMENT .....	28
ACCOUNT 364.00 – POLES AND FIXTURES .....	30
ACCOUNT 365.00 – OVERHEAD CONDUCTORS AND DEVICES .....	32
ACCOUNT 366.00 – UNDERGROUND CONDUIT .....	35
ACCOUNT 367.00 – UNDERGROUND CONDUCTORS AND DEVICES .....	37
ACCOUNT 368.00 – LINE TRANSFORMERS .....	39
ACCOUNT 369.00 – SERVICES .....	41
ACCOUNT 370.00 – METERS .....	43
ACCOUNT 373.00 – STREET LIGHTING AND SIGNAL SYSTEMS .....	45
<b>GENERAL PLANT</b>	
ACCOUNT 390.00 – STRUCTURES AND IMPROVEMENTS .....	47

*August 2016*

# EXECUTIVE SUMMARY

## INTRODUCTION

This report presents a study and recommended service-life statistics and future net salvage rates for transmission, distribution and general depreciable plant owned and operated by Southern California Edison Company (SCE). Foster Associates was engaged by SCE in January 2016. The study was completed in July, 2016.

Foster Associates is a public utility economics consulting firm offering economic research and consulting services on issues and problems arising from governmental regulation of business. Areas of specialization supported by the firm's Fort Myers office include property life forecasting, technological forecasting, depreciation estimation, and valuation of industrial property.

Foster Associates has undertaken numerous depreciation engagements for both public and privately owned business entities including detailed statistical life studies, analyses of required net salvage rates, and the selection of depreciation systems that will most nearly achieve the goals of depreciation accounting under the constraints of either government regulation or competitive market pricing. Foster Associates is widely recognized for industry leadership in the development of depreciation systems, life analysis techniques and computer software for conducting depreciation and valuation studies.

Depreciation rates currently used by SCE were approved by the California Public Utilities Commission (CPUC) in D.15-11-021, dated November 5, 2015. The approved rates were derived from a study conducted on December 31, 2012 plant and depreciation reserve balances. Findings and recommendations developed in the current study are summarized in Section III of this report.

## SCOPE OF STUDY

The principal activities undertaken in the course of the current study included:

- Collection of plant and net salvage data;
- Reconciliation of data to the official records of the Company;
- Field visits and discussions with SCE operations and plant accounting personnel;
- Statistical life studies and estimation of projection lives and projection curves; and
- Per unit and moving average net salvage studies and estimation of future net salvage rates.

# STUDY PROCEDURE

## INTRODUCTION

The purpose of a comprehensive depreciation study for a regulated utility is to analyze the mortality characteristics, net salvage rates and the adequacy of depreciation accruals derived from currently approved depreciation rates. The findings from such an investigation are used in the formulation of revised depreciation rates subject to regulatory approvals.

In the case of the current study, Foster Associates was engaged by SCE to only study and recommend service-life statistics and future net salvage rates in compliance with CPUC directives in D.15-11-021. SCE would then incorporate the recommendations in depreciation rates developed by the Company.

Regarding the directives in D.15-11-021, the CPUC directed SCE to provide full explanations of the quantitative or qualitative base for the application of judgment in future depreciation showings. The Commission further directed the Company to provide:

1. A quantitative discussion of historical and future COR on a per unit basis for the large (greater than 15% as measured by the portion of plant balance) asset classes in the account. This should identify and explain the key factors in changing or maintaining the per-unit COR.
2. Quantitative discussion of historical and future retirement mix; identifying and explaining the key factors in changing or maintaining this mix.
3. Quantitative discussion of asset life and original cost of assets being retired, in relation to the COR, on both a historical and prospective basis. This discussion should be integrated with and/or cross-reference the proposal for life characteristics.
4. An account-specific discussion of the process for allocating costs to COR.

## SCOPE

The steps involved in conducting the depreciation study can be grouped into three major tasks:

- Data Collection;
- Life Analysis and Estimation; and
- Net Salvage Analysis and Estimation.

The scope of the 2016 service-life and net salvage study included a consideration of each of these tasks as described below.

## DATA COLLECTION

The minimum database required to conduct a statistical life study consists of a history of vintage year additions and unaged activity—year retirements, transfers and adjustments. These data must be appropriately adjusted for transfers, sales and other plant activity that would otherwise bias the measured service life of normal retirements. The age distribution of surviving plant for unaged data can be estimated by distributing plant in service at the beginning of the study year to prior vintages in proportion to the theoretical amount surviving from a projection or survivor curve identified in the life study. The statistical methods of life analysis used to examine unaged plant data are known as *semi-actuarial techniques*.

A far more extensive database is required to apply statistical methods of life analysis known as *actuarial techniques*. Plant data used in an actuarial life study most often include age distributions of surviving plant at the beginning of a study year and the vintage year, activity year, and dollar amounts associated with normal retirements, reimbursed retirements, sales, abnormal retirements, transfers, corrections, and extraordinary adjustments over a series of prior activity years. An actuarial database may include age distributions of surviving plant at the beginning of the earliest activity year, rather than at the beginning of the study year. Plant additions, however, must be included in a database containing an opening age distribution to derive aged survivors at the beginning of the study year. All activity year transactions with vintage year identification are coded and stored in a database. These data are processed by a computer program and transaction summary reports are created in a format reconcilable to official plant records. The availability of such detailed information is dependent upon an accounting system that supports aged property records. The Continuing Property Record (CPR) system used by SCE provides aged transactions for all plant accounts.

Service life statistics estimated in the 2016 study were derived from plant accounting transactions recorded over the period 2002 through 2015. Detailed accounting transactions were extracted from the Continuing Property Record (CPR) system and assigned transaction codes which describe the nature of the accounting activity. Transaction codes for plant additions, for example, were used to distinguish normal additions from acquisitions, purchases, reimbursements and adjustments. Similar transaction codes were used to distinguish normal retirements from sales, reimbursements, abnormal retirements and adjustments. Transaction codes were also assigned to transfers, capital leases, gross salvage, cost of removal and other accounting activity that should be considered in a depreciation study.

The accuracy and completeness of the assembled database was verified for activity years 2002 through 2015 by comparing the beginning plant balance, additions, retirements, transfers and adjustments, and the ending plant balance derived for each activity year to the official plant records of the Company. Age distributions of surviving plant at December 31, 2015 were reconciled to the CPR.

## LIFE ANALYSIS AND ESTIMATION

Life analysis and life estimation are terms used to describe a two-step procedure for estimating the mortality characteristics of a plant category. The first step (*i.e.*, life analysis) is largely mechanical and primarily concerned with history. Statistical techniques are used in this step to obtain a mathematical description of the forces of retirement acting upon a plant category and an estimate of the *projection life* of the account. The mathematical expressions used to describe these life characteristics are known as *survival functions* or *survivor curves*.

It is important to note what is being estimated in a service life study. It is not unit-years of service; it is dollar-years of service. Retirements are not recorded for plant accounting purposes in units such as feet, pounds, segments or any similar physical measurement. Plant records are maintained in dollars and service lives are measured in dollar-years of service. Estimating service lives based on engineering studies of how long, on average, units of property might remain in service is not equivalent to estimating dollar-years of service.

The size of a retirement unit also matters. A company that defines a span of conductor between supports to be a retirement unit will measure longer service lives than a company that defines one foot of conductor as a retirement unit. Replacement of conductor less than a retirement unit is charged to operating expense and no retirement is recorded for the replaced unit. Larger units result in less frequent recorded retirements, which translate to longer average dollar-years of service.

An added dimension of complexity is introduced when retirements occur at varying ages, attributable to mixed forces of retirement. This creates a non-homogeneous account composed of two subpopulations acted upon by differing forces of retirement. The estimated projection life for such an account measured in dollar-years of service will converge toward the mean of the subpopulation most resistant to the forces of retirement.

The second step (*i.e.*, life estimation) is concerned with predicting the expected remaining life of property units still exposed to forces of retirement. It is a process of blending the results of a life analysis with informed judgment (including expectations about the future) to obtain an appropriate projection life and curve descriptive of the parent population from which a plant account is viewed as a random sample. The amount of weight given to a life analysis will depend upon the extent to which past retirement experience is considered descriptive of the future.

The analytical methods used in a life analysis are broadly classified as actuarial and semi-actuarial techniques. Actuarial techniques can be applied to plant accounting records that reveal the age of a plant asset at the time of its retirement from service. Stated differently, each property unit must be identifiable by date of installation and age at retirement. Semi-actuarial techniques can be used to derive service life and dispersion estimates when age identification of retirements is not

maintained or readily available. Age identification of retirements over the period 2002–2015 was available for all plant accounts included in the 2016 study.

An actuarial life analysis program designed and developed by Foster Associates was used in this study. The first step in an actuarial analysis involves a systematic treatment of the available data for the purpose of constructing an observed life table. A complete life table contains the life history of a group of property units installed during the same accounting period and various probability relationships derived from the data. A life table is arranged by age-intervals (usually defined as one year) and shows the number of units (or dollars) entering and leaving each age-interval and probability relationships associated with this activity. A life table minimally shows the age of each survivor and the age of each retirement from a group of units installed in a given accounting year.

A life table can be constructed in any one of at least five methods. The annual-rate or retirement-rate method was used in this study. The mechanics of the annual-rate method require the calculation of a series of ratios obtained by dividing the number of units (or dollars) surviving at the beginning of an age interval into the number of units (or dollars) retired during the same interval. This so-called “retirement ratio” (or set of ratios) is an estimator of the hazard rate or conditional probability of retirement during an age interval. The cumulative proportion surviving is obtained by multiplying the retirement ratio for each age interval by the proportion of the original group surviving at the beginning of that age interval and subtracting this product from the proportion surviving at the beginning of the same interval. The annual-rate method is applied to multiple groups or vintages by combining the retirements and/or survivors of like ages for each vintage included in the analysis.

The second step in an actuarial analysis involves graduating or smoothing the observed life table and fitting the smoothed series to a family of survival functions. The functions used in this study are the Iowa-type curves which are mathematically described by the Pearson frequency curve family. Observed life tables were smoothed by a weighted least-squares procedure in which first, second and third degree orthogonal polynomials were fitted to the observed retirement ratios. The resulting function was expressed as a survivorship function and numerically integrated to obtain an estimate of the projection life for each plant account. The smoothed survivorship function was then fitted by a weighted least-squares procedure to the Iowa-curve family to obtain a mathematical description or classification of the dispersion characteristics of the data.

The set of computer programs used in this analysis provides multiple rolling-band, shrinking-band and progressive-band analyses of an account. Observation bands are defined in terms of a “retirement era” that restricts the analysis to the retirement activity of all vintages represented by survivors at the beginning of a selected era. In a rolling-band analysis, a year of retirement experience is added to



each successive retirement band and the earliest year from the preceding band is dropped. A shrinking-band analysis begins with the total retirement experience available and the earliest year from the preceding band is dropped for each successive band. A progressive-band analysis adds a year of retirement activity to a previous band without dropping earlier years from the analysis. Rolling, shrinking and progressive band analyses are used to detect the emergence of trends in the behavior of the dispersion and projection life.

Options available in the Foster Associates actuarial life analysis program include: the width and location of both placement and observation bands; the interval of years included in a selected band analysis; the estimator of the hazard rate (actuarial, conditional proportion retired, or maximum likelihood); the elements to include on the diagonal of a weight matrix (exposures, inverse of age, inverse of variance, or unweighted); and the age at which an observed life table is truncated. The program also provides tabular and graphics output as an aid in the analysis.

While actuarial and semi-actuarial statistical methods are well suited to an analysis of plant categories containing a large number of homogeneous units (*e.g.*, poles and conductors), the concept of retirement dispersion is interpreted differently for plant categories composed of major items of plant that will most likely be retired as a single unit. Plant retirements from an integrated system prior to the retirement of the entire facility are more properly viewed as interim retirements that will be replaced in order to maintain the integrity of the system. Additionally, plant facilities may be added to the existing system (*i.e.*, interim additions) in order to expand or enhance its productive capacity without extending the service life of the existing system. A proper depreciation rate can be developed for an integrated system using a life-span method. All depreciable plant accounts classified in transmission, distribution and general were studied as full mortality categories in the 2016 study.

## **NET SALVAGE ANALYSIS**

Depreciation rates designed to achieve the goals and objectives of depreciation accounting will include a parameter for future net salvage and a variable for average net salvage reflecting both realized and future net salvage rates.

Estimates of net salvage rates applicable to future retirements are most often derived from an analysis of gross salvage and cost of removal realized in the past. An analysis of past experience (including an examination of trends over time) provides a reasonable basis for estimating future salvage and cost of removal. However, consideration should also be given to events that may cause deviations from net salvage realized in the past. Among the factors that should be considered are: the age of plant retirements; the portion of retirements likely to be reused; changes in the method of removing plant; the type of plant to be retired in the future; inflation expectations; the shape of the projection life curve; and economic

conditions that may warrant greater or lesser weight to be given to net salvage rates observed in the past.

Average net salvage rates for an account or plant function are derived from a direct dollar weighting of a) historical retirements with historical (or realized) net salvage rates and b) future retirements (*i.e.*, surviving plant) with the estimated future net salvage rate. Average net salvage rates will change, therefore, as additional years of retirement and net salvage activity become available and as subsequent plant additions alter the weighting of future net salvage estimates.

Special consideration should also be given to the treatment of insurance proceeds and other forms of third-party reimbursements credited to the depreciation reserve. A properly conducted net salvage study will exclude such activity from the estimate of future parameters and include the activity in the computation of realized and average net salvage rates.

A five-year moving average analysis of the ratio of realized salvage and removal expense to the associated retirements was conducted in the 2016 study for transmission, distribution and general plant categories to aid in: a) estimating a realized net salvage rate; b) detecting the emergence of historical trends; and c) establishing a basis for estimating a future net salvage rate. Cost of removal and salvage opinions obtained from Company personnel were also considered in the estimation of future net salvage rates.

In compliance with the CPUC directive in D.15-11-021, per unit net salvage analyses were conducted for the nine (9) plant accounts listed in Table 1 below.

Account Description
354.00 Towers and Fixtures
355.00 Poles and Fixtures
356.00 Overhead Conductors and Devices
364.00 Poles, Towers and Fixtures
365.00 Overhead Conductors and Devices
366.00 Underground Conduit
367.00 Underground Conductors and Devices
368.00 Line Transformers
369.00 Services

**Table 1. Per Unit Net Salvage Accounts**

Each of the nine plant accounts was grouped into one or more subpopulations of major equipment categories. Historical per unit ratios (defined as net cost per unit to retire divided by the cost per unit to install) were used in both a historical and future per unit analyses. Net costs to retire (or net salvage) were used in the analysis to maintain consistency with future net salvage parameters used in the formulation of remaining-life accrual rates.

Future per unit ratios were derived using an average of the subpopulation net sal-



vage per unit values recorded over the period 2009–2015. These values appear in the numerator of future per unit ratios.

The per unit cost of plant additions used in forecasting future net salvage rates was obtained by dividing vintaged plant in service at December 31, 2015 (*i.e.*, age distributions of surviving plant) by vintaged units in service within each subpopulation. The ratio of average net salvage per unit experienced over the period 2009–2015 (adjusted for inflation) to the per unit cost of plant in service is the ratio that was applied to forecasted retirements to estimate future net salvage for each vintage. The sum of future net salvage over all vintages divided by current plant account balances produces an estimated future net salvage rate for each primary account.

# RECOMMENDATIONS AND ANALYSIS

## RECOMMENDATIONS

Table 2 below provides a summary of current and recommended projection lives, projection curves and future net salvage rates estimated for SCE in the 2016 study.

Account Description A	Current			Recommended		
	P-Life C	Dispersion D	Sf % E	P-Life F	Dispersion G	Sf % H
<b>Transmission Plant</b>						
352.00 Structures and Improvements	55.00	S3	-35.0	55.00	L1	-35.0
353.00 Station Equipment	45.00	R0.5	-15.0	40.00	L0.5	-10.0
354.00 Towers and Fixtures	65.00	R5	-60.0	65.00	R5	-185.0
355.00 Poles and Fixtures	50.00	R0.5	-72.0	65.00	SC	-499.0
356.00 Overhead Conductors and Devices	61.00	R3	-80.0	61.00	R3	-210.0
357.00 Underground Conduit	55.00	R3	0.0	55.00	R3	0.0
358.00 Underground Conductors and Devices	40.00	R2.5	-15.0	45.00	S1	-25.0
359.00 Roads and Trails	60.00	SQ	0.0	60.00	R5	0.0
<b>Distribution Plant</b>						
361.00 Structures and Improvements	42.00	R2.5	-25.0	50.00	L0.5	-30.0
362.00 Station Equipment	45.00	R1.5	-25.0	65.00	L0.5	-50.0
364.00 Poles, Towers and Fixtures	47.00	L0.5	-210.0	55.00	R1	-488.0
365.00 Overhead Conductors and Devices	45.00	R0.5	-115.0	55.00	R0.5	-538.0
366.00 Underground Conduit	59.00	R3	-30.0	59.00	R3	-401.0
367.00 Underground Conductors and Devices	45.00	R0.5	-60.0	43.00	R1.5	-261.0
368.00 Line Transformers	33.00	R1	-20.0	33.00	S1.5	-47.0
369.00 Services	45.00	R1.5	-100.0	45.00	R1.5	-387.0
370.00 Meters	20.00	R3	-5.0	20.00	R3	0.0
373.00 Street Lighting and Signal Systems	40.00	L0.5	-30.0	48.00	L1	-100.0
<b>General Plant</b>						
390.00 Structures and Improvements	38.00	R3	-5.0	45.00	R0.5	-10.0

**Table 2. Service Life and Net Salvage Parameters**

## ANALYSIS

A description of each account examined in the 2016 study and factors considered in the estimation of recommended service life and net salvage parameters is contained in the following pages of this report.

## TRANSMISSION PLANT

### ACCOUNT: 352.00 – STRUCTURES AND IMPROVEMENTS

#### DESCRIPTION

This account includes the cost in structures and improvements used in connection with transmission operations. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	55-S3	55-L1
Future NS Rate	-35.0%	-35.0%
Realized NS	-13.3%	
Average Age (yrs.)	8.6	
Derived Additions	\$717,577,812	
Plant Retirements	\$30,750,408	
Percent Retired	4.5%	
Plant Balance	\$686,827,404	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

Major forces of retirement for this account include system upgrades, severe storms and earthquakes, traffic and fire accidents, rodent damage, automation, revisions in policy, code, and criteria, and wear and tear related to aging.

The statistical service life indications for the full account are derived from unlikely recurring retirement activity. Retirements of \$22.9M reported in 2009, constituting 75 percent of the total retirements over the 14-year study period, were related to the retirement of equipment at the Sylmar substation. Average service life indications from the statistical service life analysis range from the low 30s to the mid-50s for bands with lower censoring and conformance indexes. The majority of second- and third-degree polynomial indications are considered less reliable than first-degree polynomial indications. Graduated hazard rates in these instances are unrealistically declining and may be zeroed to remove negative hazard rates implied by the fitted polynomials.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each subpopulation are shown in Table 2 below.

The variability of subpopulation service lives is an indication of a nonhomogeneous plant account with mixed forces of retirement acting on the subpopulations. Heterogeneity coupled with high degrees of censoring reduces the level of confidence that can be placed in service-life indications obtained from either a subpopulation or total account analysis.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Foundations	178,220,072	26	85-L1	38.5
MEER Building	159,486,338	23	130-R0.5	73.4
Water Supply	107,675,420	16	103-R3	82.8
Alarm & Monitoring	45,931,434	7	194-S6	99.4
Power Lighting	30,490,714	4	107-L0.5	71.9
HVAC	12,046,998	2	38-L0	7.7
Non-unitized	120,611,640	18		
Miscellaneous	32,364,788	5	30-L0.5	3.7
Total	686,827,404	100	107	

**Table 2. Major Structural Components**

### **LIFE ESTIMATION**

Based mainly on the first-degree statistical service-life indications, thereby rejecting origin-modal dispersions in which chance is a more pervasive force of retirement, a 55-L1 projection life-curve is recommended for this account. This recommendation retains the currently approved projection life and adjusts the projection curve to reflect lower modal curves observed in the subpopulation analysis. The recommendation also reflects a lack of evidence for adjusting the service life estimates given the single retirement underlying a significant percentage of the retirement history. Foster Associates was informed that Company engineers and operations personnel do not anticipate policy or procedural changes or technological advances that would introduce significantly different forces of retirement from those observed in the past.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account exhibits an overall realized net salvage rate of -13.3 percent from \$31M of retirement activity over the period 2002-2015. More recent 5-year moving average bands indicate realized negative net salvage exceeding -87 percent.

### **NET SALVAGE ESTIMATION**

Based on this historical experience and the expectation of continuing removal costs when these facilities are retired, retention of a -35 percent future net salvage rate is recommended for consideration by SCE. As in the service life estimation, this recommendation reflects lack of evidence for adjusting future net salvage estimates given the single retirement underlying a significant percentage of the retirement history in this account.

## TRANSMISSION PLANT

### ACCOUNT: 353.00 – STATION EQUIPMENT

#### DESCRIPTION

This account includes the cost in transforming, conversion, and switching equipment used for the purpose of changing the characteristics of electricity in connection with its transmission or for controlling transmission circuits. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	45-R0.5	40-L0.5
Future NS Rate	-15.0%	-10.0%
Realized NS	0.6%	
Average Age (yrs.)	10.3	
Derived Additions	\$5,785,827,668	
Plant Retirements	\$538,115,861	
Percent Retired	10.3%	
Plant Balance	\$5,247,711,807	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

Retirement activity in transmission station equipment is largely associated with age, obsolescence and growing or shifting loads that necessitate rebuilding to larger capacities. Company engineers report that thermal, mechanical, and electrical integrity issues intensify with age typically beginning around age 30 years when insulation degradation, increased in-service failures, and increased maintenance arises. Retirements occur when increased costs and decreased utilization rates dictate it is no longer economic to repair such equipment. Decreased spare parts availability as equipment ages also plays a major role in age-related retirements.

The Company utilizes a Condition Based Maintenance (CBM) approach to manage all transformers and circuit breakers by routinely conducting off-line diagnostics, visual inspections, and functional checks. These analysis components are combined with other key data such as age, design, moisture levels, loading, and fault exposure to develop a health index ranking that is maintained throughout the life of these assets and used in the determination of when to repair or retire.

Average service life indications from the statistical analysis of the full account range from the low 30s to the low-40s for bands with lower censoring and conformance indexes. The majority of second- and third-degree polynomial indications are considered less reliable than first-degree polynomial indications. Graduated hazard rates in these instances are unrealistically declining and may be zeroed to remove negative hazard rates implied by the fitted polynomials.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Transformers	1,068,594,714	20	41-SC	7.6
Circuit Breakers	631,804,488	12	32-L1.5	0.8
Switches & Switch Gear	520,013,661	10	34-L0	10.4
Control & Monitoring Devices	478,204,337	9	50-L0	-
Bus Support Structures	439,776,382	8	63-R0.5	27.5
Capacitors	309,258,912	6	49-L1	0.6
Power Control Cable	267,340,154	5	51-SC	30.6
Foundations	151,926,940	3	70-L1	34.5
Non-unitized	790,758,849	15		
Miscellaneous	590,033,371	11	36-L0.5	11.2
Total	5,247,711,807	100	44	

**Table 2. Major Structural Components**

The subpopulation analysis of the full historical experience exhibits a range of average service lives between 32 and 63 years with a direct-dollar-weighted average of 44 years and a preponderance of lower-left modal dispersions. Service-life indications derived from a statistical analysis of the combined subpopulations are well within a zone of reasonableness when compared to the subpopulation indications. The analysis of these subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category.

### **LIFE ESTIMATION**

Based on indications from both the full account and subpopulation statistical service life analyses, a 40-L0 projection life-curve is recommended for this account. This recommendation is derived from account total service lives indicated for trials with lower censoring, conformance indexes, and hazard functions uncompromised by declining or negative hazard rates. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of -12.7 percent, a composite of an 8.2 percent gross salvage rate and a 20.9 percent cost of retiring rate. The most recent 5-year rolling average indicates a -26.4 percent realized net salvage rate.

### **NET SALVAGE ESTIMATION**

Minimal gross salvage, generally from scrap metal and recycling, is expected from the retirement of this equipment. Significant cost of retiring, however, is expected in the form of labor and equipment such as cranes. The adjusted historical net salvage experience provides the basis for recommending a –10 percent future net salvage rate for consideration by SCE. This recommendation reflects discounting indications obtained from small retirements and large cost of removal recorded in 2015 and focusing more on activity years 2009–2014. The –12.7 realized net salvage rate and –26.4 percent realized net salvage rate observed for the most recent 5–year rolling band are somewhat distorted by the 2015 activity, which is not considered indicative of future expectations.

## TRANSMISSION PLANT

### ACCOUNT: 354.00 – TOWERS AND FIXTURES

#### DESCRIPTION

This account includes the cost installed of towers and appurtenant fixtures used for supporting overhead transmission conductors. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	65-R5	65-R5
Future NS Rate	-60.0%	-185.0%
Realized NS	-799.7%	
Average Age (yrs.)	9.3	
Derived Additions	\$2,264,446,057	
Plant Retirements	\$4,473,231	
Percent Retired	0.2%	
Plant Balance	\$2,259,972,826	

Table 1. Account Parameters and Statistics

#### LIFE ANALYSIS

Forces of retirement acting upon transmission towers and fixtures include line upgrades, corrosion, relocation (for lower voltage structures), and failures due to wind storms, ice, or floods. Most of these forces tend to increase with age. Although storm damage can generally be expected to impact retirements at any age, in combination with deterioration, the probability of failure is cumulative. SCE performs annual inspections on all transmission towers and performs subsequent maintenance identified from those inspections.

The statistical service life indications for the full account are derived from minimal and irregular retirement activity. Retirements recorded in this account amount to only \$4.5M from an average plant balance exceeding \$1.3B over the study period and less than 0.2 percent of derived additions. Statistical service life indications derived from this minimal experience are highly censored, unrealistically long (approaching 200 years), and contrary to Company expectations of the future age of tower retirements.

The distribution of major categories of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Towers	1,139,621,027	50	132-S2	71.6
Non-unitized	1,018,898,065	45		
Other	101,453,734	4	178-R2.5	82.2
Total	2,259,972,826	100	136	

Table 2. Major Structural Components



The subpopulation analysis is also highly censored and does not produce interpretative life indications. The account could not be reasonably sub-divided into more than three subpopulations with miscellaneous items constituting only four percent and non-unitized items constituting 45 percent of the investment.

### **LIFE ESTIMATION**

The minimal retirement activity and resulting unreliable service life indications from both the full account and subpopulation statistical analyses do not provide a strong foundation for service-life estimation. Foster Associates, therefore, deferred to SCE in recommending the currently approved 65–R5 projection life-curve. Factors evaluated by SCE beyond the service-life analyses include operational, accounting and ratemaking considerations.

### **NET SALVAGE ANALYSIS**

The adjusted net salvage analysis for this account indicates an overall net salvage rate of –799.7 percent realized from \$4.5M of retirements recorded over the period 2002–2015. However, as noted above, total retirements are less than 0.2% of derived additions.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –104 and –185 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Although minimal gross salvage, generally from scrap, is expected from these assets, significant costs of retiring and removing (attributable to labor costs and cost of equipment such as cranes used in the retirement process) are expected to be incurred in the future. Based on the above analysis, a future net salvage rate of –185 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

## TRANSMISSION PLANT

### ACCOUNT: 355.00 – POLES AND FIXTURES

#### DESCRIPTION

This account includes the installed cost of transmission line poles, wood, steel, concrete, or other material, together with appurtenant fixtures used for supporting overhead transmission conductors. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	50-R0.5	65-SC
Future NS Rate	-72.0%	-499.0%
Realized NS	-155.5%	
Average Age (yrs.)	10.1	
Derived Additions	\$1,073,636,145	
Plant Retirements	\$65,068,786	
Percent Retired	6.5%	
Plant Balance	\$1,008,567,359	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

The majority of wood poles in the Company's system are full-length and "through-boring" treated to protect against decay and insect attack. Wood poles may also be treated with a steel stub or a fiberglass wrap to provide additional support. In addition to pole treatment, the Company conducts a 10-year inspection cycle to address safety and reliability. Tree trimming and vegetation management are also a significant component of reliability measures undertaken by the Company.

Major forces of retirement acting upon transmission wood poles include external, internal, top rot, and split top deterioration. Additional forces include vehicles, wind, storm, fire, and bird (mainly woodpecker) damage. Response to these forces partly depends on the specific locale of the pole given the Company's wide geographical area encompassing mainly desert but also agricultural, rural, and urban communities.

Indications from the statistical service life analysis for this account range from the mid-60s to the low-80s for bands with lower censoring and conformance indexes. The majority of third-degree polynomial indications are considered less reliable than first-degree or second-degree polynomial indications. Graduated hazard rates in these instances are unrealistically declining and may be zeroed to remove negative hazard rates implied by the fitted polynomials.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a

full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Eng. Light Duty Steel, Concrete	419,049,403	42	84-L0.5	57.2
Wood/Fiberglass/Composite	375,781,560	37	57-SC	29.6
Non-Unitized	212,474,639	21		
Other	1,261,756	0	46-S4	53.5
Total	1,008,567,359	100	71	

**Table 2. Major Structural Components**

The subpopulation analysis indicates service lives ranging between 46 and 84 years with an average of 71 years. It is the opinion of Foster Associates that service-life indications derived from a statistical analysis of the combined subpopulations are well within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, non-homogeneous plant category.

### **LIFE ESTIMATION**

Based on the first-degree and second-degree indications of the full account analysis and observations from the subpopulation analysis, a 65-SC projection life-curve is recommended for this account. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall realized net salvage rate of -155.5 percent and a -242.5 percent rate for the most recent five-year rolling band. Five-year rolling bands indicate negative net salvage rates exceeding -100 percent for 8 of the 11 analyzed bands.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between -90 and -499 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of -499 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

## TRANSMISSION PLANT

### ACCOUNT: 356.00 – OVERHEAD CONDUCTORS AND DEVICES

#### DESCRIPTION

This account includes the installed cost of overhead conductors and devices used for transmission purposes. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	61-R3	61-R3
Future NS Rate	-80.0%	-210.0%
Realized NS	-284.3%	
Average Age (yrs.)	13.7	
Derived Additions	\$1,500,210,639	
Plant Retirements	\$18,103,015	
Percent Retired	1.2%	
Plant Balance	\$1,482,107,624	

Table 1. Account Parameters and Statistics

#### LIFE ANALYSIS

Forces of retirement acting upon transmission conductors include deterioration resulting from atmospheric corrosion, fatigue failure due to conductor vibration, storm damage, failure of splices or dead-ends, relocation (*e.g.*, highway widening, damsite construction, etc.), circuit upgrades, system reconfiguration and idle facilities (*e.g.*, closure of generation facilities or loss of large customers).

The statistical service life analysis for this account indicates average service lives exceeding 85 years. The analysis, however, is based on \$18M of retirement activity from derived additions exceeding \$1.5B. Retirement activity of 1.2 percent of derived additions is not considered sufficient to provide a reliable basis for service life estimation.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 is shown in Table 2. More than 40 percent of the classified investment is conductor larger than 1500 MCM. Service life indications obtained from a full-band statistical analysis of the major categories are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Conductor > 220 kV	739,015,019	50	106-R3	57.7
Conductor < 220 kV	202,769,129	14	82-R1.5	84.0
Switches	27,761,688	2	39-R1	2.5
Non-Unitized	399,410,246	27		
Other	113,151,541	8	199-SQ	100.0
Total	1,482,107,623	100	110	

Table 2. Major Structural Components

The subpopulation analysis of the full historical experience evidences a range of average service lives between 39 and 199 years with a dollar-weighted average of 110 years. These indications are compromised by high censoring and minimal retirement activity comparable to observations in the full account.

### **LIFE ESTIMATION**

With consideration given to the minimal retirement experience in this account and the resulting extremes in service life indications, Foster Associates deferred to the Company in recommending retention of the currently approved 61–R3 projection service–life parameters.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –284.3 percent. However, as noted above, this history is based on relatively minimal retirement activity over the period 2002–2015.

The per–unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –114 and –210 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –210 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

.

## TRANSMISSION PLANT

### ACCOUNT: 357.00 – UNDERGROUND CONDUIT

#### DESCRIPTION

This account includes the installed cost of underground conduit and tunnels used for housing transmission cables or wires. Account statistics and current and proposed parameters are shown in Table 1.

	Current	Proposed
Plife-Curve	55-R3	55-R3
Future NS Rate	0.0%	0.0%
Realized NS	-69.5%	
Average Age (yrs.)	15.6	
Derived Additions	\$61,474,359	
Plant Retirements	\$387,297	
Percent Retired	0.6%	
Plant Balance	\$61,087,062	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

Rebuild and digging are the major forces of retirement expected to affect this account. The statistical service-life analysis for the full account is based on highly censored trials (87 percent) with life indications ranging between 88 and 146 years. Only \$387,297 or 0.6% of derived additions has been retired from the account.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Conduit	34,334,761	56	130-S1.5	86.3
Manholes and Vaults	17,239,213	28	65-S2	81.1
Trenches	2,063,079	3		N/A
Non-unitized	7,410,219	12		
Other	39,791	0		N/A
Total	61,087,062	100	108	

**Table 2. Major Structural Components**

full-band statistical analysis of each category are shown in Table 2 below.

Subpopulation service life indications are similarly derived from highly censored trials providing little insight into future live expectancies.

**LIFE ESTIMATION**

Neither the full account nor the subpopulation analysis is considered to provide sufficient evidence to support adjusting the currently approved 55–R3 projection life and curve. Current parameters are, therefore, recommended to be retained for this account.

**NET SALVAGE ANALYSIS**

The adjusted net salvage analysis for this account indicates an overall net salvage rate of –69.5% percent realized from minimal retirement activity of only \$387,297.

**NET SALVAGE ESTIMATION**

The historical net salvage experience is considered insufficient to support an adjustment to the currently approved zero percent future net salvage rate. The current rate is, therefore, recommended for consideration by SCE.

## TRANSMISSION PLANT

### ACCOUNT: 358.00 – UNDERGROUND CONDUCTORS AND DEVICES

#### DESCRIPTION

This account includes the installed cost of underground conductors and devices used for transmission purposes. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	40-R2.5	45-S1
Future NS Rate	-15.0%	-25.0%
Realized NS	-27.0%	
Average Age (yrs.)	11.6	
Derived Additions	\$284,995,149	
Plant Retirements	\$16,382,826	
Percent Retired	6.1%	
Plant Balance	\$268,612,323	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

Deterioration, failure, relocations, upgrades and accidental dig-ins are the major forces of retirement acting upon underground conductors. The statistical life analysis conducted for this account indicates average service lives between the mid-30s and mid-40s for trials with lower censoring, conformance indexes, and non-negative retirement ratios.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Conductor	163,955,728	61	45-S1.5	51.1
Potheads	27,568,689	10	29-S2	5.2
Arresters	19,845,390	7	31-S1.5	2.0
Cathodic Protection	12,086,839	4	39-R1	81.4
Non-unitized	45,155,677	17		
Total	268,612,323	100	41	

**Table 2. Major Structural Components**

An analysis of the subpopulations indicates a range of service lives between 29 and 45 years with lower modal dispersions and an average of 41 years. Service-life indications derived from a statistical analysis of the combined subpopulations are well within a zone of reasonableness when compared to the subpopulation in-



dications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category.

### **LIFE ESTIMATION**

Based on these observations and considerations, a 45–S1 projection life–curve is recommended for this account. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –27 percent realized from \$16M of retirement activity over the period 2002–2015. Five–year rolling bands are relatively stable and range between –14.4 and –49.7 percent. The most recent 5–year rolling band indicates a realized average net salvage rate of –30.6 percent.

### **NET SALVAGE ESTIMATION**

Based on the analysis observations, a –25 percent future net salvage rate is recommended for consideration by SCE. Consideration was given in this recommendation to both the –27 historical average realized net salvage rate and the likelihood of more negative future net salvage given recent experience such as the –30.6 percent realized net salvage rate observed for the most recent 5–year rolling band.

## **TRANSMISSION PLANT**

### **ACCOUNT: 359.00 – ROADS AND TRAILS**

#### **DESCRIPTION**

This account includes the cost of roads, trails, and bridges used primarily as transmission facilities. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	60-SQ	60-R5
Future NS Rate	0.0%	0.0%
Realized NS	-314.1%	
Average Age (yrs.)	5.1	
Derived Additions	\$194,172,555	
Plant Retirements	\$154,514	
Percent Retired	0.1%	
Plant Balance	\$194,018,041	

**Table 1. Account Parameters and Statistics**

#### **LIFE ANALYSIS**

The statistical service life analysis for this account is based on minimal retirement activity of \$154,514, or 0.1 percent of derived additions from an average plant balance exceeding \$108M over the period 2002–2015. Retirements were reported in only 3 years during that period. The service life analysis is highly censored at more than 76.8 percent with resulting life indications ranging between 95 and 175 years.

#### **LIFE ESTIMATION**

Statistical service life indications for this account are considered insufficient to warrant an adjustment to the currently approved projection life. The current SQ projection curve, however, is considered extreme given the historical experience and the likelihood of more dispersed retirements. Based on these observations and considerations, a 60–R5 projection life–curve is recommended for this account.

#### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates a realized net salvage rate of –314.1 percent from retirements recorded in 2010, 2012, and 2013 only.

#### **NET SALVAGE ESTIMATION**

The underlying retirement experience in the historical net salvage analysis is not considered sufficient to warrant adjusting the currently approved zero percent future net salvage. Retention of the current rate is, therefore, recommended for consideration by SCE.

## DISTRIBUTION PLANT

### ACCOUNT: 361.00 – STRUCTURES AND IMPROVEMENTS

#### DESCRIPTION

This account includes the cost in place of structures and improvements used in connection with distribution operations. The account comprises mainly control houses and related structures at distributions substations. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	42-R2.5	50-L0.5
Future NS Rate	-25.0%	-30.0%
Realized NS	-33.1%	
Average Age (yrs.)	13.8	
Derived Additions	\$632,396,471	
Plant Retirements	\$55,690,492	
Percent Retired	9.7%	
Plant Balance	\$576,705,979	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

Major forces of retirement for this account include system upgrades, severe storms and earthquakes, traffic and fire accidents, rodent damage, automation, revisions in policy, code, and criteria, and wear and tear related to aging.

Statistical service life indications for this account range from the low-40s to low-60s for bands with lower censoring and conformance indexes. The majority of second and third-degree polynomial indications are considered less reliable than first-degree polynomial indications. Graduated hazard rates in these instances are unrealistically declining and may be zeroed to remove negative hazard rates implied by the fitted polynomials.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Foundation etc.	112,919,451	20	28-S4	76.6
MEER Building	102,746,634	18	38-S1.5	80.8
Water Supply	50,908,790	9	41-S1.5	74.6
Power Lighting	45,421,111	8	39-S3	92.0
HVAC	33,804,236	6	35-R2	72.5
Alarm & Monitoring	16,557,229	3	29-S3	84.1
Non-unitized	39,863,694	7		
Other	174,484,836	30	60-O3	29.4
Total	576,705,980	100	43	

**Table 2. Major Structural Components**

An analysis of the subpopulations indicates average service lives ranging between 29 and 60 years, various dispersions, and a dollar-weighted mean of 43 years.

### **LIFE ESTIMATION**

Based on these observations and ignoring origin-modal dispersions in which chance is a more pervasive force of retirement, a 50-L0.5 projection life-curve is recommended for this account.

Service-life indications derived from a statistical analysis of the combined subpopulations are well within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category. Company operations personnel do not expect policy or procedural changes or technological advances that would introduce significantly different forces of retirement from those observed in the past.

### **NET SALVAGE ANALYSIS**

The historical net salvage analysis for this account indicates an adjusted overall net salvage rate of -33.1 percent realized from \$55,690,492 of retirement activity over the period 2002-2015. Five-year rolling band rates have not been less negative than -21.3 percent during that period and the five-year band ending in 2015 shows a -44.2 percent net salvage rate.

### **NET SALVAGE ESTIMATION**

Based on these observations and considerations, a -30 percent future net salvage rate is recommended for consideration by SCE. It is considered unlikely that the upward trend in cost of removal will reverse in the near future.

## DISTRIBUTION PLANT

### ACCOUNT: 362.00 – STATION EQUIPMENT

#### DESCRIPTION

This account includes the installed cost of station equipment, including transformer banks, used for the purpose of changing the characteristics of electricity in connection with its distribution. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	45-R1.5	65-L0.5
Future NS Rate	-25.0%	-50.0%
Realized NS	-46.5%	
Average Age (yrs.)	13.1	
Derived Additions	\$2,382,404,227	
Plant Retirements	\$138,133,698	
Percent Retired	6.2%	
Plant Balance	\$2,244,270,529	

**Table 1. Account Parameters and Statistics**

#### LIFE ANALYSIS

The statistical service life analysis for this account indicates average service lives within a narrow range between the mid-50s and mid-60s for bands with lower censoring and conformance indexes.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Transformers	359,814,116	16	56-L1	81.9
Monitoring Devices	275,879,081	12	34-R2	61.6
Circuit Breakers	270,107,330	12	45-S0.5	81.3
Bus Support	182,345,026	8	75-L0.5	90.1
Power Control Cable	115,539,624	5	42-L1	75.7
Switches	95,098,077	4	52-L1	81.7
Non-unitized	394,553,141	18		
Other	550,934,134	25	64-L0.5	19.7
Total	2,244,270,528	100	54	

**Table 2. Major Structural Components**

An analysis of the subpopulations indicates average service lives between 34 and 75 years with lower modal dispersions and a dollar-weighted mean of 54 years.

Service-life indications derived from a statistical analysis of the combined subpopulations are well within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category.

### **LIFE ESTIMATION**

Based on these observations and considerations, a 65–L0.5 projection life–curve is recommended for this account. This recommendation is within the range of both full account and subpopulation service life indications. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

Although not equivalent to dollar–years of service, SCE engineers estimate a mean time to wear–out of about 37 years for A–Bank (200 kV) transformers and about 57 years for B–Bank (115 or 66 kV) transformers. The number of transformers in service at year–end 2015 was 158 A–Bank and 2,226 B–Bank. Company engineers also estimate that the mean time to wear–out of mainline and radial oil switches is about 35 years and about 49 years for circuit breakers. The average age of transformers measured in unit–years is about 26 years whereas the average age measured in dollar–years is about 10 years. Similarly, the average age of circuit breakers measured in unit–years is about 32 years whereas the average age measured in dollar–years is about 10 years.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –46.5 percent, realized from \$138,133,698 of retirement activity and 5.8 percent of derived addition over the period 2002–2015. Most recent 5–year rolling bands ending in 2013, 2014, and 2015 exhibit net salvage rates of –47.2, –65.6 and –81.4 percent respectively.

### **NET SALVAGE ESTIMATION**

Based on these observations and the expectation of continuing negative net salvage, a –50 percent future net salvage rate is recommended for consideration by SCE.

## **DISTRIBUTION PLANT**

### **ACCOUNT: 364.00 – POLES, TOWERS AND FIXTURES**

#### **DESCRIPTION**

This account includes the installed cost of poles, towers, and related fixtures used for supporting overhead distribution conductors and service wires. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	47-L0.5	55-R1
Future NS Rate	-210.0%	-488.0%
Realized NS	-505.0%	
Average Age (yrs.)	11.3	
Derived Additions	\$2,608,099,972	
Plant Retirements	\$144,713,616	
Percent Retired	5.9%	
Plant Balance	\$2,463,386,356	

**Table 1. Account Parameters and Statistics**

#### **LIFE ANALYSIS**

The majority of wood poles in the Company's system are full-length and "through-boring" treated to protect against decay and insect attack. Wood poles may also be treated with a steel stub or a fiberglass wrap to provide additional support. In addition to pole treatment, the Company conducts a 10-year inspection cycle to address safety and reliability. Tree trimming and vegetation management are also a significant component of reliability measures undertaken by the Company.

As with transmission wood poles, major forces of retirement acting upon distribution wood poles include external, internal, top rot, split top deterioration and pole loading. Additional forces include vehicles, wind, storm, fire, and bird (mainly woodpecker) damage. Response to these forces partly depends on the specific locale of the pole given the Company's wide geographical area encompassing mainly desert but also agricultural, rural, and urban communities.

The statistical service life analysis for this account indicates consistent indications with average service lives around the mid-50s for bands with lower censoring and conformance indexes.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

An analysis of the single subpopulation of poles indicates a 53-R1 projection life-curve at 46 percent censoring. This indication is comparable to indications obtained for the full band statistical service life analysis.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Poles	2,191,572,261	89	53-R1	46.0
Non-unitized	271,814,095	11		
Total	2,463,386,356	100	53	

**Table 2. Major Structural Components**

### **LIFE ESTIMATION**

Based on these indications of a slightly longer projection life than currently approved, a 55–R1 projection life–curve is recommended for this account.

### **NET SALVAGE**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –505.0 percent, realized from \$144.7M of retirement activity constituting 5.5 percent of derived addition over the period 2002–2015. More recent 5–year rolling bands ending in 2013, 2014, and 2015 exhibit negative net salvage rates exceeding –600 percent.

The per–unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –180 and –488 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and three percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –488 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.



## **DISTRIBUTION PLANT**

### **ACCOUNT: 365.00 – OVERHEAD CONDUCTORS AND DEVICES**

#### **DESCRIPTION**

This account includes the cost installed of overhead conductors and devices used for distribution purposes. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	45-R0.5	55-R0.5
Future NS Rate	-115.0%	-538.0%
Realized NS	-206.4%	
Average Age (yrs.)	16.7	
Derived Additions	\$1,571,387,374	
Plant Retirements	\$138,400,064	
Percent Retired	9.7%	
Plant Balance	\$1,432,987,310	

**Table 1. Account Parameters and Statistics**

#### **LIFE ANALYSIS**

Rebuild programs and relocation to address changes in capacity and rights of way, deterioration resulting from atmospheric corrosion, fatigue failure due to conductor vibration, storm damage, and splice failure are the major forces of retirement acting upon this plant category. Lightning strikes also nick the conductor, reducing its capacity and eventually causing burn-down. Although repair at the damaged point is possible with splicing and reconnecting, it is costly. It is common, therefore, to remove and replace a longer section of the damaged conductor, which is usually the span between supports. Overhead to underground facilities conversion, such as that governed by CPUC Rule 20, continues to be a force of retirement acting upon this account.

The statistical service life analysis for this account is based on moderately censored trials with censoring exceeding 47 percent. A number of first and second-degree polynomials indications derived from graduated hazard rates that are unrealistically declining or zeroed were rejected. Origin-modal dispersions in which chance is a more pervasive force of retirement were also rejected. More consistent indications for bands with lower censoring and conformance indexes indicated average service lives between 36 and 65 years and lower modal dispersions.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below. Equipment classified in the "Other" category includes primarily circuit breakers and fuse holders.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Overhead Conductor	946,696,334	66	70-R0.5	65.3
Switches	347,104,388	24	42-S0	26.7
Non-unitized	52,173,406	4		
Other	87,013,183	6	24-O3	3.8
Total	1,432,987,311	100	60	

**Table 2. Major Structural Components**

An analysis of the subpopulations indicates service lives between 24 and 70 years with lower modal dispersions and a dollar-weighted average of 60 years. Service-life indications derived from a statistical analysis of the combined subpopulations are considered to be within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, non-homogeneous plant category.

### **LIFE ESTIMATION**

Based on these observations and considerations, a 55–R0.5 projection life-curve is recommended for this account based upon the more consistent indications for bands with lower censoring and conformance indexes in both the full account and subpopulation statistical service-life analysis.

Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category. Although not equivalent to dollar-years of service, SCE engineers estimate the mean time to wear-out of an overhead capacitor bank is about 30 years. Approximately 11,388 capacitor banks were installed in the overhead system at year-end 2015.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –206.4 percent realized from \$138,400,064 of retirement activity constituting 8.8 percent of derived addition over the period 2002–2015. More recent 5-year rolling bands ending in 2013, 2014, and 2015 show negative net salvage rates exceeding –300 percent.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –195 and –538 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and three percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –538 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

## DISTRIBUTION PLANT

### ACCOUNT: 366.00 – UNDERGROUND CONDUIT

#### DESCRIPTION

This account includes the installed cost of underground conduit and tunnels used for housing distribution cables or wires. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	59-R3	59-R3
Future NS Rate	-30.0%	-401.0%
Realized NS	-183.1%	
Average Age (yrs.)	14.2	
Derived Additions	\$1,848,035,134	
Plant Retirements	\$36,174,527	
Percent Retired	2.0%	
Plant Balance	\$1,811,860,607	

Table 1. Account Parameters and Statistics

#### LIFE ANALYSIS

Conduit failures are generally the result of mechanical damage caused by excavating or drilling crews inadvertently digging into or drilling through the duct. The statistical service life analysis for this account is based on highly censored trials with indicated average service lives exceeding 70 years. Additionally, only minimal retirement activity of \$36M from derived additions exceeding \$1.8B has been reported. Constituting 2.0 percent of derived additions, this retirement activity is considered insufficient to provide a reliable basis for service life estimation.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Conduit	789,932,796	44	93-S3	93.0
Pull and Slab Boxes	447,741,061	25	50-S2	50.5
Vaults	324,651,530	18	79-S2	80.6
Excavation Trenches	16,836,983	1	184-R4	100.0
Non-unitized	75,629,378	4		
Other	157,068,859	9	49-L1	45.0
Total	1,811,860,607	100	76	

Table 2. Major Structural Components

Equipment classified in the "Other" category includes primarily risers, manholes, and blower assemblies.

As noted with the full account analysis, high censoring of the subpopulations also produces indeterminate service life indications.

### **LIFE ESTIMATION**

With consideration given to the minimal retirement experience in this account and the resulting unreliable service-life indications, Foster Associates deferred to the Company in recommending retention of the currently approved 59-R3 projection service-life parameters.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of -183.1 percent. As noted above, however, this history provides minimal retirement activity over the period 2002-2015.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between -108 and -401 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions..

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of -401 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

## **DISTRIBUTION PLANT**

### **ACCOUNT: 367.00 – UNDERGROUND CONDUCTORS AND DEVICES**

#### **DESCRIPTION**

This account includes the installed cost of underground conductors and devices used for distribution purposes. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	45-R0.5	43-R1.5
Future NS Rate	-60.0%	-261.0%
Realized NS	-155.7%	
Average Age (yrs.)	11.0	
Derived Additions	\$5,946,990,287	
Plant Retirements	\$398,585,960	
Percent Retired	7.2%	
Plant Balance	\$5,548,404,327	

**Table 1. Account Parameters and Statistics**

#### **LIFE ANALYSIS**

The majority of SCE's underground cable population is XLPE, which generally fails due to breakdown of insulation over time. The statistical service life analysis for this account indicates average service lives in a narrow range between 40.5 and 44.7 years with lower modal dispersions for trials with lower censoring, conformance indexes, and hazard functions not compromised by negative or declining rates.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Cable	4,452,641,073	80	45-R2	18.6
Non-unitized	288,856,647	5		
Other	809,879,908	15	27-L1	18.1
Total	5,551,377,628	100	42	

**Table 2. Major Structural Components**

Equipment classified in the "Other" category includes primarily circuit breakers and switches.

An analysis of the subpopulations indicates a 27-L1 and a 45-R2 service life curves with lower modal dispersions and a dollar-weighted mean of 42 years. Service-life indications derived from a statistical analysis of the combined sub-

populations are considered to be within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, non-homogeneous plant category.

### **LIFE ESTIMATION**

Based on these observations and considerations, a 45–R1.5 projection life–curve is recommended for this account. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

Although not equivalent to dollar-years of service, SCE engineers estimate a mean time to failure (MTTF) of 41 years for cross-linked polyethylene (XLPE) and 46 years for tree retardant cross-linked polyethylene (TR-XLPE) conductor. Company engineers also estimate that the mean time to wear-out of underground mainline and radial oil switches is about 35 years and the mean time to wear-out of an underground capacitor bank is about 30 years and 25 years for automatic reclosers. Approximately 11,549 subsurface oil-filled switches, 2,253 capacitor banks and 47 automatic reclosers were installed in the underground system at year-end 2015.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –155.7 percent realized from \$398,585,960 of retirement activity constituting 6.7 percent of derived addition over the period 2002–2015. The most recent four 5-year rolling bands show negative net salvage rates exceeding –150 percent.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –112 and –261 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –261 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

## DISTRIBUTION PLANT

### ACCOUNT: 368.00 – LINE TRANSFORMERS

#### DESCRIPTION

This account includes the investment in overhead and underground distribution line transformers used in transforming electric energy to secondary voltages. Equipment continues to be classified in this account regardless of whether actually in service or held in reserve for future use. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
PLife-Curve	33-R1	33-S1.5
Future NS Rate	-20.0%	-47.0%
Realized NS	-46.9%	
Average Age (yrs.)	12.5	
Derived Additions	\$4,034,390,510	
Plant Retirements	\$525,751,213	
Percent Retired	15.0%	
Plant Balance	\$3,508,639,297	

Table 1. Account Parameters and Statistics

#### LIFE ANALYSIS

Distribution transformers are replaced when they fail in service or when deterioration is observed during inspection or other field work. Deterioration includes leaks, corrosion and damage caused by vehicles or acts of nature. The statistical service life analysis for this account is stable and indicates average service lives in the mid-20s to high-30s and lower modal dispersions for bands with lower censoring and conformance indexes. It should be noted, however, that “cradle-to-grave” accounting is used for line transformers and associated equipment (*e.g.*, capacitors and network protectors). Service lives indicated from a statistical analysis provide estimates of the age at which transformers are permanently retired from service.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve
	Amount (\$)	%	
Undeground Transformers	1,262,937,734	36	34-S2
Overhead Transformers	1,045,618,106	30	40-S2
Fuseholders	749,306,101	21	38-S3
Non-unitized	57,769,013	2	
Other	393,008,343	11	25-O2
Total	3,508,639,297	100	36

Table 2. Major Structural Components



An analysis of the subpopulations indicates average service lives between 25 and 40 years with lower modal dispersions and a dollar-weighted mean of 36 years. Service-life indications derived from a statistical analysis of the combined subpopulations are considered to be within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category.

### **LIFE ESTIMATION**

Service-life indications from both the full account and subpopulation polynomial analyses bound the currently approved 33–S1.5 projection life-curve. Adjusting the currently approved parameters would imply a degree of precision beyond that which can be measured or estimated from a statistical life analysis.

Based on these considerations, retention of a 33–S1.5 projection-life is recommended for this account.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –46.9 percent realized from \$525.8M of retirement activity constituting 13.0 percent of derived addition over the period 2002–2015. Most recent 5-year rolling bands show negative net salvage rates exceeding –130 percent.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –27 and –47 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions.

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –47 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

**DISTRIBUTION PLANT**  
**ACCOUNT: 369.00 – SERVICES**

**DESCRIPTION**

This account includes the installed cost of overhead and underground services used for distribution purposes. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	45-R1.5	45-R1.5
Future NS Rate	-100.0%	-387.0%
Realized NS	-271.0%	
Average Age (yrs.)	17.2	
Derived Additions	\$1,347,309,968	
Plant Retirements	\$45,902,562	
Percent Retired	3.5%	
Plant Balance	\$1,301,407,406	

**Table 1. Account Parameters and Statistics**

**LIFE ANALYSIS**

Overhead (OH) services are typically installed in older urban areas and remote rural areas where it is cost prohibitive to install conductor underground. Services are installed underground (UG) in newer urban areas and in new rural areas under development. Forces of retirement acting upon UG services are comparable to those acting upon UG primary conductors such as operating temperature, insulation type, vintage of cables, installation method, manufacturing quality, corrosive environment and where installed.

The statistical service life analysis for this account is based on highly censored (63-79 percent) samples producing unreliable service-life indications for a majority of trials. The analysis reveals a few inconclusive indications with service lives between the low-40s and mid-60s.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
UG Service Conductor	783,834,596	60	71-S2	85.4
OH Service Conductor	387,892,896	30	52-R1.5	70.6
Risers	63,694,659	5	64-R2	77.8
Non-Unitized	21,112,757	2		
Other	44,872,497	3	79-R2	82.1
Total	1,301,407,406	100	65	

Equipment classified in the "Other" category includes primarily underground conduit.

An analysis of the subpopulations indicates full-band average service lives between 52 and 79 years with lower modal dispersions and a dollar-weighted mean of 65 years. Subpopulation service life indications are similarly based on highly censored trials and the resulting indications are considered less than conclusive.

### **LIFE ESTIMATION**

Neither the full account nor the subpopulation analysis provides sufficient evidence to warrant adjusting the currently approved 45–R1.5 projection life and curve. It was also revealed in conducting the analysis of this account that the pricing and vintaging of retirements may be contributing to the observed high degrees of censoring. Pending further investigation of the ageing of retirements, Foster Associates concurs with SCE that current parameters should be retained for this account.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of –271.0 percent realized from \$45.4M of retirement activity constituting 3.4 percent of derived addition over the period 2002–2015. The most recent three 5-year rolling bands show negative net salvage rates exceeding –500 percent.

The per-unit net salvage analysis conducted for this account indicates future net salvage rates ranging between –178 and –387 percent, depending upon the rate of future inflation. Inflation rates ranging between zero and 2.72 percent were assumed in the analysis. Future net salvage rates would increase with longer projection lives and/or lower modal retirement dispersions..

### **NET SALVAGE ESTIMATION**

Based on the above analysis, a future net salvage rate of –387 percent (derived from a 2.72 percent inflation rate) is recommended for consideration by SCE.

**DISTRIBUTION PLANT**  
**ACCOUNT: 370.00 – METERS**

**DESCRIPTION**

This account includes the cost of smart meters, devices and related appurtenances for use in measuring the electricity delivered to its users, whether actually in service or held in reserve. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	20-R3	20-R3
Future NS Rate	-5.0%	0.0%
Realized NS	-2.4%	
Average Age (yrs.)	7.7	
Derived Additions	\$896,271,606	
Plant Retirements	\$1,349,434	
Percent Retired	0.2%	
Plant Balance	\$894,922,172	

**Table 1. Account Parameters and Statistics**

**LIFE ANALYSIS**

SCE has a population of slightly over 5 million installed meters. With the exception of a small number (less than 20 thousand) of electromechanical meters, AMI meters have been deployed systemwide. A large-scale migration to AMI meters began in 2009 following a pilot program in 2007–2008. The relatively recent deployment of AMI meters produces an insufficient sample of retirements to draw inferences from a statistical analysis. Censoring is about 99 percent.

**LIFE ESTIMATION**

AMI meters are electronic devices encased in plastic, typically installed in harsh environments, exposed to extreme weather conditions, and targets for vandalism. While the metrology element used in smart meters is generally considered mature and reliable technology, the life-span of the communication element is far from certain. Metering communication technology and protocols overlaid on electronic meters are rapidly evolving and will likely accelerate the rate of smart meter replacements relative to older-style, electromechanical metering equipment.

Lacking life analysis indications, the service life estimation for this account is based on a consideration of design life (20 years) and the opinions of Company engineers and operations personnel familiar with smart meters and ever evolving communications technology. Foster Associates therefore deferred to SCE in recommending retention of the currently approved 20–R3 projection life-curve for this account.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account is based upon a minimal amount of \$1.3M retired between 2011 and 2015 from derived additions exceeding \$896M. The analysis indicates an overall net salvage rate of –271.0 percent realized from \$45.4M of retirement activity constituting 3.4 percent of derived addition over the period 2002–2015. The most recent three 5–year rolling bands indicate negative net salvage rates exceeding –500 percent. The historical net salvage recorded in this account is not considered to be a reasonable predictor of future net salvage for AMI meters.

### **NET SALVAGE ESTIMATION**

Noting that “cradle-to-grave” accounting is used for meters and associated equipment (*e.g.*, current and potential transformers), minimal salvage and cost of disposal are expected for this account. Meter removal and reinstallation costs are charged to expense. Based on these observations and expectations, a zero percent future net salvage rate is recommended for consideration by SCE.

## **DISTRIBUTION PLANT**

### **ACCOUNT: 373.00 – STREET LIGHTING AND SIGNAL SYSTEMS**

#### **DESCRIPTION**

This account includes the installed cost of equipment used wholly for public overhead street and highway lighting. Account statistics and current and proposed parameters are shown in Table 1 below.

	Current	Proposed
Plife-Curve	40-L0.5	48-L1
Future NS Rate	-30.0%	-100.0%
Realized NS	-111.3%	
Average Age (yrs.)	15.5	
Derived Additions	\$974,350,403	
Plant Retirements	\$102,266,782	
Percent Retired	11.7%	
Plant Balance	\$872,083,621	

**Table 1. Account Parameters and Statistics**

#### **LIFE ANALYSIS**

During the last 15 years, SCE undertook an accelerated steel pole replacement program to address structural integrity deterioration and related public safety concerns. Pole deterioration found during this program was attributable to atmospheric and water corrosion, and pole, nut and anchor bolt rust. The majority of retired poles were replaced with concrete poles.

The Company conducts annual compliance patrolling and visual inspection of systems and facilities to identify safety issues early. The potential service life of concrete poles is enhanced by adding chlorine ion intrusion inhibitors and using high quality attachments with galvanized coatings.

The major forces of retirement for street light poles include car accidents, deterioration, idled facilities, and street upgrades and relocations.

The statistical service life analysis for this account is reasonably stable for trials with lower censoring, conformance indexes, and non-negative fitted hazard functions. Indications from such trials support average service lives between the lower 40s and mid-50s.

The composition of major categories (or subpopulations) of plant classified in this account at December 31, 2015 and the service life indications obtained from a full-band statistical analysis of each category are shown in Table 2 below.

An analysis of the subpopulations indicates full-band average service lives between 27 and 67 years with lower modal dispersions and a dollar-weighted mean of 54 years. Service-life indications derived from a statistical analysis of the

Category	Investment		Full Band PLife-Curve	Censoring (%)
	Amount (\$)	%		
Poles	388,111,928	46	58-S0.5	48.9
Cable & Conduit	260,964,203	31	67-R2	66.3
Light Fixtures	177,270,403	21	27-S0	2.4
Non-unitized	22,542,405	3		
Other	23,194,681	3	39-O2	38.3
Total	872,083,621	100	54	

**Table 2. Major Structural Components**

combined subpopulations are considered to be within a zone of reasonableness when compared to the subpopulation indications. The analysis of subpopulations does not indicate forces of retirement that would significantly bias the observed indications for a combined, nonhomogeneous plant category.

### **LIFE ESTIMATION**

Based on these considerations and observations, a 48-L1 projection life-curve, derived from the full account broadest placement and observation bands, is considered reasonable and is recommended for this account.

### **NET SALVAGE ANALYSIS**

The adjusted historical net salvage analysis for this account indicates an overall net salvage rate of -111.3 percent realized from \$102,266,782 of retirement activity constituting 10.5 percent of derived addition over the period 2002-2015. The most recent 5 and 10-year rolling bands indicate net salvage rates exceeding -115 percent.

### **NET SALVAGE ESTIMATION**

Based on these observations and the historical net salvage analysis, retention of the currently approved -100 percent future net salvage rate is recommended for consideration by SCE. It appears unlikely that lesser amounts of cost of removal will be realized in the future.

**GENERAL PLANT DEPRECIABLE**  
**ACCOUNT: 390.00 – STRUCTURES AND IMPROVEMENTS**

**DESCRIPTION**

This account includes the cost in place of structures and improvements used for Company purposes, the cost of which is not properly includible in other structures and improvements accounts. Account statistics and current and proposed parameters are shown in Table 1 and the composition of major structural components classified in this account at December 31, 2015 is shown in Table 2.

	Current	Proposed
Plife-Curve	38-R3	45-R0.5
Future NS Rate	-5.0%	-10.0%
Realized NS	-24.5%	
Average Age (yrs.)	12.7	
Derived Additions	\$1,035,908,700	
Plant Retirements	\$88,821,443	
Percent Retired	9.4%	
Plant Balance	\$947,087,257	

**Table 1. Account Parameters and Statistics**

Category	Investment	
	Amount (\$)	%
Common	229,531,472	24
Buildings	220,785,582	23
Power & Lighting Systems	170,306,642	18
HVAC	100,134,622	11
Alarms and Monitoring Systems	65,852,228	7
Foundations & Related Structures	57,908,077	6
Water Supply Systems	33,133,484	3
Non-unitized	27,376,214	3
Miscellaneous	42,058,937	4
	947,087,257	100

**Table 2. Structural Components Distribution**

**LIFE ANALYSIS**

The statistical service life analysis for this account indicates average service lives between 40 and 60 years for trials with lower censoring and conformance indexes. A number of trials are considered less reliable if hazard rates are unrealistically declining or zeroed to avoid the suggestion of negative hazard rates. No attempt was made to analyze equipment classified in the subpopulations for this plant category.



### **LIFE ESTIMATION**

Based on the indications obtained from the broader bands of the statistical life analysis, a 45–R0.5 projection life–curve is recommended for this account. Foster Associates was informed that Company engineers do not anticipate that future forces of retirement will be significantly different from those observed in the past for this plant category.

### **NET SALVAGE ANALYSIS**

The historical net salvage analysis for this account indicates an overall adjusted net salvage rate of –24.1 percent realized from \$88.8M of retirement activity constituting 8.6 percent of derived addition over the 2002–2015 study period.

### **NET SALVAGE ESTIMATION**

Based on these observations and the expectation of continuing negative net salvage, a –10 percent future net salvage rate is recommended for consideration by SCE. This recommendation adjusts the future net salvage parameter from a –5 percent in the direction of the historical net salvage observations.

## **Appendix B**

### **Formulation of Per Unit Net Salvage Rates**

## FORMULATION OF PER-UNIT NET SALVAGE RATES

Average realized net salvage per unit retired for the  $k^{\text{th}}$  subpopulation of a plant account is given by

$$\overline{NSR}_k = \frac{\sum_{2009}^{2015} NSR_{jk}}{\sum_{2009}^{2015} NUR_{jk}}$$

where

$NSR_j$  = net salvage realized in the  $j^{\text{th}}$  activity year; and

$NUR_j$  = number of units retired in the  $j^{\text{th}}$  activity year.

The installed cost per unit of plant remaining in service at December 31, 2015 from the  $i^{\text{th}}$  vintage of the  $k^{\text{th}}$  subpopulation of a plant account is given by

$$ICU_{ik} = \frac{PIS_{ik}}{NUS_{ik}}$$

where

$PIS_{ik}$  = plant in service from the  $i^{\text{th}}$  vintage of the  $k^{\text{th}}$  subpopulation; and

$NUS_{ik}$  = number of units in service from the  $i^{\text{th}}$  vintage of the  $k^{\text{th}}$  subpopulation.

The ratio of the net salvage per unit retired to the installed cost of the  $i^{\text{th}}$  vintage of the  $k^{\text{th}}$  subpopulation of a plant account becomes

$$PUR_{ik} = \frac{\overline{NSR}_k}{ICU_{ik}}.$$

The plant-weighted average of vintage subpopulation ratios used to estimate the future net salvage of vintages at the account level (*i.e.*, the sum of subpopulation vintages) is given by

$$\overline{PUR}_i = \frac{\sum_{k=1}^n (PIS_{ik})(PUR_{ik})}{\sum_{k=1}^n PIS_{ik}}$$

where

$n$  = number of subpopulations within a plant account.

Forecasted retirements from the  $i^{\text{th}}$  vintage in the  $j^{\text{th}}$  activity year are the product of plant in service at December 31, 2015 and the probability of retirement in activity years beyond 2015

obtained from an Iowa–type probability density function. Retirements from the  $i^{\text{th}}$  vintage in the  $j^{\text{th}}$  activity year are given by

$$RET_{ij} = (PIS_i)(p_{ij})$$

where

$p_{ij}$  = probability of retirement during age interval  $j-i-0.5$  and  $j-i+0.5$ .

Estimated future net salvage for retirements from the  $i^{\text{th}}$  vintage in the  $j^{\text{th}}$  activity year is given by

$$FNS_{ij} = RET_{ij}(\overline{PUR}_i)(1+r)^{j-2015}$$

$r$  = estimated rate of inflation.

where

The estimated future net salvage rate for a plant account is the ratio of the sum of future net salvage to the sum of vintaged plant in service given by

$$FNS = \frac{\sum_i \sum_j FNS_{ij}}{\sum_i \sum_k PIS_{ik}}.$$