

**Hydro One Networks Inc.**

7<sup>th</sup> Floor, South Tower  
483 Bay Street  
Toronto, Ontario M5G 2P5  
www.HydroOne.com

Tel: (416) 345-5680  
Cell: (416) 568-5534  
Frank.Dandrea@HydroOne.com

**Frank D'Andrea**

Vice President, Chief Regulatory Officer,  
Chief Risk Officer



BY COURIER

June 18, 2018

Ms. Kirsten Walli  
Board Secretary  
Ontario Energy Board  
Suite 2700, 2300 Yonge Street  
P.O. Box 2319  
Toronto, ON M4P 1E4

Dear Ms. Walli,

**EB-2017-0049 – Oral Hearing Undertakings for Hydro One Networks Inc.’s 2018-2022  
Distribution Custom IR Application (the “Application”)**

---

Please find enclosed the responses to undertakings J 1.5 and J 2.4 from the Oral Hearing held on June 11 and 12, 2018 in regards to the above noted proceeding.

This filing has been submitted electronically using the Board's Regulatory Electronic Submission System and two (2) hard copies will be sent via courier.

Sincerely,

ORIGINAL SIGNED BY FRANK D'ANDREA

Frank D'Andrea

Encls.

cc. EB-2017-0049 parties (electronic)

**UNDERTAKING – J 1.5**

**Reference**

I-18-SEC-029

K1.6

**Undertaking**

To advise what caused the change in cost per customer from 2014 to 2015.

**Response**

The *Total Cost per Customer* measure in the Electricity Distributor Scorecard is calculated by the Pacific Economics Group, LLC (PEG), based on the annual Reporting and Record-keeping Requirements (RRR) filings to the Ontario Energy Board.

Table 1 below illustrates the inputs used in the 2017 PEG Benchmarking Update Calculations<sup>1</sup> (the “PEG model”) for the years 2014 and 2015.

**Table 1 – Inputs to the PEG Model for Total Cost per Customer**

<i>in dollars, u.o.s.</i>	<b>2014</b>	<b>2015</b>	<b>Variance</b>	
Total Actual Cost	1,304,202,201	1,236,083,718	(68,118,483)	(A)
Total Customer Count	1,219,670	1,257,467	37,797	(B)
<b>Total Cost per Customer</b>	<b>1,069</b>	<b>983</b>	<b>(86)</b>	(A) ÷ (B)

The decrease of about 8 per cent, or \$86 in the *Total Cost per Customer* in 2015 was primarily due to lower *Total Actual Costs* resulting from lower *Total OM&A* and *Capital Costs*, and a slightly higher *Total Customer Count*.

<sup>1</sup> Pacific Economics Group LLC. (2017, August 17). *Total cost benchmarking - updates, Benchmarking Update Calculations*. Retrieved June 11, 2018, from Audit and Performance Assessment: <https://www.oeb.ca/industry/rules-codes-and-requirements/audit-and-performance-assessment>

1 The lower *Total OM&A* expense was mainly due to:

- 2
- 3 • A decrease of \$70.1 million in OM&A from:
  - 4 ○ Lower costs related to remediating the Company's customer information
  - 5 system and lower customer support expenses
  - 6 ○ Lower preventative maintenance related to vegetation management
  - 7

8 The lower *Capital Cost* was mainly due to:

- 9
- 10 • A decrease of \$12.9 million in Capital Costs, which were partially offset by \$7.8
- 11 million stemming from the inclusion of Norfolk Power Inc.
- 12

13 Capital Costs are subject to various PEG-based adjustments, which cannot be directly  
14 attributed to the operations and capital work of Hydro One, but which can be explored in  
15 further detail within the PEG model.

16

17 The higher *Total Customer Count* was mainly due to:

- 18
- 19 • An increase of 37,797 customers, with 19,564 customers attributable to the
- 20 merger with Norfolk Power Inc.
- 21

22 For RRR purposes, Hydro One was required to report the impact of the Norfolk  
23 acquisition in its 2015 RRR annual filing. For the purposes of Hydro One's rate  
24 application (EB-2017-0049), the impact of the mergers & acquisitions (i.e. Norfolk  
25 Power Inc., Haldimand County Hydro Inc., and Woodstock Hydro Services Inc., are only  
26 recognized starting in 2021.

**UNDERTAKING – J 2.4**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

**Reference**

I-38-CCC-044-01

**Undertaking**

To provide in advance of the appearance of panel 5 material created by Boston Consulting Group.

**Response**

The Boston Consulting Group conducted an initial review of Hydro One’s vegetation management program and prepared a draft PowerPoint presentation of their findings, provided as Attachment 1. The presentation was never finalized.

Hydro One did not consider the Boston Consulting Group’s draft presentation when it developed its vegetation strategy in this application.

To develop its vegetation strategy in this application, Hydro One retained Clear Path Utility Solutions LLC, an expert in utility vegetation and shared the Boston Consulting Group’s draft presentation with them for that purpose.

# Executive summary

## Effectiveness of Hydro One's existing VM programs on par with other utilities

- \$/ACI for cyclic and strategic trim in line with BCG benchmarks

## Under existing grid technology/design, opportunity to improve reliability through better VM practices appears limited

- Based on historical data, trimming every year would only drive a SAIFI improvement of 0.09 (18%)
- Consistent with observation that ~80% of tree-related outages come from off-ROW

## Hydro One's VM program can deliver maximum value to customers by focusing on two areas

- Ensuring that existing VM program is optimized for cost effectiveness
- Delivering expected reliability outcomes (e.g. ensuring high reliability to LDAs while maintaining performance for rural customers)


## 3 potential opportunities for reducing VM spend while meeting customer segment expectations

- 1 Cyclical trim: reduce trim cycle for highest priority feeders (M-class, LDA-serving, 3-phase, etc.)
  - Shorter trim cycle reduces total O&M costs but likely not feasible/optimal for all feeders
- 2 Strategic trim: optimize around cost effectiveness of spend
- 3 Deployment of new design standards (e.g. Hendrix cables) in high risk areas to reduce customer impacts from tree outages

# Tree contacts are a large and growing driver of outages in the distribution system


## Tree contacts remain major driver of SAIFI, increasing in the past 3 years

SAIFI (2011-2015 avg.)



## Tree contact outages have highest CAIDI, reflecting high cost of response

CAIDI (2011-2015 avg.)




**Tree contracts account for 16% of system SAIFI and 28% of overall SAIDI**

Note: Data includes LOS and excludes FM; data follows the Hydro One standard defining a sustained outage as greater than 1 minute; FM events calculated using 10% methodology  
 Source: H1 OMS Data

# H1's historical vegetation management cost effectiveness on par with other utilities

## Hydro One vegetation management historical \$/ACI




- 1 Hydro One's veg mgmt program effectiveness in line with BCG benchmarks
- 2 Sub-Tx cyclic trim more cost effective than Dx trim
- 3 Hazard tree program is effective but represents limited spend (~\$250k /yr)

Note: Data includes LOS and excludes FM; FM events calculated using 10% methodology


Source: BCG Analysis, BCG experience with other utilities

# Outages increase with time since last trim – but base level of outages likely due to fall-ins

## Recently trimmed feeders still suffer from number of tree-related outages



## Majority of tree-related outages caused by trees falling from off ROW



### Utilities report 80-90% of fallen-tree outages are caused by trees outside managed ROW

- Challenging to identify hazard trees outside maintenance zone

**Outage/km floor suggests trimming on 1-year cycle reduces tree-related SAIFI by 18%, from 0.51 to 0.42**

Note: Outages/km data includes LOS and excludes FM; outages/yr data includes FM events; data follows the Hydro One standard defining a sustained outage as greater than 1 minute; FM events calculated using 10% methodology. Source: H1 OMS Data



# Several potential levers identified to improve vegetation management program

Historic		Future		
Current H1 programs	\$/ACI	High potential reliability levers	\$/ACI + ease of implementation	
<b>1</b> Cyclic trim	Dx: \$949 Sub-Tx: \$325	OM&A	<b>4</b> Clear current backlog Dx: \$589 Sub-Tx: \$405	
<b>2</b> Off-cycle requests	Dx: \$256 Sub-Tx: N/A		<b>5</b> Adjust trim cycle Dx: <b>(\$549)</b> Sub-Tx: <b>(\$589)</b>	
<b>3</b> Hazard tree program	Dx: \$86 Sub-Tx: \$26		<b>6</b> Increase strategic trim Dx: \$170 Sub-Tx: \$96	
			<b>7</b> Enhance trim standards • Trim standards in line with others; opportunity to address hazard trees?	
			<b>8</b> Tech-enabled risk-based trim Dx: \$310-\$646 Sub-Tx: \$245-\$493	
			CapEx	<b>9</b> Spacer cables Dx: \$26-\$525 <sup>1</sup> Sub-Tx: \$22-\$499 <sup>1</sup>
				<b>10</b> Aerial bundled cables Dx: \$2,250-2,960 Sub-Tx: \$1,850-2,430

= suggested approach

= in progress


**( )** = negative

*\$/ACI reflects cost per avoided customer interruption on a 10-year timeframe*


Source: BCG Analysis, H1 OMS Data, 1. Lower limit of cost range reflects \$/ACI for first 100km of addressible line.

# Increased trim costs with age lead to lower overall VM costs with shorter cycles

## Trim cost rises with age since last trim




## Opportunity to reduce total O&M expense through shift to shorter cycle




**Moving to short cycle on all feeders not optimal due to execution constraints**

# Small number of feeders have significantly more tree-related outages than system average

### Tree-related customer interruptions for Dx feeders



### Tree-related customer interruptions for Sub-Tx feeders



= opportunity for strategic trim

Note: Data includes LOS and excludes FM; data follows the Hydro One standard defining a sustained outage as greater than 1 minute; FM events calculated using 10% methodology  
 Source: H1 OMS Data, BCG Analysis

# Adjusting strategic trim prioritization mechanism yields significant cost benefits

## H1's current strategic trim prioritization emphasizes overall SAIDI/SAIFI

### H1's current prioritization criteria

- Feeder-level reliability data (SAIDI / SAIFI for last 3 years) - **(70%)**
- Years since last trim - **(20%)**
- Condition data from SAP on per-pole defects - **(10%)**

Age and defect count do not enhance prediction of future reliability

## More cost efficient to prioritize based on potential \$/ACI

### Focus on CI/km rather than absolute number of interruptions

- Customer interruptions (non-FM) per km is more relevant reliability metric than total CI

### Factor in variation in trimming costs

- Longer feeders are more expensive to trim
- Trimming costs vary significantly by region

## Projected SAIFI impact of highest priority Dx feeder trim

	H1 2016 Scheduled <sup>1</sup>	H1 2016 Prioritized <sup>2</sup>	New Priority <sup>3</sup>
<b>Cost (\$M)</b>	25.5	25.7	7.3
<b>SAIFI Improve.</b>	0.013	0.013	0.013
<b>\$/ACI</b>	302	303	88

1. Highest priority feeders using H1 methodology scheduled for work in 2016. 2. Highest priority feeders using H1 methodology. 3. Highest priority feeders using new \$/ACI methodology. Source: H1 OMS Data, BCG Analysis

# Spacer cables provide opportunity to reduce outages from tree fall-ins, but are not suitable everywhere

## Spacer cables offer potential to reduce tree-caused outage baseline

### Network reliability benefits

- Reduction in tree-caused outages of 70-90%<sup>1</sup> relative to bare wires

### Reduced tree trimming costs

- Compact design and shielded wires allow vegetation to grow closer to lines



### Assumptions

Reduction in VM spend of 30%<sup>3,4</sup> and tree-related outages by 70%<sup>1</sup>

Incremental spacer cable cost is 15% above bare line cost<sup>3,4</sup>

Outages measured under all conditions  
 Source: H1 OMS Data, 1. Electric Power Distribution Handbook, T&D World. 2. Lower limit of cost range reflects \$/ACI for first 100km of addressible line. 3. CEMIG (Brazil) case study 4. Hendrix Wire and Cable, BCG Analysis

## Spacer cables have low \$/ACI on select feeders


	Dx	Sub-Tx
<b>Spacer Cables</b>	\$26-\$525 <sup>2</sup>	\$22-\$499 <sup>2</sup>

### Initial Observations

- Low \$/ACI for both Dx and Sub-Tx on high-impact feeders
- Cost effectiveness of spacer cables highly dependent on reduction in customer interruptions
- Spacer cables likely not suitable for widespread deployment, but appear cost effective for some feeders

# Spacer cables cost effective on significant portion of ROW

## ROW addressable by spacer cables



## Replacement program targets highest impact feeders at end of line life

### Spacer cables only suitable when line is at end of life or for new build

- Not cost effective to replace conductors which are in good condition

### Feeders with highest CI/km are most attractive target for replacement

- Areas with either high outages/km (densely forested) or high CI/outage (densely populated) are good candidates

### Trimming standards can be adjusted on replaced feeders

- Compact design and covered conductors permit smaller clearances

**Deployment will require implementation of new design standards as lines reach end of life**

# Summary of proposed vegetation management program

- 1 Strict maintenance of shorter cycle on high-priority feeders**
  - Maintain M-class, LDA-serving, and 3-phase F-class feeders on strict cycle corresponding to lowest total VM costs
- 2 Increased use of targeted strategic trim on lower-priority feeders**
  - Adjust prioritization methodology to maximize avoided customer interruptions per dollar
  - Continue to evaluate tech-based monitoring to better assess vegetation risk
- 3 Deployment of spacer cables in high-impact areas as lines reach end of life**
- 4 Management of existing backlog to maintain system integrity**
  - Will need to establish maximum age since last trim
  - Likely to be driven by regulatory pressures

# Appendix



# Shortening trim cycle results in lower costs and higher reliability

## Methodology

**Calculated total veg mgmt cost for various trim cycle lengths**

- used historical \$/km trim cost data

**Determined historical outages/km for all Dx feeders based on time since last trim**

**Estimated impact of scenarios on tree-related SAIFI**

- reduction in tree-related outages used to calculate O&M savings from storm/trouble calls

## Assumptions

**Sub-Tx feeders display same rate of reliability benefit degradation from veg mgmt as Dx feeders**

**Shorter trim cycle would yield lower overall costs and better reliability**

Cycle Length	Total cost (trim + brush + trouble calls)	Tree-related SAIFI
1	485	0.420
2	292	0.433
3	229	0.446
4	197	0.460
5	178	0.473
6	179	0.486
7	190	0.500
8	207	0.513

## Initial Observations

- System will be further segmented to determine optimal cycle length for feeder subsets

Note: Data includes LOS and excludes FM; data follows the Hydro One standard defining a sustained outage as greater than 1 minute; FM events calculated using 10% methodology  
Source: H1 OMS Data, BCG Analysis

# Targeted strategic trim is more cost effective than cyclic trim

## Methodology

### Estimated \$/ACI for each feeder

- Outages/km assumed to reach system average after targeted trim
- Trim cost estimated from historical data

Rank ordered feeders from worst to best based on \$/ACI

Determined total cost and reliability impact for all feeders with \$/ACI below \$300

## Assumptions

Assumed feeder outages/km reaches system average after strategic trim

Linear decline in VM benefit over 5 year period

## Projected impact from first year targets

	Dx	Sub-Tx
Total ACI (5-yr)	220,000	209,000
Trim Cost	\$37 M	\$20 M
SAIFI Improvement	0.034	0.032
<b>\$/ACI</b>	<b>170</b>	<b>96</b>

H1 has strategic trim program


## Initial Observations

- 1 High-outage feeders represent large SAIFI improvement opportunity
- 2 Hydro One initiated strategic trim program on F-class feeders in 2016

# Well-targeted strategic trim has large SAIFI impact

## SAIFI Improvement for various levels of strategic trim spend

Cumulative SAIFI Improvement



SAIFI Imprvt.

0.028

0.040

0.048

0.056

0.062

\$/ACI

\$56

\$79

\$95

\$111

\$124

# Recent reliability is best predictor of future SAIFI

Years since last trim and defects/km do not reliably predict SAIFI for individual feeders

## Factors used in current strategic trim prioritization

- 1 Feeder-level reliability data (SAIDI / SAIFI for last 3 years) - (70%)
- 2 Years since last trim - (20%)
- 3 Condition data from SAP on per-pole defects - (10%)

## Recent CI/km is only significant predictor of 2015 CI/km<sup>1</sup>

	Coeff.	Std. Error	p-value
2012-2014 CI/km	0.66	0.06	2 x 10 <sup>-25</sup>
Age (yrs)	-0.21	0.16	0.21
Defects/km	0.14	0.31	0.66

## Suggested new prioritization criteria

- 1 Length-normalized feeder-level reliability data (CI/km for last 3 years)
- +
- 2 Trimming cost/km
- 
- = **Projected \$/ACI for each feeder**

1. Multiple regression analysis performed on feeders trimmed prior to 2014. Coefficient indicates rise in 2015 CI/km for one unit rise in independent variable listed. P-value is likelihood relationship between variables was obtained by chance.


# Jurisdictions with mandated vegetation management have similar clearance standards to Hydro One but shorter cycles

State/province (standard)	Horizontal Clearance (m)	Vertical Clearance (m)	Trim Cycle (yrs)	Motivation
Hydro One	3.0 (at trim)	3.0 (at trim)	8	<ul style="list-style-type: none"> <li>Provide cost effective service that mitigates tree related risk</li> </ul>
Maryland	3.0 (at trim)	3.0 (at trim)	4 (urban) 6 (rural)	<ul style="list-style-type: none"> <li>Response to PEPCO's status as one of the most unreliable utilities</li> </ul>
Alberta	1.0	2.0	n/a	<ul style="list-style-type: none"> <li>Desire to create 'best in class' utilities which comprehensively address risk of tree contact</li> </ul>
Oregon	1.5	1.5	n/a	<ul style="list-style-type: none"> <li>Attempt to mitigate accidents and electrocutions from climbing tree near power lines</li> </ul>
California	1.2	1.2	n/a	<ul style="list-style-type: none"> <li>Primarily adopted to reduce high risk of fire</li> </ul>
Missouri	n/a	n/a	6(r) 4 (u)	<ul style="list-style-type: none"> <li>Improve utility reliability</li> </ul>
Oklahoma	n/a	n/a	4	<ul style="list-style-type: none"> <li>Improve utility reliability</li> </ul>
Florida	n/a	n/a	3	<ul style="list-style-type: none"> <li>Reduce hurricane related damage</li> </ul>

Source: 1. CNUC 2010 Regulatory Requirements Report 2. Oregon Public Utilities Commission Division 24 Safety Standards. 3. Electrical Protection Act Alberta Electrical & Communication Utility Code Section 3.1.7 4. MD PSC RM 43 Vegetation Management 5. California Public Resource Code 4293, General Order 95 Rule 35

# Backlog has now grown to nearly 30% of entire right-of-way, increasing strain on vegetation management

## 28% of right-of-way is greater than 8 years since last clearing



## Backlog imposes growing burdens on vegetation management

### Trimming costs increase with years since last trim

- More trees must be addressed in cyclic trim
- Higher-cost labor must be employed for brush management when brush nears lines (>6 years)

### Safety concerns rise for trimming and outage response


- Overgrown feeders present greater challenges for forestry and repair crews working in vicinity of lines

### Tree-related outages increase with years since last trim


- Outage rate rises linearly with trim age causing deterioration in system SAIFI

# Sub-Tx lines have been maintained on a 6-8 year cycle at the expense of Dx lines

**Nearly all Sub-Tx lines have been maintained on 6-8 year cycle**



**Over one third of Dx feeders older than 8 years old**



**Current vegetation management spending insufficient to maintain all ROW on <8 year cycle**