



Install removable jumper connection (typical) supported by post type insulators on the steel tower connecting between the T61S and T2R circuits. Jumper connection to be used as a temporary "Normally opened MSO switch" at TWR #634B (Typical)

