

ENERGY PROBE COMPENDIUM #2

EB-2019-0018

ONTARIO ENERGY BOARD

IN THE MATTER OF the *Ontario Energy Board Act, 1998, S.O. 1998, c.15 (Sched. B)*;

AND IN THE MATTER OF an application by Alectra Utilities Corporation under Section 78, for an Order or Orders approving or fixing just and reasonable rates and other service charges for the distribution of electricity, as of January 1, 2020.

Alectra Utilities Hearing

Energy Probe Research Foundation

October 15, 2019

Alectra Hearing October 15, 2019
EP Compendium #2


INDEX

Topic	References	Page(s)
Alectra Service Areas and Rate Zones	Exhibit 04 Tab 01 Schedule 01 Figure 5-1-1	2
Historic Legacy Rate Zone Reliability	EP IRR-4; EP Exhibit TC-KT2.1 Excel Spreadsheet –EP Summary Reliability and Trends Tab 1	3
Comparison to Ontario Utilities	EP IRR 4 c) System Interruptions (SAIDI) for Ontario Utilities	4
Causes of Declining Reliability	EP KT2.1 Page 2 Causes of Interruptions SAIDI and SAIFI EP Exhibit TC-KT2.1 Excel Spreadsheet Tab2	5
Asset Condition and the DSP with the Requested Capital Plan and Partial Plan.	EP IRR-1 Exhibit 2, Tab 1, Schedule 2, Page 1 Long Term System Renewal Trends	6
Customer Engagement	EP IRR 5 Customer Survey 5.4.3 Innovative Workbook Pages 33-35 and pages 40-43	7-11
Underground Cable	EP IRR 8 Parts e) and f) U/G Cable Replacement Quantities and Costs	12
Underground Cable Replacement and Refurbishment Capital Program	EP IRR 8 EP Spreadsheet KT2.1 Alectra DSP System Reliability Improvement Scenarios	13
DSP System Renewal Capital Plan	Energy Probe Workbook Page 1 System Renewal Spending	14
U/G Cable Replacement and Reliability Projects	Energy Probe Workbook Page 2 DSP U/G Cable Projects IRR G-Staff-29 SEC 2; Staff IRR G-29 part b	15
Data Set for U/G Projects	Energy Probe Workbook U/G Cable Projects Page 1 JT2.5	16
Pace of U/G Cable Replacement/refurbishment	Board Staff IRR G-29c; Energy Probe Workbook Page 3	17
Alectra Capital Plan DSP Capital- Base Rates and M-Factor	JT2.2 Q1 and Q7 Appendix 2-AB EP Workbook Page 4 DSP Capital Plan	18
SAIDI and SAIFI Improvements	Board Staff IRR G-4 M-Factor Funded System Renewal Projects PowerStream Example	19
M-Factor Capital Cost Allocation and Rates	Exhibit 2 Tab1 Schedule 3 page 10 M-Factor Revenue Requirement; JT2.10	20

Table 5.1 - 1: Alectra Utilities' Operating Areas

Operating Area	Municipality
East	Alliston, Aurora, Barrie, Beeton, Bradford, Markham, Penetanguishene, Richmond Hill, Thornton, Tottenham, Vaughan
Central	Brampton (North), Mississauga (South)
West	Hamilton, St. Catharines
South West	Guelph, Rockwood

Figure 5.1 - 1: Alectra Utilities' Service Area








KT2.1 Page 1

EP Exhibit TC XX based on EP-4 IRR

Alectra Utilities Rate Zones System Reliability

SAIDI [MEDS Adjusted]		HISTORIC 2014-2018					Target	SAIDI [MEDS Adjusted]		Defective Equipment Cause Code							
Rate Zone	2014	2015	2016	2017	2018	5 year Avg	Trend*	2020-2024	Rate Zone	2014	2015	2016	2017	2018	5 year Avg	% of SAIDI	Trend*
ERZ	0.53	0.72	0.81	0.61	0.94	0.72	Worse		ERZ	0.31	0.37	0.48	0.34	0.56	0.41	57.06%	
BRZ	0.38	0.48	0.45	0.41	0.58	0.46	Worse		BRZ	0.27	0.17	0.19	0.24	0.38	0.25	54.35%	
HRZ	1.00	1.57	1.51	1.23	1.93	1.45	Worse		HRZ	0.49	0.74	0.35	0.38	0.65	0.52	36.05%	
PRZ	1.23	1.19	0.90	1.05	1.10	1.09	Better		PRZ	0.49	0.42	0.41	0.45	0.48	0.45	41.13%	
GRZ	0.75	0.57	0.82	0.47	0.30	0.58	Better		GRZ	0.06	0.18	0.34	0.18	0.08	0.17	28.87%	
Alectra	0.88	1.05	0.96	0.87	1.14	0.98	Worse	0.98	Alectra	0.40	0.44	0.37	0.36	0.50	0.41	42.29%	Worse
SAIFI [MEDS Adjusted]		HISTORIC 2014-2018					Target	SAIFI [MEDS Adjusted]		Defective Equipment Cause Code							
Rate Zone	2014	2015	2016	2017	2018	5 year Avg	Trend*	2020-2024	Rate Zone	2014	2015	2016	2017	2018	5 year Avg	% of SAIFI	Trend*
ERZ	0.97	1.64	1.13	1.14	1.50	1.28	Worse		ERZ	0.51	0.53	0.54	0.54	0.75	0.57	44.98%	
BRZ	0.81	0.98	0.72	0.68	0.87	0.81	Better		BRZ	0.47	0.21	0.20	0.35	0.42	0.33	40.64%	
HRZ	1.48	1.86	1.93	1.74	2.54	1.91	Worse		HRZ	0.44	0.46	0.35	0.35	0.45	0.41	21.47%	
PRZ	1.48	1.14	0.96	1.16	1.24	1.20	Better		PRZ	0.51	0.31	0.41	0.40	0.45	0.42	34.78%	
GRZ	1.30	1.53	1.95	1.30	0.97	1.41	Better		GRZ	0.10	0.49	0.39	0.38	0.13	0.30	21.13%	
Alectra	1.27	1.41	1.24	1.23	1.53	1.34	Worse	1.34	Alectra	0.47	0.38	0.39	0.41	0.49	0.43	31.92%	Worse
MAIFI																	
Alectra						3.53		No Target									

Summary Alectra Reliability						
	2014	2015	2016	2017	2018	5 year Avg
Alectra SAIDI Meds Adj	0.88	1.05	0.96	0.87	1.14	0.98
Alectra SAIFI Meds Adj	1.27	1.41	1.24	1.23	1.53	1.34



SAIDI		Effect of Major Event Days					Difference	
Rate Zone	2014	2015	2016	2017	2018			
ERZ MEDS Adj	0.53	0.72	0.81	0.61	0.94	0.72		
ERZ Unadjusted	0.67	0.72	0.81	0.71	1.72	0.93	0.20	
BRZ MEDS Adj	0.38	0.48	0.45	0.41	0.58	0.46		
BRZ Unadjusted	0.57	0.72	0.45	0.48	0.72	0.59	0.13	
HRZ MEDS Adj	1.00	1.57	1.51	1.23	1.93	1.45		
HRZ Unadjusted	2.18	1.77	1.64	1.47	2.96	2.00	0.56	
PRZ MEDS Adj	1.23	1.19	0.90	1.05	1.10	1.09		
PRZ Unadjusted	1.45	1.99	2.74	1.44	1.95	1.91	0.82	
GRZ MEDS Adj	0.75	0.57	0.82	0.47	0.30	0.58		
GRZ Unadjusted	0.75	0.57	1.08	0.47	0.50	0.67	0.09	
Alectra MEDS Adj	0.88	1.05	0.96	0.87	1.14	0.98		
Alectra Unadjusted	1.3	1.42	1.66	1.1	1.87	1.47	0.49	

EP IRR 4 c) System Interruptions (SAIDI) for Ontario Utilities 2018 showing Alectra Legacy Utilities

c) Alectra Utilities has updated the chart provided in EB-2018-0165 as Figure 1 and Figure 2, below. A breakdown of SAIDI and SAIFI by quartile is provided in Tables 23 to 24, below.




Figure 1: SAIDI Excluding MEDS and LOS


Table 24 - SAIDI Quartile Grouping

Quartile	SAIDI
Q1	BRZ, GRZ
Q2	ERZ, Alectra
Q3	PRZ and HRZ
Q4	None

EP KT2.1 Page 2 Causes of Interruptions SAIDI and SAIFI

Alectra EP IRR 26 Table 2
Ex 04 Tab1 Sch 1Fig 5.2.3-11


Asset Type	# of Events	5 Year Reliability Average Impact						
		# of Customer Interruptions	Customer Hour Interruptions	Per Event Customer Impact	Per Event Duration Impact hrs	% of Events	% of Duration	Customer Int SAIDI*
Cable & Accessories PILC	14	14,633	23,966	1,031	1.64	0.01	0.06	0.02
Cable & Accessories XLPE	504	168,999	202,003	335	1.20	0.44	0.49	0.20
Switches	87	38,916	29,262	446	0.75	0.08	0.07	0.03
Switchgear	57	51,104	41,099	897	0.80	0.05	0.10	0.04
OH Line Hardware	157	87,219	85,845	557	0.98	0.14	0.21	0.09
Transformer	317	20,365	32,666	64	1.60	0.28	0.08	0.03
TOTAL	1,136	381,236	414,841	3,330		1.00	1.00	0.41



*assumes ~1 million Customers

Replacement Scenario	2019	2020	2021	2022	2023	2024	Total	Impact on #	Impact on
								Interruptions SAIFI	Duration Hrs SAIDI
# Units									
Cable & Accessories PILC	0	0	0	0	0	0	0	0	0
Cable & Accessories XLPE	216	306	400	445	495	538	2400	0.246	0.560
Switches	49	44	44	44	44	44	269	0.006	0.025
Switchgear	81	83	83	83	83	83	496	0.016	0.066
OH Line Hardware - Poles	912	868	929	907	890	868	5374	0.034	0.009
Transformer	1008	485	530	565	580	590	3758	0.016	0.066

Figure 2: Long-Term System Renewal Trends



Customer Engagement Exhibit 4 Appendix C

Online Workbook

Reliability Experience | Preamble

Residential



33

Reliability Experience


Reliability is a key priority for Alectra Utilities. Since 2014, both the average number and duration of outages has increased for the typical Alectra Utilities customer.

- The average number of outages (excluding major event days) has increased by an average of 6% per year from 2014-2018, rising from 1.27 to 1.53 over this period.
- The average duration of outages (excluding major event days) has increased by an average of 8% per year from 2014-2018, rising from 0.88 hours to 1.14 hours over this period.

The two primary contributors to outages account for more than 50% of all outages.

1. **Defective equipment** accounted for 30% of customer hours of interruption between 2014-2018, the single largest outage cause.
2. **Adverse weather** is the second leading cause of outages. It accounted for 22% of customer hours of interruption over the same period.


Customer Outage Duration (Hours) by Cause 2014-2018



Depending on what rate zone you are in, the subsequent pages will ask you to review between 7 and 13 choices, many of which address the issues identified in the chart above.



Q In the past 12 months, how many power outages do you recall experiencing at home/your organization?



Rate Zone Breakdown	ERZ	BRZ	HRZ	PRZ	GRZ
No outages	30%	37%	20%	17%	29%
1 outage	28%	27%	30%	26%	30%
2 or 3 outages	28%	26%	37%	39%	29%
4 or more outages	8%	5%	10%	14%	8%
Don't know	6%	5%	3%	4%	4%




Technical Conference Undertaking JT1.8
Table 1: Customer Outages by Rate Zone in 2018

Multiple Sustained Outages (Scheduled Outages Removed)					
Metric	PRZ	ERZ	HRZ	BRZ	GRZ
No Outages	27%	22%	25%	44%	31%
1 Outage	32%	30%	32%	17%	29%
2 or 3 Outages	33%	30%	34%	23%	29%
4 or more Outages	8%	18%	10%	16%	11%
Total	100.00%	100.00%	100.00%	100.00%	100.00%



Underground Asset Renewal

Equipment failure is the single largest cause of outages in Alectra Utilities' system. As the chart below illustrates, a particular type of equipment known as cross-linked polyethylene (XLPE) cable is the leading cause of outages across Alectra Utilities' system.



Case Study

The deterioration of these cables is directly impacting customers. For example, the York/Hilda neighbourhood in Vaughan was originally scheduled to have its cables replaced in 2019. But in 2018, customers began to experience a cascading series of prolonged outages, due to cable failures. Cables repaired one week would fail again the next. In the summer, 250 customers experienced eight cable faults (one outage a week). As a result, the cable had to be replaced on an emergency basis at both a higher cost to Alectra Utilities and major inconvenience to the affected customers.

As Alectra Utilities reviewed all of its equipment across all of its operating areas, it became clear that replacing XLPE underground cable requires an accelerated investment plan. To provide the best value to customers, Alectra Utilities will be using two approaches:

- **Cable Rejuvenation:** Cable rejuvenation is a lower-cost solution that can extend the life of these cables without the need to excavate and replace the entire cable. While it is the better value for customers for cables in fair condition, it is not effective for cables that are already declining.
- **Cable Replacement:** In some cases, Alectra Utilities has no prudent choice but to replace the cable. Replacing this equipment now rather than trying to extend its life will cost more now, but will deliver superior reliability over time, relative to older standards of cable.

Alectra Utilities has a decision to make regarding the pace in which they invest in replacing or extending the life of at-risk underground equipment.

Online Workbook

Residential




Pacing Investments in the Underground System

Within current rates, the reliability of underground cable is expected to further worsen by approximately 4% from current 2018 levels. As such, Alectra Utilities is recommending a pace of cable replacement and rehabilitation that will maintain current levels of reliability.



Which of the following cable replacement strategies would you prefer?

Option	Cable replaced or rehabilitated	Expected Reliability Outcome
Accelerated Pace <i>Additional \$X.XX per month annually (\$Y.YY more per bill by 2024)</i>	2,184 km by 2024	Improve the reliability of cables by 8% from the current (2018) level
Recommended Pace <i>Additional \$X.XX per month annually (\$Y.YY more per bill by 2024)</i>	1,978 km by 2024	Maintain the reliability of cables at the current (2018) level
Base Pace <i>Within current rates</i>	1,861 km by 2024	Reliability of cables to further worsen by 4% from the current (2018) level
Slower Pace <i>Decrease of \$X.XX per month annually (\$Y.YY less per bill by 2024)</i>	1,624 km by 2024	Reliability of cables expected to further worsen by 10% from the current (2018) level



Rate Zone Breakdown	ERZ	HRZ	PRZ
Accelerated Pace	21%	26%	17%
Recommended Pace	53%	52%	51%
Base Pace	21%	17%	24%
Slower Pace	6%	6%	7%

Key Findings

A strong majority of Alectra Utilities customers across all rate classes and in all rate zones support additional investments in infrastructure that most directly serve customers. These investments include:

- Overhead renewal;
- Underground renewal;
- Transformer replacement;
- Monitoring and control equipment; and
- Converting rear lot services.

The table below illustrates the typical reaction for underground investment options.

Percentage of Customers Who Chose Recommended or Higher Option for Underground System Investments

Rate Zone Breakdown <i>% Recommended or higher n-size for sample sizes <60</i>	ERZ	HRZ	PRZ
Residential	74%	77%	68%
Small Business	67%	74%	57%
GS > 50 kW - 4,999	34/51	17/24	46/62
Large Use	4/5	5/7	1/1

EP IRR 8 Parts e) and f) U/G Cable Replacement Quantities and Costs

Table 1: Cost (\$MM) and Quantity (kms) of Cable Replacement by Area per Year Between 2015-2018

Area		Year			
		2015	2016	2017	2018
BRZ	Cost (\$MM)	\$2.657	\$0.634	\$4.251	\$4.001
	Quantity (km)	1.97	0.5	5.09	7
	Unit Cost (\$MM/km)	\$1.349	\$1.268	\$0.835	\$0.572
PRZ	Cost (\$MM)	\$12.105	\$9.790	\$8.341	\$9.865
	Quantity (km)	33.3	29.6	20.5	22.3
	Unit Cost (\$MM/km)	\$0.364	\$0.331	\$0.407	\$0.442
ERZ	Cost (\$MM)	\$14.977	\$13.434	\$18.670	\$16.125
	Quantity (km)	21.69	16.75	19.12	33.64
	Unit Cost (\$MM/km)	\$0.691	\$0.802	\$0.976	\$0.479
HRZ	Cost (\$MM)	\$0.000	\$2.886	\$6.610	\$2.486
	Quantity (km)	0	17.28	14.5	10.57
	Unit Cost (\$MM/km)	\$0.000	\$0.167	\$0.456	\$0.235
GRZ	Cost (\$MM)	\$0.502	\$2.030	\$1.548	\$0.256
	Quantity (km)	1.49	5.27	6.6	0.43
	Unit Cost (\$MM/km)	\$0.337	\$0.385	\$0.235	\$0.595
Alectra Utilities	Cost (\$MM)	\$30.241	\$28.773	\$39.419	\$32.733
	Quantity (km)	58.45	69.40	65.81	73.94
	Unit Cost (\$MM/km)	\$0.517	\$0.415	\$0.599	\$0.443

- f) Alectra Utilities proposes to replace 675.38km at a total cost of \$236.33MM over 2020-2024 time period. Alectra Utilities provides the details by year in Table 2.

Table 2: Cost (\$MM) and Quantity (kms)

	2020	2021	2022	2023	2024
Cable Length (kms)	93.00	130.00	139.75	150.23	162.40
Cost	\$ 32.67	\$ 44.20	\$ 49.21	\$ 52.71	\$ 57.54


EP KT2.1 Page 3 Alectra DSP System Reliability Improvement Scenarios

Alectra Revision

Table 5: 10 Year Reliability Impact Projection for SAIDI and SAIFI for Scenarios Considered in the Long Term Planned System Renewal Capital Investment Analysis

Year	DSP - Planned SR Scenario		Partial Funding - Planned SR Scenario	
	SAIFI (Interruptions)	SAIDI (Hours)	SAIFI (Interruptions)	SAIDI (Hours)
2019	1.53	1.14	1.53	1.14
2020	1.34	0.98	1.57	1.19
2021	1.34	0.98	1.64	1.27
2022	1.34	0.98	1.71	1.36
2023	1.34	0.98	1.80	1.47
2024	1.34	0.98	1.89	1.58
2025	1.34	0.98	1.99	1.70
2026	1.34	0.98	2.11	1.83
2027	1.34	0.98	2.22	1.96
2028	1.34	0.98	2.32	2.08

Chart 6



ENERGY PROBE WORKBOOK PAGE 1 System Renewal Spending

EP Exhibit XX based on Staff IRR 104

Table 2 - Actual spending from 2012 to 2018, 2019 Q2 Forecast, 2020 – 2024 Plan (\$MM)

Category		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2012-2018	2020-2024
		Actual	Actual	Actual	Actual	Actual	Actual	Actual	Actual	Plan	Plan	Plan	Plan	Plan	Average	DSP Spend
System Renewal	All Assets															
	Powerstream	\$17.00	\$22.30	\$39.20	\$47.40	\$42.20	\$39.40	\$38.10	\$38.20	\$52.10	\$52.20	\$55.60	\$61.00	\$66.10	\$35.09	Higher
	Horizon	\$14.10	\$18.40	\$15.40	\$17.40	\$23.00	\$33.30	\$31.60	\$36.30	\$25.70	\$27.90	\$30.40	\$23.40	\$33.50	\$21.89	Higher
	Enersource	\$16.20	\$20.90	\$31.30	\$44.70	\$40.40	\$43.90	\$41.60	\$32.80	\$37.60	\$39.80	\$42.40	\$45.30	\$51.80	\$34.14	Higher
	Brampton	\$8.70	\$12.10	\$9.10	\$9.80	\$7.20	\$11.90	\$13.60	\$14.70	\$17.40	\$15.80	\$19.10	\$19.80	\$19.10	\$10.34	Lower
	Guelph	\$2.50	\$2.80	\$3.70	\$3.30	\$6.20	\$7.50	\$4.80	\$5.60	\$6.10	\$6.30	\$6.50	\$6.60	\$6.80	\$4.40	Lower
	Total	\$58.50	\$76.50	\$98.70	\$122.60	\$119.00	\$136.00	\$129.70	\$127.60	\$138.90	\$142.00	\$154.00	\$156.10	\$177.30	\$105.86	
U/G Repl. / Rehab	All Assets															
	Powerstream	\$3.00	\$19.60	\$21.00	\$19.30	\$14.50	\$12.00	\$13.50	\$11.80	\$19.30	\$23.00	\$26.60	\$29.10	\$32.30	\$14.70	Higher
	Horizon	\$0.00	\$1.60	\$0.90	\$0.30	\$4.70	\$7.50	\$6.60	\$7.80	\$6.30	\$7.10	\$7.40	\$7.40	\$8.10	\$3.09	Higher
	Enersource	\$5.10	\$6.50	\$16.90	\$15.00	\$13.40	\$18.70	\$16.10	\$9.80	\$16.80	\$24.00	\$26.70	\$29.30	\$30.90	\$13.10	Higher
	Brampton	\$3.50	\$4.00	\$3.90	\$2.70	\$0.60	\$4.30	\$4.00	\$3.80	\$4.30	\$5.70	\$6.30	\$7.20	\$8.40	\$3.29	Higher
	Guelph	\$2.10	\$2.60	\$3.20	\$1.30	\$3.20	\$4.00	\$0.60	\$0.00	\$1.30	\$1.30	\$1.30	\$1.30	\$1.40	\$2.43	Lower
	Subtotal	\$13.70	\$34.30	\$45.90	\$38.60	\$36.40	\$46.50	\$40.80	\$33.20	\$48.00	\$61.10	\$68.30	\$74.30	\$81.10	\$36.60	
Wood Pole Replacements	All Assets															
	Powerstream	\$4.10	\$4.90	\$5.90	\$6.20	\$4.40	\$4.00	\$4.60	\$4.90	\$5.60	\$5.90	\$6.10	\$6.40	\$6.40	\$4.87	Higher
	Horizon	\$0.90	\$0.70	\$1.20	\$1.30	\$1.60	\$0.80	\$1.90	\$1.90	\$2.30	\$2.50	\$2.80	\$3.10	\$3.30	\$1.20	Higher
	Enersource	\$0.60	\$0.30	\$0.50	\$7.30	\$9.60	\$8.40	\$7.70	\$6.40	\$4.50	\$3.90	\$3.50	\$3.10	\$2.70	\$4.91	Lower
	Brampton	\$1.10	\$1.00	\$1.20	\$0.10	\$0.60	\$1.30	\$0.80	\$0.70	\$0.90	\$2.10	\$2.80	\$2.90	\$3.00	\$0.87	Higher
	Guelph	\$0.30	\$0.10	\$0.20	\$1.50	\$2.20	\$2.60	\$2.70	\$1.40	\$1.20	\$1.20	\$1.20	\$1.30	\$1.30	\$1.37	Lower
	Subtotal	\$7.00	\$7.00	\$9.00	\$16.40	\$18.40	\$17.10	\$17.70	\$15.30	\$14.50	\$15.60	\$16.40	\$16.80	\$16.70	\$13.23	
Reactive & Emer. Projects	All Assets															
	Powerstream	\$7.90	\$8.20	\$8.70	\$11.20	\$8.40	\$9.40	\$11.30	\$9.50	\$9.40	\$9.60	\$9.80	\$10.00	\$10.10	\$9.30	Same
	Horizon	\$4.00	\$6.10	\$4.80	\$3.40	\$3.90	\$3.70	\$5.40	\$3.20	\$3.40	\$3.50	\$3.60	\$3.70	\$3.80	\$4.47	Same
	Enersource	\$0.30	\$0.30	\$0.40	\$0.30	\$0.30	\$0.40	\$0.20	\$3.20	\$3.40	\$3.50	\$3.60	\$3.60	\$3.70	\$0.31	Lower
	Brampton	\$1.10	\$2.40	\$0.80	\$1.60	\$1.90	\$1.90	\$3.20	\$1.50	\$1.50	\$1.60	\$1.60	\$1.60	\$1.70	\$1.84	Lower
	Guelph	\$0.00	\$0.00	\$0.00	\$0.10	\$0.20	\$0.20	\$0.50	\$1.10	\$1.00	\$1.00	\$1.00	\$1.10	\$1.10	\$0.14	Same
	Subtotal	\$13.40	\$17.00	\$14.70	\$16.70	\$14.60	\$15.60	\$20.50	\$18.60	\$18.80	\$19.20	\$19.60	\$20.00	\$20.40	\$16.07	
RATE ZONE TOTALS	All Assets															
	Powerstream	\$15.00	\$32.70	\$35.60	\$36.70	\$27.30	\$25.40	\$29.40	\$26.20	\$34.30	\$38.50	\$42.50	\$45.50	\$48.80	\$28.87	Higher
	Horizon	\$4.90	\$8.40	\$6.90	\$5.00	\$10.20	\$12.00	\$13.90	\$12.90	\$12.00	\$13.10	\$13.80	\$14.20	\$15.20	\$8.76	Higher
	Enersource	\$6.00	\$7.10	\$17.80	\$22.60	\$23.30	\$27.50	\$24.00	\$19.40	\$24.70	\$31.40	\$33.80	\$36.00	\$37.30	\$18.33	Higher
	Brampton	\$5.70	\$7.40	\$5.90	\$4.40	\$3.10	\$7.50	\$8.00	\$6.00	\$6.70	\$9.40	\$10.70	\$11.70	\$13.10	\$6.00	Higher
	Guelph	\$2.40	\$2.70	\$3.40	\$2.90	\$5.60	\$6.80	\$3.80	\$2.50	\$3.50	\$3.50	\$3.50	\$3.70	\$3.80	\$3.94	Same
	Subtotal	\$34.00	\$58.30	\$69.60	\$71.60	\$69.50	\$79.20	\$79.10	\$67.00	\$81.20	\$95.90	\$104.30	\$111.10	\$118.20	\$65.90	
Other System Renewal		\$24.50	\$18.20	\$29.10	\$51.00	\$49.50	\$56.80	\$50.60	\$60.60	\$57.70	\$46.10	\$49.70	\$45.00	\$59.10		

Chart 1




Chart 2





Chart 3



ENERGY PROBE WORKBOOK PAGE 3 DSP U/G Cable Projects JT2.5

JT2.5

Cable Replacement and Refurbishment by Rate zone

Table 1

Rate Zone	Method	2020	2021	2022	2023	2024	Total
BRZ	Cable Replacement (km)	8	13	12	11	20	64
ERZ	Cable Replacement (km)	36	38	45	75	38	232
PRZ	Cable Replacement (km)	26	51	53	46	74	250
GRZ	Cable Replacement (km)	3	12	14	7	12	48
HRZ	Cable Replacement (km)	20	16	16	11	18	81
Total (km)		93	130	140	150	162	675

Table 2

BRZ	Cable Injection (km)	56	35	45	53	57	246
ERZ	Cable Injection (km)	30	55	62	68	63	278
PRZ	Cable Injection (km)	93	117	130	156	188	684
GRZ	Cable Injection (km)	2	31	37	34	34	138
HRZ	Cable Injection (km)	32	32	31	34	34	163
Total (km)		213	270	305	345	376	1509
Total (km) UG CABLE		306	400	445	495	538	2184

ENERGY PROBE WORKBOOK PAGE 4 DSP Capital Plan

APPX 2-AB; JT1.6
Staff G-104

Table 1 Alectra Capital Plan 2019-2024

	F 2019	2020	2021	2022	2023	2024	5yr TOTAL
System Access	77.4	66.5	66.9	63.2	67.1	70.2	333.9
System Renewal	132.1	139	142	154	156.1	177.2	768.3
System Service	23.5	38	36.9	36	42.4	37.2	190.5
General Plant	26.2	39.4	34.4	35.1	30.2	24.7	163.8
Total CAPEX	259.2	282.9	280.2	288.3	295.8	309.3	1456.5
ICM Threshold	?	230	233	236	240	243	1182
Unfunded Capital	32.4	52.9	47.2	52.3	55.8	66.3	274.5

M- Factor Request

Table 2 Proposed M-Factor Capital Investments

JT 2.2 Q1	PILC Cable Switches	Switchgear	OH Line	Transformer	Total	SAIDI IMP	SAIFI IMP
BRZ	26						
ERZ	\$51.80						
PRZ	\$110.60						
BRZ	\$0.00						
GRZ	\$0.00						
Multiple	25						
Total	213.4						

Board Staff IRR G-4 M-Factor Funded System Renewal Projects PowerStream Example

Table 3 – Proposed M-Factor Funded Capital Investments for PowerStream Rate Zone (\$MM)

Project	Investment (\$MM)
Vaughan TS#4 Feeder Integration - Part 3	\$8.8
Residential Meter "ICON F" Meter Replacement Program - East	\$7.3
Install Two 27.6kV Ccts on 16th Ave from Hwy 404 to Woodbine Ave	\$5.5
Markham TS #4 Feeder Egress Part 3	\$4.9
Residential solar-storage	\$4.0
Rear Lot Supply Remediation - Royal Orchard - North	\$4.0
Install Double Cct Pole Line on Major Mackenzie - Hwy 27 to Huntington Rd	\$3.7
Bathurst Street Widening	\$3.4
Connection Cost Recovery Agreement (CCRA) – Midhurst TS – 15th Anniversary True-up	\$3.2
Cable Replacement - (V15) - Jardin Dr	\$2.9
Cable Replacement - (A02) - Steeplechase Ave	\$2.9
Cable Injection Project - (V17) - Langstaff - Keele - Rutherford - Dufferin, Vaughan	\$2.8
Install two additional 27.6 kV ccts on Hwy 7 from Jane St to Weston Rd	\$2.6
Rear Lot Supply Remediation - East of Queen St. to Eastern Ave./North of Greenway St.	\$2.6
Rear Lot Supply Remediation - Main Street / Unionville / Carlton	\$2.5
Cable Replacement Project - (V17) - Langstaff - Keele - Rutherford - Dufferin, Vaughan	\$2.4
New Barrie 20MVA Substation - Harvie	\$2.2
Rebuild 27.6 kV pole line for 4 Ccts on Warden Ave from Major Mack to Elgin Mills	\$2.2
Cable Replacement - (M33) - 16th Avenue and Village Parkway	\$2.1
27.6 kV Pole Line on 14th Ave from Hwy 48 to 9th Line	\$2.0
Aurora MS6 Expansion - (Year 1 of 2) - Design & Order Equipment	\$2.0
New Alliston 10MVA Substation - Industrial Parkway	\$1.9
Rear Lot - Gunn/Oakley Park/St.Vincent	\$1.8
Rear Lot - East of Queen Street/North of Mill Street	\$1.8
Cable Replacement – (Barrie) - Cook St and Steel St	\$1.7
Net Zero Energy Emissions	\$1.6
Two Ccts on Birchmount Rd from ROW to 14th Ave	\$1.6
Radial Supply Remediation/Conversion - 13.8 kV to 27.6 kV on Miller Ave	\$1.5
Cable Injection Project - (V50) - Hwy 7 - Kipling - Steeles - Hwy 27, Vaughan	\$1.5
Pole Line Installation Double Cct on Major Mack - Huntington Rd to Hwy 50	\$1.4
Install a new 4 ccts CNR yard overhead crossing on the south side of Hwy 7	\$1.4
Add one Additional 27.6 kV Cct on Major Mack Dr and 9th Line	\$1.3
Build double ccts 27.6kV pole line on 19th Ave between Leslie St and Bayview Ave	\$1.3
Cable Injection Project - (V25) - Major Mackenzie - Keele - Rutherford - Jane, Vaughan	\$1.3
Cable Injection Project - (V24) - Langstaff - Jane - Rutherford - Keele, Vaughan	\$1.3
Install 44kV & 13.8kV Bryne Drive	\$1.1
Cable Replacement - (Barrie) - Cundles Rd and Janine St	\$1.1
Cable Replacement Project - (V51) - Langstaff - Kipling - Hwy 7 - Hwy 27, Vaughan	\$1.0
Cable Replacement Project - (V24) - Langstaff - Jane - Rutherford - Keele, Vaughan	\$1.0
Fleet East 2024 Vehicle replacement - Cube Vans	\$0.7
Fleet East Unit # 75 83' Double Bucket	\$0.7
Cable Injection Project - (V51) - Langstaff - Kipling - Hwy 7 - Hwy 27, Vaughan	\$0.7
Fleet East Unit # 125, 83' Double Bucket	\$0.7
Install 2nd 27.6 kV Cct on Woodbine Ave from Elgin Mills Rd to 19th Ave	\$0.6

Exhibit 2 Tab1 Schedule 3 page 10 M-Factor Revenue Requirement

Calculation of M-Factor Funding and Riders

This section sets out Alectra Utilities' proposal for how the M-factor and resulting riders should be calculated during the 2020-2024 DSP period.

The cumulative 5-year capital revenue requirement associated with the M-factor funding request of \$286,036,835 is \$27,891,068. Table 6 below summarizes the M-factor capital revenue requirement for 2020 through 2024.

Table 6 – M-factor Capital Revenue Requirement (\$MM)

M-factor Revenue Requirement	2020	2021	2022	2023	2024	Total
Return on Rate base - Total	\$3.2	\$2.6	\$3.2	\$3.0	\$3.9	\$15.8
Amortization	\$1.9	\$2.0	\$2.1	\$2.8	\$2.4	\$11.2
Incremental Grossed Up PILs	(\$0.4)	(\$2.3)	(\$1.3)	(\$0.3)	(\$0.9)	(\$5.1)
Total	\$4.7	\$2.3	\$3.9	\$5.6	\$5.4	\$21.8

Alectra Utilities has calculated capital revenue requirement by rate zone based on the projects to be completed in each of the service areas. In the MAADs Application, Alectra Utilities identified that rates will not be harmonized until rate differences are immaterial.

JT 2.1 Rate Zone Distribution Bill Impacts

Table 1 M-Factor Bill Impact vs Distribution Bill Impact 2020-2024

Energource Rate Class	Unit	kWh	kW	2020			2021			2022			2023			2024		
				M-Factor Bill Impact ↓	Distribution Bill (Proposed)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %
Residential	KWh	750		\$ 0.12	\$ 25.77	0.47%	\$ 0.18	\$ 26.11	0.67%	\$ 0.34	\$ 26.58	1.27%	\$ 0.53	\$ 27.07	1.97%	\$ 0.91	\$ 27.75	3.27%
GS<50	KWh	2,000		\$ 0.35	\$ 74.67	0.47%	\$ 0.51	\$ 75.69	0.68%	\$ 0.99	\$ 77.03	1.28%	\$ 1.55	\$ 78.47	1.97%	\$ 2.64	\$ 80.45	3.28%
GS>50	KW	100,000	230	\$ 5.79	\$ 1,289.07	0.45%	\$ 8.44	\$ 1,305.97	0.65%	\$ 16.26	\$ 1,327.98	1.22%	\$ 25.53	\$ 1,351.73	1.89%	\$ 43.57	\$ 1,384.41	3.15%
GS>500	KW	400,000	2,250	\$ 36.01	\$ 7,875.43	0.46%	\$ 52.60	\$ 7,880.05	0.66%	\$ 101.25	\$ 8,117.79	1.25%	\$ 159.04	\$ 8,255.73	1.92%	\$ 271.37	\$ 8,469.30	3.20%
LU	KW	3,000,000	5,000	\$ 144.81	\$ 31,179.19	0.46%	\$ 211.49	\$ 31,599.85	0.67%	\$ 407.14	\$ 32,153.72	1.27%	\$ 639.51	\$ 32,748.61	1.95%	\$ 1,091.18	\$ 33,567.16	3.25%
Brampton Rate Class	Unit	kWh	kW	M-Factor Bill Impact ↓	Distribution Bill (Proposed)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %
Residential	KWh	750		\$ 0.31	\$ 25.43	1.21%	\$ 0.35	\$ 25.77	1.35%	\$ 0.57	\$ 26.28	2.15%	\$ 0.76	\$ 26.78	2.83%	\$ 0.87	\$ 27.20	3.21%
GS<50	KWh	2,000		\$ 0.74	\$ 64.32	1.18%	\$ 0.89	\$ 65.15	1.37%	\$ 1.39	\$ 66.62	2.10%	\$ 1.87	\$ 67.64	2.76%	\$ 2.16	\$ 69.67	3.13%
GS>50	KW	182,500	500	\$ 19.98	\$ 1,659.30	1.20%	\$ 22.56	\$ 1,681.13	1.35%	\$ 36.71	\$ 1,714.55	2.14%	\$ 49.34	\$ 1,745.71	2.92%	\$ 56.72	\$ 1,774.05	3.20%
GS>700	KW	627,216	1,432	\$ 75.66	\$ 6,242.61	1.21%	\$ 85.80	\$ 6,325.28	1.36%	\$ 139.00	\$ 6,461.90	2.15%	\$ 186.46	\$ 6,573.65	2.94%	\$ 214.61	\$ 6,677.18	3.22%
LU	KW	10,220,000	20,000	\$ 706.27	\$ 58,832.84	1.20%	\$ 800.89	\$ 59,604.58	1.34%	\$ 1,297.53	\$ 60,786.46	2.13%	\$ 1,740.54	\$ 61,922.94	2.81%	\$ 2,005.15	\$ 62,889.34	3.19%
Horizon Rate Class	Unit	kWh	kW	M-Factor Bill Impact ↓	Distribution Bill (Proposed)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %
Residential	KWh	750		\$ 0.72	\$ 27.30	0.81%	\$ 0.38	\$ 27.73	1.35%	\$ 0.65	\$ 28.25	1.99%	\$ 0.74	\$ 28.77	2.45%	\$ 0.92	\$ 29.32	3.17%
GS<50	KWh	2,000		\$ 0.53	\$ 85.59	0.80%	\$ 0.51	\$ 87.14	1.35%	\$ 1.35	\$ 89.27	1.97%	\$ 1.70	\$ 91.52	2.44%	\$ 2.23	\$ 93.85	3.15%
GS>50	KW	110,000	250	\$ 8.64	\$ 1,051.69	0.82%	\$ 14.75	\$ 1,070.47	1.38%	\$ 21.97	\$ 1,090.51	2.01%	\$ 27.59	\$ 1,109.10	2.49%	\$ 36.29	\$ 1,130.93	3.21%
LU	KW	2,555,000	5,000	\$ 260.33	\$ 32,114.72	0.81%	\$ 444.65	\$ 32,680.67	1.36%	\$ 652.19	\$ 33,284.82	1.99%	\$ 831.63	\$ 33,845.31	2.46%	\$ 1,093.88	\$ 34,503.31	3.17%
LUOA	KW	10,220,000	20,000	\$ 103.89	\$ 12,885.85	0.81%	\$ 177.45	\$ 13,111.80	1.35%	\$ 264.27	\$ 13,352.83	1.98%	\$ 331.89	\$ 13,576.52	2.44%	\$ 436.55	\$ 13,838.11	3.15%
PowerStream Rate Class	Unit	kWh	kW	M-Factor Bill Impact ↓	Distribution Bill (Proposed)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %
Residential	KWh	750		\$ 0.30	\$ 29.38	1.04%	\$ 0.47	\$ 29.88	1.59%	\$ 0.69	\$ 30.43	2.24%	\$ 1.15	\$ 31.25	3.68%	\$ 1.43	\$ 31.88	4.49%
GS<50	KWh	2,000		\$ 0.65	\$ 89.29	0.93%	\$ 1.01	\$ 90.46	1.43%	\$ 1.45	\$ 91.72	2.02%	\$ 2.44	\$ 93.54	3.32%	\$ 3.03	\$ 94.97	4.05%
GS>50	KW	80,000	250	\$ 11.81	\$ 1,275.35	0.93%	\$ 18.38	\$ 1,296.70	1.42%	\$ 26.39	\$ 1,319.67	2.00%	\$ 44.51	\$ 1,352.92	3.29%	\$ 56.31	\$ 1,379.05	4.01%
LU	KW	2,800,000	7,350	\$ 223.40	\$ 24,030.55	0.93%	\$ 347.70	\$ 24,434.50	1.42%	\$ 499.32	\$ 24,869.15	2.01%	\$ 842.15	\$ 25,498.40	3.30%	\$ 1,046.64	\$ 25,992.74	4.03%
Guelph Rate Class	Unit	kWh	kW	M-Factor Bill Impact ↓	Distribution Bill (Proposed)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %	M-Factor Bill Impact ↓	Distribution Bill (Forecast)	Bill Impact %
Residential	KWh	750		\$ 0.03	\$ 29.42	0.10%	\$ 0.10	\$ 29.84	0.32%	\$ 0.24	\$ 30.34	0.78%	\$ 0.38	\$ 30.85	1.23%	\$ 0.46	\$ 31.30	1.48%
GS<50	KWh	2,000		\$ 0.05	\$ 45.46	0.10%	\$ 0.15	\$ 46.11	0.32%	\$ 0.37	\$ 46.89	0.78%	\$ 0.59	\$ 47.68	1.24%	\$ 0.72	\$ 48.35	1.49%
GS>50	KW	169,500	500	\$ 1.64	\$ 1,599.60	0.10%	\$ 5.19	\$ 1,622.37	0.32%	\$ 12.74	\$ 1,649.38	0.77%	\$ 20.61	\$ 1,676.93	1.23%	\$ 26.13	\$ 1,701.37	1.48%
GS>1000	KW	489,100	1,000	\$ 3.81	\$ 3,689.01	0.10%	\$ 12.09	\$ 3,742.07	0.32%	\$ 29.69	\$ 3,804.98	0.78%	\$ 48.01	\$ 3,869.15	1.24%	\$ 58.53	\$ 3,926.10	1.49%
LU	KW	4,216,750	7,500	\$ 22.78	\$ 22,184.20	0.10%	\$ 72.78	\$ 22,501.45	0.32%	\$ 177.52	\$ 22,877.64	0.78%	\$ 287.07	\$ 23,261.40	1.23%	\$ 350.01	\$ 23,601.84	1.48%