Hydro One Networks Inc.

### EB-2019-0082

### **OEB Staff Compendium**

### Capital Expenditures and Transmission System Plan Issues

### Panel 1

### October 22, 2019

# **2** DESCRIPTION OF THE DATA

#### Introduction

#### Data Sets

Conductor data was organized into two principal sets:

- 1) Conductor condition assessment data. This data was provided in two data sets:
  - a) The first condition assessment data set (referred to hereafter as data set 1a) was from an earlier study conducted by Hydro One, i.e. Conductor End of Life Study dated August 2016. This set was used to perform exploratory data analyses as documented in Chapter 3.
  - b) The second condition assessment data set (referred to hereafter as data set 1b) was provided at a later date and consists of additional OCS 4 data as well as additional samples from "Long Test Reports". This set was used to derive condition assessment based Weibull models as documented in Chapter 4.
- 2) Replacements and in-service fleet demographic data. The replacement data was used to derive the replacement-based Weibull model as documented in Chapter 4. The in-service fleet demographic data was used as the basis for calculating projections of circuit-kilometers that will reach conditions that require replacements in the future, as documented in Chapter 5.

The remainder of this chapter provides a more detailed description of the above mentioned data sets. Note that the following section on conductor assessment data focuses on data set 1b as this is the data used to derive the condition-based hazard functions.

#### Conductor Assessment Data

The conductor assessment data set (1b) comprises 443 records extracted from test reports dated from 2001 to 2016, with one assessment performed per conductor. Of the 443 records, 420 records applied to aluminum conductor steel reinforced (ACSR) samples, therefore the analysis focused on ACSR conductors. Other conductor types may perform differently.

The assessment data provided for each conductor included (1) demographic description such as age, size and stranding, and (2) condition assessment including extent of rust, severity of rust, remaining zinc, torsional ductility, and tensile strength. From this data, the project team explored how the conductor overall condition and its constituent assessment factors are affected by independent variables including age, conductor stranding, conductor size, and corrosion zone categorization.

#### **General Discussion**

The conductor Condition Assessment (Score) data used are not from random samples.

For the replacements data, it is unclear whether all replacements were due to failures or lines reaching condition(s) that warrant replacements or some other reasons. Analysis results from such data can potentially be pessimistic. However, the similarity between results based on condition assessment data and results based on replacements data lead one to believe that such a concern is not necessarily warranted, especially when the commonalities between the two data sources in terms of time periods and circuits represented are limited (as discussed previously and shown in Figure 4-3).

both OCS 5 and OCS 4, and five circuits are represented by both OCS 5 (long) and OCS 4. Among these intersections, three circuits (C27P, D2L) are represented by all three subsets.



#### Figure 2-1

Venn Diagram Showing Circuits Associated with All Three Subsets of the Conductor Assessment Data, i.e. OCS 5, OCS 5 (long), and OCS 4, along with their Intersections

#### Replacements and In-Service Fleet Demographic Data

In addition to the assessment data, Hydro One provided historical replacement records. These replacement records span from January 1988 to January 2017 and the youngest age at replacement recorded was 41. A total of 126 replacement records were provided for 48 unique circuit designations and totaled 3,858 kilometers. Also provided was a list of in-service line sections and their ages representing 559 unique circuit designations. Figure 2-2 shows the cumulative installed conductor length by age, based on in-service ACSR fleet data as of October 2017.

1 possible.

2 MR. KEIZER: That's fine.

3 MR. SIDLOFSKY: So that will be JT1.1.

4 MR. WALSH: Next question is on 77, thank you. So I'd 5 understood that in Hydro One's response it is not possible 6 to refurbish or maintain deteriorated conductor through 7 repairs.

8 If Hydro One were to replace a deteriorated splicer 9 sleeve, is this considered to be a repair to the conductor 10 system or the conductor?

11 MS. JABLONSKY: It would be considered a repair.

12 MR. WALSH: A repair to the conductor?

MS. JABLONSKY: To the conductor. It is a component. MR. WALSH: Okay. So if you had the repair would it change the condition assessment for the conductor?

MS. JABLONSKY: If that was the only component that was deteriorated. But if we are looking at the ESL for the conductor, it is far greater than the ESL of the subcomponent of the conductor.

20 MR. WALSH: Okay, thank you. So in response to Staff 118, Hydro One stated that conductor-caused outages are 21 22 tracked at the conductor system level and not at the 23 conductor sub-components level. That's my understanding. 24 How does Hydro One differentiate between an outage 25 caused by -- or caused by deteriorated or improperly 26 installed splice or sleeve or connector on a conductor and 27 an outage caused by a deterioration of the actual 28 conductor?

ASAP Reporting Services Inc.

(416) 861-8720

MR. JESUS: We don't differentiate. If a conductor
 fails we treat it as a failure of the conductor.

MR. WALSH: Okay. Thank you. In Staff 119(b) you 3 4 stated that replacing a splice costs approximately 1/20th 5 as much as replacing the conductor section between splices. Given the significant cost differential between replacing 6 7 splices and replacing entire conductor systems, would it be 8 prudent for Hydro One to track conductor system failure 9 causes to validate whether conductor failure risk is 10 primarily attributable to splice failures or to general 11 conductor failures?

MR. JESUS: I think -- I think we need to recognize that a conductor is -- we take samples in sections of the conductor. So although it's failed in a small section, it has not addressed the overall condition of that conductor.

16 So, yes, a splice if it fails would be used to quickly 17 restore supply to our customers, but the overall condition 18 of that conductor has not changed. So we will -- we take samples of our sections. We don't normally go in there and 19 say there's a 200-kilometre line and replace the whole 20 thing. We look at the appropriate sections where we carry 21 out condition maintenance and condition assessments of 22 various sections and we determine whether or not the entire 23 24 conductor needs to be replaced. Splicing is just a 25 temporary fix, and it has not addressed the overall deterioration of that steel that's in the air. 26 27 MR. WALSH: Okay, thank you. Is loss of tensile 28 strength and loss of ductility for typical Hydro One

ASAP Reporting Services Inc.

(613) 564-2727

(416) 861-8720

21

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 119 Page 1 of 1

1		<b>OEB INTERROGATORY #119</b>
2		
3	Re	ference:
4	TS	P-03-03, ISD-SR-19
5		
6	Int	errogatory:
7 8	a)	Please confirm that the example in Figure 5 shows a failed splice rather than a failed conductor.
9 10	b)	Please compare the relative cost of replacing a sleeve or dead end fitting versus the
11	0)	cost of replacing 3 to 4 km of conductor (i.e. the distance between splices for typical
12		reel lengths).
13	- )	Des Hade Or and all and all a starting as had a free had a 's site of an above
14	C)	Does Hydro One preferentially replace entire reels of conductor in situations where the conductor system deterioration is focused at cleaves and/or doed and fittings?
15 16		the conductor system deterioration is focused at sieeves and/or dead end fittings?
17	Re	sponse:
18	a)	As stated in ISD SR-19, page 7, Figure 5 shows a fallen conductor as a result of an
19		insulator failure.
20		
21	b)	The cost of replacing a single conductor connector is approximately $1/20^{\text{th}}$ of the cost
22		of replacing 3 to 4 km of conductor.
23		
24	c)	Hydro One does not preferentially replace entire reels of conductor in situations
25		where a conductor system's deterioration is verified to be isolated to a conductor
26		connector.

Witness: Donna Jablonsky

Filed: 2019-03-21 EB-2019-0082 ISD SR-19 Page 4 of 15

1

3

4

12

13

14



**Figure 1 - Distribution of Overhead Conductor Condition** 

ACSR conductors consist of aluminum strands that surround galvanized steel strands, referred to as the core. Once the galvanized coating of the core wears off, for example as a result of weather or strand movement, the exposed steel strands corrode quickly, resulting in a loss of tensile strength or ductility. Deterioration of tensile strength results in a failure to hold required loads, while deterioration in ductility, makes the conductor brittle, making the suspended conductor which is moved by wind forces susceptible to cracking and breaking, as shown in Figure 2.

Witness: Donna Jablonsky



Filed: 2019-03-21 EB-2019-0082 ISD SR-19 Page 6 of 15

1

2 3

4



**Figure 4 - Fallen span of conductor** 





#### **Condition Assessment Methodology**

The following describes the parameters considered by Hydro One when performing condition assessment on ACSR conductors. These condition parameters are derived through 3<sup>rd</sup> party laboratory testing on conductor samples typically five meters in length. These five condition parameters are:

- 1) Extent of Rust Visual Inspection
- 2) Severity of Rust Visual Inspection
- 3) Remaining Zinc ASTM test
- 4) Torsional Ductility ASTM test
- 5) Tensile Strength ASTM test

Based on the test results, a 1 to 5 (best to worst) condition value was assigned for each test. Strand tests were translated to overall conductor state. Conductor overall condition is expressed as a weighted average, as shown in Table 2-1.

#### Table 2-1

Overall Conductor Condition: Weighted Average
(Source: Hydro One Conductor Condition Assessment Program)

Assessment (Test) Factor	Weight for Overall Condition
Extent of Rust	10%
Severity of Rust	10%
Remaining Zinc	10%
Torsional Ductility	30%
Tensile Strength	40%
Total	100%

#### **Conductor Condition Assessment Data**

The Hydro One Conductor Condition Assessment Program defines an overall condition score of 5 as equivalent to "end-of-life." Hydro One provided condition assessment data collected between January 2001 and December 2016.

Investigators separated conductor assessment data by Overall Condition Score (OCS). Of the initial 404 conductor samples, 28 samples were assessed as OCS 5 from 21 different circuits and 61 samples were assessed as OCS 4 from an additional 29 different circuits. The remaining 315 samples were assessed as OCS 1 through 3.

Hydro One provided an additional set of 16 ACSR condition assessments based on "Long Test Reports" for 12 unique circuits. These were reports of more extensive laboratory investigations of this added set of field samples. All of these samples were considered as OCS 5 providing another 9 different circuits not assessed as OCS 5 in the previous data set.

Considering all the available assessment data, samples from a total of 30 unique circuits were deemed to have an OCS of 5. Figure 2-1 illustrates the circuits that are represented by all three subsets of the conductor assessment data, namely OCS 5, OCS 5 (long), and OCS 4. Note that three circuits are represented by both OCS 5 and OCS 5 (long). Nine circuits are represented by

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 23 Page 3 of 3

e) As discussed in Exhibit B-1-1, TSP 2.2, the number of forced outages due to 1 conductor failures has improved over the past ten years while the outage duration has 2 been relatively stable over the same period. However, Hydro One aims to proactively 3 replace its deteriorated assets before they fail. As such, meaningful correlation 4 5 between failure rates and fleet/system condition is not available. As noted in Interrogatory I-01-OEB-120 part e) i) and discussed in See I-01-OEB-125, between 6 2008 and 2018, 36 delivery points were interrupted as a result of failures along the 7 1903 circuit-km of ACSR conductor planned for replacement. This corresponds to 8 0.02 delivery point interruptions per km. In comparison, the overall fleet of 29,107 9 circuit-km of conductor experienced 126 delivery point interruptions between 2008 10 and 2018. This corresponds to 0.004 delivery point interruptions per km. Therefore, 11 the 1903 circuit-km of conductor planned for refurbishment is presently 12 demonstrating five times more delivery point interruption when compared to the 13 overall fleet. 14

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 93 Page 1 of 2

#### **OEB INTERROGATORY #93**

1	<b>OEB INTERROGATORY #93</b>
2	
3	Reference:
4	TSP-03-01 p. 16 TSP-01-01 p. 43
5	
6	Interrogatory:
7	At the first reference above, Hydro One stated the following:
8	
9	Hydro One operates a condition assessment program that focuses on conductors beyond
10	50 years of age. Condition assessment results indicate that 13% of the conductor fleet is
11	at high risk. Despite a planned increased level of replacements when compared to
12	historical levels, the number of conductors beyond the ESL of 90 years is still increasing.
13	An overhead conductor failure can have severe reliability and safety consequences. If this
14	issue is not addressed in a proactive and timely manner, system and customer reliability
15	as well as safety will be placed at risk. Consequently, an increase in planned
16	replacements – even though it will not completely stop or reverse the trend in line
17	demographics – is required to maintain acceptable fleet condition and performance and to
18	avoid a sudden spike in future investments that would otherwise be required as a result of
19	deferred replacements.
20	At the second reference shows Under One stated the following
21	At the second reference above, Hydro One stated the following:
22	Lines Asset Monogoment
23	Hudro One's approach to asset management for its transmission line assets is shaped by
24	the nature of the specific line assets and their typical service lives. In particular
25 26	transmission conductors have an expected service life of 90 years. When a conductor fails
20 27	or based on its condition as confirmed by testing has been determined to have reached
27	end of life replacement is the only solution
20	ond of file, replacement is the only solution.
30	a) How common are system events caused by overhead conductor failures? To be more
31	specific, what percentage of Hydro One customer delivery point interruptions are
32	directly caused by spontaneous condition-related conductor failures?
33	
34	b) How many such events occur each year?

Witness: Bruno Jesus, Donna Jablonsky

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 93 Page 2 of 2

c) Please confirm that the stated percentages and event counts in Hydro One's response
 to parts a) and b) do not include conductor failures caused by external factors such as
 tree falls, vehicle contacts, lightning strikes, tornadoes/extreme wind fronts or
 extreme snow/ice loads that exceed design loads.

- d) Please provide a list of the most common conductor-related failure modes
  experienced by Hydro One (e.g. sagging into objects during hot weather power loads,
  heavy snow loads or heavy ice loads, blowing into other objects under extreme wind
  loads, phase to phase contacts under galloping conditions, splice/sleeve failures, dead
  end/termination compression hardware failures, etc.).
- 11

5

- e) Please provide an associated percentage of conductor failures per mode identified in
   part d).
- 14
- f) Please distinguish between conductor life and risk of failure versus sleeve (splice) or
   compression dead end failure.
- 17

#### 18 **Response:**

- a) Approximately 1% of delivery point interruptions are due to conductor failure.
- 20 21
  - b) There are on average 9 delivery point interruptions per year.
- c) The interruptions are related to conductor failure. The mechanism of failure is not
  - readily available.
- 24 25
- d) There are two major modes of failure with transmission conductors loss of tensile
   strength and loss of ductility. Isolated deficiencies such as surface corrosion bird caging, strand fraying or splice disconnects can be repaired and are not considered
   failure modes for the conductor system.
- 30
- e) Statistics on conductor modes of failure are not readily available.
- 32
- f) This differentiation is not available. As presented in Exhibit B-1-1, TSP Section 2.2,
   page 58, conductor caused outages are tracked at the conductor system level as a
   whole and not down to individual conductor components.

Witness: Bruno Jesus, Donna Jablonsky

Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 15 of 20

I

- look at these projects first for reprioritization. Failure to complete Low Priority
   projects is not expected to have significant detrimental effects on the system in
   the near term.
- 4

5

#### Table 5 - System Access - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SA-01	Connect New IAMGOLD Mine	24.9	0.0	0.0	0.0	0.0
SA-02	Horner TS: Build a Second 230/27.6kV Station	29.9	0.0	0.0	0.0	0.0
SA-03	Halton TS: Build a Second 230/27.6kV Station	8.0	17.7	6.0	0.0	0.0
SA-04	Connect Metrolinx Traction Substations	6.5	7.9	7.1	1.0	0.0
SA-05	Future Transmission Load Connection Plans	0.0	5.0	24.9	24.9	0.0
SA-06	6 Protection and Control Modifications for Distributed Generation		3.1	2.7	2.8	2.8
SA-07	Secondary Land Use Transmission Asset Modifications	55.1	15.0	13.9	15.6	3.9
	System Access Projects & Programs Less Than \$3M	27.6	9.4	8.5	7.8	9.2
Total Gross System Access Capital (\$M)			58.1	63.0	52.0	15.8
Less Capital Contributions (\$M)			(46.7)	(51.3)	(39.3)	(11.7)
Total Net System Access Capital (\$M)		24.8	11.3	11.7	12.7	4.1

6 7

#### Table 6 - System Renewal - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SR-01	Air Blast Circuit Breaker Replacement Projects	107.5	128.4	133.5	129.2	98.7
SR-02	Station Reinvestment Projects	107.0	125.4	120.6	87.9	53.9
SR-03	Bulk Station Transformer Replacement Projects	33.2	51.8	72.5	131.5	113.8
SR-04	Bulk Station Switchgear and Ancillary Equipment Replacement Projects	17.5	32.4	41.4	34.6	49.3
SR-05	Load Station Transformer Replacement Projects	91.2	132.3	129.4	178.5	200.0
SR-06	Load Station Switchgear and Ancillary Equipment Replacement Projects	19.2	30.8	47.5	58.4	77.0
SR-07	Protection and Automation Replacement Projects	6.7	8.6	12.7	12.2	21.7
SR-08	John Transformer Station Reinvestment Project	3.5	17.9	25.6	24.0	20.9
8						

Witness: Donna Jablonsky/Robert Reinmuller/Rob Berardi/Lincoln Frost-Hunt

Filed: 2002-03-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 16 of 20

SR-09	Transmission Station Demand and Spares and Targeted Assets	44.2	36.4	37.0	37.7	38.3
SR-10	Transformer Protection Replacement	3.8	0.0	0.0	0.0	0.0
SR-11	Legacy SONET System Replacement	4.1	26.0	27.6	28.1	28.1
SR-12	Telecom Performance Improvements	0.0	0.9	5.5	3.7	0.0
SR-13	ADSS Fibre Optic Cable Replacements	7.0	7.1	1.0	0.0	0.0
SR-14	Mobile Radio System Replacement	2.9	6.2	6.1	4.0	0.0
SR-15	Telecom Fibre IRU Agreement Renewals	0.0	2.8	8.5	2.6	1.5
SR-16	NERC CIP-014 Physical Security Implementation	18.0	18.0	18.0	0.0	0.0
SR-17	NERC CIP Transient Cyber Asset Project	3.5	0.0	0.0	0.0	0.0
SR-18	PSIT Cyber Equipment Replacement	1.0	5.0	7.7	7.0	3.4
SR-19	Transmission Line Refurbishment - End of Life ACSR, Copper Conductors & Structures	81.8	122.1	94.5	51.0	75.9
SR-20	Transmission Line Refurbishment - Near End of Life ACSR Conductor	ansmission Line Refurbishment - Near End of Life 62.2 63.4		111.7	117.8	137.7
SR-21	Wood Pole Structure Replacements	51.0	52.0	53.0	54.1	55.2
SR-22	Steel Structure Coating Program	11.4	21.8	22.3	22.7	23.2
SR-23	Tower Foundation Assess/Clean/Coat Program	11.8	22.3	22.8	23.3	23.7
SR-24	Transmission Line Shieldwire Replacement	12.3	12.6	12.8	13.1	13.4
SR-25	Transmission Line Insulator Replacement	68.3	69.7	66.3	67.6	68.9
SR-26	Transmission Line Emergency Restoration	9.6	9.8	10.0	10.2	10.4
SR-27	C5E/C7E Underground Cable Replacement	2.1	29.8	30.9	32.2	29.2
SR-28	OPGW Infrastructure Projects	5.3	7.5	2.2	6.2	9.7
SR-29	Physical Security ISL Application Replacement         5.0         1.1         0.0					0.0
System Renewal Projects & Programs Less Than \$3M		77.8	67.3	60.1	44.1	41.1
Total Gross System Renewal Capital (\$M)			1,109.2	1,181.1	1,181.5	1,194.9
	Less Capital Contributions (\$M)	(3.8)	(6.1)	(8.3)	(4.1)	(1.1)
Total N	et System Renewal Capital (\$M)	865.2	1,103.1	1,172.8	1,177.4	1,193.8

1 2

Table 7 - System Service - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SS-01	Lennox TS: Install 500kV Shunt Reactors	32.3	0.0	0.0	0.0	0.0
SS-02	Wataynikaneyap Line to Pickle Lake Connection	24.9	1.5	0.0	0.0	0.0

Witness: Donna Jablonsky/Robert Reinmuller/Rob Berardi/Lincoln Frost-Hunt

Filed: 2019-08-28 EB-2019-0082 Exhibit JT 1.11 Page 1 of 1

#### **UNDERTAKING - JT 1.11**

1 2

3

#### **Reference:**

- 4 I-07-SEC-016, part c)
- 5

#### 6 **Undertaking:**

To re-file previous undertakings, now un-redacting the previously redacted transmission
 related information.

9

#### 10 **Response:**

Attachments 1 to 8 contain Hydro One's response to the undertakings J2.4 and J7.01 that were filed in the EB-2017-0049 proceeding. These attachments are also referenced in the interrogatory response, I-07-SEC-016 filed in the current proceeding. Certain portions of the attachments contain information that has been redacted with a red box or a black box as follows:

16

Red box redactions contain information that relates to the unregulated business of
 Hydro One's affiliated companies and as such is not relevant and falls outside of
 the scope of the current proceeding. In the EB-2017-0049 proceeding, the Board
 considered the relevance of the red box redacted information and concluded that it
 has little probative value to the Board in assessing the ultimate proposal submitted
 by Hydro One in its application.

23

Black box redactions contain information that was prepared in contemplation of ٠ 24 Hydro One's 2017-2018 transmission rate application (EB-2016-0160). In most 25 instances, the information contains plans, strategies, or considerations that were 26 formulated in developing the 2017-2018 transmission rate application. It also 27 contains historical information and values that have been reproduced in the 28 current proceeding. The EB-2016-0160 proceeding has been adjudicated and the 29 Board rendered its revised decision on November 1, 2017. As such, the 30 information pertaining to the concluded proceeding is not relevant and has no 31 probative value to the Board in assessing Hydro One's proposals that are subject 32 of the current proceeding. 33 34

Clear backlog Sub-Tx lines have been maintained on a 6-8 year cycle at the expense of Dx lines



Nearly all Sub-Tx lines have been

#### Over one third of Dx feeders older than 8 years old



Current vegetation management spending insufficient to maintain all ROW on <8 year cycle

Source: Hydro One Asset Portfolio Document: Right-of-Way Management

hydro 🥝



### **Context: Where we are in the longer-term journey**

Completing Planning in preparation for Execution



Copyright © 2016 by The Boston Consulting Group, Inc. All rights reserved

### **Overall strategic narrative (I)**

#### Since privatization, Hydro One has embarked on a journey to becoming a best-in-class, customer-centric commercial organization. This is consistent with the 4 core principles of the RRFE<sup>1</sup>

- Customer focus: Responding to the needs and preferences of customers •
- Operational effectiveness: Meeting reliability and guality objectives while continuously driving productivity •
- Public policy responsiveness: Delivering on obligations mandated by government •
- Financial performance: Maintaining financial viability, sustaining operational effectiveness efforts

#### Our strategy translates these principles into our approach to

- Serving our customers •
- Forming our investment plans (for approval in rate filings) •
- Operating and managing the costs of our business
- ...while maintaining our strong commitment to Safety and the Environment

#### Serving our customers: Improving the end-to-end customer experience and satisfaction by addressing the unique needs of our four core segments. In the near-term we will focus on:

- Residential/Small Business: Improving first-call resolution, enhancing digital experience, redesigning the bill •
- Commercial & Industrial: Marketing energy conservation programs, improving first-call resolution ٠
- Large Distribution: Marketing energy conservation programs, better communicating unplanned outages •
- Transmission: Pro-active reporting on power quality and reliability, following through on commitments made ٠

### **Overall strategic narrative (II)**

#### Forming investment plans: Be responsible stewards of assets while taking a customer-centric approach

- Transmission: Sustain assets to meet reliability, risk, and power quality needs of customers
- Distribution: Transition to a modern, reliable grid through condition-based asset renewal and <u>targeted</u> enhancement programs to increase reliability and functionality with highest return on investment

#### Investment plans will be presented in 3 rate filings, each with unique objectives to consider:

- 2-year Transmission filing (May 2016):
  - Signal longer-term capital plan (5 year plan weighted to out-years, based on risk modeling)
  - Shift to RRFE<sup>1</sup> principles (e.g. consult with customers, incorporate productivity commitment)
- 5-year Distribution filing (May 2017):
  - Assess range of investment options through customer consultation
  - Align on incentive rate structure based on capital flexibility and fair distribution of productivity incentives
- 5-year Transmission filing (May 2018):
  - Secure investment plan previewed in May 2016 submission and replicate
  - Replicate incentive rate structure established in Distribution the prior year

# Operating and managing the costs of our business: Set efficiency targets informed by benchmarks and track through a performance management system

- · Efficiency program launched to both offset customer bill impacts and capture productivity benefits
- Unconstrained potential of ~\$200M (~50/50 OM&A vs. capital) with varying degrees of difficulty to capture
- · Execution already underway to build early momentum and drive impact near-term

### **Overall strategic narrative (III)**

#### Our strategy effectively balances shareholder returns and rate payer impacts over the next 5 years

- Total capital expected to grow to ~\$2B+ by 2021, resulting in rate base of ~\$22B (~5-6% growth)
- OM&A expected to remain flat to 2021, with cost pressures (e.g. inflation) offset by efficiency program impacts
- · Range of scenarios possible, depending on investment plan approval and efficiency potential realized
- Implies TSR and annual tariff increases of 2-3% for Distribution and 5-6% for Transmission

## As we continue our transition to a high performing culture, we have identified 10 core capabilities to successfully deliver on this plan and prepare us for future growth

- · Aspire to be best-in-class in 3 of them: customer service, regulatory, asset management
- While still early, already down path of developing and embedding improvements across 10 core capabilities
- · Assessment, development and acquisition of talent remains a critical focus

#### Achieving excellence in these areas prepares and earns us the right to grow beyond our core business



### Sensitivity of key economic drivers

Drivers	Starting point	Sensitivity	<b>Earnings impact</b> (\$M average annually, 2017-2021)
<b>Approved OM&amp;A</b> (% of investment plan)	100% of planned OM&A approved by OEB		
<b>Approved capital</b> (% of investment plan)	100% of planned Capital approved by OEB		
<b>Cost efficiencies</b> (\$M of OM&A efficiencies realized)	No OM&A efficiencies realized		
<b>Load</b> (% variance to forecast)	No variance to forecast		
Allowed return on deemed equity (% return on equity)	9.19% (2016 actual)		

Board 5 Year Strategy May6 - April28vFINAL.pptx





Copyright  $\otimes$  2016 by The Boston Consulting Group, Inc. All rights reserved.

 1. Based on last 5 years of Hydro One filings and recent filings from other Ontario distribution companies

 Board 5 Year Strategy May6 - April28vFINAL.pptx

 THE BOSTON CONSULTING GROUP



### Variety of appropriate delivery models considered

Delivery Activity	Traits	Owner-managed (OM) <sup>1</sup>	Engineering Procurement & Construction Mgmt	Design & Construct	Engineering Procurement & Construction	Build Own Operate / Build Own Operate Transfer
Overall	Typical value driver	System performance	System performance, schedule, cost	Schedule, system performance, cost	Schedule, cost, system performance	Moving scope off balance sheet
Engineering	Ability to influence design	High	High	Up to detailed design	Early design input only	Minimal
Procurement	Ability to influence procurement (e.g. free issue, strategic sourcing)	High	High	Medium	By exception	By exception
	Transfer of productivity risk	Low – in contracting model only	Low – in contracting model only	Medium	High – market dependent	High – market dependent
	Ability to influence constr. methodology	High	High	Medium	Early input only	Low
Construction	Ability to influence contract packaging	High	High	Low - by exception	Low	No
	Ability to influence schedule (e.g. early works, putting on hold)	Yes	Yes	Limited (claim implications)	Limited (claim implications)	Limited (claim implications)
O&M	Ownership of operations	Owner	Owner	Owner	Owner	Transfer over agreed time

Unlikely fit

1. Includes integrated team

Good to Great SCM 1 PreRead 9Feb2016.pptx

THE DOSTON CONSULTING GROUP 23

#### Draft—for discussion onlyPage 45 of 78 44

Copyright © 2014 by The Boston Consulting Group, Inc. All rights reserved.





### **Opportunity to shift delivery model in certain segments**



Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 1.4 Page 10 of 33

Hydro One's volume of replacement over the plan period is higher primarily due replacement criteria that were not included in the EPRI report. These criteria include obsolescence concerns, safety concerns (e.g. lack of or insufficient arc resistance rating), change in system conditions (e.g. short circuit level), polychlorinated biphenyl ("PCB") mitigation per regulatory requirements and integrated investments. Further details on the reasons can be found in Section 3.2.4 of the TSP.

- 7
- 8

#### **1.4.2.4 DERIVATION OF OVERHEAD CONDUCTOR HAZARD FUNCTION**

9 This report describes EPRI's efforts to develop a conductor hazard curve and its ESL
10 which can be used to project expected replacement needs for planning purposes.

11

The results of this study based on current condition assessment data and historical overhead conductor replacement data, indicate that ESL for overhead conductors in the Hydro One transmission system should be approximately 90 years. Hydro One's assigned ESL for overhead conductors was set at 70 years before this study. The new ESL resulting from this study does not affect the current business plan as identified replacements are not age based decisions, they are based on verified asset condition..

- 18
- 19

20

#### 1.4.2.5 OPERATING SPARE TRANSFORMERS REQUIREMENT ASSESSMENT

The purpose of this study is to verify that Hydro One's spare transformer requirements 21 are appropriate and consistent with industry best practices. Hydro One uses the Markov 22 Model to determine the appropriate number of spare transformers required to ensure 23 continuity of electricity supply to customers, safety and reliability. The Markov Model 24 takes into consideration the probability of failure, carrying costs and procurement lead 25 time to determine the most cost-effective number of spares to be kept in inventory. EPRI 26 has developed analytics to optimize the power transformer spares practice which was 27 compared with Hydro One Markov modeling. 28

Witness: Donna Jablonsky

Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.2 Page 18 of 28

utilization of the relay fleet while managing its associated risk. For the time being,
Hydro One will maintain the current ESL for all solid state and microprocessor-based
relays systems as 25 years and 20 years, respectively as described in Section 2.2.

4

Specific integrated investments that include the replacement of protection system over
the next five years are further described in ISDs SR-01, SR-02, SR-03, SR-04, SR-05,
SR-06, SR-07, and SR-08.

8

9

#### 3.2.4.9 Degradation Rates of Steel Tower Coating Systems

The EPRI study supports Hydro One's current investment plan by validating the existing approach and assumptions. Using the findings of the study, Hydro One continues to focus on coating steel structures in C4 and C5 corrosion zones whose age has reached 35-75 years of age.

14

#### 15 **3.2.4.10** Derivation of Overhead Conductor Hazard Function

The purpose of this EPRI study is to provide valuable insights into fleet mean life expectancy from analysis of historical condition assessment and replacement data pertaining to overhead conductors. In particular, this study presents EPRI's analysis to develop a conductor hazard curve and its ESL which can be used to project expected replacement needs for planning purposes.

21

As a result of the study, Hydro One has changed its conductor ESL from 70 to 90 years. The EPRI report forecasts that 3,920 circuit km of the ACSR conductor fleet will be at End-Of-Life ("EOL") or near EOL condition by 2024.<sup>3</sup> This forecast of ACSR conductor condition aligns with the fact that by the end of 2024, about 13% or 3,653 circuit km of the overall conductor fleet will reach or exceed their ESL without further replacements.

<sup>&</sup>lt;sup>3</sup> TSP Section 1.4 Attachment 4 - Derivation of Overhead Conductor Hazard Function, section 5-3, p 93.

# **1** INTRODUCTION AND BACKGROUND

#### Introduction

Hydro One Networks Inc., like many utilities, is striving to maintain the reliability of its transmission network while controlling maintenance, repair and replacement costs. Aging equipment, more stringent operating requirements, financial constraints and retiring expertise have made the management of transmission line assets increasingly challenging.

To address these challenges, Hydro One is reviewing its maintenance and replacement practices to ensure they are underpinned by sound evidence. This includes the use of condition and risked-based maintenance and replacement scheduling using advanced analytics-based techniques. Understanding the condition and remaining life of conductors would help transmission asset managers make better decisions about conductor maintenance, repair, and replacement.

As part of this asset management effort, Hydro One asked EPRI to investigate available Hydro One overhead transmission line conductor demographic and condition data and determine what insights could be obtained to support asset management decisions.

This report describes the EPRI investigation.

#### Background

Hydro One's service territory is the size of Texas plus California, and driving across it can take three days. Most of the province's population is concentrated along the southeastern border far from hydroelectric generating stations. Long transmission circuits as well as widely distributed substations are required to deliver power over these distances. These transmission and distribution assets are exposed to environmental stresses, including severe weather and temperature variations that can degrade equipment over time.

Hydro One defines Expected Service Life (ESL) as the average age in years that an asset can be expected to operate under normal system conditions. Half of the assets are expected to operate beyond this ESL. Hydro One also defines End of Life (EOL) as the state of having a high likelihood of failure, or loss of an asset's ability to provide the intended functionality as determined through diagnostic data, wherein the failure or loss of functionality would cause unacceptable consequences. EOL is always determined by condition assessment.

One asset of interest, and the focus of this report, is Hydro One's overhead transmission line conductor fleet. Hydro One's estimated ESL for conductors is approximately age 70. Based on past experience, condition assessments are not conducted before 50 years of age. As shown in Figure 1-1, many of the fleet conductor assets are beyond their presently used ESL.

Filed: 2019-08-28 EB-2019-0082 Exhibit JT 1.1 Page 1 of 2

#### **UNDERTAKING - JT 1.1**

1 2

#### 3 **Reference:**

4 I-01-OEB-062

5

#### 6 **Undertaking:**

To confirm that Hydro One asserts that an analysis based upon data set that includes
 removals for all causes, including failure and non-failure replacements, and one that does
 not include non-failure removals, would generate identical condition-based end of life
 results.

#### 12 **Response:**

Hydro One has provided an update to Interrogatory I-1-OEB-62 found in Attachment 1 to align with EPRI's guidance regarding this Undertaking and the analysis it conducted.

15

11

The analysis referenced in the undertaking would generate a hazard function not a condition-based end of life result.

18

EPRI has advised that the hazard function (or Weibull model) derived from failure and non-failure data would not be identical to the hazard function derived from failure only data. Any similarity between the two functions would be dependent upon the proportion of failure removals to non-failure removals in the data set used to derive the function. Therefore, if a large portion of the removals were for failures and only a small portion were due to non-failures, the two functions would tend to converge i.e. they would be similar.

26

Given an understanding for the basis for transformer removals, it is reasonable to 27 consider the removal hazard function as a good proxy for the failure hazard function, 28 especially for younger transformers (younger transformers are rarely replaced except for 29 failure). Therefore, it is expected that if the data allowed that only failure data were used, 30 the cumulative hazard function would look very similar to the one presented in Region 1 31 of Figure 1 below (red line), which was derived from Hydro One's removal data. In this 32 region, the cumulative hazard function derived from the Weibull model (red line) 33 matches the cumulative hazard function calculated from the actual event data (black line). 34 In Region 2 the cumulative hazard function derived from Hydro One's removal data 35 (black line) is much steeper than the cumulative hazard function derived from the 36

Filed: 2019-08-28 EB-2019-0082 Exhibit JT 1.1 Page 2 of 2

Weibull model (red line). EPRI's report<sup>1</sup> proposed that this may be due to either a "failure process that is more dominant in older units" or a "result of discretionary replacement decisions" or a combination of both. Hydro One does not run its transformer fleet to failure as this would be imprudent and would elevate safety and system risk. Rather Hydro One replaces transformers before failure driven by condition criteria that demonstrate the transformer has reached end of life.



Figure 1: Comparison of Model and Sample Cumulative Hazard Functions 115 kV
 Transformers - Exhibit B-1-1 TSP 1.4 Attachment 2, Figure 2-4 on page 2-6.

<sup>&</sup>lt;sup>1</sup> Exhibit B-1-1 TSP Section 1.4 Attachment 2 page 2-6

Witness: Donna Jablonsky

Filed: 2019-08-28 EB-2019-0082 Exhibit JT-1.1 Attachment 1 Page 1 of 3

Updated: 2019-08-28 EB-2019-0082 Exhibit I Tab 01 Schedule 62 Page 1 of 3

#### **OEB INTERROGATORY #62**

2       Reference:         3       TSP-01-04-02 p. 21 & 25TSP-01-04-03 p. 21         5       Interrogatory:         7       At the first reference above, EPRI stated the following:         8       However, removed from service data is more abundant and consist of 419 transformers         9       However, removed from service data is more abundant and consist of 419 transformers         9       However, removed from service data is more abundant and consist of 419 transformers         9       within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in         10       data, therefore failures and discretionary replacements cannot be distinguished. Since the         11       reason is not supplied a time-to-event model can be developed where the event, rather         12       than failure, is removal.         13       At the second reference above, EPRI stated the following:         14       The removal rate model is verified by comparing the sample cumulative hazard function         16       Fitting the data to the Model         18       The removal rate model is verified by comparing the sample cumulative hazard functions         19       bazard functions created from the Weibull model. There are cumulative hazard functions         10       carculate the median         11       cumulative hazard rate and the corresponding 95% credibility interval.     <	1	<b>OEB INTERROGATORY #62</b>
<ul> <li>Reference:</li> <li>TSP-01-04-02 p. 21 &amp; 25TSP-01-04-03 p. 21</li> <li>Interrogatory:</li> <li>At the first reference above, EPRI stated the following:</li> <li>However, removed from service data is more abundant and consist of 419 transformers within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in data, therefore failures and discretionary replacements cannot be distinguished. Since the reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	2	
<ul> <li>TSP-01-04-02 p. 21 &amp; 25TSP-01-04-03 p. 21</li> <li>Interrogatory: <ul> <li>At the first reference above, EPRI stated the following:</li> </ul> </li> <li>However, removed from service data is more abundant and consist of 419 transformers within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in data, therefore failures and discretionary replacements cannot be distinguished. Since the reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	3	Reference:
<ul> <li>Interrogatory:</li> <li>At the first reference above, EPRI stated the following:</li> <li>However, removed from service data is more abundant and consist of 419 transformers</li> <li>within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in</li> <li>data, therefore failures and discretionary replacements cannot be distinguished. Since the</li> <li>reason is not supplied a time-to-event model can be developed where the event, rather</li> <li>than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	4	TSP-01-04-02 p. 21 & 25TSP-01-04-03 p. 21
<ul> <li>Interrogatory: <ul> <li>At the first reference above, EPRI stated the following:</li> </ul> </li> <li>However, removed from service data is more abundant and consist of 419 transformers within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in data, therefore failures and discretionary replacements cannot be distinguished. Since the reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> </ul>	5	
<ul> <li>At the first reference above, EPRI stated the following:</li> <li>However, removed from service data is more abundant and consist of 419 transformers</li> <li>within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in</li> <li>data, therefore failures and discretionary replacements cannot be distinguished. Since the</li> <li>reason is not supplied a time-to-event model can be developed where the event, rather</li> <li>than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removal from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	6	Interrogatory:
<ul> <li><sup>8</sup></li> <li><sup>9</sup> However, removed from service data is more abundant and consist of 419 transformers</li> <li><sup>9</sup> within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in</li> <li><sup>11</sup> data, therefore failures and discretionary replacements cannot be distinguished. Since the</li> <li><sup>12</sup> reason is not supplied a time-to-event model can be developed where the event, rather</li> <li><sup>14</sup> that failure, is removal.</li> <li><sup>14</sup> At the second reference above, EPRI stated the following:</li> <li><sup>16</sup> Fitting the data to the Model</li> <li><sup>17</sup> The removal rate model is verified by comparing the sample cumulative hazard function</li> <li><sup>18</sup> calculated from the actual event data (previously described) against the cumulative</li> <li><sup>19</sup> hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li><sup>10</sup> for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li><sup>12</sup> cumulative hazard rate and the corresponding 95% credibility interval.</li> <li><sup>13</sup> At the third reference above, EPRI stated the following:</li> <li><sup>14</sup> At the third reference above, EPRI stated the following:</li> <li><sup>15</sup> at the third reference above, EPRI stated the following:</li> <li><sup>16</sup> At the third reference above, EPRI stated the following:</li> <li><sup>17</sup> At the third reference above, EPRI stated the following:</li> <li><sup>18</sup> At the third reference above, EPRI stated the following:</li> <li><sup>19</sup> At the third reference above, EPRI stated the following:</li> <li><sup>10</sup> At the third reference above, EPRI stated the following:</li> <li><sup>13</sup> At the third reference above, EPRI stated the following:</li> <li><sup>14</sup> At the third reference above, EPRI stated the following:</li> <li><sup>15</sup> At the third reference above, EPRI stated the following:</li> <li><sup>16</sup> At the third reference above, EPRI stated the following:</li> <li><sup>17</sup> At the third reference above, EPRI stated the following:</li> <li><sup>18</sup> At the third reference above, EPRI stated the following:&lt;</li></ul>	7	At the first reference above, EPRI stated the following:
<ul> <li>However, removed from service data is more abundant and consist of 419 transformers</li> <li>within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in</li> <li>data, therefore failures and discretionary replacements cannot be distinguished. Since the</li> <li>reason is not supplied a time-to-event model can be developed where the event, rather</li> <li>than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	8	
<ul> <li>within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in data, therefore failures and discretionary replacements cannot be distinguished. Since the reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	9	However, removed from service data is more abundant and consist of 419 transformers
<ul> <li>data, therefore failures and discretionary replacements cannot be distinguished. Since the</li> <li>reason is not supplied a time-to-event model can be developed where the event, rather</li> <li>than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	10	within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in
<ul> <li>reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions created from the Weibull model. There are cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	11	data, therefore failures and discretionary replacements cannot be distinguished. Since the
<ul> <li>than failure, is removal.</li> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	12	reason is not supplied a time-to-event model can be developed where the event, rather
<ul> <li>At the second reference above, EPRI stated the following:</li> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	13	than failure, is removal.
At the second reference above, EPRI stated the following: <b>Fitting the data to the Model</b> The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions created from the Weibull model. There are cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval. At the third reference above, EPRI stated the following: <b>Removed from Service Data</b> The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided. a) Please confirm that the term "removals" is not synonymous with the term "failures".	14	
<ul> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	15	At the second reference above, EPRI stated the following:
<ul> <li>Fitting the data to the Model</li> <li>The removal rate model is verified by comparing the sample cumulative hazard function</li> <li>calculated from the actual event data (previously described) against the cumulative</li> <li>hazard functions created from the Weibull model. There are cumulative hazard functions</li> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median</li> <li>cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li><b>Removed from Service Data</b></li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	16	
<ul> <li>The removal rate model is verified by comparing the sample cumulative hazard function calculated from the actual event data (previously described) against the cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li><b>Removed from Service Data</b></li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	17	Fitting the data to the Model
<ul> <li>calculated from the actual event data (previously described) against the cumulative hazard functions created from the Weibull model. There are cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li><b>Removed from Service Data</b></li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	18	The removal rate model is verified by comparing the sample cumulative hazard function
<ul> <li>hazard functions created from the Weibull model. There are cumulative hazard functions for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li><b>Removed from Service Data</b></li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	19	calculated from the actual event data (previously described) against the cumulative
<ul> <li>for each MCMC observation. For each age from 0 to 100, we calculate the median cumulative hazard rate and the corresponding 95% credibility interval.</li> <li>At the third reference above, EPRI stated the following:</li> <li><b>Removed from Service Data</b></li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	20	hazard functions created from the Weibull model. There are cumulative hazard functions
<ul> <li><sup>22</sup> cumulative hazard rate and the corresponding 95% credibility interval.</li> <li><sup>23</sup> At the third reference above, EPRI stated the following:</li> <li><sup>25</sup> <b>Removed from Service Data</b></li> <li><sup>27</sup> The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li><sup>29</sup> a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li><sup>31</sup> b) Demovals are being used to create a "begard" aurual even though the reasons for the</li> </ul>	21	for each MCMC observation. For each age from 0 to 100, we calculate the median
<ul> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> </ul>	22	cumulative hazard rate and the corresponding 95% credibility interval.
<ul> <li>At the third reference above, EPRI stated the following:</li> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>b) Demovals are being used to create a "begard" sume even though the reasons for the</li> </ul>	23	
<ul> <li>Removed from Service Data</li> <li>The removed from service data provided by Hydro One consists of 1218 circuit breakers as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>b) Demovals are being used to create a "begard" sume over though the reasons for the</li> </ul>	24	At the third reference above, EPRI stated the following:
<ul> <li>26 Removed from Service Data</li> <li>27 The removed from service data provided by Hydro One consists of 1218 circuit breakers</li> <li>28 as of third quarter 2017. No reason for removal was provided.</li> <li>29</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>31</li> <li>b) Demovals are being used to create a "begard" suma even though the reasons for the</li> </ul>	25	Demons d from Service Dete
<ul> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>b) Demovals are being used to create a "begard" sume even though the reasons for the</li> </ul>	26	Removed from Service Data
<ul> <li>as of third quarter 2017. No reason for removal was provided.</li> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>b) Demovals are being used to create a "begard" summer even though the reasons for the</li> </ul>	27	The removed from service data provided by Hydro One consists of 1218 circuit breakers
<ul> <li>a) Please confirm that the term "removals" is not synonymous with the term "failures".</li> <li>b) Removals are being used to create a "bagard" sumula over though the reasons for the</li> </ul>	28	as of third quarter 2017. No reason for removal was provided.
<ul> <li>a) Please communitatione term removals is not synonymous with the term randres .</li> <li>b) Demovals are being used to create a "begard" sumula over though the reasons for the</li> </ul>	29	a) Places confirm that the term "removals" is not supervised with the term "failures"
b) Demovals are being used to greate a "begard" surve even though the reasons for the	30	a) Flease comminum that the term removals is not synonymous with the term randres.
	31	b) Demovals are being used to create a "bazard" surve, even though the reasons for the
removals have not been categorized. Is this methodology appropriate as EDDI is	32 22	removals have not been categorized. Is this methodology appropriate as EDDI is
applying it here?	24	applying it here?

Filed: 2019-08-28 EB-2019-0082 Exhibit I Tab 01 Schedule62 Page 2 of 3

c) A true "Hazard Rate" implies an age-related likelihood of failure. Please confirm that 1 the supplied input data does not support the determination of a true Hazard Rate for 2 these assets. 3

4

d) Based on the above references, it appears that EPRI has used uncategorized asset 5 removal data in its derivation of Hazard Rates because that was the data set provided 6 by Hydro One, rather than because the data is fit for purpose. Does the lack of 7 categorization of retirement causes in the data supplied to EPRI potentially invalidate the conclusions drawn in the both the "Derivation of Circuit Breaker Hazard Functions" report and the "Derivation of Transmission Substation Transformer Hazard Functions" report?

11 12

8

9

10

#### **Response:** 13

a) Confirmed. The term "removals" is not synonymous with the term "failures." 14 Removals may include but are not limited to "failures". 15

16

b) Yes. The methodology is mathematically appropriate for developing a removal 17 hazard curve. See the further discussions in c) and d) below. 18

19

c) Confirmed, the supplied data was for removals for any reason and therefore may have 20 included both failure and non-failure related data. No, a hazard rate does not need to 21 be restricted to failures only. 22

23 24

25

26

27

28

"Hazard rate" is a statistical term used as one way to mathematically describe the functional relationship between the waiting time and the occurrence of a well-defined event. The analysis of such relationships often is called time-to-event analysis. The event depends on the focus of the study. In the EPRI analysis under discussion, the defined event is removal for any reason. Where the hazard rate of interest is that for failure, the terms hazard rate and failure rate are often used interchangeably.

29 30

d) No, the asset removal data EPRI analyzed does not invalidate the conclusions 31 presented. It is reasonable to believe that, given the expenses involved, removals of 32 transmission assets were done for well-considered reasons such as (1) actual failure, 33 (2) increased risk of failure beyond acceptable limits or (3) unacceptable maintenance 34 costs. There is very little reason for removing from service a young transformer other 35 than (1) or (2) above. Therefore, it is reasonable to consider the removal hazard rate 36 as a good proxy for the failure hazard rate, especially for younger transformers. 37

Witness: Donna Jablonsky

Updated: 2019-08-28 EB-2019-0082 Exhibit I Tab 01 Schedule 62 Page 3 of 3

1

For older transformers, the replacement rate was found to be much steeper. EPRI's report<sup>1</sup> proposed that this may be due to either a "failure process that is more dominant in older units" or a "result of discretionary replacement decisions" or a combination of both. Hydro One does not run its transformer fleet to failure as this would be imprudent and would elevate safety and system risk. Rather Hydro One replaces transformers before failure driven by condition criteria that demonstrate the transformer has reached end of life.

<sup>&</sup>lt;sup>1</sup> Exhibit B-1-1 TSP Section 1.4 Attachment 2 page 2-6

Witness:Donna Jablonsky



#### Figure 2-4 Comparison of Model and Sample Cumulative Hazard Functions 115 kV Transformers

Figure 2-4 for the 115 kV transformer group show two regions with different levels of agreement between the red and black lines. A good Weibull model fit for most of the life (Region 1) and a much steeper replacement rate (black line) than provided by the Weibull model in later life (Region 2). However, younger power transformers are rarely replaced except for failure. Therefore, Region 1 may be a reasonable model for the failure hazard rate. The break points between the two regions could indicate the following:

- The onset of a failure process that is more dominant in older units.
- The result of discretionary replacement decisions.
- Some combination of both failure process and discretionary replacement.

Since the reasons for removal are not noted, failures and discretionary replacements cannot be distinguished.

#### **Modeling Assumptions**

- The starting data is complete and contains all removals and in-service units for the period within 1981 through first quarter 2017.
- The criteria for removal have been constant over the historical period being analyzed.
- Future criteria for removals will be the same as in the past.

# **2** REMOVAL RATE MODELING

#### **Data Review**

Originally Hydro One sought to obtain a year-by-year prediction of the expected number of transmission substation transformer failures for the next five years. However, the supplied failure data appeared sparse in relation to the number of transformer-years experienced and consequently the derivation would not provide a usable failure hazard rate. The failure data provided for the period of 2006 through 2016 consists of 42 failures. Confidence limits for any derived hazard rate would be large using this supplied failure data as noted in Figure 2-1. For example, for the failure rate of derived from this data could be anywhere between approximately 0.6% and 2% for a 60 year old transformer using a 95% confidence band. For a 40 year old transformer the failure rate could be anywhere between approximately 0.3% and 1%.



#### Figure 2-1 Failure Hazard Rate Derived from Spares Data

However, removed from service data is more abundant and consist of 419 transformers within a period of 1981 to first quarter 2017. The reasons for removal are not supplied in data, therefore failures and discretionary replacements cannot be distinguished. Since the reason is not supplied a time-to-event model can be developed where the event, rather than failure, is removal.

Figure 2-2 show the Service Ages of the 115 kV transformer group using data from both the removed from service (left) and failures (right). In the Service Ages plot, the horizontal axis is the age of the transformers. Each horizontal line represents a distinct transformer denoted by an

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 3.2 Page 13 of 28

#### **3.2.4.1** Operating Spare Transformers Requirement Assessment

This study found that the results of Hydro One's Markov model analysis (used to determine the appropriate number of spare transformers), aligns with the independent and alternative analysis from the third-party expert, Electric Power Research Institute ("EPRI"). Hydro One continues to take steps to achieve and maintain the required quantity of operating spare transformers to ensure reliability and improve cost efficiency.

7

8

#### **3.2.4.2** Derivation of Transformer Hazard Functions

9 This study confirmed that Hydro One's pacing approach to the replacement of 10 transformers is appropriate. This pacing of transformer replacement has been reflected in 11 the following ISDs: SR-02 (Station Reinvestment Projects), SR-03 (Bulk Station 12 Transformer Replacement Projects), SR-05 (Load Station Transformer Replacement 13 Projects), and SR-08 (John Transformer Station Reinvestment).

14

#### 15 **3.2.4.3 Derivation of Circuit Breaker Hazard Function**

This study was performed by EPRI and describes EPRI's efforts to (i) model and develop 16 circuit breaker removal rates from historical replacement records and (ii) apply them to 17 forecast the number of circuit breakers expected to require replacement based on past 18 practices. EPRI has developed a methodology using advanced statistical techniques for 19 analyzing circuit breaker historical removals and applied it to the Hydro One's circuit 20 breaker fleet. Using Hydro One's circuit breaker retirement data, EPRI modeled Hydro 21 One's circuit breaker removals and has forecast probable future removal rates. The study 22 confirmed that Hydro One is replacing younger circuit breakers at a rate expected from 23 the statistical model. However, older circuit breakers are being replaced at a quicker rate 24 than expected. The reason for faster paced replacement is due to replacement criteria that 25 are not included in the EPRI report as explained below. 26

27

Hydro One plans to address 638 breakers over the planning period. This includes the removal of 49 breakers as a result of station decommissioning and reconfiguration as well

#### Witness: Bruno Jesus/Donna Jablonsky/Robert Reinmuller
Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 15 of 20

- look at these projects first for reprioritization. Failure to complete Low Priority
   projects is not expected to have significant detrimental effects on the system in
   the near term.
- 4

5

### Table 5 - System Access - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SA-01	Connect New IAMGOLD Mine	24.9	0.0	0.0	0.0	0.0
SA-02	Horner TS: Build a Second 230/27.6kV Station	29.9	0.0	0.0	0.0	0.0
SA-03	Halton TS: Build a Second 230/27.6kV Station	8.0	17.7	6.0	0.0	0.0
SA-04	Connect Metrolinx Traction Substations	6.5	7.9	7.1	1.0	0.0
SA-05	Future Transmission Load Connection Plans	0.0	5.0	24.9	24.9	0.0
SA-06	Protection and Control Modifications for Distributed Generation	3.8	3.1	2.7	2.8	2.8
SA-07	Secondary Land Use Transmission Asset Modifications	55.1	15.0	13.9	15.6	3.9
	System Access Projects & Programs Less Than \$3M	27.6	9.4	8.5	7.8	9.2
Total G	ross System Access Capital (\$M)	155.7	58.1	63.0	52.0	15.8
	Less Capital Contributions (\$M)	(130.9)	(46.7)	(51.3)	(39.3)	(11.7)
Total Ne	et System Access Capital (\$M)	24.8	11.3	11.7	12.7	4.1

6 7

#### Table 6 - System Renewal - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SR-01	Air Blast Circuit Breaker Replacement Projects	107.5	128.4	133.5	129.2	98.7
SR-02	Station Reinvestment Projects	107.0	125.4	120.6	87.9	53.9
SR-03	Bulk Station Transformer Replacement Projects	33.2	51.8	72.5	131.5	113.8
SR-04	Bulk Station Switchgear and Ancillary Equipment Replacement Projects	17.5	32.4	41.4	34.6	49.3
SR-05	Load Station Transformer Replacement Projects	91.2	132.3	129.4	178.5	200.0
SR-06	Load Station Switchgear and Ancillary Equipment Replacement Projects	19.2	30.8	47.5	58.4	77.0
SR-07	Protection and Automation Replacement Projects	6.7	8.6	12.7	12.2	21.7
SR-08	John Transformer Station Reinvestment Project	3.5	17.9	25.6	24.0	20.9
8						

Witness: Donna Jablonsky/Robert Reinmuller/Rob Berardi/Lincoln Frost-Hunt

Updated: 2019-06-19 EB-2019-0082 Exhibit F Tab 1 Schedule 1 Page 3 of 12

			v				1	```	,	
				Histo	orical				Bridge	Test
	201	15	201	6	201	17	20	18	2019	2020
	Actual	Plan	Actual	Plan	Actual	Plan	Actual	Plan	Forecast	Forecast
Category Level										
Sustainment	233.6	238.7	215.1	241.1	218.1	241.2	229.4	238.5	200.6	214.2
Development	6.1	12.9	4.6	13.4	5.1	4.8	5.2	5.0	6.0	6.9
Operations	59.0	58.5	62.5	59.1	61.1	61.3	53.4	62.1	46.1	48.9
Customer Care	5.1	5.5	4.5	5.5	8.5	4.0	11.0	3.9	7.3	7.5
Common Corporate Costs and Other Costs <sup>1</sup>	73.9	70.2	60.1	71.3	41.5	49.9	54.9	47.5	29.4	30.3
Property Taxes & Rights Payments	63.9	66.3	61.3	67.0	50.7	63.6	65.3	64.3	67.2	68.1
Adjustments										
EB-2014-0140 Settlement Reduction		-20.0		-20.0						
EB-2016-0160 Decision Reduction						-15.0		-15.0		
Removal of B2M Expense		-0.9		-0.7		-0.8		-2.1		
Pension Adjustment						-11.4		-9.9		
Directive *									-0.1	-0.1
				Envelo	pe Level	-				
Total Transmission OM&A	441.6	431.2	408.1	436.8	385.0	397.7	419.2	394.3	356.5	375.8
% Change Year over Year			-7.6%		-5.6%		8.9%		-9.6%	5.4%
Variance to Plan	10.4		-28.7		-12.7		24.9			

#### Table 1: Summary of Transmission OM&A Expenditures (\$ millions)

\*Directive refers to the Government Directive as detailed and defined in Exhibit F, Tab 4, Schedule 1.

2 Hydro One's 2019 OM&A expenses are expected to be \$38 million or 9.6 percent lower

than the 2018 plan funding envelope. This OM&A reduction will be achieved largely

4 through sustained productivity gains, a one-time extension of Hydro One's planned asset

5 maintenance cycles, and corporate cost reductions, which are described further within

6 Section 6 of this Exhibit. Hydro One plans to increase its 2020 OM&A expenditures by 5

<sup>7</sup> percent from 2019 levels while still remaining 4.7 percent below the 2018 plan funding

<sup>&</sup>lt;sup>1</sup> Common Corporate Costs and Other Costs includes Planning, (exhibit F-02-03), CCF&S (exhibit F-02-02), Information Technology (exhibit F-02-04), Cost of External Revenue (exhibit F-02-05), and Other OM&A (exhibit F-02-01).



#### Figure 2-2 Comparison of Model and Sample Cumulative Hazard Functions44kV Oil Circuit breakers

Figure 2-2 for the 44 kV oil circuit breaker group show two regions with different levels of agreement between the red and black lines. A good Weibull model fit for most of the life (Region 1) and a much steeper replacement rate (black line) than provided by the Weibull model in later life (Region 2). However, younger power circuit breakers are rarely replaced except for failure. Therefore, Region 1 may be a reasonable model for the failure hazard rate. The transition point between the two regions could indicate the following:

- The onset of a failure process that is more dominant in older units.
- The result of discretionary replacement decisions.
- Some combination of both failure process and discretionary replacement.

Since the reasons for removal are not noted, failures and discretionary replacements cannot be distinguished.

## **Modeling Assumptions**

- The starting data is complete and contains all removals and in-service units for the period within 1982 through third quarter 2017.
- The criteria for removal have been constant over the historical period being analyzed.

- Future criteria for removals will be the same as in the past.
- Any external effects on removal rates (e.g. budget constraints) were constant over the historical period and will be unchanged over the forecast period.
- Underlying wear-out processes will not change.
- It is important to note that the hazard rate function derived is for removals, not failures.

### Modeling Results

There are currently 443 circuit breakers in service of various ages in the 44 kV oil group. Based on the age of each individual circuit breaker, the distributions of the number of removals was predicted from a Monte Carlo simulation.

Each of the 9,600 pair results from the analyses results (Figure 2-1) is used in a Monte Carlo simulation to generate the expected number of removals. Each shape and scale pair defines a Weibull distribution. This distribution is applied to each of the in-service circuit breakers and the number of removals are summed for the total population for that particular distribution.

The resulting histogram of the sum of the number of removals recorded in each plot (Figure 2-3) gives the probability distribution of removals. The entire process is then repeated for the next year with each circuit breaker's age incremented by one.

Figure 2-3 shows the predicted number of removals of the currently in-service circuit breakers for each of the next five years and the five year total.

The figure can be interpreted as probability distributions. For example, in the plot for year 1, adding up the probabilities corresponding to 0 through 8 removals, we can say that we are 99% certain that the number of circuit breaker removals will be 8 or fewer.

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 3.2 Page 14 of 28

as the additional installation of 15 breakers resulting from customer requests to increase operational flexibility in the Toronto area. As per the EPRI analysis, there is a 90% probability that Hydro One will need to replace 491 breakers or fewer. However, Hydro One's volume of replacement over the plan period is higher primarily due to obsolescence concerns, safety concerns (e.g. insufficient arc resistance), PCB mitigation, and integrated investments which are not reflected in the EPRI analysis.

7

The EPRI analysis is derived from asset retirement data from 1981 to 2017. The analysis 8 does not reflect the necessary replacement of 95 ABCBs over the planning period due to 9 worsening reliability, as Hydro One has operated its fleet longer than industry peers. 10 Similarly, the historical mid-life refurbishment of oil breakers from 1950 to 2007 has 11 enabled Hydro One to operate approximately 300 currently in-service breakers for a 12 13 longer period prior to retirement. Based on how the calculations were performed, this skews the predicted replacement rate. PCB mitigation also contributes to the increased 14 rate of replacement in order to meet federally legislated deadlines. Out of the 247 oil 15 circuit breakers identified for replacement over the planning period, 69 (28%) have 16 measured above the acceptable level of 45 ppm for PCBs. Due to increased obsolescence 17 concerns and the lack of, or reduction of, vendor support with respect to oil, metalclad, 18 and vacuum breakers, the capital plan paces breaker replacements to mitigate reliability 19 impact. Where breakers that are not end of life are removed from service because it is 20 part of an integrated investment (e.g., due to the replacement and relocation of a 21 switchyard), these breakers are placed into spares to support the remaining fleet. Oil 22 circuit breakers can be salvaged for parts to support the remaining fleet, while complete 23 SF6 breakers are placed into the spare equipment pool to support demand replacements. 24

25

<sup>26</sup> This pacing of circuit breaker replacement has been reflected in the following ISDs: SR-

27 02 Station Reinvestment Projects, SR-04 Bulk Station Switchgear and Ancillary

28 Equipment Replacement Projects, SR-06 Load Station Switchgear and Ancillary

29 Equipment Replacement Projects, and SR-08 John Transformer Station Reinvestment.

Witness: Bruno Jesus/Donna Jablonsky/Robert Reinmuller

Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 15 of 20

I

- look at these projects first for reprioritization. Failure to complete Low Priority
   projects is not expected to have significant detrimental effects on the system in
   the near term.
- 4

5

## Table 5 - System Access - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SA-01	Connect New IAMGOLD Mine	24.9	0.0	0.0	0.0	0.0
SA-02	Horner TS: Build a Second 230/27.6kV Station	29.9	0.0	0.0	0.0	0.0
SA-03	Halton TS: Build a Second 230/27.6kV Station	8.0	17.7	6.0	0.0	0.0
SA-04	Connect Metrolinx Traction Substations	6.5	7.9	7.1	1.0	0.0
SA-05	Future Transmission Load Connection Plans	0.0	5.0	24.9	24.9	0.0
SA-06	Protection and Control Modifications for Distributed Generation	3.8	3.1	2.7	2.8	2.8
SA-07	Secondary Land Use Transmission Asset Modifications	55.1	15.0	13.9	15.6	3.9
	System Access Projects & Programs Less Than \$3M	27.6	9.4	8.5	7.8	9.2
Total G	ross System Access Capital (\$M)	155.7	58.1	63.0	52.0	15.8
	Less Capital Contributions (\$M)	(130.9)	(46.7)	(51.3)	(39.3)	(11.7)
Total Ne	et System Access Capital (\$M)	24.8	11.3	11.7	12.7	4.1

6 7

#### Table 6 - System Renewal - Material Capital Investments Proposed

ISD	Investment Name	2020	2021	2022	2023	2024
SR-01	Air Blast Circuit Breaker Replacement Projects	107.5	128.4	133.5	129.2	98.7
SR-02	Station Reinvestment Projects	107.0	125.4	120.6	87.9	53.9
SR-03	Bulk Station Transformer Replacement Projects	33.2	51.8	72.5	131.5	113.8
SR-04	Bulk Station Switchgear and Ancillary Equipment Replacement Projects	17.5	32.4	41.4	34.6	49.3
SR-05	Load Station Transformer Replacement Projects	91.2	132.3	129.4	178.5	200.0
SR-06	Load Station Switchgear and Ancillary Equipment Replacement Projects	19.2	30.8	47.5	58.4	77.0
SR-07	Protection and Automation Replacement Projects	6.7	8.6	12.7	12.2	21.7
SR-08	John Transformer Station Reinvestment Project	3.5	17.9	25.6	24.0	20.9
8						

Witness: Donna Jablonsky/Robert Reinmuller/Rob Berardi/Lincoln Frost-Hunt

Updated: 2019-06-19 EB-2019-0082 Exhibit F Tab 1 Schedule 1 Page 3 of 12

	1		v				1	· · ·	,	
				Histo	orical				Bridge	Test
	201	15	201	6	20	17	20	18	2019	2020
	Actual	Plan	Actual	Plan	Actual	Plan	Actual	Plan	Forecast	Forecast
Category Level										
Sustainment	233.6	238.7	215.1	241.1	218.1	241.2	229.4	238.5	200.6	214.2
Development	6.1	12.9	4.6	13.4	5.1	4.8	5.2	5.0	6.0	6.9
Operations	59.0	58.5	62.5	59.1	61.1	61.3	53.4	62.1	46.1	48.9
Customer Care	5.1	5.5	4.5	5.5	8.5	4.0	11.0	3.9	7.3	7.5
Common Corporate Costs and Other Costs <sup>1</sup>	73.9	70.2	60.1	71.3	41.5	49.9	54.9	47.5	29.4	30.3
Property Taxes & Rights Payments	63.9	66.3	61.3	67.0	50.7	63.6	65.3	64.3	67.2	68.1
				Adjus	tments					
EB-2014-0140 Settlement Reduction		-20.0		-20.0						
EB-2016-0160 Decision Reduction						-15.0		-15.0		
Removal of B2M Expense		-0.9		-0.7		-0.8		-2.1		
Pension Adjustment						-11.4		-9.9		
Directive *									-0.1	-0.1
			-	Envelo	pe Level			-		
Total Transmission OM&A	441.6	431.2	408.1	436.8	385.0	397.7	419.2	394.3	356.5	375.8
% Change Year over Year			-7.6%		-5.6%		8.9%		-9.6%	5.4%
Variance to Plan	10.4		-28.7		-12.7		24.9			

#### Table 1: Summary of Transmission OM&A Expenditures (\$ millions)

\*Directive refers to the Government Directive as detailed and defined in Exhibit F, Tab 4, Schedule 1.

2 Hydro One's 2019 OM&A expenses are expected to be \$38 million or 9.6 percent lower

than the 2018 plan funding envelope. This OM&A reduction will be achieved largely

4 through sustained productivity gains, a one-time extension of Hydro One's planned asset

5 maintenance cycles, and corporate cost reductions, which are described further within

6 Section 6 of this Exhibit. Hydro One plans to increase its 2020 OM&A expenditures by 5

<sup>7</sup> percent from 2019 levels while still remaining 4.7 percent below the 2018 plan funding

<sup>&</sup>lt;sup>1</sup> Common Corporate Costs and Other Costs includes Planning, (exhibit F-02-03), CCF&S (exhibit F-02-02), Information Technology (exhibit F-02-04), Cost of External Revenue (exhibit F-02-05), and Other OM&A (exhibit F-02-01).

1 if you go to Staff 73 (a), there is a statement by METSCO 2 in which you were asked to confirm -- which essentially 3 said risk is probability times consequence; I am 4 paraphrasing.

5 But your response to 71 (c) is that the sub indices in 6 your risk process do not inform either probability or 7 consequence, and I was hoping to have clarification.

8 MR. JESUS: So I think, for the purpose of item (c) 9 here, the facts associated with the specific transformer or 10 asset that's in question, the asset analytics would provide 11 the condition information, the performance information, the 12 criticality of the unit, the utilization, how much money 13 we're spending on the unit, how old it is. So they would 14 provide that information.

The actual probability times consequence is not being carried out in the asset analytic solution. It's actually being carried out in our asset investment planning tool, i.e. Copperleaf.

So the probability and the consequence are in fact being informed by the facts presented from the asset analytic solution.

22 MR. WALSH: Okay, thank you. Under Staff 73(e) and 23 (f), parts (e) and (f), part (e) provided a graphic to 24 illustrate the notion of the worst reasonable outcome. 25 Can you confirm if Hydro One ever uses the worst 26 reasonable outcome to represent the expected consequence of

27 failure?

28

MR. JESUS: So planners are constantly using the worst

**ASAP Reporting Services Inc.** 

(613) 564-2727

(416) 861-8720

reasonable outcome to make asset is investment decisions.
 The assessment is informed by the asset risk assessment and
 they're taking what is the most reasonable, credible case
 or consequence to be used in the assessment.

5 MR. WALSH: I'm sorry, could you repeat that? 6 MR. JESUS: So planners are using the worst reasonable 7 outcome, i.e. the most reasonable outcome or consequence 8 associated with an event, to assess the consequence as part 9 of the risk assessment.

MR. WALSH: Okay. If I have understood correctly, worst reasonable outcome is approximately one standard deviation away from most probable outcome. What is the associated probability of worst reasonable outcome? MR. JESUS: So the worst reasonable outcome is a one

15 standard deviation away, and it's not the most probable.
16 These are probabilities, and the intent is to identify what
17 a reasonable outcome or event could occur.

18 So a good example is a line being held by an 19 insulator. If it's a brand new insulator, is there a 20 probability that that conductor can fall? Absolutely. Is 21 it credible? Is it reasonable, given that it's a new 22 insulator? No.

But a 60-year old insulator that is CP, or Canadian porcelain, Canadian Ohio brass with known defect issues, is the worst credible case that the conductor could fall and injure someone from a safety point of view? Absolutely. That would be the most credible case.

28

So when we are doing the investments, we look at what

ASAP Reporting Services Inc.

(613) 564-2727

(416) 861-8720

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 73 Page 4 of 4

c) No. It is more than a modest incremental adjustment.

1 2

d) Please refer to c) above.

3 4 5

6

7

e) From the perspective of a hypothetical risk distribution curve, the worst reasonable outcome would lie approximately 1 standard deviation away from the most probable outcome, as shown in the illustrative example below:



### 8 f) Confirmed.

9 i. N/A

ii. Hydro One subsequently applies a modifier to translate from the most probably
 outcome to the worst reasonable outcome – for example, if there is a certain set of
 coincident circumstances required for a worst reasonable outcome to materialize,
 the joint likelihood of the triggering event and coincident event is used.

14 iii. N/A

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 2.1 Page 13 of 54

condition) to be further evaluated against the relevant planning context. The investment
 candidates are further scored and prioritized through Hydro One's Investment Planning
 process (as described in TSP Section 2.1.4 below) to achieve the optimal balance of risk
 and benefits.

5

Hydro One performs a continuous asset risk assessment ("ARA") process to determine
individual asset needs which rely on asset condition data, engineering analysis and other
information including the input of experienced planning professionals. The ARA is
primarily concerned with the major equipment groups (e.g. transformers, conductors,
breakers, and protection and control systems) that directly affect system reliability.

11

One of the inputs into the ARA is a quantitative asset analytics system, which combines 12 information from various Hydro One databases to provide an initial common 13 understanding of asset health. This process drives efficiency and effective planning 14 decisions by ensuring a consistent view of asset information for all planners. As part of 15 the preliminary risk assessment, asset analytics enables the review and consolidation of a 16 variety of information from enterprise reporting systems, such as condition information 17 driven by deficiency and preventive maintenance reports, demographic information 18 including make, model, and type, criticality to the transmission system, performance data 19 based on equipment outages, utilization information, and economics. While not a 20 determinative driver in the ARA process, asset analytics is one useful tool that aids 21 Hydro One planners in identifying asset risks for further screening and confirmation. 22 Hydro One's planners also take into account additional factors such as load forecasts, 23 equipment ratings, operating restrictions, security incidents, environmental risks and 24 requirements, compliance obligations, equipment defects, obsolescence, and health and 25 safety considerations to ensure capital expenditures target the most appropriate mix of 26 assets. As part of the ARA process, transmission assets are evaluated on the following six 27 risk factors: 28

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 2.1 Page 14 of 54

• **Condition** - Risk related to the increased probability of failure that assets 1 experience when their condition degrades over time. Asset condition is defined 2 using different criteria, depending on the asset. For example, the condition of a 3 transmission station transformer is measured by visual inspections and analysis of 4 the oil within the transformer. The condition of a wood pole is measured by a 5 visual inspection, a sounding test, and if required, a boring test. While methods to 6 evaluate condition vary from asset type to asset type, the condition of all assets of 7 a given type is evaluated consistently. Assets of a given type that have a relatively 8 high condition risk are candidates for refurbishment or replacement. 9

- **Demographics** Risk related to the increased probability of failure exhibited by assets of a particular make, manufacturer, and/or vintage. Typically, the probability of asset failure increases with age. Thus, the asset demographic risk increases as an asset ages. Assets with relatively high demographic risk are candidates for refurbishment or replacement.
- **Criticality** Represents the impact that the failure of a specific asset would have 15 on the transmission system. Primarily, it is used to show relative importance of an 16 asset compared to other assets of the same type. Assets whose failure would result 17 in an interruption to a larger amount of load would have an asset criticality that is 18 higher than assets whose failure would have a smaller impact on the system load. 19 Asset criticality is used to prioritize the refurbishment or replacement of assets 20 whose condition, demographic, performance, utilization or economic risk has 21 already resulted in the asset being considered a candidate for refurbishment or 22 replacement. 23
- **Performance** Risk that reflects the historical performance of an asset, derived from the frequency and duration of outages. Past performance can be a good indicator of expected future performance. Therefore, assets with a relatively highperformance risk can be considered candidates for refurbishment or replacement.
- Utilization Risk that reflects the increased rate of deterioration exhibited by an asset that is highly utilized. The relative deterioration of some assets is highly

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 2.1 Page 15 of 54

dependent on the loading placed upon them or the number of operations they 1 experience. For example, transformers that are heavily loaded relative to their 2 nameplate rating deteriorate more quickly than those that are lightly loaded. 3 Similarly, circuit breakers utilized for capacitor and reactor switching which are 4 subject to significant operations experience accelerated mechanical and electrical 5 wear-out of the breaker. Therefore, the asset utilization risk for transformers and 6 circuit breakers attempts to consider their relative deterioration based on available 7 loading and operational history, respectively. 8

Economics - Risk based on the economic evaluation of the ongoing costs 9 associated with the operation of an asset. Depending on the asset type, this 10 evaluation may be as simple as determining the replacement cost of the asset, or 11 as complex as comparing the present value of ongoing maintenance to that of 12 complete refurbishment or replacement. While an economic evaluation can 13 identify assets that are candidates for replacement, more typically, the evaluation 14 assists in selecting the best form of remediation for assets already deemed to be 15 candidates for refurbishment or replacement. 16

17

It is important to recognize that although asset analytics aids in the identification of asset needs as an initial step, it is not the sole input or driver of the ARA. Hydro One planners take into account a range of other considerations and data sources, as informed by sound engineering oversight and experience-based decision making, in the initial determination of asset needs, which are then ultimately verified against asset condition assessments.

23

Throughout the assessment of individual asset needs, Hydro One's planners carry out a process of grouping identified needs into logical, functional and geographic groups. For example, a customer need for increased capacity and an asset need to replace transmission station equipment, such as a transformer or switchgear, might be grouped together if the same transmission station is involved. Through this process, diverse individual needs are brought together to form potential projects or programs that may be

Witness: Bruno Jesus



The following section describes how the AA outputs, once generated in accordance with specifications related to each asset class, undergo further assessments in the subsequent stages of the ARA process.

## 2.1.2. Asset Risk Assessment (ARA) Capability Characteristics

Asset Risk Assessment (ARA) entails a full-spectrum asset management planning process that identifies the asset candidates to be included in the scope of the investment projects, of which AA is an input component used in conjunction with other input parameters, including:

- Asset class strategy and technical assessment documents, which utilize AA results and underlying data points in their analysis;
- Customer needs and preferences related to particular asset classes;
- Legal and regulatory requirements relevant for consideration;
- System planning and coordination requirements affecting potential intervention options;
- Health & Safety, environmental, and obsolescence-related;
- Field inputs, maintenance notifications, and relevant event investigations;
- Results of detailed assessments and diagnostic testing; and
- Field visit validation of asset needs suggested by ARA analysis.

Figure 3 illustrates the entire scope of the ARA process.

# METSCO MAKING IT POSSIBLE

#### May 8<sup>th</sup>, 2018 Review of Hydro One's Capabilities in Transmission Asset Analytics & Reliability Risk Modelling FINAL Report & Conclusions - Privileged & Confidential



Figure 3. Asset Risk Assessment Process

Overall, the ARA functionality serves to expand upon the initial prioritization as established by AA, by allowing asset planners and managers to assess and stress-test the insights produced by the AA functionality in the context of incremental data points, and considerations that connection field data with the broader strategic, planning, and regulatory environment in which Hydro One operates.

# 2.1.3. Reliability Risk Forecasting Capability Characteristics

Reliability Risk Model is a standalone tool designed to develop system-level forecasts of changes in values of reliability risk relative to the capital investment levels underlying a particular scenario. METSCO understands that up to this point in its existence, the RRM's outputs were only used in the context of customer engagement meetings, to represent directional implications of reliability risk relative to the range of investment levels contemplated by the utility.

Given its current utilization, the tool and its outputs help contextualize Hydro One's investment considerations to customers, acting as a supporting mechanism in gathering customer feedback that is considered in the course of investment planning. With the exception of this indirect contribution into the investment planning activities, the tool

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 55 Page 1 of 1

1	<b>OEB INTERROGATORY #55</b>
2	
3	Reference:
4	TSP-01-04 p. 22
5	
6	Interrogatory:
7	At the above noted reference, Hydro One stated that "Half of utilities refurbish
8	transformers to extend life."
9	
10	a) Does Hydro One refurbish transformers to extend life?
11	i. If yes, please provide documented examples of refurbishment vs. retirement
12	decisions.
13	ii. If no, please explain why not.
14	
15	b) If one exists, please provide the formula used by Hydro One to establish
16	refurbishment investment limits, driven solely by estimated remaining service life
17	(defined as ESL minus actual age).
18	i. Once an asset has exceeded ESL, what is the maximum allowed refurbishment
19	investment?
20	
21	<u>Response:</u>
22	a) No, power transformers are refurbished to preserve their expected service life and
23	reliability, not to extend their life.
24	b) Hudre One employees model that marridge the Dresent Value for three options
25	b) Hydro One employs a model that provides the Present value for three options:
26	maintain status quo, returbish, or replace. It uses several factors such as maintenance
27	to Interrogatory I 01 OEP 10 Attachment 1 for an example
28	in There is no set value and the maximum allowed refurbishment cost will
29	1. There is no set value and the maximum anowed refut distillent cost will depend on the evaluated asset
28 29 30	<ul> <li>i. There is no set value and the maximum allowed refurbishment cost will depend on the evaluated asset.</li> </ul>

Witness: Donna Jablonsky

1 would you then decide to spend more money to get the same
2 result?

3 MS. JABLONSKY: This varies, actually, because this 4 will be based on other work that's in the queue to be done 5 at the time. So it's assessed per transformer. So the 6 decision that's made would be as per this unit and where it 7 fits in the work program at that time.

8 So sometimes a decision would be to follow that as 9 well as to do status quo or major repair based on what else 10 is in the queue to be done, because both these require a 11 planner's intervention.

MR. WALSH: So the "status quo maintain", would that be representative if the planner said that there has to be major maintenance? Would that be a fair representation of this net present value expectation?

16 MS. JABLONSKY: When we do maintenance on these units and we collect data for the assessment of the unit, status 17 18 quo is a last resort for us, because if there's an issue that's prominent with the unit it should be addressed. So 19 status quo, unless the replacement of the unit is within 20 the next year, is not the field that we go to. So it's 21 refurbish, a known issue with the unit would be the 22 preferred. 23

MR. WALSH: Okay, thank you. So just to clarify, if you did a major maintenance would it change the expected duration, remaining life of the asset?

MS. JABLONSKY: It would not change the expectedservice life of the asset. The asset may live beyond that,

ASAP Reporting Services Inc.

1 but it would not change the recorded ESL of the asset.

2 MR. WALSH: So -- and just to clarify, each asset has 3 its own individual ESL or each asset has the ESL that's 4 attributable to that asset class?

5 MS. JABLONSKY: The ESL is on the fleet level. So the 6 asset -- all asset in that -- that particular asset, they 7 all have the same ESL date time frame to them.

8 MR. WALSH: Okay, thank you.

9 MS. JABLONSKY: The condition assessment is on the 10 individual level.

11 MR. WALSH: Okay. If we can go to the graph that 12 follows this, so on the next page. On this graph and on 13 the Marathon there's a similar graph, but at the top of 14 this graph and the title -- or just below the title it says 15 that the replace asset life is 40.

16 So am I correct in understanding that under the 17 assumption that you've replaced the asset that the expected 18 service life of the asset would be 40 years?

19 MS. JABLONSKY: Please repeat your question.

20 MR. WALSH: Under this -- under the table that's 21 above, at the -- just below the title it reads "replacing 22 asset cost 580K and replacing asset life 40." Am I to 23 understand that the assumptions if you replace the asset 24 and that's being used in the calculations in the previous 25 table, is that the asset would last for 40 years?

26 MS. JABLONSKY: No.

MR. WALSH: Could you explain what the 40 means?
MS. JABLONSKY: The 40 is the ESL of the asset. This

ASAP Reporting Services Inc.

(613) 564-2727



#### 7.2 Net Present Value Analysis

This section evaluates the cost benefit for various asset management options (Status Quo Maintain, repair, replacement) of T13 with Net Present Value Analysis (NPV).

- <u>Status Quo Maintain</u>: Perform routine maintenance to keep the unit in service. Replace at economic end of life (2021). Continue to maintain new unit to end of study period (2081).
- <u>Repair/Refurbish</u>: Perform major repair/refurbishment in the year of interest (2017), then maintain as normal and replace the unit at economic end of life (2021). Continue to maintain new unit to end of study period (2081).
- <u>Replace</u>: Advance the replacement to the year of interest (2017) instead of performing a refurbishment. Continue to maintain new unit to end of study period (2081).

The study makes the following assumptions:

- Study period : 64 years<sup>1</sup>
- T13 will undergo refurbishment/ repair at 60 year old (2017), at approx. CAD\$583.8k<sup>2</sup>.
- Replacement cost is assumed to be CAD\$5.8M<sup>3</sup> for a unit that matches purchasing standard S115-106
- The new unit will benefit from lower OM&A cost because it will be equipped with vacuum tap changer. Estimated interval for internal inspection is lengthened to 12 years. New unit will utilize Buchholz relay and eliminate D2 maintenance task.
- Inflation: 2%. [2]
- Cost of Capital: 5.78% [2]
- Corporate Tax rate : 26.5% [2]
- CCA rate for Transmission Asset : 8% [2]
- Disposal Value : \$0
- Average corrective cost of CAD\$8K per year. (Total : CAD \$32K)

NPV of 3 options (Status Quo Maintain, Repair and Replace) were evaluated under the aforementioned assumptions. In general, NPV calculation has preferred the option to maintain status quo and wait for replacement as it has the lowest present value.

Should a repair becomes necessary, the maximum economically viable budget to repair/refurbish the unit is CAD \$583.8K - CAD \$39.88K = CAD \$543.92K. Therefore, the model suggests that it will be more economical to replace instead of to repair/refurbish the unit when T13 reaches 60 years old and onwards.

Result Summary	Status Quo Maintain	Major Investment Maintain/Repair	Replace	Preferred Option
With CCA tax savings				
PV of Options, \$k, with terminal value	5262.46	5809.02	5769.14	
PV of Options, \$k, terminal value = 0	5377.25	5923.81	5993.20	
Investment Decision		NPV, \$k		
Status Quo Maintain - Refurbish		-546.56		Maintain
Major Investment (Repair/Refurbish) - Replace		39.88		Further Review
Repair - Replace boundary			543.92	
Repair - Replace boundary, upper bound			598.31	
Repair - Replace boundary, lower bound			489.53	

Table 7: Present Value comparison for different sustainment options.

<sup>&</sup>lt;sup>1</sup> Study period lengthen to 64 years to accommodate the fact that the unit is already 60 years old. Normal Study period is 40 years

 $<sup>^{2}</sup>$  \$583.8 K is the 2010 – 2015 recorded average cost to refurbish transformer under AR 18335 (Transformer Oil Leak Reduction )

<sup>&</sup>lt;sup>3</sup> Based on 2015 March, Average I/S Cost for Power Transformers in 115kV class.

Copyright © 2016 Hydro One Networks Inc. This document is the property of HONI. No exploitation or transfer of any information contained herein is permitted in the absence of an agreement of HONI, and neither the document nor any such information may be released without the written consent of HONI. Printed copies of this document are uncontrolled.

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 2.1 Page 2 of 54

- and prioritized based on the level of risk mitigated and the cost and value delivered
- 4 toward achieving business objectives.
- 4
- 5 The overall Investment Planning process is set out below in Figure 1.

	Investment Planning Context Candidate Investment Development Scoring and Calibration Prioritization Enterprise Prioritization Prioritization Prioritization Calibration Calibration Prioritization Prioritization Prioritization Prioritization Plan Plan Plan Plan Plan Plan Plan Pla
6 7	Figure 1 – Improved Eight-Step Investment Planning Process
8	
9	Key improvements to Hydro One's investment planning process include the use of:
11	• Revised risk assessment framework to provide consistent risk assessment of
12	safety, reliability and environmental risks;
14	• Clear definitions of risk impacts to enable consistent assessments across
15	investments and calibration sessions to calibrate and align risk assessment
16	practices; and
16	• Challenge sessions to engage stakeholders across the organization to review the
17	investments and discuss potential trade-offs.
17	
21	Hydro One management at all levels, including the Executive Leadership Team ("ELT"),
22	are involved in the investment planning process to develop an investment plan that
23	achieves the overall corporate strategy, efficiently mitigates risks, and delivers value to
24	customers.
22	
27	The Investment Planning process generates an annual budget for Operations,
28	Maintenance and Administration ("OM&A") and capital work programs, and a six-year
29	planning forecast that allows Hydro One to meet the OEB's filing requirements. The
30	2020-2024 Investment Plan presented in this TSP is a product of the improved
31	investment planning process.

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 1.4 Attachment 15 Page 3 of 8

are kept up-to-date and accurate, the strategies are regularly reviewed. Since the Prior
 Proceeding, Hydro One has reviewed and revised strategy documents for the majority of
 Transmission Lines, Stations and Protection & Automation assets. These are among the
 most critical assets in Hydro One's transmission system. To further strengthen Hydro
 One's asset management capabilities, the development of new strategy documents for
 minor assets is currently underway.

7

#### 8 Outcomes Tracking

Guided by the BCG recommendations outlined in the Investment Planning Process
Review, Hydro One implemented a new process step in 2018, which included an upfront
identification of corporate strategic direction, the establishment of interim targeted
outcomes and more granular, strategic budget allocations based on operational, financial,
regulatory and customer considerations at the beginning of the investment planning
process.

15

Hydro One conducted a strategic budget (capital/OM&A) allocation at the beginning of the process, whereby the plan was divided into smaller, discrete budgets based on business unit, and then investments were subsequently prioritized within those budgets. The basis for this upfront allocation was the expenditure levels included in the previous plan, adjusted for efficiency gains and new strategic directions, as illustrated in Figure 1 below. This was done by business unit, resulting in nine allocations.

Witness: Bruno Jesus/Donna Jablonsky

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 1.4 Attachment 15 Page 4 of 8



Witness: Bruno Jesus/Donna Jablonsky

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 1.4 Attachment 15 Page 5 of 8



#### Line of Business Allocation, (SM Net)



- 8
- 4 In addition to the end-of-plan outcomes, near-term, 1-year outcome metrics were
- 5 identified, as outlined in Table 1 below. 1-year metrics were developed at the beginning
- <sup>6</sup> of the Investment Planning Process and subsequently revised based on the approved plan,
- <sup>7</sup> to form the various business unit scorecards that will be used for 2019. The
- 8 establishment of interim targets supports the overall approach to long-term target setting
- <sup>9</sup> and monitoring, ensuring that the long-term targets have updated targets annually.

Witness: Bruno Jesus/Donna Jablonsky

1

2

Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 2 of 20

2

1

	Historical (Previous Plan and Actual)												
OFD Cotores	2015				2016			2017			2018		
<b>OEB</b> Category	Actual	Plan	Var	Actual	Plan	Var	Actual	Plan	Var	Actual	Plan	Var	
	\$M	<b>\$M</b>	%	\$M	\$M	%	\$M	\$M	%	\$M	<b>\$M</b>	%	
System Access	7.6	19.7	-61%	17.0	31.9	-47%	42.7	33.3	28%	33.7	24.3	39%	
System Renewal	688.9	573.6	20%	733.9	539.9	36%	740.7	733.7	1%	776.2	780.4	-1%	
System Service	157.9	189.9	-17%	140.9	180.0	-22%	93.5	97.0	-4%	73.9	75.6	-2%	
General Plant	88.6	116.3	-24%	94.8	114.6	-17%	76.9	86.0	-11%	83.6	119.7	-30%	
Total	943.0	899.4	5%	986.7	866.3	14%	953.9	950.0	0%	967.3	1,000.0	-3%	
System OM&A <sup>1</sup>	441.6	431.2	2%	408.1	436.8	-7%	385.0	397.7	-3%	419.2	394.3	6%	

#### Table 1 - Historical Capital Expenditure Summary

<sup>&</sup>lt;sup>1</sup> System OM&A includes Operations, Maintenance and Administration expenses. System OM&A for 2021 to 2022 is determined based on the Revenue Cap Index identified in Exhibit A, Tab 4, Schedule 1.

Witness: Donna Jablonsky/Robert Reinmuller/Rob Berardi/Lincoln Frost-Hunt

Updated: 2019-06-19 EB-2019-0082 Exhibit B-1-1 TSP Section 3.3 Page 3 of 20

	Bridge			Forecast		
OFP Catagory	2019	2020	2021	2022	2023	2024
OLD Category	F/Cast	Test	Test	Test	Plan	Plan
	<b>\$M</b>	\$M	<b>\$M</b>	<b>\$M</b>	<b>\$M</b>	<b>\$M</b>
System Access	45.1	24.8	11.3	11.7	12.7	4.1
System Renewal	773.3	865.2	1,103.1	1,172.8	1,177.4	1,193.8
System Service	103.8	204.1	148.2	151.8	174.3	204.2
General Plant	116.3	115.4	94.4	94.7	83.6	58.9
Progressive Productivity Placeholder	0.0	-17.0	-39.0	-61.0	-78.0	-91.0
Directive <sup>2</sup>	-0.3	-0.3	-0.3	-0.4	-0.4	-0.4
Total	1,038.2	1,192.2	1,317.7	1,369.6	1,369.6	1,369.6
System OM&A <sup>1,3</sup>	356.5	375.8	*	*	N/A	N/A

#### Table 2 - Bridge Year and Test Year Capital Expenditure Summary

2

1

<sup>3</sup> For explanatory notes on Forecast Trends vs. Historical Budgets by Category, please see

5

For explanatory notes on Plan vs. Actual Variance Trends by Category, please see
Section 3.3.3.

8

9 For explanatory notes on System OM&A, please see Exhibit F.

<sup>4</sup> Section 3.3.2.

<sup>&</sup>lt;sup>2</sup> The Directive adjustment reflects the impact of the directive issued by Ontario's Management Board of Cabinet on February 21, 2019 and the associated framework they approved on March 7, 2019. Refer to Exhibit F, Tab 4, Schedule 1 for further details.

<sup>&</sup>lt;sup>3</sup> Includes the Directive adjustment. Refer to Exhibit F, Tab 1, Schedule 1 for further details.

Filed: 2019-03-21 EB-2019-0082 Exhibit B-1-1 TSP Section 1.6 Page 7 of 13

1         Table 1 - Productivity Savings Forecast Summary (\$Millions)											
\$mm	2020	2021	2022	2023	2024	Total					
Operations	47	52	53	53	54	259					
Progressive Operations (Defined											
Capital)	6	12	12	10	10	49					
Corporate	12	11	9	7	6	45					
Capital Total	\$65	\$74	\$73	\$70	\$70	\$353					
Operations	9	10	9	9	9	45					
Information Technology	6	9	10	10	10	44					
Corporate	7	6	5	4	3	25					
OM&A Total	\$22	\$25	\$23	\$23	\$22	\$114					
Total Defined	\$87	\$ <b>99</b>	\$97	\$93	\$92	\$468					
Progressive Operations (Undefined											
Capital)	11	27	49	68	81	237					
Grand Total	\$98	\$126	\$146	\$161	\$173	\$704					
Progressive Productivity											
Progressive Operations (Defined											
Capital)	6	12	12	10	10	49					
Progressive Operations (Undefined											
Capital)	11	27	49	68	81	237					
Progressive Productivity Placeholder	17	39	61	78	91	286					

...... `` . \_

As noted in the table above, Hydro One has identified savings opportunities totalling 2 approximately \$704M over the 2020-2024 TSP period. This reflects Tier 1 Productivity 3 savings only. There are \$353M in capital productivity savings, \$114M in OM&A 4 productivity savings and \$237M in undefined capital savings. This latter category of 5 savings falls within "Progressive Productivity". Progressive Productivity is a further 6 reduction in cost that Hydro One has included in the final Transmission Business Plan in 7 response to concerns that were raised in the OEB's decision in the Prior Proceeding 8 regarding the level of investment. It represents a commitment from Hydro One to find 9 further efficiencies over the planning period when executing the necessary planned 10

Witness: Joel Jodoin, Andrew Spencer

Filed: 2019-08-28 EB-2019-0082 Exhibit JT 2.28 Page 1 of 1

## **UNDERTAKING - JT 2.28**

1

#### 2 . **D**

# 3 **<u>Reference:</u>**

- 4 SEC-026
- 5

## 6 **Undertaking:**

7 Regarding SEC 26, to consider if further level of details can be provided beyond what is

<sup>8</sup> currently provided in evidence regarding the base number for each one of the initiatives.

9

## 10 **Response:**

<sup>11</sup> Please see Attachment 1 to this Exhibit.

#### Filed: 2019-08-28 EB-2019-0082 Exhibit JT-2.28 Attachment 1 Page 1 of 2

						U	Updated Savings									Tage Torz				
	Category	Initiative Grouping	Measurement and Expected Benefit	2016	6A	2017A	2	018A	2	2019	20	020	202	1	2022	:	2023	:	2024	Baseline
		Engineering	Cost Reduction from Software Implementation Estimated by quantifying the expected FTE reductions in Engineering through the implementation of EDM software enhancements	Ş	-	\$ -	\$	_	Ş	0.4	\$	0.9	Ş	1.1	\$ :	L.4 :	\$	\$	1.4	129 Tx FTEs (2017 actual) in records and drafting job functions.
		Fleet Telematics and Right-Sizing	Fleet Rationalization - Unit Based Capital Plan Reduction Estimated by utilizing Telematics data on fleet utilization and then measures the expected unit based reduction in the capital plan	\$	-	\$ 1.9	ş	10.2	\$	10.6	Ş	11.0	\$ 1	.1.1	\$ 1:	1.4	\$ 11.6	\$	11.3	Baseline is \$59.7M annual spend (HONI Total). See EB-2017-0049 Exhibit J 2.3 for detailed methodology
		Transmission and Stations	Cost Reduction based on Historical spend Expected Capital allocation based on historical spend for Transmission and Stations efficiencies and Temporary work HQ. Calculated by measuring expected benefit per occurrence	\$	-	\$ 1.8	\$	0.6	\$	0.7	Ş	0.7	\$	0.7	\$ (	).7	\$ 0.7	\$	0.7	Savings Calculated per occurance for TWHQ (varies by zone - approx. \$185). Baseline for Transmission and Stations efficiencies (BGIS Outsourcing )is 650k.
		OT Reductions	Overtime Reductions Targeted effort to reduce the number of relative OT hours worked as a % vs prior year baseline	\$	-	\$ 1.5	ş	0.5	\$	0.5	Ş	0.5	\$	0.5	\$ (	).5	\$ 0.5	\$	0.5	Savings calculated against 2015 baseline of 12.3% OT as a % of Base Hours - please refer to I-07-SEC-25
Capital	Operations	Procurement	Lower Cost per Unit - Historical Baseline vs Actual Savings are estimated at a category level based on historical spend, expected and achieved negotiated savings, and updated per business plan assumptions (Capital program spend)	Ś	1.2	\$ 12.8	ŝ	27.9	s	25.1	Ś	30.3	Ś 3	4.9	Ś 35	5.8	\$ 35.7	Ś	37.1	Calculation described in EB-2017-0049 Exhibit J 2.3. As there are tens of thousands of materials being tracked (automated system reports) Hydro One is unable to reasonably provide the baseline price for each item.
		Progressive Defined	Targeted Efficiencies - Defined Efficiencies that have been allocated to specific Operating initiatives that are not yet proven. Allocations taken in Business Plan based on preliminary estimates. Ex - Hydro Vac reduction, Temp Access Roads	Ś	-	s -	Ś	_	s	5.0	Ś	6.1	\$ 1	.1.6	\$ 1:	1.6	\$ 10.1	Ś	10.1	Refer to JT 1.09 for an Update on Progressive initiatives.
		Progressive Undefined	Targeted Efficiencies - Undefined Escalating commitment of 1-3% of capital work program to be allocated to future initiatives as they are defined. Included as a Top Line capital reduction	\$	-	\$ -	Ş	_	\$	-	\$	10.9	\$ 2	7.4	\$ 49	9.4 :	\$	\$	80.9	N/A
		Scheduling Tool	Cost Reduction from Software Implementation Estimated by quantifying the expected FTE reductions in Scheduling Staff through the implementation of software enhancements	Ş	-	\$ -	\$	0.2	Ş	0.9	\$	0.9	Ş	0.9	\$ (	).9	\$ 0.9	\$	0.9	32 Tx FTEs (2017 Actual) in Scheduling job functions
		Wrench Time	Lower Cost Per Unit of Operation Utilize unit reporting to compare like for like work in actuals vs baseline year to determine \$ savings per operation.	Ś	-	Ś -	s	-	s	0.5	s	0.5	Ś	0.5	\$ (	0.5	Ś 0.5	s	0.5	Labour efficiency per Task: 2015 Labour Hours Less Estimated Labour Hours for planned orders multiplied by \$143 per hour. Due to the volume of orders Hydro One is unable to reasonably provide the baseline price for each Task.
	Information Technology	Contract Reductions	Cost Reduction Based on Historical Spend Lower cost resulting from Inergi IT Contract renegotiation. Measured against baseline spend for same scope of work	\$	2.0	\$ 2.3	Ş	6.6	\$	6.3	\$	6.4	\$	8.9	\$ 9	9.6	\$ 9.6	\$	9.6	Baseline is \$65.5M (Total 2015 Actual/2016 Plan)
		Engineering	Cost Reduction from Software Implementation Estimated by quantifying the expected FTE and contractor reductions in Engineering through the implementation of PCMIS software enhancements	\$	-	\$ -	Ş	0.7	\$	0.6	Ş	0.6	\$	0.6	\$ (	0.6	\$ 0.6	\$	0.6	Baseline is 13 Non-Regular FTEs (2017 Historical Actual) in P&C functions.
		Fleet Telematics and Right-Sizing	Fleet Rationalization - Unit Based Capital Plan Reduction Estimated by utilizing relematics data on fleet utilization and then measures the expected unit based reduction in the capital plan	\$	-	\$ 0.5	Ş	0.2	\$		Ş	-	\$	-	\$ -	:	\$ -	\$	-	There are no savings included in the plan years.
		Forestry Initiatives	Lower Cost per KM Estimated based on reductions in cost due to staff policy for inclement weather and expected overall unit volume reduction in trouble calls	\$	-	\$ -	Ş	1.3	\$	2.1	Ş	2.0	\$	3.4	\$ 2	2.0 :	\$ 2.4	\$	1.9	Estimate per occurance for inclement weather @ \$85 per hour. Forestry baseline is \$1566 per km (2015, escalated for labour inflation)
ţ.A		Transmission and Stations	Cost Reduction based on Historical spend Expected OM&A allocation based on historical spend for Transmission and Stations efficiencies and Temporary work HQ. Calculated by measuring expected benefit per occurrence	Ş	_	\$ 0.8	\$	1.8	\$	1.2	\$	1.2	Ş	1.2	\$ :	1.2	\$	\$	1.2	Savings Calculated per occurance for TWHQ. See above in this table.
0M8	Operations	Network Operating Efficiencies	Operational Program Efficiencies Unit cost reduction in completing Load Transfer studies through Network Operating group	\$	-	\$ -	\$	0.4	\$	1.0	\$	1.0	\$	1.0	\$ :	L.O :	\$ 1.0	\$	1.0	Baseline is historical program budget of \$1.0M
		OT Reductions	Overtime Reductions Targeted effort to reduce the number of relative OT hours worked as a % vs prior year baseline	Ş	-	\$ 1.5	Ş	0.5	\$	0.5	\$	0.5	\$	0.5	\$ (	).5	\$ 0.5	\$	0.5	See OT reductions within the Capital section above in this table

_				Updated Savings							ngs								
	Category	Initiative Grouping	Measurement and Expected Benefit	20	16A	20	)17A	201	L8A	2019	9	2020	202	21	2022	2	023	2024	Baseline
		Procurement	Lower Cost per Unit - Historical Baseline vs Actual Savings are estimated at a category level based on historical spend, expected and achieved negotiated savings, and updated per business plan assumptions	\$	1.8	\$	2.9	\$	1.7	\$	).9 Ş	5 0.8	\$	0.8	\$ 0.9	Ş	0.8	\$ 0.8	See Procurement category within the Capital section above in this table
		Scheduling Tool	Cost Reduction from Software Implementation Estimated by quantifying the expected FTE reductions in Scheduling Staff through the implementation of software enhancements	\$	-	\$		Ş	0.2	ş.		5 -	\$	-	\$ -	\$	_	\$ -	See Scheduling Tool category within the Capital section above in this table
		Wrench Time	Lower Cost Per Unit of Operation Utilize unit reporting to compare like for like work in actuals vs baseline year to determine \$ savings per operation.	\$	-	\$	-	\$	1.5	\$	2.3 \$	5 2.3	\$	2.3	\$ 2.3	\$	2.3	\$ 2.3	See Wrench Time category within the Capital section above in this table
	Corporate	Corporate Initiatives	Corporate Cost Initiative Identified reductions in vacancies and contractor and consulting spending	\$	2.3	\$	1.2	Ş	1.4	\$ 2(	0.1 \$	5 19.1	\$ :	16.5	\$ 13.6	\$	11.3	\$ 9.4	Baseline is \$303.9M (2019 Prior Plan (2018-2023). Tx is allocated by B&V methodology.
8	Operation	Procurement	Lower Cost per Unit - Historical Baseline vs Actual Savings are estimated at a category level based on historical spend, expected and achieved negotiated savings, and updated per business plan assumptions (Carporate Allocation)	\$	0.1	\$	1.8	Ş	5.4	\$	2.3 \$	5 2.3	\$	2.3	\$ 2.3	\$	2.3	\$ 2.3	Baseline is \$0. Savings are quantified as a Early Pay credit (negotiated cost reduction) received from Vendors.
			Total Capital	\$	1.2	\$	18.0	\$	39.4	\$ 4	3.6 \$	61.7	\$ 8	88.7	\$ 112.2	\$	129.2	\$ 143.4	
			Total OM&A	\$	3.8	\$	8.0	Ş	14.8	\$ 14	4.7 \$	5 14.7	\$ 1	18.6	\$ 17.9	\$	18.3	\$ 17.8	
			lotal common	<u>&gt;</u>	2.3	\$	3.1	ş	61.0	\$ 2 \$ 8	2.4 \$	97.9	\$ 12	18.8	\$ 16.0 \$ 146.1	\$	13.6	\$ 11.7 \$ 172.9	-
				Ŷ	2.5	<b>Y</b>	-5.1	÷	01.0	÷ 0			÷ 1		· -+0.1	<b>Y</b>		· ····	

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 1 of 9

## UNDERTAKING – J 2.3

# 1

## 3 **<u>Reference</u>**

- 4 I-25-Staff-123
- 5 K2.1
- 6

## 7 **Undertaking**

8 To provide the detail behind the numbers for the three initiatives move to mobile, 9 procurement, and telematics, as well as the methodology for determining these 10 calculations; and to provide a narrative as to whether or not what we are seeing is the 11 same approach used in other initiatives.

12

#### 13 **Response**

### 14 1. Move to Mobile – OM&A and Capital – Background

The Move to Mobile (M2M) solution was initiated to enhance Distribution workflow, with technology (SAP Work Manager with GIS Technology), upgrading our scheduling/dispatch tool (PCAD) and best in class process improvements. It was launched in Zone 3B in February 2017 and after a three-week period (to identify gaps/issues) was deployed across the province. The M2M project went live in the final Distribution Zone on April 24, 2017 and transitioned to sustainment on July 4, 2017.

21

M2M has two productivity savings components: Field Force Productivity (Capital) and Clerical Staff savings (OM&A).

24

## 25 Clerical Staff

- <sup>26</sup> M2M has automated the following:
  - Automate creation of some work orders/notifications
  - Auto scheduling of work types using improved scheduling technology
- 28 29

27

Some of this work was previously performed manually. This automation represents a
 reduction/ elimination of manual data entry.

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 2 of 9

### **Field force productivity**

2 M2M has allowed for:

- Improved tools to support work planning, scheduling and dispatching.
- Improved data quality and timeliness
- Reduce re-work (truck rolls) when information is missing or incorrect
- Provide electronic access to documents, design standards and maps
- Allow field to create new asset notifications and clear erroneous system recorded
   defects

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 3 of 9

## 1 Target Setting Methodology

## M2M Benefit Card Summary (\$K)

Benefits were estimated and submitted as part of business case. Benefit Card values were used to set the budget.

							Calculation
Category	Description	2018	2019	2020	2021	2022	Assumptions
							reduction of 21
							clerical FTE @
							labour rate of
	BASC Reduced						\$96, 492 PWU
OM&A	Data Capture	2,121	2,164	2,207	2,207	2,207	57
							reduction of 8
							clerical FTE @
							labour rate of
OM&A/	FBC - Optimized	050	075	000	000	000	\$102,456 PWU
Capital	Process	858	875	893	893	893	58
							5% of 900 FTE
	0.1.1.1						@ labour rate
Concise 1	Scheduling	0.100	0.250	0.507	0.507	0.507	\$157,844 PWU
Capital	Optimization	8,196	8,359	8,527	8,527	8,527	01
							4 calls $x 4/,504$
							trouble calls x 2
	Trouble / Outage						11111@ Tabout Tale
Capital	Undates	765	780	706	706	706	\$137,644 F W U
Capital	Opulaits	705	700	790	790	790	01 man binder
							undates 90
							hrs/ons/vear +
							man issues 48
							hrs/ops/year @
							labour rate
	Maps & Standards						\$157,844 PWU
Capital	Updates	838	855	872	872	872	01
<b>^</b>	•						253 jobs
							reverified/yr @ 1
							hr + 4 material
							issues/ops per
							year @ 1 hr @
							labour rate
	Field - Data						\$157,844 PWU
Capital	Capture	55	56	57	57	57	01
							25 pages per job
							folder x 100,000
							job folders +
	Courier and	1.00	<b>2</b> 2-		<b>2</b> 2 <i>-</i>		75% of courier
Capital	Printing	169	225	225	225	225	costs
Total Sa	vings (\$K)	13,001	13,314	13,576	13,576	13,576	

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 4 of 9

#### 1 Calculation Methodology

Clerical Staff (OM&A) - Productivity savings are realized through reduced headcount.
 Baseline headcount is compared to actual headcount on a monthly basis. The change in
 headcount is quantified using actual labour rates.

5

Field Force Productivity (Capital) - A baseline of Labour Hours per unit has been
quantified using SAP system data. Productivity Savings are calculated using Labor hours
saved across the work program and compared to the established baseline. A unit based
calculation compares historical labour hours per unit to actual.

10

## 11 2. Procurement Savings – OM&A and Capital – Background

In 2016, Supply Chain performed a comprehensive spend analysis to bundle procurement spend from across the company into natural sourcing categories for all goods and services. An opportunity analysis was conducted on these categories to identify and prioritize key initiatives and go-to-market strategies.

16

These strategies utilize industry best practices and streamlined processes. Examples of these strategies include; multiple feedback rounds in competitive sourcing events, enhanced direct negotiations for contract extensions and a redesigned sourcing process to make it faster and easier to do business with Hydro One. The opportunity analysis and category strategy developed were used to create a targeted savings percentage for each category.

23

During the investment planning process, Hydro One applied the targeted savings percentage to its work program by embedding the savings into the category related investment drivers.

27

Hydro One is unable to release the planned savings targets for categories that have not yet been executed as this would negatively impact Hydro One's ability to effectively negotiate with its suppliers. Below are examples of the target savings for completed sourcing events, including the weighted average savings target that was used to plan the procurement savings from 2018 to 2022.

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 5 of 9

Category	Target Savings %	Methodology	САР	OM&A	ссс	2018	2019	2020	2021	2022
Equipment Rentals	7%	Hourly Rate	100%			2.9	3.3	3.5	3.7	3.9
General Contractors	4%	Hourly Rate	100%			1.0	1.1	1.2	1.3	1.3
Electrical Hardware	5%	Unit Cost	100%			3.2	3.8	3.8	4.0	4.1
General Hardware	10%	Unit Cost	70%	30%		0.1	0.1	0.1	0.1	0.1
Volume Rebates*	N/A	Total Rebates			100%	0.7	0.7	0.7	0.7	0.7
Other Categories						7.9	8.2	12.7	11.8	13.4
Total						15.9	17.2	21.9	21.6	23.5

2 \*Note: volume rebate Savings are based on total dollar rebates received on all procurement spend and is not

3 a percentage based target.

## 5 Target and Actual Calculation Methodologies

6 Categories that are services based and charged out on an hourly basis, such as Equipment 7 Rentals and General Contractors, have savings estimates calculated based on the target 8 hourly rate reduction. The target savings are based on all services provided within the 9 category proportionately represented by estimated volume. To track actual savings, the 10 negotiated savings rate (old hourly rate vs. new hourly rate) is multiplied by the actual 11 volume purchased.

12

4

1

Categories for materials and equipment that have unit counts, such as Electrical Hardware and General Hardware, have savings estimates calculated based on the target unit cost reduction. The target savings are calculated by considering all units within the category proportionately represented by estimated volume. To track actual savings, the negotiated savings rate (old unit cost v.s new unit cost) is multiplied by the actual volume purchased.

19

An example of our corporate common cost savings are the Volume Rebates that Hydro One receives from suppliers from negotiated contracts. Not all contracts have volume rebates built into them and the target savings is based on a total dollar figure and not a percentage. Savings are tracked throughout the year based on actual credit notes or cash received.

Witness: BERARDI Rob

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 6 of 9

### **3.** <u>Telematics – OM&A - Background</u>

As a further safety initiative, Fleet Services has implemented Telematics Technology across the transport and work equipment in Hydro One. Telematics is an integrated use of telecommunications, including Global Positioning Systems (GPS) and informatics systems, which provide location of vehicles and live data. The benefits of telematics include:

7 8

9

- Provides insight to driving behaviours which allows us to reinforce road safety
- Allows for real-time management of corporate assets
- Provides solutions that allow operators to become more efficient and allows
   management to exercise better control of equipment
  - Provides solutions to allow for driver behavior modification
- 12 13

The telematics initiative is one of the most significant initiatives underway in Fleet Services. The project was completed at the end of 2016 with a total of ~4,800 telematics units installed across various T&WE (Transport and Work Equipment) asset categories. The technology provides data that allows us to realize efficiencies in T&WE use, resulting in optimal usage of the assets. Some of the key metrics being tracked are fleet utilization, speeding, harsh driving, idling, PTO (power take-off) usage and fuel efficiency.

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 7 of 9

#### **Target Setting Calculation**

Reduction in Net Fleet Complement	2018	2019	2020	2021	2022
Light duty vehicles	32	32	64	64	129
Misc. (Chippers, Manlifts, Forklifts, etc)	14	14	16	28	72
Total	46	46	80	92	201

Reduction of 10% of Light duty and 5% of other specialized equipment as per the Telematics Business Case

Reduction in Fleet OM&A Requirement	2018	2019	2020	2021	2022
Fuel Savings Estimate Preliminary Estimate	\$0.5	\$0.5	\$0.5	\$0.5	\$0.0
Maint. Savings \$16k per unit estimate	\$0.7	\$0.7	\$1.3	\$1.5	\$3.2
Extending life of parts replacement	\$0.0	\$0.0	\$0.3	\$0.0	\$0.0
Total	\$1.2	\$1.2	\$2.1	\$2.0	\$3.2
Allocation to Distribution (67%)	0.8	0.8	1.4	1.3	2.2

#### Assumptions

OM&A Savings: Blended avg. maintenance cost per unit for Light and Misc. vehicles (Annual) = \$16,000 Savings anticipated from Fuel Savings in Speeding & Harsh event reduction - \$500K/year (Based on 2017 estimate), due to Driver behavior modification

Additional one-time saving of \$300K for maintenance through optimizing asset maintenance efficiency/extending life of parts replacement

#### Notes:

The table above represents the original savings targets. In 2017 all committed savings were allocated to 'Fuel Savings Estimate' to correspond with approved tracking methodology.

2
Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 8 of 9

# 1 Calculation Methodology - 2018

2 Encompassing all of Hydro One's vehicles across the province, savings are achieved

3 through rationalization and improvement in driver behavior via the use of telematics to

- determine areas of consolidation and reduction of overall footprint. Savings are
   calculated as:
  - calculated as.

$$Savings = \left[ \left(\frac{B}{A}\right) - C \right] \times D$$

6

7 Where:

8 9

A: Average kilometers per litre of fuel for 2016 (used as baseline year)

B: Total kilometers in 2018

- 11 C: Total litres of fuel in 2018
- <sup>12</sup> D: Average 2018 fuel cost per liter from ARI Reports<sup>1</sup>
- 13

# 14 **Telematics - Capital - Background**

The Fleet Right-Sizing Initiative leverages telematics data to identify all underutilized vehicles and remove all excess vehicles from service. The equipment complement has been reduced by 10% in 2017 and will be maintained at the new optimal level going forward. The goal is to have the right equipment and the right number of equipment to

<sup>19</sup> successfully execute the work programs and satisfy all customer staffing requirements.

<sup>&</sup>lt;sup>1</sup> Data provided by ARI Global Feet Management Services, ARI Fleet Management System and Fuel Reports

Filed: 2018-06-15 EB-2017-0049 Exhibit J 2.3 Page 9 of 9

# 1 Target Setting Methodology

2

	2018	2019	2020	2021	2022
Baseline	59.70	59.70	59.70	59.70	59.70
Updated Business Plan	39.72	44.59	45.10	45.41	45.76
Savings	19.98	15.11	14.60	14.29	13.94
Savings allocated to Distribution (67%)	13.4	10.1	9.8	9.6	9.3
<b>Baseline Replacement Units</b>	805	805	805	805	805
New Plan Units	503	473	473	473	473
	0.050	0.004	0.005	0.004	0.00
New Plan Cost/unit	0.079	0.094	0.095	0.096	0.097
Baseline Cost/Unit	0.074	0.074	0.074	0.074	0.074

3

### 4 <u>Calculation Methodology</u>

5 Baseline capital replacement plan (monthly) is compared to actual Capital replacement.

<sup>6</sup> The variance to baseline in actual units and actual cost per unit is quantified to determine

7 savings.

8

# 9 Other Initiatives

10 A similar framework is used when setting the anticipated targets and determining a

calculation methodology for quantifying the benefits of the other initiatives.

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 136 Page 1 of 4

1		<b>OEB INTERROGATORY #136</b>
2		
3	Re	ference:
4	EB	-2018-0098, Exh B/Tab 7/Sch 1/p.1, Table 1
5		
6	Int	errogatory:
7 8	a)	The original cost estimate for the "10 MVAr reactive support" project component was \$4 million. What is the current estimate for this component?
9 10 11 12	b)	The original cost estimate for the "10 MVAr capacitive support" project component was \$2 million. What is the current estimate for that component?
13 14 15 16	c)	What was the initial estimate quality associated with each of these components, using the AACE estimate classification system and also expressed in terms of +/- percentage range?
17 18 19	d)	What is the present estimate quality for each of these components using the same system?
<ol> <li>20</li> <li>21</li> <li>22</li> <li>23</li> <li>24</li> <li>25</li> </ol>	e)	Does the updated estimate include other incremental substation components that cannot be classified as either reactive support or capacitive support and cannot be attributed prorata to either of those primary project components? Please provide details of all such unattributed project components and explain why they are now required to satisfy the IESO's functional specifications for the KAR project.
26 27 28	f)	Did Hydro One inform the OEB of the initial estimate quality and range when the LTC application was submitted?
29 30 31	g)	Did Hydro One inform the OEB of the present estimate quality and range when submitting the revised cost estimates in March 2019?
32 33 34	h)	Please provide a detailed description of all site-specific and non-site-specific factors that were considered when Hydro One developed the initial reactive and capacitive support project component estimates.

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 136 Page 2 of 4

What new information became available following the initial LTC application i) 1 regarding each of these project components that informed the cost variances 2 identified in the revised estimates filed with the OEB in March 2019? 3 4 What additional design and procurement work has been done between the time the j) 5 initial LTC application was submitted and the issuance of the revised cost estimate? 6 7 k) Has project scope changed since the initial cost estimate? 8 i. If yes, what triggered the scope change? 9 ii. If yes, were all changes authorized through Hydro One's project management 10 process? 11 12 1) What are the detailed drivers that caused the variance between the initial and revised 13 cost estimates? 14 15 m) Did Hydro One originally estimate the substation component additions as if this was a 16 greenfield project, or was the initial estimate developed with the understanding that 17 this is a brownfield renovation-type project? 18 19 n) Would Hydro One consider it to be good utility practice to develop a brownfield 20 construction estimate using greenfield construction site assumptions? 21 22 o) Did Hydro One apply the same level of estimate diligence and expertise to estimating 23 costs for the substation components as it applied to estimating the line component 24 costs? If no, please explain why not. 25 26 p) What would Hydro One do differently in preparing and submitting a Leave to 27 Construct application for a similar facility today? 28 29 **Response:** 30 a) The current Class 3 cost estimate provided to the OEB in March 2019 was \$17.3 31 million and included the installation of both reactor and capacitor bank. Individual 32 cost estimates for reactive and capacitive devices were not prepared as both devices 33 were required. 34 35 36 b) Please see response to part (a) above.

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 136 Page 3 of 4

1	c)	As documented in the LTC Application for this Project, the initial estimate quality of
2		the station component of this investment was referenced as being preliminary in
3		nature, and made no reference to an AACE or accuracy range.
4	(L	The summent estimate quality for the station component is AACE Class 2 with an
5	a)	The current estimate quality for the station component is AACE Class 5 with an $200\%$ to $\pm 200\%$
6		accuracy 01 - 20% 10 + 50%.
7		The current estimate provided to the OEP in March 2010 does not include
8	6)	incremental facilities or substation components beyond those required to meet IESO
9		requirements
10		requirements.
12	f)	Please see response to part (c) above.
13		
14	g)	In the March 2019 letter the OEB was informed that, "detailed estimating and field
15		verification has unearthed the need for increased scope of work to accommodate the
16		new reactive facilities beyond what would normally be expected in a project of this
17		scale." Hydro One's detailed estimate terminology refers to AACE Class 3 estimates
18		(-20% to +30%).
19		
20	h)	At the time of preparing the initial estimate, there were no site specific factors
21		anticipated. The non-site specific factor related to the installation of shunt capacitor
22		bank and reactor.
23		
24	i)	In the March 2019 letter to the OEB, details were provided on the new information
25		that resulted in the cost variances. As noted in the letter, "detailed estimating and
26		field verification has unearthed the need for increased scope of work to accommodate
27		the new reactive facilities beyond what would normally be expected in a project of
28		this scale. Site specific conditions led to increased scope in the following areas:
29		relocation of the existing low voltage capacitor bank, extension of the control
30		building, increased grounding required, and increased cable trench / civil work."
31	• `	
32	j)	Between the initial estimate and revised cost notification to the OEB, design work
33		necessary to prepare detailed estimates was carried out. There were no procurement
34		activities during this time.
35	1-)	Devices soons for both the line and station remains we shared and in line with UCO.
36	к)	Project scope for both the line and station remains unchanged and in line with IESOs
37		requirements.

Witness: Robert Reinmuller, Bruno Jesus, Donna Jablonsky

Filed: 2019-08-02 EB-2019-0082 Exhibit I Tab 01 Schedule 136 Page 4 of 4

- 1 l) Please see response to part (i) above.
- 2 3

m) Hydro One developed the initial estimate with the understanding that Kapuskasing TS is an existing station but will have new facilities installed within the existing site.

4 5

n) Hydro One does not classify estimates as brownfield or greenfield. Estimates are
developed based on the purpose required. Initial estimates would be of a preliminary
or budgetary type and are developed based on a high level review of the site, review
of cost of similar project, and input from staff. These estimates would be refined and
accuracy improved as further detailed engineering is done and more information
becomes known.

12

o) At the time of LTC Application, the line work was a detailed estimate, and station
 work estimate was preliminary in nature. The LTC Application was filed with the
 information available at the time due to the timing of the project to ensure sufficient
 time for the line work to be executed in order to satisfy the IESO's requested in service date.

18

p) Hydro One would endeavor to submit detailed estimates as part of its LTC
 Application, provided that sufficient time is available between the IESO request and
 the specific need date.

Hydro One Networks Inc. 7<sup>th</sup> Floor, South Tower 483 Bay Street Toronto, Ontario M5G 2P5 www.HydroOne.com Tel: (416) 345-5393 Fax: (416) 345-6833 Joanne.Richardson@HydroOne.com



Joanne Richardson Director – Major Projects and Partnerships Regulatory Affairs

## BY COURIER

March 18, 2019

Ms. Nancy Marconi Manager, Supply and Infrastructure Applications Ontario Energy Board Suite 2700, 2300 Yonge Street Toronto, ON M4P 1E4

Dear Ms. Marconi:

# EB-2018-0098 – Hydro One Networks Inc.'s Section 92 - Kapuskasing Area Reinforcement Project – Project Update

In accordance with the Decision and Order in the aforementioned proceeding, Hydro One Networks Inc. ("Hydro One") is writing to inform the OEB of a change in the in-service date and cost of the Kapuskasing Area Reinforcement Project ("KAR Project" or "the Project").

As documented in Exhibit B, Tab 3, Schedule 1 of the prefiled evidence, the station cost component of the KAR Project was in the budgetary estimating phase of a project lifecycle. Since the leave to construct approval of the Project, detailed estimating and field verification has unearthed the need for increased scope of work to accommodate the new reactive facilities beyond what would normally be expected in a project of this scale.

Site specific conditions led to increased scope in the following areas:

- Relocation of the existing low voltage capacitor bank
- Extension of the control building
- Increased grounding required
- Increased cable trench / civil work

Hydro One has confirmed the design has not been overbuilt nor does it accommodate work outside of the direct scope documented in the IESO need evidence for the leave to construct application provided at Exhibit B, Tab 3, Schedule 1, Attachment 1 of the Application.

As a result of the increased station scope, the overall project cost estimate, provided at Exhibit B, Tab 7, Schedule 1 of the prefiled evidence, of approximately \$21.07M (\$15.07M in lines costs and \$6M in station costs) has increased. The new estimate to complete the project is



approximately \$32.1M (\$14.8M in lines costs and \$17.3M in station costs). The breakdown of this cost, in a manner analogous to that originally provided in Exhibit B, Tab 7, Schedule 1 of the prefiled evidence is provided as Attachment 1 of this correspondence. Additionally, as a result of the increased scope, the schedule for the Project originally provided in Exhibit B, Tab 11, Schedule 1, has also been revised. The updated schedule is provided as Attachment 2 of this correspondence and results in a five month delay in the in-service of the H9K line.

Hydro One has circled back with the IESO to confirm that the installation of a capacitor bank and reactor remains the preferred solution and, as Hydro One understands, the IESO maintains this position.

If you have any further questions or concerns, please contact Pasquale Catalano via email at regulatory@Hydroone.com or by phone at 416-345-5405.

An electronic copy of this correspondence has been filed through the Ontario Energy Board's Regulatory Electronic Submission System.

Sincerely,

ORIGINAL SIGNED BY JOANNE RICHARDSON

Joanne Richardson

Attach.



## Attachment 1 Table 1: Project Cost

	Estimated Cost
	(\$000's)
Materials	3,059
Labour	5,389
Equipment Rental & Contractor Costs	3,400
Sundry	400
Contingencies	700
Overhead <sup>1</sup>	1,534
Allowance for Funds Used During Construction <sup>2</sup>	334
Total Line Work	\$14,816
Materials	2,962
Labour	5,718
Equipment Rental & Contractor Costs	4,208
Sundry	450
Contingencies	1,498
Overhead <sup>3</sup>	1,725
Allowance for Funds Used During Construction <sup>4</sup>	783
Total Station Work	\$17,344
TOTAL PROJECT WORK	\$32,160

<sup>&</sup>lt;sup>1</sup> Overhead costs allocated to the project are for corporate services costs. These costs are charged to capital projects through a standard overhead capitalization rate. As such they are considered "Indirect Overheads". Hydro One does not allocate any project activity to "Direct Overheads" but rather charges all other costs directly to the project.

<sup>&</sup>lt;sup>2</sup> Capitalized interest (or AFUDC) is calculated using the Board's approved interest rate methodology (EB-2006-0117) to the projects' forecast monthly cash flow and carrying forward closing balance from the preceding month.

<sup>&</sup>lt;sup>3</sup> Overhead costs allocated to the project are for corporate services costs. These costs are charged to capital projects through a standard overhead capitalization rate. As such they are considered "Indirect Overheads". Hydro One does not allocate any project activity to "Direct Overheads" but rather charges all other costs directly to the project.

<sup>&</sup>lt;sup>4</sup> Capitalized interest (or AFUDC) is calculated using the Board's approved interest rate methodology (EB-2006-0117) to the projects' forecast monthly cash flow and carrying forward closing balance from the preceding month.



Attachment 2

TASK	START	FINISH				
Submit Section 92		February 2018				
Projected Section 92 Approval		August 30, 2018				
LINES						
Detailed Engineering	March 2018	May 2019				
Procurement	July 2018	June 2019				
Receive Material	September 2018	June 2019				
Construction	June 2019	March 2020				
IN SERVICE		24 March 2020				
STATIONS						
Detailed Engineering	November 2018	November 2019				
Procurement	May 2019	November 2019				
Receive Material	June 2019	March 2020				
Construction	May 2019	January 2021				
IN SERVICE		21 January 2021				