

REF: Exhibit B / Tab 1 / Sch. 1 / pg. 2

Preamble: EGI's evidence states: *"There are a number of other factors related to its condition that are equally as relevant when considering the need for replacement. Such factors include:*

- *History of leakage with significant costs to repair*

We would like to understand better this history.

- 1) Please provide recent repair history including amount of time between detection, category and repair and cost.

REF: Exhibit B / Tab 1 / Sch. 1 / pg. 3

Preamble: We would like to understand better how EGI is mitigating any risks associated with the higher operating pressure.

- 2) Are there or will there be any sources of moisture into the new 3450kPa pipe (e.g., local production, etc.? Please explain.
- 3) How will EGI mitigate risk of freeze off at the initial pressure cut?

REF: Exhibit B / Tab 1 / Sch. 5 / pg. 1

Preamble We would like to understand better the scale and scope of this project in relation to the capital budget of the legacy Union territory.

- 4) Please provide:
 - a) The replacement capital budget for 2020
 - i) The top 5 projects by project estimate
 - b) The actual replacement capital for the years 2014-2018
 - i) The top 5 projects by actual expenditures for each year

REF: Exhibit B / Tab 1 / Sch. 5 / pg. 3

Preamble: We would like to understand better the impact of the new services on the project.

- 5) How many new services will be added? What is the cost estimate for the new services portion of the project?

REF: Exhibit C / Tab 1 / Sch. 1 / pg. 1

Preamble: We would like to understand better the pipeline network that supplies the area.

- 6) Please re-create this map showing all surrounding and interconnected pipelines.
 - a) Please provide the size, Maximum and Minimum operating pressures and flow direction of those lines.

REF: Exhibit C / Tab 2 / Sch. 1 / pg. 1

- 7) Provide the other pipelines, sizes, locations, directions of flow and MOP's including non-Enbridge pipelines. Please show the design day forecasted pressures upstream and downstream of inter-connects between pipelines for the winter of 2019/20.

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 5

- 8) Please confirm that the temperature of 25.1 is actually minus 25.1.

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 6

- 9) Please provide the design day flows at the respective connections and distribution stations on the line.

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 10

- 10) Please provide the simulated pressures vs. actual pressure at the distribution stations and interconnections from the verification process.

- 11) Please provide the flow capacity to Leamington before and after the replacement to 3450 kPa.

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 12

- 12) Was NPS 4 evaluated? If not, why not? If so, please provide the distribution station pressures:

- i) with current design
- ii) with current design replacing the "Remaining Pipeline" as NPS 6

- 13) What is the cost differential of NPS 4 vs. NPS 6?

- 14) Did EGI evaluate a hybrid of NPS 6 in some sections and NPS 4 in others?

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 16

- 15) Using a NPS 4 for the entire project and the forecast in Appendix 2, in what year would the pressures reach inadequate levels?
- a) Leaving the new proposed pipe as NPS 4 as the majority, how much NPS 6 would be needed to extend the capacity to meet the forecasted additions in Appendix 2?

REF: Exhibit C / Tab 3 / Sch. 1 / pg. 23 / App. 1

- 16) Please add the cost of NPS 4 and the combined NPS 6 and NPS 4 to the table.