

Hydro One Networks Inc.

7th Floor, South Tower
483 Bay Street
Toronto, Ontario M5G 2P5
www.HydroOne.com

Tel: (416) 345-5393
Fax: (416) 345-6833
Joanne.Richardson@HydroOne.com



Joanne Richardson

Director, Major Projects and Partnerships
Regulatory Affairs

BY COURIER

January 09, 2020

Ms. Christine E. Long
Board Secretary
Ontario Energy Board
Suite 2700, 2300 Yonge Street
P.O. Box 2319
Toronto, ON M4P 1E4

Dear Ms. Long:

EB-2018-0117- Hydro One Networks Inc.'s Section 92 – Barrie Area Transmission Upgrade Project – Interrogatory Responses

Please find attached Hydro One Networks Inc.'s responses to interrogatories received in the above-noted proceeding as part of Procedural Order No.1 dated December 6, 2019.

An electronic copy of this has been filed through the Ontario Energy Board's Regulatory Electronic Submission System (RESS).

Sincerely,

ORIGINAL SIGNED BY JOANNE RICHARDSON

Joanne Richardson

1 **OEB STAFF INTERROGATORY #1**

2
3 **Reference:**

4 Exhibit B/Tab 1/Schedule 1/Attachment 1/p. 1

5 Exhibit B/Tab 3/Schedule 1/Attachment 2/Integrated Regional Resource Plan/pp. 14,
6 35, 53

7 Exhibit B/Tab 3/Schedule 1/Attachment 2/Integrated Regional Resource Plan/Appendix
8 A, p. 70, Table A-10; Appendix B, p. 89, Table B-2

9 Exhibit B/Tab 3/Schedule 1/Attachment 3/Regional Infrastructure Plan/p. 39, Appendix
10 C and D

11
12 **Interrogatory:**

13 The application indicates that the Barrie Transformer Station (TS) limited time rating
14 (LTR) will be exceeded in 2022. The load forecasts in the Integrated Regional
15 Resource Plan (IRRP) have been revised in the Regional Infrastructure Plan (RIP). The
16 RIP indicates lower actual 2014 load demand and lower forecast 2015 to 2034 load
17 demand than the IRRP.

18
19 Currently, six feeders in the Barrie TS are used to supply Alectra Utilities
20 Corporation (Alectra) and one feeder supplies InnPower Corporation
21 (InnPower). Based on the forecasts provided in the IRRP, the IRRP concluded
22 that InnPower will exceed its existing feeder load capacity of 25 MW by 2020.
23 It recommended that Hydro One Distribution and InnPower develop a plan to
24 uprate Barrie TS, build new 44 kV feeders to support InnPower's forecast
25 growth and enable the existing 13M3 feeder to be relocated out of the Hydro
26 One Transmission corridor.

27
28 Load forecasts for InnPower's service area indicate that the power demand in Innisfil
29 and South Barrie will grow by approximately 48 MVA in the next five years. The
30 Barrie Area Transmission Upgrade (BATU) Project will provide an estimated
31 additional 36 MVA of supply to InnPower.

32
33 **Questions:**

34 a) Please provide the following information for the Barrie TS:

- 35 i. An updated demand forecast for the Barrie TS that shows both 5 year historical
36 and 20 year forecast demand.

- 1 ii. Please confirm that the Barrie TS remains a summer peaking station.
2 iii. When will the Barrie TS LTR be exceeded based on the most recent load
3 forecasts?
4 iv. Are these forecasts consistent with the IRRP and RIP? If they differ, please
5 explain.
6
7 b) Please confirm that the Alectra Load Transfer from Barrie TS to Midhurst TS has
8 occurred. If so, please confirm the date in which it occurred.
9
10 c) Please confirm that there was no option to transfer InnPower's load growth to
11 another station, which would avoid the need to upgrade Barrie TS.
12
13 d) Please explain the impact of Alectra not needing capacity on the project, including
14 the need date.
15
16 e) Please provide a five year historical load plus 20 year forecast of load for Barrie TS.
17 For each year, please provide a breakdown of each utilities' load supplied by Barrie
18 TS. Please explain any significant year-to-year changes in the forecast.
19
20 f) Please provide the load forecast for InnPower on the existing and new feeder
21 positions at the Barrie TS.
22
23 g) Please provide any updates to the planning information provided in the pre-filed
24 evidence including the impact of the latest provincial conservation targets.
25
26 h) Please provide any updates on the progress of the 13M3 feeder relocation out of the
27 Hydro One Transmission corridor.
28

29 **Response:**

- 30 a)
31 i. The most recent Barrie TS forecast is the same one that was used to run the
32 Economic Evaluation in this Section 92 application. The forecast is provided in
33 the Table 1 below.

Table 1 – Historical and Forecast Barrie TS Load

	Historical						Forecast -->						
Year	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
Load (MW)	112	95*	98*	90*	120	115	112	119	128	137	140	140	140
	---> Forecast												
Year	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039
Load (MW)	140	140	140	140	140	140	140	140	140	140	140	140	140

*Load transfers and cooler than normal summers resulted in historical load values in 2015-2017 that were lower than normally expected.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33

- ii. Confirmed. The Barrie TS remains a summer peaking station.
- iii. Based on the most recent historical data, the Barrie TS summer Limited Time Rating (“LTR”) 103.5 MW based on a 0.9 power factor has already been exceeded and the forecast values, in response Part (a) (i) above show that the station LTR will continue to be exceeded.
- iv. The forecast provided in response to Part (a) (i) above differs from those used in the IRRP and RIP because Alectra revised its load forecast at Barrie TS resulting in Alectra not exceeding their assigned capacity at Barrie TS. Any additional Alectra load growth will be supplied by Midhurst TS, where Alectra has spare capacity available at that station. Additionally, during this time, InnPower also provided an updated forecast (in March 2019) to Hydro One as they received more information on development in the South Barre/Innifil area. As a result, InnPower’s forecast increased from that provided in the IRRP and RIP.

b) Alectra provided the following update to Hydro One, via email, on December 17, 2019. The below is an extract from that communication;

“The planned transfer by the legacy PowerStream (now Alectra Utilities) of 27MW of load from Barrie TS to Midhurst TS has not yet occurred. As described in the December 16, 2016 Barrie/Innisfil Sub-Region IRRP (Ex B-3-1 Attachment 2 Page 13), legacy PowerStream planned to transfer load from Barrie TS to Midhurst TS by 2020 should full data centre load growth materialize. As of December 2019, the load growth of the data centres has not fully materialized and thus, the need to transfer load has not yet materialized. Alectra Utilities has installed the necessary tie-in switches in December 2017

1 *and October 2018 to enable the transfer and will*
2 *continue to monitor the load growth of data centres to*
3 *determine the need to transfer load from Barrie TS to*
4 *Midhurst TS as required.”*
5

6 c) InnPower has confirmed there is no other viable option to transfer InnPower’s load
7 growth to another station without incurring significant voltage issues along other
8 feeders, and/or capacity issues at the closest alternate transformer stations (i.e.
9 Everett TS and Alliston TS). The BATU Project is necessary to meet the mid-term
10 needs of InnPower by increasing its supply out of Barrie TS. The Project will be
11 pivotal for the future extension of 230 kV transmission line into Innisfil to address
12 future load growth. This upgrade and associated mid to long-term plans are
13 consistent with the recommendations of the Barrie/Innisfil sub-region regional
14 planning process.

15
16 d) Although Alectra has indicated it does not need additional capacity at Barrie TS, the
17 immediate capacity need at the station still exists since the Barrie TS LTR has
18 already been exceeded several times. The forecast, provided in response to part (a)
19 (i) above still supports the immediate need for additional capacity. The long-term
20 capacity need at the upgraded Barrie TS (indicated in IRRP to occur in 2026, and in
21 RIP to occur in 2031) will likely be delayed due to Alectra’s lack of capacity needs,
22 and there will likely be spare capacity available at Barrie TS for new customers
23 seeking to connect in the area.

24
25 e) Historical and forecast Barrie TS peak load, split by utility, is provided in the Table
26 below. The abnormally high historical loading on the InnPower feeder at Barrie TS
27 in 2018 was due to temporary load transfers that were required to facilitate
28 distribution work on feeders normally supplied by neighbouring stations. The
29 slightly higher-than-normal historical loading for InnPower in 2017 and 2018 was
30 also due to similar temporary load transfers. InnPower’s actual peak at Barrie TS in
31 2019 was 11 MW, however its load was 9 MW at the time when Barrie TS hit its
32 peak of 115 MW. Based on development plans in the South Barrie and Innisfil area,
33 InnPower load is expected to grow significantly over the next 5 to 10 years.

34
35 The load forecast portion of Table 2 shows the non-coincident peaks that each LDC
36 is expecting to reach without load transfers.

1 **Table 2 – Historical and Forecast Barrie TS Load – Split by Utility**

Year	Historical						Forecast -->						
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
InnPower Load (MW)	11	5	18	18	32	9	22	29	38	46	50	50	50
Alectra Load (MW)	101	90	80	72	88	106	90	90	90	90	90	90	90
Barrie TS Load (MW)	112	95	98	90	120	115	112	119	128	137	140	140	140
---> Forecast													
Year	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039
InnPower Load (MW)	50	50	50	50	50	50	50	50	50	50	50	50	50
Alectra Load (MW)	90	90	90	90	90	90	90	90	90	90	90	90	90
Barrie TS Load (MW)	140	140	140	140	140	140	140	140	140	140	140	140	140

2

3 f) The most recent InnPower forecast for Barrie TS (updated in March 2019), as
 4 shown in Table 2 above is the same forecast load Hydro One used to run the
 5 Economic Evaluation in this Application. Up to mid-2022, the forecast InnPower
 6 load will be supplied by the one existing Barrie TS feeder, and any over-loading up
 7 to this point will be addressed through temporary load transfers. Following the in-
 8 servicing of the BATU Project in June 2022, the forecast InnPower load will be
 9 able to be supplied by two Barrie TS feeders. Typically, 44kV feeders have a
 10 capacity of 25 MW and once the second Barrie TS feeder is available for InnPower,
 11 exact feeder loading will be an InnPower exercise done at a later date.

12

13 g) The planning information provided in the pre-filed evidence is up-to-date and
 14 reflects the most recent information from all stakeholders involved.

15

16 With respect to provincial conservation targets, in March 2019, the Minister of
 17 Energy, Northern Development and Mines directed the IESO to immediately
 18 discontinue the 2015-2020 Conservation First Framework and implement a new
 19 Interim Framework with a centrally delivered program offering until December 31,
 20 2020. As a result, the long-term province-wide conservation target of 30 TWh by
 21 2032 described in the 2015 IRRP is no longer in effect.

22

23 Compared to the 2016 Barrie/Innisfil IRRP, the update to the long-term provincial
 24 conservation target is expected to only affect the energy efficiency programs

1 portion of the conservation savings forecast beyond 2020. The estimated impact of
2 the update as mentioned above is an increase in the Barrie TS planning forecast of
3 nearly 12 MW by the end of 2034 (which represents the end of the IRRP forecast
4 period). The need for the Project remains and this additional load will be assessed in
5 future cycles of Regional Planning.

6

7 h) Hydro One Distribution has requested an estimate for the 13M3 feeder relocation.
8 The design is expected to be completed by November 2020. Once completed,
9 Hydro One Distribution will work through the agreement with InnPower based on
10 the cost estimate and release the work for construction in 2021. The expectation is
11 that the feeder will be relocated by end of 2021 to be ready for the targeted in-
12 service date of the BATU Project, which is June 2022.

1 **OEB STAFF INTERROGATORY #2**

2
3 **Reference:**

4 Exhibit B/Tab 3/Schedule 1/Attachment 1/pp. 3-4

5 Exhibit B/Tab 3/Schedule 1/Attachment 2/p. 39

6 Exhibit B/Tab 9/Schedule 1/p. 6

7
8 **Interrogatory:**

9 The application states that the existing 115/44 kV transformation facilities at Barrie TS
10 are nearing end-of-life and have reached capacity. Likewise, circuits E3B and E4B,
11 which supply Barrie TS, are nearing end-of-life and are expected to exceed their load
12 meeting capability in the near-term. Furthermore, the 115 kV switchyard and the T1
13 230/115 kV auto-transformer at Essa TS that supply circuits E3B and E4B have already
14 exceeded their expected life.

15
16 The application asserts that development of the annexed lands in South Barrie, the
17 continued development of data centres in the City of Barrie and forecast growth in the
18 Town of Innisfil, including the proposed industrial and commercial development of
19 Innisfil Heights, contribute to the forecast growth.

20 Due to changing load growth in the area since the RIP, Alectra indicated that it no longer
21 required incremental capacity.

22
23 **Questions:**

24 a) Please describe the impact on reliability for Barrie TS and for the feeders supplied
25 from it in the event that the new 230 kV circuits, E28 and E29, are not available.

26
27 b) Please provide information on any plans that Hydro One has for connecting additional
28 stations to E28 and E29 or otherwise utilizing the 230 kV capacity of the line.

29
30 c) Please comment on the status of the anticipated developments in the South Barrie and
31 Innisfil areas, and discuss implications with regard to the BATU Project.

32
33 **Response:**

34 a) In the extremely rare event that both new 230kV circuits are not available, supply to
35 Barrie TS will be lost. Barrie TS has low voltage load transfer capability with
36 Midhurst TS and Alliston TS and thus load transfers will occur to temporarily restore

1 power to the affected loads until at least one of the 230kV circuits is restored into
2 service.

3

4 b) To the best of Hydro One's knowledge, Metrolinx is planning on building an
5 electrification station (which will be known as the 'Allandale Traction Power
6 Station') in the near future that will be supplied directly from this Project's new
7 230kV line and utilize capacity of the line.

8

9 To the best of Hydro One's knowledge, InnPower is considering to build a new
10 transformer station in the next 5-10 years that will also be supplied from this Project's
11 new 230kV line and utilize capacity of the line.

12

13 c) Hydro One confirmed with InnPower that commercial and industrial development has
14 occurred in both South Barrie and Innisfil and is expected to continue in 2020. As per
15 the most recent forecast, InnPower will start exceeding its single feeder capacity of
16 25MW at the existing Barrie TS in 2021, therefore the need for additional supply
17 must be addressed as soon as possible. Regardless of any new development in the
18 area, the need for additional capacity at Barrie TS is urgent. The station has already
19 peaked above its Limited Time Rating on several occasions over the past two years
20 and is anticipated to continue to do so in the future. Should the BATU project not
21 proceed, InnPower will have major issues in supplying its forecast load past the year
22 2022.

1 **OEB STAFF INTERROGATORY #3**

2
3 **Reference:**

4 Exhibit B/Tab 3/Schedule 1/Attachment 1/pp. 16, 43, 97
5 Exhibit B/Tab 3/Schedule 1/Attachment 2/p. 39
6

7 **Interrogatory:**

8 Metrolinx is planning to electrify the Barrie GO train lines and has approached Hydro
9 One, requesting 40-50 MW of capacity. The new 230 kV circuits from Essa TS to Barrie
10 TS would provide adequate capacity and tapping positions for Metrolinx's substation,
11 however, the supply capacity at Essa TS may present some limitations.
12

13 **Question:**

14 a) Please comment on the status of the Metrolinx Electrification Plans for the Barrie
15 Area and discuss implications with regard to the BATU Project.
16

17 **Response:**

18 a) The Metrolinx electrification is part of the Government of Ontario Regional Express
19 Rail ("RER") expansion program. The scope and timing of these Traction Power
20 Station projects will be determined by the successful bidder that Metrolinx will select
21 to undertake the RER project. Metrolinx issued a Request for Qualifications on April
22 3, 2018, and prequalified teams were selected on May 30, 2019 (see links below). To
23 Hydro One's knowledge the selection process remains ongoing.
24

25 Whether or not Metrolinx's electrification plans materialize the need for the BATU
26 project still exists. On the other hand, if the BATU project does not proceed, there
27 will not be sufficient capacity available to supply Metrolinx, or to address the
28 additional non-Metrolinx related capacity needs in the Barrie/Innsfil area.
29

30 More information please refer to the following:

31 [https://www.infrastructureontario.ca/Request-for-Qualifications-Issued-RER-GO-
32 Regional-Express-Rail-Corridor/](https://www.infrastructureontario.ca/Request-for-Qualifications-Issued-RER-GO-Regional-Express-Rail-Corridor/)
33

34 Information regarding the status can be found at the following link;

35 [https://www.infrastructureontario.ca/RER-GO-Regional-Express-Rail-
36 Corridor/#pDetailStatus](https://www.infrastructureontario.ca/RER-GO-Regional-Express-Rail-Corridor/#pDetailStatus)

1 **OEB STAFF INTERROGATORY #4**

2
3 **Reference:**

4 Exhibit B/Tab 3/Schedule 1/Attachment 1/p. 1

5 Exhibit B/Tab 5/Schedule 1/pp. 1-4

6
7 **Interrogatory:**

8 The IESO letter states that based on the timeline and magnitude of the urgent need to
9 replace infrastructure nearing its end-of-life and to provide supply capacity for the
10 Barrie/Innisfil area, it will not be feasible to address the transmission line supply need
11 and transformation capacity need through additional conservation and local generation. A
12 wires option has been determined to be the only feasible option. The IESO recommended
13 replacing the existing Barrie TS and the E3B/E4B transmission line with new 230 kV
14 infrastructure.

15 The application states that three transmission alternatives were considered for the project.
16 Alternative 3, which recommends rebuilding Barrie TS to 230 kV supply, is the preferred
17 alternative. This option addresses the near-term and medium-term capacity needs,
18 removes an aging 115 kV switchyard at Essa TS, allows for future expansion capability
19 to supply the region's long-term capacity needs, and satisfies the IESO's Ontario
20 Resource and Transmission Assessment Criteria.

21
22 **Questions:**

- 23 a) The evidence indicates that the IESO recommends an integrated solution, comprising
24 conservation and additional transmission and distribution facilities to meet the
25 growing demand. Please comment on or provide any information which demonstrates
26 the IESO's support for Hydro One's specific proposed solution since Alectra has
27 withdrawn from the project.
- 28
- 29 b) Please explain the methodology to determine that facilities are at end-of-life and
30 provide the information that was used to determine end-of-life for this project.
- 31
- 32 c) Please explain how and when facilities transition from near end-of-life status to end-
33 of-life status, including Barrie TS transformers and E3B circuit.

- 1 d) In the evaluation of Alternative 1, was distributed generation considered to increase
2 capacity? What is the impact of distributed generation and conservation on the
3 viability of Alternative 1?
4
- 5 e) Please provide the cost of the line losses for Alternative 2.
6
- 7 f) Please provide an updated cost estimate for Alternative 3, if the estimate has changed
8 from that provided in the application.
9
- 10 g) Was replacing only the end-of-life E4B circuit with a 230 kV line to provide a dual
11 115/230 kV supply to Barrie TS considered? If not, please explain.
12
- 13 h) Please provide information on any other alternatives that were considered for meeting
14 the forecast growth in the Barrie/Innisfil area, but were rejected.
15

16 **Response:**

- 17 a) The following response was provided to Hydro One by the IESO to assist with
18 answering this part (a) of the interrogatory.
19

20 The 2016 Barrie/Innisfil Sub-region IRRP provides recommendations to address the
21 sub-region's forecast electricity needs over the next 20 years, based on the application
22 of the IESO's Ontario Resource and Transmission Assessment Criteria ("ORTAC").
23 Electricity needs come in different forms such as: equipment capacity, load
24 restoration, and equipment end-of-life. The proposed solution primarily addresses the
25 end-of-life ("EOL") needs at Barrie TS and components of its 115 kV supply
26 infrastructure. In addition, the net demand growth in the southern portion of the City
27 of Barrie and in the Town of Innisfil is forecast to exceed the supply capacity of both
28 Barrie TS and the 115 kV supply circuits to the station in the near term. While
29 Alectra's departure from the project has released additional capacity which is of value
30 in the future (since load in the area is growing), the EOL and capacity needs
31 identified remain and must still be addressed. Given that the EOL and capacity needs
32 remain, IESO is in support of the proposed solution consistent with the
33 recommendations from the 2016 Barrie/Innisfil Sub-region IRRP.
34

- 35 b) Hydro One performs a continuous asset risk assessment ("ARA") process to
36 determine individual asset needs, which includes the determination of end-of-life, and
37 relies on asset condition data, engineering analysis and other information including

1 the input of experienced electrical system planning professionals. The methodology
2 and inputs into this process are explained in detail as part of Hydro One's 2020-2022
3 Transmission Rate Application, Case EB-2019-0082, Exhibit B, Tab 1, Schedule 1,
4 Transmission System Plan Section 2.1.2.3. Specific asset condition assessment
5 information used for determining Essa TS and Barrie TS transformer end-of-life is
6 provided below in part (c).

- 7
- 8 c) Consistent with the response in part (b) above, the determination of an asset as end-
9 of-life is through verified condition information as obtained through Hydro One's
10 preventive and corrective maintenance programs. Hydro One uses the Expected
11 Service Life ("ESL") of assets as a general guideline to inform investment decisions.
12 The ESL is defined as the average time duration in years that an asset can be expected
13 to operate under normal system conditions and is determined by considering
14 manufacturer guidelines and Hydro One's historical asset retirement data. The ESL
15 is used as a fleet-wide parameter to inform investment decisions. Assets operating
16 beyond ESL generally have a higher likelihood of failing and/or are in poor condition
17 and therefore, generally, incur higher maintenance costs. The term End of Life is also
18 used and is defined as the likelihood of failure, or loss of an asset's ability to provide
19 the intended functionality, wherein the failure or loss of functionality would cause
20 unacceptable consequences. Therefore, while assets may be operating beyond ESL
21 they may not be at EOL.

22

23 Asset assessment information (current as of December 2019) used to determine end-
24 of life for the transformers at Barrie TS and Essa TS that relate to this project, is
25 shown below:

Table 1 - Barrie TS: T1&T2 Transformer Asset Risk Assessment Information

Risk	Asset	Asset Risk Index (ARI)				Asset Risk Assessment (ARA)	Comments
		Age	Demographics	Condition	Composite		
Equipment: Transformers	T1	57	100	75	40	High	<ul style="list-style-type: none"> • Assessment concludes the T1 has been approaching its expected service life, experiencing insulating material degradation per Dissolved Gas Analysis. • Oil leaks were reported from the transformer. • Tap changer is old model, showing operation defects. • Insulation oil quality is in an acceptable range. • T1 is a non-standard unit. • Recommend to replace the T1 in next 5 years to mitigate reliability risk, environmental risk, and lower lifecycle cost.

1
2

	T2	57	100	71	38	Very High	<ul style="list-style-type: none"> • Assessment concludes the faulty gases were detected in the T2 main tank, indicating electrical discharge activities have been occurring. • Tap changer was old model, and multifold issues were reported including dysfunction, burning contacts and high moisture contents. • T2 is a non-standard unit. • Oil leaks were reported on the transformer. • Recommend to replace the unit within next 5 years to mitigate reliability risk, environmental risk, and lower lifecycle cost.
--	----	----	-----	----	----	-----------	---

Table 2 - Essa TS: T1&T2 Transformer - Asset Risk Assessment Information

Risk	Asset	Age	Asset Risk Index (ARI)			Asset Risk Assessment (ARA)	Comments
			Demographics	Condition	Composite		
Equipment: Transformers	T1	66	100	78	45	Very High	<ul style="list-style-type: none"> • Assessment concludes the T1 has exceeded its expected service life, experienced insulating material degradation and has significantly aged. • There is a history of oil leaks from the transformer. • Subcomponents are obsolete and their operational integrities are deteriorating • T1 is a non-standard unit. • Recommend to replace the T1 within next 5 years to mitigate reliability risk, environmental risk, and lower lifecycle cost.
	T2	27	8	12	10	low	<ul style="list-style-type: none"> • Assessment concludes the T2 is currently in a good operational condition, and will be maintained as normal.

1 Regarding E3B: the conductor is 70 years old and in decent condition; the insulators
2 range from 69-71 years old; and the poles range from 69-71 years old and were last
3 assessed in 2015 as being in decent condition. Based on ESL statistics, the E3B assets
4 are expected to reach EOL within the next 10 years.

5
6 Regarding E4B: the conductor is 58 years old and in good condition; 65% of the
7 insulators are 58 years old; and 65% of the poles are 58 years old, most of which were
8 assessed as being in poor condition. Based on ESL statistics, most E4B assets are
9 expected to reach EOL with the next 10 to 20 years, however, the wood poles that are
10 in poor condition will likely need to be replaced in the next 2-5 years.

11
12 The remaining assets at Essa TS and Barrie TS, are due for replacement based on
13 Hydro One methodology; specifically Barrie 44 kV breakers due to performance &
14 utilization, and Essa 115 kV breakers due to relative age, maintenance costs, and
15 performance.

16
17 d) As indicated in the IRRP, large transmission-connected generation and small-scale
18 distribution-connected DG options were considered, however, they were ruled out as
19 viable alternatives for meeting both asset end-of-life and capacity needs in the
20 Barrie/Innisfil Sub-region. According to the IESO¹, while Alternative 1 meets the
21 end-of-life asset needs for the area, it would not result in incremental supply capacity
22 at Barrie TS or the 115 kV supply circuits from Essa TS needed to accommodate the
23 near term demand forecast at Barrie TS. The incremental cost of additional
24 distributed generation and conservation required to provide the required supply
25 capacity to accommodate the medium term demand forecast is estimated to be four
26 times higher in comparison to the incremental cost of Alternative 3.

27
28 e) Hydro One did not specifically calculate line losses for Alternative 2, given this
29 alternative's solution does not satisfy any long-term supply need criteria. However,
30 for perspective, a simple illustrative example is provided below which is indicative of
31 the magnitude of the results that could be expected:

¹ The IESO provided information to Hydro One to assist with the response to this part of the interrogatory

1 Line losses are calculated as:

2

3

$$\text{Equation (1): Losses in MW} = I^2 \times R$$

4

5

Where:

6

I = current in amperes

7

R = resistance of conductor in ohms

8

MW = Power (P)*

9

10

$$\text{Equation (2): *Power (P) is calculated as: } P = V \times I$$

11

12

Where:

13

V = voltage and,

14

I = current

15

16

17

18

19

20

21

22

23

24

25

26

With respect to equation (1): for a set amount of load (P), the higher the voltage (V) the lower the current (I). Specifically V and I are inversely proportional. To supply the same load (P) at different voltages, 44 kV or 230 kV for example, five times the current on a 44 kV system is required, compared to that on a 230kV system (assuming the same conductor size). At 44 kV voltage, the same amount of load would require five times the amperes required to supply, as compared to that under a 230 kV voltage system. Assuming the same conductor is used for both systems, the losses on a 44kV circuit system would be 25 times higher than losses on a 230 kV circuit system. The loss calculations for both voltage level systems are shown below, using the line loss equation (1):

27

This scenario is represented formulaically below:

28

$$\text{On the 230 kV system: } 230 \text{ kV Losses} = I^2 \times R = I^2R$$

29

$$\text{On the 44 kV system: } 44 \text{ kV Losses} = (5I)^2 \times R = 25 I^2 \times R = 25I^2R$$

30

31

Therefore, the total additional loss on the 44kV system, compared to the 230kV system with all other factors assumed to be equal, is a multiple of 25 times.

32

f) The BATU Project cost estimate has not changed from that provided in the prefiled evidence to this Application.

33

34

35

36

g) Replacing and/or converting only the E4B circuit with a 230 kV line while keeping E3B operating at 115 kV will result in not meeting the capacity need as the two

37

1 circuits would not be able to back each other up during contingencies as per ORTAC
2 criteria. Furthermore, replacing and/or converting only E4B to 230 kV does not
3 address the other end-of-life asset needs at Barrie TS and Essa TS, which is critical to
4 maintaining the reliability of supply to the load. Therefore, this option is not
5 considered a viable option.

6

7 h) All alternatives considered were included and identified in the IRRP.

1 **OEB STAFF INTERROGATORY #5**

2
3 **Reference:**

4 Exhibit B/Tab 3/Schedule 1/Attachment 2/p. 70

5
6 **Interrogatory:**

7 InnPower provides service to the Town of Innisfil, as well as lands annexed by the City
8 of Barrie in 2010. InnPower's distribution loads are supplied via ten distribution stations
9 which are supplied by five 44 kV feeders and four distribution feeders from Hydro One
10 owned distribution stations (i.e., Cookstown DS and Thornton DS); and three feeders
11 originating from Alliston TS, one from Barrie TS, and one from Everett TS. InnPower's
12 distribution voltages include 27.6 kV and 8.32 kV.

13
14 InnPower is currently a winter peaking utility. When accounting for diversity with the
15 other local distribution companies at the substation level, however, the stations supplying
16 InnPower are summer peaking. With anticipated growth from new developments and
17 changing demographics, InnPower expects to transition to summer peaking. As such,
18 InnPower has provided a summer peak forecast in-line with the sub-region's peak
19 demand needs.

20
21 **Questions:**

- 22 a) What proportion of the InnPower load is supplied from Barrie TS?
- 23
- 24 b) Please explain whether the load growth could be supplied from other Hydro One
25 feeders and distribution stations that currently supply InnPower instead of upgrading
26 Barrie TS.
- 27
- 28 c) When is InnPower expected to become a summer peaking utility?

29
30 **Response:**

- 31 a) Approximately 50% of InnPower's load is supplied from Barrie TS.
- 32
- 33 b) See response to Exhibit I, Tab 1, Schedule 1, Part (c).

Filed: 2020-01-09

EB-2018-0117

Exhibit I

Tab 1

Schedule 5

Page 2 of 2

- 1 c) InnPower has been a summer peaking utility since 2016, reaching a 2019 peak of 60
- 2 MW in the month of July. The last time InnPower peaked in the winter was in 2015,
- 3 reaching a peak of 51 MW in February.

1 **OEB STAFF INTERROGATORY #6**

2
3 **Reference:**

4 Exhibit B/Tab 9/Schedule 1/p. 1

5
6 **Interrogatory:**

7 The cost of the upgraded circuits will be included in the Line Connection Pool since these
8 circuits are radially supplying Barrie TS. The cost of the new Barrie TS will be included in
9 the Transformation Connection Pool since it is a step down transformer station that will
10 supply existing and new load, and the cost of the additional line connections at Essa TS
11 will be included in the Network Pool for cost classification purposes.

12
13 Hydro One will be responsible for the avoided cost of the sustainment work and InnPower
14 will be responsible for the remainder of the project cost which will be paid through load
15 revenue and capital contribution.

16
17 **Questions:**

18 a) Please confirm whether the BATU Project costs are included in Hydro One's
19 application for its 2020-2022 transmission revenue requirement. If so, please confirm
20 that the project costs included in this application are the same as those provided in
21 Hydro One's 2020-2022 transmission revenue requirement.

22
23 b) Please comment on InnPower's plans for the inclusion of its portion of the line and
24 station costs of this project in its rate base, including whether InnPower expects to
25 recover these costs in its next cost of service application.

26
27 **Response:**

28 a) The BATU Project is included in Hydro One's application for its 2020-2022
29 transmission revenue requirement with in-service additions totaling \$80.9M¹.

30
31 As per this Application, Hydro One expects that \$84.9M² will be included in its rate
32 base in 2022³.

¹ Consisting of \$58.6M in 2020 and \$22.3M in 2021, totaling \$80.9M.

² Equal to the total capitalized cost of \$86.4M (per sum of the cost tables 1, 2 and 3 in Exhibit B, Tab 7, Schedule 1), less \$1.5M which represents the first-year capital contribution in 2022 from InnPower, as provided in Exhibit B, Tab 9, Schedule 1, Table = total of \$84.9M.

³ As per Exhibit B, Tab 11, Schedule 1.

1 b) The following was provided by InnPower:

2

3 Related to the BATU Project, InnPower plans to seek approval at its next Cost of
4 Service distribution rates application, for

5 i. the inclusion of the annual capital contribution principal payment of the line and
6 station costs in its rate base, and

7 ii. the annual interest payment associated with funding the project.

8

9 As per the Accounting Procedures Handbook Article 410, InnPower will be recording
10 the capital contribution paid to Hydro One Networks Inc. in Uniform System of
11 Accounts, account 1609 – Intangible Assets – Capital Contribution Paid. Therefore the
12 capital contribution to Hydro One will come into InnPower's rate base, equally, over
13 the 15 year payment period.

OEB STAFF INTERROGATORY #7

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19

Reference:

Exhibit B/Tab 9/Schedule 1/p. 5

Interrogatory:

Table 7 indicates a pool cost responsibility for transformation facilities of \$25.5 M. Table 10, however, indicates a pool cost responsibility for transformation facilities of \$25.2 M.

Question:

a) Please confirm the correct pool cost responsibility for transformation facilities and update the tables accordingly.

Response:

a) Hydro One confirms the correct pool cost responsibility for transformation is \$25.5M and has updated Table 10 accordingly per the below;

Table 10: Transformation Connection Pool Project Cost Responsibility and Capital Contribution

SM	Cost of Work (per B-7-1)	Cost Responsibility		Customer Capital Contribution
		Customer	Pool	
Station Facilities (230k/44V DESN at Barrie TS)	36.7	11.2	25.5	2.6
Total	36.7	11.2	25.5	2.6

1 **OEB STAFF INTERROGATORY #8**

2
3 **Reference:**

4 Exhibit B/Tab 6/Schedule 1/p. 1

5
6 **Interrogatory:**

7 The Qualitative Benefits of the project are listed in Exhibit B, Tab 6, Schedule 1.

8
9 The Filing Requirements for Electricity Transmission Applications (Chapter 4) states that
10 when an applicant attributes market efficiency benefits to a proposed project, such as
11 lower energy market prices, congestion reduction, or transmission loss reduction, the
12 evidence submitted must include quantification of each of the market efficiency benefits
13 listed for that proposed project.

14
15 **Question:**

16 a) Has Hydro One quantified any benefits of the BATU Project? If so, please provide
17 them.

18
19 **Response:**

20 a) Hydro One has identified the line losses savings of the BATU project to be about 0.6
21 MW at peak load, and an annual energy savings of 2,238 MWh (please see Table 5-1
22 Impact of Network Upgrades, in EB-2019-0082 at Exhibit B, Tab 1, Schedule 1, TSP
23 Section 1.8.

24
25 Based on an average 2018 Hourly Ontario Energy Price (“HOEP”) of \$24.30/MWh,
26 the annual cost savings would be approximately \$54k.

1 **OEB STAFF INTERROGATORY #9**

2
3 **Reference:**

4 Exhibit B/Tab 7/Schedule 1/pp. 1, 3, 6, and 7

5
6 **Interrogatory:**

7 A budgetary estimate was included with the leave to construct application. Hydro One
8 estimated line work cost to be \$23.4 million and the avoided sustainment cost to be \$7
9 million with a pool contribution of \$3.4 million.

10
11 **Questions:**

- 12 a) Please explain the significant variance in cost of the proposed line work compared to
13 the like-for-like sustainment line work and the customer allocation.
- 14
15 b) Given the current stage of the development work, please comment on the AACE
16 classification of the cost estimates provided in the application and whether any
17 revision of these estimates is anticipated or required.
- 18
19 c) Please confirm whether the budgeted contingency costs are sufficient to cover the
20 identified risks. Hydro One has estimated the contingency cost to be \$7.4 million
21 which is 8.1% of the total cost of the project.
- 22
23 d) How did Hydro One establish that \$7.4 million is an appropriate contingency cost?

24
25 **Response:**

- 26 a) Comparison of major aspects driving the cost difference between the proposed BATU
27 line work and the like-for-like sustainment line work are listed below:

1

115kV like-for-like line work	230kV development line work
This work involves replacing individual components of the circuit that have been classified as end-of-life. Components are typically replaced on an as-required basis.	This work involves building a new 230 kV double circuit steel lattice transmission line.
Replacement of wood poles is significantly cheaper: <ul style="list-style-type: none"> • Wood poles typically do not require foundations • Equipment costs to install wood poles are comparatively cheaper, than the 230kV infrastructure requirements 	Construction of new lattice towers is significantly more expensive: <ul style="list-style-type: none"> • New lattice towers require concrete foundations which become even more complex when dealing with wetland and swampy conditions • Heavier equipment required compared to that of 115kV infrastructure, and the added complexity of getting the equipment to site through poor soil conditions at this Project’s location results in increased cost
Under a like-for-like replacement, no new capacity would be added and as such no capital contribution would be triggered from the existing connected customers using their existing contracted capacity	The Transmission System Code requires a cost allocation calculation (which in turn would drive a potential capital contribution) to determine the assignment of the incremental cost of supplying increased supply capacity requests/connections to triggering customer(s).

2

3 b) The cost estimate for the BATU Project is an Association for the Advancement of
 4 Cost Engineering (“AACE”) Class 3 (which has an expected accuracy range of
 5 +30%/-20%). No revision of the Project estimate is anticipated at this time.

6

7 c) Confirmed. Hydro One anticipates that the budgeted contingency costs are sufficient
 8 to cover the identified risks.

9

10 d) For major projects Hydro One reviews the risks of those projects during the project
 11 development and estimation phase. A risk workshop was undertaken to identify major

1 risks for this Project. The risk of any unplanned outage requirements at Essa TS and
2 Barrie TS due to age and condition of equipment, the risk of an escalation of the price
3 of materials/major components (such as the Transformers) and the risk of schedule
4 delays due to availability of outages to the existing 230 kV circuits at Essa TS were
5 identified and assessed, and cost provisions for those items were included in the cost
6 estimate.

1 **OEB STAFF INTERROGATORY #10**

2
3 **Reference:**

4 Exhibit C/Tab 1/Schedule 1/pp. 3-5

5
6 **Interrogatory:**

7 The new 230 kV lines will be equipped with an appropriate conductor size that will meet
8 current and future load requirements and an optical ground wire (OPGW) located at one
9 of the two shield wire positions on the towers. Conductor size will be 1443.8 kcmil
10 ACSR/TW (56/19) Superior, shield wire will be 7 No. 5 Alumoweld, and OPGW will be
11 7 No. 5 Equivalent (short-circuit capacity and rated tensile strength).

12
13 The application states Barrie TS is currently supplied by two single circuit 115 kV
14 transmission lines from Essa TS spanning between the two stations associated with
15 circuit E3B constructed on 60 foot high wood structures and circuit E4B constructed on
16 80 foot high wood structures. The double circuit that will be constructed is to be built
17 using steel lattice towers ranging in height from 130 to 150 feet.

18
19 The Barrie TS footprint requires expansion to accommodate the new 230/44 kV switch
20 yard. The expansion will occur on property owned by Hydro One adjacent to the existing
21 station fence.

22
23 **Questions:**

- 24 a) What is the difference in capacity provided by the BATU Project by changing from
25 115 kV to 230 kV?
- 26
- 27 b) Does the proposed BATU Project provide sufficient capacity for any future increases
28 in load that may be required to meet the supply for any new customer connections,
29 such as the proposed Metrolinx Station?
- 30
- 31 c) Is Hydro One aware of any proposed customer connections along the new 230 kV
32 circuit or on the ROW south of Barrie TS?
- 33
- 34 d) Please explain any reliability and/or back-up supply concerns for Barrie TS with both
35 circuits now proposed to be on a single tower structure instead of on two separate
36 tower lines.

- 1 e) What has been Hydro One's experience with scheduled outages during construction
2 of similar projects in this area of the province? If there have been delays or
3 cancellations of scheduled outages, what were the impacts on both schedule and final
4 costs?
5
6 f) Please confirm what will be done with the existing 115 kV facilities at Barrie TS.
7

8 **Response:**

- 9 a) The capacity of the existing 115 kV E3B/E4B circuits is approximately 120 MW and
10 the capacity of the new 230kV circuits will be between 400 MW to 450 MW.
11
12 b) Yes, the BATU project circuits will provide sufficient capacity to meet the long-term
13 growth needs in the Barrie/Innisfil area, including those load connections related to
14 new customer connections, such as the proposed Metrolinx Station.
15
16 c) See response to Exhibit I, Tab 1, Schedule 2, part c.
17
18 d) See response to Exhibit I, Tab 1, Schedule 2, part a.
19
20 e) Outages are an ongoing risk for all construction projects, however there have not been
21 any identified elevated risk within the project plan. The impact of any outage delays
22 or cancellations will be determined by the significance of those events, however the
23 current project plan includes consideration for minor impacts in the form of project
24 contingency.
25

26 Scheduled outages are required in order to perform the Project work at both Essa TS
27 and Barrie TS. The risk to executing scheduled/planned outages is dependent on
28 prevailing system conditions, including unplanned outages that are beyond the control
29 of Hydro One.
30

31 A recent experience with scheduled outage delays during the construction of a project
32 in this area of the province occurred in 2019 when both AL6 breaker and a T4
33 transformer failures at Essa TS caused several outage cancellations during installation
34 of new 230 kV in-line switches at Orillia TS. This was due to system conditions
35 (power flow limitations on a major Ontario interface) that would not accommodate an
36 outage for this project at that time. The impact of the cancelled outage on the
37 schedule is estimated to result in a delay to the in-service date of approximately 10-12

1 months. The additional cost to that project is not yet know and will not be available
2 until the project's post-in-service.

3

4 The impact to cost and schedule due to outage delays or cancellations is highly
5 variable. The impact of a specific delay to a project schedule is dependent on
6 whether the outage is part of the critical path and whether float-time (a period of time
7 allowed for unexpected outage delays) was allotted for these types of project related
8 delays. Delayed or cancelled outages can range from several hours to many months.

9

10 Ultimately the granting of a planned outage is provided by the IESO and is beyond
11 the control of Hydro One. Hydro One and the IESO work closely together,
12 maintaining frequent communication, to manage the impacts of any constraints to
13 planned outages they may impact a specific Hydro One project. The cost impact of
14 outage delays can range from hourly standby charges for resourcing & equipment to
15 significant costs that include demobilization and remobilizing of those resources and
16 equipment.

17

18 f) The existing 115kV end-of-life facilities at Barrie TS will be decommissioned and
19 removed/scrapped.

1 **OEB STAFF INTERROGATORY #11**
2

3 **Reference:**

4 Exhibit B/Tab 1/Schedule 2/p. 6
5 Exhibit B/Tab 6/Schedule 1
6 Exhibit E/Tab 1/Schedule 1/pp. 2-3 and Attachment 1
7

8 **Interrogatory:**

9 The evidence states that the Barrie TS footprint will be expanded 100 feet by 40 feet and
10 that the ROW associated with the BATU Project will require new land rights. The
11 application provides information on directly impacted properties. The application states
12 that the new 230 kV E28/E29 double circuit will follow the existing E3B ROW corridor.
13

14 Approximately 7.5 km of the transmission line easement, shared by both E3B and E4B,
15 will be reduced from the current width of 165 feet to 110 feet. Additionally, Hydro One
16 will no longer require the 1.5 km easement section currently occupied solely by the E4B
17 line, which runs east from Essa TS and joins at a point with the E3B line ROW.
18 Easement rights along the proposed corridor route are being renegotiated for the new
19 double circuit 230 kV transmission line.
20

21 **Questions:**

- 22 a) Please explain why the E3B ROW will be used instead of the E4B ROW for the new
23 circuits.
24
- 25 b) Please clarify why new property rights are needed since the new route is on the
26 existing E3B ROW.
27
- 28 c) Please confirm that the 1.5 km section of E4B ROW that is not required for the
29 BATU Project will be abandoned. If not, please clarify what will be done with this
30 section of the ROW.
31
- 32 d) Please confirm that the E3B ROW will remain at a width of 165 feet for the first 1.5
33 km from Essa TS towards Barrie TS.

- 1 e) The ROW requires 16.01 hectares of land rights on lands owned by private
2 landowners. Please provide additional information on the ownership of the privately-
3 owned properties, identifying the number of residential properties and the number of
4 commercial properties.
5
- 6 f) Please provide an update on the negotiations for the new permanent land rights
7 required for the BATU Project with private landowners, including any concerns that
8 have been expressed by landowners with respect to the BATU Project.
9
- 10 g) Please provide an update on the status of permits related to the use of federal,
11 provincial and municipal lands, municipal roads allowances and highways, as well as
12 rail and water crossings.
13
- 14 h) Please discuss any concerns that Hydro One has with respect to obtaining any of the
15 required new land rights and/or permits for the BATU Project.
16
- 17 i) Has Hydro One approached any landowners that will be impacted by temporary
18 access rights to be used for construction staging, access, flagging and permitting?
19 Have any of these landowners expressed any concerns with the temporary access
20 rights? Will the temporary access rights require any environmental approvals? If so,
21 please explain.
22
- 23 j) Please explain whether it is possible for the Barrie TS to be rebuilt within the existing
24 footprint, and if so, why this option was not selected. Also, please clarify the increase
25 in size of the Barrie TS footprint as in the application it is listed as 100 feet by 40
26 feet, and in other places as an expansion of 90 feet.
27

28 **Response:**

- 29 a) During the 230 kV project construction phase, Hydro One is required to maintain
30 115kV supply to the existing Barrie TS. This can only be accomplished by utilizing
31 either circuit E3B or E4B as a temporary bypass. The new project construction could
32 occur on either the E3B or E4B ROW. Hydro One selected to construct the new 230
33 kV line on the E3B ROW because, of the two existing 115 kV circuits, E4B is in
34 better condition compared to E3B and is considered a more reliable option to
35 maintain supply to Barrie TS during Project construction. Additionally E4B has a
36 higher capacity, than E3B, and will better accommodate recent historical summer

1 peak loading at Barrie TS. Once the new 230 kV circuits are built and in-serviced, the
2 E4B circuit will be disconnected and removed.

3
4 b) Where Hydro One's existing E3B ROW is sited, Hydro One relies upon various land
5 rights for its current occupation. These land rights include:

- 6 • Hydro One-owned property;
- 7 • Statutory easement right on Infrastructure Ontario Bill 58 lands;
- 8 • Existing easement rights on municipal and privately-owned properties;
- 9 • Municipal road allowance

10
11 In the instances where Hydro One relies on existing easement rights on privately-
12 owned properties, due to the restrictive nature of the existing easement rights, it was
13 determined that Hydro One was not able to site the new 230 kV E28/E29 double
14 circuit on the majority of those directly impacted properties. These easements are
15 specific to structure type (i.e. wood pole structures), number of structures per
16 property and centerline location. Hydro One would be restricted to the construction of
17 a like-for-like line if no new property rights were acquired, which is not the preferred
18 option.

19
20 Hydro One has acquired new, less restrictive easement rights to allow for the planned
21 230 kV double circuit BATU project. Hydro One will release all existing registered
22 easement agreements on third party lands impacted by this section where Hydro One
23 will no longer require associated land rights (as referred to in Exhibit E, Tab 1,
24 Schedule 1). These releases will be completed at the conclusion of the BATU project
25 construction phase and/or when all E4B infrastructure has been removed from the
26 existing E4B ROW in this section.

27
28 c) Confirmed.

29
30 d) Not confirmed. The first 1.5 km of the E3B ROW, from Essa TS towards Barrie TS,
31 is currently not 165 feet, and Hydro One will not require the ROW for the new 230
32 kV E28/E29 double circuit line in this section to be 165 feet. Hydro One requires a
33 100 foot width ROW in this section, using its proposed engineering design. This is
34 consistent with the existing ROW and the existing associated easement agreements
35 that Hydro One is relying upon.

1 e) The below table identifies the number of residential properties and the number of
2 commercial properties:
3

Property Ownership Type	Number of Properties
Residential Includes land use types: rural recreational, rural residential, vacant agricultural, improved agricultural	11
Commercial Includes land use types: institutional lands, industrial resource, commercial	4
Total	15

4
5 f) Hydro One has initiated land acquisition activities with all impacted private
6 landowners. Hydro One has been successful in negotiating all of the required fifteen
7 permanent land right agreements with private landowners.
8

9 To date, no substantial concerns have been raised by private landowners with respect
10 to the proposed Project and Hydro One has not received any substantial concerns
11 regarding the Project's tower locations, line clearances or continued operations in
12 proximity to the proposed transmission line.
13

14 g) The status of permits related to the use of federal and municipal lands, municipal road
15 allowances and highways, as well as rail and water crossings are as follows:

- 16 • Hydro One has identified all municipal road allowance occupations and shared
17 the location of the occupations to the local municipality. Hydro One does not
18 require any permits and/or approval to occupy municipal road allowances as
19 Hydro One enjoys legislated occupation rights pursuant to Section 41 of the
20 *Electricity Act, 1998*;
- 21 • The new 230 kV E28/E29 double circuit ROW does not impact federal or
22 provincial lands which require permitting and does not cross highway, rail, or
23 permanent water crossings.
24

25 h) Since presenting formal offers to impacted landowners, (beginning in Q2 2017)
26 Hydro One has not received any significant concerns from those land owners with
27 respect to obtaining any of the land rights. Hydro One has acquired all permanent

1 land right requirements for this Project. All construction-related permits will be
2 acquired in 2020 prior to the start of construction.

- 3
4 i) Hydro One has identified and will utilize fee simple owned land adjacent to Essa TS
5 for the majority of the construction staging and material storage for the BATU
6 Project.

7
8 Hydro One has identified three temporary off-corridor access road requirements and
9 will be engaging these third-party property owners in Q1 2020. Any additional
10 required temporary access rights, construction staging, flagging and permitting
11 required for project construction on third-party owned properties if any, will be
12 identified in Q1 2020 and any impacted landowners will be approached at that time.
13 Hydro One does not anticipate any issues with acquiring temporary access rights if
14 determined they are necessary.

15
16 The temporary real estate access rights do not require environmental approvals.

- 17
18 j) It is not possible to construct the new 230kV Barrie TS station project within the
19 current Barrie TS yard footprint due to insufficient space. The current Barrie TS
20 facility will need to remain energized and maintain existing load supply. The existing
21 Barrie TS 115kV station equipment cannot not be de-energized, decommissioned and
22 removed until the new 230kV station has been constructed and placed in-service.
23 Expanding the existing Barrie TS yard will utilize existing land already owned by
24 Hydro One and avoid any additional real estate acquisition costs for land or land
25 rights for this Project.

26
27 In Exhibit B, Tab 2, Schedule 1, of the Application's prefiled evidence it states that
28 the, "Station's footprint will be expanded by an additional area measuring
29 approximately 100 feet by 400 feet". The 90 feet that was indicated in Exhibit C, Tab
30 2, Schedule 1, is a typo and should read as, "the fenced yard facility will be expanded
31 approximately 100 feet to the west".

1 **OEB STAFF INTERROGATORY #12**
2

3 **Reference:**

4 Exhibit E/Tab 1/Schedule 1/p. 6 and Attachments 2 to 7
5

6 **Interrogatory:**

7 Hydro One has provided the forms of land rights agreements that will be used to obtain
8 the required land rights for the project.
9

10 **Questions:**

- 11 a) Please confirm that all of the affected property owners had the option to receive, or
12 will receive the option of, independent legal advice regarding the land agreements.
13
- 14 b) Please confirm that the forms of agreements are consistent with agreements
15 previously approved by the OEB in Hydro One leave to construct decisions. If so,
16 please reference the EB number of the Decision and Order in which they were
17 approved.
18

19 **Response:**

- 20 a) Confirmed. Hydro One provided all affected property owners the option to receive
21 independent legal advice regarding the land agreements. Hydro One committed to
22 reimbursing these owners for reasonably incurred legal fees associated with the
23 review and completion of the necessary land rights.
24
- 25 b) Confirmed. The Hydro One form agreements included in this application have been
26 previously approved by the OEB in Hydro One's leave to construct application EB-
27 2019-0077, the Power South Nepean Project.

1 **OEB STAFF INTERROGATORY #13**

2
3 **Reference:**

4 Exhibit B/Tab 1/Schedule 1/p. 5

5 Exhibit B/Tab 11/Schedule 1

6
7 **Interrogatory:**

8 Hydro One provided a project schedule, setting out the construction and in-service
9 timelines.

10
11 **Questions:**

12 a) Please update the project schedule at the above reference, if the schedule has
13 changed.

14
15 b) Hydro One has indicated that it hopes to receive a decision granting leave to construct
16 by February 28, 2020. Please comment on the impact to the proposed in-service date
17 of June 2022, if the OEB's decision is issued after February 28, 2020.

18
19 **Response:**

20 a) The Project schedule as per Exhibit B, Tab 11, Schedule 1, is accurate and remains
21 unchanged. Hydro One's request for an OEB approval in February 2020 per Exhibit
22 B, Tab 1, Schedule 1, page 5 was incorrect. Please refer to Part (b) below for more
23 information.

24
25 b) As per Exhibit B, Tab 11, Schedule 1, construction related activities for station and
26 line work are scheduled to start in May and July 2020 respectively. Hydro One
27 requests OEB approval of this Application prior to May 2020, specifically by April
28 15, 2020, to facilitate an effective execution of the BATU Project. Approval by April
29 15, 2020 will allow crews to be mobilized for the intended start of station
30 construction in May 2020.

1 **OEB STAFF INTERROGATORY #14**
2

3 **Reference:**

4 Exhibit B/Tab 7/Schedule 1/p. 12

5 Exhibit B/Tab 3/Schedule 1/Attachment 2/p. 13
6

7 **Interrogatory:**

8 Hydro One has indicated that the BATU Project requires the following environmental
9 approvals - Environmental Certificate of Approval and Environmental Screen Out/Class
10 EA.
11

12 **Question:**

13 a) Please comment on the current status of these approvals.
14

15 **Response:**

16 a) The BATU project was subject to the Class Environmental Assessment (“EA”) for
17 Minor Transmission Facilities (2016) under the *Ontario Environmental Assessment*
18 *Act*. The Class EA was completed on March 23, 2018.
19

20 An Environmental Compliance Approval (“ECA”) is required under the
21 *Environmental Protection Act and Ontario Water Resources Act* for regulated
22 systems and processes. An Environmental Activity and Sector Registry (“EASR”) approval is required for significant noise or air emissions sources. Hydro One facilities associated with the BATU Project, in this case Barrie TS and Essa TS, both require an ECA for Industrial Sewage (Drainage) and an EASR approval. The applications for the Barrie TS and Essa TS ECAs and EASRs have not yet been submitted.
27

28
29 These approvals will be submitted within the next six months once detailed engineering has been finalized. The EASRs are effective upon submission of the application, while the ECAs require up to 12 months for the Ministry of the Environment, Conservation, and Parks to review and issue the approval. All approvals will be obtained prior to the installation or construction of the station components they relate to, while unrelated Project work can proceed as scheduled.
34 The schedule presented at Exhibit B, Tab 11, Schedule 1 includes these
35

Filed: 2020-01-09

EB-2018-0117

Exhibit I

Tab 1

Schedule 14

Page 2 of 2

- 1 environmental related approval timelines. Hydro One does not anticipate any adverse
- 2 impacts to that schedule due to these approvals.

1 **OEB STAFF INTERROGATORY #15**
2

3 **Reference:**

4 Exhibit B/Tab 7/Schedule 1/Tables 1 and 8
5

6 **Interrogatory:**

7 The real estate cost for the project is \$2.5 million. There is no real estate cost listed for
8 the comparable station projects. The most recent comparable project for the Essa TS
9 work is Detweiler TS, which has an in-service date of November 2011.
10

11 **Questions:**

- 12 a) Please confirm the real estate costs for all alternatives provided in the application.
13 Please update alternative project costs, if required, to reflect the inclusion of real
14 estate costs.
15
- 16 b) Please confirm that, although not listed, comparable station project costs include real
17 estate costs. If not, please adjust for real estate costs.
18
- 19 c) Are there any projects more current than 2011 for cost comparison of the Essa TS
20 work? If so, please provide their costs.
21
- 22 d) Please clarify the use of a 2% escalation cost for comparable projects versus actual
23 CPI rates. What would be the impact(s) if actual CPI rates were used instead of a 2%
24 escalation cost?
25

26 **Response:**

- 27 a) Real estate costs for the BATU line Project have been included and updated in Table
28 8, as provided below. Hydro One confirms the station project's comparative Tables,
29 (Table 9 and Table 10) do not include any real estate costs as the land on which the
30 project work was undertaken was already owned by Hydro One prior to the project
31 work being undertaken.

1

Table 8: Costs of Comparable Line Projects¹

Project	BATU Project	WATR Project	GATR Project	SGTR Project
Technical	230 kV double circuits on single structures All steel lattice towers	230 kV double circuits on single structures Predominantly steel lattice tower structures with some steel poles	230 kV double circuits on single structures Predominantly steel lattice tower structures with some steel poles	230 kV double circuits on single structures Predominantly steel lattice tower structures with some steel poles
Length (circuit km)	9.0	13.6	5.0	27.0
Project Surroundings	Mostly rural	Urban-Rural Parallel to Karn Rd Multiple road crossings	Urban Parallel to Hwy 6 Multiple crossings -highway, roads	Mostly rural
Environmental Issues	Wetland and swamp conditions, are requiring increased foundation sizing, helical piles and more complex access requirements	None	None	Poor soil conditions required some tower foundations to be changed to pad and pier or piled type foundations
In-Service Date	Jun - 2022	Mar - 2012	Nov - 2016	Oct - 2008
Total Lines Work Cost	\$22.9 M	\$35.6 M	\$23.1 M	\$43.0 M
Less: Non-Comparable Costs				
Real Estate	\$2.5	\$0.5 M	\$1.4 M	-
Line Bypass	-	\$4.3 M	-	-
Total Comparable Project Costs	\$20.4 M	\$30.8 M	\$21.7 M	\$43.0 M
Add: Escalation Adjustment (2%/year)	-	\$6.9 M	\$2.5 M	\$13.4 M
Total Comparable Project Costs	\$20.4 M	\$37.7 M	\$24.2 M	\$56.4 M
Total Cost per Km (\$M's / km)	\$2.3 M	\$2.8 M	\$4.8 M	\$2.1 M

¹ Updated for real estate costs from the original Table 8 filed in Exhibit B, Tab 7, Schedule 1

- 1 b) See response a), above, with respect to real estate costs for station projects.
2
3 c) No there are no projects more current than 2011 to which Hydro One can reasonably
4 compare the BATU related Essa TS work. Selection of projects with comparable
5 work, to that proposed at Essa TS, focused on the expansion of the 230 kV
6 diameters/bus-work that provide new 230 kV termination points, because that is the
7 primary goal at Essa TS for this part of the BATU Project.
8
9 d) A 2% CPI cost escalation rate was chosen for use in the comparable project costs for
10 consistency and simplicity purposes. The Bank of Canada's target CPI rate has
11 historically been around 2% and continues to be so. (Please refer to the Bank of
12 Canada's recent October 2019 Monetary Policy report²).
13

14 The below table provides actual historical Ontario CPI rates back as far as 2008 (2008
15 is the in-service date of the oldest Project comparable used in the BATU evidence).
16 The average CPI rate is 1.95% over the 15 year period, excluding 2009 (this is
17 considered an outlier data-year) which is approximately the same as that used in
18 Tables 8, 9 and 10 of Exhibit B, Tab 7, Schedule 1.
19
20

Table 1: Ontario CPI

Year	CPI Rate (%)³
2008	2.27
2009	0.38
2010	2.43
2011	3.08
2012	1.41
2013	1.05
2014	2.31
2015	1.22
2016	1.79
2017	1.68

² <https://www.bankofcanada.ca/wp-content/uploads/2019/10/mpr-2019-10-30.pdf>

³ Data source: IHS Global November 2019. Data from 2008 to 2018 are actual and beyond 2018 forecast.

2018	2.35
2019	1.98
2020	1.80
2021	1.90
2022	2.00

1

2 Notwithstanding the above, and to be responsive to OEB Staff's question, Hydro One
 3 calculated comparative project cost results using the Table 1 Annual Ontario CPI rate
 4 values above and compared these to the totals provided in evidence at Table 8 and 9 of
 5 Exhibit B, Tab 7, Schedule 1. Table 2 below provides comparative project totals with CPI
 6 escalation using both methods and shows the results are not materially different.

7 **Table 2: Cost of Comparable Projects Using Annual Ontario CPI rates**
 8 (Using information in Tables 8, 9 & 10 filed Exhibit B, Tab 7, Schedule 1)

Table 8 Comparison - Costs of Comparable Line Projects	WATR Project	GATR Project	SGTR Project
Costs Sub-total*	30.8 M	21.7 M	43.0 M
Escalation Adjustment (2%/year)*	6.9 M	2.5 M	13.4 M
Total Comparable Project Costs (using 2% per annum)*	37.7 M	24.2 M	56.4 M
Total Cost per Km (\$M's / km)*	2.8 M	4.8 M	2.1 M
Escalation Adjustment (using actual Ontario CPI/year)	6.0 M	2.5 M	12.0 M
Total Comparable Project Costs (using actual Ontario CPI/year)	36.8 M	24.2 M	55.0 M
Total Cost per Km (\$M's / km)	2.7 M	4.8 M	2.0 M

9 * Per the Prefiled evidence in Exhibit B, Tab 7, Schedule 1

1

Table 9 Comparison - Costs of Comparable Station Projects for Barrie TS	Detweiler 230kV, 350 MVar SVC	Hydro Quebec: 1250 MVA Interconnection	Detour Lake – 230kV Line Connection at Pinard TS
Costs Sub-total*	26.0 M	21.5 M	23.7 M
Escalation Adjustment (2%/year)*	6.1 M	6.6 M	5.0 M
Total Comparable Project Costs (using 2% per annum)*	32.1 M	28.1 M	28.7 M
Escalation Adjustment (using actual Ontario CPI/year)	5.3 M	5.9 M	4.4 M
Total Comparable Project Costs (using actual Ontario CPI/year)	31.3 M	27.4 M	28.1 M

2 * Per the Prefiled evidence in Exhibit B, Tab 7, Schedule 1

3

Table 10 Comparison - Costs of Comparable Station Projects for Essa TS	St. Isidore TS T3/T4 Replacement	Palmerston TS Station Refurbishment	Enfield TS New Station Build
Costs Sub-total*	35,369k	33,934k	31,088k
Escalation Adjustment (2%/year)*	1,797 k	1,797 k	1,961 k
Total Comparable Project Costs (using 2% per annum)*	37,166 k	37,166 k	33,049 k
Escalation Adjustment (using actual Ontario CPI/year)	1,724 k	2,090 k	1,861 k
Total Comparable Project Costs (using actual Ontario CPI/year)	37,093 k	36,024 k	32,949 k

4 * Per the Prefiled evidence in Exhibit B, Tab 7, Schedule 1

1 **OEB STAFF INTERROGATORY #16**

2
3 **Reference:**

4 Transmission System Code 6.3.19

5
6 **Interrogatory:**

7 Under section 6.3.19 of the Transmission System Code (TSC), the approval is being
8 sought for an extension from five years to 15 years for InnPower to provide \$15.7 million
9 in capital contributions. The Board in its decision to permit extensions in the capital
10 contribution installments beyond five years foresaw only one justification for an extended
11 period. That is, where the consumer bill impacts are still too high and continue to present
12 a barrier to the implementation of a regional plan.

13
14 **Questions:**

- 15 a) Please confirm that the consumer bill impacts would be too high for InnPower over a
16 five year capital contribution period, and thus, the need for a 15 year capital
17 contribution period.
- 18
19 b) Please explain and clarify any difference between the interest rate that InnPower will
20 be charged versus the amount to be shown in the proposed variance account.
- 21
22 c) Please confirm if the proposed variance account balance will be recovered from
23 Hydro One customers.
- 24
25 d) If Metrolinx (or any other large customer) will be connecting to the line, please
26 confirm if they will be providing a portion of capital contribution towards the cost of
27 the BATU Project. If possible, please provide the capital contribution that will be
28 made by Metrolinx (or any other large customer).
- 29
30 e) Please explain how InnPower's capital contribution could change if additional
31 customers are supplied from Barrie TS.

32
33 **Response:**

- 34 a) Confirmed. The following response was provided to Hydro One by InnPower to assist
35 in answering this part of the interrogatory.

1 InnPower confirms that by including the capital contribution of \$15.7 million over 5
2 years in its rate base, as opposed to over 15 years as recommended by Hydro One and
3 InnPower, will create a significant rate impact¹ to InnPower's customers. InnPower
4 estimates that the \$15.7 million capital contribution will ultimately account for an
5 increase in excess of 20% to InnPower's rate base. If the capital contribution is
6 payable over five years, the full \$15.7 million will included in InnPower's next cost
7 of service application, anticipated to be for rates effective January 1, 2022, which
8 coincides with the BATU Project in service date of 2022. The BATU project is
9 required for InnPower to service load growth which is anticipated to increase at a
10 more or less even annual stream over the next 10 to 15 years, as opposed to a sudden
11 step change at a particular point in time. By extending the capital contribution
12 payment term from 5 years to 15 years, the capital contribution payment stream will
13 more closely coincide with the forecast additional customers and the associated load
14 increases. This will allow for the new customer base to fund, through their
15 distribution rate charges, the capital contribution relating to the new load they are
16 utilizing, as opposed to InnPower's current customer base, who do not require the
17 expansion of the system.

18

19 Further InnPower rate impact information is provided at Exhibit I, Tab 1, Schedule
20 21.

21

22 b) InnPower is only being charged the prescribed CWIP rate on the deferred capital
23 contribution in accordance with the TSC.

24

25 The 2.88% interest rate that InnPower will be charged by Hydro One shown in the
26 calculations outlining the proposed variance account is the interest on the unpaid
27 balance at the Board's prescribed construction work in progress (CWIP) rate which is
28 updated quarterly and published on the Ontario Energy Board's website as per 6.3.19
29 of the Transmission System Code. Any difference in the amount shown in the
30 calculation contained in this application versus actuals would be a result of updates
31 published on the Ontario Energy Board's website at
32 <https://www.oeb.ca/industry/rules-codes-and-requirements/prescribed-interest-rates>.

33 For the calculation provided to the Ontario Energy Board as part of this application,

¹ InnPower estimate the impact to their residential customer's base distribution charges, by Year-5, to be an increase greater than 10%, compared to that under the 15 year scenario, which would only be an increase of approximately an incremental 3% in the fifth year.

1 Hydro One did not forecast future updates to the rate but held the rate constant at
2 2.88% as per the Q4 2019 update (which has remained unchanged for the Q1 2020
3 update). The CWIP rate used can be seen in the list of assumptions on page 2 of
4 Attachment 1 to Exhibit B, Tab 9, Schedule 9. The amount being booked to the
5 variance account is the difference between what InnPower is being charged (CWIP
6 rate) and the revenue requirement applicable for the in-serviced assets (dependent on
7 NBV vs. Load methodology). Any unrecovered balance, credit or debit, on the
8 variance account would be subject to the OEB's prescribed interest rate for approved
9 deferral and variance Accounts

10
11 c) Confirmed. Any approved balances would be recovered through Uniform
12 Transmission Rates from all Ontario Transmission customers. The proposed variance
13 account balance will be subject to review by the OEB when brought forward for
14 disposition in a future Hydro One transmission revenue requirement application.

15
16 d) Yes, if Metrolinx (or any other large customer) will be connecting, or require
17 additional capacity from the line, they will be providing a portion of capital
18 contribution towards the cost of the BATU Project as per the Transmission System
19 Code 6.3.17. At this time it is not possible to forecast the amount of capital
20 contribution that Metrolinx, or any other large customer, may be required to make. In
21 fact at this time no other customers, including Metrolinx, have indicated they are
22 prepared to contract for any capacity on the line.

23
24 e) If an additional customer(s) are supplied from Barrie TS, it is expected that this could
25 have a material impact upon InnPower's capital contribution as forecast in this
26 Application. As per the TSC, section 6.3.17, the actual cost reconciliation for
27 InnPower would be recalculated in proportion to the revised incremental capital that
28 InnPower is cost accountable for. This cost accountability split is directly related to
29 the portion of contracted capacity that InnPower and any other connecting
30 customer(s) require.

31
32 To demonstrate the potential impact to InnPower's capital contribution if other
33 customer(s) were to connect at (or before) the project is placed into service, Hydro
34 One has analyzed two hypothetical scenarios in which two customers require
35 capacity: *Scenario 1*, where one additional customer requires an equal increase in
36 capacity to that of InnPower and *Scenario 2*, where one additional customer requires

1 only a fraction (10%) of the increase in the new line's capacity compared to that of
2 InnPower's increased capacity request.

3
4 ***Scenario 1***

5 Where another customer requires additional capacity in an amount equal to that of
6 InnPower's incremental capacity requirements, the incremental Project costs would
7 be allocated 50/50 between those two customers for the purposes of calculating their
8 capital contributions. If no other factors change (i.e. load forecast), this would
9 effectively eliminate the requirement of InnPower paying a capital contribution
10 towards the Transformation Pool investments (currently amounting to \$2.6M), and it
11 would reduce InnPower's current forecast capital contribution towards the Line Pool
12 investments from the current \$13.1M to \$2.6M.

13
14 ***Scenario 2***

15 To demonstrate the impacts of calculating the capital contribution based on a scenario
16 where two customers may contract for different proportions of the additional supply,
17 Hydro One have assumed a scenario where InnPower's incremental capacity
18 requirements at 90% and an additional customer is only 10%. Again, assuming no
19 other factors change, this would reduce InnPower capital contribution towards the
20 Transformation Pool investments to \$1.5M (from the current \$2.6M) and reduce the
21 capital contribution towards the Line Pool investments from the current \$13.1M to
22 \$11.0M, for a total capital contribution from InnPower of \$12.5M instead of the
23 current \$15.7M.

24
25 The above examples provide an indication of how InnPower's current capital
26 contribution calculations could be impacted. If the OEB provides leave to construct
27 approval for the BATU Project and a new customer(s) contracts for significant
28 capacity prior to the completion and in-servicing of the Project or during the 15 year
29 rebate period outlined in the TSC post in-service, effectively triggering 6.3.17 of the
30 TSC, Hydro One would inform the OEB of the impact of the new customer
31 connection upon the capital contribution of InnPower and enter into discussions with
32 InnPower regarding the necessity of InnPower continuing a 15-year deferred capital
33 contribution payment schedule requested in this Application and make appropriate
34 revisions to protect the rate payer.

OOEB STAFF INTERROGATORY #17

Reference:

Exhibit B/Tab 9/Schedule 1/pp. 12-17, Attachment 1

Interrogatory:

Hydro One has provided discounted cash flow analysis tables in the application.

Question:

a) Please explain how the discount rate of 5.59% used in discounted cash flow tables was determined.

Response:

a) As outlined on Exhibit B, Tab 9, Schedule 1, page 24, the 5.59% discount rate was determined by utilizing the OEB-approved return on equity of 9.00%¹ on common equity, 2.29%² on short-term debt, and 4.68%³ on long-term debt with the OEB-approved deemed equity to debt ratio (40%/60%) and takes into consideration the current enacted income tax rate of 26.5%.

	Deemed Capital Structure	Cost (%)	Weighted Average	Tax Affected
Debt				
<i>Short-Term</i>	4%	2.29%	0.09%	0.07%
<i>Long-Term</i>	56%	4.68%	2.62%	1.93%
Equity	40%	9.00%	3.60%	3.60%
Cost of Capital			6.31%	5.59%⁴

¹ OEB-approved ROE from Hydro One's most recent transmission rate application EB-2016-0160

² OEB-approved short-term debt rate from Hydro One's most recent transmission rate application EB-2016-0160

³ Hydro One's actual long-term debt rate as approved by the OEB in Hydro One's current transmission rate application EB-2016-0160

⁴ Due to displaying the rounding of line items in the table to two decimal places, the above values add to 5.60%, however, the actual tax effected Cost of Capital is 5.59% - as shown.

1 **OEB STAFF INTERROGATORY #18**

2
3 **Reference:**

4 Exhibit B/Tab 9/Schedule 1/pp. 4-5, Tables 8-10

5
6 **Interrogatory:**

7 Hydro One has provided tables outlining the cost responsibility and capital contribution.

8
9 **Questions:**

- 10 a) In calculating the Pool allocation as discussed in Tab 7, avoided costs that occur in
11 the first three years are not discounted. Please explain why.
12
13 b) Please show/explain how the customer capital contributions in Tables 8 to 10 are
14 calculated.
15

16 **Response:**

- 17 a) Avoided costs that occur in the first three years were not discounted as the current
18 assets are at end-of-life and would have been replaced at the same time as the other
19 assets being replaced as part of a consolidated sustainment project to maximize cost
20 savings by bundling work as well as reducing the impacts on downstream customers
21 by reducing the number of planned outages.
22
23 b) These calculations were provided on page 12 to 24 of Exhibit B, Tab 9, Schedule 1.
24 The calculations are performed in accordance with the Transmission System Code
25 section 6.5 Economic Evaluations of New and Modified Connections and Appendix 5
26 Methodology and assumptions for economic evaluations.

1 **OEB STAFF INTERROGATORY #19**

2
3 **Reference:**

4 Exhibit B/Tab 9/Schedule 1/pp. 2 and 7, Attachment 1

5
6 **Interrogatory:**

7 Page 2 states that the need for the requested deferral and variance account is to ensure
8 that: (1) Hydro One is able to recover the appropriate cost of capital over the loan term as
9 Hydro One would be charging InnPower interest at the OEB's CWIP rate, which does not
10 equate to Hydro One's full cost of capital; and (2) to ensure that Hydro One is able to
11 recover the cost of its investment during the capital contribution deferral period.

12 Hydro One proposed to record costs associated with the BATU Project using the Loan
13 Methodology as opposed to the "standard capital contribution methodology" (i.e., the
14 NBV Reduction Methodology).

15
16 **Questions:**

17 a) Please confirm that both the Loan Methodology and the NBV Reduction
18 Methodology would allow Hydro One to recover the revenue requirement on the
19 unpaid capital contribution over the loan period instead of recovering the CWIP rate
20 on the unpaid capital contribution. If not, please explain what is being recovered
21 under both methodologies.

22
23 b) Please confirm that the revenue requirement difference between the Loan
24 Methodology and the NBV Reduction Methodology is due to the tax calculation as a
25 result of the way the capital contribution is recorded (i.e., as a capital contribution or
26 in a deferral and variance account). If not, please explain the reason for the revenue
27 requirement difference.

28
29 c) Please confirm that the tax treatments shown in Tables A to D reflect actual tax
30 treatments. If not, please explain the actual tax treatment.

31
32 d) Under the NBV Reduction Methodology in Tables C and D, please explain why taxes
33 on capital contribution are applied during the period that the capital contribution is
34 received and not the period that the capital contribution is amortized into income over
35 the life of the asset.

1 e) Please explain whether the revenue requirement difference between the two
2 methodologies is a permanent difference or a timing difference that will reverse in the
3 future. If it will reverse, please explain when it will reverse and whether it will be
4 reflected in the proposed account.

5
6 **Response:**

7 a) Confirmed. Both the Loan Methodology and the NBV Reduction Methodology would
8 allow Hydro One to recover the revenue requirement on the unpaid capital
9 contribution as per the OEB's Notice of Revised Proposal to Amend a Code¹.
10 However, the Loan Methodology option would result in a smaller impact on Hydro
11 One Transmission's rate payers versus the NBV Reduction Methodology.

12
13 b) The majority of the revenue requirement difference between the Loan Methodology
14 and the NBV Reduction Methodology is due to the tax calculation as a result of the
15 way the capital contribution is recorded; the remainder is due to the impact on
16 depreciation.

17
18 c) Confirmed. Table A to Table D of Exhibit B, Tab 9, Schedule 1, reflect actual tax
19 treatments.

20
21 d) As per section 12(1)(x) of the *Income Tax Act*, any additional capital contributions
22 from the customer after the initial in-service are treated as revenue for corporate
23 taxation purposes and subject to the full 26.5% corporate tax rate.

24
25 Taxes have been applied during the period the capital contribution is received in
26 accordance with the Income Tax Act. In accordance with paragraph 12(1)(x) amounts
27 received as reimbursements/inducements (i.e. capital contributions) are treated as
28 income for tax. However, there are exceptions where amounts are received in respect
29 of a depreciable property that was; i) Acquired in the current year, ii) acquired three
30 years preceding the current year, and iii) acquired the year immediately following the
31 current year. Under these exemptions the taxpayer can elect to reduce the capital cost
32 of the property (rather than take the amounts into income). Since, the capital
33 contributions received fall outside the time frames noted in i) to iii) above they do not
34 qualify for an exception and are treated as income.

35

¹ EB-2016-0003 dated August 23, 2018

- 1 e) The revenue requirement difference between the two methodologies is a permanent
- 2 difference due to the tax implications between both methodologies.

1 **OEB STAFF INTERROGATORY #20**

2
3 **Reference:**

4 Exhibit B/Tab 10/Schedule 1/p. 3, Appendix A

5
6 **Interrogatory:**

7 Hydro One is requesting approval of an accounting order to establish a new variance
8 account, the “Capital Contribution Differential Account”.

9
10 **Questions:**

11 Regarding the requested establishment of the deferral and variance account:

- 12
- 13 a) In the application, Hydro One is unclear on the specific section of the *Ontario Energy*
14 *Board Act, 1998* (OEB Act) in which it is requesting approval of an accounting order
15 to establish a new variance account. Please identify the specific section of the OEB
16 Act in which Hydro One is requesting approval of an accounting order.
- 17
- 18 b) Please confirm that the account is requested regardless of if the Loan Methodology or
19 NBV Reduction Methodology is used in determining the revenue requirement
20 difference.
- 21
- 22 c) Hydro One indicated that the expected shortfall in revenue requirement to be recorded
23 in the account is \$5.2 million over the loan period, which exceeds the \$3 million
24 materiality threshold of Hydro One Transmission. Typically, the materiality threshold
25 is an annual amount. Please confirm that the annual amount expected to be recorded
26 in the account would not meet an annual materiality threshold of \$3 million.
- 27
- 28 i. The NBV Reduction Methodology expects \$7.5 million to be recorded in the
29 account over 15 years or \$4.6 million to be recorded in the account over five
30 years. This equates to an average of \$500,000 annually for 15 years or
31 \$920,000 annually for five years. Please explain why Hydro One
32 Transmission is requesting the account given the immaterial annual amounts.

1 d) In the draft accounting order, it states that Hydro One is proposing the establishment
2 of this account for any other customer in the future that utilizes the provision in TSC
3 section 6.3.19 to delay full capital contribution payment.

4
5 i. Please explain whether this account is to be used only if the payment period
6 exceeds a five year period or for all capital contributions regardless of
7 payment period.

8 ii. Please confirm that Hydro One is requesting this account to be used for any
9 future projects where there is a delay in the capital contribution payment and
10 not specifically for the BATU Project.

11
12 e) In the Notice of Revised Proposal to Amend a Code (EB-2016-0003), dated August
13 23, 2018, page 17 indicates a transmitter expressed the view that distributors should
14 pay interest to the transmitter at the transmitter's OEB approved cost of capital on the
15 unpaid capital contribution balance, rather than the OEB's prescribed CWIP rate. The
16 OEB disagreed. Please provide additional rationale on Hydro One's position to
17 deviate from the OEB's policy on using the CWIP rate.

18
19 **Response:**

20 a) Hydro One is requesting approval to establish a new variance account under section
21 78 of the OEB Act.

22
23 b) Confirmed. However, utilizing the NBV methodology over the loan methodology
24 would result in a higher deferral account balance to be recovered from Hydro One
25 Transmission rate payers.

26
27 c) Hydro One confirms that the annual amount expected to be recorded in the account
28 relating to this specific BATU Project would **not** meet an *annual* materiality
29 threshold of \$3 million. However, Hydro One is requesting this to be a generic
30 variance account which would be available to use for future transmission projects
31 where similar circumstances may occur, e.g. if other customers elect to avail
32 themselves to the recent amendments to the Transmission System Code ("TSC")
33 allowing a delay in their capital contribution payment beyond Day One of a project's
34 in-service date. Section 6.3.19 of the TSC states:

35
36 *"Where a distributor is required under this Code to*
37 *provide a capital contribution to a transmitter, the*

1 *transmitter shall permit the capital contribution to be*
2 *provided in equal installments over a period of time not to*
3 *exceed five years unless a longer period is approved by the*
4 *Board. Where a distributor provides the capital*
5 *contribution in installments, the transmitter shall charge*
6 *interest on the unpaid balance at the Board's prescribed*
7 *construction work in progress (CWIP) rate which is*
8 *updated quarterly and published on the Board's website.*
9 *The interest charges shall accrue monthly commencing on*
10 *the date the connection asset goes into service and be paid*
11 *annually, as part of each installment payment.” [emphasis*
12 *added]*
13

14 Due to the updated amendments to the TSC, Hydro One points out that it has
15 effectively **no** control over the timing of when it will receive the customer's capital
16 contributions (e.g. the customer may choose to pay their capital contribution all
17 upfront or over an extended period). This will create a cash shortfall to Hydro One, as
18 the CWIP rate is insufficient to cover the long-term debt rate of Hydro One, much
19 less the WACC to maintain the asset in rate base. Hydro One anticipates the annual
20 cumulative impact of shortfalls will grow as other distributors become aware, and
21 then avail themselves, of the new opportunity these TSC provisions allowed on other
22 Hydro One constructed projects. This will likely result in entries that will satisfy the
23 deferral account eligibility threshold criteria.

- 24
25 d)
- 26 i. Hydro One proposes that the account will be used for all capital projects in
27 which a distributor elects to defer the capital contribution, regardless of the
28 elected payment period.
 - 29 ii. Confirmed.
- 30
31
- 32 e) Under the proposal, the distributor will only be paying the OEB prescribed CWIP rate
33 (currently 2.88%) for the outstanding capital contribution balance as per the TSC
34 6.3.19 (as quoted in part c above). As per the OEB Notice of Revised Proposal to
35 Amend a Code EB-2016-0003 August 23, 2018 (“the Amendments”), the “OEB
36 intent was to hold the transmitter harmless”. As the asset will be fully in-service, the
37 transmitter, per OEB standard rate-making principles, should be allowed to recover
38 all costs associated with the approved asset. Hydro One current third party long term

1 debt rate is 4.68% and return on equity is even higher, which results in Hydro One
2 cross-subsidizing the distributor.

3

4 Additionally, as Hydro One will not be able to forecast if customers will elect to defer
5 capital contribution payments, Hydro One's business plan assumes that any customer
6 capital contributions are received on Day 1, thus lowering its rate base and revenue
7 requirement. This also results in Hydro One cross-subsidizing the distributor.

8

9 The regulatory account is designed to calculate the impact of the delayed receipt of
10 capital contributions on the transmitter and allow the transmitter to recover its
11 prudently incurred costs (as shown in Exhibit B, Tab 9, Schedule 1, Attachment 1).

12

13 Hydro One believes requesting the account for approval at this time is prudent, due to
14 the uncertainty of these risks and their potential size. If the OEB does not approve the
15 account in this Application, Hydro One will be required to amend the transmission
16 rate application to forecast delays in capital contribution payments and their resulting
17 impact on revenue requirement for all transmission projects for distributors within
18 Ontario (not just the current investment) to ensuring Hydro One is held whole.

19

20 Hydro One believes it is more prudent and less impactful to rate payers to manage
21 this risk through a regulatory account instead of forecasting the potential impact in
22 revenue requirement. Hydro One understands that the OEB's approval to establish the
23 account is not a guarantee of cost recovery. The Board will have the opportunity,
24 during a future transmission revenue requirement application, to review the prudence
25 of any amounts recorded in the deferral account prior to approving for disposition.

1 **OEB STAFF INTERROGATORY #21**
2

3 **Reference:**

4 Exhibit B/Tab 1/Schedule 1/Attachment 1 – InnPower May 23, 2019 letter
5 InnPower October 16, 2019 letter
6

7 **Interrogatory:**

8 As part of the application, Hydro One included a letter from InnPower regarding the
9 capital contribution period and its support for the BATU Project. The following questions
10 are directed to Hydro One as the applicant, but OEB staff requests that Hydro One make
11 all necessary inquiries of InnPower in order to respond to these questions.
12

13 **Questions:**

- 14 a) In the October 16, 2019 InnPower letter, InnPower states that if the capital
15 contribution is to be paid within five years, this will impose increased financial
16 pressure on the company as well as on InnPower's ratepayers.
17
- 18 i. Please quantify the impact of the capital contribution payment over a five year
19 and 15 year period on InnPower's cash flows, ROE and bill impact to rate
20 payers.
 - 21 ii. Please further discuss any other pressures or issues that may arise due to the
22 difference in payment terms.
23

24 **Response:**

- 25 a) The following responses were provided to Hydro One by InnPower to assist in
26 answering this interrogatory.
27
- 28 i. Please refer to the response provided in Exhibit I, Tab 1, Schedule 16, Part (a).
29
 - 30 ii. InnPower continues to experience significant growth throughout their service
31 territory, including the Town of Innisfil and the South Barrie lands. In order to
32 supply and support the growth, InnPower is contributing to and supporting the
33 BATU Project.
34

35 Consistent with the response provided in Exhibit I, Tab, 1, Schedule 16, InnPower is
36 supporting Hydro One's request for a 15 year capital contribution payment period due

1 to the quantum of the capital contribution payment and its impacts on InnPower
2 customers if it was levied into rate base over a shorter period of time. For example, if
3 InnPower was required to pay the capital contribution over 5 years, this would result
4 in a \$3.14 million/year capital expenditure. Based on InnPower's 2016 cost of
5 service, the approved annual capital expenditures, included in rates, were \$4.4
6 million. The BATU Project's capital contribution would represent approximately
7 71% of InnPower's annual approved capital expenditures. InnPower requires its
8 approved capital expenditure budget for expansion and maintenance of its distribution
9 network. To reduce or defer 70% of its planned investments, to accommodate the
10 BATU rate base portion under its current level of approval, would impact electricity
11 service to InnPower's customers. If the Board was to allow InnPower to increase its
12 capital expenditure portfolio by the capital contribution amount over only five years,
13 this will result in a substantial rate impact to customers¹. By extending the BATU
14 Project's capital contribution over 15 years, InnPower can effectively manage its
15 annual capital expenditures to include the \$1.05 million capital contribution payment.

16
17 If the 15 year time horizon is disallowed by the OEB, InnPower will also incur
18 significant borrowing costs, which will be included in revenue requirement, to
19 finance the larger annual \$3.14 million payment. These increased interest costs will
20 contribute to rate increases as a result of the significant increase in the rate base for
21 the 5-year scenario, compared to the interest costs under the longer 15-year period.

22
23 Extending the capital contribution payment over a 15-year time horizon also
24 coincides with InnPower's preliminary load growth estimates. A 15-year payment
25 term allows for new customers, who require the BATU Project expansion, to
26 contribute (in the form of rates revenues) towards the annual \$1.05 million capital
27 contribution payment. This allows for a more measured rate base growth that will be
28 matched more closely to InnPower customer and load growth increases.

¹ Please refer to Exhibit I, Tab, 1, Schedule 16, Part (a), regarding estimated customer impacts.