

UNDERTAKING J5.9

Undertaking

To provide total OM&A cost and total lost production for each outage for 2005, 2006 and 2007.

Response

The following tables show actual planned outage days (ref: E2-T1-S2 Table 2a) including force extension of planned outages with the corresponding revenue impact along with the actual outage costs (ref: F2-T1-S1 Table 1) for 2005, 2006, 2007. Note: the outage costs for the year also include expenditures on preparatory work for outages that will occur in the future.

2007 Planned Outages				
	Duration (days)	Generation Impact (TWh)	Revenue Loss (M\$)	Outage OM&A (M\$)
Pickering A - U1	76.2	1.0	49.0	40.8
Pickering A - U4	49.2	0.64	31.7	2.0
Pickering B - U5	94.1	1.2	60.4	34.5
Pickering B - U6	78.0	1.0	50.0	26.5
Pickering B - U7	28.0	0.36	17.8	0.3
Darlington - U2	59.7	1.34	66.3	48.0
Darlington - U3	18.6	0.4	20.8	2.4
Darlington - U4	58.5	1.31	64.9	46.2
Preparatory work for future outages				14.9

2006 Planned Outages				
	Duration (days)	Generation Impact (TWh)	Revenue Loss (M\$)	Outage OM&A (M\$)
Pickering A - U1	14.9	0.2	9.4	40.6
Pickering A - U4	80.1	1.0	51.5	2.2
Pickering B - U6	35.4	0.46	22.7	0.8
Pickering B - U7	13.6	0.2	8.4	0.0
Pickering B - U7	108.3	1.4	69.8	41.5
Pickering B - U8	117.6	1.5	75.2	35.6
Darlington - U3	73.2	1.6	81.2	36.4
Darlington - U1	47.3	1.1	52.5	23.8
Preparatory work for future outages				6.8

1
2

2005 Planned Outages				
	Duration (days)	Generation Impact (TWh)	Revenue Loss (M\$)	Outage OM&A (M\$)
Pickering B - U5	146.0	1.9	94.1	45.1
Pickering B - U6	122.4	1.6	78.7	44.5
Darlington - U2	69.4	1.6	77.2	30.8
Darlington - U4	13.3	0.30	14.9	1.2
Darlington - U4	33.9	0.8	37.6	15.8
Preparatory work for future outages				9.1
PA planned work accomplished during Unit 4 forced outage (feeder thinning issue)				16.5

3