



# NEWMARKET-TAY POWER DISTRIBUTION 2020 ASSET CONDITION ASSESSMENT

K-814216-RA-0001 R00

Prepared for

Newmarket-Tay Power Distribution Ltd.

Issue Date

2020-Nov-23

|  |   |   |
|--|---|---|
| <p>Prepared by</p> <hr/> <p><i>Signature</i></p> <p>Katrina Lotho<br/>Engineer<br/>Distribution Asset<br/>Management<br/>2020-Nov-23</p> | <p>Reviewed by</p> <hr/> <p><i>Signature</i></p> <p>Fan Wang<br/>Engineer<br/>Distribution Asset<br/>Management<br/>2020-Nov-23</p> | <p>Approved by</p> <hr/> <p><i>Signature</i></p> <p>Yury Tsimberg<br/>Director<br/>Asset Management<br/>2020-Nov-23</p> |
|--|---|---|



## Revision History

|     |                                |               |             |             |
|-----|--------------------------------|---------------|-------------|-------------|
| Rev | Description                    |               |             |             |
| D00 | Draft Report for Client Review |               |             |             |
|     | Issue Date                     | Prepared by   | Reviewed by | Approved by |
|     | 2020-June-03                   | Katrina Lotho | F. Wang     |             |
| Rev | Description                    |               |             |             |
| D01 | Asset ID                       |               |             |             |
|     | Issue Date                     | Prepared by   | Reviewed by | Approved by |
|     | 2020-Aug-08                    | Katrina Lotho | F. Wang     |             |
| Rev | Description                    |               |             |             |
| R00 | Final Report                   |               |             |             |
|     | Issue Date                     | Prepared by   | Reviewed by | Approved by |
|     | 2020-Nov-23                    | Katrina Lotho | F. Wang     | Y. Tsimberg |

### DISCLAIMER

Kinectrics prepared this report as a work of authorship sponsored by their Client. This report has been prepared solely for the benefit of the Client and may not be used or relied upon in whole or in part by any other person or entity without Client permission or without Kinectrics' permission if required by the Contract between Client and Kinectrics Inc. Neither Kinectrics, their client nor any person acting on behalf of them: (a) makes any warranty or representation whatsoever, express or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, with respect to (i) the use of any information, apparatus, method, process, or similar item disclosed in this report including the merchantability or fitness for any particular purpose of any information contained in this report or the respective works or services supplied or performed or (ii) that such use does not infringe on or interfere with privately owned rights, including any party's intellectual property; or (b) assumes responsibility for any damages or other liability whatsoever (including any consequential damages resulting from a third party's selection or use of this report or any information, apparatus, method, process, or similar item disclosed.

Copyright © 2020 Kinectrics Inc. All rights reserved.



## Table of Contents

- 1. Introduction ..... 8
  - 1.1 Objective and Scope of Work..... 8
- 2. Asset Condition Assessment Methodology ..... 9
  - 2.1 Health Index ..... 9
  - 2.2 Condition Based Flagged for Action Plan..... 11
    - 2.2.1 Flagged for Action Plan Using a Life Curve Approach ..... 13
    - 2.2.2 Flagged for Action Plan Using a Risk-Based Approach ..... 14
  - 2.3 Data Assessment ..... 18
    - 2.3.1 Data Availability Indicator (DAI)..... 18
    - 2.3.2 Data Gaps ..... 19
- 3. Results ..... 21
  - 3.1 Health Index Results ..... 21
  - 3.2 Condition-Based Flagged for Action (FFA) Plan ..... 24
  - 3.3 Data Assessment ..... 29
- 4. Conclusions and Recommendations ..... 31
- 5. References ..... 34
- Appendix A Results for Each Asset Category..... 35
  - 1. Substation Transformers ..... 35
    - 1.1 Health Index ..... 36
      - 1.1.1 Health Index Formula ..... 36
      - 1.1.2 Health Index Results ..... 44
    - 1.2 Flagged for Action Plan ..... 45
    - 1.3 Risk Based Prioritized List..... 46
    - 1.4 Data Assessment ..... 47
  - 2. Circuit Breakers ..... 48
    - 2.1 Health Index ..... 49
      - 2.1.1 Health Index Formula ..... 49
      - 2.1.2 Health Index Results ..... 53
    - 2.2 Flagged for Action Plan ..... 53
    - 2.3 Risk Based Prioritized List..... 54
    - 2.4 Data Assessment ..... 56
  - 3. Pole Mounted Transformers ..... 57
    - 3.1 Health Index ..... 58
      - 3.1.1 Health Index Formula ..... 58
      - 3.1.2 Health Index Results ..... 61
    - 3.2 Flagged for Action Plan ..... 62
    - 3.3 Health Index Based Prioritized List ..... 63
    - 3.4 Data Assessment ..... 66
  - 4. Pad Mounted Transformers ..... 67
    - 4.1 Health Index ..... 68
      - 4.1.1 Health Index Formula ..... 68
      - 4.1.2 Health Index Results ..... 71
    - 4.2 Flagged for Action Plan ..... 72
    - 4.3 Health Index Based Prioritized List ..... 73
    - 4.4 Data Assessment ..... 76
  - 5. Pad Mounted Switchgear..... 77



- 5.1 Health Index ..... 78
  - 5.1.1 Health Index Formula ..... 78
  - 5.1.2 Health Index Results ..... 80
- 5.2 Flagged for Action Plan ..... 81
- 5.3 Health Index Based Prioritized List ..... 82
- 5.4 Data Assessment ..... 85
- 6. Poles..... 86
  - 6.1 Wood Poles ..... 86
    - 6.1.1 Health Index ..... 87
      - 6.1.1.1 Health Index Formula ..... 87
      - 6.1.1.2 Health Index Results ..... 89
    - 6.1.2 Flagged for Action Plan ..... 90
    - 6.1.3 Health Index Based Prioritized List ..... 91
  - 6.2 Concrete Poles..... 94
    - 6.2.1 Health Index ..... 95
      - 6.2.1.1 Health Index Formula ..... 95
      - 6.2.1.2 Health Index Results ..... 96
      - 6.2.1.3 Flagged for Action Plan ..... 96
    - 6.2.2 Health Index Based Prioritized List ..... 97
  - 6.3 Data Assessment ..... 100
- 7. Underground Cables..... 101
  - 7.1 Non-TR XLPE Underground Cables ..... 101
    - 7.1.1 Health Index Formula ..... 102
    - 7.1.2 Health Index Results ..... 103
    - 7.1.3 Flagged for Action Plan ..... 104
  - 7.2 TRXLPE Underground Cables ..... 105
    - 7.2.1 Health Index ..... 106
      - 7.2.1.1 Health Index Formula ..... 106
      - 7.2.1.2 Health Index Results ..... 106
    - 7.2.2 Flagged for Action Plan ..... 107
  - 7.3 Data Assessment ..... 108



## List of Figures

Figure 2-1 Weibull Functions ..... 13

Figure 2-2 Risk Assessment Procedure ..... 14

Figure 2-3 Stress Curve..... 15

Figure 2-4 Likelihood of Removal vs. Health Index ..... 16

Figure 3-1 Health Index Summary (Graphical) .....23

Figure 3-2 Flagged for Action Plan (Graphical) .....27

Figure 3-3 Flagged for Action Plan Levelized (Graphical) .....28

Figure A 1-1 Substation Transformers Age Distribution .....35

Figure A 1-2 Substation Transformers Age Limiter.....43

Figure A 1-3 Substation Transformers Health Index Distribution.....44

Figure A 1-4 Substation Transformers Flagged for Action Plan .....45

Figure A 2-1 Circuit Breakers Age Distribution .....48

Figure A 2-2 Circuit Breakers Age Limiter .....52

Figure A 2-3 Circuit Breakers Health Index Distribution .....53

Figure A 3-1 Pole Mounted Transformers Age Distribution .....57

Figure A 3-2 Pole Mounted Transformers Age Limiter .....60

Figure A 3-3 Pole Mounted Transformers Health Index Distribution.....61

Figure A 3-4 Pole Mounted Transformers Flagged for Action Plan .....62

Figure A 4-1 Pad Mounted Transformers Age Distribution .....67

Figure A 4-2 Pad Mounted Transformers Age Limiter .....70

Figure A 4-3 Pad Mounted Transformers Health Index Distribution .....71

Figure A 4-4 Pad Mounted Transformers Flagged for Action Plan .....72

Figure A 5-1 Pad Mounted Switchgear Age Distribution.....77

Figure A 5-2 Pad Mounted Switchgear Age Limiter.....79

Figure A 5-3 Pad Mounted Switchgear Health Index Distribution.....80

Figure A 5-4 Pad Mounted Switchgear Flagged for Action Plan.....81

Figure A 6-1 Wood Poles Age Distribution .....86

Figure A 6-2 Poles Age Limiter .....88

Figure A 6-3 Wood Poles Health Index Distribution.....89

Figure A 6-4 Wood Poles Flagged for Action Plan .....90

Figure A 6-5 Concrete Poles Age Distribution .....94

Figure A 6-6 Concrete Poles Health Index Distribution .....96

Figure A 7-1 Non-TRXLPE Underground Cables Age Distribution ..... 101

Figure A 7-2 Underground Cables Age Limiter..... 102

Figure A 7-3 Non-TRXLPE Underground Cables Health Index Distribution ..... 103

Figure A 7-4 Non-TRXLPE Underground Cables Flagged for Action Plan ..... 104

Figure A 7-5 TRXLPE Underground Cables Age Distribution..... 105

Figure A 7-6 TRXLPE Underground Cables Health Index Distribution ..... 106

Figure A 7-7 Non-TRXLPE Underground Cables Flagged for Action Plan ..... 107



## List of Tables

|  |    |
|--|----|
| Table 3-1 Health Index Summary .....                                   | 22 |
| Table 3-2 Flagged for Action Plan .....                                | 25 |
| Table 3-3 Flagged for Action Plan – Levelized .....                    | 26 |
| Table 3-4 Data Assessment Summary .....                                | 30 |
|  |    |
| Table A 1-1 Substation Transformers Health Index Formula.....          | 36 |
| Table A 1-2 DGA Criteria .....   | 38 |
| Table A 1-3 General Oil Quality (GOQ)Test Criteria.....                | 38 |
| Table A 1-4 TTR Criteria.....  | 39 |
| Table A 1-5 Winding Resistance Criteria .....                          | 39 |
| Table A 1-6 Degree of Polymerization Criteria .....                    | 40 |
| Table A 1-7 Power Factor Test Criteria .....                           | 40 |
| Table A 1-8 Insulation Resistance .....                                | 40 |
| Table A 1-9 Inspection Criteria .....                                  | 41 |
| Table A 1-10 Loading History .....                                     | 41 |
| Table A 1-11 De-Rating Multiplier Based on Oil Quality Score.....      | 42 |
| Table A 1-12 De-Rating Multiplier Based on TDCG Trend .....            | 42 |
| Table A 1-13 De-Rating Multiplier CO2:CO Ratio.....                    | 42 |
| Table A 1-14 Substation Transformers Risk Based Prioritized List ..... | 46 |
| Table A 2-1 Circuit Breakers Health Index Formula .....                | 49 |
| Table A 2-2 Contact Resistance Criteria.....                           | 50 |
| Table A 2-3 Inspection Criteria .....                                  | 50 |
| Table A 2-4 Timing Test Criteria .....                                 | 51 |
| Table A 2-5 Operating Derating Criteria .....                          | 51 |
| Table A 2-6 Circuit Breakers Risk Based Prioritized List.....          | 54 |
| Table A 3-1 Pole Mounted Transformers Health Index Formula .....       | 58 |
| Table A 3-2 Inspection Criteria .....                                  | 58 |
| Table A 3-3 De-Rating Multiplier IR Scan .....                         | 59 |
| Table A 3-4 De-Rating Multiplier Overall Hazard.....                   | 59 |
| Table A 3-5 De-Rating Multiplier PCB Content .....                     | 59 |
| Table A 3-6 Pole Mounted Transformers Risk Based Prioritized List..... | 63 |
| Table A 3-7 Pole Mounted Transformers Data Gaps.....                   | 66 |
| Table A 4-1 Pad Mounted Transformers Health Index Formula .....        | 68 |
| Table A 4-2 Inspection Criteria .....                                  | 69 |
| Table A 4-3 De-Rating Multiplier IR Scan .....                         | 69 |
| Table A 4-4 De-Rating Multiplier Overall Hazard.....                   | 70 |
| Table A 4-5 De-Rating Multiplier PCB Content .....                     | 70 |
| Table A 4-6 Pad Mounted Transformers Risk Based Prioritized List.....  | 73 |
| Table A 4-7 Pad Mounted Transformers Data Gaps .....                   | 76 |
| Table A 5-1 Pad Mounted Switchgear Health Index Formula.....           | 78 |
| Table A 5-2 Inspection Criteria .....                                  | 79 |



Table A 5-3 Pad Mounted Switchgear De-Rating Multiplier Criteria ..... 80

Table A 5-4 Pad Mounted Switchgear Risk Based Prioritized List ..... 82

Table A 5-5 Pad Mounted Switchgear Data Gaps ..... 85

Table A 6-1 Wood Poles Health Index Formula..... 87

Table A 6-2 Inspection Criteria ..... 87

Table A 6-3 Poles De-Rating Multiplier Criteria ..... 88

Table A 6-4 Wood Poles Risk Based Prioritized List ..... 91

Table A 6-5 Concrete Poles Health Index Formula ..... 95

Table A 6-6 Concrete Poles Risk Based Prioritized List ..... 97

Table A 6-7 Poles Data Gaps ..... 100

Table A 7-1 Underground Cables Health Index Formula ..... 102

Table A 7-2 Underground Cables Data Gaps ..... 108



## 1. Introduction

Newmarket-Tay Power Distribution Ltd. (NTPDL) is a local distribution company (LDC) that provides electricity to the Town of Newmarket, Township of Tay, and Town of Midland. NTPDL is an Ontario Energy Board licensed company and activities, performance standards, and rates are regulated by the Ontario Energy Board.

In keeping with a commitment to strategic and prudent investment planning, NTPDL recognized the need to perform an Asset Condition Assessment (ACA) on its key distribution assets. ACA is crucial part of asset management and provides a systematic process for determining and justifying long-term sustainment needs. Health indexing and risk assessment form the basis of ACA process. The Health Index (HI) expresses the condition of an asset as a single number, and risk assessment accounts for the consequence of asset failure. Using this process, the quantities of assets that will require attention in the next several years can be estimated.

Kinectrics Inc. (Kinectrics) performed ACAs for NTPDL's key distribution assets in 2011, in 2013, and again in 2017. This 2020 ACA marks the first year since the amalgamation of Midland PUC.

Kinectrics used NTPDL's 2020 asset information (which includes assets in Newmarket, Tay, and Midland) and Kinectrics' s up to date methodologies to develop HI distributions and estimate action plans based on the asset condition. This report presents the results of Kinectrics' assessment.

### 1.1 Objective and Scope of Work

The objective of the work was to conduct ACA on a subset of NTPDL's key distribution assets. The ACA was designed to quantify the extent of aging and to estimate the number of assets that likely need to be addressed in the near future.

The categories of assets included in this study are as follows:

- Substation Transformers
- Circuit Breakers
- Pole Mounted Transformers
- Pad Mounted Transformers
- Pad Mounted Switchgear
- Poles
  - Wood
  - Concrete
- Underground Cables
  - Non-Tree Retardant XLPE
  - Tree Retardant XLPE

For each asset category, the following are included:

- HI formula
- Age distribution
- HI distribution





- Condition-based flagged for action (FFA) Plan
- Prioritized list of assets requiring attention
- Assessment of data availability and a data gap analysis

## 2. Asset Condition Assessment Methodology

The ACA methodology involves the process of determining asset HI, as well as developing a condition based FFA Plan for each asset group. In this project, NTPDL customized algorithms were developed using existing utility data and information, as well as input from the utility technical and field staff.

### 2.1 Health Index

Health Indexing quantifies equipment condition based on numerous condition parameters related to the degradation factors that lead to an asset’s end of service life. The Health Index is an indicator of the asset’s overall health and is typically given in terms of percentage, with 100% representing an asset in brand new condition and values close to 0 representing an asset close to the end of its physical life. Health Indexing provides a measure of long-term degradation and thus differs from defect management, whose objective is finding defects and deficiencies that need correction or remediation in order to keep an asset operating prior to reaching its end of life.

*Condition parameters* are the asset characteristics or properties that are used to derive the HI. A condition parameter may be comprised of several sub-condition parameters. For example, a parameter called ‘Oil Quality’ may be a composite of parameters such as ‘Moisture’, ‘Acid’, ‘Interfacial Tension’, ‘Dielectric Strength’ and ‘Color’.

In formulating a HI, condition parameters are ranked, through the assignment of *weights*, based on their contribution to asset degradation. The *condition parameter score* for a parameter is a numeric evaluation of an asset with respect to that parameter.

HI, which is a function of scores and weights, is therefore given by:

$$HI = \frac{\sum_{m=1}^{\forall m} \alpha_m (CPS_m \times WCP_m)}{\sum_{m=1}^{\forall m} \alpha_m (CPS_{m.max} \times WCP_m)} \times DR$$

Equation 1

where



$$CPS_m = \frac{\sum_{n=1}^{\forall n} \beta_n (SCPS_n \times WSCP_n) \times DR_n}{\sum_{n=1}^{\forall n} \beta_n (WSCP_n)} \times DR_m$$

**Equation 2**

|                      |   |
|----------------------|---|
| CPS                  | Condition Parameter (CP) Score, 0-4   |
| WCP                  | Weight of Condition Parameter   |
| $\alpha_m / \beta_n$ | Data availability coefficient for condition/sub-condition parameter (1 if input data available; 0 if not available) |
| SCPS                 | Sub-Condition Parameter (SCP) Score, 0-4  |
| WSCP                 | Weight of Sub-Condition Parameter   |
| DR                   | Derating Multiplier   |

The scale that is used to determine an asset’s score for a parameter is called the *condition criteria*. In the Kinectrics methodology, a condition criterion scoring system of 0 through 4 is used. A score of 0 is the ‘worst’ possible score; a score of 4 is the ‘best’ score, i.e.  $CPS_{max} = SCPS_{max} = 4$ .

The  $\alpha$  and  $\beta$  values are set to 0 if the parameter data is unavailable and 1 if the data is available. It is evident from the equations that the HI formula will, in essence, be readjusted for each unit depending on the specific data available for each unit. For example, if the HI formula for a certain asset category is based originally on 5 condition parameters (i.e.  $m = 5$  in Equation 1) but a specific unit only has parameters 1 and 3 available (e.g.  $\alpha_1 = 1, \alpha_2 = 0, \alpha_3 = 1, \alpha_4 = 0, \alpha_5 = 0$ ), its HI calculation will only be based on parameters 1 and 3.

Derating (DR) Multipliers are also used to adjust a condition or sub-condition parameter score or calculated Health Index to reflect certain conditions. These may be factors that may or may not be related to asset condition but may impact asset service life. For example, certain breaker operating mechanisms may be problematic, so a DR Multiplier may be associated with operating mechanism. A certain population of wood poles may be in a region that is prone to lightning strikes. The HI of these poles may be de-rated to reflect higher likelihood of lightning.

Dominant parameters may be used as Derating multipliers. These are asset properties that are of such importance that their status has a dominant impact on the value of the Health Index. An example is oil dielectric breakdown strength of transformers. If the breakdown strength is poor, a DR Multiplier can be applied to the HI, placing the transformer in poor condition, regardless of the overall HI score.

In this methodology, the final HI assigned to an individual asset is limited by the asset’s age. An *Age Limiter (AL)*, which is equal to the cumulative survival probability at a given age of an asset group, is compared to the calculated HI. If the calculated HI is less than or equal to the AL, the



final HI assigned is the calculated HI. If the calculated HI is more than the AL, then the final HI assigned is equal to the AL. It is important to note in using the AL that although the calculated HI (based in condition data such as test results, inspections, loading, etc.) may be high, the final HI may be low because of asset age.

The final HI score is:

$$HI_{Final} = \begin{cases} \text{if } (AL < HI, HI_{Final} = AL) \\ \text{else } (HI_{Final} = HI) \end{cases}$$

**Equation 3**

AL            Age Limiter  
HI            Health Index calculated per Equation 1

As stated previously, an asset’s HI is given as a percentage, with 100% representing ‘as new’ condition. The HI is calculated if there is age or some condition data available. The subset of the population with such data is called the *sample size*. Results are presented in terms of number of units and as a percentage of the sample size. If the sample size is sufficiently large and the units within the sample size are sufficiently random, the results may be extrapolated for the entire population.

The HI distribution given for each asset group illustrates the overall condition of the asset group. Further, although HI is calculated for each unit, for simplicity of presentation the results are aggregated into five categories and the categorized distribution for each asset group is given. The HI categories are as follows:

|           |                         |
|-----------|-------------------------|
| Very Poor | Health Index < 25%      |
| Poor      | 25 ≤ Health Index < 50% |
| Fair      | 50 ≤ Health Index < 70% |
| Good      | 70 ≤ Health Index < 85% |
| Very Good | Health Index ≥ 85%      |

## 2.2 Condition Based Flagged for Action Plan

In this methodology, the Flagged for Action (FFA) Plan for a given asset category shows the number of assets that may require attention or action each year within the planning period. Possible actions are to replace, refurbish, further test, monitor, implement operating solution, etc. The plan is condition or health based, meaning other factors, such as economics, obsolescence, system growth, etc. are not considered. A ‘Levelized’ FFA Plan smooths the peaks and valleys of the FFA Plan.

The two ways for determining the assets within FFA Plan in this methodology are the ‘Life Curve’ approach and the ‘Risk Based’ approach. The selected action is asset dependent. These are further explained in subsequent sections. The asset life curve models are first established.



**Life Curves**

In this project the term ‘removals’ is used to describe the removal of assets from service, regardless of the reason. Reasons for removal can include asset failure, proactive replacement because of condition, system growth, obsolescence, third party construction, etc.

A frequency of removals that grows exponentially with age generally provides a good overall model of asset service life. Based on Kinectrics’ experience in failure rate studies of multiple power system asset groups, Kinectrics has selected the Weibull equation to model the removals as functions of asset age. The Weibull distribution has no specific characteristic shape and, as such, can model the exponentially increasing removal rate using appropriate parameters.

The Weibull distribution is a continuous probability distribution with the following probability density function equation:

$$f(t) = \frac{\beta t^{\beta-1}}{\alpha^\beta} e^{-\left(\frac{t}{\alpha}\right)^\beta}$$

**Equation 4**

- $f(t)$  = probability density function (PDF), i.e. *likelihood that an asset will be removed from service when its age is within a particular range*
- $t$  = time (age in years)
- $\alpha, \beta$  = constant parameters that control the shape of the curve

The corresponding cumulative distribution function is as described in the equation below. The function models cumulative likelihood of removals over time. The likelihood of survival is the complement of the likelihood of removal:

$$Q(t) = 1 - R(t) = 1 - e^{-\left(\frac{t}{\alpha}\right)^\beta}$$

**Equation 5**

- $Q(t)$  = cumulative distribution function (CDF), i.e. *cumulative likelihood of removals*
- $R(t)$  = survival function

The removal rate (i.e. percentage of removals associated with a certain age) is:


$$\lambda(t) = \frac{f(t)}{1 - Q(t)} = \frac{\beta t^{\beta-1}}{\alpha^\beta}$$

**Equation 6**

- $\lambda(t)$  = percent removals per year per age, i.e. *removal rate*

Different asset groups experience different removal rates. The parameters  $\alpha$  and  $\beta$  define the shape of the Weibull distribution for a specific asset group. Examples of the three functions described above are shown in Figure 2-1, where  $\alpha = 57.503$  and  $\beta = 4.132$ . It can be seen from the graph and from Equation 4 that  $Q(40) = 0.2$  and  $Q(75) = 0.95$ . In other words, the cumulative distribution functions (i.e. cumulative likelihood of removals) at age = 40 and 75 years are 20% and 95% respectively. The area beneath the red PDF curve between the purple hatched lines (at age = 45 and 60 years) equates to 41.6% of the entire area under the beneath curve. This represents a 41.6% likelihood that an asset removed from service will be between the ages of 45 to 60 years.

For each asset group, the values of these constant  $\alpha$  and  $\beta$  parameters were calculated such that they reflect typical service lives of the asset groups. With assets that are run to failure, the removal curve may closely resemble the failure curve of the asset. Note however, that the removal curves will include assets that have been removed for reasons other than failure (e.g. removals because of proactive replacement based on condition, system growth, obsolescence, etc.). In this project that the life curves developed for all asset groups were based on typical industry values.



**Figure 2-1 Weibull Functions**

### 2.2.1 Flagged for Action Plan Using a Life Curve Approach

The Life Curve approach is used to estimate the number of assets to be addressed in a given year, using the asset's removal rate (Equation 6).

An example of such a Flagged for Action Plan is as follows: Consider an asset distribution of 100 5-year-old units, 20 10-year-old units, and 50 20-year-old units. Assume that the failure rates for

5, 10, and 20-year-old units for this asset class are  $f_5 = 0.02$ ,  $f_{10} = 0.05$ ,  $f_{20} = 0.1$  failures / year respectively. In the current year, the total number of replacements is  $100(.02) + 20(0.05) + 50(0.1) = 2 + 1 + 5 = 8$ .

In the following year, the expected asset distribution is, as a result, as follows: 8 1-year old units, 98 6-year-old units, 19 11-year-old units, and 45 21-year-old-units. The number of replacements in year 2 is therefore  $8(f_1) + 19(f_6) + 45(f_{11}) + 45(f_{21})$ .

Note that in this study the ‘age’ used is in fact ‘effective age’, or condition-based age as defined by the asset HI, as opposed to the chronological age of the asset.

For the asset categories below, this probabilistic approach is used to estimate the FFA Plan. It is also important to note that the FFA Plan gives only the estimated number of assets per year that need to be addressed; the year that a specific unit needs to be addressed is not calculated.

- Pole Mounted Transformers
- Pad Mounted Transformers
- Pad Mounted Switchgear
- Poles (Wood and Concrete)
- Underground Cables (Non-TRXLPE, TRXLPE)

### 2.2.2 Flagged for Action Plan Using a Risk-Based Approach

For some assets costs of replacement and/or consequences of failure are significant, and as a result planning for replacement requires more consideration than only condition. For these assets, a risk-based approach is taken when developing the FFA Plan. The FFA Year (the year that a unit is flagged for action) is calculated for each asset unit.

This risk-based methodology considers both the asset likelihood of removal (as related to HI) and its consequence of failure (criticality). The product of likelihood or removal and consequence of failure determines asset risk.





Figure 2-2 Risk Assessment Procedure

*Relating Health Index to Likelihood of Removal*

The health of an asset correlates to condition based likelihood of removal. The methodology that this project uses to relate HI to likelihood or removal considers asset stress as described below.

If there are no dominant sources, it is assumed in this methodology that the stress to which an asset is exposed is not constant and will have a somewhat normal frequency distribution. This is illustrated by the probability density curve of stress below. The vertical lines in the figure represent condition or strength (HI) of an asset.




**Figure 2-3 Stress Curve**

An asset in as-new condition (100% strength) should be able to withstand most levels of stress. As the condition of the asset deteriorates, it may be less able to withstand higher levels of stress. Consider, for example, the green vertical line that represents 70% condition/strength. The asset should be able to withstand magnitudes of stress to the left of the green line. If, however, the stress is of a magnitude to the right of the green line, the asset can fail and consequently be removed from service.

To create a relationship between the HI and likelihood of removal, assume two “points” on the stress curve that correspond to two different HI values. In this example, assume that an asset that has a condition/strength (HI) of 100% can withstand all magnitudes of stress to the left of the purple line. It then follows that probability that an asset in 100% condition will fail is the

probability that the magnitude of stress is at levels to the right of the purple line. This corresponds to the area under the stress density curve to the right of the purple line. Similarly, if it assumed that an asset with a condition of 15% will fail if subjected to stress at magnitudes to the right of the red line, the probability of failure at 15% condition is the area under the stress density curve to the right of the red line.

The likelihood of removal at a particular HI is found from plotting the HI on the X-axis and the area under the probability density curve to the right of the HI line on the Y-axis, as shown on the graph of the figure below.



**Figure 2-4 Likelihood of Removal vs. Health Index**

*Criticality*

In this study, the metric used to measure consequence of failure is referred to as *Criticality*. Criticality may be determined in numerous ways, with monetary consequence or degree of risk to corporate business values being examples. The higher the criticality value assigned to a unit, the higher it's consequence of failure.

The asset's criticality is defined as follows:

$$\text{Criticality} = (\text{Criticality}_{\text{max}} - \text{Criticality}_{\text{min}}) * \text{Criticality\_Index} + \text{Criticality}_{\text{min}}$$

**Equation 7**

Where the maximum and minimum criticality values are as follows:

$$\text{Criticality}_{\text{max}} = 1/(80\%) = 1.25$$





$$\text{Criticality}_{\min} = 1/(95\%) = 1.05$$

This study flags an asset as a candidate for action when the risk (product of its likelihood of removal and criticality) is greater than or equal to one. The above maximum and minimum Criticality values were selected to ensure that units with highest relative importance are flagged as soon as the likelihood of removal is 80% (i.e. Consider an asset whose HI corresponds to an 80% likelihood of removal and whose Criticality = 1.25. Its risk = likelihood of removal x Criticality = 80% X 1.25 = 1. Since the risk = 1, the asset is flagged for action). Action for units that are least critical can be deferred until likelihood of removal is 95%.

As seen in Equation 6 above, a *Criticality Index* (CI) will be calculated for each asset to quantify Criticality. Similar to the HI, the CI is a sum-product of scores and weights of parameters that represent a unit's consequence of failure. CI ranges from 0% to 100%, with 100% representing the unit with the highest possible consequence of failure.

$$\text{Criticality\_Index} = \frac{\sum_{i=1}^{n_i} (\text{SCR}_i \times \text{WCR}_i)}{\sum_{i=1}^{n_i} (\text{WCR}_i)}$$

**Equation 8**

SCRP Score of criticality risk parameter  
WCRP Weight of criticality risk parameter

*Risk*

As previously mentioned, asset risk is the product of likelihood of removal and Criticality:

$$\text{Risk} = \text{Likelihood of Removals} \times \text{Criticality}$$

**Equation 9**

Since the likelihood of removal ranges from 0 to 1 and Criticality ranges from 1.05 to 1.25 in this methodology (i.e. Criticality<sub>min.</sub> = 1.05 and Criticality<sub>max.</sub> = 1.25), asset Risk will range from 0 to 1.25. However, to better visualize the relative risk of each asset within an asset category, a normalized *Risk Index* for each asset is also given. The Risk Index is simply the asset's calculated Risk divided by the maximum Criticality (i.e. Risk Index = (Likelihood of Failure x Criticality) / Criticality<sub>max.</sub>). As a result the Risk Index ranges from 0% to 100%.

The risk-based approach was used to estimate the FFA Plan for Substation Transformers and Circuit Breakers. With this approach, in addition to the estimated number of assets per year that need to be addressed, the FFA Year (i.e. the years that a particular unit is flagged for action) is calculated for each asset unit.



## 2.3 Data Assessment

The condition data used in this study was provided by NTPDL and included the following:

- Asset Properties (e.g. age, size, voltage, location information)
- Test Results (e.g. Oil Quality, DGA, power factor, contact resistance, etc.)
- Loading information
- Inspection records

There are two dimensions for assessing the availability and completeness of data used in this study: Data Availability Indicator (DAI) and data gap.

### 2.3.1 Data Availability Indicator (DAI)

The Data Availability Indicator (DAI) is a measure of the amount of condition parameter data that an asset has, as measured against the condition parameters included in the HI formula. It is determined by the ratio of the weighted condition parameters score and the subset of condition parameters data available for the asset over the “best” overall weighted, total condition parameters score. The formula is given by:

$$DAI = \frac{\sum_{m=1}^{\forall m} (DAI_{CPSm} \times WCP_m)}{\sum_{m=1}^{\forall m} (WCP_m)}$$

Equation 10

where

$$DAI_{CPSm} = \frac{\sum_{n=1}^{\forall n} \beta_n \times WSCP_n}{\sum_{n=1}^{\forall n} (WSCP_n)}$$

Equation 11

|              |  |
|--------------|--|
| $DAI_{CPSm}$ | Data Availability Indicator for Condition Parameter m with n Sub-Condition Parameter (SCP)                   |
| $\beta_n$    | Data availability coefficient for sub-condition parameter (=1 when data available, =0 when data unavailable) |
| $WSCP_n$     | Weight of Sub-Condition Parameter n Parameters   |
| $WCP_m$      | Weight of Condition Parameter m  |



For example, consider an asset with the following condition parameters and sub-condition parameters:

| Condition Parameter |      | Condition Parameter Weight (WCP) | Sub-Condition Parameter |      | Sub-Condition Parameter Weight (WSCP) | Data Available? ( $\beta = 1$ if available; 0 if not) |
|---------------------|------|----------------------------------|-------------------------|------|---------------------------------------|---|
| m                   | Name |                                  | n                       | Name |                                       |   |
| 1                   | A    | 1                                | 1                       | A_1  | 1                                     | 1   |
| 2                   | B    | 2                                | 1                       | B_1  | 2                                     | 1   |
|                     |      |                                  | 2                       | B_2  | 4                                     | 1   |
|                     |      |                                  | 3                       | B_3  | 5                                     | 0   |
| 3                   | C    | 3                                | 1                       | C_1  | 1                                     | 0   |

The DAI is calculated as follows:

$$DAI_{CP1} = (1 \cdot 1) / (1) = 1$$

$$DAI_{CP2} = (1 \cdot 2 + 1 \cdot 4 + 0 \cdot 5) / (2 + 4 + 5) = 0.545$$

$$DAI_{CP3} = (0 \cdot 1) / (1) = 0$$

$$DAI = (DAI_{CP1} \cdot WCP_1 + DAI_{CP2} \cdot WCP_2 + DAI_{CP3} \cdot WCP_3) / (WCP_1 + WCP_2 + WCP_3)$$

$$= (1 \cdot 1 + 0.545 \cdot 2 + 0 \cdot 3) / (1 + 2 + 3)$$

$$= 35\%$$

An asset with all condition parameter data represented will, by definition, have a DAI value of 100%. In this case, an asset will have a DAI of 100% regardless of its HI score. Provided that the condition parameters used in the HI formula are of good quality and there are few data gaps, there will be a high degree of confidence that the HI score accurately reflects the asset's condition.

Note that where no condition data is available (i.e. no condition parameters are available) for an asset but the age is known, an HI can be calculated based on age (i.e. HI will be equal to the likelihood of survival at the asset's age). For these cases, the DAI is 0%. If there is no data whatsoever the HI will not be calculated. The DAI will still be shown as 0% because 0% means no condition data is available, and the HI will be reflected as a blank.

### 2.3.2 Data Gaps

The HI formulas developed and used in this study are based only on NTPDL's available data. There are additional data or tests that NTPDL may not collect or perform at the present time, but such data/tests are important indicators of the deterioration and degradation of assets. While these will not be included in the HI formula, the set of unavailable data are referred to as data gaps. I.e. a data gap is the case where **none** of the units in an asset group has data. This could be because the data is not collected, certain tests are not conducted, no inspection



procedures are in place to obtain condition data, etc. The situation where data is provided for only a sub-set of the population is not considered as a data gap. Consider a utility that has just implemented a wood pole testing program. The “pole strength” parameter will be added to the wood pole HI formula. Say that because the program is new, only 5% of the wood pole population presently have test data. In this case, wood pole is **not** a data gap. However, 95% of the wood pole population will have reduced DAI because they lack data pole strength data.

As part of this study, the data gaps of each asset category are identified. In addition, the data items are ranked in terms of importance. There are three priority levels, the highest being most indicative of asset degradation.

| Priority | Description  | Symbol |
|----------|--|--------|
| High     | Most useful as an indicator of asset degradation   | 1      |
| Medium   | Important data; can indicate the need for corrective maintenance or increased monitoring | 2      |
| Low      | Helpful data; least indicative of asset deterioration                                    | 3      |

It is generally recommended that data collection be initiated for the most critical items because such information will result in higher quality HI formulas.

The more critical and important data included in the HI formula of a certain asset group, and the higher the DAI of a particular unit in that group, the higher the confidence in the HI calculated for the particular unit.

If an asset group has significant data gaps and the data used to derive the HI is not good condition data (e.g. age only), there is less confidence that the HI score of a particular unit accurately reflects its condition, regardless of the value of its DAI.

To facilitate the incorporation of data gap items into improved HI formulas for future assessments, the data gap items are presented in this report as condition parameters. Given are a description of the data, priority, and possible data sources.

The following is an example for “Tank Corrosion” on a Pad-Mounted Transformer:

| Data Gap       | Priority | Description   | Source                                 |
|----------------|----------|---|--|
| Tank Corrosion | 2        | Tank surface rust or deterioration due to environmental factors | Inspections or corrective work orders. |



### 3. Results

This section summarizes the findings of this study.

#### 3.1 Health Index Results

A summary of the HI results is shown in Table 3-1. For each asset category the population, sample size (number of assets with sufficient data for Health Indexing), and average age are given. The average HI and HI distribution are also shown. A summary of the HI distributions for all asset categories are also graphically shown in Figure 3-1.

Three, 13% of the population, substation transformers were classified in the very poor category (details shown in Appendix A, Section 1). Two transformers were categorized as such, primarily because of age. One, however, had poor moisture test results. This transformer should be investigated as it may require closer monitoring or more immediate corrective actions to ensure proper operation.

Approximately 19% of pole mounted transformers were in the poor or very poor condition category. A major contributor to this is the age of the asset group; Approximately 54% of the population is 40 years or older.

Eleven percent (11%) of pad mounted transformers were in the poor or very poor condition category. With 18% of the population being 40 years or older, this is also an asset group that is aging. Many were units were also flagged being in poor condition overall during NTPDL inspections.

About 19% of Non-TRXLPE cables (more than 74 conductor-km) were classified as very poor. Note that this estimation was based on cable age only since there is no other data available for cables.

Also of note are the 6% of wood poles in poor or very poor condition. Because of the large population, this equates to 354 poles. The remaining asset categories had minimal or no percentage of units in poor or very poor condition.

***[ The remainder of this page intentionally left blank.]***



**Table 3-1 Health Index Summary**

| Asset Category                   | Population         | Sample Size |       | Average Health Index | Health Index Distribution |                  |                  |                  |                    | Average Age | Average DAI |     |
|----------------------------------|--------------------|-------------|-------|----------------------|---------------------------|------------------|------------------|------------------|--------------------|-------------|-------------|-----|
|                                  |                    | Counts      | %     |                      | Very Poor (< 25%)         | Poor (25 - <50%) | Fair (50 - <70%) | Good (70 - <85%) | Very Good (>= 85%) |             |             |     |
| <b>Substation Transformers</b>   | 23                 | 23          | 100%  | 82%                  | 13%                       | 0%               | 4%               | 13%              | 70%                | 29          | 73%         |     |
| <b>Circuit Breakers</b>          | 61                 | 61          | 100%  | 100%                 | 0%                        | 0%               | 0%               | 0%               | 100%               | 15          | 67%         |     |
| <b>Pole Mounted Transformers</b> | 1797               | 1318        | 73%   | 76%                  | 3%                        | 16%              | 19%              | 4%               | 58%                | 29          | 33%         |     |
| <b>Pad Mounted Transformers</b>  | 4428               | 4187        | 95%   | 86%                  | 5%                        | 5%               | 5%               | 9%               | 75%                | 23          | 56%         |     |
| <b>Pad Mounted Switchgear</b>    | 133                | 130         | 98%   | 83%                  | < 1%                      | 4%               | 20%              | 20%              | 55%                | 19          | 98%         |     |
| <b>Poles</b>                     | <b>Wood</b>        | 8147        | 6149  | 75%                  | 88%                       | 3%               | 3%               | 7%               | 16%                | 71%         | 29          | 62% |
|                                  | <b>Concrete</b>    | 303         | 300   | 99%                  | 100%                      | 0%               | 0%               | 0%               | 0%                 | 100%        | 9           | 39% |
| <b>UG Cables* (conductor-km)</b> | <b>Non-TR XLPE</b> | 412.6       | 389.7 | 94%                  | 80%                       | 11%              | 8%               | 2%               | 10%                | 69%         | 32          | 0%  |
|                                  | <b>TR XLPE</b>     | 278.5       | 229.1 | 82%                  | 100%                      | 0%               | 0%               | 0%               | 0%                 | 100%        | 18          | 0%  |

Note: In addition to the total of 691 conductor-km of cables shown, there is an additional 92 conductor-km of cables with insufficient information for assessment. The total population of underground cables is 783 conductor-km. The overall sample size for underground cables is 79%.




Figure 3-1 Health Index Summary (Graphical)



## 3.2 Condition-Based Flagged for Action (FFA) Plan

Table 3-2 and Table 3-3 show the 10-year FFA Plan and 'Levelized' FFA Plan. The FFA Plan estimates the number of units expected to require attention in a given year, whereas the 'Levelized' FFA Plan smooths out peaks and valleys to more constant rates. In both tables, the yearly average for Years 0 through 5 (i.e. sum of assets flagged for action between years 0 through 5 divided by 6) is also shown. The same results are shown graphically in Figure 3-2 and Figure 3-3.

It is evident that there may be significantly larger quantities of assets flagged for action in the first year than in subsequent years. This represents a backlog of assets that require attention. This is generally the case when there is a large quantity of assets that are at or near the end of their expected service lives. Because such assets would have higher likelihood of failure, large quantities will be flagged for intervention in the first year. Since the assessment methodology assumes that all units flagged for action are addressed, the quantities flagged for action in year 2 or later may be significantly smaller than that of the first year. In reality, only some of the units flagged for action in the first year will be dealt with while the remaining units will be addressed in subsequent years. This will eventually change the flagged for action list in the coming years as the backlog is gradually reduced.

NTPDL's most significant numbers flagged for action, in terms of number of units, in the current year were found to be for pole and pad mounted transformers, wood poles, and underground cables. In the current year, 416 distribution transformers, 266 wood poles, and 51 km of cables are flagged for attention. If levelized and averaged over the next few, the quantities to be addressed may be more manageable. For example, the number of distribution transformers is reduced to 167 per year in the next 5 years.

The 3 substation transformers classified as poor or fair were flagged for action within the next 5 years. Those that were flagged based on age should be monitored closely (test results, inspections, loading, etc.) for any change in condition. The transformer flagged because of poor high moisture should be investigated further to determine if any immediate corrective actions are required.





**Table 3-2 Flagged for Action Plan**

| Asset Category                   | Years (0-10) |      |      |      |      |      |      |      |      |      |      | Now (Year 0)    |                          | Years 0 - 5 Inclusive |                |
|----------------------------------|--------------|------|------|------|------|------|------|------|------|------|------|-----------------|--------------------------|-----------------------|----------------|
|                                  | 0            | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    | 10   | Number of Units | Percentage of Population | Total Number of Units | Yearly Average |
| <b>Substation Transformers</b>   | 0            | 0    | 1    | 2    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 3                     | < 1            |
| <b>Circuit Breakers</b>          | 0            | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 0                     | 0              |
| <b>Pole Mounted Transformers</b> | 100          | 75   | 64   | 50   | 46   | 50   | 46   | 47   | 42   | 40   | 37   | 100             | 6%                       | 385                   | < 65           |
| <b>Pad Mounted Transformers</b>  | 316          | 133  | 88   | 73   | 67   | 68   | 71   | 76   | 80   | 84   | 96   | 316             | 7%                       | 745                   | < 125          |
| <b>Pad Mounted Switchgear</b>    | 2            | 2    | 1    | 2    | 2    | 2    | 4    | 4    | 2    | 4    | 5    | 2               | 2%                       | 11                    | < 2            |
| <b>Wood Poles</b>                | 266          | 178  | 125  | 99   | 83   | 71   | 65   | 67   | 62   | 59   | 59   | 266             | 3%                       | 822                   | < 137          |
| <b>Concrete Poles</b>            | 0            | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 0                     | 0              |
| <b>UG Cables Non-TR XLPE*</b>    | 50.9         | 22.8 | 18.8 | 17.4 | 16.6 | 16.4 | 16.9 | 17.9 | 18.8 | 19.5 | 19.6 | 50.9            | 12%                      | 142.9                 | < 24           |
| <b>UG Cables TR XLPE*</b>        | 0.0          | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 1.0  | 1.0  | 1.0  | 1.0  | 0.0             | 0%                       | 0                     | 0              |

\*conductor-km



**Table 3-3 Flagged for Action Plan – Levelized**

| Asset Category                   | Years (0-10) |      |      |      |      |      |      |      |      |      |      | Now (Year 0)    |                          | Years 0 - 5 Inclusive |                |
|----------------------------------|--------------|------|------|------|------|------|------|------|------|------|------|-----------------|--------------------------|-----------------------|----------------|
|                                  | 0            | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    | 10   | Number of Units | Percentage of Population | Total Number of Units | Yearly Average |
| <b>Substation Transformers</b>   | 0            | 0    | 1    | 1    | 1    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 3                     | < 1            |
| <b>Circuit Breakers</b>          | 0            | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 0                     | 0              |
| <b>Pole Mounted Transformers</b> | 65           | 62   | 59   | 56   | 53   | 50   | 48   | 48   | 48   | 48   | 48   | 65              | 4%                       | 345                   | < 58           |
| <b>Pad Mounted Transformers</b>  | 124          | 115  | 109  | 104  | 101  | 100  | 100  | 101  | 100  | 100  | 100  | 124             | 3%                       | 653                   | < 109          |
| <b>Pad Mounted Switchgear</b>    | 2            | 2    | 3    | 2    | 3    | 3    | 3    | 3    | 3    | 4    | 3    | 2               | 2%                       | 15                    | < 3            |
| <b>Wood Poles</b>                | 137          | 125  | 115  | 106  | 99   | 92   | 86   | 86   | 87   | 86   | 88   | 137             | 2%                       | 674                   | < 113          |
| <b>Concrete Poles</b>            | 0            | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0               | 0%                       | 0                     | 0              |
| <b>UG Cables Non-TR XLPE*</b>    | 22.2         | 22.0 | 21.7 | 21.2 | 21.0 | 20.9 | 20.2 | 20.2 | 19.3 | 19.3 | 19.3 | 22.2            | 5%                       | 129                   | < 22           |
| <b>UG Cables TR XLPE*</b>        | 0.0          | 0.0  | 0.0  | 0.0  | 0.0  | 1.0  | 1.0  | 1.0  | 1.0  | 1.0  | 1.0  | 0.0             | 0%                       | 1                     | < 1            |

\*conductor-km




Figure 3-2 Flagged for Action Plan (Graphical)




Figure 3-3 Flagged for Action Plan Levelized (Graphical)



### 3.3 Data Assessment

This section summarizes the data that was used for the assessment and observations and recommendations pertaining to the data used in the assessment. Note that details for each asset category are given in Appendix A.

Table 3-4 shows the data feeding the health index, average DAIs, and data gaps and observations. An overall data assessment, representing to the degree with which the data reflects asset condition, is also given. Recall from Section 2.3.1 that the DAI is a measurement that is relative to the condition information that NTPDL currently collects (and is included as an HI parameter), whereas data gaps are HI parameter information that NTPDL does not collect for any of the units within an asset group. As such, even if an asset group has a high DAI, this does not mean that ideal information for this asset group is complete. If numerous high priority data gaps exist, the degree of confidence that the HI reflects true conditions may still be low. The overall assessment is shown as either 1, 2 or 3, where a score of '1' indicates the highest relative degree of confidence in the data quality and quantity.

Substation transformers and circuit breakers were given a score of '1' because average DAIs were high and data gaps were minimal. Additionally, many of the data (and therefore parameters) were based on test results. Pad mounted transformers were also given a '1' because of relatively more comprehensive inspection records and overall hazard assessment. The DAI should, however, be improved.

Pad mounted switchgear, wood and poles were categorized as '2'. These asset groups had inspection records for overall condition and pad mounted switchgear had other basic inspection records. Additionally, this data was available for the majority of the populations.

Pole mounted transformers were categorized as a '2/3' (i.e. between 2 and 3) because while basic inspection information was available for transformers in Midland, the remainder of the population had only age information. Concrete poles were also categorized as '2/3' because although there were inspection records for overall condition, they were only available for 39% of the population.

Cables were categorized as '3' because the assessments were age-based.

There are also general observations and recommendations applicable to all asset categories:

1. For future assessments, it is suggested that work order information be collected and incorporated into the health index formulas. Total work orders and severity of each work order give an overall indication of whether a particular unit is historically problematic.
2. NTPDL should also consider collecting removal data. When building NTPDL specific asset life curves, historic removal records are essential. For each removal (permanent out of service), details such as age, nameplate information, reason for removal, HI score at the time of removal, etc. should be recorded.



- The data used in this assessment was extracted from different locations (e.g. numerous spreadsheets or PDF files). For more efficient record keeping and ease of future assessments, NTPDL may wish to consider implementing platform that consolidates asset information and condition data (e.g. nameplate information, test results, operational information, inspection records, etc.) and that can perform live asset analytics.

**Table 3-4 Data Assessment Summary**

| Asset Category                   | Basis of Health Index Formula  | Average DAI | Data Gaps and Observations (H, M, L = high, medium, low priority respectively)  | Overall Data Assessment |
|----------------------------------|--|-------------|---|-------------------------|
| <b>Substation Transformers</b>   | Nameplate<br>GOQ<br>DGA<br>TTR<br>Winding Resistance<br>Power Factor<br>Insulation Resistance<br>Inspection Records<br>Loading | 73%         |   | 1                       |
| <b>Circuit Breakers</b>          | Nameplate<br>Maintenance Test (timing gests, contact resistance)<br>Inspection Records<br>Operation Counts                     | 67%         | <i>Test Result</i><br>Historical, as-found, as-left test results (e.g. timing tests, contact resistance). This will enable incorporation of trends into the health index model. (L-M) | 1                       |
| <b>Pole Mounted Transformers</b> | Nameplate<br>Inspection Records<br>Infra-red inspections   | 33%         | <i>Inspection Records</i><br>All inspections for Newmarket and Tay units (H)<br>Termination condition for all regions (H)<br><br><i>Loading (H)</i>                                   | 2/3                     |
| <b>Pad Mounted Transformers</b>  | Nameplate<br>Inspection Records<br>Infra-red inspections   | 56%         | <i>Inspection Records</i><br>More granular inspections, i.e. Door mechanism (L)<br>Insulation (H)<br>Termination (H)<br>Base and Surroundings (H)<br><br><i>Loading (H)</i>           | 1                       |
| <b>Pad Mounted Switchgear</b>    | Nameplate<br>Inspection Records  | 98%         | <i>Inspection Records</i><br>More granular inspections, i.e. Enclosure (L)<br>Fuse/Switch (H)<br>Insulation (H)<br>Connections (H)<br>Base and Surroundings (L)                       | 2                       |



| Asset Category      |            | Basis of Health Index Formula | Average DAI | Data Gaps and Observations (H, M, L = high, medium, low priority respectively)  | Overall Data Assessment |
|---------------------|------------|-------------------------------|-------------|---|-------------------------|
| Poles               | Wood       | Nameplate Inspection Records  | 62%         | <i>Pole Strength</i> (wood) (H)<br><br><i>Inspection Records</i><br>More granular inspections, i.e. Detailed physical condition (M)<br>Pole Accessories, i.e. hardware, insulators, conductors, and brace (M)<br>Environment (L)                                      | 2                       |
|                     | Concrete   | Nameplate                     | 39%         |   | 2/3                     |
| Under-ground Cables | Non TRXLPE | Age                           | Age-based   | <i>Test Result</i><br>Dielectric tests, PD test, neutral resistance, conductor resistance, IR Scans, etc. (H)<br><br><i>Inspection Records</i><br>Damage on visible parts, e.g. terminations (M)<br><br><i>Fault Rate</i><br>Historical failure rates per segment (M) | 3                       |
|                     | TRXLPE     | Age                           | Age-based   |   |                         |

#### 4. Conclusions and Recommendations

This section summarizes the findings of this study.

1. An ACA was conducted for a NTPDL's key distribution assets. For each asset category, the health indices were calculated and a condition based FFA Plan was developed. Asset lists, prioritized by risk or health, were developed. An assessment of the data available and data gaps was also conducted.
2. Three substation transformers were placed in the poor category and flagged for action within the next 5 years. Those that were flagged based on age should be monitored closely (test results, inspections, loading, etc.) for any change in condition. The transformers flagged because of poor test results (high moisture) should be investigated further to determine if any immediate corrective actions are required.
3. Approximately 19% of pole mounted transformers were in poor or very poor condition category. Approximately 58 pole mounted transformers a year in the next 5 years (levelized plan) may require attention (e.g. maintenance, refurbishment, replacement).



4. Approximately 11% of pad mounted transformers were in poor or very poor condition category. As such, 109 pad mounted transformers a year in the next 5 years (levelized plan) may require attention.
5. Six (6%) of wood poles were in poor or very poor condition. Because of the large population of wood poles, approximately 113 poles per year (levelized plan) may need to be addressed.
6. About 19% of Non-TRXLPE cables (74 conductor-km) were classified as very poor or poor. Note that this estimation was based on cable age since no other data was available for cables. Because the service life of non-TRXLPE cables is expected to be shorter than that of TRXLPE cables, it is estimated that approximately 22 conductor-km per year may need to be addressed.

There are many considerations in deciding the most appropriate and cost-effective course of action (e.g. replacement, refurbishment, etc.) for underground cables. Examples are vintage, cable type, condition of concentric neutrals, etc. NTPDL may wish to collect additional information (e.g. failure rates, cause of failure from failure investigation, implement a cable testing program, etc.) to facilitate such decision making.

7. Observations pertaining to the data used in this study were made. Where they exist, data gaps were also identified for each asset category.

Relative to the other asset categories, station transformers had the most complete data set, in terms of quality and quantity (i.e. data gap or concern and DAI). Circuit breakers also had good data and a fairly high DAI. Pad-mounted transformers had good data also, but better data collection can be done to improve the current 56% DAI.

Pad mounted switchgear, distribution transformers, and poles inspections for overall conditions, at varying degrees of DAI.

Underground cables were assessed based on asset age only.

It is recommended that data be collected in a prioritized manner so that such data can be used in future assessments. It is also recommended that the DAI be improved for each asset category by ensuring that ultimately the complete health index data set is made available for each asset.

8. For future assessments, NTPDL should consider collecting and incorporating work order information. Total work orders and severity of each work order give an overall indication of whether a unit is historically problematic.
9. NTPDL should also consider collecting removal data to enable the development of NTPDL specific asset life curves. The curves used in the current assessment are currently based on a combination of NTPDL's asset demographics and typical industry experience. Using actual removal curves will result in more accurate life curves.





10. The data used in this assessment was from different locations (e.g. numerous spreadsheets or PDF files). For more efficient record keeping and ease of future assessments, NTPDL may wish to consider implementing platform that consolidates asset information and condition data (e.g. nameplate information, test results, operational information, inspection records, etc.) and that can perform live asset analytics.
  
11. It is important to note that the Flagged for Action plan presented in this study is based primarily on asset condition. It is worth noting that there are numerous other considerations that may influence NTPDL's asset management plan. Among these are obsolescence, system growth, corporate priorities, technological advancements, etc.

*[The remainder of this page is intentionally left blank.]*



## 5. References

ABB, "Instruction Manual, R-MAG@Medium Voltage Outdoor Dead Tank Vacuum Magnetic Circuit Breaker, 38kV 1250/2000A," 1VAL255104-MB Rev D.

Edvard, "Comparison between Vacuum and SF6 Breaker", Electrical Engineering Portal, September 5, 2010.

CEATI International, " CEATI 6005-Distribution Line Reliability Improvements Impacts Upstream Equipment Life," 2014.

Cress S.L. et al, "Utility Guide to Root Cause Analysis of Distribution Failures" CEATI Report No. T074700-5068, February 2010.

Hjartarson T, Jesus B, Hughes D.T., Godfrey R.M., "The Application of Health Indices to Asset Condition Assessment", presented at IEEE-PES Conference in Dallas, September 2003.

Kinectrics Inc, K-014949, Title of document, 2014.

Kinectrics Inc, "Newmarket-Tay Power Distribution Ltd 2013 Asset condition Assessment Report", Kinectrics Inc. Report No: K-418514-RA-001-R000, August 25, 2014.

Kinectrics Inc, "Asset Depreciation Study for the Ontario Energy Board", Kinectrics Inc. Report No: K-418033-RA-001-R000, July 8, 2010.

IEEE Std C57.106-2015 IEEE Guide for Acceptance and Maintenance of Insulating Mineral Oil in Electric Equipment.

IEEE Std C57.104-2008 IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers.

Siemens, "Instructions, Installation, Adjustment, Maintenance, Type SPS2-15.5, 25.8, 38, 48.3, and 72.5 Gas Circuit Breaker Spring Operating Mechanism," PB 3638-01.

Siemens, "Instructions, Installation, Operation, Maintenance, Type 3AH 4.16kV to 38kV Vacuum Circuit Breaker Operator Module," SGIM-9918D.



## Appendix A Results for Each Asset Category

The results for each individual asset category are detailed in this section.

### 1. Substation Transformers

This asset class includes NTPDL's Substation Transformers. Sizes range from 5 to 16.6 MVA, with primary voltages ranging from 44 to 46 kV. There are 23 Substation Transformers at NTPDL. Of these, all 23 had sufficient data for assessment. The average age of the population is 29 years; age distribution is as follows:




Figure A 1-1 Substation Transformers Age Distribution



## 1.1 Health Index

### 1.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria for substation transformers.

**Table A 1-1 Substation Transformers Health Index Formula**

| Condition Parameter (CP) |              | Sub-Condition Parameter (SCP) |             |               |             |
|--------------------------|--------------|-------------------------------|-------------|---------------|-------------|
| Description              | Weight (WCP) | Description                   | Data Source | Weight (WSCP) | Criteria    |
| Internals                | 10           | H2                            | DGA         | 5             | Table A 1-2 |
|                          |              | CH4 (Methane)                 | DGA         | 3             | Table A 1-2 |
|                          |              | C2H6 (Ethane)                 | DGA         | 3             | Table A 1-2 |
|                          |              | C2H4 (Ethylene)               | DGA         | 3             | Table A 1-2 |
|                          |              | C2H2 (Acetylene)              | DGA         | 5             | Table A 1-2 |
| Insulation Oil           | 8            | Dissipation Factor            | GOQ         | 2             | Table A 1-3 |
|                          |              | Moisture                      | GOQ         | 4             | Table A 1-3 |
|                          |              | Dielectric Strength           | GOQ         | 5             | Table A 1-3 |
|                          |              | Interfacial Tension           | GOQ         | 3             | Table A 1-3 |
|                          |              | Acid Number                   | GOQ         | 2             | Table A 1-3 |
|                          |              | Colour                        | GOQ         | 1             | Table A 1-3 |
|                          |              | Particle Count                | GOQ         | 0*            | NA          |
|                          |              | Oxygen Inhibitor              | GOQ         | 0*            | NA          |
| Windings                 | 6            | Turns Ratio                   | Test        | 1             | Table A 1-4 |
|                          |              | Winding Resistance            | Test        | 1             | Table A 1-5 |
|                          |              | Exciting Current              | Test        | 0*            | NA          |
|                          |              | Leakage Reactance             | Test        | 0*            | NA          |
| Paper/<br>Pressboard     | 8            | Furanic Compound              | Oil Test    | 3             | Table A 1-6 |
|                          |              | Power Factor                  | Test        | 5             | Table A 1-7 |
|                          |              | Insulation Resistance         | Test        | 4             | Table A 1-8 |
|                          |              | Capacitance                   | Test        | 0*            | NA          |
|                          |              | PF Tip-Up                     | Test        | 0*            | NA          |
|                          |              | DGA CO                        | DGA         | 2             | Table A 1-2 |
|                          |              | DG CO2                        | DGA         | 1             | Table A 1-2 |
| Bushings                 | 5            | Capacitance                   | Test        | 0*            | NA          |
|                          |              | Power Factor                  | Test        | 0*            | NA          |
|                          |              | Dielectric Loss               | Test        | 0*            | NA          |
|                          |              | Oil Level (bushings only)     | Visual      | 0*            | NA          |
|                          |              | Partial Discharge (PD)        | Test        | 0*            | NA          |
|                          |              | Visual Appearance             | Visual      | 1             | Table A 1-9 |



|   |    |                                  |        |                |              |
|---|----|----------------------------------|--------|----------------|--------------|
| Tap Changer   | 1  | Visual Appearance                | Visual | 1              | Table A 1-9  |
| Rads, Coolers, and Valves   | 2  | Visual Appearance                | Visual | 0*             | NA           |
| Fans  | 1  | Visual Appearance                | Visual | 0*             | Table A 1-9  |
| Pump  | 0* | Visual Appearance                | Visual | 0*             | NA           |
| Conservator   | 1  | Visual Appearance                | Visual | 0*             | NA           |
| Tank  | 2  | Oil Leak                         | Visual | 1              | Table A 1-9  |
|   |    | Corrosion                        | Visual | 1              | Table A 1-9  |
|   |    | Oil Containment                  | Visual | 1              | Table A 1-9  |
| Auxiliary Components  | 1  | Pad                              | Visual | 1              | Table A 1-9  |
|   |    | Heater                           | Visual | 0*             | NA           |
|   |    | Thermostat                       | Visual | 0*             | NA           |
|   |    | Vent                             | Visual | 0*             | NA           |
|   |    | Temp Gauge                       | Visual | 0*             | NA           |
|   |    | Alarms                           | Visual | 0*             | NA           |
|   |    | Oil Temp Gauge                   | Visual | 1              | Table A 1-9  |
|   |    | Wires                            | Visual | 0*             | NA           |
|   |    | Gas Relay                        | Visual | 1              | Table A 1-9  |
|   |    | Control Wiring                   | Visual | 1              | Table A 1-9  |
|   |    | Pressure Gauge                   | Visual | 1              | Table A 1-9  |
|   |    | Winding Temp Gauge               | Visual | 1              | Table A 1-9  |
| Service Record  | 5  | Loading                          |        | 1              | Table A 1-10 |
| <b>HI De-Rating Multiplier (DR)</b>   |    | GOQ, DGA                         |        | Equation A 1-1 |              |
| <b>Age Limiter (AL)</b>   |    | Based on 45-55 year typical life |        | Figure A 1-2   |              |
| *where there is no available data for any assets, the weight of the parameter is set to 0 |    |                                  |        |                |              |

**Oil DGA – Transformer Oil**

**Table A 1-2 DGA Criteria**

|                   | Dissolved Gas        | Scores        |                   |                    |                       |                     |                     |            |
|-------------------|----------------------|---------------|-------------------|--------------------|-----------------------|---------------------|---------------------|------------|
|                   |                      | 4             | 3.2               | 2.4                | 1.6                   | 0.8                 | 0                   |            |
| 2.5 MVA to 10 MVA | H2 (Hydrogen)        | $X \leq 70$   | $70 < X \leq 100$ | $100 < X \leq 200$ | $200 < X \leq 400$    | $400 < X \leq 1000$ | $X > 1000$          |            |
|                   | CH4 (Methane)        | $X \leq 70$   | $70 < X \leq 120$ | $120 < X \leq 200$ | $200 < X \leq 400$    | $400 < X \leq 600$  | $X > 600$           |            |
|                   | C2H6 (Ethane)        | $X \leq 75$   | $75 < X \leq 100$ | $100 < X \leq 150$ | $150 < X \leq 250$    | $250 < X \leq 500$  | $X > 500$           |            |
|                   | C2H4 (Ethylene)      | $X \leq 60$   | $60 < X \leq 100$ | $100 < X \leq 150$ | $150 < X \leq 250$    | $250 < X \leq 500$  | $X > 500$           |            |
|                   | C2H2 (Acetylene)     | $X \leq 3$    | $3 < X \leq 7$    | $7 < X \leq 35$    | $35 < X \leq 50$      | $50 < X \leq 100$   | $X > 100$           |            |
|                   | > 10 MVA             | H2 (Hydrogen) | $X \leq 40$       | $40 < X \leq 100$  | $100 < X \leq 300$    | $300 < X \leq 500$  | $500 < X \leq 1000$ | $X > 1000$ |
| CH4 (Methane)     |                      | $X \leq 80$   | $80 < X \leq 150$ | $150 < X \leq 200$ | $200 < X \leq 500$    | $500 < X \leq 700$  | $X > 700$           |            |
| C2H6 (Ethane)     |                      | $X \leq 70$   | $70 < X \leq 100$ | $100 < X \leq 150$ | $150 < X \leq 250$    | $250 < X \leq 500$  | $X > 500$           |            |
| C2H4 (Ethylene)   |                      | $X \leq 60$   | $60 < X \leq 100$ | $100 < X \leq 150$ | $150 < X \leq 250$    | $250 < X \leq 500$  | $X > 500$           |            |
| C2H2 (Acetylene)  |                      | $X \leq 3$    | $3 < X \leq 7$    | $7 < X \leq 35$    | $35 < X \leq 50$      | $50 < X \leq 80$    | $X > 80$            |            |
| CO and CO2        | Dissolved Gas        | Scores        |                   |                    |                       |                     |                     |            |
|                   |                      | 4             |                   | 2.67               |                       | 1.33                |                     | 0          |
|                   | CO (Carbon Monoxide) | $X \leq 350$  |                   | $350 < X \leq 570$ |                       | $570 < X \leq 1400$ |                     | $X > 1400$ |
|                   | $X \leq 2500$        |               | $2500 < X < 4000$ |                    | $4000 < X \leq 10000$ |                     | $X > 10000$         |            |

**General Oil Quality**

**Table A 1-3 General Oil Quality (GOQ) Test Criteria**

| Oil Quality Test                           | Voltage Class [kV] | Score          |      |         |           |         |      |
|--|--------------------|----------------|------|---------|-----------|---------|------|
|  |                    | 4              | 3    | 2       | 1         | 0       |      |
| Water Content (D1533) [ppm]                | Main Tank          | $V \leq 69$    | < 30 | 30-33.3 | 33.3-36.6 | 36.6-40 | > 40 |
|  |                    | $69 < V < 230$ | < 20 | 20-25   | 25-30     | 30-35   | > 35 |
|  |                    | $V \geq 230$   | < 15 | 15-18.3 | 18.3-21.6 | 20-25   | > 25 |
|  | Tap                | $V \leq 69$    | < 30 | 30-33.3 | 33.3-36.6 | 36.6-40 | > 40 |
|  |                    | $V > 69$       | < 20 | 20-25   | 25-30     | 30-35   | > 35 |
| Dielectric Strength (D1816 – 1mm gap) [kV] | Main Tank          | $V \leq 69$    | > 20 | 20-17.5 | 12.5-17.5 | 10-12.5 | < 10 |
|  |                    | $69 < V < 230$ | > 25 | 21-25   | 17-21     | 13-17   | < 13 |
|  |                    | $V \geq 230$   | > 27 | 23-27   | 20-23     | 17-20   | < 17 |
|  | Tap                | $V \leq 69$    | > 25 | 21.6-25 | 18.3-21.6 | 15-18.3 | < 15 |
|  |                    | $V > 69$       | > 30 | 26-30   | 22-26     | 18-22   | < 18 |
| Dielectric Strength (D877) [kV]            | Main Tank          | All            | > 40 | 33.3-40 | 22.6-33.3 | 20-22.6 | < 20 |
|  | Tap                | All            | > 25 | 21.6-25 | 18.3-21.6 | 15-18.3 | < 15 |



|  |                         |                |           |            |             |            |          |
|--|-------------------------|----------------|-----------|------------|-------------|------------|----------|
| IFT<br>(D971)<br>[dynes/cm]            | Main Tank               | $V \leq 69$    | $> 25$    | 21.6-25    | 18.3-21.6   | 15-18.3    | $< 15$   |
|  |                         | $69 < V < 230$ | $> 30$    | 26-30      | 22-26       | 18-22      | $< 18$   |
|  |                         | $V \geq 230$   | $> 32$    | 28-32      | 24-28       | 20-24      | $< 20$   |
|  | Tap                     | All            | $> 25$    | 21.6-25    | 18.3-21.6   | 15-18.3    | $< 15$   |
| Color                                  | Main Tank               | All            | $< 1.5$   | 1.5-1.8    | 1.8-2.1     | 2.1-2.5    | $> 2.5$  |
|  | Tap                     | All            | $< 2.0$   | 2.0-2.3    | 2.3-2.6     | 2.6-3.0    | $> 3.0$  |
| Acid Number<br>(D974)<br>[mg KOH/g]    | Main Tank               | $V \leq 69$    | $< 0.05$  | 0.05-0.1   | 0.1-0.15    | 0.15-0.2   | $> 0.2$  |
|  |                         | $69 < V < 230$ | $< 0.04$  | 0.04-0.077 | 0.077-0.113 | 0.113-0.15 | $> 0.15$ |
|  |                         | $V \geq 230$   | $< 0.03$  | 0.03-0.053 | 0.053-0.076 | 0.076-0.1  | $> 0.1$  |
|  | Tap                     | All            | $< 0.05$  | 0.05-0.1   | 0.1-0.15    | 0.15-0.2   | $> 0.2$  |
| Dissipation<br>Factor<br>(D924 - 25C)  | Main Tank<br>and<br>Tap | All            | $< 0.5\%$ | 0.5%-1%    | 1-1.5%      | 1.5-2%     | $> 2\%$  |
| Dissipation<br>Factor<br>(D924 - 100C) |                         | All            | $< 5\%$   | 5%-10%     | 10%-15%     | 15%-20%    | $> 20\%$ |

### Transformer Turns Ratio (TTR)

The 'turns ratio' parameter compares the TTR variation to the calculated value in all tap positions.

**Table A 1-4 TTR Criteria**

|             |   |
|-------------|---|
| <i>If</i>   | Maximum TTR variation across any tap position at any phase is greater than 0.5% |
| <i>Then</i> | <b>Score = 0</b>  |
| <i>Else</i> | <b>Score = 4</b>  |

### Winding Resistance

The 'winding resistance' parameter compares the winding resistance variation between phases in all tap positions.

**Table A 1-5 Winding Resistance Criteria**

|             |   |
|-------------|---|
| <i>If</i>   | Maximum winding resistance variation between three phases across any tap position (LV or HV) is greater than 5% |
| <i>Then</i> | <b>Score = 0</b>  |
| <i>Else</i> | <b>Score = 4</b>  |



**Degree of Polymerization**

**Table A 1-6 Degree of Polymerization Criteria**

| Score | Degree of Polymerization |
|-------|--------------------------|
| 0     | 0                        |
| 1     | $250 \leq DP < 400$      |
| 2     | $400 \leq DP < 500$      |
| 2.6   | $500 \leq DP < 600$      |
| 3.2   | $600 \leq DP < 650$      |
| 3.4   | $650 \leq DP < 700$      |
| 3.6   | $700 \leq DP < 750$      |
| 3.8   | $750 < DP < 800$         |
| 4     | $DP \geq 800$            |

Where DP =  $(\text{LOG}(2\text{FAL} * 0.88) - 4.51) / (-0.0035)$

**Power Factor Test**

**Table A 1-7 Power Factor Test Criteria**

| Score | Power Factor Reading (PF) |                         |
|-------|---------------------------|-------------------------|
|       | Fluid                     | Dry Type                |
| 4     | $PF < 0.5\%$              | $PF \leq 1.0\%$         |
| 3     | $0.5\% < PF \leq 1.0\%$   | $1.0\% < PF \leq 2.0\%$ |
| 2     | $1.0\% < PF \leq 1.5\%$   | $2.0\% < PF \leq 4.0\%$ |
| 1     | $1.5\% < PF \leq 2.0\%$   | $4.0\% < PF \leq 6.0\%$ |
| 0     | $PF > 2.0\%$              | $PF > 6.0\%$            |

Where PF is the worst-case power factor measurement.  
**Example:** If C<sub>H</sub>, C<sub>L</sub>, and C<sub>HL</sub> are available, PF = Max (C<sub>H</sub>, C<sub>L</sub>, C<sub>HL</sub>)

**Insulation Resistance**

**Table A 1-8 Insulation Resistance**

|       |      |   |
|-------|------|---|
|       | If   | (IR > kV) then <b>Score = 4</b>           |
|       | Else | <b>Score = 0</b>                          |
| Where |      |   |
|       |      | IR = measured insulation resistance in MΩ |
|       |      | kV = rated voltage in kV                  |





**Inspections Records**

**Table A 1-9 Inspection Criteria**

| Score | Condition Description   |                             |                    |        |
|-------|---|-----------------------------|--------------------|--------|
|       | 4   | Excellent working condition | No apparent issues | Good   |
| 3     | Minor wear, working as required   | Mild severity               |                    |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity             | Fair               |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe                      |                    |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe                 | Poor               | Not OK |

**Loading History**

**Table A 1-10 Loading History**

|   |
|---|
| Data: S <sub>1</sub> , S <sub>2</sub> , S <sub>3</sub> , ..., S <sub>N</sub> recorded data (monthly peaks)  |
| <p>S<sub>B</sub>= rated MVA</p> <p>N<sub>A</sub>=Number of S<sub>i</sub>/S<sub>B</sub> which is lower than 0.6</p> <p>N<sub>B</sub>= Number of S<sub>i</sub>/S<sub>B</sub> which is between 0.6 and 0.8</p> <p>N<sub>C</sub>= Number of S<sub>i</sub>/S<sub>B</sub> which is between 0.8 and 1.0</p> <p>N<sub>D</sub>= Number of S<sub>i</sub>/S<sub>B</sub> which is between 1 and 1.2</p> <p>N<sub>E</sub>= Number of S<sub>i</sub>/S<sub>B</sub> which is greater than 1.2</p> $Score = \frac{4 * N_A + 3 * N_B + 2 * N_C + 1 * N_D}{N}$ |
| Note: If there are 2 numbers in N <sub>A</sub> to N <sub>E</sub> greater than 1.5, then the Score should be multiplied by 0.6 to show the effect of overheating.  |



**De-Rating Multiplier**

The de-rating is based on the following equation and DR is described in the subsequent table.

$$DR = \min (DR_1, DR_2, DR_3)$$

**Equation A 1-1**

Where DR<sub>1</sub>, DR<sub>2</sub>, and DR<sub>3</sub> are as follows:

**Table A 1-11 De-Rating Multiplier Based on Oil Quality Score**

|  |  |
|--|--|
| $DR_1 = \min (DR_{Score_{Moisture}}, DR_{Score_{Dielectric\ Strength}})$ |  |
| <b>DR_Score</b>  | <b>Score<sub>Oil Quality Test</sub></b>                |
|  | Score <sub>Oil Quality</sub> is defined in Table A 1-3 |
| 0.25   | $0 \leq \text{Score}_{Oil\ Quality\ Test} < 1$         |
| 0.5  | $1 \leq \text{Score}_{Oil\ Quality\ Test} < 2$         |
| 1  | $\text{Score}_{Oil\ Quality\ Test} \geq 2$             |

**DR<sub>2</sub>: Dissolved Gas Trend**

DR<sub>2</sub> is based on total dissolved combustible gas (TDCG) concentration daily rate increase.

**Table A 1-12 De-Rating Multiplier Based on TDCG Trend**

|                                     |  |                               |                                |                      |
|-------------------------------------|--|-------------------------------|--------------------------------|----------------------|
| <b>Daily Increase<br/>(ppm/day)</b> | <b>IEEE C57.104 Condition Codes for TDCG</b> |                               |                                |                      |
|                                     | Condition 1                                  | Condition 2                   | Condition 3                    | Condition 4          |
|                                     | $0 \leq \text{TDCG} \leq 720$                | $720 \leq \text{TDCG} < 1920$ | $1920 \leq \text{TDCG} < 4630$ | $\text{TDCG} > 4630$ |
|                                     | <b>DR_Score</b>                              |                               |                                |                      |
| $0 \leq X < 0.33$                   | 1  | 1                             | 1                              | 1                    |
| $0.33 \leq X < 1$                   | 0.9  | 0.9                           | 0.85                           | 0.75                 |
| $1 \leq X < 1.43$                   | 0.9  | 0.9                           | 0.75                           | 0.75                 |
| $1.43 \leq X < 4.29$                | 0.9  | 0.9                           | 0.75                           | 0.5                  |
| $X \geq 4.29$                       | 0.9  | 0.9                           | 0.5                            | 0.25                 |

**DR<sub>3</sub>: CO<sub>2</sub>/CO**

DR<sub>3</sub> is based analysis of CO and CO<sub>2</sub> ratio using IEC 60599. The derating values are:

**Table A 1-13 De-Rating Multiplier CO<sub>2</sub>:CO Ratio**

|                       |   |
|-----------------------|---|
| <b>DR<sub>3</sub></b> | <b>IEC 60599 CO<sub>2</sub>:CO Assessment</b> |
| 0.75                  | Paper Fault                                   |
| 0.85                  | Mild paper overheating <160 C or oil decomp   |
| 1                     | Not Significant                               |

### Age Limiter

The Age Limiter used is equivalent to the survival function of the asset group. As described in Section 2.2, asset removal rate is assumed to increase exponentially with age. In this project the removal rate is modeled by the Weibull curve. The cumulative distribution function, introduced in Equation 5, is:

$$Q(t) = 1 - R(t) = e^{-\left(\frac{t}{\alpha}\right)^\beta}$$

where

- $Q(t)$  = likelihood of removal
- $R(t)$  = survival function
- $\alpha$  = constant that controls shape of function
- $\beta$  = constant that controls scale of function

It was assumed that the likelihood of removal at 45 years is 20% and that at 55 years the likelihood of removal is 95% (i.e.  $Q(45) = 1-0.8=0.2$ ;  $Q(55) = 1-0.5=0.95$ ). The resultant survival curve ( $1 - \text{likelihood of removals}$ ) is shown in below. This survival curve was used as the Age Limiter.



**Figure A 1-2 Substation Transformers Age Limiter**



### 1.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. The average HI for the asset group was 81.2%. Three transformers were classified as 'poor' as detailed in Table A 1-14.

From Table A 1-14 it can be seen that Port McNicoll, the first transformer on the list, was flagged because of high moisture content. Since moisture is a significant degradation mechanism for transformer insulation, further investigation is necessary so that appropriate action can be taken.

The second and third transformers, Thompson MS T1 and T2 were flagged primarily because of age as test results do not indicate any issues. However, because transformers are a critical asset that require considerable planning, units that are aging chronologically are flagged.

Although classified in the 'good' category, SCOTT had somewhat elevated carbon monoxide and carbon dioxide levels, which can be indicative of thermal degradation of cellulose. Further investigation of these units is also suggested.




Figure A 1-3 Substation Transformers Health Index Distribution



## 1.2 Flagged for Action Plan

The 10-year FFA Plan was based on HI results and the associated criticality information as described in Section 2.2.1. In this study, all units were assumed to have equal criticality. As such, the Criticality Index for each unit was set to 0% (i.e. least critical). The FFA is shown below and detailed in Table A 1-14.

Port McNicoll, Thompson M.S. T1, and Thompson M.S. T2 are all flagged for action within the next 5 years. As mentioned, Thompson MS1 and Thompson MS2 were flagged because of their chronological age. As such, deferral of action may be possible. Port McNicoll has a high moisture content; this should prompt immediate investigation (e.g. monitor, more frequent testing, etc.) and, if required, action (e.g. transformer dry-out, replacement, etc.) should be planned soon.

For transformers the 'levelized' plan advances or defers depending on health and criticality.




Figure A 1-4 Substation Transformers Flagged for Action Plan





## 1.4 Data Assessment

The data for transformers included age, nameplate information, inspection records, loading, oil quality, dissolved gas analysis, and power factor tests.

Since data was available for the overwhelming majority of transformers, the average DAI was high as shown in the table below.

| Asset Category          | Population | Average DAI |
|-------------------------|------------|-------------|
| Substation Transformers | 18         | 73%         |

Very good condition data is already being collected for transformers. As such, no condition parameter data gaps were identified.



## 2. Circuit Breakers

There are 61 Circuit Breakers at NTPDL. Of these, all 61 had sufficient data for assessment. The average age of the population is 15 years; age distribution is as follows:




Figure A 2-1 Circuit Breakers Age Distribution





## 2.1 Health Index

### 2.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

**Table A 2-1 Circuit Breakers Health Index Formula**

| Condition Parameter (CP)        |                                    | Sub-Condition Parameter (SCP)          |             |                                   |              |
|---------------------------------|------------------------------------|--|-------------|-----------------------------------|--------------|
| Description                     | Weight (WCP)                       | Description                            | Data Source | Weight (WSCP)                     | Criteria     |
| Operating Mechanism and Control | 1 <sup>1</sup><br>7 <sup>2,3</sup> | Operating Mechanism                    | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Charging System                        | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Electrical and Manual Operation        | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Mechanical Operation                   | Inspections | 1                                 | Table A 2-3  |
| Contacts                        | 3                                  | Stationary Contact                     | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Moving Contact                         | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Arcing Contact                         | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Contact Alignment                      | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Main Contact                           | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Closing timing                         | Test        | 1                                 | Table A 2-4  |
|                                 |                                    | Trip timing                            | Test        | 1                                 | Table A 2-4  |
|                                 |                                    | Contact Resistance                     | Test        | 1                                 | Table A 2-2  |
| Interrupters                    | 1                                  | Arc Chute                              | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Vacuum Interrupter                     | Inspections | 1 <sup>2</sup> , 0 <sup>1,3</sup> | Table A 2-3  |
| Insulation and Connections      | 1                                  | Phase Barrier Condition                | Inspections | 2                                 | Table A 2-3  |
|                                 |                                    | Stationary Ground Contacts             | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Moving Ground Contacts                 | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Connections                            | Inspections | 1                                 | Table A 2-3  |
| Racking                         | 1                                  | Stationary & Moving Bus Stabs          | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Ground Bus Stab                        | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Racking Mechanism                      | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Cell Alignment                         | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Interlocks                             | Inspections | 1                                 | Table A 2-3  |
| Heating and Controls            | 1                                  | Cell Space Heater/Thermostat           | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Auxiliary Trips                        | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Under Voltage Trips                    | Inspections | 1                                 | Table A 2-3  |
|                                 |                                    | Electrical & Manual Indicators         | Inspections | 1                                 | Table A 2-3  |
| <b>Derating Multiplier (DR)</b> |                                    | Based on relative number of operations |             |                                   | Table A 2-5  |
| <b>Age Limiter (AL)</b>         |                                    | Based on typical life curve            |             |                                   | Figure A 2-2 |

<sup>1</sup> Air; <sup>2</sup> Vacuum; <sup>3</sup> SF6



**Contact Resistance**

The contact resistance criteria compare the measured contact resistance to assumed limits. The worst-case contact resistance of the three phases is used as the score.

**Table A 2-2 Contact Resistance Criteria**

| Score (SCPS) | "Percent Limit" Description      |  |  |  |  |  |
|--------------|----------------------------------|--|--|--|--|--|
| 4            | Percent Limit $\leq$ 80%         |  |  |  |  |  |
| 3            | 80% < Percent Limit $\leq$ 100%  |  |  |  |  |  |
| 1            | 100% < Percent Limit $\leq$ 120% |  |  |  |  |  |
| 0            | Percent Limit > 120%             |  |  |  |  |  |

Where Percent Limit = (Contact Resistance) / (Allowable Limit)

Allowable Limit assume as:

| CB Type | Contact Resistance Limit [ $\mu\Omega$ ] |                 |                            |                  |                            |            |
|---------|--|-----------------|----------------------------|------------------|----------------------------|------------|
|         | V $\leq$ 69 kV                           | 69 < V < 110 kV | 110 $\leq$ V $\leq$ 230 kV | 230 < V < 345 kV | 345 $\leq$ V $\leq$ 765 kV | V > 765 kV |
| SF6     | 150                                      | 150             | 150                        | 150              | 150                        | 300        |
| Vacuum  | 250                                      | 250             | 250                        | 250              | 250                        | 250        |

**Inspections Records**

**Table A 2-3 Inspection Criteria**

| Score | Condition Description   |                    |      |        |
|-------|---|--------------------|------|--------|
| 4     | Excellent working condition   | No apparent issues | Good | OK     |
| 3     | Minor wear, working as required   | Mild severity      |      |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity    | Fair |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe             |      |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe        | Poor | Not OK |



**Timing Test**

The timing test criteria compare the measured time to assumed limits.

**Table A 2-4 Timing Test Criteria**

| Score (SCPS) | “Percent Limit” Description      |
|--------------|----------------------------------|
| 4            | Percent Limit $\leq$ 80%         |
| 3            | 80% < Percent Limit $\leq$ 100%  |
| 1            | 100% < Percent Limit $\leq$ 120% |
| 0            | Percent Limit > 120%             |

Where Percent Limit = (Trip or Close time) / (Allowable Limit)

Allowable Limit assume as:

| CB Type | Trip Limit [ms] |                 |                            |                  |                            |            |
|---------|-----------------|-----------------|----------------------------|------------------|----------------------------|------------|
|         | V $\leq$ 69 kV  | 69 < V < 110 kV | 110 $\leq$ V $\leq$ 230 kV | 230 < V < 345 kV | 345 $\leq$ V $\leq$ 765 kV | V > 765 kV |
| SF6     | 42              | 42              | 42                         | 42               | 25                         | 25         |
| Vacuum  | 42              | 42              | 42                         | 42               | 25                         | 25         |

| CB Type | Close Limit [ms] |                 |                            |                  |                            |            |
|---------|------------------|-----------------|----------------------------|------------------|----------------------------|------------|
|         | V $\leq$ 69 kV   | 69 < V < 110 kV | 110 $\leq$ V $\leq$ 230 kV | 230 < V < 345 kV | 345 $\leq$ V $\leq$ 765 kV | V > 765 kV |
| SF6     | 250              | 250             | 142                        | 142              | 83                         | 83         |
| Vacuum  | 250              | 250             | 142                        | 142              | 83                         | 83         |

**Derating Multiplier**

The HI of breakers that have relatively higher operation counts are de-rated to reflect greater wear. The Derating multiplier is calculated as follows:

The operating counter criteria compare the measured time to assumed limits.

**Table A 2-5 Operating Derating Criteria**

| DR   | Priority Description      |
|------|---------------------------|
| 1    | C < 10000                 |
| 0.95 | 10000 $\leq$ C < 100000   |
| 0.9  | 100000 $\leq$ C < 1000000 |
| 0.85 | C $\geq$ 1000000          |

### Age Criteria

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal at 50 years is 20% and that at 60 years the likelihood of removal is 95%. The resultant survival curve (1 – likelihood of removals) is shown in below. This survival curve was used as the Age Limiter.



**Figure A 2-2 Circuit Breakers Age Limiter**

*[The remainder of this page is intentionally blank.]*

### 2.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. All were found to be in very good condition. The average HI for the asset group was nearly 99.6%.




Figure A 2-3 Circuit Breakers Health Index Distribution

## 2.2 Flagged for Action Plan

The 10-year FFA Plan was based on HI results and the associated criticality information as described in Section 2.2.1. In this study, all units were assumed to have equal criticality. As such, the Criticality Index for each breaker was set to 0% (i.e. least critical).

No breakers were flagged for action in the next 10 years.



### 2.3 Risk Based Prioritized List

The following table shows the risk-based prioritization lists for this asset category. The results are sorted by highest to lowest Risk Index. Because the FFA Plan was developed using the risk-based approach, an FFA Year was determined for each asset.

**Table A 2-6 Circuit Breakers Risk Based Prioritized List**

| Asset Information |                |          |        |                |     | DAI  | HI Calculated                  |           |             | Final HI |             | Risk Index<br>100% = Most Risk<br>0% = Least Risk | FFA Year | De-Rating Multiplier<br>(Number of Operations) | HI Parameter Scores |                     |                |                            |                   |                      |
|-------------------|----------------|----------|--------|----------------|-----|------|--------------------------------|-----------|-------------|----------|-------------|---|----------|--|---------------------|---------------------|----------------|----------------------------|-------------------|----------------------|
| #                 | Asset ID       | Location | Type   | Year Installed | Age |      | Calculated HI (with De-rating) | Age Limit | Age Limited | HI       | HI Category |   |          |  | Operating Mechanism | Contact Performance | Arc extinction | Insulation and Connections | Racking Mechanism | Heating and Controls |
| 1                 | F30            | NT       | SF6    | 1994           | 26  | 100% | 86.0%                          | 1         | N           | 86.0%    | Very Good   | 0%  | >10      |  | 100%                | 50%                 |                | 100%                       | 100%              |                      |
| 2                 | F21            | NT       | Vacuum | 2006           | 14  | 94%  | 98.1%                          | 1         | N           | 98.1%    | Very Good   | 0%  | >10      | 1  | 100%                | 94%                 | 100%           | 100%                       | 100%              |                      |
| 3                 | F24            | NT       | Vacuum | 2006           | 14  | 94%  | 98.1%                          | 1         | N           | 98.1%    | Very Good   | 0%  | >10      | 1  | 100%                | 94%                 | 100%           | 100%                       | 100%              |                      |
| 4                 | F41            | NT       | Vacuum | 2010           | 10  | 100% | 98.6%                          | 1         | N           | 98.6%    | Very Good   | 0%  | >10      | 1  | 100%                | 96%                 |                | 100%                       | 100%              |                      |
| 5                 | F42            | NT       | Vacuum | 2010           | 10  | 100% | 98.6%                          | 1         | N           | 98.6%    | Very Good   | 0%  | >10      | 1  | 100%                | 96%                 |                | 100%                       | 100%              |                      |
| 6                 | F3             | NT       | SF6    | 1991           | 29  | 100% | 98.8%                          | 1         | N           | 98.8%    | Very Good   | 0%  | >10      | 1  | 100%                | 95%                 | 100%           | 100%                       |                   |                      |
| 7                 | F4             | NT       | SF6    | 1991           | 29  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       |                   |                      |
| 8                 | F5             | NT       | SF6    | 1991           | 29  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 9                 | F10            | NT       | SF6    | 1994           | 26  | 74%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           |                            | 100%              | 100%                 |
| 10                | F11            | NT       | SF6    | 1994           | 26  | 74%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           |                            | 100%              | 100%                 |
| 11                | F12            | NT       | SF6    | 1994           | 26  | 74%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           |                            | 100%              | 100%                 |
| 12                | F14            | NT       | SF6    | 1994           | 26  | 74%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           |                            | 100%              | 100%                 |
| 13                | F33            | NT       | SF6    | 1994           | 26  | 92%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 14                | F32            | NT       | SF6    | 1994           | 26  | 91%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                | 100%                |                | 100%                       | 100%              |                      |
| 15                | F31            | NT       | SF6    | 1994           | 26  | 72%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     |                | 100%                       | 100%              |                      |
| 16                | F70            | NT       | SF6    | 1996           | 24  | 72%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     |                | 100%                       | 100%              |                      |
| 17                | F72            | NT       | SF6    | 1996           | 24  | 72%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     |                | 100%                       | 100%              |                      |
| 18                | F73            | NT       | SF6    | 1996           | 24  | 72%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     |                | 100%                       | 100%              |                      |
| 19                | F71            | NT       | SF6    | 1996           | 24  | 72%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     |                | 100%                       | 100%              |                      |
| 20                | F50            | NT       | Vacuum | 1999           | 21  | 88%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 21                | F52            | NT       | Vacuum | 1999           | 21  | 70%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 22                | F23            | NT       | Vacuum | 2006           | 14  | 94%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 23                | F25            | NT       | Vacuum | 2006           | 14  | 94%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 24                | F28            | NT       | Vacuum | 2006           | 14  | 88%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 25                | F26            | NT       | Vacuum | 2006           | 14  | 88%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 26                | F63            | NT       | Vacuum | 2007           | 13  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 27                | F62            | NT       | Vacuum | 2007           | 13  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 28                | F61            | NT       | Vacuum | 2007           | 13  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              |                      |
| 29                | SCOTT ST DS S1 | MID      | Vacuum | 2007           | 13  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 30                | SCOTT ST DS S1 | MID      | Vacuum | 2007           | 13  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 31                | SCOTT ST DS S2 | MID      | Vacuum | 2007           | 13  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 32                | SCOTT ST DS S3 | MID      | Vacuum | 2007           | 13  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 33                | SCOTT ST DS S4 | MID      | Vacuum | 2007           | 13  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 34                | F51            | NT       | Vacuum | 2008           | 12  | 70%  | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                |                     | 100%           | 100%                       | 100%              |                      |



| Asset Information |                     |          |        |                |     | DAI  | HI Calculated                  |           |             | Final HI |             | Risk Index<br>100% = Most Risk<br>0% = Least Risk | FFA Year | De-Rating Multiplier<br>(Number of Operations) | HI Parameter Scores |                     |                |                            |                   |                      |
|-------------------|---------------------|----------|--------|----------------|-----|------|--------------------------------|-----------|-------------|----------|-------------|---|----------|--|---------------------|---------------------|----------------|----------------------------|-------------------|----------------------|
| #                 | Asset ID            | Location | Type   | Year Installed | Age |      | Calculated HI (with De-rating) | Age Limit | Age Limited | HI       | HI Category |   |          |  | Operating Mechanism | Contact Performance | Arc extinction | Insulation and Connections | Racking Mechanism | Heating and Controls |
| 35                | F1                  | NT       | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       |                   |                      |
| 36                | F2                  | NT       | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       |                   |                      |
| 37                | BRANDON DS MAIN     | MID      | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                |                | 100%                       | 100%              |                      |
| 38                | BRANDON DS B1       | MID      | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                |                | 100%                       | 100%              |                      |
| 39                | BRANDON DS B2       | MID      | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                |                | 100%                       | 100%              |                      |
| 40                | BRANDON DS B3       | MID      | Vacuum | 2008           | 12  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                |                | 100%                       | 100%              |                      |
| 41                | DORION DS MAIN      | MID      | Vacuum | 2010           | 10  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 42                | DROION DS D1        | MID      | Vacuum | 2010           | 10  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 43                | DROION DS D2        | MID      | Vacuum | 2010           | 10  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 44                | DROION DS D3        | MID      | Vacuum | 2010           | 10  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 45                | DROION DS D4        | MID      | Vacuum | 2010           | 10  | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 46                | FOURTH ST DS MAIN   | MID      | Vacuum | 2010           | 10  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 47                | FOURTH ST DS F1     | MID      | Vacuum | 2010           | 10  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 48                | FOURTH ST DS F2     | MID      | Vacuum | 2010           | 10  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 49                | FOURTH ST DS F3     | MID      | Vacuum | 2010           | 10  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 50                | FOURTH ST DS F4     | MID      | Vacuum | 2010           | 10  | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  | 100%                |                     | 100%           | 100%                       | 100%              |                      |
| 51                | MONTREAL ST DS MAIN | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 52                | MONTREAL ST DS M1   | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 53                | MONTREAL ST DS M2   | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 54                | MONTREAL ST DS M3   | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 55                | MONTREAL ST DS M4   | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 56                | MONTREAL ST DS M5   | MID      | Vacuum | 2012           | 8   | 100% | 100.0%                         | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      | 1  | 100%                | 100%                | 100%           | 100%                       | 100%              | 100%                 |
| 57                | QUEEN ST DS MAIN    | MID      | Air    | 2013           | 7   | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 58                | QUEEN ST DS Q1      | MID      | Air    | 2013           | 7   | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 59                | QUEEN ST DS Q2      | MID      | Air    | 2013           | 7   | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 60                | QUEEN ST DS Q3      | MID      | Air    | 2013           | 7   | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |
| 61                | QUEEN ST DS Q4      | MID      | Air    | 2013           | 7   | 0%   |                                | 1         | Y           | 100.0%   | Very Good   | 0%  | >10      |  |                     |                     |                |                            |                   |                      |



## 2.4 Data Assessment

The data for breakers included timing tests, contact resistance tests, operations counts, and inspection records.

Since data was available for the most of breakers, the average DAI was fairly high as shown in the table below. The DAI can be improved by consistently collecting timing tests information and contact resistance for all breakers in all three regions (Newmarket, Tay, and Midland).

| <b>Asset Category</b>   | <b>Population</b> | <b>Average DAI</b> |
|-------------------------|-------------------|--------------------|
| <b>Circuit Breakers</b> | 61                | 67%                |

Very good condition data is already being collected for breakers. As such, no condition parameter data gaps were identified. However, data quality can be improved through consistent recording of as-found and as-left timing test data. Evaluation of timing, contact resistance, and operations count parameters can be improved by collecting asset-specific manufacturer or baseline values so that current readings can be compared to these baseline values.

*[The remainder of this page is intentionally blank.]*





### 3. Pole Mounted Transformers

There are 1797 Pole Mounted Transformers at NTPDL. Of these, 1318 had sufficient data for assessment. The average age of the population is 29 years; age distribution is as follows:




Figure A 3-1 Pole Mounted Transformers Age Distribution



### 3.1 Health Index

#### 3.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

**Table A 3-1 Pole Mounted Transformers Health Index Formula**

| Condition Parameter (CP)  |              | Sub-Condition Parameter (SCP)             |              |               |                |
|---|--------------|---|--------------|---------------|----------------|
| Description   | Weight (WCP) | Description                               | Data Source  | Weight (WSCP) | Criteria       |
| Main Tank   | 1            | Corrosion                                 | Inspections  | 3             | Table A 3-2    |
|   |              | Oil Leak                                  | Inspections  | 5             | Table A 3-2    |
| Primary Termination   | 0*           | Termination Condition                     | Inspections  | 0*            | NA             |
| Secondary Termination   | 0*           | Termination Condition                     | Inspections  | 0*            | NA             |
| Service Record  | 0*           | Loading                                   | Loading Data | 0*            | NA             |
| <b>Derating Multiplier (DR)</b>   |              | Based on PCB, Overall Hazard, and IR Scan |              |               | Equation A 3-1 |
| <b>Age Limiter (AL)</b>   |              | Based on typical life curve               |              |               | Figure A 3-2   |
| *where there is no available data for any assets, the weight of the parameter is set to 0 |              |   |              |               |                |
| NA = not applicable   |              |   |              |               |                |

### Inspections Records

**Table A 3-2 Inspection Criteria**

| Score | Condition Description   |                    |      |        |
|-------|---|--------------------|------|--------|
| 4     | Excellent working condition   | No apparent issues | Good | OK     |
| 3     | Minor wear, working as required   | Mild severity      |      |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity    | Fair |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe             |      |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe        | Poor | Not OK |



**De-Rating Multiplier**

The de-rating is based on the following equation and DR is described in the subsequent table.

$$DR = \min (DR_1, DR_2, DR_3)$$

**Equation A 3-1**

Where DR<sub>1</sub>, DR<sub>2</sub>, and DR<sub>3</sub> are as follows:

DR<sub>1</sub>: IR Scan

**Table A 3-3 De-Rating Multiplier IR Scan**

| De-Rating Multiplier | Description  |
|----------------------|--|
| 0.9                  | Possible deficiency; warrants investigation.           |
| 0.8                  | Indicates probable deficiency; repair as time permits. |
| 0.7                  | Monitor until corrective measures can be accomplished. |
| 0.5                  | Major discrepancy; repair immediately.                 |

DR<sub>2</sub>: Overall Hazard Assessment

**Table A 3-4 De-Rating Multiplier Overall Hazard**

| De-Rating Multiplier | Description |
|----------------------|-------------|
| 1                    | Good        |
| 0.5                  | Average     |
| 0                    | Poor        |

DR<sub>3</sub>: PCB Content

**Table A 3-5 De-Rating Multiplier PCB Content**

| De-Rating Multiplier | PCB Content (PPM) |
|----------------------|-------------------|
| 1                    | 0-50              |
| 0.25                 | > 50              |

### Age Limiter

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal at 40 years is 20% and that at 60 years the likelihood of removal is 95%. The resultant survival curve (1 – likelihood of removals) is shown in below. This survival curve was used as the Age Limiter.




Figure A 3-2 Pole Mounted Transformers Age Limiter

*[The remainder of this page is intentionally blank.]*



### 3.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. Approximately 19% of the sample size was found to be in poor/very poor condition. The average HI for the asset group was 76.2%.




Figure A 3-3 Pole Mounted Transformers Health Index Distribution

### 3.2 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from 'sample size' (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a 'levelized' plan for better pacing of investments is also provided.




Figure A 3-4 Pole Mounted Transformers Flagged for Action Plan



### 3.3 Health Index Based Prioritized List

The following table shows the “worst” 100 assets. The results are sorted by lowest to highest HI.

**Table A 3-6 Pole Mounted Transformers Risk Based Prioritized List**

| Asset Information |          |        |                                 |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                           |                             |                |
|-------------------|----------|--------|---------------------------------|-----|--------------------|----------|-------------|---|---------------------------|-----------------------------|----------------|
| #                 | Asset ID | Region | Year Installed/<br>Manufactured | Age |                    | HI       | HI Category | Main Tank   | Primary Cable Termination | Secondary Cable Termination | Service Record |
| 1                 | 0928     | MID    | 1996                            | 24  | 100%               | 0.0%     | Very Poor   | 38%   | NA                        | NA                          | NA             |
| 2                 | 0683     | MID    | 1966                            | 54  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 3                 | 0791     | MID    | 2008                            | 12  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 4                 | 2001     | MID    | 1970                            | 50  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 5                 | 0031     | MID    | 1973                            | 47  | 100%               | 0.0%     | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 6                 | 2272B    | MID    | 1989                            | 31  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 7                 | 2272R    | MID    | 1989                            | 31  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 8                 | 2272W    | MID    | 1969                            | 51  | 100%               | 0.0%     | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 9                 | 1100     | MID    | 1952                            | 68  | 0%                 | 0.1%     | Very Poor   |   | NA                        | NA                          | NA             |
| 10                | 1037     | NT     | 1962                            | 58  | 0%                 | 8.8%     | Very Poor   |   | NA                        | NA                          | NA             |
| 11                | 1416W    | MID    | 1963                            | 57  | 100%               | 11.4%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 12                | 1416B    | MID    | 1963                            | 57  | 100%               | 11.4%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 13                | 1416R    | MID    | 1963                            | 57  | 100%               | 11.4%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 14                | 0585     | MID    | 1963                            | 57  | 100%               | 11.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 15                | 0012B    | MID    | 1963                            | 57  | 100%               | 11.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 16                | 1113     | MID    | 1964                            | 56  | 0%                 | 14.4%    | Very Poor   |   | NA                        | NA                          | NA             |
| 17                | 0912     | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 18                | 1086     | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 19                | 0656     | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 20                | 1560     | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 21                | 1599     | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 22                | 0530R    | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 23                | 0530W    | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 24                | 0530B    | MID    | 1964                            | 56  | 100%               | 14.4%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 25                | 2438     | MID    | 1979                            | 41  | 100%               | 15.6%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 26                | 1052R    | MID    | 1970                            | 50  | 100%               | 15.6%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 27                | 1257     | NT     | 1965                            | 55  | 0%                 | 17.8%    | Very Poor   |   | NA                        | NA                          | NA             |
| 28                | 1419     | MID    | 1974                            | 46  | 100%               | 18.8%    | Very Poor   | 38%   | NA                        | NA                          | NA             |
| 29                | 2148     | NT     | 1966                            | 54  | 0%                 | 21.5%    | Very Poor   |   | NA                        | NA                          | NA             |
| 30                | 0584R    | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 31                | 0584W    | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 32                | 0584B    | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 63%   | NA                        | NA                          | NA             |
| 33                | 1081     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |



| Asset Information |          |        |                                 |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                           |                             |                |
|-------------------|----------|--------|---------------------------------|-----|--------------------|----------|-------------|---|---------------------------|-----------------------------|----------------|
| #                 | Asset ID | Region | Year Installed/<br>Manufactured | Age |                    | HI       | HI Category | Main Tank   | Primary Cable Termination | Secondary Cable Termination | Service Record |
| 34                | 0776     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 35                | 1210     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 36                | 1418     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 37                | 7201     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 38                | 3275     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 39                | 1454     | MID    | 1966                            | 54  | 100%               | 21.5%    | Very Poor   | 100%  | NA                        | NA                          | NA             |
| 40                | 7202     | MID    | 1974                            | 46  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 41                | 3724     | MID    | 1989                            | 31  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 42                | 5321     | MID    | 1979                            | 41  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 43                | 4604     | MID    | 1989                            | 31  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 44                | 0405     | MID    | 1998                            | 22  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 45                | 3517     | MID    | 1974                            | 46  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 46                | 0193B    | MID    | 1975                            | 45  | 100%               | 25.0%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 47                | 0003     | MID    | 1967                            | 53  | 0%                 | 25.6%    | Poor        |   | NA                        | NA                          | NA             |
| 48                | 0900     | MID    | 1967                            | 53  | 0%                 | 25.6%    | Poor        |   | NA                        | NA                          | NA             |
| 49                | 0948     | MID    | 1967                            | 53  | 0%                 | 25.6%    | Poor        |   | NA                        | NA                          | NA             |
| 50                | 0023     | MID    | 1967                            | 53  | 0%                 | 25.6%    | Poor        |   | NA                        | NA                          | NA             |
| 51                | 1060     | MID    | 1967                            | 53  | 0%                 | 25.6%    | Poor        |   | NA                        | NA                          | NA             |
| 52                | 0949     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 53                | 3898     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 54                | 0966     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 55                | 0183     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 56                | 0665     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 57                | 0297     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 58                | 0985     | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 59                | 1080R    | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 60                | 1080W    | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 61                | 1080B    | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 62                | 0463W    | MID    | 1967                            | 53  | 100%               | 25.6%    | Poor        | 100%  | NA                        | NA                          | NA             |
| 63                | 1244     | NT     | 1968                            | 52  | 0%                 | 29.9%    | Poor        |   | NA                        | NA                          | NA             |
| 64                | 1694     | NT     | 1968                            | 52  | 0%                 | 29.9%    | Poor        |   | NA                        | NA                          | NA             |
| 65                | 242      | NT     | 1968                            | 52  | 0%                 | 29.9%    | Poor        |   | NA                        | NA                          | NA             |
| 66                | 614      | NT     | 1968                            | 52  | 0%                 | 29.9%    | Poor        |   | NA                        | NA                          | NA             |
| 67                | 0910     | MID    | 1996                            | 24  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 68                | 0891     | MID    | 1990                            | 30  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 69                | 0950     | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 70                | 0578     | MID    | 1974                            | 46  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 71                | 0577     | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |
| 72                | 0945     | MID    | 1970                            | 50  | 100%               | 31.3%    | Poor        | 63%   | NA                        | NA                          | NA             |





| Asset Information |          |        |                                 |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                              |                                |                |
|-------------------|----------|--------|---------------------------------|-----|--------------------|----------|-------------|---|------------------------------|--------------------------------|----------------|
| #                 | Asset ID | Region | Year Installed/<br>Manufactured | Age |                    | HI       | HI Category | Main Tank   | Primary Cable<br>Termination | Secondary Cable<br>Termination | Service Record |
| 73                | 0720     | MID    | 1970                            | 50  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 74                | 0719     | MID    | 1998                            | 22  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 75                | 0252     | MID    | 1998                            | 22  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 76                | 0288     | MID    | 1970                            | 50  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 77                | 0385     | MID    | 1996                            | 24  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 78                | 0122     | MID    | 1998                            | 22  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 79                | 0173     | MID    | 2008                            | 12  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 80                | 0170W    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 81                | 0170B    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 82                | 0170R    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 83                | 1039     | MID    | 1995                            | 25  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 84                | 2779     | MID    | 1976                            | 44  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 85                | 1650     | MID    | 2007                            | 13  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 86                | 0890     | MID    | 1998                            | 22  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 87                | 0572     | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 88                | 0567R    | MID    | 1989                            | 31  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 89                | 0567W    | MID    | 1969                            | 51  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 90                | 0567B    | MID    | 1969                            | 51  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 91                | 2395W    | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 92                | 2395B    | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 93                | 2395R    | MID    | 1987                            | 33  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 94                | 0194W    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 95                | 0194B    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 96                | 0194R    | MID    | 2011                            | 9   | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 97                | 0773W    | MID    | 1976                            | 44  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 98                | 0773B    | MID    | 1976                            | 44  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 99                | 0773R    | MID    | 1976                            | 44  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |
| 100               | 0020W    | MID    | 1974                            | 46  | 100%               | 31.3%    | Poor        | 63%   | NA                           | NA                             | NA             |



### 3.4 Data Assessment

The only available data for pole mounted transformers was age and inspections. However, inspections were only available for units in Midland. Problematic infrared scan, overall condition inspection assessment, and PCB content were used as a de-rating multiple.

Since inspections was available for Midland, the average DAI 33%.

| Asset Category            | Population | Average DAI |
|---------------------------|------------|-------------|
| Pole Mounted Transformers | 1797       | 33%         |

**Table A 3-7 Pole Mounted Transformers Data Gaps**

| Data Gap    | Priority | Description     | Source                      |
|-------------|----------|-----------------|-----------------------------|
| Connections | H        | Terminations    | Visual inspection, IR scans |
| Loading     | H        | Loading history | Operations records          |



#### 4. Pad Mounted Transformers

There are 4428 Pad Mounted Transformers at NTPDL. Of these, 4187 had sufficient data for assessment. The average age of the population is 23 years; age distribution is as follows:




Figure A 4-1 Pad Mounted Transformers Age Distribution



## 4.1 Health Index

### 4.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

**Table A 4-1 Pad Mounted Transformers Health Index Formula**

| Condition Parameter (CP)  |              | Sub-Condition Parameter (SCP)             |              |               |                |
|---|--------------|---|--------------|---------------|----------------|
| Description   | Weight (WCP) | Description                               | Data Source  | Weight (WSCP) | Criteria       |
| Main Tank   | 5            | Corrosion                                 | Inspections  | 3             | Table A 4-2    |
|   |              | Oil leak                                  | Inspections  | 5             | Table A 4-2    |
|   |              | Paint                                     | Inspections  | 3             | Table A 4-2    |
|   |              | Skirt                                     | Inspections  | 1             | Table A 4-2    |
| Door Mechanism  | 1            | Locks                                     | Inspections  | 1             | Table A 4-2    |
|   |              | Handles                                   | Inspections  | 0*            | NA             |
|   |              | Hinges                                    | Inspections  | 1             | Table A 4-2    |
|   |              | Latches                                   | Inspections  | 0*            | NA             |
| Insulation  | 3            | Barriers                                  | Inspections  | 1             | NA             |
|   |              | Insulators                                | Inspections  | 1             | NA             |
| Primary Termination   | 0*           | Termination Condition                     | Inspections  | 0*            | NA             |
| Secondary Termination   | 0*           | Termination Condition                     | Inspections  | 0*            | NA             |
| Base and Surroundings   | 2            | Base / Foundation                         | Inspections  | 1             | Table A 4-2    |
|   |              | Grade Change                              | Inspections  | 0*            | Table A 4-2    |
|   |              | Placement                                 | Inspections  | 0*            | Table A 4-2    |
|   |              | Grounding                                 | Inspections  | 0*            | Table A 4-2    |
|   |              | Access                                    | Inspections  | 0*            | Table A 4-2    |
| Service Record  | 0*           | Loading                                   | Loading Data | 0*            | NA             |
| <b>Derating Multiplier (DR)</b>   |              | Based on PCB, Overall Hazard, and IR Scan |              |               | Equation A 4-1 |
| <b>Age Limiter (AL)</b>   |              | Based on typical life curve               |              |               | Figure A 4-2   |
| *where there is no available data for any assets, the weight of the parameter is set to 0 |              |   |              |               |                |
| NA = not applicable   |              |   |              |               |                |



**Inspections Records**

**Table A 4-2 Inspection Criteria**

| Score | Condition Description   |                    |      |        |
|-------|---|--------------------|------|--------|
| 4     | Excellent working condition   | No apparent issues | Good | OK     |
| 3     | Minor wear, working as required   | Mild severity      |      |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity    | Fair |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe             |      |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe        | Poor | Not OK |

**De-Rating Multiplier**

The de-rating is based on the following equation and DR is described in the subsequent table.

$$DR = \min (DR_1, DR_2, DR_3)$$

**Equation A 4-1**

Where DR<sub>1</sub>, DR<sub>2</sub>, and DR<sub>3</sub> are as follows:

**DR<sub>1</sub>: IR Scan**

**Table A 4-3 De-Rating Multiplier IR Scan**

| De-Rating Multiplier | Description  |
|----------------------|--|
| 0.9                  | Possible deficiency; warrants investigation.           |
| 0.8                  | Indicates probable deficiency; repair as time permits. |
| 0.7                  | Monitor until corrective measures can be accomplished. |
| 0.5                  | Major discrepancy; repair immediately.                 |

DR<sub>2</sub>: Overall Hazard Assessment

**Table A 4-4 De-Rating Multiplier Overall Hazard**

| De-Rating Multiplier | Description |
|----------------------|-------------|
| 1                    | Good        |
| 0.5                  | Average     |
| 0                    | Poor        |


DR<sub>3</sub>: PCB Content

**Table A 4-5 De-Rating Multiplier PCB Content**

| De-Rating Multiplier | PCB Content (PPM) |
|----------------------|-------------------|
| 1                    | 0-50              |
| 0.25                 | > 50              |

**Age Limiter**

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal at 40 years is 20% and that at 50 years the likelihood of removal is 95%. The resultant survival curve (1 – likelihood of removals) is shown in below. This survival curve was used as the Age Limiter.



**Figure A 4-2 Pad Mounted Transformers Age Limiter**



### 4.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. Nearly 11% of the sample size was found to be in poor/very poor condition. The average HI for the asset group was 85.9%.




Figure A 4-3 Pad Mounted Transformers Health Index Distribution



## 4.2 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from 'sample size' (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a 'levelized' plan for better pacing of investments is also provided.




Figure A 4-4 Pad Mounted Transformers Flagged for Action Plan





### 4.3 Health Index Based Prioritized List

The following table shows the “worst” 100 assets. The results are sorted by lowest to highest HI.

**Table A 4-6 Pad Mounted Transformers Risk Based Prioritized List**

| Asset Information |          |          |                      |     | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                |            |                           |                |             |                |
|-------------------|----------|----------|----------------------|-----|----------|-------------|---|----------------|------------|---------------------------|----------------|-------------|----------------|
| #                 | Asset ID | Location | Install / Manuf Date | Age | HI       | HI Category | Main Tank   | Door Mechanism | Insulation | Primary Cable Termination | Service Record | Environment | Service Record |
| 1                 | 1016B    | MID      | 1973                 | 47  | 0.0%     | Very Poor   | 0%  | 0%             | NA         | NA                        | NA             | NA          | NA             |
| 2                 | 0811W    | MID      | 1986                 | 34  | 0.0%     | Very Poor   | 0%  | 0%             | NA         | NA                        | NA             | NA          | NA             |
| 3                 | 0947W    | MID      | 1990                 | 30  | 0.0%     | Very Poor   | 0%  | 100%           | NA         | NA                        | NA             | NA          | NA             |
| 4                 | 0904R    | MID      | 1990                 | 30  | 0.0%     | Very Poor   | 0%  | 100%           | NA         | NA                        | NA             | NA          | NA             |
| 5                 | 2517     | NT       | 1997                 | 23  | 0.0%     | Very Poor   | 0%  | 0%             | NA         | NA                        | NA             | NA          | NA             |
| 6                 | 1021W    | MID      | 1997                 | 23  | 0.0%     | Very Poor   | 0%  | 100%           | NA         | NA                        | NA             | NA          | NA             |
| 7                 | 0172B    | MID      | 1987                 | 33  | 0.0%     | Very Poor   | 39%   | 100%           | NA         | NA                        | NA             | NA          | NA             |
| 8                 | 0082     | MID      | 1990                 | 30  | 0.0%     | Very Poor   | 39%   |                | NA         | NA                        | NA             | NA          | NA             |
| 9                 | 0928     | MID      | 1996                 | 24  | 0.0%     | Very Poor   | 39%   |                | NA         | NA                        | NA             | NA          | NA             |
| 10                | 0683     | MID      | 1966                 | 54  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 11                | 2272W    | MID      | 1969                 | 51  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 12                | 2001     | MID      | 1970                 | 50  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 13                | 1025W    | MID      | 1973                 | 47  | 0.0%     | Very Poor   | 61%   | 0%             | NA         | NA                        | NA             | NA          | NA             |
| 14                | 2272B    | MID      | 1989                 | 31  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 15                | 2272R    | MID      | 1989                 | 31  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 16                | 0791     | MID      | 2008                 | 12  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 17                | 0031     | MID      | 1973                 | 47  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 18                | 1100     | MID      | 1952                 | 68  | 0.0%     | Very Poor   |   |                | NA         | NA                        | NA             | NA          | NA             |
| 19                | 1416W    | MID      | 1963                 | 57  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 20                | 1416B    | MID      | 1963                 | 57  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 21                | 1416R    | MID      | 1963                 | 57  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 22                | 0585     | MID      | 1963                 | 57  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 23                | 0012B    | MID      | 1963                 | 57  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 24                | 0912     | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |
| 25                | 1560     | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 26                | 1599     | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 27                | 0656     | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 28                | 1086     | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 29                | 0530R    | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 30                | 0530W    | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 31                | 0530B    | MID      | 1964                 | 56  | 0.0%     | Very Poor   | 100%  |                | NA         | NA                        | NA             | NA          | NA             |
| 32                | 1113     | MID      | 1964                 | 56  | 0.0%     | Very Poor   |   |                | NA         | NA                        | NA             | NA          | NA             |
| 33                | 0584R    | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 61%   |                | NA         | NA                        | NA             | NA          | NA             |



| Asset Information |          |          |                      |     | Final HI |             | HI Parameters  |                |            |                           |                |             |                |
|-------------------|----------|----------|----------------------|-----|----------|-------------|--|----------------|------------|---------------------------|----------------|-------------|----------------|
| #                 | Asset ID | Location | Install / Manuf Date | Age | HI       | HI Category | Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                |            |                           |                |             |                |
|                   |          |          |                      |     |          |             | Main Tank  | Door Mechanism | Insulation | Primary Cable Termination | Service Record | Environment | Service Record |
| 34                | 0584W    | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 35                | 0584B    | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 36                | 3275     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 37                | 7201     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 38                | 1081     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 39                | 0776     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 40                | 1210     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 41                | 1454     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 42                | 1418     | MID      | 1966                 | 54  | 0.1%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 43                | 3898     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 44                | 0297     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 45                | 0985     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 46                | 1080R    | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 47                | 0183     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 48                | 0665     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 49                | 0463W    | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 50                | 0949     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 51                | 0966     | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 52                | 1080W    | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 53                | 1080B    | MID      | 1967                 | 53  | 0.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 54                | 0023     | MID      | 1967                 | 53  | 0.3%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 55                | 0900     | MID      | 1967                 | 53  | 0.3%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 56                | 0948     | MID      | 1967                 | 53  | 0.3%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 57                | 0003     | MID      | 1967                 | 53  | 0.3%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 58                | 1060     | MID      | 1967                 | 53  | 0.3%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 59                | 0582R    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 60                | 0567W    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 61                | 0567B    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 62                | 0126B    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 63                | 0427B    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 64                | 0742     | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 65                | 1051     | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 66                | 5539     | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 67                | 1003     | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 68                | 0126R    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 69                | 0622B    | MID      | 1969                 | 51  | 2.3%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 70                | 0288     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 71                | 0720     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 72                | 0945     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |



| Asset Information |          |          |                      |     | Final HI |             | HI Parameters  |                |            |                           |                |             |                |
|-------------------|----------|----------|----------------------|-----|----------|-------------|--|----------------|------------|---------------------------|----------------|-------------|----------------|
| #                 | Asset ID | Location | Install / Manuf Date | Age | HI       | HI Category | Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |                |            |                           |                |             |                |
|                   |          |          |                      |     |          |             | Main Tank  | Door Mechanism | Insulation | Primary Cable Termination | Service Record | Environment | Service Record |
| 73                | 1052R    | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 74                | 1052W    | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 75                | 1052B    | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 61%  |                | NA         | NA                        | NA             | NA          | NA             |
| 76                | 106      | NT       | 1970                 | 50  | 5.0%     | Very Poor   | 88%  | 100%           | NA         | NA                        | NA             | NA          | NA             |
| 77                | 0237     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 78                | 0301     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 79                | 0700     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 80                | 0019     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 81                | 0126W    | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 82                | 1124     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 83                | 0812     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 84                | 0667     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 85                | 0673     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 86                | 0638     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 87                | 0694     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 88                | 0954     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 89                | 0220     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 90                | 1027     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 91                | 0348     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 92                | 3838     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 93                | 1068R    | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 94                | 0712     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 95                | 0929     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 96                | 0940     | MID      | 1970                 | 50  | 5.0%     | Very Poor   | 100%   |                | NA         | NA                        | NA             | NA          | NA             |
| 97                | 120      | NT       | 1970                 | 50  | 5.0%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 98                | 121      | NT       | 1970                 | 50  | 5.0%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 99                | 0380     | MID      | 1970                 | 50  | 5.0%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |
| 100               | 0029     | MID      | 1970                 | 50  | 5.0%     | Very Poor   |  |                | NA         | NA                        | NA             | NA          | NA             |



#### 4.4 Data Assessment

Age and inspection records were available for pad mounted transformers. Many transformers had some inspection and/or age, so the DAI was 56%. The important data gaps are information about connections and insulation and loading. It is recommended that inspections be conducted and collected for all units to increase the DAI.

| Asset Category           | Population | Average DAI |
|--------------------------|------------|-------------|
| Pad Mounted Transformers | 4428       | 56%         |

The data gaps for this asset category are as follows:

**Table A 4-7 Pad Mounted Transformers Data Gaps**

| Data Gap              | Priority | Description  | Source                       |
|-----------------------|----------|--|------------------------------|
| Door Mechanism        | L        | Handles, latches   | Visual inspection            |
| Insulation            | H        | Insulators, barrier boards   | Visual Inspections           |
| Connections           | H        | Terminations, elbows, inserts  | Visual inspections, IR scans |
| Base and Surroundings | L        | Grade change, poor placement, poor access, poor grounding connection | Visual inspection            |
| Loading               | H        | Loading history  | Operations records           |



## 5. Pad Mounted Switchgear

There are 133 Pad Mounted Switchgear at NTPDL. Of these, 130 had sufficient data for assessment. The average age of the population is 19 years; age distribution is as follows:




Figure A 5-1 Pad Mounted Switchgear Age Distribution



## 5.1 Health Index

### 5.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

**Table A 5-1 Pad Mounted Switchgear Health Index Formula**

| Condition Parameter (CP)  |              | Sub-Condition Parameter (SCP) |             |               |              |
|---|--------------|-------------------------------|-------------|---------------|--------------|
| Description   | Weight (WCP) | Description                   | Data Source | Weight (WSCP) | Table        |
| Enclosure   | 3            | Corrosion (Enclosure)         | Inspections | 1             | Table A 5-2  |
|   |              | Door                          | Inspections | 0*            | NA           |
|   |              | Paint                         | Inspections | 0*            | NA           |
| Inside  | 5            | Inside                        | Inspections | 1             | Table A 5-2  |
| Switch / Fuse   | 0*           | Switch                        | Inspections | 0*            | NA           |
|   |              | Fuse                          | Inspections | 0*            | NA           |
| Insulation  | 0*           | Insulator                     | Inspections | 0*            | NA           |
|   |              | Barriers Boards               | Inspections | 0*            | NA           |
| Connections   | 0*           | Termination Condition         | Inspections | 0*            | NA           |
| Base and Surroundings   | 2            | Base / Foundation             | Inspections | 1             | Table A 5-2  |
|   |              | Grade Change                  | Inspections | 0*            | NA           |
|   |              | Placement                     | Inspections | 0*            | NA           |
|   |              | Grounding                     | Inspections | 0*            | NA           |
|   |              | Access                        | Inspections | 0*            | NA           |
| <b>HI De-Rating Multiplier (DR)</b>   |              | Hazard Assessment             |             |               | Table A 5-1  |
| <b>Age Limiter (AL)</b>   |              | Based on typical life curve   |             |               | Figure A 4-2 |
| *where there is no available data for any assets, the weight of the parameter is set to 0 |              |                               |             |               |              |


**Inspections Records**

**Table A 5-2 Inspection Criteria**

| Score | Condition Description   |                             |                    |        |
|-------|---|-----------------------------|--------------------|--------|
|       | 4   | Excellent working condition | No apparent issues | Good   |
| 3     | Minor wear, working as required   | Mild severity               |                    |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity             | Fair               |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe                      |                    |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe                 | Poor               | Not OK |

**Age Limiter**

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal at 30 years is 20% and that at 45 years the likelihood of removal is 95% (i.e.  $Q(40) = 1 - 0.8 = 0.2$ ;  $Q(60) = 1 - 0.5 = 0.5$ ). The resultant survival curve (1 – likelihood of removals) is shown below. This survival curve was used as the Age Limiter.



**Figure A 5-2 Pad Mounted Switchgear Age Limiter**



**De-Rating Multiplier**


The de-rating is based on NTPDL Overall hazard assessment scan results:

**Table A 5-3 Pad Mounted Switchgear De-Rating Multiplier Criteria**

| De-Rating Multiplier | Overall Hazard Score |
|----------------------|----------------------|
| 1                    | 0                    |
| 0.9                  | 1                    |
| 0.75                 | 2                    |
| 0.5                  | 3                    |
| 0.25                 | 4                    |

**5.1.2 Health Index Results**

The HI Distribution, in terms of number of units and percentage of units, is shown below. Fewer than 5% of the sample size was found to be in poor/very poor condition. The average HI for the asset group was 83.3%.



**Figure A 5-3 Pad Mounted Switchgear Health Index Distribution**



## 5.2 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from 'sample size' (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a 'levelized' plan for better pacing of investments is also provided.




Figure A 5-4 Pad Mounted Switchgear Flagged for Action Plan



### 5.3 Health Index Based Prioritized List

The following table shows the list of pad mounted switchgear, sorted by lowest to highest HI.

**Table A 5-4 Pad Mounted Switchgear Risk Based Prioritized List**

| Asset Information |          |          |                       |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |        |             |               |            |                       |
|-------------------|----------|----------|-----------------------|-----|--------------------|----------|-------------|---|--------|-------------|---------------|------------|-----------------------|
| #                 | Asset ID | Location | Install or Manuf Date | Age |                    | HI       | HI Category | Enclosure   | Inside | Connections | Fuse / Switch | Insulation | Base and Surroundings |
| 1                 | 40       | NT       | 1992                  | 28  | 100%               | 20.8%    | Very Poor   | 0%  | 50%    | NA          | NA            | NA         | 100%                  |
| 2                 | 25       | NT       | 1989                  | 31  | 100%               | 25.0%    | Poor        | 0%  | 100%   | NA          | NA            | NA         | 100%                  |
| 3                 | 4        | NT       | 1985                  | 35  | 100%               | 28.1%    | Poor        | 0%  | 75%    | NA          | NA            | NA         | 75%                   |
| 4                 | 63       | NT       | 1997                  | 23  | 100%               | 33.3%    | Poor        | 100%  | 100%   | NA          | NA            | NA         | 0%                    |
| 5                 | 9        | NT       |                       |     | 100%               | 37.5%    | Poor        | 0%  | 100%   | NA          | NA            | NA         | 100%                  |
| 6                 | 22       | NT       | 2008                  | 12  | 100%               | 37.5%    | Poor        | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 7                 | 95       | NT       | 2008                  | 12  | 100%               | 50.0%    | Fair        | 50%   | 50%    | NA          | NA            | NA         | 50%                   |
| 8                 | 2        | NT       | 1985                  | 35  | 100%               | 55.4%    | Fair        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 9                 | 11       | NT       | 1986                  | 34  | 100%               | 56.3%    | Fair        | 75%   | 75%    | NA          | NA            | NA         | 75%                   |
| 10                | 88       | NT       |                       |     | 100%               | 56.3%    | Fair        | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 11                | 14       | NT       | 1989                  | 31  | 100%               | 60.0%    | Fair        | 50%   | 50%    | NA          | NA            | NA         | 100%                  |
| 12                | 10       | NT       | 1986                  | 34  | 100%               | 61.2%    | Fair        | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 13                | 79       | NT       | 2001                  | 19  | 100%               | 62.5%    | Fair        | 100%  | 0%     | NA          | NA            | NA         | 100%                  |
| 14                | 5        | NT       |                       |     | 100%               | 63.8%    | Fair        | 75%   | 50%    | NA          | NA            | NA         | 75%                   |
| 15                | 96       | NT       |                       |     | 100%               | 63.8%    | Fair        | 75%   | 50%    | NA          | NA            | NA         | 75%                   |
| 16                | 31       | NT       | 1990                  | 30  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 17                | 50       | NT       | 1995                  | 25  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 18                | 52       | NT       | 1995                  | 25  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 19                | 67       | NT       | 1997                  | 23  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 20                | 71       | NT       | 2001                  | 19  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 21                | 72       | NT       | 2002                  | 18  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 22                | 77       | NT       | 2001                  | 19  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 23                | 80       | NT       | 1996                  | 24  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 24                | 81       | NT       | 2002                  | 18  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 25                | 86       | NT       |                       |     | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 26                | 93       | NT       | 2005                  | 15  | 100%               | 65.6%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 27                | 3        | NT       | 1987                  | 33  | 100%               | 66.7%    | Fair        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 28                | 36       | NT       | 1990                  | 30  | 100%               | 67.5%    | Fair        | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 29                | 47       | NT       | 1995                  | 25  | 100%               | 67.5%    | Fair        | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 30                | 107      | NT       | 2007                  | 13  | 100%               | 67.5%    | Fair        | 75%   | 75%    | NA          | NA            | NA         | 75%                   |
| 31                | 45       | NT       | 1990                  | 30  | 100%               | 68.8%    | Fair        | 100%  | 50%    | NA          | NA            | NA         | 100%                  |
| 32                | 60       | NT       | 1996                  | 24  | 100%               | 68.8%    | Fair        | 100%  | 50%    | NA          | NA            | NA         | 100%                  |
| 33                | 18       | NT       | 1996                  | 24  | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 25%                   |



| Asset Information |          |          |                       |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |        |             |               |            |                       |
|-------------------|----------|----------|-----------------------|-----|--------------------|----------|-------------|---|--------|-------------|---------------|------------|-----------------------|
| #                 | Asset ID | Location | Install or Manuf Date | Age |                    | HI       | HI Category | Enclosure   | Inside | Connections | Fuse / Switch | Insulation | Base and Surroundings |
| 34                | 26       | NT       | 1989                  | 31  | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 35                | 44       | NT       | 1990                  | 30  | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 36                | 46       | NT       | 1994                  | 26  | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 37                | 97       | NT       |                       |     | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 38                | 110      | NT       | 2009                  | 11  | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 50%                   |
| 39                | 112      | NT       | 2011                  | 9   | 100%               | 75.0%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 50%                   |
| 40                | 13       | NT       | 1989                  | 31  | 100%               | 76.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 41                | 15       | NT       | 1989                  | 31  | 100%               | 76.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 42                | 17       | NT       | 1989                  | 31  | 100%               | 76.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 43                | 19       | NT       | 1989                  | 31  | 100%               | 76.2%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 44                | 28       | NT       | 1989                  | 31  | 100%               | 76.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 45                | 12       | NT       | 1990                  | 30  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 46                | 54       | NT       | 1995                  | 25  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 47                | 58       | NT       | 1996                  | 24  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 48                | 59       | NT       | 1996                  | 24  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 49                | 66       | NT       | 2001                  | 19  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 50                | 68       | NT       | 2001                  | 19  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 51                | 74       | NT       | 1999                  | 21  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 52                | 98       | NT       | 2003                  | 17  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 53                | 102      | NT       | 2006                  | 14  | 100%               | 78.8%    | Good        | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 54                | 30       | NT       | 1990                  | 30  | 100%               | 80.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 55                | 33       | NT       | 1990                  | 30  | 100%               | 80.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 56                | 37       | NT       | 1990                  | 30  | 100%               | 80.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 57                | 38       | NT       | 1990                  | 30  | 100%               | 80.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 58                | 42       | NT       | 1990                  | 30  | 100%               | 80.2%    | Good        | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 59                | SC003    | MID      | 2000                  | 20  | 100%               | 85.0%    | Very Good   | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 60                | SC010    | MID      | 2010                  | 10  | 100%               | 85.0%    | Very Good   | 50%   | 100%   | NA          | NA            | NA         | 100%                  |
| 61                | 41       | NT       | 1992                  | 28  | 100%               | 86.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 62                | 99       | NT       | 1992                  | 28  | 100%               | 86.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 63                | 103      | NT       | 1992                  | 28  | 100%               | 86.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 64                | 51       | NT       | 1995                  | 25  | 100%               | 87.5%    | Very Good   | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 65                | 94       | NT       | 2003                  | 17  | 100%               | 87.5%    | Very Good   | 100%  | 75%    | NA          | NA            | NA         | 75%                   |
| 66                | 100      | NT       |                       |     | 100%               | 87.5%    | Very Good   | 75%   | 100%   | NA          | NA            | NA         | 100%                  |
| 67                | 21       | NT       | 1995                  | 25  | 100%               | 90.0%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 68                | 89       | NT       |                       |     | 100%               | 90.0%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 69                | 90       | NT       |                       |     | 100%               | 90.0%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 70                | 32       | NT       | 1994                  | 26  | 100%               | 91.6%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 71                | 53       | NT       | 1994                  | 26  | 100%               | 91.6%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |



| Asset Information |          |          |                       |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |        |             |               |            |                       |
|-------------------|----------|----------|-----------------------|-----|--------------------|----------|-------------|---|--------|-------------|---------------|------------|-----------------------|
| #                 | Asset ID | Location | Install or Manuf Date | Age |                    | HI       | HI Category | Enclosure   | Inside | Connections | Fuse / Switch | Insulation | Base and Surroundings |
| 72                | 20       | NT       | 1995                  | 25  | 100%               | 93.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 73                | 48       | NT       | 1995                  | 25  | 100%               | 93.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 74                | 49       | NT       | 1995                  | 25  | 100%               | 93.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 75                | SC011    | MID      | 1995                  | 25  | 100%               | 93.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 76                | 56       | NT       | 1996                  | 24  | 100%               | 94.9%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 77                | 57       | NT       | 1996                  | 24  | 100%               | 94.9%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 78                | 61       | NT       | 1996                  | 24  | 100%               | 94.9%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 79                | 64       | NT       | 1997                  | 23  | 100%               | 96.1%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 80                | 73       | NT       | 1998                  | 22  | 100%               | 97.0%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 81                | 35       | NT       | 1999                  | 21  | 100%               | 97.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 82                | 84       | NT       | 1999                  | 21  | 100%               | 97.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 83                | SC001    | MID      | 2000                  | 20  | 100%               | 98.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 84                | SC002    | MID      | 2000                  | 20  | 100%               | 98.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 85                | SC004    | MID      | 2000                  | 20  | 100%               | 98.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 86                | SC005    | MID      | 2000                  | 20  | 100%               | 98.4%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 87                | 65       | NT       | 2001                  | 19  | 100%               | 98.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 88                | 76       | NT       | 2001                  | 19  | 100%               | 98.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 89                | 78       | NT       | 2001                  | 19  | 100%               | 98.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 90                | 6        | NT       | 2002                  | 18  | 100%               | 99.2%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 91                | 75       | NT       | 2002                  | 18  | 100%               | 99.2%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 92                | 82       | NT       | 2002                  | 18  | 100%               | 99.2%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 93                | 83       | NT       | 2002                  | 18  | 100%               | 99.2%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 94                | 1        | NT       | 2004                  | 16  | 100%               | 99.6%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 95                | 27       | NT       | 2005                  | 15  | 100%               | 99.7%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 96                | 91       | NT       | 2005                  | 15  | 100%               | 99.7%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 97                | 92       | NT       | 2005                  | 15  | 100%               | 99.7%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 98                | 101      | NT       | 2006                  | 14  | 100%               | 99.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 99                | SC006    | MID      | 2006                  | 14  | 100%               | 99.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |
| 100               | SC007    | MID      | 2006                  | 14  | 100%               | 99.8%    | Very Good   | 100%  | 100%   | NA          | NA            | NA         | 100%                  |



## 5.4 Data Assessment

Age and basic inspection records were available for pad mounted switchgear. Additionally, an overall NTPDL hazard/risk score was assigned to each unit. Most transformers had some inspection and/or age available, so the DAI was 98%. However, the available inspection records were not very detailed, leaving the data gaps shown below.

| Asset Category         | Population | Average DAI |
|------------------------|------------|-------------|
| Pad Mounted Switchgear | 133        | 98%         |

The data gaps for this asset category are related to inspection granularity and include the following:

**Table A 5-5 Pad Mounted Switchgear Data Gaps**

| Data Gap                | Priority | Description  | Source                              |
|-------------------------|----------|--|-------------------------------------|
| Enclosure (door, paint) | L        | Peeling paint, deteriorating door, hinges, etc.                      | Visual inspection                   |
| Fuse                    | H        | Issues with fuse   | Visual inspection (live-front gear) |
| Switch                  | H        | Issues with switches   | Visual inspection (live-front gear) |
| Insulation              | H        | Insulators, barrier boards   | Visual Inspections                  |
| Connections             | H        | Terminations or elbows and inserts                                   | Visual inspections, IR scans        |
| Base and Surroundings   | L        | Grade change, poor placement, poor access, poor grounding connection | Visual inspection                   |

## 6. Poles

This section summarizes the ACA results for NTPDL's Wood and Concrete Poles.

### 6.1 Wood Poles

There are 8147 Wood Poles at NTPDL. Of these, 6149 had sufficient data for assessment. The average age of the population is 29 years; age distribution is as follows:




Figure A 6-1 Wood Poles Age Distribution



### 6.1.1 Health Index

#### 6.1.1.1 Health Index Formula

HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

### Wood Poles

**Table A 6-1 Wood Poles Health Index Formula**

| Condition Parameter (CP)  |              | Sub-Condition Parameter (SCP)                 |             |               |                |
|---|--------------|---|-------------|---------------|----------------|
| Description   | Weight (WCP) | Description                                   | Data Source | Weight (WSCP) | Criteria       |
| Pole  | 7            | Pole Strength                                 | Test        | 0*            | NA             |
|   |              | Pole Appearance                               | Inspections | 1             | Table A 6-2    |
|   |              | Hammer Test                                   | Inspections | 1             | Table A 6-2    |
| Crossarm  | 0*           | Crossarm                                      | Inspections | 0*            | NA             |
| Guy Assembly  | 4            | Guy Assembly                                  | Inspections | 1             | Table A 6-2    |
| Hardware  | 0*           | Hardware                                      | Inspections | 0*            | NA             |
| Insulators  | 0*           | Insulators                                    | Inspections | 0*            | NA             |
| Conductor   | 0*           | Conductor                                     | Inspections | 0*            | NA             |
| Brace   | 0*           | Brace   | Inspections | 0*            | NA             |
| Grounding   | 2            | Grounding                                     | Inspections | 1             | Table A 6-2    |
| Environment   | 0*           | Environment                                   | Inspections | 0*            | NA             |
| <b>Age Limiter (AL)</b>   |              | Based on typical life curve                   |             |               | Figure A 6-2   |
| <b>HI De-Rating Multiplier (DR)**</b>   |              | Hazard Assessment and proximity to major road |             |               | Equation A 6-1 |
| *where there is no available data for any assets, the weight of the parameter is set to 0                                     |              |   |             |               |                |
| ** Note that for poles in Newmarket and Tay, the HI formula is based only on the overall hazard assessments from inspections. |              |   |             |               |                |

### Inspections Records

**Table A 6-2 Inspection Criteria**

| Score | Condition Description   |                    |      |        |
|-------|---|--------------------|------|--------|
| 4     | Excellent working condition   | No apparent issues | Good | OK     |
| 3     | Minor wear, working as required   | Mild severity      |      |        |
| 2     | Wear or failed, repaired during inspection, regular monitoring required | Medium severity    | Fair |        |
| 1     | Major wear or failed, repaired during inspection                        | Severe             |      |        |
| 0     | Immediate replacement or emergency repair required                      | Very severe        | Poor | Not OK |



**De-Rating Multiplier**

The de-rating is based on the following equation and DR is described in the subsequent table.

$$DR = \min (DR_1, DR_2)$$


Equation A 6-1

**Table A 6-3 Poles De-Rating Multiplier Criteria**

| De-Rating Multiplier | Description          |                 |
|----------------------|----------------------|-----------------|
|                      | DR <sub>1</sub>      | DR <sub>2</sub> |
|                      | Overall Hazard Score | Location        |
| 1                    | 4                    | -               |
| 0.9                  | 3                    | -               |
| 0.8                  | -                    | On a major road |
| 0.75                 | 2                    | -               |
| 0.5                  | 1                    | -               |
| 0.25                 | 0                    | -               |

**Age Limiter**

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal for wood poles at 55 years is 20% and that at 75 years the likelihood of removal is 95%. For concrete poles, the assumed 20% and 95% of removal ages are 60 and 80 years respectively. The resultant survival curves (1 – likelihood of removals) are shown below. This survival curve was used as the Age Limiter.



**Figure A 6-2 Poles Age Limiter**





### 6.1.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. Approximately 6% of the sample size was found to be in poor/very poor condition. The average HI for the asset group was 87.9%.




Figure A 6-3 Wood Poles Health Index Distribution

### 6.1.2 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from ‘sample size’ (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a ‘levelized’ plan for better pacing of investments is also provided.




Figure A 6-4 Wood Poles Flagged for Action Plan



### 6.1.3 Health Index Based Prioritized List

The following table shows the list of very poor and poor wood poles, sorted by lowest to highest HI.

**Table A 6-4 Wood Poles Risk Based Priortized List**

| Asset Information |          |          |            |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |           |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|--------------------|----------|-------------|---|-----------|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age |                    | HI       | HI Category | Pole  | Crossarms | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 1                 | 0162     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 2                 | 0161     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 3                 | 0174     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 4                 | 0180     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 5                 | 0319     | MID      | 1953       | 67  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 6                 | 0250     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 7                 | 0476     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 8                 | 1454     | MID      | 1974       | 46  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 9                 | 0211     | MID      | 1985       | 35  | 100%               | 0.0%     | Very Poor   | 13%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 10                | 1277     | MID      | 1949       | 71  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 11                | 0047     | MID      | 1950       | 70  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 12                | 0133     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 13                | 0134     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 14                | 0173     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 15                | 0179     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 16                | 0242     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 17                | 0241     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 18                | 0248     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 19                | 0095     | MID      | 1953       | 67  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 20                | 0118     | MID      | 1953       | 67  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 21                | 0119     | MID      | 1953       | 67  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 22                | 0144     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 23                | 0234     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 24                | 0473     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 25                | 0316     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 26                | 0203     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 27                | 1011     | MID      | 1958       | 62  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 28                | 0078     | MID      | 1960       | 60  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 29                | 1282     | MID      | 1974       | 46  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 30                | 0115     | MID      | 1977       | 43  | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 31                | 1966     | MID      | 2011       | 9   | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 32                | 0300     | MID      | 2012       | 8   | 100%               | 0.0%     | Very Poor   | 25%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



| Asset Information |          |          |            |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |           |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|--------------------|----------|-------------|---|-----------|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age |                    | HI       | HI Category | Pole  | Crossarms | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 33                | 0238     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 34                | 0229     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 35                | 0192     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 36                | 0194     | MID      | 1952       | 68  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 37                | 0479     | MID      | 1953       | 67  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 38                | 1206     | MID      | 1954       | 66  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 39                | 0062     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 40                | 0232     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 41                | 0474     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 42                | 0475     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 43                | 0317     | MID      | 1955       | 65  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 44                | 1437     | MID      | 1974       | 46  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 45                | 0122     | MID      | 1974       | 46  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 46                | 1625     | MID      | 1977       | 43  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 47                | 0184     | MID      | 1979       | 41  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 48                | 1344     | MID      | 1980       | 40  | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 49                | 0908     | MID      | 2013       | 7   | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 50                | 0910     | MID      | 2013       | 7   | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 51                | 0948     | MID      | 2013       | 7   | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 52                | 0949     | MID      | 2013       | 7   | 100%               | 0.0%     | Very Poor   | 50%   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 53                | 0564     | MID      | 1974       | 46  | 100%               | 0.0%     | Very Poor   | 100%  | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 54                | 0306     | MID      | 2012       | 8   | 100%               | 0.0%     | Very Poor   | 100%  | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 55                | 1507     | MID      | 2013       | 7   | 100%               | 0.0%     | Very Poor   | 100%  | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 56                | 0143     | MID      | 2017       | 3   | 100%               | 0.0%     | Very Poor   | 100%  | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 57                | P41109   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 58                | P41110   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 59                | P41112   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 60                | P41114   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 61                | P41115   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 62                | P41116   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 63                | P41118   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 64                | P41119   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 65                | P41121   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 66                | P41122   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 67                | P41124   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 68                | P41126   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 69                | P41127   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 70                | P41129   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



| Asset Information |          |          |            |     | Condition Data DAI | Final HI |             | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |           |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|--------------------|----------|-------------|---|-----------|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age |                    | HI       | HI Category | Pole  | Crossarms | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 71                | P41130   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 72                | P41131   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 73                | P41132   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 74                | P41134   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 75                | P41135   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 76                | P41136   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 77                | P41137   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 78                | P41140   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 79                | P41143   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 80                | P41144   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 81                | P41146   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 82                | P41148   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 83                | P41149   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 84                | P41150   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 85                | P41151   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 86                | P41153   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 87                | P41154   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 88                | P41155   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 89                | P41156   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 90                | P41157   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 91                | P41160   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 92                | P41161   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 93                | P41162   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 94                | P41163   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 95                | P41164   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 96                | P41165   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 97                | P41167   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 98                | P41169   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 99                | P41171   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 100               | P41172   | NT       | 1939       | 81  | 0%                 | 0.4%     | Very Poor   |   | NA        | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



## 6.2 Concrete Poles

There are 303 Concrete Poles at NTPDL. Of these, 300 had sufficient data for assessment. The average age of the population is 9 years; age distribution is as follows:




Figure A 6-5 Concrete Poles Age Distribution



## 6.2.1 Health Index

### 6.2.1.1 Health Index Formula


The condition and sub-condition parameters are as follows:

**Table A 6-5 Concrete Poles Health Index Formula**

| Condition Parameter (CP)  |              | Sub-Condition Parameter (SCP)                 |             |               |                |
|---|--------------|---|-------------|---------------|----------------|
| Description   | Weight (WCP) | Description                                   | Data Source | Weight (WSCP) | Criteria       |
| Pole  | 7            | Pole Strength                                 | Test        | 0*            | NA             |
|   |              | Pole Appearance                               | Inspections | 1             | Table A 6-2    |
| Crossarm  | 0*           | Crossarm                                      | Inspections | 0*            | NA             |
| Guy Assembly  | 4            | Guy Assembly                                  | Inspections | 1             | Table A 6-2    |
| Hardware  | 0*           | Hardware                                      | Inspections | 0*            | NA             |
| Insulators  | 0*           | Insulators                                    | Inspections | 0*            | NA             |
| Conductor   | 0*           | Conductor                                     | Inspections | 0*            | NA             |
| Brace   | 0*           | Brace   | Inspections | 0*            | NA             |
| Grounding   | 2            | Grounding                                     | Inspections | 1             | Table A 6-2    |
| Environment   | 0*           | Environment                                   | Inspections | 0*            | NA             |
| <b>Age Limiter (AL)</b>   |              | Based on typical life curve                   |             |               | Figure A 6-2   |
| <b>HI De-Rating Multiplier (DR)**</b>   |              | Hazard Assessment and proximity to major road |             |               | Equation A 6-1 |
| *where there is no available data for any assets, the weight of the parameter is set to 0                                     |              |   |             |               |                |
| ** Note that for poles in Newmarket and Tay, the HI formula is based only on the overall hazard assessments from inspections. |              |   |             |               |                |

**6.2.1.2 Health Index Results**

The HI Distribution, in terms of number of units and percentage of units, is shown below. None were found to be in poor/very poor condition. The average HI for the asset group was 100%.



**Figure A 6-6 Concrete Poles Health Index Distribution**

**6.2.1.3 Flagged for Action Plan**

In this study, the 10-year FFA Plan was estimated based on the life curve approach detailed in Section 2.2. No poles were flagged for action in the next 10 years.





### 6.2.2 Health Index Based Prioritized List

The following table shows 'worst' 100 concrete poles, sorted by lowest to highest HI.

**Table A 6-6 Concrete Poles Risk Based Prioritized List**

| Asset Information |          |          |            |     | Final HI |             | Pole | HI Parameters  |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|----------|-------------|------|--|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age | HI       | HI Category | Pole | Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |              |          |            |           |       |           |             |
|                   |          |          |            |     |          |             |      | Crossarms  | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 1                 | 3524     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 2                 | 3525     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 3                 | 3526     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 4                 | 3527     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 5                 | 3528     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 6                 | 3529     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 7                 | 3530     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 8                 | 3531     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 9                 | 3532     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 10                | 3533     | MID      | 1992       | 28  | 100.0%   | Very Good   | 100% | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 11                | P20015   | NT       | 1993       | 27  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 12                | P20718   | NT       | 1993       | 27  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 13                | P20001   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 14                | P20002   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 15                | P20003   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 16                | P20004   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 17                | P20005   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 18                | P20006   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 19                | P20007   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 20                | P20008   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 21                | P20009   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 22                | P20012   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 23                | P20013   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 24                | P20014   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 25                | P20016   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 26                | P20017   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 27                | P20019   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 28                | P22615   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 29                | P22709   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 30                | P23628   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 31                | P23767   | NT       | 1995       | 25  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 32                | P20000   | NT       | 1997       | 23  | 100.0%   | Very Good   |      | NA   | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



| Asset Information |          |          |            |     | Final HI |             | Pole | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|----------|-------------|------|---|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age | HI       | HI Category | Pole | Crossarms   | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 33                | P22064   | NT       | 1999       | 21  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 34                | P24049   | NT       | 1999       | 21  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 35                | P21915   | NT       | 2000       | 20  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 36                | P21916   | NT       | 2000       | 20  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 37                | P23669   | NT       | 2000       | 20  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 38                | 3546     | MID      | 2002       | 18  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 39                | 3544     | MID      | 2002       | 18  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 40                | P20018   | NT       | 2003       | 17  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 41                | P22796   | NT       | 2003       | 17  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 42                | P23173   | NT       | 2003       | 17  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 43                | 3542     | MID      | 2003       | 17  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 44                | 3545     | MID      | 2003       | 17  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 45                | P20010   | NT       | 2006       | 14  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 46                | P20011   | NT       | 2006       | 14  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 47                | P21560   | NT       | 2006       | 14  | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 48                | 3523     | MID      | 2007       | 13  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 49                | 3543     | MID      | 2008       | 12  | 100.0%   | Very Good   | 100% | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 50                | P21656   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 51                | P21657   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 52                | P21658   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 53                | P21666   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 54                | P21667   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 55                | P21668   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 56                | P21669   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 57                | P21670   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 58                | P21671   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 59                | P21672   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 60                | P21673   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 61                | P21674   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 62                | P21675   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 63                | P21676   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 64                | P21677   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 65                | P21678   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 66                | P21679   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 67                | P21680   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 68                | P21681   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



| Asset Information |          |          |            |     | Final HI |             | Pole | HI Parameters<br>Blanks cells indicate no data for a particular unit.<br>Data Gaps denoted by 'Not Available' (NA). |              |          |            |           |       |           |             |
|-------------------|----------|----------|------------|-----|----------|-------------|------|---|--------------|----------|------------|-----------|-------|-----------|-------------|
| #                 | Asset ID | Location | Asset Year | Age | HI       | HI Category | Pole | Crossarms   | Guy Assembly | Hardware | Insulators | Conductor | Brace | Grounding | Environment |
| 69                | P21682   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 70                | P21683   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 71                | P21684   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 72                | P21685   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 73                | P21686   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 74                | P21687   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 75                | P21688   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 76                | P21689   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 77                | P21690   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 78                | P21691   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 79                | P21692   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 80                | P21693   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 81                | P21694   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 82                | P21695   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 83                | P21696   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 84                | P21697   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 85                | P21698   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 86                | P21699   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 87                | P21700   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 88                | P21701   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 89                | P21702   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 90                | P21703   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 91                | P21704   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 92                | P21705   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 93                | P21706   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 94                | P21707   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 95                | P21708   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 96                | P21709   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 97                | P21710   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 98                | P21711   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 99                | P21712   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |
| 100               | P21713   | NT       | 2012       | 8   | 100.0%   | Very Good   |      | NA  | NA           | NA       | NA         | NA        | NA    | NA        | NA          |



### 6.3 Data Assessment

Age was available for both wood and concrete poles. Additionally, overall condition and other basic inspection items, such as pole appearance, hammer tests, and comments about guying and electrical grounding, were available. The DAI are 62% and 39% for wood and concrete poles respectively. However, there are no pole strength tests. Further, inspection records were not granular and minor details could only be found in the inspection comments.

| Asset Category | Population | Average DAI |
|----------------|------------|-------------|
| Wood Poles     | 8147       | 62%         |
| Concrete Poles | 303        | 39%         |

The data gaps for this asset category are as follows. While some basic inspection items are available, more granular inspection items are noted below.

**Table A 6-7 Poles Data Gaps**

| Data Gap   | Priority | Description   | Source             |
|--|----------|---|--------------------|
| Pole Strength (wood)   | H        | Pole strength test (e.g. Circumference , PSI)               | Test Records       |
| Physical Condition<br>Wood poles:<br>damage, rot, animal<br>damage, leaning<br><br>Concrete poles:<br>damage, rebar<br>corrosion, spalling,<br>leaning | M        | Detailed information on physical<br>appearance of the pole. | Inspection records |
| Pole Accessories   | M        | Condition of hardware,<br>insulators, conductors, and brace | Inspection records |
| Environment  | L        | In water, soil conditions.                                  | Inspection records |

## 7. Underground Cables

This section summarizes the ACA results for NTPDL’s Underground Cables. This section summarizes the ACA results for NTPDL’s Underground Cables. There were a total of 413 conductor-km of Non-TRXLPE cables and 279 conductor-km of TRXLPE cables. Approximately 92 conductor-km were of unknown type and age. As such, these cables were not included in the assessment.

### 7.1 Non-TR XLPE Underground Cables

There were a total of 413 conductor-km of Non-TRXLPE cables. Of these, 390 conductor-km had age and were therefore included in the assessment. The average age is 32 years; the age distribution is as follows.




Figure A 7-1 Non-TRXLPE Underground Cables Age Distribution

### 7.1.1 Health Index Formula


HI is a function of scores and weights of condition and sub-condition parameters and is calculated using Equation 1 and Equation 2 described in Section 2.1. This section defines the condition and sub-condition parameters, as well as criteria.

**Table A 7-1 Underground Cables Health Index Formula**

| Condition Parameter (CP)   |              | Sub-Condition Parameter (SCP) |                             |               |              |
|--|--------------|-------------------------------|-----------------------------|---------------|--------------|
| Description  | Weight (WCP) | Description                   | Source                      | Weight (WSCP) | Table        |
| Cable Condition  | 0*           | Insulation                    | Tests                       | 0*            | NA           |
|  |              | Conductor                     | Tests                       | 0*            | NA           |
|  |              | Neutral Corrosion             | Tests                       | 0*            | NA           |
| Accessories  | 0*           | Splices                       | Tests                       | 0*            | NA           |
|  |              | Terminations                  | Tests<br>Visual Inspections | 0*            | NA           |
| <b>Age Limiter (AL)</b>  |              | Based on typical life curve   |                             |               | Figure A 7-2 |
| <b>HI De-Rating Multiplier (DR)</b>  |              | Fault Rate (segments)         |                             |               |              |
| *where there is no available data for any assets, the weight of the parameter is set to 0<br>Since no parameters were available, the assessment was age-based (i.e. equivalent to the Age Limiter) |              |                               |                             |               |              |

### Age Limiter

The Age Limiter used is equivalent to the survival function of the asset group, as described in Equation 5. It was assumed that the likelihood of removal for non-TRXLPE at 35 years is 20% and that at 45 years the likelihood of removal is 95%. For concrete poles, the assumed 20% and 95% of removal ages are 45 and 55 years respectively. The resultant survival curves (1 – likelihood of removals) are shown below.



**Figure A 7-2 Underground Cables Age Limiter**



### 7.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. Approximately 19% were found to be in poor/very poor condition. The average HI for the asset group was 79.8%.




Figure A 7-3 Non-TRXLPE Underground Cables Health Index Distribution



### 7.1.3 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from ‘sample size’ (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a ‘levelized’ plan for better pacing of investments is also provided.




Figure A 7-4 Non-TRXLPE Underground Cables Flagged for Action Plan



## 7.2 TRXLPE Underground Cables

There were a total of 279 conductor-km of TRXLPE cables. Of these, 229 conductor-km had age and were therefore included in the assessment. The average age is 18 years; the age distribution is as follows.




Figure A 7-5 TRXLPE Underground Cables Age Distribution



## 7.2.1 Health Index

### 7.2.1.1 Health Index Formula

See Section 7.1.1.

### 7.2.1.2 Health Index Results

The HI Distribution, in terms of number of units and percentage of units, is shown below. None were found to be in poor/very poor condition. The average HI for the asset group was 99.9%.




Figure A 7-6 TRXLPE Underground Cables Health Index Distribution



### 7.2.2 Flagged for Action Plan

The flagged for action plan, which was derived using the life curve method in Section 2.2 shows the expected number of assets to be addressed each year. The plan accounts for the entire asset population, i.e. the results from 'sample size' (assets with HI) were extrapolated to the population. As it may not always be feasible to address assets per this plan, a 'levelized' plan for better pacing of investments is also provided.




Figure A 7-7 Non-TRXLPE Underground Cables Flagged for Action Plan



### 7.3 Data Assessment

The assessment for underground cables was age-based.

| Asset Category   | Population (conductor-km) | Average DAI |
|------------------|---------------------------|-------------|
| Non-TRXLPE Poles | 413                       | Age-based   |
| TRXLPE Poles     | 279                       | Age-based   |

The data gaps for this asset category are as follows:

**Table A 7-2 Underground Cables Data Gaps**

| Data Gap                   | Priority | Description  | Source                            |
|----------------------------|----------|--|-----------------------------------|
| Insulation condition       | H        | Insulation defect (dielectric loss, partial discharge)               | Tests                             |
| Conductor condition        | M        | Conductor resistance, damage   | Tests                             |
| Neutral condition          | M        | Neutral resistance, damage, corrosion                                | Tests                             |
| Splices                    | H        | Splices  | Testing                           |
| Terminations               | H        | Termination defect   | Tests, IR scan, Visual inspection |
| Neutral Corrosion          | M        | Neutral defect   | Testing                           |
| Fault Rate (segment level) | M        | Failure records that can be associated with specific cable segments. | Historic records                  |