OAPPA Interrogatory #6

Interrogatory

Reference:
Exhibit E2-1-1, Page 14, lines 3 to 6 describe OPG's FLR challenges and targets, despite DRP. At line 6 it reads, "*However, OPG has decided to maintain this industry-leading FLR target in the 2020-2026 Business Plan with a view to continuous improvement*".

Please explain why the production schedule of Exhibit E2-1-2, Table 1a uses much higher FLR rates than the 1% FLR target considered by the Business Plan, necessarily affecting lower production.

Response

As referenced in Ex. E2-1-1, p. 14, lines 3-6, the 1% FLR forecast is applied to each unit in advance of refurbishment, with the 3 year FLR schedule post refurbishment applied before returning to the 1% target, as described in Ex. E2-1-1, p. 14, lines 8-14, again on a per unit basis.

The FLR rates shown in Ex. E2-1-2, Table 1a are a station average comprised of units at various lifecycle stages of pre-refurbishment and post-refurbishment throughout 2020-2026. Units in refurbishment do not contribute to station FLR.