ONTARIO POWER GENERATION

ZERO INJURIES Believe it. Achieve it.

SAFETY FLASH Report

INITIATED BY:
- ☐ CORPORATE GROUPS
- ☐ HYDRO
- ☐ THERMAL
- ☒ NUCLEAR

Notice No.14-0016 Issued: 2014.05.12
OPG Records #08960.2424 T5 yyyy.mm.dd

☒ Initial Communication ☐ Summary of Investigation

Type of Event	**Contractor High MRPH**	**Falling Light Standard**
Title • Location	Darlington Nuclear	
• Type of Event	Falling Object	
• Description	A light standard, ~ 6.1 meters (20 feet), weighing ~ 136 - 227 kg (300-500 lbs) was knocked over by a Sub-Contractor truck driver.	
• MRPH Rating	High	
Date of Event	May 8, 2014	
Event Summary	On May 8, 2014 at approximately 23:00 hrs a Sub-Contractor (Detox) truck driver in the process of aligning the truck to load a tote ran into and knocked over a light standard (600 V supply) on the C-13 project, east of the powerhouse. The C-13 area is fenced off and the only work in the area at the time was the removal of the totes. A contractor spotter was assisting with the alignment at the rear of the truck. Black and McDonald is the main contractor for the project. There were no injuries. An investigation is underway.	
Injuries/Damage		

Causes ☐ **Unknown** ☒ **Apparent** ☐ **Root**	Human Performance – maneuvering truck in close proximity to light standard.			
Actions Taken				
Recommended Action for Others				
Contact	Management Contact:	Pat Kennelly	Phone Number:	703-3103
	Safety Contact:	Tom Fennell	Phone Number:	(905) 576-6959 Ext.3346
IMS No./SCR No.	SCR No. N-2014-15070			

For Site Use Only

Local Site Disposition	

94343 Rev 06-04