

Hydro One Networks Inc.
7th Floor, South Tower
483 Bay Street
Toronto, Ontario M5G 2P5
www.HydroOne.com

Tel: (416) 345-5393
Cell: (416) 902-4326
Fax: (416) 345-6833
Joanne.Richardson@HydroOne.com



Joanne Richardson
Director – Major Projects and Partnerships
Regulatory Affairs

BY EMAIL AND RESS

October 8, 2021

Ms. Christine E. Long
Registrar
Ontario Energy Board
Suite 2700, 2300 Yonge Street
P.O. Box 2319
Toronto, ON M4P 1E4

Dear Ms. Long:

EB-2021-0136 – Hydro One Networks Inc. Leave to Construct Application – Richview TS by Trafalgar TS Reconductoring Project – Interrogatory Responses

Hydro One Networks Inc. (Hydro One) is submitting written responses to the Ontario Energy Board (“OEB”) staff, City of Mississauga, Environmental Defence, Association of Power Producers of Ontario, and Capital Power Corporation interrogatories on Hydro One’s Richview TS by Trafalgar TS Reconductoring Project consistent with the timing outlined in the OEB’s Procedural Order No. 1.

In responding to the interrogatories, Hydro One is providing certain informational data separately on a confidential basis, consistent with the OEB’s rules. Hydro One has filed a separate Application asking the OEB to approve confidential treatment of that data.

Additionally, in the same Application, also filed today, October 8, 2021, Hydro One is asking for individual’s names and personal information contained in another Attachment which forms responses to these interrogatories, to remain redacted, as the non-disclosure of that information outweighs the public interest.

An electronic copy of the confidential information will be provided to the OEB (via email) and shall not be used by any party for any purpose other than the matters at hand.

An electronic copy of the interrogatory responses has been submitted using the Board’s Regulatory Electronic Submission System.

Sincerely,

A handwritten signature in black ink, appearing to read "Joanne Richardson".

Joanne Richardson

c/ EB-2021-0136 Intervenors (Electronic only)

1 **OEB STAFF INTERROGATORY #1**

2
3 **Reference:**

4 Exhibit B, Tab 1, Schedule 1, Attachment 3, pages 7 – 8

5
6 **Preamble:**

7 The reference above discusses conservation, new supply resource and import alternatives
8 to the Richview by Trafalgar Reconductoring Project.

9
10 **Interrogatory:**

- 11 a) Do the resources to the west of FETT that would be enabled to flow east towards
12 Toronto by the proposed reconductoring project already exist or are already planned
13 for (or some combination of the two)? In other words, would the Richview by Trafalgar
14 Reconductoring Project allow Ontario to make use of existing or already planned
15 resources to the west of FETT and therefore obviate the need to develop new resources
16 in an effectively equivalent amount to the east of FETT (i.e., to address FETT
17 limitations projected by approximately 2026)? If not, please clarify.
- 18
19 b) If so, would the IESO agree that this represents a cost advantage of the proposed
20 Richview by Trafalgar Reconductoring Project compared to the east-of-FETT
21 alternatives considered by the IESO in the reference above, in addition to the feasibility
22 considerations considered by the IESO? If not, please clarify.

23
24 **Response:**

25 **The following response has been provided by the IESO.**

- 26
27 a) The proposed reconductoring project eliminates the requirement to locate 2,000 MW
28 east of FETT by 2026, however, there is still a capacity need in the province and new
29 resources east of FETT could help meet that need. The RTR Project would not obviate
30 the need to acquire new resources in the province. As stated on page 7 of Exhibit B,
31 Tab 1, Schedule 1, Attachment 3, there is an overall need for capacity in Ontario
32 (province-wide) due to increasing demand for electricity and the retirement of
33 Pickering GS combined with nuclear unit outages for refurbishment. For the year 2026,
34 that amount was determined to be about 5,200 MW after re-acquiring Lennox GS and
35 3,400 MW assuming all other resources with expiring contracts in the province are re-

1 acquired. The proposed RTR Project will remove the constraint that 2,000 MW of those
2 new resources must be located east of the FETT interface.

3

4 b) By providing flexibility to acquire new resources west of the FETT interface, the
5 proposed RTR Project should provide for greater competition amongst supply
6 resources and ultimately lead to ratepayer savings. The IESO's assessment of ratepayer
7 savings is conceptual in nature. The IESO has not calculated the value of the potential
8 savings associated with greater competition and does not believe it would be possible
9 to do so with any degree of precision at this time.

1 **OEB STAFF INTERROGATORY #2**

2
3 **Reference:**

- 4 (1) Exhibit B, Tab 3, Schedule 1, Attachment 3, page 6
5 (2) Exhibit B, Tab 3, Schedule 1, Attachment 3, page 7
6 (3) Exhibit B, Tab 3, Schedule 1, Attachment 3, page 10
7 (4) Exhibit B, Tab 3, Schedule 1, Attachment 3, page 8
8

9 **Preamble:**

10 The first reference shows capacity needs east of FETT to meet transmission security that
11 range between 4,950 MW and 5,600 MW by 2034. These needs will reduce to between
12 1,800 MW and 2,250 MW in 2026 once the extension to the Lennox GS contract is
13 negotiated.
14

15 The first reference also states that supply capacity east of the FETT interface will be needed
16 “in the summer of 2023 when the Lennox GS contract expires in 2022” and identifies
17 “further significant needs starting in 2026 after Pickering GS retires”. The reference also
18 states that “generating stations located east of FETT with expiring contracts around 2030
19 further adds to this need (Portland GS, Goreway GS, Halton Hills GS and York Energy
20 Centre GS).”
21

22 The second reference states that “1850 MW to 2250 MW of supply is required to maintain
23 security east of the FETT interface by 2026”.
24

25 The third reference shows that that the proposed Richview by Trafalgar Reconductoring
26 Project would increase FETT capacity by 2,150 MW (all in service).
27

28 The fourth reference states “depending on the outcomes of [...] future provincial resource
29 acquisitions, additional incremental increase in FETT transfer capability may be
30 recommended as a second stage.”

1 **Interrogatory:**

2 a) Please confirm that capacity needs east of FETT beyond the year 2026 exceed the
3 capacity provided by recontacting Lennox GS and implementing the proposed
4 Richview by Trafalgar Reconductoring Project. If confirmed, please comment on why
5 a larger transmission upgrade was not proposed given that capacity needs are projected
6 to arise even if Lennox GS is recontacted.

7
8 b) If not confirmed, please clarify.

9
10 c) Please comment on any key practical considerations, such as upstream or downstream
11 constraints, that would limit the suitability or feasibility of implementing a larger
12 upgrade to the Richview by Trafalgar circuits than proposed in this application.

13
14 d) Please explain whether the proposed upgrade will provide value even if additional
15 incremental increases in FETT transfer capability are eventually implemented as a
16 second stage. Please clarify whether those potential future increases will reduce the
17 usefulness and cost effectiveness of the currently proposed upgrade.

18
19 e) Please explain whether and how the proposed upgrade will provide value even if
20 expiring generation contracts around 2030 are replaced in the east. Please confirm and
21 clarify whether replacing/recontracting/or otherwise making up for those expiring
22 generation contracts will reduce the usefulness and cost effectiveness of the currently
23 proposed upgrade.

24
25 **Response:**

26 **The following response has been provided by the IESO.**

27
28 a) Confirmed. The IESO assessed but did not recommend a larger transmission upgrade
29 for the following reasons:

- 30
31 1. The recommended transmission upgrade will be sufficient to meet the need for
32 the foreseeable future if existing resources east of FETT are re-acquired.
33 Furthermore, even if not all existing resources are re-acquired post-2026 there
34 is a high likelihood that some of the new generation required to meet the
35 provincial capacity need will be sited in eastern Ontario. Hence, there is not an
36 urgency to pursue further upgrades to the FETT interface nor are we expecting
37 that further upgrades would be required.

1 **OEB STAFF INTERROGATORY #3**

2
3 **Reference:**

4 Exhibit B, Tab 1, Schedule 1, Attachment 3, pages 10 – 11

5
6 **Preamble:**

7 The reference compares the Richview by Trafalgar Reconductoring Project to a
8 transmission alternative (called Alternative 2). The estimated cost of Alternative 2 is \$88
9 Million. The references states that Alternative 2 would displace the need for other
10 transmission, providing a benefit of about \$23M. The reference states that “even with this
11 credit [...] the cost of Alternative 2 is still expected to be higher” than the Richview by
12 Trafalgar Reconductoring Project.

13
14 **Interrogatory:**

- 15 a) Please clarify whether the estimated \$23 Million credit is already factored into the
16 estimated \$88 Million cost of Alternative 2 (i.e. without the credit, would the cost of
17 Alternative 2 be \$88 Million + \$23 Million credit = \$111 Million, or would the credit
18 reduce the \$88 Million estimate by \$23 Million for an effective cost of \$65 Million?).
19
- 20 b) Whether or not the \$23 Million credit is already factored into the \$88 Million cost of
21 Alternative 2, would the IESO agree that the cost of Alternative 2 per long term MW
22 of increase is higher compared to the proposed Richview by Trafalgar Reconductoring
23 Project as outlined in Table 3 (both from the perspective of “all in service” or “element
24 out of service” conditions)? If yes, please briefly illustrate. If not, please clarify.
25

26 **Response:**

27 This response has been provided with collaboration from Hydro One and the IESO.
28

- 29 a) The \$23M credit has not been factored into the estimated \$88M cost of Alternative 2.
30 Factoring in the credit would result in an effective cost of \$65M for Alternative 2.
31
- 32 b) Yes, the IESO concurs that the cost of Alternative 2, on a dollar per megawatt basis, is
33 more costly than the proposed RTR Project’s dollar per megawatt cost. The proposed
34 RTR Project, as detailed in Hydro One’s Application, provides a greater long-term
35 transfer capability at a lower cost, compared to the alternative. The costs per MW is
36 illustrated in Table 1, below.

1

Table 1 – Project Cost per MW

Alternatives (Estimated Project Cost)	Incremental increase all in-service Transfer Capability (MW)	Cost / MW (\$K)	Incremental increase with one element out- of-service Transfer Capability (MW)	Cost / MW (\$K)
RTR Project (\$61 M)	2,150	\$28	1,550	\$39
Alternative 2 ¹ (\$65 M)	1,700	\$38	1,250	\$52

¹ Including the \$23M Credit

1 b) Yes. Hydro One has internal standards¹ for skywire replacement that follows best-
2 practices. The standards dictate that installed skywire needs to be in a good condition
3 and be able to carry out its function of conducting the short circuit current under system
4 fault conditions. Skywire is replaced generally for one of two reasons; a) conductor
5 deterioration (i.e. poor condition) or, b) inadequate short circuit capacity.

6

7 Hydro One's skywire population is monitored through its condition assessment
8 program. Under this program, skywire is regularly tested for deterioration and work is
9 scheduled and undertaken to replace any skywire that has deteriorated beyond an
10 acceptable level.

11

12 Hydro One also screens skywire to ensure that they have adequate capacity to carry the
13 highest expected fault current. The screening is done as part of the system assessment
14 whenever the system is refurbished, reinforced, or new generation is connected.

¹ These standards are consistent with Institute of Electrical and Electronics Engineers (IEEE) Standard 1863-2019 - Guide for Overhead AC Transmission Line Design

1 **OEB STAFF INTERROGATORY #6**

2
3 **Reference:**

4 Exhibit E, Tab 1, Schedule 1

5
6 **Preamble:**

7 The reference above identifies the land right agreements that Hydro One proposes to use
8 to obtain any identified land rights for the Richview by Trafalgar Reconductoring Project.

9
10 **Interrogatory:**

- 11 a) Please confirm that all impacted landowners will have the option to receive
12 independent legal advice regarding the proposed land agreements.
13
14 b) Please clarify whether Hydro One has committed to or will commit to reimbursing
15 landowners for reasonably incurred legal fees associated with the review and execution
16 of the necessary land rights agreements.

17
18 **Response:**

- 19 a) Confirmed, impacted landowners will have the option to receive independent legal
20 advice.
21
22 b) Confirmed. Hydro One is committed to reimbursing landowners that Hydro One
23 identifies will be impacted by the RTR Project, for the reasonably incurred fees for
24 independent legal advice associated with the review and execution of the necessary
25 land rights agreements.

1 **OEB STAFF INTERROGATORY #7**

2
3 **Reference:**

4 Exhibit B, Tab 1, Schedule 1

5
6 **Preamble:**

7 Hydro One has applied for leave to construct approval. Procedural Order No.1 includes the
8 OEB's standard conditions of approval for transmission leave to construct applications.
9 OEB staff proposes that the standard conditions be placed on Hydro One in relation to this
10 application. The standard conditions are reproduced below for convenience:

- 11 1. Hydro One shall fulfill any requirements of the SIA and the CIA, and shall obtain
12 all necessary approvals, permits, licences, certificates, agreements and rights
13 required to construct, operate and maintain the project.
- 14 2. Unless otherwise ordered by the OEB, authorization for leave to construct shall
15 terminate 12 months from the date of the Decision and Order, unless construction
16 has commenced prior to that date.
- 17 3. Hydro One shall advise the OEB of any proposed material change in the project,
18 including but not limited to changes in: the proposed route, construction schedule,
19 necessary environmental assessment approvals, and all other approvals, permits,
20 licences, certificates and rights required to construct the project.
- 21 4. Hydro One shall submit to the OEB written confirmation of the completion of the
22 project construction. This written confirmation shall be provided within one month
23 of the completion of construction.
- 24 5. Hydro One shall designate one of their employees as project manager who will be
25 the point of contact for these conditions, and shall provide the employee's name
26 and contact information to the OEB and to all affected landowners, and shall clearly
27 post the project manager's contact information in a prominent place at the
28 construction site.

29
30 **Interrogatory:**

- 31 a) Please comment on the above standard conditions in relation to this application. If
32 Hydro One does not agree with any of the draft conditions of approval, please identify
33 the specific conditions that Hydro One disagrees with and explain why. For conditions
34 in respect of which Hydro One would like to recommend changes, please provide the
35 proposed changes.

Filed: 2021-10-08

EB-2021-0136

Exhibit I

Tab 1

Schedule 7

Page 2 of 2

1 **Response:**

2 a) Hydro One agrees to the standard OEB conditions of approval listed above.

1 **OEB STAFF INTERROGATORY #8**

2
3 **Reference:**

- 4 (1) Exhibit B, Tab 1, Schedule 1, p. 4.
5 (2) Exhibit B, Tab 3, Schedule 1, p. 2.
6 (3) Exhibit B, Tab 3, Schedule 1, Attachment 1
7 (4) Exhibit B, Tab 3, Schedule 1, Attachment 2
8 (5) Exhibit B, Tab 3, Schedule 1, Attachment 3
9

10 **Preamble:**

11 At reference (1), Hydro One states that the cost of the transmission line and related facilities
12 for which it is seeking OEB approval is approximately \$60.9 million, of which \$56.3
13 million is capital and will be added to rate base, and \$4.6 million is removals.
14

15 Reference (3) is the IESO letter recommending that Hydro One proceed with the Richview
16 by Trafalgar Reconductoring Project and is dated December 10, 2020.
17

18 Reference (4) is Hydro One's September 9, 2020 memorandum cited by the IESO in its
19 recommendation letter. In it, Hydro One states that the estimated cost to complete the
20 project is \$47.7M. At reference (2), Hydro One states that the cost estimate provided in
21 the memorandum "informed the decision and direction that the IESO provided to Hydro
22 One in its [recommendation] Letter."
23

24 Reference (5) is the IESO report entitled "Trafalgar TS x Richview TS 230 kV line
25 upgrade: Need and Selection of the Preferred Plan" and is dated July 12, 2021. In its report,
26 the IESO stated "[a]t the time the IESO recommended Hydro One to proceed with
27 Alternative 1 in the IESO letter to Hydro One dated December 18, 2020, the cost estimate
28 for Alternative 1 was \$48M. Subsequently, Hydro One has indicated the cost estimate now
29 stands at \$61M after further reviews."
30

31 **Interrogatory:**

- 32 a) At reference (5), the IESO describes that the cost estimate for Alternative 1 was \$48
33 million, but now stands at \$61 million after further reviews. Please describe the further
34 reviews undertaken by Hydro One that resulted in the revised cost estimate. Please also
35 describe the drivers of the additional cost as well as the reasons these drivers were
36 previously unknown.

- 1 b) Please identify the level of confidence associated with the revised \$61 million estimate.
2 E.g., is the estimate subject to the same 30%/-20% confidence as the \$47.7M estimate
3 in the September 9, 2020 memorandum?
4
- 5 c) Alternative 2 as described at reference (5) has an estimated cost of \$88 million. Please
6 identify the level of confidence associated with the \$88 million estimate. E.g., is the
7 estimate subject to a similar 30%/-20% confidence?
8
- 9 d) Please described the process used to determine Alternative 2's cost estimate of \$88
10 million.
11
- 12 e) At reference (5) the IESO states that Alternative 2 would displace the need for
13 transmission enhancements that increase the supply to Richview South and provide a
14 benefit of about \$23 million. The IESO further stated that even with this benefit and
15 the higher cost of Alternative 1, the cost of Alternative 2 is still expected to be higher
16 than Alternative 1. Please describe how the \$23 benefit was calculated and indicate the
17 level of confidence associated with it.
18

19 **Response:**

- 20 a) Hydro One's standard internal process was followed to prepare the revised estimate.
21 The project plan and schedule were updated based on the project conditions and a new
22 risk workshop was undertaken to determine the revised contingency amount. The
23 estimate was also updated based on the latest available applicable rates (such as
24 hardware, procurement and installation costs with revised labour, material, overhead
25 and rental rates). Site walkthroughs were undertaken this year by the project team to
26 identify and map access and craning requirements.
27

28 Table 1, below, provides a comparison of the current Richview by Trafalgar
29 Reconductoring Project (RTR) Project estimate of \$60.9M with the previously-
30 provided estimate of \$47.7M provided to the IESO, and referred to in Reference 4 of
31 the interrogatory, above.

1

Table 1

Category	Costs		Increase (\$M)
	Reference (4) (\$M)	Current S.92 Costs (\$M)	
Project Management	1.4	1.4	0.0
Real Estate	0.2	0.2	0.0
Engineering	0.8	1.5	0.7
Procurement	11.5	14.6	3.1
Construction	21.3	28.2	6.9
Commissioning	0.1	0.1	0.0
Contingency	2.2	3.0	0.8
Interest	2.6	2.3	-0.3
Overhead	4.0	5.0	1.0
Removals	3.6	4.6	1.0
Total	47.7	60.9	13.2

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

The main contributors to the increase in costs from the initial project estimate prepared in 2020 and the current 2021 RTR Project estimate are based on increased project maturity as identified below:

- Additional access roads to support crane access requirements, undetected due to limited site walkthroughs resulting from pandemic measures
- Additional crane pads to safely access all towers
- Increase in hardware, procurement and installation costs with revised labour, material, overhead and rental rates
- Updated risk evaluation resulting in increased contingency

b) Yes, the current RTR Project estimate has the same accuracy level (+30%/-20%) as the \$47.7M estimate in the September 9, 2020 memorandum. The contributing factors of the cost difference are based on increased project maturity and listed in the response to part a) above.

c) The \$88M cost for project Alternative # 2 is a planning estimate and has an accuracy level of (+100/-50%).

d) The \$88M cost estimate for Alternative #2 was derived using transmission line unit costs, equipment unit costs, and similar prior project unit costs.

Filed: 2021-10-08

EB-2021-0136

Exhibit I

Tab 1

Schedule 8

Page 4 of 4

- 1 e) The \$23M estimate is a budgetary estimate for the Richview TS x Manby TS line
- 2 project. It has an accuracy of (+50%/-30%).

1 **OEB STAFF INTERROGATORY #9**
2

3 **Reference:**

- 4 (1) Exhibit B, Tab 7, Schedule 1, page 2
5 (2) Exhibit B, Tab 7, Schedule 1, Table 1, page 1
6

7 **Preamble:**

8 The first reference above outlines project risks, including Hydro One's estimated top four
9 project risks. The second reference states the total estimated project cost of \$56.2 million,
10 which includes a contingency cost estimate of \$2.7 million. This contingency cost estimate
11 represents approximately 5% of the pre-contingency estimate.
12

13 **Interrogatory:**

- 14 a) Please explain the methods Hydro One used to assess project risks for the Richview by
15 Trafalgar Reconductoring Project and please clarify how Hydro One's contingency
16 estimate relates to that analysis. Through its response, Hydro One is also requested to
17 articulate why the contingency cost estimate is appropriate.
18
19 b) Please describe how the contingency cost estimate for the Richview by Trafalgar
20 Reconductoring Project compares to contingency cost estimates developed for similar
21 Hydro One projects.
22
23 c) How would Hydro One characterize the confidence of the cost estimate for the
24 Richview by Trafalgar Reconductoring Project? What method did Hydro One use to
25 estimate its confidence?
26
27 d) How did Hydro One develop its estimates and confidence estimates for project
28 material, labour, equipment rental and contractor costs?
29

30 **Response:**

- 31 a) Hydro One utilizes the risk assessment framework from the Project Management
32 Institute (PMI) "*A Guide to the Project Management Body of Knowledge*", an industry
33 standard. This framework was also used as guidance to determine the contingency
34 using a quantitative risk analysis.

1 Hydro One's Risk Management Process for the Project is described below:

- 2 • Risk identification: Risk types associated with environmental, external
3 stakeholders, permits and approvals, engineering, subsurface conditions,
4 construction, material delivery timelines, outages, and other external factors were
5 determined. Each risk was provided a unique identifier, risk title, description and
6 assigned a risk owner.
- 7 • Risk analysis: A probability (i.e. likelihood) of each risk occurrence is assigned to
8 that risk, along with its impact on project schedule and cost. The probability of
9 each risk was then multiplied by the impact to determine the expected value for
10 each risk. The sum of all individual expected cost values represents the total
11 contingency reserve for the Project of \$2.9M.
- 12 • Risk response plan: Mitigation actions, action delegate, action date and risk expiry
13 date were completed for each risk.

14
15 The contingency reserve amount that was determined from the risk assessment is an
16 accepted practice in the industry and considered appropriate for this Project.

- 17
18 b) The contingency amount for the RTR Project is within the range of 5% to 15% of direct
19 costs which is similar to other line construction projects recently undertaken by Hydro
20 One. The contingency amount is calculated by project specific risk factors which are
21 identified at a Hydro One conducted pre-construction kick-off Risk Workshop.
- 22
23 c) The confidence of the cost estimate for the RTR Project is considered to have an
24 accuracy range estimate of 30%/-20%. The Project estimate was prepared in
25 accordance with the recommended practice of the AACE International Cost Estimate
26 Classification System.
- 27
28 d) The RTR Project estimate was prepared using Hydro One's current standard labour
29 rates. These are consistent with labour rates used on other Hydro One-performed
30 construction activities. Likewise, the material, equipment rentals and external
31 contractor costs are based on standard rates used by Hydro One and calculated from
32 experience garnered in past and ongoing construction projects for the categories listed
33 above.

OEB STAFF INTERROGATORY #10

Reference:

Exhibit B, Tab 7, Schedule 1

Preamble:

Table 1 is an extract from the above reference.

Table 1: Extract from Exhibit B, Tab 7, Schedule 1, page 6

Table 2 - Costs of Comparable Line Projects

Project	RTR Project	WTTE Project	D6V/D7V Project	DxS Project
Scope	Reconductor four 230 kV lines	Reconductor four 115 kV lines	Reconductor two 230 kV lines	Reconductor two 115 kV lines
Length (km)	21.7	10.0	9.4	9.0
Circuit Length (km) ⁴	70.8 ⁵	40.0	18.8	18.0
Project Surroundings	Urban	Urban	Mostly Rural	Mostly Urban
In-Service Date	Apr-2026	Nov-18	Dec-20	Dec-15
Years for escalation	-	7 yrs, 5 months	5 yrs, 4 months	10 yrs, 4 months
Total Project Cost (\$M) ⁶	56.3	21.4	8.6	6.3
Less: By-Pass (\$M)	0.4	-	-	0.2
Less: OPGW Costs (\$M) ⁷	1.2	0.3	0.3	0.8
Total Project Costs Before Escalation (\$M)	54.7	21.1	8.3	5.3
Add: Escalation Adjustment (2%/year)	-	3.3	0.9	1.2
Total Comparable Project Costs (\$M)	54.7	24.5	9.2	6.6
Total Cost/Circuit km (\$M)	0.8	0.6	0.5	0.4

At the above reference, Hydro One stated that the Richview by Trafalgar Reconductoring Project differs from the comparator reconductoring projects shown in Table 1 for two reasons. One reason provided was that tower reinforcement and some tower replacements are required for the Richview by Trafalgar Reconductoring Project whereas the comparator projects did not require tower reinforcement.

At Exhibit B, Tab 7, Schedule 1, p. 7, Hydro One states that the Richview by Trafalgar Reconductoring and WTTE projects “were also very similar in scope and included structural reinforcement and replacement of existing steel towers.” At Exhibit C, Tab 1, Schedule 1 of Hydro One’s WTTE application (EB-2016-0325), Hydro One describes the

1 tower reinforcement and replacement work required to facilitate the project and for which
2 it was seeking OEB approval.

3
4 At Exhibit B, Tab 7, Schedule 1, p. 9, Hydro One states that “no tower or tower
5 replacements were required for the D6V/D7V Project”. At Exhibit C, Tab 1, Schedule 1,
6 p. 1 of Hydro One’s D6V/D7V Project application (EB-2019-0165), Hydro One describes
7 the various tower reinforcement work it planned to undertake to complete the project and
8 for which it was seeking OEB approval.

9
10 **Interrogatory:**

11 a) In light of the above, please explain why Hydro One states that one of the two reasons
12 for the higher cost of the Richview by Trafalgar Reconductoring Project is that the
13 comparator projects did not require tower reinforcement.

14
15 b) Please confirm if the WTTE and D6V/D7V project costs shown in Table 1 are inclusive
16 of tower reinforcement work.

17
18 c) With consideration to Hydro One’s response to questions a) and b) above, please
19 indicate if the only reason for the higher cost of the Richview by Trafalgar
20 Reconductoring Project is that it involves work on four 230 kV circuits carried on two
21 separate, and adjacent sets of towers, compared to the comparator projects where
22 reconductoring was carried out on only a single set of towers. If applicable, please
23 describe why it is appropriate that this single driver results in the Richview by Trafalgar
24 Reconductoring Project costing between 33% and 60% higher than the WTTE and
25 D6V/D7V project comparators, respectively, on a total cost per circuit km basis.

26
27 d) Hydro One states that the higher cost of the Richview by Trafalgar Reconductoring
28 Project is partly attributable to the fact that it involves work on four 230 kV circuits
29 carried on two separate, and adjacent sets of towers, compared to the comparator
30 projects where reconductoring was carried out on only a single set of towers.

31
32 At Exhibit C, Tab 1, Schedule 1 of Hydro One’s WTTE application (EB-2016-0325),
33 Hydro One states “K1W/K3W and 8 K11W/K12W are each strung on two 2-circuit
34 115kV towers from Manby TS to Structure 4. From Structure 4 to Wiltshire TS all
35 circuits are strung on 4-circuit 115kV towers, with the exception at Runnymede TS and
36 St. Clair JCT.” This statement indicates that while a portion of the WTTE project was

1 carried out on a single set towers, another portion was carried out on separate and
2 adjacent towers.

3
4 In light of the above, please clarify Hydro One's position that one of the two reasons
5 for the higher cost of the Richview by Trafalgar Reconductoring Project is that the
6 comparator projects only required work on a single set of towers.

7
8 e) Table 1 shows that the WTTE project involved the reconductoring of four 115 kV lines
9 whereas the RTR project involves the reconductoring of four 230 kV lines. Please
10 describe what, if any, cost differences between the RTR And WTTE projects are driven
11 by the different conductor voltages.

12
13 f) With consideration to Hydro One's response to question c) and d) above, please provide
14 an estimate of the difference in the Richview by Trafalgar Reconductoring Project's
15 cost that Hydro One would attribute to completing work on four 230 kV circuits carried
16 on two separate, and adjacent sets of towers, compared to the comparator projects
17 where reconductoring was carried out on only a single set of towers. When responding,
18 please describe the assumptions underpinning the estimate and why they are
19 reasonable.

20
21 **Response:**

22 a) Hydro One would like to clarify that the tower reinforcement work described in Exhibit
23 B, Tab 7, Schedule 1, page 4, is in the context of work required to upgrade the line
24 security class design. The RTR Project requires towers to be replaced or reinforced to
25 bring the towers up to the current security class design standards. In the three
26 comparator projects provided in Table 1, no security class tower upgrade was included
27 in the scope of work (as extracted in the question, above).

28
29 By upgrading a circuit's 'security class', Hydro One is describing when circuits,
30 including tower structures, are reinforced and/or replaced to be able to withstand a
31 severe weather event considered to have larger forces (or impacts) but usually is a
32 weather event that is assumed to occur less often.

1 For illustrative purposes only, Hydro One is providing an example to help with the
2 understanding of the concept of a ‘security class upgrade’.

3
4 *For example, Hydro One may reinforce Circuit XYZ, which is a 230 kV*
5 *circuit. The circuit could be located anywhere in Ontario, and*
6 *appropriately designed for that geographical setting. The newly reinforced*
7 *circuit (security class increase) will be designed to withstand a once-in-50*
8 *year storm, versus (for example) a one-in-10 year, or one-in-20 year*
9 *weather event, that circuit XYZ is currently designed to withstand. This is*
10 *an example of a ‘security class upgrade’.*

11
12 b) Yes, the WTTE and D6V/D7V project costs in Table 1 (included above) are inclusive
13 of tower reinforcement work.

14
15 c) No. As mentioned in Exhibit B, Tab 7, Schedule 1, Page 4, the RTR Project’s
16 comparatively higher costs are largely due to two main drivers; (1) the need to work on
17 two separate but adjacent sets of towers, and (2) the need to upgrade the line security
18 class. Both these drivers result in increased construction effort and costs, as compared
19 to the WTTE and D6V/D7V projects, which are described in more detail below:

20
21 *Comparison to WTTE Project*

22 The RTR Project has an increased construction effort when compared to the WTTE
23 Project as it requires working on two separate but adjacent sets of towers, as opposed
24 to the single set of towers for the WTTE project. This requires additional temporary
25 access roads and doubles the number of crane and stringing pads for the reconductoring
26 work. Furthermore, with the line security class upgrade, extra tower work is required
27 resulting in a longer construction period, with more labour hours, greater equipment
28 rental costs, and longer use of temporary facilities. It also increases the other associated
29 costs of construction such as interest and overhead.

30
31 Other factors contributing to a higher per km costs for the RTR Project are the use of
32 ACSS conductor and the higher voltage level of the lines. The ACSS conductor and
33 related hardware are comparatively more costly than the conventional ACSR conductor
34 and hardware used on the WTTE Project. The structural tower reinforcement work that
35 would be required for larger 230 kV towers, is in comparison, greater compared to the
36 tower reinforcement work required on the smaller 115kV towers that were associated
37 with the WTTE Project circuits.

1 Comparison with the D6V/D7V Project

2 The rationale for the higher cost for the RTR Project, when compared to the D6V/D7V
3 Project is analogous to the comparison provided above, for the WTTE Project. The
4 D6V/D7V Project was a single double circuit line, and no security upgrade was carried
5 out. In comparison, the RTR Project requires six new towers, structural steel
6 reinforcement of all of the existing towers, of which there are two sets of towers
7 adjacent to each other. Additionally on the RTR Project there is tower foundation
8 reinforcement required to some of the existing towers that will remain in place.

9
10 Other factors contributing to the higher per km cost of the RTR Project is use of the
11 ACSS-type conductor and the location of the RTR Project. The ACSS conductors and
12 hardware are more costly, compared to the conventional ACSR-type conductor which
13 was used on the D6V/D7V Project. The RTR Project is located in a dense urban setting
14 with multiple road/train/water body crossings (such as; provincial highways, railways
15 lines, GO Transit and Mississauga Bus Rapid Transit stations and the Credit River).
16 Whereas the D6V/D7V Project is located in a rural setting absent many of the crossings
17 mentioned above that the RTR Project must plan for and accommodate during
18 construction. The multiple crossings will result in increased cost due to work required
19 to establish a safe work area with Telescopic Boom Truck Cranes, temporary rider
20 poles, and traffic controllers on each side of each crossing.

21
22 d) Hydro One has provided the main reasons for the higher per km cost of the RTR
23 Project, when compared to the WTTE Project, above in part c). For clarification, a
24 major cost element variance to that of the WTTE Project is related to the configuration
25 of the design of these circuits and the number of towers that each circuit is carried by.
26 The WTTE has only two spans of conductor carried on separate, and parallel, towers.
27 These two spans of 115 kV conductor are carried on towers #1, #2 and #3 emanating
28 from Manby TS, which is a distance of less than 0.5 km. The remainder of the 10km
29 of 115 kV circuits on the WTTE Project, between Wiltshire TS to Manby TS, are strung
30 on a 4-circuit single tower configuration between Tower #4 to Tower #48 (a total of 44
31 towers). Comparatively the RTR Project configuration carries the circuits on two sets
32 of parallel towers (each carrying double circuits) the entire way from Richview TS to
33 Trafalgar TS, a distance of approximately 21 km. This is one driver of the comparable
34 per km project cost variance.

35
36 e) Please refer to the response in part c), above.

1 f) OEB staff have asked for a theoretical estimate for a project that does not exist and has
2 not been contemplated by Hydro One. Estimation of theoretical projects, in the detail
3 that OEB staff have requested, cannot be calculated in a matter of weeks with a realistic
4 degree of accuracy. Each project forecast exercise takes considerable time and
5 resources. Hydro One has explained the main drivers of the differences in the
6 comparable projects table, however this question would appear to be reaching beyond
7 reasonable expectations with which Hydro One has to provide a meaningful response.

8

9 Table 2, as presented in Exhibit B, Tab 7, Schedule 1 of the RTR Project Application,
10 provides costs and information pertaining to the similarities and differences of those
11 comparative projects, and are further supported by additional detailed information
12 provided above in responses to parts a) through part d).

- 1 For a redacted copy of the registered easements, please refer to Attachment A to this
2 response. It includes a copy¹ of;k
- 3 1. instrument number TT41304, registered November 12, 1941, which is an
4 easement for the R14/17T circuits; and
 - 5 2. instrument number TT57259, registered November 25, 1949, which is an
6 easement for the R19/21TH circuits.
- 7
- 8 b) For the proposed RTR Project, Hydro One will not be utilizing any materials that may
9 adversely affect the quality of the soil or groundwater or are otherwise defined as
10 “substances” under the *Environmental Protection Act* of Ontario.

¹ Hydro One has redacted any individual names and/or other personal information that is contained in Attachment 1. It is not in the public interest for these to be disclosed. Further, Hydro One has made an Application to the OEB, filed on the same day as the submission of these responses (i.e. October 8, 2021) asking for approval to maintain confidentiality of those details via the redactions made to Attachment 1 of evidence placed on the public record.

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #1**

2
3 **Reference:**

4 Exhibit B-3-1, p. 8

5
6 **Preamble:**

7 The IESO project report dated July 12, 2021 states as follows:

8
9 Several transmission alternatives were considered that can provide increases in the FETT
10 capacity.

11
12 Those options were narrowed down to two options that meet the following two criteria:

- 13 • Can be in-service before the summer 2026.
14 • Provide an increase in transfer capability of at least 2,250 MW in
15 2026 assuming all transmission elements in service.

16
17 **Interrogatory:**

18 a) Please confirm that the two criteria are that the project: (i) can be in-service before the
19 summer 2026; and (ii) provide an increase in transfer capability of at least 2,250 MW
20 in 2026 assuming all transmission elements in service.

21
22 **Response:**

23 **This response has been provided by the IESO.**

24
25 a) The IESO confirms these were the two screening criteria used to narrow down
26 transmission alternatives to those for detailed alternative comparison analysis. In
27 assessing these criteria, the IESO required a high degree of confidence that an
28 alternative would provide sufficient transfer capability and be in-service before the
29 summer of 2026 to meet the reliability need.

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #2**

2
3 **Reference:**

4 Exhibit B-3-1, p. 8

5
6 **Preamble:**

7 ““At the development phase of the project, numerous conductors were considered for
8 upgrading the Trafalgar TS x Richview TS lines. It was concluded that the use of 1433
9 kcmil ACSS would provide the required planning summer long term emergency (LTE)
10 rating of 2000 A. It is a high-temperature compact conductor that allows the required rating
11 without involving significant tower modifications. The existing line includes 795 kcmil
12 ACSR and 1307 kcmil ACSR conductors. The reduction in the resistance, hence reduction
13 in line losses, will be about 44% for the sections with 795 kcmil ACSR and about 8% for
14 the sections with 1307 kcmil ACSR.”

15
16 **Interrogatory:**

- 17 a) Does Hydro One take the position that it was unable to seek OEB approval for a larger
18 conductor than 1433 kcmil ACSS even if this could cost-effectively avoid transmission
19 losses (i.e., the net present value of the transmission loss reductions would be higher
20 than the net present value of the incremental cost of the larger conductor)?
- 21
22 b) Was Hydro One or the IESO responsible for determining whether a larger conductor
23 would be more cost-effective due to the value of incremental transmission loss
24 reductions (i.e., greater than 1433 kcmil ACSS)? Please provide Hydro One’s view and
25 ask for the IESO’s view.
- 26
27 c) Please provide the name and title of the primary Hydro One engineers that were
28 involved in the development of this project.
- 29
30 d) Please provide the name and title of the primary IESO engineers that were involved in
31 the development of this project.
- 32
33 e) Did Hydro One and the IESO discuss the possibility of upsizing the conductors to cost-
34 effectively reduce transmission losses? If yes, please provide the approximate dates of
35 any such discussions, a summary of what was concluded, and any correspondence on
36 that topic.

1 **Response:**

2 a) No, Hydro One does **not** take this position.

3
4 b) Hydro One's Response

5 Yes, Hydro One is ultimately responsible for determining the cost effectiveness of
6 using a larger conductor within the context of any applicable transmission project
7 where the need parameters have been established. This holds true even when factoring
8 in specific considerations, such as the impact of different conductor/s on line loss
9 reductions.

10
11 *This part of the response to part b), has been provided by the IESO.*

12
13 IESO Response

14 Please refer to Exhibit I, Tab 3, Schedule 6, part b), for the IESO's view

15
16 c) The names of the Hydro One employees are not pertinent and are out of scope of this
17 proceeding.

18
19 d) The names of the IESO employees are not pertinent and are out of scope of this
20 proceeding.

21
22 e) Hydro One provided the IESO with a list of 230kV conductors that Hydro One
23 currently utilizes on the transmission system and their associated ampacities. The
24 discussions between Hydro One and the IESO resulted in the recommendation to use
25 the 1,433 kcmil ACSS conductor because the Hydro One standard ACSR conductors
26 are not able to meet the ampacity rating requested by the IESO of 2,000A (please see
27 Table 1, below, that illustrates this conclusion).

28
29 Hydro One and IESO did not discuss the possibility of upsizing the 1,433 kcmil ACSS
30 conductor to cost effectively reduce transmission losses, because any kcmil ACSS
31 conductor greater than 1,433kcmil would require at a minimum, further tower
32 reinforcement/modifications, and/or additional towers to provide appropriate overhead
33 line clearances. Therefore Hydro One considered the use of a larger size ACSS
34 conductor and ruled it out as uneconomical. Given this conclusion it was not discussed
35 as a viable option with the IESO.

1 Please refer to Table 1 below for more information regarding the conductor types
2 considered and their ampacity/size characteristics.

3
4

Table 1 - Conductor Ampacity Comparison - by Size and Type

Size (kcmil)	1443	1780	1433	1730
Type	ACSR	ACSR	ACSS	ACSS
Ampacity (A)	1530	1720	2000	2245
Conductor Meets the IESO Ampacity Requirement?	No	No	Yes	Yes

5
6
7
8
9
10
11

Further information regarding the additional cost and scope of work required to accommodate the larger 1730 kcmil ACSS sized conductor is provided in Exhibit I, Tab 3, Schedule 3. Additionally, at the request of Environmental Defence, at Exhibit I, Tab 3, Schedule 4, an NPV was performed on the incremental project costs for the larger conductor (1730 kcmil ACSS) that is capable of providing the ampacity rating required by the IESO.

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #3**

2
3 **Reference:**

4 Exhibit B-3-1, p. 8

5
6 **Preamble:**

7 “Several transmission alternatives were considered that can provide increases in the FETT
8 capacity.

9
10 Those options were narrowed down to two options that meet the following two criteria:

- 11 • Can be in-service before the summer 2026.
12 • Provide an increase in transfer capability of at least 2,250 MW in 2026
13 assuming all transmission elements in service.

14
15 At the development phase of the project, numerous conductors were considered for
16 upgrading the Trafalgar TS x Richview TS lines. It was concluded that the use of 1433
17 kcmil ACSS would provide the required planning summer long term emergency (LTE)
18 rating of 2000 A. It is a high-temperature compact conductor that allows the required rating
19 without involving significant tower modifications. The existing line includes 795 kcmil
20 ACSR and 1307 kcmil ACSR conductors. The reduction in the resistance, hence reduction
21 in line losses, will be about 44% for the sections with 795 kcmil ACSR and about 8% for
22 the sections with 1307 kcmil ACSR.”

23
24 **Interrogatory:**

25 a) Please provide a list of the type and size of conductors that would also result in an
26 increase in transfer capability of at least 2,250 MW in 2026 assuming all transmission
27 elements in service (aside from 1433 kcmil ACSS). Presumably this will include a
28 variety of larger conductors.

1 b) Please estimate the cost of the project based on the various potential conductors that
 2 would meet the required transfer capability (at least 2,250 MW assuming all
 3 transmission elements in service) and include those estimates in the following table:
 4

Conductor Alternatives – Capital Cost Comparison	
	Total Capital Cost
Conductor 1: 1433 kcmil ACSS	\$56.3 million
Conductor 2:	
...	
Conductor n	

5
 6 c) To assist us in determining whether a more detailed transmission loss analysis is
 7 unnecessary, please estimate annual transmission losses that would result from the
 8 various potential conductors that would meet the required transfer capability (at least
 9 2,250 MW assuming all transmission elements in service) and include those estimates
 10 in the following table. Please estimate the losses as if the lines were fully loaded
 11 24/7/365. Note that this request is intended to assist in screening and is not a forecast.
 12

Conductor Alternatives – Annual Transmission Loss Comparison for Screening	
	Estimated Transmission Loss
Conductor 1: 1433 kcmil ACSS	X kwh
Conductor 2	Y kwh
...	...
Conductor n	

13
 14 d) To assist us in determining whether a more detailed transmission loss analysis is
 15 unnecessary, please calculate the cost of the transmission losses set out in part (c) above
 16 at \$120/MWh and provide the results in the following table:
 17

Conductor Alternatives – Annual Transmission Loss Value (for Screening Only)	
	Estimated Transmission Losses Value
Conductor 1: 1433 kcmil ACSS	\$X
Conductor 2	\$Y
...	...
Conductor n	

1 e) Please estimate annual transmission losses that would result from the various potential
 2 conductors that would meet the required transfer capability (at least 2,250 MW
 3 assuming all transmission elements in service) and include those estimates in the
 4 following table. Please estimate the losses based on historic load data of Hydro One’s
 5 choosing and make and state all necessary assumptions.
 6

Conductor Alternatives – Annual Transmission Loss Comparison	
	Estimated Transmission Losses
Conductor 1: 1433 kcmil ACSS	X kwh
Conductor 2	Y kwh
...	...
Conductor n	

7
 8 f) Please estimate annual transmission losses assuming the load increases by 2% annually
 9 over 40 years starting from the amount listed in (e).
 10

Conductor Alternatives – Transmission Loss Comparison – 40 Years			
	Estimated Annual Transmission Losses		
	Year 1	...	Year 40
Conductor 1: 1433 kcmil ACSS	X kwh		
Conductor 2	Y kwh		
...	...		
Conductor n			

11
 12 g) Please estimate the value of transmission losses listed in (f) based on the avoided cost
 13 figures published by the IESO as part of its latest Annual Planning Outlook and provide
 14 the results in the following table:
 15

Conductor Alternatives – Transmission Loss Value – 40 Years			
	Estimated Annual Transmission Losses Value		
	Year 1	...	Year 40
Conductor 1: 1433 kcmil ACSS	\$X	...	
Conductor 2	...		
...			
Conductor n			

1 h) Please provide the equations necessary to determine the losses along the line in question
2 based on the various conductor options that would meet the required transfer capability
3 (at least 2,250 MW assuming all transmission elements in service). Please include a
4 function to determine the losses based on the load (MW).

5
6 i) For the most recent year with available data, please provide a live excel spreadsheet
7 showing the load on the line (MW) and the transmission losses on the line (MW) for
8 every hour in that year. For that same year, please also provide HOEP for every hour
9 in the year.

10
11 **Response:**

12 a) Any ACSS conductor with a size larger than 1433 kcmil would result in a capacity
13 increase of at least 2,250 MW. However, the conductor properties need to be carefully
14 evaluated to ensure that apart from the ampacity requirements, the conductor has the
15 necessary strength to be strung on the existing towers (otherwise considerable addition
16 costs would be required to accommodate a heavier conductor on the towers). For this
17 reason, there were only two conductor sizes considered. For comparative purposes,
18 Hydro One has provided information pertaining to the 1730 kcmil ACSS conductor,
19 because this kcmil conductor is the closest diameter size to the Hydro One 1780 kcmil
20 ACSR which it uses in standard applications¹.

21
22 Hydro One has only considered the ACSS-type conductors for this project because the
23 ACSR-type conductors of a specification (i.e. size) that would be required to meet the
24 IESO capacity (of 2250MW) would require Hydro One to perform extensive tower
25 modifications/reinforcement and/or rebuilding new towers to accommodate the added
26 weight of higher capacity ACSR conductor required.

27
28 b) As mentioned in part a) above, Hydro One has only considered the 1730 kcmil ACSS
29 conductor for comparative purposes. Costs for the project that would utilize the 1730
30 kcmil conductor are provided below in Table A. The higher project cost is due to the
31 additional modifications that would be required to the existing towers, and/or additional
32 new towers beyond that proposed for the 1433 kcmil RTR Project.² The larger and
33 heavier 1730 kcmil conductor would necessitate the construction of additional new

¹ The reason Hydro One has not provided 1780 kcmil ACSR information, is because the ACSR-type conductor in that size does not meet the ampacity requirements,

² Please refer to Exhibit I, Tab 3, Schedule 5 for a cost comparison between the level of tower-related costs required for each of the two alternatives.

1 towers along the circuit pathway, and the various additional new accessory costs of
 2 connecting the conductor, in addition to increased labour and equipment effort to
 3 support an expanded the scope (for example, additional temporary access roads and
 4 crane pads for the new towers, combined with greater inherent interest, overhead and
 5 potential increased contingency), resulting from the cost of a the larger and heavier
 6 1730 kcmil reconductoring option. For these cost-inhibitive reasons any larger capacity
 7 conductor/s sizes beyond the 1730 kcmil were not assessed. Hydro One is providing
 8 the below information in the form requested by Environmental Defence for the
 9 proposed Project conductor size/type and the single alternative. Further options are not
 10 considered feasible, or appropriate.

11
 12
 13
 14

Table A below provides the cost comparison:

Table A

Conductor Alternatives – Capital Cost Comparison	
	Total Capital Cost
Conductor 1: 1433 kcmil ACSS	\$60.9 million
Conductor 2: 1730 kcmil ACSS	\$79.0 million

15
 16
 17
 18
 19
 20

c) The MWh loss for the 1433 kcmil ACSS conductor and the 1730 kcmil ACSS conductor assuming the maximum forecast flow as occurring 24/7/365 are given below in Table B:

Table B

Conductor Alternatives – Annual Transmission Loss Comparison for Screening	
	Estimated Transmission Loss
Conductor 1: 1433 kcmil ACSS	91179 MWh (peak losses = 10.41 MW)
Conductor 2: 1730 kcmil ACSS	76421 MWh (peak losses = 8.72 MW)

21
 22
 23
 24
 25

d) The cost of the transmission losses assuming peak flows 24/7/365 based on \$120/MWh are provided below in Table C:

Table C

Conductor Alternatives – Annual Transmission Loss Value (for Screening Only)	
	Estimated Transmission Losses Value
Conductor 1: 1433 kcmil ACSS	91179 MWh @ \$120MWh = \$10,941,495
Conductor 2: 1730 kcmil ACSS	76421 MWh @ \$120MWh = \$9,170,474

1 e) The annual losses based on 2020 Flows are given in Table D below:
2

3 **Table D**

Conductor Alternatives – Annual Transmission Loss Comparison	
	Estimated Transmission Losses
Conductor 1: 1433 kcmil ACSS	3908.6 MWh
Conductor 2: 1730 kcmil ACSS	3275.9 MWh

4

5 f) The estimate annual transmission losses assuming the load increases by 2% annually
6 over 40 years starting from the amount listed in Table D of part (e), above, are given in
7 Table E below.

8

9 g) The estimated value of transmission losses calculated as requested in (f) are also
10 provided in Table E below. These are based on the avoided cost figures published by
11 the IESO as part of its latest Annual Planning Outlook (APO³). The APO contains
12 values only to 2040. For the remaining years Hydro One has held the 2040 constant
13 going forward.

³ 2020 IESO Annual Planning Outlook – Link to Report
<https://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Annual-Planning-Outlook>

1 **Table E - Conductor Alternatives – Transmission Loss and Value Comparison⁴ – 40 Years**

No.	Losses (MWh)		IESO Avoided Cost (2020\$/MWH)	Avoided Cost Based on IESO APO		
	1433 kmil ACSS	1730 kmil ACSS		1433 kmil ACSS	1730 kmil ACSS	Difference
0	3908.6	3275.9	\$23	\$89,897.31	\$75,346.30	\$14,551.01
1	4064.9	3407.0	\$23	\$93,225.46	\$78,135.75	\$15,089.71
2	4227.5	3543.2	\$23	\$97,165.05	\$81,437.67	\$15,727.38
3	4396.6	3685.0	\$29	\$125,952.02	\$105,565.11	\$20,386.91
4	4572.5	3832.4	\$27	\$125,394.07	\$105,097.47	\$20,296.60
5	4755.4	3985.7	\$28	\$135,356.56	\$113,447.40	\$21,909.15
6	4945.6	4145.1	\$33	\$163,088.04	\$136,690.20	\$26,397.84
7	5143.4	4310.9	\$32	\$166,452.43	\$139,510.02	\$26,942.41
8	5349.2	4483.3	\$33	\$176,766.21	\$148,154.39	\$28,611.83
9	5563.1	4662.7	\$33	\$183,392.93	\$153,708.48	\$29,684.44
10	5785.7	4849.2	\$36	\$209,642.28	\$175,709.05	\$33,933.23
11	6017.1	5043.1	\$36	\$214,476.74	\$179,760.99	\$34,715.75
12	6257.8	5244.9	\$34	\$214,819.69	\$180,048.43	\$34,771.26
13	6508.1	5454.7	\$35	\$226,081.47	\$189,487.36	\$36,594.12
14	6768.4	5672.8	\$34	\$232,353.15	\$194,743.88	\$37,609.27
15	7039.1	5899.8	\$37	\$262,272.83	\$219,820.69	\$42,452.14
16	7320.7	6135.7	\$38	\$280,517.58	\$235,112.29	\$45,405.28
17	7613.5	6381.2	\$39	\$294,773.02	\$247,060.32	\$47,712.71
18	7918.1	6636.4	\$41	\$325,954.56	\$273,194.73	\$52,759.83
19	8234.8	6901.9	\$44	\$361,167.47	\$302,707.99	\$58,459.48
20	8564.2	7178.0	\$47	\$399,016.01	\$334,430.27	\$64,585.74
21	8906.7	7465.1	\$47	\$414,976.65	\$347,807.48	\$67,169.17
22	9263.0	7763.7	\$47	\$431,575.71	\$361,719.78	\$69,855.94
23	9633.5	8074.2	\$47	\$448,838.74	\$376,188.57	\$72,650.17
24	10018.9	8397.2	\$47	\$466,792.29	\$391,236.11	\$75,556.18
25	10419.6	8733.1	\$47	\$485,463.98	\$406,885.55	\$78,578.43
26	10836.4	9082.4	\$47	\$504,882.54	\$423,160.98	\$81,721.56
27	11269.9	9445.7	\$47	\$525,077.84	\$440,087.42	\$84,990.43
28	11720.7	9823.5	\$47	\$546,080.96	\$457,690.91	\$88,390.04
29	12189.5	10216.5	\$47	\$567,924.19	\$475,998.55	\$91,925.65
30	12677.1	10625.1	\$47	\$590,641.16	\$495,038.49	\$95,602.67
31	13184.2	11050.1	\$47	\$614,266.81	\$514,840.03	\$99,426.78
32	13711.5	11492.1	\$47	\$638,837.48	\$535,433.63	\$103,403.85
33	14260.0	11951.8	\$47	\$664,390.98	\$556,850.98	\$107,540.00
34	14830.4	12429.9	\$47	\$690,966.62	\$579,125.02	\$111,841.60
35	15423.6	12927.1	\$47	\$718,605.28	\$602,290.02	\$116,315.27
36	16040.5	13444.2	\$47	\$747,349.50	\$626,381.62	\$120,967.88
37	16682.2	13981.9	\$47	\$777,243.48	\$651,436.88	\$125,806.59
38	17349.5	14541.2	\$47	\$808,333.21	\$677,494.36	\$130,838.86
39	18043.4	15122.9	\$47	\$840,666.54	\$704,594.13	\$136,072.41
40	18765.2	15727.8	\$47	\$874,293.20	\$732,777.90	\$141,515.31

⁴ Assumes load increase growth of 2% per annum.

1 h) The losses have been determined based on the actual current flow in each circuit.

2

3 Line losses are calculated using the following equation;

4

5
$$\text{Line Losses} = 3 * I^2 R$$

6

7 Where;

8 - I is the current flowing in the line, and

9 - R is the line resistance.

10

11 The current, I, can be calculated from the MW load by using the following formula;

12

13
$$I = \frac{MW}{\sqrt{3} * Voltage}$$

14

15 Annual losses are calculated using the standard assumption that there are
16 8,760 hours in a year.

17

18 i) Please refer to Attachment A to this response for a live model in MS Excel format.

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #4**

2
3 **Reference:**

4 Exhibit B-3-1, p. 8

5
6 **Preamble:**

7 “Several transmission alternatives were considered that can provide increases in the FETT
8 capacity.

9
10 Those options were narrowed down to two options that meet the following two criteria:

- 11 • Can be in-service before the summer 2026.
12 • Provide an increase in transfer capability of at least 2,250 MW in 2026
13 assuming all transmission elements in service.
14

15 At the development phase of the project, numerous conductors were considered for
16 upgrading the Trafalgar TS x Richview TS lines. It was concluded that the use of 1433
17 kcmil ACSS would provide the required planning summer long term emergency (LTE)
18 rating of 2000 A. It is a high-temperature compact conductor that allows the required rating
19 without involving significant tower modifications. The existing line includes 795 kcmil
20 ACSR and 1307 kcmil ACSR conductors. The reduction in the resistance, hence reduction
21 in line losses, will be about 44% for the sections with 795 kcmil ACSR and about 8% for
22 the sections with 1307 kcmil ACSR.”
23

24 **Interrogatory:**

25 a) Please conduct an analysis assessing the cost-effectiveness of upsizing the conductor
26 that compares the incremental costs to the incremental benefits (i.e., reduced
27 transmission losses) over 40 years. Please express the result as an NPV figure. Please
28 provide all the calculations, variables, and assumptions.
29

30 **Response:**

31 a) Using Hydro One’s current evaluation procedures¹, Hydro One determined that the
32 1433 kcmil ACSS conductor option was the preferred option on a cost-benefit basis for

¹ Hydro One’s line losses evaluation processes, and independent evaluation of those, are provided in Hydro One’s 2023-27 transmission rate filing EB-2021-0110, currently before the OEB for approval. The primary Line Loss information references in the 2023-27 Application are; Exhibit B, Tab 2, Schedule 1, Sections 2.3 and Section 2.6, and Attachment #4 to the same Exhibit.

1 ratepayers compared to other alternatives, while still meeting the IESO's requested
2 ampacity capability. Increasing the size of conductor would result in higher costs
3 ultimately levied on ratepayers. Hydro One undertook, at the request of Environment
4 Defence, a 40-year net present value (NPV) analysis that compared the two discussed
5 alternatives, a) 1433 kcmil ACSS and b) 1730 kcmil ACSS, to re-conductor the
6 Trafalgar TS x Richview TS circuits. The incremental NPV result of selecting the larger
7 1730 kcmil ACSS conductor, compared to the preferred option over a 40 year time
8 horizon, yields an incremental negative cost (i.e. additional cost to ratepayers) of
9 \$13.6M² using the IESO-provided HOEP, or an incremental negative cost of \$10.2M³
10 using a \$120/MWH assumption. Both scenario calculations are provided in Tables 1
11 through 4 below. This NPV analysis, ultimately shows that the additional incremental
12 cost of the larger 1730 kcmil ACSS conductor will not be recovered over a 40-year
13 timeframe.

14
15 *[Hydro One notes that the above-requested analysis has yielded the same conclusion*
16 *as Hydro One's analysis. This is similar to the analysis performed and presented in*
17 *the recent OEB-approved⁴ Leave to Construct application for the Hawthorne x*
18 *Merrivale Reconductoring (HMR) Project. In the HMR Project all parties concluded*
19 *that the 1443 kcmil ACSR was the more cost-effective solution, as it pertains to line*
20 *losses, that the higher cost 1780 kcmil ACSR solution, based on cost-benefit analysis.*
21 *In the HRM Application, Environmental Defence's (ED's) consultant filed a NPV*
22 *analysis whereby Hydro One used the same processes as used in this Application to*
23 *evaluate Project's alternatives. ED suggested that the OEB ask Hydro One to improve*
24 *its assessment of project alternatives with respect to transmission line loss evaluation*
25 *and corresponding system wide benefits in future cases⁵. In its finding on this issue*
26 *the OEB stated;*

27
28 *"The OEB does not find this to be necessary in the context of this*
29 *Application. As Hydro One indicated in its reply submission, line loss*
30 *process details and guidelines will be provided in its next transmission rate*
31 *filing application which is expected later in 2021."*⁶

² As per the result of Table 1 below (based on HOEP price provided by the IESO).

³ As per the result of Table 3 below (based on the energy cost of \$120/MWH).

⁴ EB-2020-0265 - Hawthorne x Merrivale Reconductoring Project – Leave to Construct S.92 Application

⁵ EB-2020-0265, Decision and Order Page – April 22, 2021, page 14

⁶ EB-2020-0265, Decision and Order Page – April 22, 2021, pgs., 14,15

1 *As referenced above in footnote #1, Hydro One has now filed that evidence in its*
2 *transmission rate filing, and the line losses information provided is consistent with the*
3 *expectations of the OEB⁷.]*
4

5 Hydro One used the following assumptions when performing the NPV analysis
6 requested. In terms of the incremental cost NPV analysis – between two options: 1433
7 kcmil ACSS vs. 1730 kcmil ACSS conductors, Tables 1 and 2 uses the Hourly Ontario
8 Energy Price (HOEP), and Tables 3 and 4 use an energy cost of \$120/MWH. In terms
9 of the results provided in Tables 1 through 4, below, the following assumptions were
10 used in the NPV analysis requested by ED:

- 11
- 12 1. The cost for the 1433 kcmil ACSS conductor is \$60.9M vs. the cost for 1730
13 kcmil ACSS conductor is \$79.0M, and additional incremental cost of \$18.1M.
 - 14 2. There are no incremental revenues and/or operating and maintenance costs for the
15 larger 1730 kcmil ACSS conductor size, compared to the preferred option.
 - 16 3. Hydro One calculated two incremental cost analysis NPV line loss assessments as
17 described below: as follows;
 - 18 a. The first assessment is based on Hourly Ontario Energy Price (HOEP), as
19 provided by the IESO, and is not subject to inflation.⁸ The results are shown in
20 Table 1 and 2.
 - 21 b. The second assessment is based on the energy cost of \$120/MWH⁹ and the
22 results shown in Tables 3 and 4.
 - 23 4. The discount factor of 5.31% is derived from information contained in Hydro One's
24 OEB-approved Draft Rate Order for cost of capital parameters¹⁰.
 - 25 5. The transmission project capital expenditures are considered Class 47¹¹ assets for
26 tax purposes and the terminal value of the present value of the tax shield after the
27 40 year period is included in the NPV.

⁷ EB-2019-0082 – OEB's Decision and Order, April 23, 2020, pgs. 58,59.

⁸ If Ontario CPI escalation rates are considered, the NPV analysis of the 1730 kcmil ACSS conductor option would result in a change to negative \$12.6M (i.e. incremental costs not recovered).

⁹ Hydro One used \$120/MWH HOEP to be consistent with the value ED asked to be used for the HOEP in Exhibit I, Tab 3, Schedule 3, part d).

¹⁰ EB-2019-0082 - Hydro One Networks' 2020-2022 Transmission Revenue Requirement, Draft Rate Order, May 28, 2020 – Exhibit 1.4 page 1.

¹¹ For tax purposes in Canada, Class 47 assets are a class of Capital Cost Allowance (CCA) for Property acquired after February 22, 2005, that is classified as transmission or distribution equipment.

1 **Table 1 - Incremental Cost NPV Analysis – Between Two Options: 1433 kmil ACSS vs. 1730 kmil ACSS conductors, Page 1**

Incremental analysis comparing two options: 1433 vs. 1730 kmil ACSS conductors (in \$k) For 40 Years Ended December 31st, 2065																							
	Total	Period 0	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046
Incremental Revenue	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental OM&A (Costs) Cost Savings	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Operating Cash Flows	0																						
Income Tax Recovery (Provision)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Operating Cash Flows	0																						
Incremental Capital Expenditures for the upsize to 1730 kmil	-18,100	-18,100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental CCA Tax Shield	4,728	0	384	353	325	299	275	253	233	214	197	181	167	153	141	130	119	110	101	93	86	79	72
Incremental Line Loss Savings	4,757	0	62	61	62	63	66	71	70	70	76	78	86	95	101	115	110	109	112	115	117	120	123
Net Incremental Impact to Ratepayers	-8,614	-18,100	446	414	387	362	341	324	302	284	272	259	252	248	242	245	230	219	213	208	203	199	195
Discount Factor		1.0000	0.9496	0.9017	0.8563	0.8131	0.7721	0.7332	0.6963	0.6612	0.6278	0.5962	0.5661	0.5376	0.5105	0.4848	0.4603	0.4371	0.4151	0.3942	0.3743	0.3554	0.3375
Annual Net Present Value		-18,100	423	373	332	294	263	238	211	188	171	155	143	133	124	119	106	96	88	82	76	71	66
Cumulative Net Present Value for the upsize to 1730 kmil	-13,596	-18,100	-17,677	-17,304	-16,972	-16,678	-16,415	-16,177	-15,966	-15,778	-15,607	-15,453	-15,310	-15,176	-15,053	-14,934	-14,828	-14,733	-14,644	-14,562	-14,486	-14,416	-14,350

2 *Note: This Table uses the Hourly Ontario Energy Price (HOEP)*

1 **Table 2 - Incremental Cost NPV Analysis – Between Two Options: 1433 kmil ACSS vs. 1730 kmil ACSS conductors, Page 2**

Incremental analysis comparing two options: 1433 vs. 1730 kmil ACSS conductors (in \$k)																				
For 40 Years Ended December 31st, 2065																				
	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	Terminal Value
Incremental Revenue	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental OM&A (Costs) Cost Savings	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Operating Cash Flows	0																			
Income Tax Recovery (Provision)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Operating Cash Flows	0																			
Incremental Capital Expenditures for the upsize to 1730 kmil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental CCA Tax Shield	67	61	56	52	48	44	40	37	34	31	29	27	24	23	21	19	18	16	15	103
Incremental Line Loss Savings	126	129	132	134	137	140	143	146	148	151	154	157	160	163	165	168	171	174	177	0
Net Incremental Impact to Ratepayers	193	190	188	186	185	184	183	183	183	183	183	184	184	185	186	187	189	190	192	103
Discount Factor	0.3205	0.3044	0.2890	0.2744	0.2606	0.2475	0.2350	0.2232	0.2119	0.2012	0.1911	0.1815	0.1723	0.1636	0.1554	0.1475	0.1401	0.1330	0.1263	0.1263
Annual Net Present Value	62	58	54	51	48	46	43	41	39	37	35	33	32	30	29	28	26	25	24	13
Cumulative Net Present Value for the upsize to 1730 kmil	-14,288	-14,230	-14,176	-14,125	-14,077	-14,031	-13,988	-13,947	-13,909	-13,872	-13,837	-13,803	-13,772	-13,741	-13,713	-13,685	-13,658	-13,633	-13,609	-13,596

2 *Note: Table 2 uses the Hourly Ontario Energy Price (HOEP)*

1 **Table 3 - Incremental Cost NPV Analysis – Between Two Options: 1433 kmil ACSS vs. 1730 kmil ACSS conductors, Page 3**

Incremental analysis comparing two options: 1433 vs. 1730 kmil ACSS conductors (in \$k) For 40 Years Ended December 31st, 2065																							
	Total	Period 0	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046
Incremental Revenue	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental OM&A (Costs) Cost Savings	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Operating Cash Flows	0																						
Income Tax Recovery (Provision)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Operating Cash Flows	0																						
Incremental Capital Expenditures for the upsize to 1730 kmil	-18,100	-18,100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental CCA Tax Shield	4,728	0	384	353	325	299	275	253	233	214	197	181	167	153	141	130	119	110	101	93	86	79	72
Incremental Line Loss Savings	12,835	0	280	267	262	262	251	255	257	253	281	291	308	332	340	378	352	339	339	339	339	339	339
Net Incremental Impact to Ratepayers	-537	-18,100	664	620	586	561	525	508	489	467	478	472	474	485	481	508	471	449	440	432	424	417	411
Discount Factor		1.0000	0.9496	0.9017	0.8563	0.8131	0.7721	0.7332	0.6963	0.6612	0.6278	0.5962	0.5661	0.5376	0.5105	0.4848	0.4603	0.4371	0.4151	0.3942	0.3743	0.3554	0.3375
Annual Net Present Value		-18,100	631	559	502	456	406	373	341	309	300	282	269	261	246	246	217	196	183	170	159	148	139
Cumulative Net Present Value for the upsize to 1730 kmil	-10,194	-18,100	-17,469	-16,911	-16,408	-15,953	-15,547	-15,174	-14,834	-14,525	-14,225	-13,944	-13,675	-13,414	-13,169	-12,922	-12,705	-12,509	-12,327	-12,156	-11,998	-11,849	-11,711

2 *Note: Table 3 uses the energy cost of \$120/MWH*

1 **Table 4 - Incremental Cost NPV Analysis – Between Two Options: 1433 kcmil ACSS vs. 1730 kcmil ACSS conductors, Page 1**

Incremental analysis comparing two options: 1433 vs. 1730 kcmil ACSS conductors (in \$k)																				
For 40 Years Ended December 31st, 2065																				
	2047	2048	2049	2050	2051	2052	2053	2054	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	Terminal Value
Incremental Revenue	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental OM&A (Costs) Cost Savings	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Operating Cash Flows	0																			
Income Tax Recovery (Provision)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Operating Cash Flows	0																			
Incremental Capital Expenditures for the upsize to 1730 kcmil	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Incremental CCA Tax Shield	67	61	56	52	48	44	40	37	34	31	29	27	24	23	21	19	18	16	15	103
Incremental Line Loss Savings	339	339	339	339	339	339	339	339	339	339	339	339	339	339	339	339	339	339	339	0
Net Incremental Impact to Ratepayers	405	400	395	391	386	383	379	376	373	370	368	365	363	361	359	358	356	355	354	103
Discount Factor	0.3205	0.3044	0.2890	0.2744	0.2606	0.2475	0.2350	0.2232	0.2119	0.2012	0.1911	0.1815	0.1723	0.1636	0.1554	0.1475	0.1401	0.1330	0.1263	0.1263
Annual Net Present Value	130	122	114	107	101	95	89	84	79	74	70	66	63	59	56	53	50	47	45	13
Cumulative Net Present Value for the upsize to 1730 kcmil	-11,581	-11,459	-11,345	-11,238	-11,137	-11,042	-10,953	-10,869	-10,790	-10,716	-10,645	-10,579	-10,517	-10,457	-10,402	-10,349	-10,299	-10,252	-10,207	-10,194

2 *Note: Table 4 uses the energy cost of \$120/MWH*

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #5**

2
3 **Reference:**

4 Reference: Exhibit B-07-01, p. 10

5
6 **Preamble:**

7 “[T]he RTR Project requires tower modifications to accommodate the new heavier
8 conductor. This is expected to include tower reinforcement, including localized steel
9 member replacement and foundational upgrades for increased loading conditions.
10 Additionally, six towers along the route have been identified as needing full replacement.”

11
12 **Interrogatory:**

13 a) Please describe and estimate the cost of the tower modifications that would be required
14 for the various potential conductors that would meet the required transfer capability (at
15 least 2,250 MW assuming all transmission elements in service) and include those in the
16 following table:

17

Conductor Alternatives – Tower Modification Comparisons		
	Description of Tower Modifications	Estimated Cost of Tower Modifications
Conductor 1: 1433 kcmil ACSS		
Conductor 2		
...		
Conductor n		

18
19 **Response:**

20 Table A, below, provides the tower modification description and cost comparatives (less
21 removal costs) between the preferred alternative for the RTR Project (i.e. 1433 kcmil
22 ACSS conductor), vs, a 1730 kcmil ACSS project design/scope option¹.

¹ Refer to Exhibit I, Tab 1, Schedule 3 for the rationale and total project cost comparison underpinning why Hydro One has provided only two conductor/tower project options.

1

Table A - Conductor Alternatives – Tower Modification Comparisons

	Description of Tower Modifications	Estimated Cost of Tower Modifications (\$M)
Conductor 1: Proposed RTR Project 1433 kcmil ACSS	<ul style="list-style-type: none"> • Tower structural steel reinforcement • Temporary crane pads and associated access roads to the crane pads to support steel replacement • Existing concrete foundation modifications • Existing tower mounding • Six tower replacements 	\$16.7
Alternative: Conductor 2: 1730 kcmil ACSS	<ul style="list-style-type: none"> • Additional tower structural steel reinforcement compared to Conductor 1. • Temporary crane pads and associated access roads to the crane pads to support steel replacement • Existing concrete foundation modifications • Existing tower mounding • Ten tower replacements 	\$33.3

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #6**

2
3 **Reference:**

4 Exhibit B-3-1, p. 8

5
6 **Interrogatory:**

7 a) Please provide the capacity the various potential conductors that would meet the
8 required transfer capability (at least 2,250 MW assuming all transmission elements in
9 service) and include those estimates in the following table:

10

Conductor Alternatives – Capacity Comparison	
	Capacity
Conductor 1: 1433 kcmil ACSS	X MW
Conductor 2	
...	
Conductor n	

11
12 b) Please estimate the value of this additional capacity to the electricity system to the
13 extent that it may allow for less costly energy and/or capacity.

14
15 **Response:**

16 The following response has been provided by the IESO.

17
18 a)

19 **Table 1 - Conductor Alternatives – Capacity Comparison**

	Capacity
Conductor 1: 1433 kcmil ACSS	2,250 MW
Conductor 2: 1730 kcmil ACSS	(See Note 1 below)

20
21 Note 1 - The use of 1730 kcmil ACSS would provide a higher FETT transfer capability
22 than that with 1433 kcmil ACSS. The IESO has not carried out the system studies to
23 determine the higher FETT transfer capability. The purpose of the Richview x Trafalgar
24 line upgrade project is to meet the security requirement. The use of 1433 kcmil ACSS will
25 meet this need. The use of 1730 kcmil ACSS would cost approximately \$18M more and,
26 based on the information the IESO has, it would not recommend the use of 1730 kcmil
27 ACSS.

Filed: 2021-10-08

EB-2021-0136

Exhibit I

Tab 3

Schedule 6

Page 2 of 2

- 1 b) The future value of capacity is dependent on the outcome of supply procurement
- 2 decisions. It is inappropriate for the IESO to speculate about the design and outcome
- 3 to its future procurements ahead of those procurements being designed, engaged upon
- 4 with stakeholders, and implemented. Information regarding future IESO procurements
- 5 would be released in accordance with the implementation of those procurements.

1 **ENVIRONMENTAL DEFENCE INTERROGATORY #8**

2
3 **Reference:**

4 Exhibit B-03-01-03, p. 8

5
6 **Preamble:**

7 “Greater flexibility in where supply resources are located is expected to provide greater
8 competition amongst those supply resources and ultimately lead to ratepayer savings.”

9
10 **Interrogatory:**

- 11 a) Please provide an estimate of the value of the ratepayer savings described above. Please
12 do so on a best-efforts basis. An order-of-magnitude estimate is sufficient. Please make
13 and state any assumptions as necessary. If necessary, please ask the IESO for its
14 estimate.
- 15
- 16 b) Please provide a map or maps showing: (i) the approximate area in which supply
17 resources would need to be procured if the project is not built; and (ii) the approximate
18 area in which supply resources can be procured if the project is built. If necessary,
19 please ask the IESO for this information.
- 20
- 21 c) Please describe the kinds and magnitude of supply resources that this project will
22 potentially enable. For example:
- 23 a. Is this likely to enable more wind, storage, or solar assets from western Ontario,
24 and if yes, how much of each?
- 25 b. Is this likely to enable more imports, and if yes, how much from each
26 neighbour?
- 27 c. Is this likely to enable generation from gas fired generation, and if yes, how
28 much?

29
30 **Response:**

31 The following response has been provided by the IESO.

- 32
- 33 a) Please refer to the response Exhibit I, Tab 1, Schedule 2.
- 34
- 35 b) (i) The area considered to be east of FETT includes the areas shown east of the electrical
36 boundary in Map1, below.

1

Map 1 – Map of the Area East of FETT



2

3 b) (ii) If the RTR Project is implemented resources could be sited across the province.

4

5 c) The proposed upgrade to the FETT interface would allow any form of new and existing
6 resources located west of the FETT interface to support the need east of the FETT
7 interface by an additional ~2,000 MW.

1 **ASSOCIATION OF POWER PRODUCERS OF ONTARIO**
2 **INTERROGATORY #1**
3

4 **Reference:**

5 Exhibit B-3-1, Attachment 3
6

7 **Preamble:**

8 In the IESO revenue requirement (EB-2020-0230) the IESO expects to complete the
9 Market Renewal Program (MRP) by 2023. Among other market design changes, the IESO
10 is proposing to change the current two-schedule system to a single schedule system for
11 real-time operation. The result will be the adoption of Locational Marginal Pricing (LMP)
12 in Ontario. The *MRP Energy Stream Business Case* dated October 22, 2019 outlines that
13 the incentives from LMP for siting and operating generation efficiently in constrained
14 zones are a primary benefit of MRP.
15

16 Transmission congestion on the Flow East Towards Toronto (FETT) interface would
17 reasonably be expected to increase LMP prices east of FETT.
18

19 **Interrogatory:**

- 20 a) Please provide any estimates of congestion cost for do-nothing scenario (i.e., the
21 proposed project is not developed) on an annual basis. Please provided a detailed
22 explanation of the assumptions and methodology in preparing congestion costs. Please
23 provide all data sets, financial models, and sources of information used in the analysis.
24
- 25 b) Please provide the IESO’s estimate for annual and monthly average LMP for major
26 nodes and/or zones east of FETT if the project does not proceed. If the IESO has not
27 estimated LMPs east of FETT, please provide an estimate of congestion costs on the
28 FETT interface or provide reasoning why an estimate was not prepared.
29
- 30 c) Please provide the IESO’s estimate for annual and monthly average LMP for major
31 nodes and/or zones east of FETT for all proposed alternatives including the preferred
32 option. If the IESO has not estimated LMPs east of FETT, please provide an estimate
33 of congestion costs on the FETT interface or provide reasoning why an estimate was
34 not prepared.

1 d) Please provide all analyses that compares the economics of the preferred option versus
2 do nothing that include congestion costs on the FETT interface. For example, the
3 preferred project cost is estimated by Hydro One to be \$60.9 million dollars (Exhibit
4 B-1-1). Please show the amount of congestion cost savings expected for the project
5 costs. Please provide all data sheets, financial models, and sources of information used
6 in the analysis.

7
8 e) Please describe how LMP would be incorporated into the procurement mechanisms. If
9 LMP was not incorporated, please provide an explanation why LMP was ignored with
10 reference to qualitative and quantitative benefits set out in the IESO's *MRP Energy*
11 *Stream Benefits Case*.

12
13 **Response:**

14 The following response has been provided by the IESO.

15
16 a) A do-nothing scenario is not an acceptable option for 2026 when Pickering GS retires.
17 The proposed reconductoring project is required to meet North American reliability
18 standards requirements as set out in NERC TPL-001 and NPCC Directory #1. The
19 west-to-east transfer capability of the FETT transmission interface plus the capacity
20 from resources located east of FETT needs to be sufficient to supply the demand east
21 of FETT in manner meeting the above criteria. If the proposed reconductoring project
22 was not developed, the IESO would need to acquire approximately 2,000 MW of new
23 resources located east of FETT by 2026 to be compliant with its reliability obligations.
24 The IESO has concluded that successfully acquiring approximately 2,000 MW of new
25 resources east of FETT by 2026 represents an unacceptable risk. This RTR Project is
26 being recommended to address this reliability risk. It is not being recommended to
27 reduce congestion costs and, hence, calculating locational marginal prices and
28 congestion costs isn't necessary nor possible before the go-live of Market Renewal in
29 November 2023.

30
31 b) Please see response to question (a).

32
33 c) Please see response to question (a).

34
35 d) Please see response to question (a).

36
37 e) Please see response to question (a).

1 **ASSOCIATION OF POWER PRODUCERS OF ONTARIO**
2 **INTERROGATORY #2**

3
4 **Reference:**
5 Exhibit B-3-1, Attachment 3
6

7 **Preamble:**
8 Section 3.2 of the IESO’s June 12, 2021 report entitled *Trafalgar TS x Richview TS 230 kV*
9 *line upgrade: Need and Selection of the Preferred Plan* (the “**Report**”) states “[w]hen
10 acquiring new supply to meet the provincial need for capacity, it may be possible to run
11 the capacity auction and resource procurements with a requirement to locate approximately
12 2,000 MW east of the FETT interface by 2026. The IESO is aware of some interest in
13 developing new supply east of the interface and imports from Quebec and New York [*sic.*]
14 could provide some of that supply; however, the amount we’re aware of isn’t enough to
15 meet the approximately 2,000 MW need and/or it is unclear whether or not it can be
16 developed/acquired in 2026. Hence, there is significant uncertainty and risk in being able
17 to obtain a sufficient amount of new supply resources east of FETT by 2026.”
18

- 19 **Interrogatory:**
- 20 a) Please provide a detailed description of the IESO’s outreach strategy to supply resource
21 developers and existing operators as part of its system need assessment and alternative
22 solution options. If the IESO did not engage directly with resource developers, please
23 provide a detailed explanation of why and how the IESO reached its conclusion of
24 insufficient interest?
25
 - 26 b) Please provide a list of entities and market participants engaged by the IESO in
27 determining interest in developing new supply resources east of the interface. If the
28 IESO cannot provide that information, please provide a count of IESO’s
29 meetings/correspondence with resource operators and resource developers.
30
 - 31 c) Please provide a summary of interest in developing new supply east of the FETT
32 interface by:
 - 33 i. Resource type (e.g., gas-fired generation, solar generation, wind generation, energy
34 storage, imports, hydroelectric generation, nuclear generation, demand response)
 - 35 ii. Expansions of existing facilities including uprates and new capacity expansions

- 1 iii. Magnitude of resource development capabilities (i.e., capacity and annual energy
2 production)
3
- 4 d) Please provide details of all revenue mechanisms considered by the IESO in its
5 assessment of alternative solutions. Please clearly describe and identify the
6 procurement and revenue mechanisms and models used by the IESO to assess the cost
7 and uncertainty associated with alternative solutions. For example, responses should
8 identify any assumptions and details relating to revenues assumed by the IESO to be
9 available through market mechanisms (e.g., capacity, energy, ancillary services) as well
10 as through out-of-market mechanisms (e.g., out-of-market payments, programs,
11 contracts).
12
- 13 e) Did the IESO include assumptions relating to the cost and availability of capital (debt
14 and equity) when exploring and modeling procurement mechanisms and revenue
15 models that could be used to compensate proponents capable of providing alternative
16 solutions? If so, please identify the source and basis of inputs and assumptions used to
17 determine availability and cost of capital. If not, please identify reasons why this
18 analysis was not undertaken when considering the viability of alternative solutions.
19
- 20 f) Did the IESO explore continued operation of Pickering NGS beyond the current end-
21 of-life of 2024/2025?
22
- 23 g) Please provide a detailed development timeline the IESO used in its assumption that
24 new capacity could not be developed by 2026.
25
- 26 h) Please provide all IESO records (including draft reports, notes, emails, internal and
27 external meeting materials, etc.) of its consideration and/or evaluation of existing and
28 possible new capacity supply resources east of the FETT interface.
29
- 30 i) Please provide all IESO records (including draft reports, notes, emails, internal and
31 external meeting materials, etc.) of its consideration and/or evaluation of possible
32 imports from Quebec and New York to satisfy the identified ~2,000 MW need.
33
- 34 j) Please provide all IESO records (including draft reports, notes, emails, internal and
35 external meeting materials, etc.) relied upon to reach its conclusion that “the amount
36 we’re aware of isn’t enough to meet the approximately 2,000 MW need and/or it is
37 unclear whether or not it can be developed/acquired in 2026”.

1 **Response:**

2 The following response has been provided by the IESO.

- 3
- 4 a) The IESO relied upon its knowledge of the market and did not undertake specific
5 outreach to supply resource developers and existing operators on this matter. The
6 system need east of FETT that will arise due to the Pickering GS retirement has been
7 communicated to the marketplace, including in the IESO's 2020 Annual Planning
8 Outlook¹, and should be well known to resource developers and existing operators.
9 Despite the publicized need, the IESO was not, and is not, aware of planned projects
10 that are in a sufficiently advanced stage of development that could, individually or
11 collectively, meet the approximately 2,000 MW need east of FETT by 2026. There are
12 no projects east of FETT with completed System Impact Assessments nor, to the
13 IESO's knowledge, are there projects east of FETT with ongoing public/Indigenous
14 consultations. Further, the IESO's Capacity Auction² design is currently unable to
15 accommodate import volumes of this magnitude.
- 16
- 17 b) The IESO provides supply resource developers and existing operators with various
18 forums and ad hoc opportunities to engage with the IESO. As noted in response to part
19 a), above, the IESO has communicated the system need east of FETT by 2026 to the
20 marketplace and did not undertake specific outreach to supply resource developers and
21 existing operators.
- 22
- 23 c) The interest for resources developments includes gas-fired generation, nuclear
24 generation, and storage facilities. Some of these involve large capacity, but most of
25 these are at a preliminary stage. None of the proponents for these projects indicated an
26 in-service date of 2026 or earlier.
- 27
- 28 d) The IESO did not consider potential procurement and revenue mechanisms in making
29 its determination of need. As detailed in response to part a), above, the IESO is not
30 aware of planned projects that are in a sufficiently advanced stage of development that
31 could, individually or collectively, meet the approximately 2,000 MW need east of
32 FETT by 2026. This assessment would not have been affected by considering different
33 potential procurement and revenue mechanisms.

¹ <https://www.ieso.ca/en/Sector-Participants/Planning-and-Forecasting/Annual-Planning-Outlook>

² <https://www.ieso.ca/en/Sector-Participants/Market-Operations/Markets-and-Related-Programs/Capacity-Auction>

- 1 e) No. Please see the responses to parts a) and d), above.
2
3 f) The IESO has not considered the continued operation of Pickering GS beyond the
4 current end-of-life of 2024/2025 as such information has not been provided by the
5 facility owner.
6
7 g) The IESO did not utilize a generic development timeline in its assessment. As detailed
8 in response to part a), above, the IESO is not aware of any projects that are in an
9 advanced stage of development and could, individually or collectively, provide it with
10 the degree of comfort necessary to meet the approximately 2,000 MW need east of
11 FETT by 2026.
12
13 h) The IESO will not provide the requested records as they are not relevant or proportional
14 to the issues before the OEB. Please see the response to question a) for the basis of the
15 IESO's assessment.
16
17 i) Please see the response to question h).
18
19 j) Please see the response to question h).

1 **ASSOCIATION OF POWER PRODUCERS OF ONTARIO**
2 **INTERROGATORY #3**

3
4 **Reference:**

5 Exhibit B-3-1, Attachment 3, page 7 of 13
6

7 **Preamble:**

8 As previously stated, section 3.2 of the Report states that “[t]he IESO is aware of some
9 interest in developing new supply east of the interface and imports from Quebec and New
10 York could provide some of that supply; however, the amount we’re aware of isn’t enough
11 to meet the approximately 2,000 MW need and/or it is unclear whether or not it can be
12 developed/acquired by 2026.”
13

14 Section 3.3 of Report states in part that “[t]here are uncertainties on the capacity level that
15 can be obtained east of FETT through the target capacity auction process and other resource
16 acquisition mechanisms under development.”
17

18 **Interrogatory:**

- 19 a) Please specify the “other resource acquisition mechanisms under development”.
20
21 b) Please provide all IESO records (including draft reports, notes, emails, internal and
22 external meeting materials, etc.) relied upon to reach its conclusion that “[t]here are
23 uncertainties on the capacity level that can be obtained east of FETT through the
24 targeted capacity auction process”.
25
26 c) To the extent they are not provided in response to the above interrogatories, please
27 provide all IESO records (including draft reports, notes, emails, internal and external
28 meeting materials, etc.) relied upon to reach its conclusion that “[t]here are
29 uncertainties on the capacity level that can be obtained east of FETT through ... other
30 resource acquisition mechanisms under development”.
31
32 d) Please identify and delineate which alternative solutions were not pursued due to
33 insufficient capacity and which were not pursued due to lack of clarity as to whether
34 the supply could be developed/acquired by 2026.

- 1 e) Please identify and explain the extent to which procurement models and revenue
2 mechanisms identified in response to 2.1-APPPrO-2 above impacted or influenced
3 determinations of availability and certainty?
4
- 5 f) Please provide a summary of capacity offered east of FETT in the December 2020
6 capacity auction, including the following information:
7 i. Quantity of capacity (MW)
8 ii. Fuel type (e.g., gas-fired generation, energy storage, imports, etc.)
9 iii. Capacity price offered¹
10 iv. Location of capacity offered
11

12 **Response:**

13 The following response has been provided by the IESO.
14

- 15 a) The “other resource acquisition mechanisms under development” are the Mid-Term
16 Request For Proposal (RFP) and the Long-Term RFP that are being considered in the
17 IESO’s Resource Adequacy Engagement. More information on the IESO’s Resource
18 Adequacy Engagement is available on the IESO’s website².
19
- 20 b) The IESO Capacity Auction is limited to demand response, existing resources and
21 imports and cannot supply the volume of capacity needed to meet the identified need.
22 The IESO will not provide the requested records.
23
- 24 c) The IESO has explained the basis for its assessment above in this response and in
25 responses to Exhibit I, Tab 4, Schedules 1 and 2. The IESO will not provide the
26 requested records.

¹ APPrO understands this information may need to be partially redacted or aggregated to maintain commercially sensitive information.

²<https://www.ieso.ca/Sector-Participants/Engagement-Initiatives/Engagements/Resource-Adequacy-Engagement>

- 1 d) The IESO’s assessment of alternative solutions was based both on the amount of
 2 capacity available and whether it could be provided in a timely manner. If the proposed
 3 RTR Project is not developed, the IESO will require approximately 2,000 MW of new
 4 capacity east of FETT by 2026 to be compliant with its reliability obligations. As
 5 explained in response to Exhibit I, Tab 4, Schedule 2, part a), the IESO is not aware of
 6 planned projects that are in a sufficiently advanced stage of development that could,
 7 individually or collectively, meet the approximately 2,000 MW need east of FETT by
 8 2026.
- 9
- 10 e) As explained in response to Exhibit I, Tab 4, Schedule 2, part d), the procurement
 11 models and revenue mechanisms did not influence the IESO’s assessment.
- 12
- 13 f) Please refer to Table 1, below, for a summary of capacity offered east of FETT in the
 14 December 2020 by zone, resource type, and enrolled capacity.
- 15
- 16

Table 1 – Summary of Capacity Offered

Zone	Resource Type	Enrolled Capacity (MW)
East	Virtual Hourly Demand Response	142.9
	Capacity Generation Resource	103
	Physical Hourly Demand Response	18
ESSA	Virtual Hourly Demand Response	51.5
Ottawa	Virtual Hourly Demand Response	66.1
	System-Backed Import Resource	80
	Dispatchable Load Resource	25
Toronto	Virtual Hourly Demand Response	383.8
	Dispatchable Load Resource	72
Northeast	Dispatchable Load Resource	5
	Virtual Hourly Demand Response	57.6
	Capacity Storage Resource	1.7
Northwest	Virtual Hourly Demand Response	2.1

1 **CAPITAL POWER CORPORATION INTERROGATORY #1**
2

3 **Reference:**

4 Exhibit B-3-1, Attachment 3
5

6 **Preamble:**

7 In Section 1 of the IESO's June 12, 2021, report titled *Trafalgar TS x Richview TS 230 kV*
8 *line upgrade: Need and Selection of the Preferred Plan* (the "Report") the IESO states, in
9 part, that supply capacity east of the FETT interface is "expected to decline due to nuclear
10 retirements and nuclear refurbishments, and could potentially decline towards the end of
11 this decade due to contracts for generation facilities reaching the end of their terms."
12

13 The IESO goes on to state that "[t]his decline in supply contributes to an overall provincial
14 need for capacity (see the 2020 Annual Planning Outlook), where due to limitations on the
15 transfer capability of the FETT interface 1850 to 2250 MW of that capacity must be
16 acquired east of the interface by 2026. More specifically, with the decline in supply
17 capacity east of the FETT interface, studies show that the transfer capability of the FETT
18 interface will not be sufficient to meet NERC and NPCC reliability requirements by 2026
19 requiring, approximately 2000 MW of supply to be specifically acquired east of FETT."
20

21 **Interrogatory:**

22 a) Is the 2000 MW an Unforced Capacity (UCAP) value? If so, please provide analysis
23 showing calculations of the total installed capacity required to provide 2000 MW of
24 UCAP for the following resource types: gas-fired generation, energy storage, imports
25 from New York, imports from Quebec, and Demand Response.
26

27 If the 2000 MW is not a UCAP value, please explain what value it does represent and
28 why UCAP was not used.
29

30 b) Please provide in readable format (e.g., .xls, .csv) the hourly load flow estimates for
31 the FETT interface for the years 2024 to 2030 used in the IESO's analysis of system
32 need.
33

34 c) Please provide the FETT loading conditions for normal and contingency operating
35 conditions.

- 1 d) Please indicate the FETT transfer capability for normal and contingency operating
2 conditions.
3
- 4 e) Please identify the expected number of hours and magnitude (i.e., in MW) of constraint
5 used to define system need. Please provide the demand outlook and system conditions
6 underpinning the estimate.
7
- 8 f) Does the forecast used for system need utilize the IESO Annual Planning Outlook
9 Demand Outlook scenario 1 or scenario 2? If neither scenario is used, please describe
10 the scenario used for the IESO's system analysis and provide an explanation why a new
11 demand outlook was required. Please provide assumptions used to generate a new
12 demand outlook.
13
- 14 g) With respect to the IESO's estimate of need for 2000 MW of resources east of FETT,
15 please provide the following operating attributes the IESO expects to the resources to
16 have and/or provide:
17 i. Hours of operation required during constrained time periods
18 ii. Ramping capabilities
19 iii. Locational requirements to resolve system need
20
- 21 h) What forced outage assumptions for existing and committed resources were
22 incorporated in the IESO's analysis estimating a need of 2000 MW of new resources
23 as an alternative to the preferred plan?
24
- 25 i) Did the IESO perform a probabilistic analysis assessing the frequency and duration of
26 coincident forced outages for existing generation and transmission across the FETT
27 interface? If so, please provide details and findings of the probabilistic analysis and
28 explain whether the analysis aligned with the *Ontario Resource and Transmission*
29 *Assessment Criteria* ("ORTAC") for load restoration. If the analysis was not
30 performed, please explain why it was not undertaken.

1 **Response:**

2 The following response has been provided by the IESO.

- 3
- 4 a) Unforced capacity is applicable to resource adequacy requirements. The east of FETT
5 need is based on transmission security requirements. Transmission security
6 requirements are governed by NERC TPL-001 and Table 1 of NPCC Directory #1.
7 Transmission security assessment is not an hourly analysis. It is a deterministic analysis
8 that compares the demand at peak demand periods against the available resources east
9 of FETT and the established FETT transfer capability. Installed capacity available
10 during summer peak plus any firm import was used in the FETT transmission security
11 assessment. This assessment does not consider generation forced outages. However,
12 due to the nature of resources, historical hydroelectric generation output and reduced
13 values for variable generation, such as wind and solar, are used.
- 14
- 15 b) Please refer to the response in part a), above.
- 16
- 17 c) The flow levels for the FETT transmission security tests for year 2026 are: 6,460 MW
18 for all elements in-service and 4,780 MW with one critical element out of service.
19 These are for APO 2020 demand forecast S1.
- 20
- 21 d) The FETT transfer capability for year 2026 is: 4,230 MW for all element in-service and
22 2,580 MW for one critical element out of service.
- 23
- 24 e) Please see response to part c), above.
- 25
- 26 f) The IESO Annual Planning Outlook Demand Outlook Scenario 1 and Scenario 2 were
27 used.
- 28
- 29 g) For the purposes of recommending the RTR Project it wasn't necessary to determine
30 these detailed resource attributes.
- 31
- 32 h) Please refer to the response in part a), above.

- 1 i) As indicated above, transmission security requirements are based on deterministic
- 2 performance criteria. The analysis is aligned with the Ontario Resource and
- 3 Transmission Assessment Criteria (“ORTAC”)¹ but the nature of the FETT interface
- 4 study does not consider load restoration.

¹ <https://www.ieso.ca/-/media/Files/IESO/Document-Library/Market-Rules-and-Manuals-Library/market-manuals/connecting/IMO-REQ-0041-TransmissionAssessmentCriteria.pdf>

1 **CAPITAL POWER CORPORATION INTERROGATORY #2**
2

3 **Reference:**

4 Exhibit B-3-1, Attachment 3
5

6 **Preamble:**

7 Section 1 of the IESO’s Report states, in part, that supply capacity east of the FETT
8 interface is “expected to decline due to nuclear retirements and nuclear refurbishments, and
9 could potentially decline towards the end of this decade due to contracts for generation
10 facilities reaching the end of their terms.”
11

12 Section 3 of the IESO’s Report states that “[a]s indicated in the 2020 Annual Planning
13 Outlook, in addition to this specific need for capacity east of the FETT interface, there is
14 an overall need for capacity in Ontario due to increasing demand for electricity and the
15 retirement of Pickering GS combined with nuclear unit outages for refurbishment. For the
16 year 2026, that amount was determined to be about 5,200 MW after re-acquiring Lennox
17 GS and 3400 MW assuming all other resources with expiring contracts in the province are
18 re-acquired.”
19

20 **Interrogatory:**

- 21 a) Please identify what assumptions the IESO relied on with respect to the continued
22 operation of existing generation facilities for the purpose of assessing the alternative
23 options and the preferred option.
24
- 25 b) Has the IESO has determined that under both demand scenarios considered in the
26 Annual Planning Outlook that the resource adequacy need for the years 2026 to 2040
27 exceeds 2000 MW? If additional demand scenarios were used in the IESO’s analysis
28 of the preferred and alternative options, please confirm whether the resource adequacy
29 need exceeds 2000 MW under the additional demand scenarios.
30
- 31 c) In its assessment of alternative solutions, did the IESO value the ability of new supply
32 resources to solve both the provincial capacity need and needs related to the FETT
33 interface constraint? If yes, please provide details of the valuation methodology
34 including details of the analysis, data and assumptions used to inform the analysis. If
35 no, please explain why the IESO declined to undertake this analysis.

1 **Response:**

2 The following response has been provided by the IESO.

- 3
- 4 a) The figures in Table 2 of the IESO Report show the raw need – without the
5 reacquisition of resources after their contract term. However, continued operation of
6 Lennox GS at least to 2026 was assumed for the purpose of assessing the alternative
7 options and the preferred option.
- 8
- 9 b) The need for capacity east of FETT in 2026 would be 2,250 MW under Scenario 1 and
10 1,800 MW under Scenario 2 as indicated in Exhibit B, Tab 3, Schedule 1, Attachment
11 3, page 5 of the IESO’s need evidence. No other demand scenario was used for the
12 transmission security assessment.
- 13
- 14 c) As explained in response to Exhibit I, Tab 4, Schedule 2, part a), the proposed
15 reconductoring project is required to meet North American reliability standards
16 requirements as set out in NERC TPL-001 and NPCC Directory #1. The reliability
17 standards require a pass or fail deterministic assessment and are not based on an
18 assessment of value.