



Bonnie Jean Adams  
Regulatory Coordinator  
Regulatory Affairs

tel 416 495 5499  
egdregulatoryproceedings@enbridge.com

Enbridge Gas Distribution  
500 Consumers Road  
North York, Ontario M2J 1P8  
Canada

**VIA COURIER**

June 18, 2018

**RECEIVED**

**JUN 20 2018**

**ONTARIO ENERGY BOARD**

Ms. Kirsten Walli  
Ontario Energy Board  
P.O. Box 2319  
2300 Yonge Street, 26th Floor  
Toronto, ON M4P 1E4

**Re: Enbridge Gas Distribution Inc. ("Enbridge")  
Ontario Energy Board ("Board") File No.: EB-2018-0096  
Liberty Village Pipeline Project – Updated Application and Evidence**

Further to Enbridge's submission dated June 14, 2018 in the above noted proceeding, enclosed please find two copies of Exhibit D, Tab 1, Schedule 3, page 3. The paper copy provided to the OEB was inadvertently missing this page.

Please contact the undersigned if you have any questions.

Sincerely,

Bonnie Jean Adams  
Regulatory Coordinator

<u>Pipe</u>	<u>Pipe - NPS 4</u>	<u>Units</u>
Material	Polyethylene	
Diameter	114.3	mm
Wall Thickness	10.38	mm
Grade	SDR 11	
Specification	CSA B137.4	
Material Toughness	N/A	
Pipe Coating Specifications	N/A	
Cathodic Protection	N/A	
Cathodic Specification	N/A	
Class Location	4	
Design Pressure	440	kPa
Hoop Stress at Design Pressure	n/a	
Maximum Operating Pressure (MOP)	380	kPa
Hoop Stress at MOP	n/a	
Minimum Cover	0.9	metre
Fittings	CSA B137.4	
Flanges	N/A	
Valves	CSA B137.4	
Test Medium	Nitrogen or Air	
Test Pressure	700	kPa
Hoop Stress at Test Pressure	n/a	

<u>Pipe</u>	<u>Pipe - NPS 4</u>	<u>Units</u>
Material	Polyethylene	
Diameter	114.3	mm
Wall Thickness	10.38	mm
Grade	SDR 11	
Specification	CSA B137.4	
Material Toughness	N/A	
Pipe Coating Specifications	N/A	
Cathodic Protection	N/A	
Cathodic Specification	N/A	
Class Location	4	
Design Pressure	440	kPa
Hoop Stress at Design Pressure	n/a	
Maximum Operating Pressure (MOP)	380	kPa
Hoop Stress at MOP	n/a	
Minimum Cover	0.9	metre
Fittings	CSA B137.4	
Flanges	N/A	
Valves	CSA B137.4	
Test Medium	Nitrogen or Air	
Test Pressure	700	kPa
Hoop Stress at Test Pressure	n/a	