

October 12, 2023

Ontario Energy Board
By electronic filing and e-mail

Attn: Nancy Marconi, Registrar and Board Secretary

Dear Ms Marconi:

Re: EB-2022-0200, EGI 2024 Rebasing – Enbridge Reply Argument Misstatement of GEC Evidence and Argument

At paragraph 68 of the Enbridge reply argument Enbridge cites the GEC Submission, page 7, and Mr. Neme's undertaking, Exhibit J18.7, and states:

"However, in order for a cold climate air source heat pump (ccASHP) to provide 100% of the space heating requirement, the heat demand for the home would have to be less than or equal to 24,000 Btu/hr, as this is the amount of heat noted as being provided by the ccASHPs to which GEC refers."

Enbridge has apparently misunderstood and therefore incorrectly represented the evidence and argument. Both our argument and the undertaking note that the heat pumps referred to provide at least 24,000 BTU/Hr. In fact, all 161 provide more than 24,000 BTU/Hr as the Board can verify by reference to the source Mr. Neme cited, <https://ashp.neep.org/#/>.

Sincerely,



Cc: All parties