

## Hoda Youssef

**From:** Pasquale.Catalano@HydroOne.com  
**Sent:** Monday, March 19, 2018 11:02 AM  
**To:** Hoda Youssef  
**Subject:** RE: Information Request: Hydro One Networks Inc. and Kitchener-Wilmot Hydro Inc.'s Joint application\_[EB-2018-0112]

Hi Hoda,

We apologize for the oversight. In short, there will be one 30-foot pole, one 25 kVa transformer, twenty metres of secondary overhead wire, and sixty-three metres of underground wire.

The Asset Summary documentation that should have been included in Attachment 1, is provided below

### ASSET SUMMARY

Poles	30	35	40	45	50	55	Total	
	1	0	0	0	0	0	1	
Transformers	5	10	15	25	50	75	100	167
	0	0	0	1	0	0	0	0
Primary Wire (metres)	0							
Secondary O/H Wire (Metres)	20							
Secondary U/G Wire (Metres)	63							
Current Transformers	0							
Sentinel Lights	0							
Easements	0							

Please let me know if you have any further questions and/or concerns.

Kind regards,

**Pasquale Catalano**  
Regulatory Advisor, Regulatory Affairs

**Hydro One Networks Inc.**  
483 Bay Street | South Tower | 7th Floor  
Toronto, ON | M5G 2P5  
Tel: 416.345.5405  
Fax: 416.345.5866  
Email: [Pasquale.Catalano@HydroOne.com](mailto:Pasquale.Catalano@HydroOne.com)  
[www.HydroOne.com](http://www.HydroOne.com)

---

**From:** Hoda Youssef [mailto:Hoda.Youssef@oeb.ca]

**Sent:** Monday, March 12, 2018 10:09 AM

**To:** CATALANO Pasquale

**Cc:** Susi Ahlborn

**Subject:** Information Request: Hydro One Networks Inc. and Kitchener-Wilmot Hydro Inc.'s Joint application\_[EB-2018-0112]

**\*\*\* Exercise caution. This is an EXTERNAL email. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\***

Good morning Mr. Catalano,

I am writing to you regarding Hydro One Networks Inc. and Kitchener-Wilmot Hydro Inc.'s Joint application filed with the OEB under file number EB-2018-0112 requesting further amendment to Kitchener-Wilmot Hydro Inc.'s licensed service area, due to the recent identification of one residential customer that was not included in the previous application [EB-2017-0233].

The following information/ document is required in order to complete your application:

1. Provide a description of the assets that are being sold by Hydro One to Kitchener-Wilmot . As this information was not included in the Attachment 1 received.

Review of your application will be resumed upon receipt of the requested information/documents specified above.

Should you have any questions, please do not hesitate to contact me.

Kind regards,  
Hoda

**Hoda Youssef | Licensing & Performance | Consumer Protection & Industry Performance | Ontario Energy Board**  
2300 Yonge Street, 24<sup>th</sup> Floor, Toronto, Ontario, M4P 1E4 | (416) 440-7709 | [hoda.youssef@oeb.ca](mailto:hoda.youssef@oeb.ca) | [www.oeb.ca](http://www.oeb.ca)



This electronic transmission, including any accompanying attachments, may contain information that is confidential, privileged and/or exempt from disclosure under applicable law, and is intended only for the recipient(s) named above. Any distribution, review, dissemination or copying of the contents of this communication by anyone other than the intended recipient(s) is strictly prohibited. If you have received this communication in error, please notify the sender immediately by return e-mail and permanently delete the copy you have received.

Ce message, transmis par courriel, y compris tout fichier joint, peut contenir des renseignements qui sont confidentiels, qui sont protégés par le secret professionnel ou qui ne peuvent être divulgués aux termes des lois applicables et s'adressent exclusivement au(x) destinataire(s) indiqué(s) ci-dessus. La distribution, la diffusion, l'examen ou la reproduction du contenu du courriel par une autre personne que le(s) destinataire(s) voulu(s) sont strictement interdits. Si vous recevez ce message par erreur, veuillez le supprimer définitivement et en aviser l'expéditeur immédiatement par retour du courriel.