

JTM 1 7 2 3 9 4 9 6 0
4 R 4 7 0 7 7 3 0



40 J/9c
3304869
40 J
9c

lev. 5 R 0 5 8 5

The Ontario Water Resources Commission Act

basin 2 3

WATER WELL RECORD

County or District KENT Township, Village, Town or City CHATHAM
Con. XI XI Lot 3 5 Date completed 10 JUNE 69
(day month year)
Address RR 5 DRESDEN

Casing and Screen Record		Pumping Test	
Inside diameter of casing <u>4"</u>	DIVISION OF WATER RESOURCES JUL 9 1969 ONTARIO WATER RESOURCES COMMISSION	Static level <u>8'</u>	
Total length of casing <u>47'</u>		Test-pumping rate <u>20</u> G.P.M.	
Type of screen <u>-</u>		Pumping level <u>12'</u>	
Length of screen <u>-</u>		Duration of test pumping <u>4 hrs</u>	
Depth to top of screen <u>-</u>		Water clear or cloudy at end of test <u>clear</u>	
Diameter of finished hole <u>4"</u>		Recommended pumping rate <u>5</u> G.P.M.	
		with pump setting of <u>30'</u> feet below ground surface	

Well Log		Water Record		
Overburden and Bedrock Record		From ft.	To ft.	Depth(s) at which water(s) found
<u>Top soil</u>		<u>0</u>	<u>2</u>	<u>44 6 46</u> <u>Fresh</u>
<u>Yellow clay</u>		<u>2</u>	<u>7</u>	
<u>Blue clay</u>		<u>7</u>	<u>44</u>	
<u>Sand & gravel</u>		<u>44</u>	<u>46</u>	
<u>Black Shale</u>		<u>46</u>	<u>48</u>	

For what purpose(s) is the water to be used? Drinking
Is well on upland, in valley, or on hillside? upland
Drilling or Boring Firm RW Simpson
Address _____
Licence Number 3475
Name of Driller or Borer RW Simpson
Address Dresden RR 2
Date June 10 1969
RW Simpson
(Signature of Licensed Drilling or Boring Contractor)

