

2008 DSM Input Assumptions - Update November 2008

| Efficient Equipment & Technologies | Base Equipment & Technologies | Load Type | Resource Savings Assumptions | | | | Equipment Life Years | Incremental Cost | | Free Ridership % | | Reference | |
|---|-----------------------------------|-----------|------------------------------|-------------|--------|--------------------|-------------------------|------------------------------|-----------|---------------------|---|--------------------------------------|--|
| | | | Natural Gas | Electricity | Water | Customer Installed | | Contractor Installed | | | | | |
| | | | m3 | kWh | L | | | | | | | | |
| (a) | (b) | (c) | (d) | (e) | (f) | (g) | (h) | (i) | (j) | | (k) | | |
| RESIDENTIAL NEW CONSTRUCTION | | | | | | | | | | | | | |
| 1. Tankless Water Heater | Storage Tank Water Heater | base | 237 | - | - | 20 | - | \$694 | 2% | | Enbridge | updated | |
| 2. Energy Star Home | Home built to OBC 2006 | weather | 1,018 | 1,450 | - | 25 | - | \$4,701 | 5% | | Union and Enbridge - Values to be used for recording completions under current OBC. | updated | |
| RESIDENTIAL EXISTING HOMES | | | | | | | | | | | | | |
| 1a. Enhanced Furnace (ECM only) | Mid-Efficiency Furnace | weather | (65) | 730 | - | 18 | - | \$550 | 15% | | Union and Enbridge | EB-2006-0021 Phase II | |
| 1b. Enhanced Furnace (Furnace only) & High Efficiency Furnace* | Mid-Efficiency Furnace | weather | 385 | - | - | 18 | - | \$650 | 82% | | Union and Enbridge - 65% is the 2007 FR rate. 2008 is 82% and 2009 is 90%. | updated | |
| 2. Faucet Aerator (kitchen, distributed, 1.5 GPM)* | Average existing stock | base | 22 | - | 7,800 | 10 | \$2 | - | 33% / 31% | | Union & Enbridge - Savings per aerator | updated | |
| 3. Faucet Aerator (bathroom, distributed, 1.5 GPM)* | Average existing stock | base | 6 | - | 2,000 | 10 | \$1 | - | 33% / 31% | | Union & Enbridge - Savings per aerator | updated | |
| 4. Low-Flow Showerhead (Per unit, distributed, 1.5 GPM)* | Average existing stock | base | 22 | - | 6,400 | 10 | \$4 | - | 10% | | Union | updated | |
| 5. Low-Flow Showerhead (Per unit, distributed, 1.25 GPM)* | Average existing stock | base | 40 | - | 10,700 | 10 | \$4 | - | 10% | | Union | updated | |
| 6a. Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.0 GPM)* | 2.0 GPM showerhead | base | 33 | - | 8,900 | 10 | - | \$15 | 10% | | Union & Enbridge | updated | |
| 6b. Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.1-2.5 GPM)* | 2.1 -2.5 GPM showerhead | base | 47 | - | 12,400 | 10 | - | \$15 | 10% | | Union & Enbridge | updated | |
| 6c. Low-Flow Showerhead (Per household, installed, 1.25 GPM replacing 2.6 + GPM)* | 2.6 + GPM showerhead | base | 68 | - | 17,500 | 10 | - | \$15 | 10% | | Union & Enbridge | updated | |
| 7. Pipe Insulation | Water Heater w/o pipe insulation | base | 17 | - | - | 15 | \$1 | \$4 | 4% | | Union & Enbridge | EB-2006-0021 Phase II | |
| 8. Programmable Thermostat* | Standard Thermostat | weather | 152 | 26 | - | 15 | \$50 | | 43% | | Union & Enbridge | updated | |
| 9. Tankless Water Heater | Storage Tank Water Heater | base | 237 | - | - | 20 | - | \$694 | 2% | | Enbridge | updated | |
| 10. Reflector Panels | Radiant heat w/o reflector panels | weather | 143 | - | - | 18 | - | \$213 | 0% | | Enbridge | Enbridge 2007-2009 DSM Plan, updated | |
| LOW INCOME | | | | | | | | | | | | | |
| 1. Faucet Aerator (kitchen, distributed, 1.5 GPM) | Average existing stock | base | 22 | - | 7,800 | 10 | \$2 | - | 1% | | Union & Enbridge - Savings per aerator | updated | |
| 2. Faucet Aerator (bathroom, distributed, 1.5 GPM) | Average existing stock | base | 6 | - | 2,000 | 10 | \$1 | - | 1% | | Union & Enbridge - Savings per aerator | updated | |
| 3a. Low-Flow Showerhead (Per household, Installed, 1.25 GPM) | 2.0 GPM showerhead | base | 33 | - | 8,900 | 10 | - | \$15 | 1% / 5% | | Union & Enbridge | updated | |
| 3b. Low-Flow Showerhead (Per household, Installed, 1.25 GPM) | 2.1 -2.5 GPM showerhead | base | 47 | - | 12,400 | 10 | - | \$15 | 1% / 5% | | Union & Enbridge | updated | |
| 3c. Low-Flow Showerhead (Per household, Installed, 1.25 GPM) | 2.6 + GPM showerhead | base | 68 | - | 17,500 | 10 | - | \$15 | 1% / 5% | | Union & Enbridge | updated | |
| 4. Pipe Insulation | Water Heater w/o pipe insulation | base | 17 | - | - | 15 | - | \$4 | 1% | | Union & Enbridge | EB-2006-0021 Phase II | |
| 5. Programmable Thermostat | Standard Thermostat | weather | 152 | 26 | - | 15 | - | \$50 | 1% | | Union & Enbridge | updated | |
| 6. Weatherization | Existing home sample | weather | 1,143 | 165 | - | 23 | - | \$2,600 | 0% | | Union & Enbridge | Enbridge 2007-2009 DSM Plan, updated | |
| COMMERCIAL NEW BUILDING CONSTRUCTION | | | | | | | | | | | | | |
| 1. Condensing Gas Water Heater | Storage Tank Water Heater | base | 1,412 | - | - | 15 | - | \$4,200 | 5% | | Food services application | EB-2006-0021 Phase II | |
| 2. Rooftop Unit | Standard Rooftop Unit | weather | 1,275 | - | - | 20 | - | \$1,250 | 5% | | Union | EB-2006-0021 Phase II | |
| 3. Tankless Water Heater | Storage Tank Water Heater | base | 825 | - | - | 20 | - | \$2,200 | 2% | | Food services application | EB-2006-0021 Phase II | |
| 4a. Infrared Heaters (0 - 49,999 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 312 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 4b. Infrared Heaters (49,9099 - 164,999 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 624 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |

| | | | Resource Savings Assumptions | | | | | | | | | Reference |
|---|---|-----------|------------------------------------|-------------------|---------|-------------------------|--------------------|------------------------------|----------------|---|-----------------------------------|-----------|
| Efficient Equipment & Technologies | Base Equipment & Technologies | Load Type | Natural Gas | Electricity | Water | Equipment Life Years | Incremental Cost | | Free Ridership | Notes | | |
| | | | m3 | kWh | L | | Customer Installed | Contractor Installed | % | | | |
| 4c. Infrared Heaters (>165,000 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 936 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 5a. Demand Control Kitchen Ventilation (0 - 4999 CFM) | Ventilation without DCKV | weather | 3,660 | 7,229 | - | 20 | - | \$5,000 | 5% | Union & Enbridge - Updated for new OBC | updated | |
| 5b. Demand Control Kitchen Ventilation (5000 - 9999 CFM) | Ventilation without DCKV | weather | 5,960 | 22,855 | - | 20 | - | \$10,000 | 5% | Union & Enbridge - Updated for new OBC | updated | |
| 5c. Demand Control Kitchen Ventilation (10000 - 15000 CFM) | Ventilation without DCKV | weather | 10,910 | 40,334 | - | 20 | - | \$15,000 | 5% | Union & Enbridge - Updated for new OBC | updated | |
| 6. Energy Recovery Ventilators (ERV) | Ventilation without ERV | weather | 3.14 m3/CFM | - | - | 15 | - | \$2.50/CFM | 5% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 7. Heat Recovery Ventilators (HRV) | Ventilation without HRV | weather | 2.92 m3/CFM | - | - | 15 | - | \$3.40/CFM | 5% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 8. Condensing Boilers | Non-condensing Boiler (76% estimated seasonal efficiency) | base | 0.0119 m3/BTUH | - | - | 25 | - | \$15.40/10 ³ BTUH | 5% | Union For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 9. Destratification Fans | No destratification fans | weather | 6,205 | -511 | - | 15 | - | \$7,021 | 10% | Union | Substantiation Documents provided | |
| COMMERCIAL EXISTING BUILDINGS | | | | | | | | | | | | |
| 1. Condensing Gas Water Heater | Storage Tank Water Heater | base | 1,412 | - | - | 15 | - | \$4,200 | 5% | Food services application | EB-2006-0021 Phase II | |
| 2a. Faucet Aerator | Average Existing Stock | base | 14 | - | 6,520 | 10 | \$2 | - | 10% | Enbridge program - Savings per aerato | EB-2006-0021 Phase II | |
| 2b. Faucet Aerator (kitchen, distributed, 1.5 GPM)* | Average existing stock | base | 22 | - | 7,800 | 10 | \$2 | - | 10% | Union program - Savings per aerator | updated | |
| 2c. Faucet Aerator (bathroom, distributed, 1.5 GPM)* | Average existing stock | base | 6 | - | 2,000 | 10 | \$1 | - | 10% | Union program - Savings per aerator | updated | |
| 3. High Efficiency Furnace | Mid-Efficiency Furnace | weather | 5.1 per 1000 BTUH furnace capacity | - | - | 18 | - | \$650 | 17.50% | Union - Based on 75,000 BTUH residential application. Scalable m3 from residential base | EB-2006-0021 Phase II | |
| 4. Low-Flow Showerhead (Contractor installed per multi-res. Household). | Average Existing Stock | base | 115 | - | 30,966 | 10 | - | 15 | 10% | Enbridge - Recommended Evaluation Priority | EB-2006-0021 Phase II | |
| 4. Low-Flow Showerhead (Per unit, distributed, 1.5 GPM)* | Average existing stock | base | 22 | - | 6,400 | 10 | \$4 | - | 10% | Union | updated | |
| 5. Low-Flow Showerhead (Per unit, distributed, 1.25 GPM)* | Average existing stock | base | 40 | - | 10,700 | 10 | \$4 | - | 10% | Union | updated | |
| 6 a. Pre-Rinse Spray Nozzle (1.6 GPM) | Average Existing Stock | base | 2,434 | - | 432,800 | 5 | - | \$100 | 5% | Enbridge - Food services application, re | EB-2006-0021 Phase II | |
| 6b. Pre-Rinse Spray Nozzle (1.24 GPM) | Average Existing Stock | base | 3,059 | - | 544,145 | 5 | - | \$100 | 5% | Union & Enbridge - Based on same approved inputs as 1.6 GPM unit to determine appropriate savings | Union 2007 Evaluation Report | |
| 7. Programmable Thermostats | Standard Thermostat | weather | 519 | 921 | 0 | 15 | - | \$50 | 20% | Union & Enbridge - Per building. | updated | |
| 8. Rooftop Unit | Standard Rooftop Unit | weather | 1,275 | - | - | 20 | - | \$1,250 | 5% | Union & Enbridge | EB-2006-0021 Phase II | |
| 9. Tankless Water Heater | Storage Tank Water Heater | base | 825 | - | - | 20 | - | \$2,200 | 2% | Enbridge - Food services application | EB-2006-0021 Phase II | |
| 10a. Enhanced Furnace - up to 299 mbtu/h (ECM only) | Mid-Efficiency Furnace | weather | -0.87 per 1000 BTUH | 9.7 per 1000 BTUH | - | 18 | - | \$550 | 10% | Union & Enbridge - Based on 75,000 BTUH residential application | EB-2006-0021 Phase II | |
| 10b. Enhanced Furnace - up to 299 mbtu/h (furnace only) | Mid-Efficiency Furnace | weather | 5.1 per 1000 BTUH | - | - | 18 | - | \$650 | 30% | Union & Enbridge - Based on 75,000 BTUH residential application | EB-2006-0021 Phase II | |
| 11. Heat Recovery Ventilator (HRV) | Ventilation without HRV | weather | 2.92 m3/CFM | - | - | 15 | - | \$3.40/CFM | 5% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 12. Energy Recovery Ventilator (ERV) | Ventilation without ERV | weather | 3.14 m3/CFM | - | - | 15 | - | \$2.50/CFM | 5% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 13. Condensing Boilers | Non-condensing Boiler (76% estimated seasonal efficiency) | base | 0.0119 m3/BTUH | - | - | 25 | - | \$15.40/10 ³ BTUH | 5% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 14a. Infrared Heaters (0 - 49,999 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 312 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 14b. Infrared Heaters (49,9099 - 164,999 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 624 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 14c. Infrared Heaters (>165,000 BTUH) | Unit Heater | weather | 0.0102 m3/BTUH | 936 | - | 20 | - | \$15.40/10 ³ BTUH | 33% | Union - For use with Union Gas Quasi Tool, Updated for new OBC | Union 2007-2009 DSM Plan | |
| 15a. Demand Control Kitchen Ventilation (0 - 4999 CFM) | Ventilation without DCKV | weather | 3,660 | 7,319 | - | 20 | - | \$5,000 | 5% | Union & Enbridge | Union 2007-2009 DSM Plan | |
| 15b. Demand Control Kitchen Ventilation (5000 - 9999 CFM) | Ventilation without DCKV | weather | 9,535 | 23,180 | - | 20 | - | \$10,000 | 5% | Union & Enbridge | Union 2007-2009 DSM Plan | |

| Resource Savings Assumptions | | | | | | | | | | | |
|---|--|-----------|-------------|-------------|--------|----------------|--------------------|----------------------|---|---|--|
| Efficient Equipment & Technologies | Base Equipment & Technologies | Load Type | Natural Gas | Electricity | Water | Equipment Life | Incremental Cost | | Free Ridership | Notes | Reference |
| | | | m3 | kWh | L | Years | Customer Installed | Contractor Installed | % | | |
| 15c. Demand Control Kitchen Ventilation (10000 - 15000 CFM) | Ventilation without DCKV | weather | 17,455 | 40,929 | - | 20 | - | \$15,000 | 5% | Union & Enbridge | Union 2007-2009 DSM Plan |
| 16a. Air Curtains (Single Door) | | weather | 2,118 | 172 | - | 15 | - | \$1,650 | 5% | Enbridge | Enbridge 2007-2009 DSM Plan - updated |
| 16b. Air Curtains (Double Door) | | weather | 4,508 | 1,023 | - | 15 | | \$2,500 | 5% | Enbridge | Enbridge 2007-2009 DSM Plan - updated |
| 17. Destratification Fans | No destratification fans | weather | 6,205 | -511 | - | 15 | - | \$7,021 | 10% | Union - Minimum ceiling height 25' | Substantiation Documents provided |
| 18. Energy Efficient Washers | Conventional top loading washers. | base | 342 | 306 | 90,790 | 10 | | \$450 | 10% | Enbridge | Enbridge 2007-2009 DSM Plan |
| 19a. Prescriptive Schools (Elementary) | Space Heating, Hydronic Boiler with Comb. Eff. Of 80%-82%. | base | 10,830 | - | - | 25 | | \$8,646 | 100% (net to gross) | Enbridge: net to gross value is consistent with EGD Commercial sector | Substantiation Documents provided |
| 19b. Prescriptive Schools (Secondary) | Space Heating, Hydronic Boiler with Comb. Eff. Of 80%-82%. | base | 43,859 | - | - | 25 | | \$14,470 | 100% (net to gross) | Enbridge: net to gross value is consistent with EGD Commercial sector | Substantiation Documents provided |
| COMMERCIAL/INDUSTRIAL CUSTOM PROJECTS | | | | | | | | | | | |
| 1. Custom Projects | | | Actual | Actual | Actual | Actual | - | Actual | By sector from S.B. Report (dated Oct., 2008) | | |
| Union Gas | | | | | | | | | Free Ridership | | |
| Agriculture* | | | | | | | | | 0% | Union | updated: Summit Blue Custom Projects Attribution Study |
| Industrial* | | | | | | | | | Results from SB Dec'08 Study | Union | |
| Commercial* | | | | | | | | | 59% | Union | updated: Summit Blue Custom Projects Attribution Study |
| Multi-Residential* | | | | | | | | | 42% | Union | updated: Summit Blue Custom Projects Attribution Study |
| New construction* | | | | | | | | | 33% | Union | updated: Summit Blue Custom Projects Attribution Study |
| Enbridge Gas | | | | | | | | | Net to Gross** | | |
| Agriculture | | | | | | | | | 81% | Enbridge | updated: Summit Blue Custom Projects Attribution Study |
| Industrial | | | | | | | | | 71% | Enbridge | updated: Summit Blue Custom Projects Attribution Study |
| Commercial | | | | | | | | | 100% | Enbridge | updated: Summit Blue Custom Projects Attribution Study |
| Multi-Residential | | | | | | | | | 100% | Enbridge | updated: Summit Blue Custom Projects Attribution Study |
| New construction | | | | | | | | | 95% | Enbridge | updated: Summit Blue Custom Projects Attribution Study |
| OTHER MEASURES | | | | | | | | | | | |
| 1. CFL (13W) | 60W Incandescent | n/a | 0 | 45 | 0 | 8 | \$1.75 | | 24% | Enbridge | Substantiation documents provided |
| 2. CFL (23W) | 75W Incandescent | n/a | 0 | 49.7 | 0 | 8 | \$2.00 | | 24% | Enbridge | Substantiation documents provided |

Indicates no input assumption update.

New measure

asterisk*

Spillover values have been developed for these measures and may be applied to 2008 results pending a policy discussion with Union's Consultative..

asterisk**

Net-to-Gross = 1-freeridership + spillover

See also attached Table of Measure Lives

Custom Resource Acquisition Programs

Measure Life Assumptions

October 31, 2008

| | Commercial | Industrial | Multi-residential |
|------------------------------|--------------|--------------|-------------------|
| Boiler Related | | | |
| Boilers – DHY | 25* | n/a | 25* |
| Boilers - Industrial Process | n/a | 20 | n/a |
| Boilers – Space Heating | 25* | 25* | 25* |
| Combustion Tune-up | 5 | 5 | n/a |
| Controls | 15 | 15 | 15 |
| Steam pipe/tank insulation | n/a | 15 | n/a |
| Steam trap | 13*** | 13*** | n/a |
| | | | |
| Building Related | | | |
| Building envelope | 25 | 25 | 25 |
| Windows | 25 | 25 | 25 |
| Greenhouse curtains | na | 10 | na |
| Double Poly greenhouse | n/a | 5 | n/a |
| | | | |
| HVAC Related | | | |
| Dessicant cooling | 15 | n/a | n/a |
| Heat Recovery | 15 | 15 | n/a |
| Infra-red heaters | 10 | 10 | n/a |
| Make-up Air | 15 | 15 | 15 |
| Novitherm panels | 15 | n/a | 15 |
| Furnaces (gas-fired) | 18** | n/a | 18** |
| | | | |
| Process Related | | | |
| Furnaces (gas-fired) | n/a | 18** | n/a |
| | | | |
| | | | |
| | | | |

Source: RP-2002-0133 Settlement Proposal, Ex N1, Tab 1, Schedule 1, page 70.

Also applied to EB-2005-0001.

*updated in RP-2006-0001 – Source: ASHRAE

**new item - Source: ASHRAE updated in EB-2006-0021

*** Source: Measure Life of Steam Traps Research Study, Enbridge Gas Distribution, November, 2007.

TANKLESS WATER HEATERS

Residential New Construction

| Efficient Technology & Equipment Description |
|--|
| Tankless water heater (EF = 0.82) |
| Base Technology & Equipment Description |
| Storage tank water heater (EF = 0.58) |

Resource Savings Assumptions

| Natural Gas | 237 m ³ |
|---|--------------------|
| <p>Natural gas savings claims are based on Exelon Services Report¹. The consumption data was validated by Energy Technology based on the following:</p> <ol style="list-style-type: none"> 1. Hourly gas consumption data for Domestic Hot Water (DHW) from Load Research - 645 m³/year 2. Calculated average efficiency of sample population using data from Natural Resources Canada (NRCAN) - 55% thermal efficiency 3. Calculated average litres of DHW based upon average consumption and efficiencies - 179 L/day 4. Used efficiency figures from the Okaloosa study** - 85.4% for tankless 5. Adjusted energy requirement for colder city water than in Okaloosa - inlet temperature 8°C instead of 23.3°C 6. Calculated gas consumption for tank and tankless water heaters based upon our average DHW usage - 415.9m³/year for tankless versus 645m³/year as provided by load research <p>Assumptions:</p> <ol style="list-style-type: none"> 1. Load Research sample population is representative of Enbridge Gas Distribution (EGD) franchise 2. NRCAN efficiency and market composition data for Ontario adequately approximates the EGD franchise 3. Calculated efficiency is comparable or higher for colder inlet water so using the Okaloosa measured efficiencies for EGD city water temperatures is conservative 4. The load profile for Okaloosa and EGD approximate each other adequately | |
| Electricity | kWh |
| | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 20 Years |
|---|----------|
| Tankless water heaters have an estimated service life of 20 years ² | |
| Incremental Cost (Contractor Installation) | \$694 |
| <p>To validate/update installation costs, research was conducted by the Channel Consultants and Market Development (with manufacturers), across our franchise area to obtain installed costs for both Power Vented 50-gallon tank-type water heaters and tankless water heaters in the residential sector. Twenty-two contractors/installers were contacted to provide installed costs for both types of natural gas water heating; as well one retail outlet was visited to validate installation costs if the water heating equipment were purchased through a big box store.</p> | |

¹ Exelon Services Report, December 2002

² C. Aguilar, D.J. White, and David L. Ryan, "Domestic Water Heating and Water Heater Energy Consumption in Canada", CBEEDAC, April 2005

RESULTS

- This research provided average installed costs of:

| | |
|----------------------------------|--------|
| Power Vented 50-gallon tank type | |
| average installed cost | \$1956 |
| Tankless average installed cost | \$3273 |

- Assuming a purchase of a second conventional tank-type water heater will be required in 12 years*** at a cost in current dollars of approximately \$623 ($= \$1956/[1.1^{12}]$), the incremental cost of a tankless water heater is $\$3273 - \$1956 - \$623 = \694

Free Ridership

2 %

Free ridership rate will remain as filed.

ENERGY STAR FOR NEW HOMES

Residential, New Construction

| Efficient Technology & Equipment Description |
|--|
| Energy Star for New Homes, version 3, qualified home |
| Base Technology & Equipment Description |
| New Home built in Ontario, compliant to OBC-2006 |

Resource Savings Assumptions

| Natural Gas | 1018 m ³ |
|---|---------------------|
| Gas savings is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house ³ with London's climate, and another set in North Bay's climate. The sample houses are three houses which represent the mid-range of new homes built in UG Territory. The results were weighted 70% UG South and 30% UG North. The software used for analysis is HOT2000 version 9.34b. This is the same software that is currently in use for application of the EnerQuality Version 3.0 Energy Star Criteria, which is what's mandatory to evaluate homes for ESNH. A mix of 90% AFUE furnace (weighted 80%) and 80% AFUE combo heater (weighted 20%) was assumed as the base case heating system. The upgrade system was a 92% AFUE. A 3.57 ACH50 air leakage was used to describe the simply OBC-2006 houses (default present in HOT2000), which is representative of average new home construction ⁴ | |
| Electricity | 1450 kWh |
| Electrical savings is based on a simple average of a new reference house, a 1 storey house, and a 2 storey house ³ with London's climate, and another set in North Bay's climate. The sample houses are three houses which represent the mid-range of new homes built in UG Territory. ³ The results were weighted 70% UG South and 30% UG North. The software used for analysis is HOT2000 version 9.34b. This is the same software that is currently in use for application of the EnerQuality Version 3.0 Energy Star Criteria, which is what's mandatory to evaluate homes for ESNH. A 3.57 ACH50 air leakage was used to describe the simply OBC-2006 houses (default present in HOT2000), which is representative of average new home construction ⁴ | |
| Water | n/a L |

Other Input Assumptions

| Equipment Life | 25 years |
|--|----------|
| Energy Star homes have an estimated service life of 25 years (before major renovations are expected). | |
| Incremental Cost (Cust. / Contr. Install) | \$4,701 |
| Cost estimates for the upgrade measures were obtained from HVAC Trades and Builders who are actively building energy star homes. The upgrade costs based on a simple average of a new reference house, a 1 storey house, and a 2 storey house ³ . | |
| Free Ridership | 5 % |
| Free-Ridership rate adjusted during ADR Settlement – September 2006. | |

³ Based on *Comparison of EnergyStar vs. Ontario Building Code 2006 Energy Use*, spreadsheets, from July and August, 2008, by Bowser Technical Inc.

⁴ Conversation with Jennifer Tausman, ESNH files coordinator, NRCAN OEE, July 21, 2008

ENHANCED FURNACE

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| High efficiency furnace with ECM. |
| Base Technology & Equipment Description |
| Mid efficiency furnace w/o PSC. |

Resource Savings Assumptions

| | |
|---|---|
| Natural Gas ECM Only Furnace Only | - 65 m³ 385 m³ |
| Impact on natural gas use from an ECM and the resulting decrease in savings from a high efficiency furnace are based on the Final Report on ECM Motors by the Canadian Centre for Housing Technology. Using the Enbridge high-efficiency furnace savings number of 385m3, the net gas savings are reduced to 320m3. | |
| Electricity ECM Only Furnace Only | 730 kWh 0 kWh |
| Canadian Centre for Housing Technology – Final Report on the Effects of ECM Furnace Motors on Electricity and Gas Use: Results from the CCHT Research Facility and Projections. | |
| Water | n/a L |

Other Input Assumptions

| | |
|--|------------------------------|
| Equipment Life | 18 years |
| Enhanced furnaces have an estimated service life of 18 years. ²⁷ | |
| Incremental Cost (Contractor Install) ECM Only Furnace Only | \$550 \$650 |
| Enhanced furnaces have an estimated incremental cost of \$1200 | |
| Free Ridership (Updated) ECM Only Furnace Only | 15 % 82 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

² “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008

²⁷ ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3

HIGH EFFICIENCY FURNACE

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| High efficiency furnace |
| Base Technology & Equipment Description |
| Mid-efficiency furnace |

Resource Savings Assumptions

| Natural Gas | 385 m ³ |
|--|--------------------|
| Natural gas savings are based on Enbridge research that indicates the average consumption for a mid-efficiency furnace is 2,430 m ³ and 2,045 m ³ for a high efficiency furnace, suggesting annual savings of 385 m ³ as approved in the Decision for the Enbridge 2006 DSM Plan (EB2005-0001). | |
| Electricity | n/a kWh |
| | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 18 years |
|---|----------|
| High efficiency furnaces have an estimated service life of 18 years. ²⁹ | |
| Incremental Cost (Contractor Install) | \$650 |
| The incremental cost is based on a pricing survey of 15 contractors in the Union Gas franchise area. The single incremental cost number is weighted average of Union Gas South (70%) and Union Gas North (30%) average incremental costs. | |
| Free Ridership (Updated) | 82 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008

²⁹ ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3

1.5 GAL/MIN FAUCET AERATOR (Kitchen)

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | 22 m ³ |
|---|-------------------|
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 7,800 L |
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Faucet aerators have an estimated service life of 10 years. ²⁸ | |
| Incremental Cost (Cust. Install) (UG/EGD) | \$2 |
| * Actual cost per unit of product is \$1.49. | |
| Free Ridership (Updated) (UG/EGD) | 33/31 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

²⁸ U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

1.5 GAL/MIN FAUCET AERATOR (Bathroom)

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | 6 m ³ |
|---|------------------|
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 2,000 L |
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Faucet aerators have an estimated service life of 10 years. ²⁸ | |
| Incremental Cost (Cust. Install) (UG/EGD) | \$1 |
| * Actual cost per unit of product is \$0.49. | |
| Free Ridership (Updated) (UG/EGD) | 33/31 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ “Resource Savings Values In Selected Residential DSM Prescriptive Programs”, Summit Blue Consulting, June 2008.

² “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008.

²⁸ U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

1.5 GAL/MIN LOW-FLOW SHOWERHEAD

Residential Existing Homes (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.5 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas | 22 m ³ |
|--|-------------------|
| ¹ Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | |
| Electricity | n/a kWh |
| | |
| Water | 6,400 L |
| ¹ Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Cust. Install) | \$4 |
| * Actual cost per unit of product is \$3.85. | |
| Free Ridership | 10 % |
| ² Free Ridership rate recommended by Summit Blue Consulting, excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

1.25 GAL/MIN LOW-FLOW SHOWERHEAD

Residential Existing Homes (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.25 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas | 40 m ³ |
|--|-------------------|
| ¹ Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | |
| Electricity | n/a kWh |
| | |
| Water | 10,700 L |
| ¹ Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Cust. Install) | \$4 |
| * Actual cost per unit of product is \$3.39. | |
| Free Ridership | 10 % |
| ² Free Ridership rate recommended by Summit Blue Consulting, excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

1.25 GAL/MIN LOW-FLOW SHOWERHEAD

Residential Existing Homes (Installed per Household)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.25 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | | | | | See Below m ³ |
|--|---|---|--------------------------|----------------------------------|--------------------------|
| Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | | | | | |
| Participants to be tracked, and gas savings assigned, as per the following table: | | | | | |
| Scenerio | Flow rate range of old showerhead (gal/min) | "From" flow rate (i.e. midpoint of range) (gal/min) | "To" flow rate (gal/min) | Reduction in flow rate (gal/min) | Gas Savings m3 |
| New Showerhead: Scenario 1 | GT 2.5 | 3.00 | 1.25 | 1.75 | 68.0 |
| New Showerhead: Scenario 2 | GT 2.0 to 2.5 | 2.25 | 1.25 | 1.00 | 47.0 |
| New Showerhead: Scenario 3 | EQ 2.0 | 2.00 | 1.25 | 0.75 | 33.0 |
| Electricity | | | | | n/a kWh |
| | | | | | |
| Water (Updated) | | | | | See Below L |
| Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | | | | | |
| Participants to be tracked, and water savings assigned, as per the following table: | | | | | |
| Scenerio | Flow rate range of old showerhead (gal/min) | "From" flow rate (i.e. midpoint of range) (gal/min) | "To" flow rate (gal/min) | Reduction in flow rate (gal/min) | Water Savings litres |
| New Showerhead: Scenario 1 | GT 2.5 | 3.00 | 1.25 | 1.75 | 17.500 |
| New Showerhead: Scenario 2 | GT 2.0 to 2.5 | 2.25 | 1.25 | 1.00 | 12.400 |
| New Showerhead: Scenario 3 | EQ 2.0 | 2.00 | 1.25 | 0.75 | 8.900 |

Other Input Assumptions

| | |
|--|-----------------|
| Equipment Life | 10 years |
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Contr. Install) (UG/EGD) | \$15 |
| \$5.00 for product, \$10 for installation. | |
| Free Ridership | 10 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

PROGRAMMABLE THERMOSTAT

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| Programmable thermostat |
| Base Technology & Equipment Description |
| Standard manual thermostat |

Resource Savings Assumptions

| Natural Gas (Updated) | 152 m ³ |
|---|--------------------|
| Savings adjustment recommended by auditor, during the Enbridge 2007 Audit. ¹ | |
| Electricity (Updated) | 26 kWh |
| Savings adjustment recommended by auditor, during the Enbridge 2007 Audit. ¹ | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|--|----------|
| Equipment life recommended by Summit Blue Consulting and incorporated in 2008, on agreement with Union Gas 2007 Evaluation Audit Committee. | |
| Incremental Cost (Contr. Install) (UG/EGD) | \$50 |
| Based on average thermostat cost from Union survey of hardware chains. | |
| Free Ridership (Updated) | 43 % |
| Free Ridership rate recommended by Summit Blue Consulting ² , excluding spillover, a value negotiated with the 2007 Evaluation Audit Committee. | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

TANKLESS WATER HEATERS

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| Tankless water heater (EF = 0.82) |
| Base Technology & Equipment Description |
| Storage tank water heater (EF = 0.58) |

Resource Savings Assumptions

| Natural Gas | 237 m ³ |
|---|--------------------|
| <p>Natural gas savings claims are based on Exelon Services Report¹. The consumption data was validated by Energy Technology based on the following:</p> <ol style="list-style-type: none"> 1. Hourly gas consumption data for Domestic Hot Water (DHW) from Load Research - 645 m³/year 2. Calculated average efficiency of sample population using data from Natural Resources Canada (NRCAN) - 55% thermal efficiency 3. Calculated average litres of DHW based upon average consumption and efficiencies - 179 L/day 4. Used efficiency figures from the Okaloosa study** - 85.4% for tankless 5. Adjusted energy requirement for colder city water than in Okaloosa - inlet temperature 8°C instead of 23.3°C 6. Calculated gas consumption for tank and tankless water heaters based upon our average DHW usage - 415.9m³/year for tankless versus 645m³/year as provided by load research <p>Assumptions:</p> <ol style="list-style-type: none"> 1. Load Research sample population is representative of Enbridge Gas Distribution (EGD) franchise 2. NRCAN efficiency and market composition data for Ontario adequately approximates the EGD franchise 3. Calculated efficiency is comparable or higher for colder inlet water so using the Okaloosa measured efficiencies for EGD city water temperatures is conservative 4. The load profile for Okaloosa and EGD approximate each other adequately | |
| Electricity | kWh |
| | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 20 Years |
|---|----------|
| Tankless water heaters have an estimated service life of 20 years ² | |
| Incremental Cost (Contractor Installation) | \$694 |
| <p>To validate/update installation costs, research was conducted by the Channel Consultants and Market Development (with manufacturers), across our franchise area to obtain installed costs for both Power Vented 50-gallon tank-type water heaters and tankless water heaters in the residential sector. Twenty-two contractors/installers were contacted to provide installed costs for both types of natural gas water heating; as well one retail outlet was visited to validate installation costs if the water heating equipment were purchased through a big box store.</p> | |
| <u>RESULTS</u> | |

¹ Exelon Services Report, December 2002

² C. Aguilar, D.J. White, and David L. Ryan, "Domestic Water Heating and Water Heater Energy Consumption in Canada", CBEEDAC, April 2005

- This research provided average installed costs of:

| | |
|----------------------------------|--------|
| Power Vented 50-gallon tank type | |
| average installed cost | \$1956 |
| Tankless average installed cost | \$3273 |

- Assuming a purchase of a second conventional tank-type water heater will be required in 12 years*** at a cost in current dollars of approximately \$623 ($= \$1956/[1.1^{12}]$), the incremental cost of a tankless water heater is $\$3273 - \$1956 - \$623 = \694

| | |
|-----------------------|------------|
| Free Ridership | 2 % |
|-----------------------|------------|

Free ridership rate will remain as filed.

HEAT REFLECTOR PANELS

Residential Existing Homes

| Efficient Technology & Equipment Description |
|--|
| A saw tooth panel made of clear PVC with a reflective surface reducing heat losses behind radiators and convectors located on poorly insulated exterior walls. |
| Base Technology & Equipment Description |
| Existing housing with radiant heat with no reflector panels. |

Resource Savings Assumptions

| Natural Gas (Updated) | 143.2 m ³ |
|---|----------------------|
| Based on a 2008 Enbridge Gas Distribution Load Research Study of boiler sites where the panels were installed. The study concluded that the panels, on average, reduced consumption by 4.1%. A 2006 Enbridge Gas load research study showed that average boiler consumption is 3,978m ³ . A 90% confidence interval for the average resulted in a lower value of 3,493m ³ . Applying the average change in consumption from the panel load research study to the lower value of average boiler consumption resulted in recommended savings of 143.2m ³ . | |
| Electricity | kWh |
| | |
| Water | L |
| | |

Other Input Assumptions

| Equipment Life | 18 years |
|---|----------|
| Based on average space heat measure life. | |
| Incremental Cost (Customer Install) | \$213 |
| | |
| Free Ridership | 0 % |
| Product not currently available to end-use consumers through typical retail channels. | |

1.5 GAL/MIN FAUCET AERATOR (Kitchen)

Low Income (Distributed)

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | 22 m ³ |
|---|-------------------|
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 7,800 L |
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|---|----------|
| Faucet aerators have an estimated service life of 10 years. ²⁸ | |
| Incremental Cost Customer Install | \$2 |
| Actual cost per unit of product is \$1.49. | |
| Free Ridership | 1 % |
| Free Ridership rate adjusted during ADR Settlement – September 2006. | |

¹ “Resource Savings Values In Selected Residential DSM Prescriptive Programs”, Summit Blue Consulting, June 2008.

²⁸ U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

1.5 GAL/MIN FAUCET AERATOR (Bathroom)

Low Income (Distributed)

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | 6 m ³ |
|---|------------------|
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 2,000 L |
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|---|----------|
| Faucet aerators have an estimated service life of 10 years. ²⁸ | |
| Incremental Cost Customer Install | \$1 |
| Actual cost per unit of product is \$0.49. | |
| Free Ridership | 1 % |
| Free Ridership rate adjusted during ADR Settlement – September 2006. | |

¹ “Resource Savings Values In Selected Residential DSM Prescriptive Programs”, Summit Blue Consulting, June 2008.

²⁸ U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

1.25 GAL/MIN LOW-FLOW SHOWERHEAD

Low Income (Installed per Household)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.25 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas (Updated) | | See Below | | m ³ | |
|--|---|---|--------------------------|----------------------------------|----------------|
| Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | | | | | |
| Participants to be tracked, and gas savings assigned, as per the following table: | | | | | |
| Scenerio | Flow rate range of old showerhead (gal/min) | "From" flow rate (i.e. midpoint of range) (gal/min) | "To" flow rate (gal/min) | Reduction in flow rate (gal/min) | Gas Savings m3 |
| New Showerhead: Scenario 1 | GT 2.5 | 3.00 | 1.25 | 1.75 | 68.0 |
| New Showerhead: Scenario 2 | GT 2.0 to 2.5 | 2.25 | 1.25 | 1.00 | 47.0 |
| New Showerhead: Scenario 3 | EQ 2.0 | 2.00 | 1.25 | 0.75 | 33.0 |

| Electricity | | n/a | | kWh | |
|-------------|--|-----|--|-----|--|
| | | | | | |

| Water (Updated) | | See Below | | L | |
|--|--|-----------|--|---|--|
| Savings recommended by Summit Blue Consulting. Savings assumptions to be used for an interim period until additional load research is completed. | | | | | |
| Participants to be tracked, and water savings assigned, as per the following table: | | | | | |

| Scenerio | Flow rate range of old showerhead (gal/min) | "From" flow rate (i.e. midpoint of range) (gal/min) | "To" flow rate (gal/min) | Reduction in flow rate (gal/min) | Water Savings litres |
|----------------------------|---|---|--------------------------|----------------------------------|----------------------|
| New Showerhead: Scenario 1 | GT 2.5 | 3.00 | 1.25 | 1.75 | 17,500 |
| New Showerhead: Scenario 2 | GT 2.0 to 2.5 | 2.25 | 1.25 | 1.00 | 12,400 |
| New Showerhead: Scenario 3 | EQ 2.0 | 2.00 | 1.25 | 0.75 | 8,900 |

Other Input Assumptions

| | |
|---|-----------------|
| Equipment Life | 10 years |
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Contr. Install) (UG/EGD) | \$15 |
| \$5.00 for product. \$10 for installation. | |
| Free Ridership (UG/EGD) | 1/5 % |
| Free rider rate for low income adjusted to 5% in EB-2001-0021 DSM Generic Issues. | |

¹

"Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

PROGRAMMABLE THERMOSTAT

Low Income

| Efficient Technology & Equipment Description |
|---|
| Programmable thermostat |
| Base Technology & Equipment Description |
| Standard manual thermostat |

Resource Savings Assumptions

| Natural Gas (Updated) | 152 m³ |
|---|--------------------------|
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Electricity (Updated) | 26 kWh |
| Savings adjustment recommended by both Union and Enbridge auditors, during their respective 2007 Audits. ¹ | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|---|-----------------|
| Equipment life recommended by Summit Blue Consulting and incorporated in 2008, on agreement with Union Gas 2007 Evaluation Audit Committee. | |
| Incremental Cost (Contr. Install) (UG/EGD) | \$50 |
| Based on average thermostat cost from Union survey of hardware chains. | |
| Free Ridership | 1 % |
| Free Ridership rate adjusted during ADR Settlement – September 2006 | |

¹

“Resource Savings Values In Selected Residential DSM Prescriptive Programs”, Summit Blue Consulting, June 2008.

WEATHERIZATION

Low Income

Energy audits to identify and implement the most cost-effective energy retrofit to improve building envelope efficiencies.

Resource Savings Assumptions

| | |
|---|----------------------------|
| Natural Gas (Updated) | 1,143 m³ |
| Based on the results from pilot of 61 homes in 2007 | |
| Electricity (Updated) | 165 kWh |
| Based on the results from pilot of 61 homes in 2007 | |
| Water | N/A L |
| | |

Other Input Assumptions

| | |
|--|-----------------|
| Equipment Life (Updated) | 23 years |
| Based on average measure life of measures installed in 61 2007 program participant homes. Measures included attic insulation, wall insulation, door and weather stripping and caulking | |
| Incremental Cost (Contr. Install) (Updated) | \$2,600 |
| Based on average of 2007 actual results of 61 program participants including the cost of the audit | |
| Free Ridership | 0 % |
| As per Generic Proceeding Decision Phase 3 | |

INFRARED HEATERS

Commercial New Building Construction

| Efficient Technology & Equipment Description |
|--|
| Infrared Heater |
| Qualifier/Restriction (UPDATED) |
| OBC 2006 requires infrared heaters for unenclosed spaces excluding loading docks with air curtains. Therefore, the infrared heaters are not applicable to these conditions. (Caneta Research, Inc. August, 2008) |
| Base Technology & Equipment Description |
| Unit Heater |

Resource Savings Assumptions

| Natural Gas | | 0.0102 m ³ / Btu/hr | | | | | | |
|---|--------|--------------------------------|-------------------------|----------|-------|-----------------------|----------|--------------------------|
| The infrared heater gas savings were based on the analysis procedures previously created by Agviro Inc. for Union. The analysis was supplemented by adding a 20% oversizing factor on the equipment in the analysis. A generic rate of savings of 0.0102 m3 / Btu/hr of capacity was determined from this analysis. The single savings number is weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates. | | | | | | | | |
| Electricity (UPDATED) | | 312 kWh | 0-49,999 Btu/hr | | | | | |
| | | 624 kWh | 49,999 – 164,999 Btu/hr | | | | | |
| | | 936 kWh | > 165,000 Btu/hr | | | | | |
| Electricity savings are determined from the difference in electricity consumption of the infrared heater and a comparable unit heater. | | | | | | | | |
| | | Blower Motor | | Infrared | | Operating Hours (hrs) | | Electrical Savings (kWh) |
| Capacity | | hp | kW | hp | kW | Unit Heater | Infrared | |
| less than | 50000 | 0.167 | 0.124 | 0.042 | 0.031 | 2509 | 2133 | 312 |
| less than | 165000 | 0.333 | 0.249 | 0.042 | 0.031 | 2509 | 2133 | 624 |
| greater than | 165000 | 0.500 | 0.373 | 0.042 | 0.031 | 2509 | 2133 | 936 |
| *Electricity savings based on Solaronics models that use a 1/24 hp motor. | | | | | | | | |
| Water | | n/a L | | | | | | |

Other Input Assumptions

| Equipment Life | 20 years |
|--|----------------------------------|
| Infrared Heaters have an estimated service life of 20 years. ¹ | |
| Incremental Cost | \$15.40 / 10 ³ Btu/hr |
| An incremental cost of \$350 was used based on past input assumptions filed by Union. ² | |
| Free Ridership | 33 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ³ | |

¹ “Prescriptive Incentives for Select Natural Gas Technologies”, Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

² EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

³ “Demand Side Management Research to Establish Free Ridership Rates for Infra-Red Tube Heaters among End Users and Channel Partners”, marketPower Research, February 14, 2005.

DEMAND CONTROL KITCHEN VENTILATION (DCKV)

Commercial New Building Construction

| Efficient Technology & Equipment Description |
|--|
| Ventilation with DCKV |
| Qualifier/Restriction |
| None |
| Base Technology & Equipment Description |
| Ventilation without DCKV |

Resource Savings Assumptions

| Natural Gas (UPDATED) | 3,660 m3 | 0 – 4999 CFM |
|---|------------|-----------------|
| | 5,960 m3 | 5000-9999 CFM |
| | 10,910 m3 | 10000-15000 CFM |
| <p>The demand control kitchen ventilation savings were determined using the methodology described in the Detailed Energy Savings Report (www.melinkcorp.com). The savings were generated for three ranges of total range hood exhaust: 0 – 4999 CFM, 5000 – 9999 CFM, and 10,000 – 14,999 CFM. The midpoint of each exhaust range was used to generate the savings (both gas and electrical). The inputs for the savings calculations were supplied by MELINK as typical for each application range.</p> <p>These gas values were modified to take into account OBC-2006: Modified so that 50% of the Makeup Air is conditioned to (i.e., 50% of the exhaust air is offset with unconditioned makeup air) for 5000-9999 CFM and 10000-15000 CFM savings assumptions. The 0-4999 CFM gas savings was unmodified^{4, 5}.</p> | | |
| Electricity (UPDATED) | 7,229 kWh | 0 – 4999 CFM |
| | 22,855 kWh | 5000-9999 CFM |
| | 40,334 kWh | 10000-15000 CFM |
| (see Natural Gas) All capacity categories were modified to reflect the OBC-2006 increase in minimum efficiency of the air conditioning COP from 3.0 to 3.81 (SEER = 13) ⁵ | | |
| Water | n/a L | |

Other Input Assumptions

| Equipment Life | 20 years | |
|--|----------|-----------------|
| DCKV has an estimated service life of 20 years. | | |
| Incremental Cost | \$5,000 | 0 – 4999 CFM |
| | \$10,000 | 5000-9999 CFM |
| | \$15,000 | 10000-15000 CFM |
| Typical costing information was provided by MELINK. | | |
| Free Ridership | 5 % | |
| A free ridership value of 5% will be used until a more definitive value can be determined from evaluation. | | |

⁴ from Ontario Building Code (OBC) 2006 via ASHRAE 90.1-2004 clause 6.5.7.1

⁵ Caneta Research Inc, Quasi-Tool Changes and Commentary, August, 2008

ENERGY RECOVERY VENTILATOR (ERV)

Commercial New Building Construction

| Efficient Technology & Equipment Description | | |
|---|----------------------|-----------------------------|
| Ventilation with ERV | | |
| Qualifier/Restriction (UPDATED) | | |
| <p>1) Restriction for New Building Construction: This measure is not applicable to systems $\geq 5,000$ CFM with $\geq 70\%$ OA ratio because energy recovery is required by OBC 2006</p> <p>2) Restriction for New Building Construction: This measure is not applicable to systems serving health care spaces indicated in Table 1 because heat recovery is required by CSA Z317.2-01</p> | | |
| Table 1 - Health Care Spaces Not Eligible | | |
| Anaesthetic gas scavenging | Cart and can washers | Areas using hazardous gases |
| Animal facilities | Chemical storage | Isolation rooms |
| Autopsy suite | Cooking facilities | Perchloric hoods |
| Biohazard and fume hoods | Ethylene oxide | Radioisotope hoods |
| Base Technology & Equipment Description | | |
| Ventilation without ERV | | |

Resource Savings Assumptions

| Natural Gas | 3.14 m ³ / CFM |
|---|-----------------------------------|
| The ERV and HRV gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity. The operating hours of the equipment are based on typical values for the following commercial market sub-segments: Multi-Family Hotel, Restaurant, Retail, Office, School, Health Care, Nursing Home, and Warehouse. | |
| Building Occupancy | Typical Hrs of Operation per week |
| Multi-Family | 168 |
| Hotel | 168 |
| Restaurant | 108 |
| Retail | 108 |
| Office | 60 |
| School | 84 |
| Health Care | 168 |
| Nursing Home | 168 |
| Warehouse | 168 |
| Retail was used for the claim because it's close to the simple average of occupancy rates above | |
| Electricity | n/a kWh |
| | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | | 15 years |
|--|--|--------------|
| ERVs have an estimated service life of 15 years. ⁶ | | |
| Incremental Cost | | \$2.50 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$2500 / 1000 CFM. ⁶ | | |
| Free Ridership | | 5 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ⁷ | | |

⁶ "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁷ EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

HEAT RECOVERY VENTILATOR (HRV)

Commercial New Building Construction

| Efficient Technology & Equipment Description | | |
|--|----------------------|-----------------------------|
| Ventilation with HRV | | |
| Qualifier / Restriction (UPDATED) | | |
| 1) Restriction for New Building Construction: This measure is not applicable to systems $\geq 5,000$ CFM with $\geq 70\%$ OA ratio because energy recovery is required by OBC 2006 2) Restriction for New Building Construction: This measure is not applicable to systems serving health care spaces indicated in Table 1 because heat recovery is required by CSA Z317.2-01 | | |
| Table 1 - Health Care Spaces Not Eligible | | |
| Anaesthetic gas scavenging | Cart and can washers | Areas using hazardous gases |
| Animal facilities | Chemical storage | Isolation rooms |
| Autopsy suite | Cooking facilities | Perchloric hoods |
| Biohazard and fume hoods | Ethylene oxide | Radioisotope hoods |
| Base Technology & Equipment Description | | |
| Ventilation without HRV | | |

Resource Savings Assumptions

| Natural Gas | | 2.92 m ³ / CFM |
|---|-----------------------------------|---------------------------|
| The ERV and HRV gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity. The operating hours of the equipment are based on typical values for the following commercial market sub-segments: Multi-Family, Hotel, Restaurant, Retail, Office School, Health Care, Nursing Home, and Warehouse. | | |
| Building Occupancy | Typical Hrs of Operation per week | |
| Multi-Family | 168 | |
| Hotel | 168 | |
| Restaurant | 108 | |
| Retail | 108 | |
| Office | 60 | |
| School | 84 | |
| Health Care | 168 | |
| Nursing Home | 168 | |
| Warehouse | 168 | |
| Retail was used for the claim because it's close to the simple average of occupancy rates above. | | |
| Electricity | | n/a kWh |
| | | |
| Water | | n/a L |
| | | |

Other Input Assumptions

| Equipment Life | | 15 years |
|---|--|--------------|
| HRVs have an estimated service life of 15 years. ⁸ | | |
| Incremental Cost | | \$3.40 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$1700 / 500 CFM. ⁶ | | |
| Free Ridership | | 5 % |
| Previous free-Ridership rate as per 2005 ADR Settlement – EB-2005-0211 was 0%. Union will use a value of 5% will be used until a more definitive value can be determined from evaluation. | | |

⁸ "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

CONDENSING BOILERS

Commercial New Building Construction

| Efficient Technology & Equipment Description |
|---|
| Condensing Boiler (88% estimated seasonal efficiency) |
| Base Technology & Equipment Description |
| Non-condensing Boiler (76% estimated seasonal efficiency) |

Resource Savings Assumptions

| Natural Gas | 0.0119 m ³ / Btu/hr |
|--|--------------------------------|
| The natural gas savings are based on the reduction in space heating gas consumption from using a condensing boiler relative to a non-condensing boiler. The principle assumption in the calculation of the savings is that the condensing boiler is properly oversized by 20%. The heating load for the entire heating season can be determined from the installed capacity and boiler seasonal efficiency using degree day analysis. A generic rate of savings of 0.0119 m ³ / Btu/hr of capacity was determined from this analysis. The single savings number is weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates. | |
| Electricity | n/a kWh |
| | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 25 years |
|--|----------------------------------|
| Condensing boilers have an estimated service life of 25 years. ⁹ | |
| Incremental Cost | \$15.40 / 10 ³ Btu/hr |
| A generic incremental cost of \$14,000 per million Btu / hr (adjusted for the US/CDN exchange by a factor of 1.10) was used based on information recently published in the ASHRAE Journal. ¹⁰ | |
| Free Ridership | 5 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ¹¹ | |

⁹ ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3.

¹⁰ "Boiler System Efficiency", Thomas H. Durkin, ASHRAE Journal - July 2006

¹¹ EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

DESTRATIFICATION FAN

Commercial New Building Construction

| Efficient Technology & Equipment Description |
|--|
| Destratification Fan (per fan) |
| Qualifier/Restriction |
| For fans of 20' diameter and larger and in locations that have forced air space heating including unit heaters in warehousing, manufacturing, industrial, and retail buildings with ceiling heights of 25' and higher. |
| Base Technology & Equipment Description |
| Nothing |

Resource Savings Assumptions

| Natural Gas | 6,205 m ³ |
|---|----------------------|
| Based on Caneta's report ¹² , which was based largely on destratification savings methodology published by ASHRAE ¹³ and DOE2.1E building modeling software Weighted average of savings from 20' & 24' diameter fans, based on market share ¹⁴ Weighted average ceiling height of 29 ft based on market share ¹⁵ Average 20 ft heater height from floor ^{16, 17, 18} ; Temp setpoint of 70 degF (estimated) Space heating Gas usage data based on energy intensity for commercial buildings from NRCAN data ¹⁹ . Used a mix of 70% London and 30% North Bay's climate & destratification of 0.625 degF/ft. ²⁰ | |
| Electricity | (511) kWh |
| Based on Caneta's report ¹² and the same input parameters as above. | |
| Water | n/a L |

Other Input Assumptions

| Equipment Life | 15 years |
|---|----------|
| The estimated equipment life for destratification fans is 15 years [SEED Program Guidelines. J-20. December. 2004]. This value is also supported by ASHRAE [ASHRAE Handbook, HVAC Applications SI Edition. Chapter 36 -Table 4. Pg. 36.3. 2007], which lists the service life for propeller fans as 15 years. | |
| Incremental Cost (Cust. / Contr. Install) | \$ 7,021 |
| Weighted average of 20' and 24' diameter fans based on market data ²¹ | |
| Free Ridership | 10 % |
| based on market & total sales data for Ontario ²² and building type data from UG's Customer database | |

¹² "Energy Savings Associated with De-stratification Fans in Buildings with High Ceilings", by Caneta Research Inc., October 2007

¹³ "Saving Heating Costs in Warehouses." Richard Aynsley. ASHRAE Journal. Pg. 46. December 2005

¹⁴ email from EnviraNorth, July 8, 2008, with fan sales data by fan diameter

¹⁵ Weighted average based upon sales data associated with 25 ft to 35 ft ceilings EnviraNorth

¹⁶ 20' (email from Richard Aynsley, Big Ass Fan Company, July 2, 2008, to Pete Koepfgen);

¹⁷ 16-25' depending on age, New Box stores (retail) 30-35', Large high bays with crane are more like 50' (email from Bill Davies, Union Gas, 31 yrs experience, July 3, 2008 to Pete Koepfgen).

¹⁸ between 18' and 30', average is 20' - email from EnviraNorth, July 8, 2008

¹⁹ NRCAN - NEUD - Comprehensive Energy Use data tables - by end use warehouse & transportation average of data between 1990-2005

²⁰ average between 0.5 and 0.75 - "Technology Evaluation of Thermal Destratifiers and other Ventilation Technologies." Joel C. Hughes. Naval Facilities Engineering Service Center. and "Re-circulating Warm Air - Energy Tips from the Experts" ComEd An Exelon Company. 2002

²¹ Targeted Market Study. HVLS fans on Wisconsin Dairy Farms. State of Wisconsin Department of Administration Division of Energy. June 12, 2006., RSMMeans. Mechanical Cost Data - 29th Annual Edition. 2006, and communications with Manufacturers.

²² Email from Joan Wood (EnviraNorth) to Victoria Falvo (UG), May 30, 2008

1.5 GAL/MIN FAUCET AERATOR (Kitchen)

Commercial Building Retrofit (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock |

Resource Savings Assumptions

| Natural Gas (Updated) | 22 m ³ |
|--|-------------------|
| Savings adjustment based on Summit Blue's study, June 2008. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 7,800 L |
| Savings adjustment based on Summit Blue's study, June 2008. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Faucet aerators have an estimated service life of 10 years. ¹ | |
| Incremental Cost (Cust. Install) | \$2 |
| \$2 a product used by Union Gas. | |
| Free Ridership | 10 % |
| Free ridership – EB-2006-0021 Phase II | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

1.5 GAL/MIN FAUCET AERATOR (Bathroom)

Commercial Building Retrofit (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Faucet Aerator |
| Base Technology & Equipment Description |
| Average existing stock |

Resource Savings Assumptions

| Natural Gas (Updated) | 6 m ³ |
|--|------------------|
| Savings adjustment based on Summit Blue's study, June 2008. ¹ | |
| Electricity | n/a kWh |
| | |
| Water (Updated) | 2,000 L |
| Savings adjustment based on Summit Blue's study, June 2008. ¹ | |

Other Input Assumptions

| Equipment Life | 10 years |
|---|----------|
| Faucet aerators have an estimated service life of 10 years. ²⁸ | |
| Incremental Cost (Cust. Install) | \$1 |
| \$1 a product used | |
| Free Ridership (Updated) | 10 % |
| Free ridership – EB-2006-0021 Phase II | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

² "Residential Measure Free Ridership And Inside Spillover Study - Final Report", Summit Blue Consulting, June 2008.

²⁸ U.S. DOE – FEMP, Energy Cost Calculator for Faucets and Showerheads, <http://www.eere.energy.gov/femp>

1.5 GAL/MIN LOW-FLOW SHOWERHEAD

Commercial Building Retrofit (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.5 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas | 22 m ³ |
|---|-------------------|
| Savings recommended by Summit Blue Consulting. ¹ Savings assumptions to be used for an interim period until additional load research is completed. | |
| Electricity | n/a kWh |
| | |
| Water | 6,400 L |
| Savings recommended by Summit Blue Consulting. ¹ Savings assumptions to be used for an interim period until additional load research is completed. | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Cust. Install) | \$4 |
| * Actual cost per unit of product is \$3.85. | |
| Free Ridership | 10 % |
| As per EB-2006-0021 Phase II | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

1.25 GAL/MIN LOW-FLOW SHOWERHEAD

Commercial Building Retrofit (Distribution)

| Efficient Technology & Equipment Description |
|--|
| Low-flow showerhead 1.25 gal/min. |
| Base Technology & Equipment Description |
| Average existing stock. |

Resource Savings Assumptions

| Natural Gas | 40 m ³ |
|---|-------------------|
| Savings recommended by Summit Blue Consulting. ¹ Savings assumptions to be used for an interim period until additional load research is completed. | |
| Electricity | n/a kWh |
| | |
| Water | 10,700 L |
| Savings recommended by Summit Blue Consulting. ¹ Savings assumptions to be used for an interim period until additional load research is completed. | |

Other Input Assumptions

| Equipment Life | 10 years |
|--|----------|
| Low flow showerheads have an estimated service life of 10 years. | |
| Incremental Cost (Cust. Install) | \$4 |
| * Actual cost per unit of product is \$3.39. | |
| Free Ridership | 10 % |
| As per EB-2006-0021 Phase II | |

¹ "Resource Savings Values In Selected Residential DSM Prescriptive Programs", Summit Blue Consulting, June 2008.

PRE-RINSE SPRAY NOZZLE (1.24 GPM)

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Low-flow pre-rinse spray nozzle (1.24 GPM) |
| Base Technology & Equipment Description |
| Standard pre-rinse spray nozzle |

Resource Savings Assumptions

| Natural Gas | 3059 m ³ |
|--|---------------------|
| Natural gas savings claims are based on the reduction of hot water use achieved by switching from a standard flow pre-rinse spray nozzle (3 USGPM) ¹ to a low-flow pre-rinse spray nozzle (1.24 USGPM). Savings are based on the assumption of 3.75 hours of use per day ² , 363 days per year. Savings were determined using the Pre-Rinse Spray Nozzle Savings spreadsheet ³ which provides consistent results with the Food Service Technology Centre's "Pre-Rinse Spray Valve Calculator". ⁴ | |
| Electricity | n/a kWh |
| | |
| Water | 544,145 L |
| Water savings claims ^{5,6} are based on the reduction of water use achieved by switching from a standard flow spray nozzle (3 USGPM) to a low-flow spray nozzle (1.24 USGPM). | |

Other Input Assumptions

| Equipment Life | 5 years |
|---|---------|
| Pre-rinse spray nozzles have an estimated service life of 5 years. ^{2,5} | |
| Incremental Cost (Cust. / Contr. Install) | \$100 |
| The incremental cost is assumed to be \$100 – the cost of the spray nozzle and installation. This is comparable to the incremental cost of \$60 reported by the Region of Waterloo ⁶ | |
| Free Ridership | 5 % |
| A free ridership rate of 5% is based on Enbridge's consultation with distributor. | |

¹ "How to Buy a Low Flow Pre-Rinse Spray Valve", DOE Bulletin WS-5, September 2004.

² Enbridge market survey of average usage

³ Pre-Rinse Spray Nozzle Savings Assumptions rev1.xls, Union Gas

⁴ www.fishnick.com/tools/watercost/

⁵ CEE Commercial Kitchens Initiative - Program Guidance on Pre-Rinse Spray Valves

⁶ "Region of Waterloo – Pre-Rinse Spray Valve Pilot Study – Final Report", Veritec Consulting Inc., January 2005

PROGRAMMABLE THERMOSTAT

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Programmable thermostat |
| Base Technology & Equipment Description |
| Standard manual thermostat |

Resource Savings Assumptions

| Natural Gas (Updated) | 519 m ³ |
|--------------------------------------|--------------------|
| As approved in EB-2006-0021 Phase II | |
| Electricity (Updated) | 921 kWh |
| As approved in EB-2006-0021 Phase II | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|---|----------|
| Equipment life recommended by Summit Blue Consulting and incorporated in 2008, on agreement with Union Gas 2007 Evaluation Audit Committee. | |
| Incremental Cost (Contr. Install) (UG/EGD) | \$50 |
| Based on average thermostat cost from Union survey of hardware chains. | |
| Free Ridership (Updated) | 20 % |
| As approved in EB-2006-0021 Phase II | |

¹ “Resource Savings Values In Selected Residential DSM Prescriptive Programs”, Summit Blue Consulting, June 2008.

² “Residential Measure Free Ridership And Inside Spillover Study - Final Report”, Summit Blue Consulting, June 2008.

HEAT RECOVERY VENTILATOR (HRV)

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Ventilation with HRV |
| Qualifier / Restriction |
| None |
| Base Technology & Equipment Description |
| Ventilation without HRV |

Resource Savings Assumptions

| Natural Gas | 2.92 m ³ / CFM |
|--|-----------------------------------|
| The ERV and HRV gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity. The operating hours of the equipment are based on typical values for the following commercial market sub-segments: Multi-Family, Hotel, Restaurant, Retail, Office, School, Health Care, Nursing Home, and Warehouse. | |
| Building Occupancy | Typical Hrs of Operation per week |
| Multi-Family | 168 |
| Hotel | 168 |
| Restaurant | 108 |
| Retail | 108 |
| Office | 60 |
| School | 84 |
| Health Care | 168 |
| Nursing Home | 168 |
| Warehouse | 168 |
| Retail was used for the claim because it's close to the simple average of occupancy rates above | |
| Electricity | n/a kWh |
| | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|--|--------------|
| HRVs have an estimated service life of 15 years. ⁷ | |
| Incremental Cost | \$3.40 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$1700 / 500 CFM. ⁷ | |
| Free Ridership | 5 % |
| Previous free-Ridership rate as per 2005 ADR Settlement – EB-2005-0211 was 0%. Union will use a value of 5% until a more definitive value can be determined from evaluation. | |

⁷ "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

ENERGY RECOVERY VENTILATOR (ERV)

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Ventilation with ERV |
| Qualifier / Restriction |
| None |
| Base Technology & Equipment Description |
| Ventilation without ERV |

Resource Savings Assumptions

| Natural Gas | 3.14 m ³ / CFM | | | | | | | | | | | | | | | | | | | | |
|---|-----------------------------------|-----------------------------------|--------------|-----|-------|-----|------------|-----|--------|-----|--------|----|--------|----|-------------|-----|--------------|-----|-----------|-----|--|
| The ERV and HRV gas savings are determined from engineering calculations utilizing inputs such as air flow, indoor/outdoor temperatures, indoor/outdoor and relative humidity. The operating hours of the equipment are based on typical values for the following commercial market sub-segments: Multi-Family, Hotel, Restaurant, Retail, Office, School, Health Care, Nursing Home, and Warehouse. | | | | | | | | | | | | | | | | | | | | | |
| <table> <tr> <th>Building Occupancy</th><th>Typical Hrs of Operation per week</th></tr> <tr> <td>Multi-Family</td><td>168</td></tr> <tr> <td>Hotel</td><td>168</td></tr> <tr> <td>Restaurant</td><td>108</td></tr> <tr> <td>Retail</td><td>108</td></tr> <tr> <td>Office</td><td>60</td></tr> <tr> <td>School</td><td>84</td></tr> <tr> <td>Health Care</td><td>168</td></tr> <tr> <td>Nursing Home</td><td>168</td></tr> <tr> <td>Warehouse</td><td>168</td></tr> </table> | Building Occupancy | Typical Hrs of Operation per week | Multi-Family | 168 | Hotel | 168 | Restaurant | 108 | Retail | 108 | Office | 60 | School | 84 | Health Care | 168 | Nursing Home | 168 | Warehouse | 168 | |
| Building Occupancy | Typical Hrs of Operation per week | | | | | | | | | | | | | | | | | | | | |
| Multi-Family | 168 | | | | | | | | | | | | | | | | | | | | |
| Hotel | 168 | | | | | | | | | | | | | | | | | | | | |
| Restaurant | 108 | | | | | | | | | | | | | | | | | | | | |
| Retail | 108 | | | | | | | | | | | | | | | | | | | | |
| Office | 60 | | | | | | | | | | | | | | | | | | | | |
| School | 84 | | | | | | | | | | | | | | | | | | | | |
| Health Care | 168 | | | | | | | | | | | | | | | | | | | | |
| Nursing Home | 168 | | | | | | | | | | | | | | | | | | | | |
| Warehouse | 168 | | | | | | | | | | | | | | | | | | | | |
| Retail was used for the claim because it's close to the simple average of occupancy rates above | | | | | | | | | | | | | | | | | | | | | |
| Electricity | n/a kWh | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| Water | n/a L | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |

Other Input Assumptions

| Equipment Life | 15 years |
|--|--------------|
| ERV's have an estimated service life of 15 years. ⁸ | |
| Incremental Cost | \$2.50 / CFM |
| The incremental costs are based on relative scaling of incremental costs \$2500 / 1000 CFM. ⁷ | |
| Free Ridership | 5 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ⁹ | |

⁸ "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

⁹ EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

CONDENSING BOILERS

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|---|
| Condensing Boiler (88% estimated seasonal efficiency) |
| Base Technology & Equipment Description |
| Non-condensing Boiler (76% estimated seasonal efficiency) |

Resource Savings Assumptions

| Natural Gas | 0.0119 m ³ / Btu/hr |
|--|--------------------------------|
| The natural gas savings are based on the reduction in space heating gas consumption from using a condensing boiler relative to a non-condensing boiler. The principle assumption in the calculation of the savings is that the condensing boiler is properly oversized by 20%. The heating load for the entire heating season can be determined from the installed capacity and boiler seasonal efficiency using degree day analysis. A generic rate of savings of 0.0119 m ³ / Btu/hr of capacity was determined from this analysis. The single savings number is weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates. | |
| Electricity | n/a kWh |
| | |
| Water | n/a L |
| | |

Other Input Assumptions

| Equipment Life | 25 years |
|--|----------------------------------|
| Condensing boilers have an estimated service life of 25 years. ¹⁰ | |
| Incremental Cost | \$15.40 / 10 ³ Btu/hr |
| A generic incremental cost of \$14,000 per million Btu / hr (adjusted for the US/CDN exchange by a factor of 1.10) was used based on information recently published in the ASHRAE Journal. ¹¹ | |
| Free Ridership | 5 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ¹² | |

¹⁰ ASHRAE Applications Handbook – 2003, Chapter 36 – Owning and Operating Costs, Table 3.

¹¹ "Boiler System Efficiency", Thomas H. Durkin, ASHRAE Journal - July 2006

¹² EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

INFRARED HEATERS

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Infrared Heater |
| Qualifier/Restriction |
| None |
| Base Technology & Equipment Description |
| Unit Heater |

Resource Savings Assumptions

| Natural Gas | | 0.0102 m ³ / Btu/hr | | | | | | |
|---|--|--------------------------------|-------------------------|----------|-------|-----------------------|----------|--------------------------|
| The infrared heater gas savings were based on the analysis procedures previously created by Agviro Inc. for Union. The analysis was supplemented by adding a 20% oversizing factor on the equipment in the analysis. A generic rate of savings of 0.0102 m3 / Btu/hr of capacity was determined from this analysis. The single savings number is weighted average of Union Gas South (70%) and Union Gas North (30%) savings estimates. | | | | | | | | |
| Electricity | | 312 kWh | 0-49,999 Btu/hr | | | | | |
| | | 624 kWh | 49,999 – 164,999 Btu/hr | | | | | |
| | | 936 kWh | > 165,000 Btu/hr | | | | | |
| Electricity savings are determined from the difference in electricity consumption of the infrared heater and a comparable unit heater. | | | | | | | | |
| | | Blower Motor | | Infrared | | Operating Hours (hrs) | | Electrical Savings (kWh) |
| Capacity | | hp | kW | hp | kW | Unit Heater | Infrared | |
| less than 50000 | | 0.167 | 0.124 | 0.042 | 0.031 | 2509 | 2133 | 312 |
| less than 165000 | | 0.333 | 0.249 | 0.042 | 0.031 | 2509 | 2133 | 624 |
| greater than 165000 | | 0.500 | 0.373 | 0.042 | 0.031 | 2509 | 2133 | 936 |
| *Electricity savings based on Solaronics models that use a 1/24 hp motor. | | | | | | | | |
| Water | | n/a L | | | | | | |

Other Input Assumptions

| Equipment Life | 20 years |
|---|----------------------------------|
| Infrared Heaters have an estimated service life of 20 years. ¹³ | |
| Incremental Cost | \$15.40 / 10 ³ Btu/hr |
| An incremental cost of \$350 was used based on past input assumptions filed by Union. ¹⁴ | |
| Free Ridership | 33 % |
| Free-ridership rate as per 2005 ADR Settlement – EB-2005-0211. ¹⁵ | |

¹³ "Prescriptive Incentives for Select Natural Gas Technologies", Prepared for Enbridge Consumers Gas and Union Gas Ltd., Prepared by: Jacques Whitford Environment Limited, Agviro Inc., and Engineering Interface Ltd., September 27, 2000.

¹⁴ EB-2005-0211, Union Gas Settlement Agreement, April 7, 2005

¹⁵ "Demand Side Management Research to Establish Free Ridership Rates for Infra-Red Tube Heaters among End Users and Channel Partners", marketPower Research, February 14, 2005.

DEMAND CONTROL KITCHEN VENTILATION (DCKV)

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Ventilation with DCKV |
| Qualification/Restriction |
| None |
| Base Technology & Equipment Description |
| Ventilation without DCKV |

Resource Savings Assumptions

| | | |
|---|-------------------|------------------------|
| Natural Gas | 3,660 m3 | 0 – 4999 CFM |
| | 9,535 m3 | 5000-9999 CFM |
| | 17,455 m3 | 10000-15000 CFM |
| The demand control kitchen ventilation savings were determined using the methodology described in the Detailed Energy Savings Report (www.melinkcorp.com). The savings were generated for three ranges of total range hood exhaust: 0 – 4999 CFM, 5000 – 9999 CFM, and 10,000 – 14,999 CFM. The midpoint of each exhaust range was used to generate the savings (both gas and electrical). The inputs for the savings calculations were supplied by MELINK as typical for each application range. | | |
| Electricity | 7,319 kWh | 0 – 4999 CFM |
| | 23,180 kWh | 5000-9999 CFM |
| | 40,929 kWh | 10000-15000 CFM |
| (see Natural Gas) | | |
| Water | n/a L | |

Other Input Assumptions

| | | |
|--|--------------------|------------------------|
| Equipment Life | 20 years | |
| DCKV has an estimated service life of 20 years. | | |
| Incremental Cost | \$5,000 | 0 – 4999 CFM |
| | \$10,000 | 5000-9999 CFM |
| | \$15,000 | 10000-15000 CFM |
| Typical costing information was provided by MELINK. | | |
| Free Ridership | 5 % | |
| Union will use a free-ridership value of 5% until a more definitive value can be determined from evaluation. | | |

SINGLE AIR DOOR INSTALLATION

Commercial Existing Buildings

| Efficient Technology and Equipment Description | |
|--|--|
| Installing a single air barrier on an exterior entrance door in a retail facility to maintain indoor air temperature | |
| | |
| | |

Resource Savings Assumptions

| Natural Gas | 2,118 m ³ |
|---|----------------------|
| In 2007, Enbridge implemented air door projects at various small commercial sites. Savings for each 2007 project were developed using a savings calculator and the results averaged to result in a prescriptive savings value. The Air Door Calculator was developed by Agviro, an independent engineering consultant. Inputs to the Calculator include: <ul style="list-style-type: none">• Door size and location• Seasonal and daily operating schedules for the opening• Building heating and cooling loads• Heat loss through the opening• ASHRAE values for air curtain effectiveness | |
| Electricity | 172 kWh |
| As above. The Air Door Calculator includes the impact of additional electricity use by the device in calculating net electricity savings. | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|---|----------|
| Developed in conjunction with equipment manufacturers | |
| Incremental Cost (Contractor Installation) | \$1,650 |
| Developed in conjunction with equipment manufacturers | |
| Free Ridership | 5 % |
| As per Generic Proceeding Decision Phase III | |

DOUBLE AIR DOOR INSTALLATION

Commercial Existing Buildings

| Efficient Technology and Equipment Description |
|---|
| Installing a double air barrier on an exterior entrance door in a retail facility to maintain indoor air temperature. |
| |
| |

Resource Savings Assumptions

| Natural Gas | 4,508 m ³ |
|---|----------------------|
| In 2007, Enbridge implemented air door projects at various small commercial sites. Savings for each 2007 project were developed using a savings calculator and the results averaged to result in a prescriptive savings value. The Air Door Calculator was developed by Agviro, an independent engineering consultant. Inputs to the Calculator include: <ul style="list-style-type: none">• Door size and location• Seasonal and daily operating schedules for the opening• Building heating and cooling loads• Heat loss through the opening ASHRAE values for air curtain effectiveness | |
| Electricity | 1,023 kWh |
| As above. The Air Door Calculator includes the impact of additional electricity use by the device in calculating net electricity savings. | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 15 years |
|---|----------|
| Developed in conjunction with equipment manufacturers | |
| Incremental Cost (Contractor Installation) | \$2,500 |
| Developed in conjunction with equipment manufacturers | |
| Free Ridership | 5 % |
| As per Generic Proceeding Decision Phase III | |

DESTRATIFICATION FAN

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Destratification Fan (per fan) |
| Qualifier/Restriction |
| For fans of 20' diameter and larger and in locations that have forced air space heating including unit heaters in warehousing, manufacturing, industrial, and retail buildings with ceiling heights of 25' and higher. |
| Base Technology & Equipment Description |
| Nothing |

Resource Savings Assumptions

| Natural Gas | 6,205 m ³ |
|---|----------------------|
| Based on Caneta's report ¹⁶ , which was based largely on destratification savings methodology published by ASHRAE ¹⁷ and DOE2.1E building modeling software Weighted average of savings from 20' & 24' diameter fans, based on market share ¹⁸ Weighted average ceiling height of 29 ft based on market share ¹⁹ Average 20 ft heater height from floor ^{20, 21, 22} ; Temp setpoint of 70 degF (estimated) Space heating Gas usage data based on energy intensity for commercial buildings from NRCAN data ²³ . Used a mix of 70% London and 30% North Bay's climate & destratification of 0.625 degF/ft. ²⁴ | |
| Electricity | (511) kWh |
| Based on Caneta's report ¹⁶ and the same input parameters as above. | |
| Water | n/a L |

Other Input Assumptions

| Equipment Life | 15 years |
|---|----------|
| The estimated equipment life for destratification fans is 15 years [SEED Program Guidelines. J-20. December. 2004]. This value is also supported by ASHRAE [ASHRAE Handbook, HVAC Applications SI Edition. Chapter 36 -Table 4. Pg. 36.3. 2007], which lists the service life for propeller fans as 15 years. | |
| Incremental Cost (Cust. / Contr. Install) | \$ 7,021 |
| Weighted average of 20' and 24' diameter fans based on market data ¹⁸ and cost data ²⁵ | |
| Free Ridership | 10 % |
| based on market & total sales data for Ontario ²⁶ and building type data from UG's Customer database | |

¹⁶ "Energy Savings Associated with De-stratification Fans in Buildings with High Ceilings", by Caneta Research Inc., October 2007

¹⁷ "Saving Heating Costs in Warehouses." Richard Aynsley. ASHRAE Journal. Pg. 46. December 2005

¹⁸ email from EnviraNorth, July 8, 2008, with fan sales data by fan diameter

¹⁹ Weighted average based upon sales data associated with 25 ft to 35 ft ceilings EnviraNorth

²⁰ 20' (email from Richard Aynsley, Big Ass Fan Company, July 2, 2008, to Pete Koepfgen);

²¹ 16-25' depending on age, New Box stores (retail) 30-35', Large high bays with crane are more like 50' (email from Bill Davies, Union Gas, 31 yrs experience, July 3, 2008 to Pete Koepfgen).

²² between 18' and 30', average is 20' - email from EnviraNorth, July 8, 2008

²³ NRCAN - NEUD - Comprehensive Energy Use data tables - by end use warehouse & transportation average of data between 1990-2005

²⁴ average between 0.5 and 0.75 - "Technology Evaluation of Thermal Destratifiers and other Ventilation Technologies." Joel C. Hughes. Naval Facilities Engineering Service Center. and "Re-circulating Warm Air - Energy Tips from the Experts" ComEd An Exelon Company. 2002

²⁵ Targeted Market Study. HVLS fans on Wisconsin Dairy Farms. State of Wisconsin Department of Administration Division of Energy. June 12, 2006., RSMears. Mechanical Cost Data - 29th Annual Edition. 2006, and communications with Manufacturers.

²⁶ Email from Joan Wood (EnviraNorth) to Victoria Falvo (UG), May 30, 2008

ENERGY EFFICIENT WASHERS

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|---|
| High Efficiency Front Load Washers for application in the Multi-residential sector. |
| Base Technology & Equipment Description |
| Conventional top loading vertical axis washers. |

Resource Savings Assumptions

| Natural Gas | 342 m ³ |
|---|--------------------|
| <p>Source: City of Toronto Pilot Project²⁷ and communication from the Consortium for Energy Efficiency (CEE) re: dryer savings associated with change out to energy efficient washers.</p> <p>The City of Toronto conducted a study at six multi-residential sites to assess the savings from high efficiency front load washers. The sites were chosen to represent a wide range of usage patterns and included 945 suites and 39 clothes washers. Hot and cold water consumption was monitored at each site before and after washer change out and the results used to derive gas savings per washer. Data from CEE showed associated savings for a gas dryer. Savings for gas dryers were prorated to correspond to the market share in the Enbridge franchise (40% gas dryers and 60% electric dryers). Total gas savings are 342m3 per washer per year.</p> | |
| Electricity | 306 kWh |
| <p>Data from CEE showed associated savings for an electric dryer. Savings for electric dryers were prorated to correspond to the market share in the Enbridge franchise (40% gas dryers and 60% electric dryers). Total electric savings are 306kWh per washer per year.</p> | |
| Water | 90,790 L |
| City of Toronto Pilot Project. | |

Other Input Assumptions

| Equipment Life | 10 years |
|---|----------|
| | |
| Incremental Cost (Cust. / Contr. Install) | \$450 |
| | |
| Free Ridership | 10 % |
| | |

²⁷ City of Toronto Works Department and the Toronto Housing Company, Draft Report – Multi Residential High Efficiency Clothes Washer Pilot Project, 2001.

PRESCRIPTIVE SCHOOLS - ELEMENTARY

Commercial Existing Buildings

| Efficient Technology & Equipment Description |
|--|
| Space Heating, Hydronic Boiler with Combustion Efficiency of 83% or higher |
| Base Technology & Equipment Description |
| Space Heating, Hydronic Boiler with Combustion Efficiency of 80% to 82%. |

Resource Savings Assumptions

| Natural Gas | 10,830 m ³ |
|---|-----------------------|
| <p>Source: Elementary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. The AgViro study analyzed the gas usage of 859 elementary schools based on 2006 billing records. The analysis determined:</p> <ul style="list-style-type: none"> • The consumption and size of an average elementary school • The size of boiler required to heat the typical elementary school • The manufacturer's suggested retail price for boilers based on the determined size • The savings of higher efficiency boilers versus a base case of 80 to 82% efficiency • Incremental costs associated with the higher efficiency boiler <p>Based on Enbridge project records the study found that 2 smaller boilers are typically installed (2 X 400 MBH boilers for elementary schools). Also, based on project records, the study found that boiler upgrades will be weighted 89% towards the efficiency range of 85% to 88% and 11% towards boilers with combustion efficiencies ranging from 83% to 84%.</p> <p>Using this data from project records, the resulting analysis provided a weighted average savings of 10,830m³ per elementary school.</p> | |
| Electricity | N/A kWh |
| | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 25 years |
|--|----------|
| As per Enbridge 2007-2009 Multi-year plan | |
| Incremental Cost (Contractor Install) | \$8,646 |
| Source: Elementary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. Incremental costs are based on the weighted average of boiler types as noted above. | |
| Net to Gross | 100 % |
| Source: Custom Projects Attribution Study – Summit Blue Consulting, 2008. | |

PRESCRIPTIVE SCHOOLS - SECONDARY

Commercial Existing Buildings

| Efficient Technology & Equipment Description - |
|--|
| Space Heating, Hydronic Boiler with Combustion Efficiency of 83% or higher |
| Base Technology & Equipment Description |
| Space Heating, Hydronic Boiler with Combustion Efficiency of 80% to 82%. |

Resource Savings Assumptions

| Natural Gas | 43,859 m³ |
|---|-----------------------------|
| <p>Source: Secondary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. The AgViro study analyzed the gas usage of 147 secondary schools based on 2006 billing records. The analysis determined:</p> <ul style="list-style-type: none"> • The consumption and size of an average elementary school • The size of boiler required to heat the typical elementary school • The manufacturer's suggested retail price for boilers based on the determined size • The savings of higher efficiency boilers versus a base case of 80 to 82% efficiency • Incremental costs associated with the higher efficiency boiler <p>Based on Enbridge project records the study found that 2 smaller boilers are typically installed (2 X 1500 MBH boilers for secondary schools). Also, based on project records, the study found that boiler upgrades will be weighted 89% towards the efficiency range of 85% to 88% and 11% towards boilers with combustion efficiencies ranging from 83% to 84%.</p> <p>Using this data from project records, the resulting analysis provided a weighted average savings of 43,859m³ per elementary school.</p> | |
| Electricity | N/A kWh |
| | |
| Water | N/A L |
| | |

Other Input Assumptions

| Equipment Life | 25 years |
|---|-----------------|
| As per Enbridge 2007-2009 Multi-year plan | |
| Incremental Cost (Contractor Install) | \$14,470 |
| Source: Secondary Schools Prescriptive Savings Analysis Report, Agviro Inc., November 23, 2007. Incremental costs are based on the weighted average of boiler types as noted above. | |
| Net to Gross | 100 % |
| Source: Custom Projects Attribution Study –Summit Blue Consulting, 2008. | |

CFL SCREW-IN (13W)

| Efficient Technology & Equipment Description | |
|--|--|
| CFL screw-in 13W | |
| Base Technology & Equipment Description | |
| 60W Incandescent | |

Resource Savings Assumptions

| | |
|---|------------------|
| Natural Gas (Updated) | 0 m ³ |
| | |
| Electricity | 45 kWh |
| Substantiation provided by the OPA, dated September 23, 2008. | |
| Water (Updated) | 0 L |
| | |

Other Input Assumptions

| | |
|---|---------|
| Equipment Life | 8 years |
| Substantiation provided by the OPA, dated September 23, 2008. | |
| Incremental Cost Customer Install | 1.75 \$ |
| <ul style="list-style-type: none"> Average cost of 60 W incandescent bulb = \$0.75 / bulb based on Canadian Tire website (2007). Average cost of 13 W CFL = \$4.75 / bulb based on 2007 EKC distributor sales data and average bulb per coupon <p>8 years x .75 = \$6.00 - \$4.75 = \$1.25</p> <p>\$1.25 + .50 (Contractor Installation) = \$1.75</p> | |
| Free Ridership | 24 % |
| Based on the results of an OPA program evaluation. | |

CFL SCREW-IN (23W)

| Efficient Technology & Equipment Description | |
|--|--|
| CFL screw-in 23W | |
| Base Technology & Equipment Description | |
| 75W Incandescent | |

Resource Savings Assumptions

| | |
|---|------------------|
| Natural Gas (Updated) | 0 m ³ |
| | |
| Electricity | 49.7 kWh |
| Substantiation provided by the OPA, dated October 17, 2008. | |
| Water (Updated) | 0 L |
| | |

Other Input Assumptions

| | |
|---|---------|
| Equipment Life | 8 years |
| Substantiation provided by the OPA, dated October 17, 2008. | |
| Incremental Cost Customer Install | 2.00 \$ |
| <ul style="list-style-type: none"> Average cost of 75 W incandescent bulb = \$0.75 / bulb based on Canadian Tire website (2007). Average cost of 23 W CFL = \$4.50 (OPA, October 9, 2008 data) <p>8 years x .75 = \$6.00 - \$4.50 = \$1.50</p> <p>\$1.50 + .50 (Contractor Installation) = \$2.00</p> | |
| Free Ridership | 24 % |
| Based on the results of an OPA program evaluation. | |